

**NYISO TRANSFER LIMITATIONS**

Sunday ,February 05, 2017 to Tuesday ,August 07, 2018

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**RAMAPO\_\_\_345\_345\_PAR3500**

Fri 06/24/2016 to Thu 06/01/2017

**EXT FORCE by CONED 01/11/2017**

FWD REV

(Import) (Export)

1940 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

**2200 MW 1450 MW**

Impacts Total Transfer Capability 100 MW 0 MW

TTC with All Lines In Service 2300 MW 1450 MW

**PLSNTVLE-DUNWODIE\_345\_W89**

Sun 10/30/2016 to Sat 04/15/2017

**EXT FORCE by CONED 02/01/2017**

FWD

(Import)

0728 Continuous 2359

Work scheduled by: ConEd

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

**HUDSONTP-W49TH\_ST\_345\_Y56**

Thu 11/24/2016 to Mon 05/01/2017

**EXTENDED by PJM 01/27/2017**

FWD

(Import)

1500 Continuous 2359

Work scheduled by: ConEd

SCH - PJM\_HTP

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

**E13THSTA-FARRAGUT\_345\_46**

Tue 12/20/2016 to Mon 04/10/2017

**UPDATED by CONED 01/27/2017**

FWD

(Import)

0001 Continuous 2300

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**W49TH\_ST-E13THSTA\_345\_M55**

Tue 12/20/2016 to Mon 04/10/2017

**UPDATED by CONED 01/27/2017**

FWD

(Import)

0001 Continuous 2300

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**FITZPTRK-EDIC\_\_\_345\_FE-1**

Sat 01/14/2017 to Wed 02/08/2017

**EXTENDED by PA 02/03/2017**

FWD

(Import)

0200 Continuous 0100

Work scheduled by: NYPA

CENTRAL EAST - VC

**2825 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 2975 MW

**FITZPTRK-EDIC\_\_\_345\_FE-1**

Sat 01/14/2017 to Wed 02/08/2017

**EXTENDED by PA 02/03/2017**

FWD

(Import)

0200 Continuous 0100

Work scheduled by: NYPA

OSWEGO EXPORT

**4800 MW**

Impacts Total Transfer Capability 450 MW

TTC with All Lines In Service 5250 MW

**NYISO TRANSFER LIMITATIONS**

Sunday ,February 05, 2017 to Tuesday ,August 07, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-IMO-NYISO\_LIMIT\_1200**

FWD

Thu 01/19/2017 to Tue 02/21/2017 **UPDATED** **by NYPA** **01/13/2017**

(Import)

1900 Continuous 1700

Work scheduled by: NYPA

SCH - OH - NY **1500 MW**  
 Impacts Total Transfer Capability 250 MW  
 TTC with All Lines In Service 1750 MW

**MOSES-ADIRNDCK\_230\_MA2**

FWD

Mon 01/30/2017 to Fri 02/03/2017 **UPDATED** **by NYPA** **10/23/2016**

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**LEEDS-345\_LEEDS SVC**

FWD

Mon 01/30/2017 to Fri 02/24/2017

(Import)

0800 Continuous 1600

Work scheduled by: NGrid

CENTRAL EAST - VC **2950 MW**  
 Impacts Total Transfer Capability 25 MW  
 TTC with All Lines In Service 2975 MW

**CHAT\_DC\_GC1**

FWD

Mon 01/30/2017 to Wed 02/01/2017 **FORCED** **by HQ** **01/31/2017**

(Import)

2002 Continuous 1800

Work scheduled by: HQ

MOSES SOUTH **2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC1**

REV

Mon 01/30/2017 to Wed 02/01/2017 **FORCED** **by HQ** **01/31/2017**

(Export)

2002 Continuous 1800

Work scheduled by: HQ

SCH - HQ - NY **500 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 1000 MW

**BERKSHIR-ALPS-345\_393**

FWD

REV

Thu 02/02/2017 to Thu 02/02/2017 **UPDATED** **by ISONE** **01/31/2017**

(Import) (Export)

0800 Continuous 1700

Work scheduled by: NGrid

**ARR: 78**

SCH - NE - NY **1300 MW** **1300 MW**  
 Impacts Total Transfer Capability 100 MW 300 MW  
 TTC with All Lines In Service 1400 MW 1600 MW

**BERKSHIR-ALPS-345\_393**

FWD

REV

Thu 02/02/2017 to Thu 02/02/2017 **UPDATED** **by ISONE** **01/31/2017**

(Import) (Export)

0800 Continuous 1700

Work scheduled by: NGrid

**ARR: 78**

SCH - NPX\_1385 **100 MW** **100 MW**  
 Impacts Total Transfer Capability 100 MW 100 MW  
 TTC with All Lines In Service 200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,February 05, 2017 to Tuesday ,August 07, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>N.SCTLND-ALPS_____345_2</b>						FWD	REV
Thu 02/02/2017	to	Thu 02/02/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>01/31/2017</u>	(Import)	(Export)
0800	Continuous	1700				<b>900 MW</b>	<b>1600 MW</b>
Work scheduled by: NGrid					SCH - NE - NY	500 MW	0 MW
					Impacts Total Transfer Capability	1400 MW	1600 MW
					TTC with All Lines In Service		
<b>N.SCTLND-ALPS_____345_2</b>						FWD	REV
Thu 02/02/2017	to	Thu 02/02/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>01/31/2017</u>	(Import)	(Export)
0800	Continuous	1700				<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: NGrid					SCH - NPX_1385	100 MW	100 MW
					Impacts Total Transfer Capability	200 MW	200 MW
					TTC with All Lines In Service		
<b>SCH-NYISO-NE_LIMIT_600</b>							REV
Thu 02/02/2017	to	Thu 02/02/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>01/31/2017</u>		(Export)
0800	Continuous	1700					<b>800 MW</b>
Work scheduled by: NGrid					SCH - NE - NY		800 MW
					Impacts Total Transfer Capability		1600 MW
					TTC with All Lines In Service		
<b>MARCY_____765_345_AT2</b>						FWD	
Sat 02/04/2017	to	Sat 02/04/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/01/2017</u>	(Import)	
0500	Continuous	1530				<b>1700 MW</b>	
Work scheduled by: NYPA					MOSES SOUTH	1450 MW	
					Impacts Total Transfer Capability	3150 MW	
					TTC with All Lines In Service		
<b>MOSES____-ADIRNDCK_230_MA2</b>						FWD	
Mon 02/06/2017	to	Fri 02/10/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/23/2016</u>	(Import)	
0700	Continuous	1530				<b>2300 MW</b>	
Work scheduled by: NYPA					MOSES SOUTH	850 MW	
					Impacts Total Transfer Capability	3150 MW	
					TTC with All Lines In Service		
<b>NRTH1385-NOR HBR____138_601</b>						FWD	REV
Mon 02/06/2017	to	Sat 02/25/2017		<u>by LI</u>	<u>01/11/2017</u>	(Import)	(Export)
0700	Continuous	2359				<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: LI					SCH - NPX_1385	100 MW	100 MW
					Impacts Total Transfer Capability	200 MW	200 MW
					TTC with All Lines In Service		
<b>NRTH1385-NOR HBR____138_601 &amp; NRTH1385-NOR HBR____138_602</b>						FWD	REV
Mon 02/06/2017	to	Sat 02/25/2017				(Import)	(Export)
0700		2359				<b>0 MW</b>	<b>0 MW</b>
Work scheduled by:					SCH - NPX_1385	200 MW	200 MW
					Impacts Total Transfer Capability	200 MW	200 MW
					TTC with All Lines In Service		

# NYISO TRANSFER LIMITATIONS

Sunday ,February 05, 2017 to Tuesday ,August 07, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_603

Mon 02/06/2017 to Sat 02/25/2017  
0700 2359

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 0 MW 0 MW  
Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NOR HBR\_\_138\_602

Mon 02/06/2017 to Sat 02/25/2017  
0700 Continuous 2359

Work scheduled by: LI

by LI 01/11/2017

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 100 MW 100 MW  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NOR HBR\_\_138\_602 & NRTH1385-NOR HBR\_\_138\_603

Mon 02/06/2017 to Sat 02/25/2017  
0700 2359

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 0 MW 0 MW  
Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NOR HBR\_\_138\_603

Mon 02/06/2017 to Sat 02/25/2017  
0700 Continuous 2359

Work scheduled by: LI

by LI 01/11/2017

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 100 MW 100 MW  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NRTHPORT\_138\_1385

Mon 02/06/2017 to Sat 02/25/2017  
0700 Continuous 2359

Work scheduled by: LI

by LI 01/11/2017

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 0 MW 0 MW  
Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 200 MW 200 MW

ILCTLIMIT\_MARCY\_SO\_COMP\_I/S

Tue 02/07/2017 to Mon 03/06/2017  
1300 Continuous 0559

Work scheduled by: NYSEG

CANCELLED by NYISO 02/02/2017

FWD  
(Import)  
CENTRAL EAST - VC 2740 MW  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 2975 MW

LEEDS\_\_345\_LEEDS SVC & ILCTLIMIT\_MARCY\_SO\_COMP\_I/S

Wed 02/08/2017 to Fri 02/24/2017  
0200 1600

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC 2715 MW  
Impacts Total Transfer Capability 260 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,February 05, 2017 to Tuesday ,August 07, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**ILCTLIMIT\_MARCY\_SO\_COMP\_I/S**

FWD

Wed 02/08/2017 to Mon 03/06/2017

(Import)

0200 Continuous 0559

CENTRAL EAST - VC

**2740 MW**

Impacts Total Transfer Capability 235 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYISO

---

**CHAT\_DC\_GC1**

FWD

Wed 02/08/2017 to Thu 02/09/2017

(Import)

2000 Continuous 0600

**CANCELLED by HQ 02/01/2017**

MOSES SOUTH

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

---

**CHAT\_DC\_GC1**

REV

Wed 02/08/2017 to Thu 02/09/2017

(Export)

2000 Continuous 0600

**CANCELLED by HQ 02/01/2017**

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

Work scheduled by: HQ

---

**BROWNFLS-TAYLORVL\_115\_4**

FWD

REV

Sat 02/11/2017 to Sat 02/11/2017

(Import) (Export)

0600 Daily 1900

SCH - HQ\_CEDARS

**100 MW 100 MW**

Impacts Total Transfer Capability 99 MW 0 MW

TTC with All Lines In Service 199 MW 100 MW

Work scheduled by: NGrid

**ARR: 38**


---

**BECK\_\_\_\_-NIAGARA\_\_345\_PA302**

FWD

REV

Mon 02/13/2017 to Mon 02/13/2017

(Import) (Export)

0400 Continuous 1700

SCH - OH - NY

**1100 MW 950 MW**

Impacts Total Transfer Capability 650 MW 950 MW

TTC with All Lines In Service 1750 MW 1900 MW

Work scheduled by: IESO

---

**GILBOA\_\_-LEEDS\_\_\_\_345\_GL3**

FWD

Mon 02/13/2017 to Tue 02/14/2017

(Import)

0600 Continuous 1600

CENTRAL EAST - VC

**2200 MW**

Impacts Total Transfer Capability 775 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

---

**LEEDS\_\_\_\_345KV\_R395**

FWD

Mon 02/13/2017 to Tue 02/14/2017

(Import)

0600 Continuous 1600

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: NGrid

# NYISO TRANSFER LIMITATIONS

Sunday ,February 05, 2017 to Tuesday ,August 07, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MAl

Mon 02/13/2017 to Fri 02/17/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2300 MW  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## BROWNFLS-TAYLORVL\_115\_3

Sat 02/18/2017 to Sat 02/18/2017  
0600 Daily 1900

Work scheduled by: NGrid

ARR: 38

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS 100 MW 100 MW  
Impacts Total Transfer Capability 99 MW 0 MW  
TTC with All Lines In Service 199 MW 100 MW

## BECK\_\_\_-NIAGARA\_230\_PA27

Tue 02/21/2017 to Sat 02/25/2017  
0645 Continuous 1700

Work scheduled by: IESO

FWD REV  
(Import) (Export)  
SCH - OH - NY 1750 MW 1900 MW  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 1750 MW 1900 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MAl

Tue 02/21/2017 to Fri 02/24/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2300 MW  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## BROWNFLS-TAYLORVL\_115\_4

Sat 02/25/2017 to Sat 02/25/2017  
0600 Daily 1900

Work scheduled by: NGrid

ARR: 38

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS 100 MW 100 MW  
Impacts Total Transfer Capability 99 MW 0 MW  
TTC with All Lines In Service 199 MW 100 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MAl

Mon 02/27/2017 to Fri 03/03/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2300 MW  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## COOPERS\_-ROCKTVRN\_345\_CCRT-42

Wed 03/01/2017 to Wed 03/15/2017  
0500 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC 2720 MW  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,February 05, 2017 to Tuesday ,August 07, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BECK\_\_\_\_-PACKARD\_\_230\_BP76**

Wed 03/01/2017 to Wed 03/01/2017

0700 Daily(No Weekends) 1700

Work scheduled by: NGrid

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1000 MW</b>	<b>1400 MW</b>
Impacts Total Transfer Capability	750 MW	500 MW
TTC with All Lines In Service	1750 MW	1900 MW

**BROWNFLS-TAYLORVL\_115\_3**

Sat 03/04/2017 to Sat 03/04/2017

0600 Daily 1900

Work scheduled by: NGrid

**ARR: 38**

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	99 MW	0 MW
TTC with All Lines In Service	199 MW	100 MW

**W49TH\_ST\_345KV\_8**

Mon 03/06/2017 to Sat 03/11/2017

0201 Continuous 0200

Work scheduled by: ConEd

**UPDATED by CONED 01/27/2017**

	FWD
	(Import)
SCH - PJM_HTP	<b>315 MW</b>
Impacts Total Transfer Capability	345 MW
TTC with All Lines In Service	660 MW

**EDIC\_\_\_\_-FRASER\_\_345\_EF24-40**

Mon 03/06/2017 to Fri 03/17/2017

0630 Continuous 1700

Work scheduled by: NYPA

**UPDATED by NY 12/02/2016**

	FWD
	(Import)
CENTRAL EAST - VC	<b>2500 MW</b>
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

**MOSES\_\_\_\_-ADIRNDCK\_230\_MA1**

Mon 03/06/2017 to Fri 03/10/2017

0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2300 MW</b>
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

**BROWNFLS-TAYLORVL\_115\_4**

Sat 03/11/2017 to Sat 03/11/2017

0600 Daily 1900

Work scheduled by: NGrid

**ARR: 38**

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	99 MW	0 MW
TTC with All Lines In Service	199 MW	100 MW

**NIAGARA\_-ROCHESTR\_345\_NR2**

Mon 03/13/2017 to Wed 03/15/2017

0500 Continuous 1900

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>1700 MW</b>
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,February 05, 2017 to Tuesday ,August 07, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## BECK\_\_\_\_-NIAGARA\_\_345\_PA302

Mon 03/13/2017 to Fri 03/17/2017  
0700 Continuous 1600

Work scheduled by: IESO

FWD REV  
(Import) (Export)  
SCH - OH - NY 1100 MW 950 MW  
Impacts Total Transfer Capability 650 MW 950 MW  
TTC with All Lines In Service 1750 MW 1900 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 03/13/2017 to Sat 03/18/2017  
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 10/23/2016

FWD  
(Import)  
MOSES SOUTH 2300 MW  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## MILLWOOD\_345KV\_18

Tue 03/14/2017 to Fri 03/17/2017  
0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED 4350 MW  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

## ILCTLIMIT\_MARCY\_SO\_COMP\_I/S

Fri 03/17/2017 to Mon 03/20/2017  
1700 Continuous 0559

Work scheduled by: NYISO

FWD  
(Import)  
CENTRAL EAST - VC 2740 MW  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 2975 MW

## LADENTWN-BUCHAN\_S\_345\_Y88

Sat 03/18/2017 to Mon 03/20/2017  
0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED 4150 MW  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 5100 MW

## NINEMILE-CLAY\_\_\_\_345\_8

Mon 03/20/2017 to Fri 03/24/2017  
0001 Continuous 0400

Work scheduled by: NGrid

UPDATED by NGRID 01/25/2017

FWD  
(Import)  
OSWEGO EXPORT 5150 MW  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 5250 MW

## FRASANNX-COOPERS\_\_345\_UCC2-41

Mon 03/20/2017 to Fri 03/24/2017  
0600 Continuous 1630

Work scheduled by: NYPA

UPDATED by NYISO 10/27/2016

FWD  
(Import)  
CENTRAL EAST - VC 2500 MW  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,February 05, 2017 to Tuesday ,August 07, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MARCY\_\_\_-FRASANNX\_345\_UCC2-41

Mon 03/20/2017 to Fri 03/24/2017 UPDATED by NYISO 10/27/2016

0600 Continuous 1630

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 03/20/2017 to Sat 03/25/2017

0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## BERKSHIR-ALPS\_\_\_345\_393

Fri 03/24/2017 to Fri 03/24/2017 UPDATED by NG 12/27/2016

0800 Daily(No Weekends) 0900

Work scheduled by: NGrid

ARR: 78

FWD REV  
(Import) (Export)  
SCH - NE - NY **1300 MW 1300 MW**  
Impacts Total Transfer Capability 100 MW 300 MW  
TTC with All Lines In Service 1400 MW 1600 MW

## BERKSHIR-ALPS\_\_\_345\_393

Fri 03/24/2017 to Fri 03/24/2017 UPDATED by NG 12/27/2016

0800 Daily(No Weekends) 0900

Work scheduled by: NGrid

ARR: 78

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **100 MW 100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

## BERKSHIR-ALPS\_\_\_345\_393 & BERKSHIR-NORTHFLD\_345\_312

Fri 03/24/2017 to Fri 03/24/2017

0800 0900

Work scheduled by:

ARR: 78

FWD REV  
(Import) (Export)  
SCH - NE - NY **1300 MW 1300 MW**  
Impacts Total Transfer Capability 100 MW 300 MW  
TTC with All Lines In Service 1400 MW 1600 MW

## BERKSHIR-NORTHFLD\_345\_312

Fri 03/24/2017 to Sat 04/22/2017

0800 Continuous 1600

Work scheduled by: ISONE

FWD REV  
(Import) (Export)  
SCH - NE - NY **1400 MW 1450 MW**  
Impacts Total Transfer Capability 0 MW 150 MW  
TTC with All Lines In Service 1400 MW 1600 MW

## BERKSHIR-NORTHFLD\_345\_312

Fri 03/24/2017 to Sat 04/22/2017

0800 Continuous 1600

Work scheduled by: ISONE

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **100 MW 100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,February 05, 2017 to Tuesday ,August 07, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**ILCTLIMIT\_MARCY\_SO\_COMP\_I/S**

FWD

Fri 03/24/2017 to Mon 04/17/2017

(Import)

1700 Continuous 0900

CENTRAL EAST - VC

**2740 MW**

Impacts Total Transfer Capability 235 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYISO

---

**MARCY\_\_\_345KV\_CSC**

FWD

Mon 03/27/2017 to Thu 04/13/2017

(Import)

0500 Continuous 1630

CENTRAL EAST - VC

**2925 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

---

**MARCY\_\_\_345KV\_CSC & ILCTLIMIT\_MARCY\_SO\_COMP\_I/S**

FWD

Mon 03/27/2017 to Thu 04/13/2017

(Import)

0500 1630

CENTRAL EAST - VC

**2690 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 03/27/2017 to Sat 04/01/2017

(Import)

0700 Continuous 1530

**UPDATED by NYPA 10/23/2016**

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

---

**FRASER\_\_\_-GILBOA\_\_\_345\_GF5-35**

FWD

Mon 03/27/2017 to Fri 04/07/2017

(Import)

0900 Continuous 1430

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

---

**LINDN\_CG-LNDVFT\_\_\_345\_V-3022**

FWD

REV

Sun 04/02/2017 to Fri 04/07/2017

(Import) (Export)

1400 Continuous 1800

SCH - PJM\_VFT

**0 MW****0 MW**

Impacts Total Transfer Capability 315 MW

315 MW

TTC with All Lines In Service 315 MW

315 MW

Work scheduled by: PJM

---

**MOSES\_\_\_-ADIRNDCK\_230\_MAI**

FWD

Mon 04/03/2017 to Sat 04/08/2017

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Sunday ,February 05, 2017 to Tuesday ,August 07, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>HOMRC_NY-MAINS_NY_345_47</b>							
Mon 04/03/2017	to	Fri 04/14/2017	<u>UPDATED</u>	<u>by PJM</u>	<u>01/26/2017</u>		
0800	Continuous	1600				SCH - PJ - NY	<b>2300 MW</b>
Work scheduled by: NYSEG						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	2300 MW
<b>MAINESBG-WATRCURE_345_30</b>							
Mon 04/03/2017	to	Fri 04/14/2017	<u>UPDATED</u>	<u>by PJM</u>	<u>01/26/2017</u>		
0800	Continuous	1600				SCH - PJ - NY	<b>2200 MW</b>
Work scheduled by: NYSEG						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	2300 MW
<b>W49TH_ST_345KV_6</b>							
Wed 04/05/2017	to	Sun 04/09/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>01/27/2017</u>		
0001	Continuous	0200				SCH - PJM_HTP	<b>315 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	345 MW
						TTC with All Lines In Service	660 MW
<b>SCH-IMO-NYISO_LIMIT_500</b>							
Fri 04/07/2017	to	Fri 04/07/2017					
0700	Continuous	1530				SCH - OH - NY	<b>800 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	950 MW
						TTC with All Lines In Service	1750 MW
<b>COOPERS_-ROCKTVRN_345_CCRT-42</b>							
Mon 04/10/2017	to	Mon 04/24/2017					
0630	Continuous	1700				CENTRAL EAST - VC	<b>2720 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	255 MW
						TTC with All Lines In Service	2975 MW
<b>MOSES_-ADIRNDCK_230_MAI</b>							
Mon 04/10/2017	to	Thu 04/13/2017					
0700	Continuous	1530				MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
<b>W49TH_ST_345KV_6</b>							
Mon 04/10/2017	to	Mon 04/10/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>01/27/2017</u>		
2230	Continuous	2300				SCH - PJM_HTP	<b>315 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	345 MW
						TTC with All Lines In Service	660 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,February 05, 2017 to Tuesday ,August 07, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHOR_NPX-SHOREHAM_138_CSC						FWD	REV
Mon 04/17/2017	to	Sat 04/22/2017				(Import)	(Export)
0500	Continuous	1600			SCH - NPX_CSC	0 MW	0 MW
Work scheduled by: LI					Impacts Total Transfer Capability	330 MW	330 MW
					TTC with All Lines In Service	330 MW	330 MW
MOSES-ADIRNDCK_230_MAZ						FWD	
Mon 04/17/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/23/2016</u>	(Import)	
0700	Continuous	1530			MOSES SOUTH	2300 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW	
					TTC with All Lines In Service	3150 MW	
FRASER-COOPERS_345_33						FWD	
Mon 04/17/2017	to	Fri 04/21/2017	<u>UPDATED</u>	<u>by NY</u>	<u>01/12/2017</u>	(Import)	
0900	Continuous	1400			CENTRAL EAST - VC	2395 MW	
Work scheduled by: NYSEG					Impacts Total Transfer Capability	580 MW	
					TTC with All Lines In Service	2975 MW	
MARION-FARRAGUT_345_C3403						FWD	REV
Fri 04/21/2017	to	Sat 05/20/2017	<u>UPDATED</u>	<u>by CE</u>	<u>01/28/2017</u>	(Import)	(Export)
0001	Continuous	2359			SCH - PJ - NY	2300 MW	1450 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	0 MW	0 MW
					TTC with All Lines In Service	2300 MW	1450 MW
ILCTLIMIT_MARCY_SO_COMP_I/S						FWD	
Fri 04/21/2017	to	Sat 05/27/2017				(Import)	
1400	Continuous	0459			CENTRAL EAST - VC	2740 MW	
Work scheduled by: NYISO					Impacts Total Transfer Capability	235 MW	
					TTC with All Lines In Service	2975 MW	
BERKSHIR-ALPS_345_393						FWD	REV
Sat 04/22/2017	to	Sat 04/22/2017				(Import)	(Export)
1500	Daily	1600			SCH - NE - NY	1300 MW	1300 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW	300 MW
					TTC with All Lines In Service	1400 MW	1600 MW
BERKSHIR-ALPS_345_393						FWD	REV
Sat 04/22/2017	to	Sat 04/22/2017				(Import)	(Export)
1500	Daily	1600			SCH - NPX_1385	100 MW	100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW	100 MW
					TTC with All Lines In Service	200 MW	200 MW

ARR: 78

ARR: 78

# NYISO TRANSFER LIMITATIONS

Sunday ,February 05, 2017 to Tuesday ,August 07, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS\_\_\_\_\_345\_393 & BERKSHIR-NORTHFLD\_345\_312

Sat 04/22/2017 to Sat 04/22/2017  
1500 1600

Work scheduled by:

ARR: 78

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	1300 MW	1300 MW
Impacts Total Transfer Capability	100 MW	300 MW
TTC with All Lines In Service	1400 MW	1600 MW

CLAY\_\_\_\_\_EDIC\_\_\_\_\_345\_1-16

Mon 04/24/2017 to Tue 04/25/2017  
0630 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
OSWEGO EXPORT	4850 MW
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	5250 MW

STLAWRNC-MOSES\_\_\_\_\_230\_L34P

Mon 04/24/2017 to Fri 04/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1750 MW	1900 MW
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	1750 MW	1900 MW

MOSES\_\_\_\_\_ADIRNDCK\_230\_MA2

Mon 04/24/2017 to Sat 04/29/2017  
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 10/23/2016

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

NEWBRDGE\_345\_138\_BK\_1

Wed 04/26/2017 to Sun 04/30/2017  
0001 Continuous 2359

Work scheduled by: LI

UPDATED by LI 01/31/2017

	FWD
	(Import)
SCH - PJM_NEPTUNE	375 MW
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

NEWBRDGE\_345\_138\_BK\_2

Wed 04/26/2017 to Sun 04/30/2017  
0001 Continuous 2359

Work scheduled by: LI

UPDATED by LI 01/31/2017

	FWD
	(Import)
SCH - PJM_NEPTUNE	375 MW
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Wed 04/26/2017 to Tue 05/16/2017  
0001 Continuous 1800

Work scheduled by: LI

UPDATED by LI 01/31/2017

	FWD
	(Import)
SCH - PJM_NEPTUNE	0 MW
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	660 MW

**NYISO TRANSFER LIMITATIONS**

Sunday ,February 05, 2017 to Tuesday ,August 07, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NEWBRIDGE-DUFFYAVE\_345\_501**

FWD

Wed 04/26/2017 to Tue 05/16/2017

UPDATEDby LI01/31/2017

(Import)

0001 Continuous 1800

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

**NIAGARA -ROCHESTR\_345\_NR2**

FWD

Fri 04/28/2017 to Fri 04/28/2017

(Import)

0700 Continuous 1530

DYSINGER EAST

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**MARCY -N.SCTLND\_345\_18**

FWD

Mon 05/01/2017 to Fri 05/05/2017

(Import)

0600 Continuous 1630

CENTRAL EAST - VC

**2090 MW**

Impacts Total Transfer Capability 885 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 19****MARCY -N.SCTLND\_345\_18 & ILCTLMT MARCY\_SO\_COMP\_I/S**

FWD

Mon 05/01/2017 to Fri 05/05/2017

(Import)

0600 1630

CENTRAL EAST - VC

**1855 MW**

Impacts Total Transfer Capability 1120 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

**ARR: 19****BROWNFLS-TAYLORVL\_115\_3**

FWD

REV

Mon 05/01/2017 to Fri 05/26/2017

(Import) (Export)

0600 Continuous 1900

SCH - HQ\_CEDARS

**70 MW****40 MW**

Impacts Total Transfer Capability 120 MW

0 MW

TTC with All Lines In Service 190 MW

40 MW

Work scheduled by: NGrid

**ARR: 38****ROCHESTR-PANNELL\_345\_RP2**

FWD

Mon 05/01/2017 to Mon 05/01/2017

(Import)

0630 Continuous 0700

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: RGE

**PANNELL -CLAY\_345\_2**

FWD

Mon 05/01/2017 to Fri 05/05/2017

(Import)

0630 Continuous 1530

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Sunday ,February 05, 2017 to Tuesday ,August 07, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**ROCHESTR-PANNELL\_\_345\_RP2**

Fri 05/05/2017 to Fri 05/05/2017  
1500 Continuous 1530  
Work scheduled by: RGE

FWD  
(Import)  
DYSINGER EAST **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

---

**PANNELL\_-CLAY\_\_\_\_345\_2**

Mon 05/08/2017 to Mon 05/08/2017  
0700 Continuous 0730  
Work scheduled by: RGE

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

---

**ROCHESTR-PANNELL\_\_345\_RP2**

Mon 05/08/2017 to Wed 05/10/2017  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

---

**ROSETON\_-ROCKTVRN\_345\_311**

Mon 05/08/2017 to Fri 05/26/2017  
0800 Continuous 1600  
Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 5100 MW

---

**PANNELL\_-CLAY\_\_\_\_345\_2**

Wed 05/10/2017 to Wed 05/10/2017  
1500 Continuous 1530  
Work scheduled by: RGE

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

---

**FRASER\_-GILBOA\_\_\_\_345\_GF5-35**

Mon 05/15/2017 to Fri 05/19/2017  
0630 Continuous 1700  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

---

**FRASER\_\_\_\_345\_FRASER SVC**

Mon 05/15/2017 to Fri 05/19/2017  
0900 Continuous 1430  
Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2935 MW**  
Impacts Total Transfer Capability 40 MW  
TTC with All Lines In Service 2975 MW

---

# NYISO TRANSFER LIMITATIONS

Sunday ,February 05, 2017 to Tuesday ,August 07, 2018

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 5100MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## FRASER\_\_\_345\_FRASER SVC & ILCTLIMIT\_MARCY\_SO\_COMP\_I/S

Mon 05/15/2017 to Fri 05/19/2017  
 0900 1430

Work scheduled by:

FWD  
 (Import)  
 CENTRAL EAST - VC 2700 MW  
 Impacts Total Transfer Capability 275 MW  
 TTC with All Lines In Service 2975 MW

## RAMAPO\_\_\_-LADENTWN\_345\_W72

Tue 05/16/2017 to Tue 05/16/2017  
 0001 Continuous 2330

Work scheduled by: ORU

FWD  
 (Import)  
 UPNY CONED 4400 MW  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 5100 MW

## MARCY\_\_\_765\_345\_AT1

Mon 05/22/2017 to Fri 05/26/2017  
 0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

FWD  
 (Import)  
 MOSES SOUTH 1750 MW  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 3150 MW

## LINDEN\_\_\_-GOETHALS\_230\_A2253

Fri 05/26/2017 to Sat 05/27/2017  
 0001 Continuous 2359

Work scheduled by: PJM

UPDATED by CE 02/01/2017

FWD REV  
 (Import) (Export)  
 SCH - PJ - NY 2050 MW 1300 MW  
 Impacts Total Transfer Capability 0 MW 0 MW  
 TTC with All Lines In Service 2050 MW 1300 MW

## MARCY\_\_\_-N.SCTLND\_345\_18

Sat 05/27/2017 to Sat 05/27/2017  
 0500 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD  
 (Import)  
 CENTRAL EAST - VC 2090 MW  
 Impacts Total Transfer Capability 885 MW  
 TTC with All Lines In Service 2975 MW

## ILCTLIMIT\_MARCY\_SO\_COMP\_I/S

Sat 05/27/2017 to Sat 08/05/2017  
 1600 Continuous 0459

Work scheduled by: NYISO

FWD  
 (Import)  
 CENTRAL EAST - VC 2740 MW  
 Impacts Total Transfer Capability 235 MW  
 TTC with All Lines In Service 2975 MW

## BROWNFLS-TAYLORVL\_115\_4

Tue 05/30/2017 to Sat 06/24/2017  
 0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

FWD REV  
 (Import) (Export)  
 SCH - HQ\_CEDARS 70 MW 40 MW  
 Impacts Total Transfer Capability 120 MW 0 MW  
 TTC with All Lines In Service 190 MW 40 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,February 05, 2017 to Tuesday ,August 07, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BROWNFLS-TAYLORVL_115_3				FWD	REV
				(Import)	(Export)
Mon 06/26/2017	to	Sat 07/01/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			ARR: 38	SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_3				FWD	REV
				(Import)	(Export)
Wed 07/05/2017	to	Sat 07/22/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			ARR: 38	SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_4				FWD	REV
				(Import)	(Export)
Mon 07/24/2017	to	Sat 08/19/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			ARR: 38	SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
MARCY___-N.SCTLND_345_18				FWD	
				(Import)	
Sat 08/05/2017	to	Sat 08/05/2017			
0500	Continuous	1530			
Work scheduled by: NYPA			ARR: 19	CENTRAL EAST - VC	2090 MW
				Impacts Total Transfer Capability	885 MW
				TTC with All Lines In Service	2975 MW
MARCY___765_345_AT2				FWD	
				(Import)	
Sat 08/05/2017	to	Sat 08/05/2017			
0500	Continuous	1530			
Work scheduled by: NYPA			ARR: 19	MOSES SOUTH	1700 MW
				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
ILCTLIMIT_MARCY_SO_COMP_I/S				FWD	
				(Import)	
Sat 08/05/2017	to	Mon 11/06/2017			
1600	Continuous	0559			
Work scheduled by: NYISO				CENTRAL EAST - VC	2740 MW
				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	2975 MW
BROWNFLS-TAYLORVL_115_3				FWD	REV
				(Import)	(Export)
Mon 08/21/2017	to	Fri 09/01/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			ARR: 38	SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,February 05, 2017 to Tuesday ,August 07, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MARCY\_\_\_765\_345\_AT2

Tue 09/05/2017 to Sun 09/10/2017  
0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## BROWNFLS-TAYLORVL\_115\_3

Tue 09/05/2017 to Sat 09/16/2017  
0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **70 MW 40 MW**  
Impacts Total Transfer Capability 120 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

## HURLYAVE-ROSETON\_\_345\_303

Mon 09/11/2017 to Fri 09/29/2017  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 5100 MW

## SPRNBRK\_-DUNWODIE\_345\_W75

Fri 09/15/2017 to Sun 09/17/2017  
2200 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## SPRNBRK\_\_345KV\_RNS3

Fri 09/15/2017 to Sun 09/17/2017  
2200 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## BROWNFLS-TAYLORVL\_115\_4

Mon 09/18/2017 to Fri 10/13/2017  
0600 Continuous 1600

Work scheduled by: NGrid

ARR: 38

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **70 MW 40 MW**  
Impacts Total Transfer Capability 120 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

## GILBOA\_-N.SCTLND\_345\_GNS-1

Mon 09/18/2017 to Fri 10/06/2017  
0630 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2520 MW**  
Impacts Total Transfer Capability 455 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,February 05, 2017 to Tuesday ,August 07, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_\_345\_230\_AT4

Mon 09/18/2017 to Tue 09/19/2017  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1750 MW	1300 MW
Impacts Total Transfer Capability	0 MW	300 MW
TTC with All Lines In Service	1750 MW	1600 MW

## NIAGARA\_-ROCHESTR\_345\_NR2

Mon 09/25/2017 to Fri 09/29/2017  
0700 Continuous 1530

Work scheduled by: NYPA

**CANCELLED by NYPA 02/02/2017**

	FWD
	(Import)
DYSINGER EAST	1700 MW
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

## NIAGARA\_-ROCHESTR\_345\_NR2

Mon 10/02/2017 to Fri 10/06/2017  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	1700 MW
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

## CHATGUAY-MASSENA\_\_765\_7040

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	1550 MW
Impacts Total Transfer Capability	1600 MW
TTC with All Lines In Service	3150 MW

## CHATGUAY-MASSENA\_\_765\_7040

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	0 MW	0 MW
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

## MARCY\_\_765\_345\_AT1

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

	FWD
	(Import)
MOSES SOUTH	1750 MW
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	3150 MW

## MARCY\_\_765\_345\_AT2

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

	FWD
	(Import)
MOSES SOUTH	1700 MW
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,February 05, 2017 to Tuesday ,August 07, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**MASSENA\_-MARCY\_765\_MSU1**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2265 MW**  
Impacts Total Transfer Capability 710 MW  
TTC with All Lines In Service 2975 MW

---

**MASSENA\_-MARCY\_765\_MSU1**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

---

**MASSENA\_-MARCY\_765\_MSU1**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - HQ - NY **475 MW 1000 MW**  
Impacts Total Transfer Capability 1025 MW 0 MW  
TTC with All Lines In Service 1500 MW 1000 MW

---

**MASSENA\_-MARCY\_765\_MSU1 & CHATGUAY-MASSENA\_765\_7040**

Sat 10/14/2017 to Sat 10/28/2017  
0700 1530

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

---

**MASSENA\_-MARCY\_765\_MSU1 & ILCTLIMIT\_MARCY\_SO\_COMP\_I/S**

Sat 10/14/2017 to Sat 10/28/2017  
0700 1530

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **2080 MW**  
Impacts Total Transfer Capability 895 MW  
TTC with All Lines In Service 2975 MW

---

**MOSES\_-MASSENA\_230\_MMS1 & MOSES\_-MASSENA\_230\_MMS2**

Sat 10/14/2017 to Sat 10/28/2017  
0700 1530

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY **850 MW 0 MW**  
Impacts Total Transfer Capability 650 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

---

**LEEDS\_-HURLYAVE\_345\_301**

Mon 10/16/2017 to Fri 11/03/2017  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 5100 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,February 05, 2017 to Tuesday ,August 07, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## BROWNFLS-TAYLORVL\_115\_3

Mon 10/30/2017 to Sat 11/11/2017  
0700 Continuous 1900

UPDATED by NGRID 09/01/2016

Work scheduled by: NGrid

ARR: 38

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD REV  
(Import) (Export)

70 MW 40 MW

120 MW 0 MW

190 MW 40 MW

## FRASANNX-COOPERS\_345\_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017  
0600 Continuous 1700

Work scheduled by: NYPA

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
(Import)

2500 MW

475 MW

2975 MW

## MARCY\_-FRASANNX\_345\_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017  
0600 Continuous 1700

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
(Import)

2500 MW

475 MW

2975 MW

## BROWNFLS-TAYLORVL\_115\_4

Mon 11/13/2017 to Thu 11/30/2017  
0600 Continuous 1900

UPDATED by NGRID 08/25/2016

Work scheduled by: NGrid

ARR: 38

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD REV  
(Import) (Export)

100 MW 100 MW

99 MW 0 MW

199 MW 100 MW

## ILCTLIMIT\_MARCY\_SO\_COMP\_I/S

Fri 11/17/2017 to Sat 02/01/2020  
1700 Continuous 0000

Work scheduled by: NYISO

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
(Import)

2740 MW

235 MW

2975 MW

## MARCY\_765\_345\_AT2

Mon 12/04/2017 to Fri 12/08/2017  
0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
(Import)

1700 MW

1450 MW

3150 MW

## MOSES\_-ADIRNDCK\_230\_MA2

Mon 12/11/2017 to Fri 12/15/2017  
0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
(Import)

2300 MW

850 MW

3150 MW

**NYISO TRANSFER LIMITATIONS**

Sunday ,February 05, 2017 to Tuesday ,August 07, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

FWD

Mon 12/18/2017 to Fri 12/22/2017

UPDATEDby NYPA10/23/2016

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

FWD

Tue 12/26/2017 to Thu 12/28/2017

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA