

# NYISO TRANSFER LIMITATIONS

Wednesday, February 22, 2017 to Friday, August 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event ID	Start Date	End Date	Reason	By	Effective Date	Impact	FWD	REV
RAMAPO___345_345_PAR3500	Fri 06/24/2016	Thu 06/01/2017	EXT FORCE	by CONED	01/11/2017	SCH - PJ - NY	(Import)	(Export)
	1940	Continuous				Impacts Total Transfer Capability	2200 MW	1450 MW
	Work scheduled by: ConEd					TTC with All Lines In Service	2300 MW	1450 MW
PLSNTVLE-DUNWODIE_345_W89	Sun 10/30/2016	Sat 04/15/2017	EXT FORCE	by CONED	02/01/2017	UPNY CONED	(Import)	
	0728	Continuous				Impacts Total Transfer Capability	4000 MW	
	Work scheduled by: ConEd					TTC with All Lines In Service	1100 MW	5100 MW
HUDSONTP-W49TH_ST_345_Y56	Thu 11/24/2016	Mon 05/01/2017	EXTENDED	by PJM	01/27/2017	SCH - PJM_HTP	(Import)	
	1500	Continuous				Impacts Total Transfer Capability	0 MW	
	Work scheduled by: ConEd					TTC with All Lines In Service	660 MW	660 MW
E13THSTA-FARRAGUT_345_46	Tue 12/20/2016	Thu 04/20/2017	UPDATED	by CONED	02/07/2017	SPR/DUN-SOUTH	(Import)	
	0001	Continuous				Impacts Total Transfer Capability	3800 MW	
	Work scheduled by: ConEd					TTC with All Lines In Service	800 MW	4600 MW
W49TH_ST-E13THSTA_345_M55	Tue 12/20/2016	Thu 04/20/2017	UPDATED	by CONED	02/07/2017	SPR/DUN-SOUTH	(Import)	
	0001	Continuous				Impacts Total Transfer Capability	3800 MW	
	Work scheduled by: ConEd					TTC with All Lines In Service	800 MW	4600 MW
SCH-IMO-NYISO_LIMIT_1200	Thu 01/19/2017	Fri 02/17/2017	UPDATED	by NYPA	02/17/2017	SCH - OH - NY	(Import)	
	1900	Continuous				Impacts Total Transfer Capability	1500 MW	
	Work scheduled by: NYPA					TTC with All Lines In Service	250 MW	1750 MW
LEEDS___345_LEEDS SVC	Mon 01/30/2017	Fri 02/24/2017				CENTRAL EAST - VC	(Import)	
	0800	Continuous				Impacts Total Transfer Capability	2950 MW	
	Work scheduled by: NGrid					TTC with All Lines In Service	25 MW	2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 22, 2017 to Friday, August 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
<b>NRTH1385-NOR HBR__138_601</b>					
Mon 02/06/2017	to	Sat 02/25/2017	<u>by LI</u>	<u>01/11/2017</u>	
0700	Continuous	2359	SCH - NPX_1385		
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_601 &amp; NRTH1385-NOR HBR__138_602</b>					
Mon 02/06/2017	to	Sat 02/25/2017			
0700		2359	SCH - NPX_1385		
Work scheduled by:				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_601 &amp; NRTH1385-NOR HBR__138_603</b>					
Mon 02/06/2017	to	Sat 02/25/2017			
0700		2359	SCH - NPX_1385		
Work scheduled by:				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_602</b>					
Mon 02/06/2017	to	Sat 02/25/2017	<u>by LI</u>	<u>01/11/2017</u>	
0700	Continuous	2359	SCH - NPX_1385		
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_602 &amp; NRTH1385-NOR HBR__138_603</b>					
Mon 02/06/2017	to	Sat 02/25/2017			
0700		2359	SCH - NPX_1385		
Work scheduled by:				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_603</b>					
Mon 02/06/2017	to	Sat 02/25/2017	<u>by LI</u>	<u>01/11/2017</u>	
0700	Continuous	2359	SCH - NPX_1385		
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
<b>NRTH1385-NRTHPORT_138_1385</b>					
Mon 02/06/2017	to	Sat 02/25/2017	<u>by LI</u>	<u>01/11/2017</u>	
0700	Continuous	2359	SCH - NPX_1385		
Work scheduled by: LI				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 22, 2017 to Friday, August 24, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MOSES -ADIRNDCK_230_MA1</b>				FWD
Tue 02/14/2017	to	Fri 02/17/2017		(Import)
0700	Continuous	1530		<b>MOSES SOUTH 2300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
<b>GILBOA -LEEDS_345_GL3</b>				FWD
Thu 02/16/2017	to	Fri 02/17/2017	<b><u>EXTENDED</u> by NGRID <u>02/18/2017</u></b>	(Import)
0600	Continuous	1600		<b>CENTRAL EAST - VC 2200 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 775 MW
				TTC with All Lines In Service 2975 MW
<b>LEEDS_345KV_R395</b>				FWD
Thu 02/16/2017	to	Fri 02/17/2017	<b><u>EXTENDED</u> by NGRID <u>02/18/2017</u></b>	(Import)
0600	Continuous	1600		<b>UPNY CONED 3800 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 1300 MW
				TTC with All Lines In Service 5100 MW
<b>W49TH_ST_345KV_6</b>				FWD
Fri 02/17/2017	to	Thu 03/30/2017	<b><u>UPDATED</u> by CONED <u>02/07/2017</u></b>	(Import)
0001	Continuous	0300		<b>SCH - PJM_HTP 315 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 345 MW
				TTC with All Lines In Service 660 MW
<b>BROWNFLS-TAYLORVL_115_3</b>				FWD
Sat 02/18/2017	to	Sat 02/18/2017		(Import) (Export)
0600	Daily	1900		<b>SCH - HQ_CEDARS 100 MW 100 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 99 MW 0 MW
<b>ARR: 38</b>				TTC with All Lines In Service 199 MW 100 MW
<b>FITZPTRK-EDIC_345_FE-1</b>				FWD
Sat 02/18/2017	to	Sat 02/18/2017		(Import)
0700	Daily	1500		<b>CENTRAL EAST - VC 2825 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 150 MW
				TTC with All Lines In Service 2975 MW
<b>FITZPTRK-EDIC_345_FE-1</b>				FWD
Sat 02/18/2017	to	Sat 02/18/2017		(Import)
0700	Daily	1500		<b>OSWEGO EXPORT 4800 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 450 MW
				TTC with All Lines In Service 5250 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 22, 2017 to Friday, August 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>OSWEGO -VOLNEY 345_12</b>				FWD
Tue 02/21/2017 to Tue 02/21/2017				(Import)
0630	Daily(No Weekends)	1630		OSWEGO EXPORT <b>5250 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 0 MW
				TTC with All Lines In Service 5250 MW
<b>BECK -NIAGARA 230_PA27</b>				FWD REV
Tue 02/21/2017 to Sat 02/25/2017				(Import) (Export)
0645	Continuous	1700		SCH - OH - NY <b>1750 MW 1900 MW</b>
Work scheduled by: IESO				Impacts Total Transfer Capability 0 MW 0 MW
				TTC with All Lines In Service 1750 MW 1900 MW
<b>MOSES -ADIRNDCK 230_MA1</b>				FWD
Tue 02/21/2017 to Fri 02/24/2017				(Import)
0700	Continuous	1530		MOSES SOUTH <b>2300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
<b>NINEMILE-CLAY 345_8</b>				FWD
Tue 02/21/2017 to Wed 02/22/2017				(Import)
1231	Continuous	1800		OSWEGO EXPORT <b>5150 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 100 MW
				TTC with All Lines In Service 5250 MW
<b>SCH-IMO-NYISO_LIMIT_900</b>				FWD
Wed 02/22/2017 to Wed 02/22/2017 <b>UPDATED by NYISO 02/17/2017</b>				(Import)
0500	Continuous	1700		SCH - OH - NY <b>1200 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 550 MW
				TTC with All Lines In Service 1750 MW
<b>FITZPTRK-EDIC 345_FE-1</b>				FWD
Fri 02/24/2017 to Fri 02/24/2017 <b>UPDATED by PA 02/22/2017</b>				(Import)
0600	Continuous	1400		CENTRAL EAST - VC <b>2825 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 150 MW
				TTC with All Lines In Service 2975 MW
<b>FITZPTRK-EDIC 345_FE-1</b>				FWD
Fri 02/24/2017 to Fri 02/24/2017 <b>UPDATED by PA 02/22/2017</b>				(Import)
0600	Continuous	1400		OSWEGO EXPORT <b>4800 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 450 MW
				TTC with All Lines In Service 5250 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 22, 2017 to Friday, August 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS\_\_\_345\_LEEDS SVC & ILCTLIMIT\_MARCY\_SO\_COMP\_I/S

Fri 02/24/2017 to Fri 02/24/2017  
1500 to 1600

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **2715 MW**  
Impacts Total Transfer Capability 260 MW  
TTC with All Lines In Service 2975 MW

ILCTLIMIT\_MARCY\_SO\_COMP\_I/S

Fri 02/24/2017 to Mon 03/06/2017  
1500 Continuous to 0559

Work scheduled by: NYISO

FWD  
(Import)  
CENTRAL EAST - VC **2740 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 2975 MW

BROWNFLS-TAYLORVL\_115\_4

Sat 02/25/2017 to Sat 02/25/2017  
0600 Daily to 1900

Work scheduled by: NGrid

ARR: 38

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **100 MW 100 MW**  
Impacts Total Transfer Capability 99 MW 0 MW  
TTC with All Lines In Service 199 MW 100 MW

CHAT\_DC\_GC2

Sat 02/25/2017 to Sat 02/25/2017  
0800 Continuous to 1700

Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

CHAT\_DC\_GC2

Sat 02/25/2017 to Sat 02/25/2017  
0800 Continuous to 1700

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 02/27/2017 to Fri 03/03/2017  
0700 Continuous to 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

LAFAYTTE-CLRKSCRN\_345\_4-46

Tue 02/28/2017 to Tue 02/28/2017  
0700 Daily(No Weekends) 1300

Work scheduled by: NGrid

UPDATED by NGRID 02/10/2017

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 22, 2017 to Friday, August 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE-SHORE_RD_345_Y50</b>					FWD	
Wed 03/01/2017	to	Mon 03/20/2017			(Import)	
0001	Continuous	2359		CONED - LIPA	<b>800 MW</b>	
Work scheduled by: LI					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	1500 MW
<b>SHORE_RD_345_138_BK 1</b>					FWD	
Wed 03/01/2017	to	Mon 03/20/2017			(Import)	
0001	Continuous	2359		CONED - LIPA	<b>1350 MW</b>	
Work scheduled by: LI					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	1500 MW
<b>SHORE_RD_345_138_BK 2</b>					FWD	
Wed 03/01/2017	to	Mon 03/20/2017			(Import)	
0001	Continuous	2359		CONED - LIPA	<b>1350 MW</b>	
Work scheduled by: LI					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	1500 MW
<b>COOPERS_-ROCKTVRN_345_CCRT-42</b>					FWD	
Wed 03/01/2017	to	Fri 03/24/2017			(Import)	
0500	Continuous	1530		CENTRAL EAST - VC	<b>2720 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	255 MW
					TTC with All Lines In Service	2975 MW
<b>CLRKSCRN-OAKDALE__345_36</b>					FWD	
Wed 03/01/2017	to	Wed 03/01/2017			(Import)	
0700	Continuous	1500		CENTRAL EAST - VC	<b>2650 MW</b>	
Work scheduled by: NYSEG					Impacts Total Transfer Capability	325 MW
					TTC with All Lines In Service	2975 MW
<b>BECK_-NIAGARA_345_PA302</b>					FWD	REV
Sat 03/04/2017	to	Sat 03/04/2017	<b>UPDATED</b>	<b>by OH</b>	<b>02/08/2017</b>	(Import) (Export)
0400	Continuous	1700				
Work scheduled by: IESO					SCH - OH - NY	<b>1100 MW 950 MW</b>
					Impacts Total Transfer Capability	650 MW 950 MW
					TTC with All Lines In Service	1750 MW 1900 MW
<b>BROWNEFLS-TAYLORVL_115_3</b>					FWD	REV
Sat 03/04/2017	to	Sat 03/04/2017			(Import) (Export)	
0600	Daily	1900		SCH - HQ_CEDARS	<b>100 MW 100 MW</b>	
Work scheduled by: NGrid					Impacts Total Transfer Capability	99 MW 0 MW
					TTC with All Lines In Service	199 MW 100 MW

ARR: 38

# NYISO TRANSFER LIMITATIONS

Wednesday, February 22, 2017 to Friday, August 24, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>W49TH_ST_345KV_8</b>					FWD
Mon 03/06/2017	to	Mon 03/06/2017			(Import)
0001	Continuous	0030			<b>SCH - PJM_HTP</b> <b>315 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 345 MW
					TTC with All Lines In Service 660 MW
<hr/>					
<b>HUDSONP_-FARRAGUT_345_B3402</b>					FWD
Mon 03/06/2017	to	Thu 04/20/2017	<b>UPDATED</b>	<b>by CONED</b>	REV (Import) (Export)
0001	Continuous	2359		<b>02/17/2017</b>	<b>SCH - PJ - NY</b> <b>2300 MW 1450 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 0 MW 0 MW
					TTC with All Lines In Service 2300 MW 1450 MW
<hr/>					
<b>HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>					FWD
Mon 03/06/2017	to	Thu 04/20/2017			REV (Import) (Export)
0001		2359			<b>SCH - PJ - NY</b> <b>2050 MW 1450 MW</b>
Work scheduled by:					Impacts Total Transfer Capability 250 MW 0 MW
					TTC with All Lines In Service 2300 MW 1450 MW
<hr/>					
<b>MARION_-FARRAGUT_345_C3403</b>					FWD
Mon 03/06/2017	to	Thu 04/20/2017	<b>UPDATED</b>	<b>by CONED</b>	REV (Import) (Export)
0001	Continuous	2359		<b>02/17/2017</b>	<b>SCH - PJ - NY</b> <b>2300 MW 1450 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 0 MW 0 MW
					TTC with All Lines In Service 2300 MW 1450 MW
<hr/>					
<b>SCH-HQ_CEDARS-NYISO_LIMIT_160</b>					FWD
Mon 03/06/2017	to	Fri 03/24/2017	<b>CANCELLED</b>	<b>by HQ</b>	(Import)
0200	Continuous	0400		<b>02/17/2017</b>	<b>SCH - HQ_CEDARS</b> <b>160 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability 39 MW
					TTC with All Lines In Service 199 MW
<hr/>					
<b>EDIC_-FRASER_345_EF24-40</b>					FWD
Mon 03/06/2017	to	Fri 03/17/2017	<b>UPDATED</b>	<b>by NY</b>	(Import)
0630	Continuous	1700		<b>12/02/2016</b>	<b>CENTRAL EAST - VC</b> <b>2500 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 475 MW
					TTC with All Lines In Service 2975 MW
<hr/>					
<b>MOSES_-ADIRNDCK_230_MAL</b>					FWD
Mon 03/06/2017	to	Fri 03/10/2017			(Import)
0700	Continuous	1530			<b>MOSES SOUTH</b> <b>2300 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW
					TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 22, 2017 to Friday, August 24, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_8**

Wed 03/08/2017 to Wed 03/08/2017  
 2130 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **315 MW**  
 Impacts Total Transfer Capability 345 MW  
 TTC with All Lines In Service 660 MW

**BROWNFLS-TAYLORVL\_115\_4**

Sat 03/11/2017 to Sat 03/11/2017  
 0600 Daily 1900  
 Work scheduled by: NGrid

**ARR: 38**

FWD REV  
 (Import) (Export)  
 SCH - HQ\_CEDARS **100 MW 100 MW**  
 Impacts Total Transfer Capability 99 MW 0 MW  
 TTC with All Lines In Service 199 MW 100 MW

**CHAT\_DC\_GC1**

Sun 03/12/2017 to Sun 03/12/2017  
 0001 Continuous 0200  
 Work scheduled by: HQ

**UPDATED by HQ 02/14/2017**

FWD  
 (Import)  
 MOSES SOUTH **2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC1**

Sun 03/12/2017 to Sun 03/12/2017  
 0001 Continuous 0200  
 Work scheduled by: HQ

**UPDATED by HQ 02/14/2017**

REV  
 (Export)  
 SCH - HQ - NY **500 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 1000 MW

**CHAT\_DC\_GC1 & CHAT\_DC\_GC2**

Sun 03/12/2017 to Sun 03/12/2017  
 0001 0200  
 Work scheduled by:

FWD  
 (Import)  
 MOSES SOUTH **2550 MW**  
 Impacts Total Transfer Capability 600 MW  
 TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC1 & CHAT\_DC\_GC2**

Sun 03/12/2017 to Sun 03/12/2017  
 0001 0200  
 Work scheduled by:

FWD REV  
 (Import) (Export)  
 SCH - HQ - NY **1370 MW 0 MW**  
 Impacts Total Transfer Capability 130 MW 1000 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

**CHAT\_DC\_GC2**

Sun 03/12/2017 to Sun 03/12/2017  
 0001 Continuous 0200  
 Work scheduled by: HQ

**UPDATED by HQ 02/14/2017**

FWD  
 (Import)  
 MOSES SOUTH **2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 22, 2017 to Friday, August 24, 2018

Seasonal Limits

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC2</b>						REV
Sun 03/12/2017	to	Sun 03/12/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>02/14/2017</u>	(Export)
0001	Continuous	0200				<b>500 MW</b>
Work scheduled by: HQ						500 MW
						TTC with All Lines In Service 1000 MW
<b>SCH-HQ-NYISO_LIMIT_1100</b>						FWD
Sun 03/12/2017	to	Sun 03/12/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>02/14/2017</u>	(Import)
0001	Continuous	0200				<b>1100 MW</b>
Work scheduled by: HQ						400 MW
						TTC with All Lines In Service 1500 MW
<b>NIAGARA_-ROCHESTR_345_NR2</b>						FWD
Mon 03/13/2017	to	Wed 03/15/2017				(Import)
0500	Continuous	1200				<b>1700 MW</b>
Work scheduled by: NYPA						1450 MW
						TTC with All Lines In Service 3150 MW
<b>BECK_-NIAGARA_345_PA302</b>						FWD REV
Mon 03/13/2017	to	Fri 03/17/2017				(Import) (Export)
0700	Continuous	1600				<b>1100 MW 950 MW</b>
Work scheduled by: IESO						650 MW 950 MW
						TTC with All Lines In Service 1750 MW 1900 MW
<b>MOSES_-ADIRNDCK_230_MA2</b>						FWD
Mon 03/13/2017	to	Sat 03/18/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/23/2016</u>	(Import)
0700	Continuous	1530				<b>2300 MW</b>
Work scheduled by: NYPA						850 MW
						TTC with All Lines In Service 3150 MW
<b>MILLWOOD_345KV_18</b>						FWD
Tue 03/14/2017	to	Fri 03/17/2017				(Import)
0001	Continuous	2359				<b>4350 MW</b>
Work scheduled by: ConEd						750 MW
						TTC with All Lines In Service 5100 MW
<b>ILCTLIMIT_115KV_ALCOA_R8105_TIE_B</b>						FWD
Tue 03/14/2017	to	Tue 03/14/2017				(Import)
0700	Daily(No Weekends)	1600				<b>3100 MW</b>
Work scheduled by: NGrid						50 MW
						TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 22, 2017 to Friday, August 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ILCTLIMIT	Zone	Start	End	Time	Day	Work	SCH	FWD	REV
ILCTLIMIT_115KV_ALCOA_R8105_TIE_B		Tue 03/14/2017	to	Tue 03/14/2017			SCH - HQ_CEDARS	(Import)	(Export)
		0700	Daily(No Weekends)	1600				<b>100 MW</b>	<b>60 MW</b>
		Work scheduled by: NGrid					Impacts Total Transfer Capability	99 MW	40 MW
							TTC with All Lines In Service	199 MW	100 MW
ILCTLIMIT_115KV_ALCOA_R8105_TIE_B		Wed 03/15/2017	to	Wed 03/15/2017			MOSES SOUTH	(Import)	
		0700	Daily(No Weekends)	1600				<b>3100 MW</b>	
		Work scheduled by: NGrid					Impacts Total Transfer Capability	50 MW	
							TTC with All Lines In Service	3150 MW	
ILCTLIMIT_115KV_ALCOA_R8105_TIE_B		Wed 03/15/2017	to	Wed 03/15/2017			SCH - HQ_CEDARS	(Import)	(Export)
		0700	Daily(No Weekends)	1600				<b>100 MW</b>	<b>60 MW</b>
		Work scheduled by: NGrid					Impacts Total Transfer Capability	99 MW	40 MW
							TTC with All Lines In Service	199 MW	100 MW
ILCTLIMIT_MARCY_SO_COMP_I/S		Fri 03/17/2017	to	Mon 03/20/2017			CENTRAL EAST - VC	(Import)	
		1700	Continuous	0459				<b>2740 MW</b>	
		Work scheduled by: NYISO					Impacts Total Transfer Capability	235 MW	
							TTC with All Lines In Service	2975 MW	
LADENTWN-BUCHAN_S_345_Y88		Sat 03/18/2017	to	Mon 03/20/2017			UPNY CONED	(Import)	
		0001	Continuous	2359				<b>4150 MW</b>	
		Work scheduled by: ConEd					Impacts Total Transfer Capability	950 MW	
							TTC with All Lines In Service	5100 MW	
NINEMILE-CLAY_345_8		Mon 03/20/2017	to	Wed 03/22/2017		<b>UPDATED</b>	OSWEGO EXPORT	(Import)	
		0001	Continuous	0400		<b>by NGRID</b>		<b>5150 MW</b>	
		Work scheduled by: NGrid				<b>01/25/2017</b>	Impacts Total Transfer Capability	100 MW	
							TTC with All Lines In Service	5250 MW	
FRASANNX-COOPERS_345_UCC2-41		Mon 03/20/2017	to	Fri 03/24/2017		<b>UPDATED</b>	CENTRAL EAST - VC	(Import)	
		0500	Continuous	1630		<b>by NYISO</b>		<b>2500 MW</b>	
		Work scheduled by: NYPA				<b>10/27/2016</b>	Impacts Total Transfer Capability	475 MW	
							TTC with All Lines In Service	2975 MW	

# NYISO TRANSFER LIMITATIONS

Wednesday, February 22, 2017 to Friday , August 24, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY -FRASANNX_345_UCC2-41</b>					FWD	
Mon 03/20/2017	to	Fri 03/24/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/27/2016</u>	(Import)
0500	Continuous	1630				CENTRAL EAST - VC <b>2500 MW</b>
Work scheduled by: NYPA			<b>ARR: 19</b>			Impacts Total Transfer Capability 475 MW
						TTC with All Lines In Service 2975 MW
<b>MOSES -ADIRNDCK_230_MA2</b>					FWD	
Mon 03/20/2017	to	Sat 03/25/2017				(Import)
0700	Continuous	1530				MOSES SOUTH <b>2300 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 850 MW
						TTC with All Lines In Service 3150 MW
<b>BERKSHIR-ALPS 345_393</b>					FWD	REV
Fri 03/24/2017	to	Fri 03/24/2017	<u>UPDATED</u>	<u>by NG</u>	<u>12/27/2016</u>	(Import) (Export)
0800	Daily(No Weekends)	0900				SCH - NE - NY <b>1300 MW 1300 MW</b>
Work scheduled by: NGrid			<b>ARR: 78</b>			Impacts Total Transfer Capability 100 MW 300 MW
						TTC with All Lines In Service 1400 MW 1600 MW
<b>BERKSHIR-ALPS 345_393</b>					FWD	REV
Fri 03/24/2017	to	Fri 03/24/2017	<u>UPDATED</u>	<u>by NG</u>	<u>12/27/2016</u>	(Import) (Export)
0800	Daily(No Weekends)	0900				SCH - NPX_1385 <b>100 MW 100 MW</b>
Work scheduled by: NGrid			<b>ARR: 78</b>			Impacts Total Transfer Capability 100 MW 100 MW
						TTC with All Lines In Service 200 MW 200 MW
<b>BERKSHIR-ALPS 345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Fri 03/24/2017	to	Fri 03/24/2017				(Import) (Export)
0800		0900				SCH - NE - NY <b>1300 MW 1300 MW</b>
Work scheduled by:			<b>ARR: 78</b>			Impacts Total Transfer Capability 100 MW 300 MW
						TTC with All Lines In Service 1400 MW 1600 MW
<b>BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Fri 03/24/2017	to	Sat 04/22/2017				(Import) (Export)
0800	Continuous	1600				SCH - NE - NY <b>1400 MW 1450 MW</b>
Work scheduled by: ISONE						Impacts Total Transfer Capability 0 MW 150 MW
						TTC with All Lines In Service 1400 MW 1600 MW
<b>BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Fri 03/24/2017	to	Sat 04/22/2017				(Import) (Export)
0800	Continuous	1600				SCH - NPX_1385 <b>100 MW 100 MW</b>
Work scheduled by: ISONE						Impacts Total Transfer Capability 100 MW 100 MW
						TTC with All Lines In Service 200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 22, 2017 to Friday, August 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ILCTLIMIT_MARCY_SO_COMP_I/S				FWD	
Fri 03/24/2017	to	Mon 04/17/2017		(Import)	
1700	Continuous	0900		CENTRAL EAST - VC	<b>2740 MW</b>
Work scheduled by: NYISO				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	2975 MW
<hr/>					
<b>W49TH_ST_345KV_8</b>				FWD	
Sat 03/25/2017	to	Thu 03/30/2017	<u>UPDATED</u> <u>by CONED</u> <u>02/07/2017</u>	(Import)	
0201	Continuous	0200		SCH - PJM_HTP	<b>315 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	345 MW
				TTC with All Lines In Service	660 MW
<hr/>					
<b>MARCY___345KV_CSC</b>				FWD	
Mon 03/27/2017	to	Thu 04/13/2017		(Import)	
0500	Continuous	1630		CENTRAL EAST - VC	<b>2925 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	50 MW
				TTC with All Lines In Service	2975 MW
<hr/>					
<b>MARCY___345KV_CSC &amp; ILCTLIMIT_MARCY_SO_COMP_I/S</b>				FWD	
Mon 03/27/2017	to	Thu 04/13/2017		(Import)	
0500		1630		CENTRAL EAST - VC	<b>2690 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	285 MW
				TTC with All Lines In Service	2975 MW
<hr/>					
<b>MOSES__-ADIRNDCK_230_MA2</b>				FWD	
Mon 03/27/2017	to	Sat 04/01/2017	<u>UPDATED</u> <u>by NYPA</u> <u>10/23/2016</u>	(Import)	
0700	Continuous	1530		MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
<hr/>					
<b>FRASER_-GILBOA___345_GF5-35</b>				FWD	
Mon 03/27/2017	to	Fri 04/07/2017		(Import)	
0900	Continuous	1430		CENTRAL EAST - VC	<b>2650 MW</b>
Work scheduled by: NYSEG				Impacts Total Transfer Capability	325 MW
				TTC with All Lines In Service	2975 MW
<hr/>					
<b>LINDN_CG-LNDVFT___345_V-3022</b>				FWD	REV
Sun 04/02/2017	to	Fri 04/07/2017		(Import)	(Export)
1400	Continuous	1800		SCH - PJM_VFT	<b>0 MW</b> <b>0 MW</b>
Work scheduled by: PJM				Impacts Total Transfer Capability	315 MW 315 MW
				TTC with All Lines In Service	315 MW 315 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 22, 2017 to Friday, August 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MOSES___-ADIRNDCK_230_MAL</b>						FWD	
Mon 04/03/2017	to	Sat 04/08/2017				(Import)	
0700	Continuous	1530			MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
<b>HOMRC_NY-MAINS_NY_345_47</b>						FWD	REV
Mon 04/03/2017	to	Fri 04/14/2017	<u>UPDATED</u>	<u>by PJM</u>	<u>01/26/2017</u>	(Import)	(Export)
0800	Continuous	1600				<b>2300 MW</b>	<b>1450 MW</b>
Work scheduled by: NYSEG						Impacts Total Transfer Capability	0 MW 0 MW
						TTC with All Lines In Service	2300 MW 1450 MW
<b>MAINESBG-WATRCURE_345_30</b>						FWD	REV
Mon 04/03/2017	to	Fri 04/14/2017	<u>UPDATED</u>	<u>by PJM</u>	<u>01/26/2017</u>	(Import)	(Export)
0800	Continuous	1600				<b>2200 MW</b>	<b>1450 MW</b>
Work scheduled by: NYSEG						Impacts Total Transfer Capability	100 MW 0 MW
						TTC with All Lines In Service	2300 MW 1450 MW
<b>W49TH_ST_345KV_6</b>						FWD	
Wed 04/05/2017	to	Sun 04/09/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>02/07/2017</u>	(Import)	
0001	Continuous	0200				<b>315 MW</b>	
Work scheduled by: ConEd						Impacts Total Transfer Capability	345 MW
						TTC with All Lines In Service	660 MW
<b>SCH-IMO-NYISO_LIMIT_500</b>						FWD	
Fri 04/07/2017	to	Fri 04/07/2017				(Import)	
0700	Continuous	1530			SCH - OH - NY	<b>800 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	950 MW
						TTC with All Lines In Service	1750 MW
<b>COOPERS_-ROCKTVRN_345_CCRT-42</b>						FWD	
Mon 04/10/2017	to	Mon 04/24/2017				(Import)	
0630	Continuous	1700			CENTRAL EAST - VC	<b>2720 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	255 MW
						TTC with All Lines In Service	2975 MW
<b>MOSES___-ADIRNDCK_230_MAL</b>						FWD	
Mon 04/10/2017	to	Thu 04/13/2017				(Import)	
0700	Continuous	1530			MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 22, 2017 to Friday, August 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>N. SCTLND-LEEDS</b> ___ 345_93				FWD	
Mon 04/10/2017	to	Mon 04/10/2017		(Import)	
1100	Daily(No Weekends)	1500			
Work scheduled by: NGrid				CENTRAL EAST - VC	<b>2650 MW</b>
				Impacts Total Transfer Capability	325 MW
				TTC with All Lines In Service	2975 MW
<b>LEEDS</b> ___-PLSNTVLY_345_92				FWD	
Tue 04/11/2017	to	Thu 04/13/2017		(Import)	
0730	Continuous	1600			
Work scheduled by: NGrid				UPNY CONED	<b>3800 MW</b>
				Impacts Total Transfer Capability	1300 MW
				TTC with All Lines In Service	5100 MW
<b>SHOR_NPX-SHOREHAM</b> 138_CSC				FWD	REV
Mon 04/17/2017	to	Sat 04/22/2017		(Import)	(Export)
0500	Continuous	1600			
Work scheduled by: LI				SCH - NPX_CSC	<b>0 MW 0 MW</b>
				Impacts Total Transfer Capability	330 MW 330 MW
				TTC with All Lines In Service	330 MW 330 MW
<b>MOSES</b> ___-ADIRNDCK_230_MA2				FWD	
Mon 04/17/2017	to	Sat 04/22/2017	<b>UPDATED by NYPA 10/23/2016</b>	(Import)	
0700	Continuous	1530			
Work scheduled by: NYPA				MOSES SOUTH	<b>2300 MW</b>
				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
<b>FRASER</b> ___-COOPERS_345_33				FWD	
Mon 04/17/2017	to	Fri 04/21/2017	<b>UPDATED by NY 01/12/2017</b>	(Import)	
0900	Continuous	1400			
Work scheduled by: NYSEG				CENTRAL EAST - VC	<b>2395 MW</b>
				Impacts Total Transfer Capability	580 MW
				TTC with All Lines In Service	2975 MW
<b>W49TH_ST</b> 345KV_6				FWD	
Thu 04/20/2017	to	Thu 04/20/2017	<b>UPDATED by CONED 02/07/2017</b>	(Import)	
0230	Continuous	0300			
Work scheduled by: ConEd				SCH - PJM_HTP	<b>315 MW</b>
				Impacts Total Transfer Capability	345 MW
				TTC with All Lines In Service	660 MW
<b>MARION</b> ___-FARRAGUT_345_C3403				FWD	REV
Fri 04/21/2017	to	Sat 05/20/2017	<b>UPDATED by CE 01/28/2017</b>	(Import)	(Export)
0001	Continuous	2359			
Work scheduled by: PJM				SCH - PJ - NY	<b>2300 MW 1450 MW</b>
				Impacts Total Transfer Capability	0 MW 0 MW
				TTC with All Lines In Service	2300 MW 1450 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 22, 2017 to Friday , August 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ILCTLIMIT_MARCY_SO_COMP_I/S			FWD	REV
Fri 04/21/2017	to	Sat 05/27/2017	(Import)	
1400	Continuous	0459	CENTRAL EAST - VC	<b>2740 MW</b>
Work scheduled by: NYISO			Impacts Total Transfer Capability	235 MW
			TTC with All Lines In Service	2975 MW
<b>BERKSHIR-ALPS 345_393</b>			FWD	REV
Sat 04/22/2017	to	Sat 04/22/2017	(Import)	(Export)
1500	Daily	1600	SCH - NE - NY	<b>1300 MW 1300 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	100 MW 300 MW
<b>ARR: 78</b>			TTC with All Lines In Service	1400 MW 1600 MW
<b>BERKSHIR-ALPS 345_393</b>			FWD	REV
Sat 04/22/2017	to	Sat 04/22/2017	(Import)	(Export)
1500	Daily	1600	SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	100 MW 100 MW
<b>ARR: 78</b>			TTC with All Lines In Service	200 MW 200 MW
<b>BERKSHIR-ALPS 345_393 &amp; BERKSHIR-NORTHFLD 345_312</b>			FWD	REV
Sat 04/22/2017	to	Sat 04/22/2017	(Import)	(Export)
1500		1600	SCH - NE - NY	<b>1300 MW 1300 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	100 MW 300 MW
<b>ARR: 78</b>			TTC with All Lines In Service	1400 MW 1600 MW
<b>ROSETON_-EFISHKIL 345_RFK305</b>			FWD	
Mon 04/24/2017	to	Fri 05/05/2017	(Import)	
0001	Continuous	1900	UPNY CONED	<b>4100 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1000 MW
			TTC with All Lines In Service	5100 MW
<b>CLAY_-EDIC 345_1-16</b>			FWD	
Mon 04/24/2017	to	Tue 04/25/2017	(Import)	
0630	Continuous	1530	OSWEGO EXPORT	<b>4850 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	400 MW
			TTC with All Lines In Service	5250 MW
<b>STLAWRNC-MOSES 230_L34P</b>			FWD	REV
Mon 04/24/2017	to	Fri 04/28/2017	(Import)	(Export)
0700	Continuous	1530	SCH - OH - NY	<b>1750 MW 1900 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	0 MW 0 MW
			TTC with All Lines In Service	1750 MW 1900 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 22, 2017 to Friday, August 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event	Start	End	Time	Frequency	Work by	Notes	Zone	FWD (Import)	REV (Export)	
<b>MOSES -ADIRNDCK_230_MA2</b>	Mon 04/24/2017	Sat 04/29/2017	0700	Continuous	1530	<u>UPDATED</u> <u>by NYPA</u> <u>10/23/2016</u>	MOSES SOUTH	2300 MW		
	Work scheduled by: NYPA							Impacts Total Transfer Capability	850 MW	
								TTC with All Lines In Service	3150 MW	
<b>ALCOA -DENNISON_115_12</b>	Wed 04/26/2017	Wed 04/26/2017	0700	Daily(No Weekends)	1800		SCH - HQ_CEDARS	100 MW	100 MW	
	Work scheduled by: NGrid							Impacts Total Transfer Capability	99 MW	0 MW
								TTC with All Lines In Service	199 MW	100 MW
<b>ALCOA -DENNISON_115_12 &amp; ALCOA -NOGDNRBG_115_13</b>	Wed 04/26/2017	Wed 04/26/2017	0700		1800		SCH - HQ_CEDARS	100 MW	60 MW	
	Work scheduled by:							Impacts Total Transfer Capability	99 MW	40 MW
								TTC with All Lines In Service	199 MW	100 MW
<b>ILCTLIMIT_115KV_ALCOA_R8105_TIE_B</b>	Wed 04/26/2017	Wed 04/26/2017	0700	Daily(No Weekends)	1800		MOSES SOUTH	3100 MW		
	Work scheduled by: NGrid							Impacts Total Transfer Capability	50 MW	
								TTC with All Lines In Service	3150 MW	
<b>ILCTLIMIT_115KV_ALCOA_R8105_TIE_B</b>	Wed 04/26/2017	Wed 04/26/2017	0700	Daily(No Weekends)	1800		SCH - HQ_CEDARS	100 MW	60 MW	
	Work scheduled by: NGrid							Impacts Total Transfer Capability	99 MW	40 MW
								TTC with All Lines In Service	199 MW	100 MW
<b>NIAGARA -ROCHESTR_345_NR2</b>	Fri 04/28/2017	Fri 04/28/2017	0700	Continuous	1530		DYSINGER EAST	1700 MW		
	Work scheduled by: NYPA							Impacts Total Transfer Capability	1450 MW	
								TTC with All Lines In Service	3150 MW	
<b>NEPTUNE -DUFFYAVE_345_NEPTUNE</b>	Mon 05/01/2017	Tue 05/16/2017	0400	Continuous	1800	<u>UPDATED</u> <u>by LI</u> <u>02/14/2017</u>	SCH - PJM_NEPTUNE	0 MW		
	Work scheduled by: LI							Impacts Total Transfer Capability	660 MW	
								TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

Wednesday, February 22, 2017 to Friday, August 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD
NEWBRDGE-DUFFYAVE_345_501						(Import)
Mon 05/01/2017	to	Tue 05/16/2017	<u>UPDATED</u>	<u>by LI</u>	<u>02/14/2017</u>	
0400	Continuous	1800				SCH - PJM_NEPTUNE 0 MW
Work scheduled by: LI						Impacts Total Transfer Capability 660 MW TTC with All Lines In Service 660 MW
<hr/>						FWD
MARCY -N.SCTLND_345_18						(Import)
Mon 05/01/2017	to	Fri 05/05/2017				CENTRAL EAST - VC 2090 MW
0600	Continuous	1630				Impacts Total Transfer Capability 885 MW TTC with All Lines In Service 2975 MW
Work scheduled by: NYPA					ARR: 19	
<hr/>						FWD
MARCY -N.SCTLND_345_18 & ILCTLIMIT_MARCY_SO_COMP_I/S						(Import)
Mon 05/01/2017	to	Fri 05/05/2017				CENTRAL EAST - VC 1855 MW
0600		1630				Impacts Total Transfer Capability 1120 MW TTC with All Lines In Service 2975 MW
Work scheduled by:					ARR: 19	
<hr/>						FWD
BROWNFLS-TAYLORVL_115_3						REV
Mon 05/01/2017	to	Fri 05/26/2017				(Import) (Export)
0600	Continuous	1900				SCH - HQ_CEDARS 70 MW 40 MW
Work scheduled by: NGrid					ARR: 38	Impacts Total Transfer Capability 120 MW 0 MW TTC with All Lines In Service 190 MW 40 MW
<hr/>						FWD
ROCHESTR-PANNELL_345_RP2						(Import)
Mon 05/01/2017	to	Mon 05/01/2017				DYSINGER EAST 2300 MW
0630	Continuous	0700				Impacts Total Transfer Capability 850 MW TTC with All Lines In Service 3150 MW
Work scheduled by: RGE						
<hr/>						FWD
PANNELL -CLAY_345_2						(Import)
Mon 05/01/2017	to	Fri 05/05/2017				WEST CENTRAL 1300 MW
0630	Continuous	1530				Impacts Total Transfer Capability 950 MW TTC with All Lines In Service 2250 MW
Work scheduled by: NYPA						
<hr/>						FWD
ROCHESTR-PANNELL_345_RP2						(Import)
Fri 05/05/2017	to	Fri 05/05/2017				DYSINGER EAST 2300 MW
1500	Continuous	1530				Impacts Total Transfer Capability 850 MW TTC with All Lines In Service 3150 MW
Work scheduled by: RGE						

# NYISO TRANSFER LIMITATIONS

Wednesday, February 22, 2017 to Friday, August 24, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PANNELL\_-CLAY\_345\_2**

Mon 05/08/2017 to Mon 05/08/2017  
0700 Continuous 0730

Work scheduled by: RGE

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**ROCHESTR-PANNELL\_345\_RP2**

Mon 05/08/2017 to Wed 05/10/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**ROSETON\_-ROCKTVRN\_345\_311**

Mon 05/08/2017 to Fri 05/26/2017  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 5100 MW

**PANNELL\_-CLAY\_345\_2**

Wed 05/10/2017 to Wed 05/10/2017  
1500 Continuous 1530

Work scheduled by: RGE

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**FRASER\_-GILBOA\_345\_GF5-35**

Mon 05/15/2017 to Fri 05/19/2017  
0630 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

**STONYRDG-HILLSIDE\_230\_72**

Mon 05/15/2017 to Mon 05/15/2017  
0800 Continuous 1700

Work scheduled by: NYSEG

FWD  
(Import)  
DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

**FRASER\_345\_FRASER SVC**

Mon 05/15/2017 to Fri 05/19/2017  
0900 Continuous 1430

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2935 MW**  
Impacts Total Transfer Capability 40 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 22, 2017 to Friday, August 24, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**FRASER\_\_\_345\_FRASER SVC & ILCTLIMIT\_MARCY\_SO\_COMP\_I/S**

Mon 05/15/2017 to Fri 05/19/2017  
 0900 1430

Work scheduled by:

FWD  
 (Import)  
 CENTRAL EAST - VC **2700 MW**  
 Impacts Total Transfer Capability 275 MW  
 TTC with All Lines In Service 2975 MW

-----  
**RAMAPO\_\_-LADENTWN\_345\_W72**

Tue 05/16/2017 to Tue 05/16/2017  
 0001 Continuous 2330

Work scheduled by: ORU

FWD  
 (Import)  
 UPNY CONED **4400 MW**  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 5100 MW

-----  
**MARCY\_\_\_765\_345\_AT1**

Mon 05/22/2017 to Fri 05/26/2017  
 0500 Continuous 1630

Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 MOSES SOUTH **1750 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 3150 MW

-----  
**LINDEN\_\_-GOETHALS\_230\_A2253**

Fri 05/26/2017 to Sat 05/27/2017  
 0001 Continuous 2359

Work scheduled by: PJM

**UPDATED by CE 02/01/2017**

FWD REV  
 (Import) (Export)  
 SCH - PJ - NY **2050 MW 1300 MW**  
 Impacts Total Transfer Capability 0 MW 0 MW  
 TTC with All Lines In Service 2050 MW 1300 MW

-----  
**MARCY\_\_\_-N.SCTLND\_345\_18**

Sat 05/27/2017 to Sat 05/27/2017  
 0500 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2090 MW**  
 Impacts Total Transfer Capability 885 MW  
 TTC with All Lines In Service 2975 MW

-----  
**ILCTLIMIT\_MARCY\_SO\_COMP\_I/S**

Sat 05/27/2017 to Sat 08/05/2017  
 1600 Continuous 0459

Work scheduled by: NYISO

FWD  
 (Import)  
 CENTRAL EAST - VC **2740 MW**  
 Impacts Total Transfer Capability 235 MW  
 TTC with All Lines In Service 2975 MW

-----  
**BROWNEFLS-TAYLORVL\_115\_4**

Tue 05/30/2017 to Sat 06/24/2017  
 0600 Continuous 1900

Work scheduled by: NGrid

**ARR: 38**

FWD REV  
 (Import) (Export)  
 SCH - HQ\_CEDARS **70 MW 40 MW**  
 Impacts Total Transfer Capability 120 MW 0 MW  
 TTC with All Lines In Service 190 MW 40 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 22, 2017 to Friday, August 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work Scheduled	Work Scheduled by	ARR	Impact	Impact	TTC
<b>STONYRDLG-HILLSIDE_230_72</b>					
Mon 06/05/2017 0800 to Mon 06/05/2017 1000	Continuous		FWD (Import)		
Work scheduled by: NYSEG			DYSINGER EAST	2850 MW	
			Impacts Total Transfer Capability	300 MW	
			TTC with All Lines In Service	3150 MW	
<b>STONYRDLG-HILLSIDE_230_72</b>					
Fri 06/09/2017 1500 to Fri 06/09/2017 1700	Continuous		FWD (Import)		
Work scheduled by: NYSEG			DYSINGER EAST	2850 MW	
			Impacts Total Transfer Capability	300 MW	
			TTC with All Lines In Service	3150 MW	
<b>BROWNFLS-TAYLORVL_115_3</b>					
Mon 06/26/2017 0600 to Sat 07/01/2017 1900	Continuous		FWD (Import)	REV (Export)	
Work scheduled by: NGrid		ARR: 38	SCH - HQ_CEDARS	70 MW	40 MW
			Impacts Total Transfer Capability	120 MW	0 MW
			TTC with All Lines In Service	190 MW	40 MW
<b>BROWNFLS-TAYLORVL_115_3</b>					
Wed 07/05/2017 0600 to Sat 07/22/2017 1900	Continuous		FWD (Import)	REV (Export)	
Work scheduled by: NGrid		ARR: 38	SCH - HQ_CEDARS	70 MW	40 MW
			Impacts Total Transfer Capability	120 MW	0 MW
			TTC with All Lines In Service	190 MW	40 MW
<b>BROWNFLS-TAYLORVL_115_4</b>					
Mon 07/24/2017 0600 to Sat 08/19/2017 1900	Continuous		FWD (Import)	REV (Export)	
Work scheduled by: NGrid		ARR: 38	SCH - HQ_CEDARS	70 MW	40 MW
			Impacts Total Transfer Capability	120 MW	0 MW
			TTC with All Lines In Service	190 MW	40 MW
<b>MARCY-N.SCTLND_345_18</b>					
Sat 08/05/2017 0500 to Sat 08/05/2017 1530	Continuous		FWD (Import)		
Work scheduled by: NYPA		ARR: 19	CENTRAL EAST - VC	2090 MW	
			Impacts Total Transfer Capability	885 MW	
			TTC with All Lines In Service	2975 MW	
<b>MARCY-765_345_AT2</b>					
Sat 08/05/2017 0500 to Sat 08/05/2017 1530	Continuous		FWD (Import)		
Work scheduled by: NYPA		ARR: 19	MOSES SOUTH	1700 MW	
			Impacts Total Transfer Capability	1450 MW	
			TTC with All Lines In Service	3150 MW	

# NYISO TRANSFER LIMITATIONS

Wednesday, February 22, 2017 to Friday , August 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ILCTLIMIT_MARCY_SO_COMP_I/S			FWD		
Sat 08/05/2017	to	Mon 11/06/2017	(Import)		
1600	Continuous	0559		CENTRAL EAST - VC	<b>2740 MW</b>
Work scheduled by: NYISO				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	2975 MW
<hr/>					
<b>BROWNFLS-TAYLORVL_115_3</b>			FWD	REV	
Mon 08/21/2017	to	Fri 09/01/2017	(Import)	(Export)	
0600	Continuous	1900		SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
<b>ARR: 38</b>					
<hr/>					
<b>MARCY___765_345_AT2</b>			FWD		
Tue 09/05/2017	to	Sun 09/10/2017	(Import)		
0500	Continuous	1630		MOSES SOUTH	<b>1700 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
<b>ARR: 19</b>					
<hr/>					
<b>BROWNFLS-TAYLORVL_115_3</b>			FWD	REV	
Tue 09/05/2017	to	Sat 09/16/2017	(Import)	(Export)	
0600	Continuous	1900		SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
<b>ARR: 38</b>					
<hr/>					
<b>HURLYAVE-ROSETON__345_303</b>			FWD		
Mon 09/11/2017	to	Fri 09/29/2017	(Import)		
0800	Continuous	1600		UPNY CONED	<b>4100 MW</b>
Work scheduled by: CHGE				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	5100 MW
<hr/>					
<b>SPRNBRK_-DUNWODIE_345_W75</b>			FWD		
Fri 09/15/2017	to	Sun 09/17/2017	(Import)		
2200	Continuous	0200		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
<hr/>					
<b>SPRNBRK__345KV_RNS3</b>			FWD		
Fri 09/15/2017	to	Sun 09/17/2017	(Import)		
2200	Continuous	0200		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 22, 2017 to Friday, August 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BROWNFLS-TAYLORVL\_115\_4**

Mon 09/18/2017 to Fri 10/13/2017  
0600 Continuous 1600

Work scheduled by: NGrid

**ARR: 38**

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

**GILBOA -N.SCTLND\_345\_GNS-1**

Mon 09/18/2017 to Fri 10/06/2017  
0630 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2520 MW</b>
Impacts Total Transfer Capability	455 MW
TTC with All Lines In Service	2975 MW

**NIAGARA\_345\_230\_AT4**

Mon 09/18/2017 to Tue 09/19/2017  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1750 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	0 MW	300 MW
TTC with All Lines In Service	1750 MW	1600 MW

**NIAGARA -ROCHESTR\_345\_NR2**

Mon 10/02/2017 to Fri 10/06/2017  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>1700 MW</b>
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

**CHATGUAY-MASSENA\_765\_7040**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>1550 MW</b>
Impacts Total Transfer Capability	1600 MW
TTC with All Lines In Service	3150 MW

**CHATGUAY-MASSENA\_765\_7040**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

**MARCY\_765\_345\_AT1**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

	FWD
	(Import)
MOSES SOUTH	<b>1750 MW</b>
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 22, 2017 to Friday, August 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_765\_345\_AT2**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**MASSENA\_-MARCY\_\_\_765\_MSU1**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2265 MW**  
Impacts Total Transfer Capability 710 MW  
TTC with All Lines In Service 2975 MW

**MASSENA\_-MARCY\_\_\_765\_MSU1**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

**MASSENA\_-MARCY\_\_\_765\_MSU1**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - HQ - NY **475 MW 1000 MW**  
Impacts Total Transfer Capability 1025 MW 0 MW  
TTC with All Lines In Service 1500 MW 1000 MW

**MASSENA\_-MARCY\_\_\_765\_MSU1 & CHATGUAY-MASSENA\_765\_7040**

Sat 10/14/2017 to Sat 10/28/2017  
0700 1530

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

**MASSENA\_-MARCY\_\_\_765\_MSU1 & ILCTLIMIT\_MARCY\_SO\_COMP\_I/S**

Sat 10/14/2017 to Sat 10/28/2017  
0700 1530

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **2080 MW**  
Impacts Total Transfer Capability 895 MW  
TTC with All Lines In Service 2975 MW

**MOSES\_\_\_-MASSENA\_230\_MMS1 & MOSES\_\_\_-MASSENA\_230\_MMS2**

Sat 10/14/2017 to Sat 10/28/2017  
0700 1530

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY **850 MW 0 MW**  
Impacts Total Transfer Capability 650 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 22, 2017 to Friday , August 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>LEEDS___-HURLYAVE_345_301</b>				FWD	
Mon 10/16/2017	to	Fri 11/03/2017		(Import)	
0800	Continuous	1600	UPNY CONED	<b>4100 MW</b>	
Work scheduled by: CHGE			Impacts Total Transfer Capability	1000 MW	
			TTC with All Lines In Service	5100 MW	
<b>BROWNFLS-TAYLORVL_115_3</b>				FWD	REV
Mon 10/30/2017	to	Sat 11/11/2017	<u>UPDATED</u> <u>by NGRID</u> <u>09/01/2016</u>	(Import)	(Export)
0700	Continuous	1900	SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Work scheduled by: NGrid			ARR: 38	Impacts Total Transfer Capability	120 MW 0 MW
			TTC with All Lines In Service	190 MW	40 MW
<b>FRASANNX-COOPERS__345_UCC2-41</b>				FWD	
Mon 11/06/2017	to	Fri 11/17/2017		(Import)	
0600	Continuous	1700	CENTRAL EAST - VC	<b>2500 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	475 MW	
			TTC with All Lines In Service	2975 MW	
<b>MARCY___-FRASANNX_345_UCC2-41</b>				FWD	
Mon 11/06/2017	to	Fri 11/17/2017		(Import)	
0600	Continuous	1700	CENTRAL EAST - VC	<b>2500 MW</b>	
Work scheduled by: NYPA			ARR: 19	Impacts Total Transfer Capability	475 MW
			TTC with All Lines In Service	2975 MW	
<b>BROWNFLS-TAYLORVL_115_4</b>				FWD	REV
Mon 11/13/2017	to	Thu 11/30/2017	<u>UPDATED</u> <u>by NGRID</u> <u>08/25/2016</u>	(Import)	(Export)
0600	Continuous	1900	SCH - HQ_CEDARS	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: NGrid			ARR: 38	Impacts Total Transfer Capability	99 MW 0 MW
			TTC with All Lines In Service	199 MW	100 MW
<b>ILCTLIMIT_MARCY_SO_COMP_I/S</b>				FWD	
Fri 11/17/2017	to	Sat 02/01/2020		(Import)	
1700	Continuous	0000	CENTRAL EAST - VC	<b>2740 MW</b>	
Work scheduled by: NYISO			Impacts Total Transfer Capability	235 MW	
			TTC with All Lines In Service	2975 MW	
<b>MARCY___765_345_AT2</b>				FWD	
Mon 12/04/2017	to	Fri 12/08/2017		(Import)	
0500	Continuous	1630	MOSES SOUTH	<b>1700 MW</b>	
Work scheduled by: NYPA			ARR: 19	Impacts Total Transfer Capability	1450 MW
			TTC with All Lines In Service	3150 MW	

# NYISO TRANSFER LIMITATIONS

Wednesday, February 22, 2017 to Friday, August 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 12/11/2017 to Fri 12/15/2017  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 12/18/2017 to Fri 12/22/2017 **UPDATED by NYPA 10/23/2016**  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Tue 12/26/2017 to Thu 12/28/2017  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW