

NYISO TRANSFER LIMITATIONS

Thursday ,February 16, 2017 to Saturday ,August 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event ID	Start Date	End Date	Time	Duration	Reason	By	Effective Date	SCH	FWD	REV	
RAMAPO___345_345_PAR3500	Fri 06/24/2016	Thu 06/01/2017	1940	Continuous	2359	<u>EXT FORCE</u>	<u>by CONED</u>	<u>01/11/2017</u>	SCH - PJ - NY	(Import)	(Export)
Work scheduled by: ConEd									2200 MW	1450 MW	
									Impacts Total Transfer Capability	100 MW	0 MW
									TTC with All Lines In Service	2300 MW	1450 MW
PLSNTVLE-DUNWODIE_345_W89	Sun 10/30/2016	Sat 04/15/2017	0728	Continuous	2359	<u>EXT FORCE</u>	<u>by CONED</u>	<u>02/01/2017</u>	UPNY CONED	(Import)	
Work scheduled by: ConEd									4000 MW		
									Impacts Total Transfer Capability	1100 MW	
									TTC with All Lines In Service	5100 MW	
HUDSONTP-W49TH_ST_345_Y56	Thu 11/24/2016	Mon 05/01/2017	1500	Continuous	2359	<u>EXTENDED</u>	<u>by PJM</u>	<u>01/27/2017</u>	SCH - PJM_HTP	(Import)	
Work scheduled by: ConEd									0 MW		
									Impacts Total Transfer Capability	660 MW	
									TTC with All Lines In Service	660 MW	
E13THSTA-FARRAGUT_345_46	Tue 12/20/2016	Thu 04/20/2017	0001	Continuous	0300	<u>UPDATED</u>	<u>by CONED</u>	<u>02/07/2017</u>	SPR/DUN-SOUTH	(Import)	
Work scheduled by: ConEd									3800 MW		
									Impacts Total Transfer Capability	800 MW	
									TTC with All Lines In Service	4600 MW	
W49TH_ST-E13THSTA_345_M55	Tue 12/20/2016	Thu 04/20/2017	0001	Continuous	0300	<u>UPDATED</u>	<u>by CONED</u>	<u>02/07/2017</u>	SPR/DUN-SOUTH	(Import)	
Work scheduled by: ConEd									3800 MW		
									Impacts Total Transfer Capability	800 MW	
									TTC with All Lines In Service	4600 MW	
SCH-IMO-NYISO_LIMIT_1200	Thu 01/19/2017	Tue 02/21/2017	1900	Continuous	1700	<u>UPDATED</u>	<u>by NYPA</u>	<u>01/13/2017</u>	SCH - OH - NY	(Import)	
Work scheduled by: NYPA									1500 MW		
									Impacts Total Transfer Capability	250 MW	
									TTC with All Lines In Service	1750 MW	
LEEDS___345_LEEDS SVC	Mon 01/30/2017	Fri 02/24/2017	0800	Continuous	1600				CENTRAL EAST - VC	(Import)	
Work scheduled by: NGrid									2950 MW		
									Impacts Total Transfer Capability	25 MW	
									TTC with All Lines In Service	2975 MW	

NYISO TRANSFER LIMITATIONS

Thursday ,February 16, 2017 to Saturday ,August 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
NRTH1385-NOR HBR__138_601					
Mon 02/06/2017	to	Sat 02/25/2017	<u>by LI</u>	<u>01/11/2017</u>	
0700	Continuous	2359			
Work scheduled by: LI				SCH - NPX_1385	100 MW
				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602					
Mon 02/06/2017	to	Sat 02/25/2017			
0700		2359			
Work scheduled by:				SCH - NPX_1385	0 MW
				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603					
Mon 02/06/2017	to	Sat 02/25/2017			
0700		2359			
Work scheduled by:				SCH - NPX_1385	0 MW
				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_602					
Mon 02/06/2017	to	Sat 02/25/2017	<u>by LI</u>	<u>01/11/2017</u>	
0700	Continuous	2359			
Work scheduled by: LI				SCH - NPX_1385	100 MW
				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603					
Mon 02/06/2017	to	Sat 02/25/2017			
0700		2359			
Work scheduled by:				SCH - NPX_1385	0 MW
				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_603					
Mon 02/06/2017	to	Sat 02/25/2017	<u>by LI</u>	<u>01/11/2017</u>	
0700	Continuous	2359			
Work scheduled by: LI				SCH - NPX_1385	100 MW
				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NRTHPORT_138_1385					
Mon 02/06/2017	to	Sat 02/25/2017	<u>by LI</u>	<u>01/11/2017</u>	
0700	Continuous	2359			
Work scheduled by: LI				SCH - NPX_1385	0 MW
				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW

NYISO TRANSFER LIMITATIONS

Thursday ,February 16, 2017 to Saturday ,August 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
BROWNFLS-TAYLORVL_115_4					
Sat 02/11/2017	to	Sat 02/11/2017			
0600	Daily	1900			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	100 MW
				Impacts Total Transfer Capability	99 MW
				TTC with All Lines In Service	199 MW
					100 MW
VOLNEY -MARCY 345_19				FWD	
Mon 02/13/2017	to	Mon 02/13/2017	CANCELLED by NGrid 02/13/2017	(Import)	
0700	Daily	(No Weekends) 1630			
Work scheduled by: NGrid			ARR: 19		
				CENTRAL EAST - VC	2825 MW
				Impacts Total Transfer Capability	150 MW
				TTC with All Lines In Service	2975 MW
VOLNEY -MARCY 345_19				FWD	
Mon 02/13/2017	to	Mon 02/13/2017	CANCELLED by NGrid 02/13/2017	(Import)	
0700	Daily	(No Weekends) 1630			
Work scheduled by: NGrid			ARR: 19		
				OSWEGO EXPORT	4900 MW
				Impacts Total Transfer Capability	350 MW
				TTC with All Lines In Service	5250 MW
MOSES -ADIRNDCK_230_MA1				FWD	
Tue 02/14/2017	to	Fri 02/17/2017		(Import)	
0700	Continuous	1530			
Work scheduled by: NYPA					
				MOSES SOUTH	2300 MW
				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
SCH-IMO-NYISO_LIMIT_1000				FWD	
Tue 02/14/2017	to	Fri 02/17/2017	CANCELLED by PJM 02/14/2017	(Import)	
0800	Continuous	1600			
Work scheduled by: PJM					
				SCH - OH - NY	1300 MW
				Impacts Total Transfer Capability	450 MW
				TTC with All Lines In Service	1750 MW
SCH-NYISO-PJM_LIMIT_100					REV
Tue 02/14/2017	to	Fri 02/17/2017	CANCELLED by PJM 02/14/2017		(Export)
0800	Continuous	1600			
Work scheduled by: PJM					
				SCH - PJ - NY	400 MW
				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	1450 MW
VOLNEY -MARCY 345_19				FWD	
Wed 02/15/2017	to	Wed 02/15/2017		(Import)	
0630	Daily	(No Weekends) 1459			
Work scheduled by: NGrid			ARR: 19		
				CENTRAL EAST - VC	2825 MW
				Impacts Total Transfer Capability	150 MW
				TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Thursday ,February 16, 2017 to Saturday ,August 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>VOLNEY -MARCY 345_19</p> <p>Wed 02/15/2017 to Wed 02/15/2017 0630 Daily(No Weekends) 1459</p> <p>Work scheduled by: NGrid</p>	<p>ARR: 19</p>	<p>FWD (Import)</p> <p>OSWEGO EXPORT 4900 MW</p> <p>Impacts Total Transfer Capability 350 MW</p> <p>TTC with All Lines In Service 5250 MW</p>
<p>BULYMO -BOONVILLE 115_6</p> <p>Wed 02/15/2017 to Wed 02/15/2017 1300 Daily(No Weekends) 1530</p> <p>Work scheduled by: NGrid</p>	<p>ARR: 38</p>	<p>FWD REV (Import) (Export)</p> <p>SCH - HQ_CEDARS 199 MW 100 MW</p> <p>Impacts Total Transfer Capability 0 MW 0 MW</p> <p>TTC with All Lines In Service 199 MW 100 MW</p>
<p>TAYLORVL-BULYMO 115_6</p> <p>Wed 02/15/2017 to Wed 02/15/2017 1300 Daily(No Weekends) 1530</p> <p>Work scheduled by: NGrid</p>	<p>ARR: 38</p>	<p>FWD REV (Import) (Export)</p> <p>SCH - HQ_CEDARS 199 MW 100 MW</p> <p>Impacts Total Transfer Capability 0 MW 0 MW</p> <p>TTC with All Lines In Service 199 MW 100 MW</p>
<p>GILBOA -LEEDS 345_GL3</p> <p>Thu 02/16/2017 to Fri 02/17/2017 0600 Continuous 1600</p> <p>Work scheduled by: NGrid</p>	<p>ARR: 38</p>	<p>FWD (Import)</p> <p>CENTRAL EAST - VC 2200 MW</p> <p>Impacts Total Transfer Capability 775 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>LEEDS 345KV_R395</p> <p>Thu 02/16/2017 to Fri 02/17/2017 0600 Continuous 1600</p> <p>Work scheduled by: NGrid</p>	<p>ARR: 38</p>	<p>FWD (Import)</p> <p>UPNY CONED 3800 MW</p> <p>Impacts Total Transfer Capability 1300 MW</p> <p>TTC with All Lines In Service 5100 MW</p>
<p>OSWEGO -VOLNEY 345_12</p> <p>Thu 02/16/2017 to Thu 02/16/2017 0630 Daily(No Weekends) 1630</p> <p>Work scheduled by: NGrid</p>	<p>ARR: 38</p>	<p>FWD (Import)</p> <p>OSWEGO EXPORT 5250 MW</p> <p>Impacts Total Transfer Capability 0 MW</p> <p>TTC with All Lines In Service 5250 MW</p>
<p>W49TH_ST 345KV_6</p> <p>Fri 02/17/2017 to Thu 03/30/2017 0001 Continuous 0300</p> <p>Work scheduled by: ConEd</p>	<p>ARR: 38</p>	<p>FWD (Import)</p> <p>SCH - PJM_HTP 315 MW</p> <p>Impacts Total Transfer Capability 345 MW</p> <p>TTC with All Lines In Service 660 MW</p>

NYISO TRANSFER LIMITATIONS

Thursday ,February 16, 2017 to Saturday ,August 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
BROWNFLS-TAYLORVL_115_3						
Sat 02/18/2017	to	Sat 02/18/2017				
0600	Daily	1900			SCH - HQ_CEDARS	100 MW
Work scheduled by: NGrid			ARR: 38	Impacts Total Transfer Capability	99 MW	0 MW
					TTC with All Lines In Service	199 MW 100 MW
FITZPTRK-EDIC 345_FE-1						
Sat 02/18/2017	to	Sat 02/18/2017				
0700	Daily	1500			CENTRAL EAST - VC	2825 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability		150 MW	
					TTC with All Lines In Service	2975 MW
FITZPTRK-EDIC 345_FE-1						
Sat 02/18/2017	to	Sat 02/18/2017				
0700	Daily	1500			OSWEGO EXPORT	4800 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability		450 MW	
					TTC with All Lines In Service	5250 MW
FITZPTRK-EDIC 345_FE-1						
Sun 02/19/2017	to	Mon 02/20/2017	UPDATED	by PA	02/12/2017	
1800	Continuous	0800			CENTRAL EAST - VC	2825 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability		150 MW	
					TTC with All Lines In Service	2975 MW
FITZPTRK-EDIC 345_FE-1						
Sun 02/19/2017	to	Mon 02/20/2017	UPDATED	by PA	02/12/2017	
1800	Continuous	0800			OSWEGO EXPORT	4800 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability		450 MW	
					TTC with All Lines In Service	5250 MW
LEEDS 345_LEEDS SVC & ILCTLIMIT_MARCY_SO_COMP_I/S						
Mon 02/20/2017	to	Fri 02/24/2017				
0900		1600			CENTRAL EAST - VC	2715 MW
Work scheduled by:			Impacts Total Transfer Capability		260 MW	
					TTC with All Lines In Service	2975 MW
ILCTLIMIT_MARCY_SO_COMP_I/S						
Mon 02/20/2017	to	Mon 03/06/2017				
0900	Continuous	0559			CENTRAL EAST - VC	2740 MW
Work scheduled by: NYISO			Impacts Total Transfer Capability		235 MW	
					TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Thursday ,February 16, 2017 to Saturday ,August 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

OSWEGO__-VOLNEY__345_12			FWD	
Tue 02/21/2017 to Tue 02/21/2017			(Import)	
0630	Daily(No Weekends)	1630	OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	0 MW
			TTC with All Lines In Service	5250 MW
BECK__-NIAGARA__230_PA27			FWD	REV
Tue 02/21/2017 to Sat 02/25/2017			(Import)	(Export)
0645	Continuous	1700	SCH - OH - NY	1750 MW 1900 MW
Work scheduled by: IESO			Impacts Total Transfer Capability	0 MW 0 MW
			TTC with All Lines In Service	1750 MW 1900 MW
MOSES__-ADIRNDCK_230_MA1			FWD	
Tue 02/21/2017 to Fri 02/24/2017			(Import)	
0700	Continuous	1530	MOSES SOUTH	2300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
HUDSONP_-FARRAGUT_345_B3402			FWD	REV
Fri 02/24/2017 to Sat 04/08/2017			(Import)	(Export)
0001	Continuous	0400	SCH - PJ - NY	2300 MW 1450 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	0 MW 0 MW
			TTC with All Lines In Service	2300 MW 1450 MW
HUDSONP_-FARRAGUT_345_B3402 & MARION__-FARRAGUT_345_C3403			FWD	REV
Fri 02/24/2017 to Sat 04/08/2017			(Import)	(Export)
0001		0400	SCH - PJ - NY	2050 MW 1450 MW
Work scheduled by:			Impacts Total Transfer Capability	250 MW 0 MW
			TTC with All Lines In Service	2300 MW 1450 MW
MARION__-FARRAGUT_345_C3403			FWD	REV
Fri 02/24/2017 to Sat 04/08/2017			(Import)	(Export)
0001	Continuous	0400	SCH - PJ - NY	2300 MW 1450 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	0 MW 0 MW
			TTC with All Lines In Service	2300 MW 1450 MW
BROWNFLS-TAYLORVL_115_4			FWD	REV
Sat 02/25/2017 to Sat 02/25/2017			(Import)	(Export)
0600	Daily	1900	SCH - HQ_CEDARS	100 MW 100 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	99 MW 0 MW
			TTC with All Lines In Service	199 MW 100 MW

ARR: 38

NYISO TRANSFER LIMITATIONS

Thursday ,February 16, 2017 to Saturday ,August 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC2

Sat 02/25/2017 to Sat 02/25/2017
 0800 Continuous 1700
 Work scheduled by: HQ

FWD
 (Import)
 MOSES SOUTH **2850 MW**
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

CHAT_DC_GC2

Sat 02/25/2017 to Sat 02/25/2017
 0800 Continuous 1700
 Work scheduled by: HQ

REV
 (Export)
 SCH - HQ - NY **500 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 1000 MW

MOSES__-ADIRNDCK_230_MAL

Mon 02/27/2017 to Fri 03/03/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

LAFAYTTE-CLRKSCRN_345_4-46

Tue 02/28/2017 to Tue 02/28/2017 **UPDATED by NGRID 02/10/2017**
 0700 Daily(No Weekends) 1300
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

DUNWODIE-SHORE_RD_345_Y50

Wed 03/01/2017 to Mon 03/20/2017
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
 CONED - LIPA **800 MW**
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 1500 MW

SHORE_RD_345_138_BK 1

Wed 03/01/2017 to Mon 03/20/2017
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
 CONED - LIPA **1350 MW**
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 1500 MW

SHORE_RD_345_138_BK 2

Wed 03/01/2017 to Mon 03/20/2017
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
 CONED - LIPA **1350 MW**
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 1500 MW

NYISO TRANSFER LIMITATIONS

Thursday ,February 16, 2017 to Saturday ,August 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

COOPERS_-ROCKTVRN_345_CCRT-42					FWD
Wed 03/01/2017	to	Fri 03/24/2017			(Import)
0500	Continuous	1530			CENTRAL EAST - VC 2720 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 255 MW
					TTC with All Lines In Service 2975 MW
CLRKSCRN-OAKDALE_345_36					FWD
Wed 03/01/2017	to	Wed 03/01/2017			(Import)
0700	Continuous	1500			CENTRAL EAST - VC 2650 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability 325 MW
					TTC with All Lines In Service 2975 MW
BECK_-NIAGARA_345_PA302					FWD REV
Sat 03/04/2017	to	Sat 03/04/2017	<u>UPDATED</u>	<u>by OH</u>	<u>02/08/2017</u>
0400	Continuous	1700			(Import) (Export)
Work scheduled by: IESO					SCH - OH - NY 1100 MW 950 MW
					Impacts Total Transfer Capability 650 MW 950 MW
					TTC with All Lines In Service 1750 MW 1900 MW
BROWNFLS-TAYLORVL_115_3					FWD REV
Sat 03/04/2017	to	Sat 03/04/2017			(Import) (Export)
0600	Daily	1900			SCH - HQ_CEDARS 100 MW 100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 99 MW 0 MW
ARR: 38					TTC with All Lines In Service 199 MW 100 MW
W49TH_ST_345KV_8					FWD
Mon 03/06/2017	to	Mon 03/06/2017			(Import)
0001	Continuous	0030			SCH - PJM_HTP 315 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 345 MW
					TTC with All Lines In Service 660 MW
SCH-HQ_CEDARS-NYISO_LIMIT_160					FWD
Mon 03/06/2017	to	Fri 03/24/2017			(Import)
0200	Continuous	0400			SCH - HQ_CEDARS 160 MW
Work scheduled by: HQ					Impacts Total Transfer Capability 39 MW
					TTC with All Lines In Service 199 MW
EDIC_-FRASER_345_EF24-40					FWD
Mon 03/06/2017	to	Fri 03/17/2017	<u>UPDATED</u>	<u>by NY</u>	<u>12/02/2016</u>
0630	Continuous	1700			(Import)
Work scheduled by: NYPA					CENTRAL EAST - VC 2500 MW
					Impacts Total Transfer Capability 475 MW
					TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Thursday ,February 16, 2017 to Saturday ,August 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA1					FWD		
Mon 03/06/2017	to	Fri 03/10/2017			(Import)		
0700	Continuous	1530			MOSES SOUTH	2300 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW	
					TTC with All Lines In Service	3150 MW	
W49TH_ST_345KV_8					FWD		
Wed 03/08/2017	to	Wed 03/08/2017			(Import)		
2130	Continuous	2200			SCH - PJM_HTP	315 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	345 MW	
					TTC with All Lines In Service	660 MW	
BROWNFLS-TAYLORVL_115_4					FWD	REV	
Sat 03/11/2017	to	Sat 03/11/2017			(Import)	(Export)	
0600	Daily	1900			SCH - HQ_CEDARS	100 MW	100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	99 MW	0 MW
					TTC with All Lines In Service	199 MW	100 MW
CHAT_DC_GC1					FWD		
Sun 03/12/2017	to	Sun 03/12/2017	UPDATED	by HQ	02/14/2017	(Import)	
0001	Continuous	0200			MOSES SOUTH	2850 MW	
Work scheduled by: HQ					Impacts Total Transfer Capability	300 MW	
					TTC with All Lines In Service	3150 MW	
CHAT_DC_GC1						REV	
Sun 03/12/2017	to	Sun 03/12/2017	UPDATED	by HQ	02/14/2017	(Export)	
0001	Continuous	0200			SCH - HQ - NY	500 MW	
Work scheduled by: HQ					Impacts Total Transfer Capability	500 MW	
					TTC with All Lines In Service	1000 MW	
CHAT_DC_GC1 & CHAT_DC_GC2					FWD		
Sun 03/12/2017	to	Sun 03/12/2017			(Import)		
0001		0200			MOSES SOUTH	2550 MW	
Work scheduled by:					Impacts Total Transfer Capability	600 MW	
					TTC with All Lines In Service	3150 MW	
CHAT_DC_GC1 & CHAT_DC_GC2					FWD	REV	
Sun 03/12/2017	to	Sun 03/12/2017			(Import)	(Export)	
0001		0200			SCH - HQ - NY	1370 MW	0 MW
Work scheduled by:					Impacts Total Transfer Capability	130 MW	1000 MW
					TTC with All Lines In Service	1500 MW	1000 MW

NYISO TRANSFER LIMITATIONS

Thursday ,February 16, 2017 to Saturday ,August 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC2					FWD		
Sun 03/12/2017	to	Sun 03/12/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>02/14/2017</u>	(Import)	
0001	Continuous	0200				MOSES SOUTH 2850 MW	
Work scheduled by: HQ					Impacts Total Transfer Capability	300 MW	
					TTC with All Lines In Service	3150 MW	
CHAT_DC_GC2					REV		
Sun 03/12/2017	to	Sun 03/12/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>02/14/2017</u>	(Export)	
0001	Continuous	0200				SCH - HQ - NY 500 MW	
Work scheduled by: HQ					Impacts Total Transfer Capability	500 MW	
					TTC with All Lines In Service	1000 MW	
SCH-HQ-NYISO_LIMIT_1100					FWD		
Sun 03/12/2017	to	Sun 03/12/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>02/14/2017</u>	(Import)	
0001	Continuous	0200				SCH - HQ - NY 1100 MW	
Work scheduled by: HQ					Impacts Total Transfer Capability	400 MW	
					TTC with All Lines In Service	1500 MW	
NIAGARA_-ROCHESTR_345_NR2					FWD		
Mon 03/13/2017	to	Wed 03/15/2017				(Import)	
0500	Continuous	1200				DYSINGER EAST 1700 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	1450 MW	
					TTC with All Lines In Service	3150 MW	
BECK___-NIAGARA_345_PA302					FWD	REV	
Mon 03/13/2017	to	Fri 03/17/2017				(Import)	(Export)
0700	Continuous	1600				SCH - OH - NY 1100 MW	950 MW
Work scheduled by: IESO					Impacts Total Transfer Capability	650 MW	950 MW
					TTC with All Lines In Service	1750 MW	1900 MW
MOSES___-ADIRNDCK_230_MA2					FWD		
Mon 03/13/2017	to	Sat 03/18/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/23/2016</u>	(Import)	
0700	Continuous	1530				MOSES SOUTH 2300 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW	
					TTC with All Lines In Service	3150 MW	
MILLWOOD_345KV_18					FWD		
Tue 03/14/2017	to	Fri 03/17/2017				(Import)	
0001	Continuous	2359				UPNY CONED 4350 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	750 MW	
					TTC with All Lines In Service	5100 MW	

NYISO TRANSFER LIMITATIONS

Thursday ,February 16, 2017 to Saturday ,August 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ILCTLIMIT_MARCY_SO_COMP_I/S					FWD	
Fri 03/17/2017	to	Mon 03/20/2017			(Import)	
1700	Continuous	0459			CENTRAL EAST - VC	2740 MW
Work scheduled by: NYISO					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	2975 MW
<hr/>						
LADENTWN-BUCHAN_S_345_Y88					FWD	
Sat 03/18/2017	to	Mon 03/20/2017			(Import)	
0001	Continuous	2359			UPNY CONED	4150 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	5100 MW
<hr/>						
NINEMILE-CLAY_____345_8					FWD	
Mon 03/20/2017	to	Wed 03/22/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>01/25/2017</u>	
0001	Continuous	0400			OSWEGO EXPORT	5150 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	5250 MW
<hr/>						
FRASANX-COOPERS__345_UCC2-41					FWD	
Mon 03/20/2017	to	Fri 03/24/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/27/2016</u>	
0500	Continuous	1630			CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW
<hr/>						
MARCY___-FRASANX_345_UCC2-41					FWD	
Mon 03/20/2017	to	Fri 03/24/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/27/2016</u>	
0500	Continuous	1630			CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA				ARR: 19	Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW
<hr/>						
MOSES___-ADIRNDCK_230_MA2					FWD	
Mon 03/20/2017	to	Sat 03/25/2017			(Import)	
0700	Continuous	1530			MOSES SOUTH	2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
<hr/>						
BERKSHIR-ALPS_____345_393					FWD	REV
Fri 03/24/2017	to	Fri 03/24/2017	<u>UPDATED</u>	<u>by NG</u>	<u>12/27/2016</u>	(Import) (Export)
0800	Daily(No Weekends)	0900			SCH - NE - NY	1300 MW 1300 MW
Work scheduled by: NGrid				ARR: 78	Impacts Total Transfer Capability	100 MW 300 MW
					TTC with All Lines In Service	1400 MW 1600 MW

NYISO TRANSFER LIMITATIONS

Thursday ,February 16, 2017 to Saturday ,August 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS_____345_393	FWD	REV
Fri 03/24/2017 to Fri 03/24/2017 UPDATED by NG 12/27/2016	(Import)	(Export)
0800 Daily(No Weekends) 0900	100 MW	100 MW
SCH - NPX_1385	Impacts Total Transfer Capability	100 MW
Work scheduled by: NGrid	TTC with All Lines In Service	200 MW
ARR: 78		
<hr/>		
BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312	FWD	REV
Fri 03/24/2017 to Fri 03/24/2017	(Import)	(Export)
0800 0900	1300 MW	1300 MW
SCH - NE - NY	Impacts Total Transfer Capability	100 MW
Work scheduled by:	TTC with All Lines In Service	300 MW
ARR: 78		1600 MW
<hr/>		
BERKSHIR-NORTHFLD_345_312	FWD	REV
Fri 03/24/2017 to Sat 04/22/2017	(Import)	(Export)
0800 Continuous 1600	1400 MW	1450 MW
SCH - NE - NY	Impacts Total Transfer Capability	0 MW
Work scheduled by: ISONE	TTC with All Lines In Service	1400 MW
		1600 MW
<hr/>		
BERKSHIR-NORTHFLD_345_312	FWD	REV
Fri 03/24/2017 to Sat 04/22/2017	(Import)	(Export)
0800 Continuous 1600	100 MW	100 MW
SCH - NPX_1385	Impacts Total Transfer Capability	100 MW
Work scheduled by: ISONE	TTC with All Lines In Service	200 MW
		200 MW
<hr/>		
ILCTLIMIT_MARCY_SO_COMP_I/S	FWD	
Fri 03/24/2017 to Mon 04/17/2017	(Import)	
1700 Continuous 0900	2740 MW	
CENTRAL EAST - VC	Impacts Total Transfer Capability	235 MW
Work scheduled by: NYISO	TTC with All Lines In Service	2975 MW
<hr/>		
W49TH_ST_345KV_8	FWD	
Sat 03/25/2017 to Thu 03/30/2017 UPDATED by CONED 02/07/2017	(Import)	
0201 Continuous 0200	315 MW	
SCH - PJM_HTP	Impacts Total Transfer Capability	345 MW
Work scheduled by: ConEd	TTC with All Lines In Service	660 MW
<hr/>		
MARCY_____345KV_CSC	FWD	
Mon 03/27/2017 to Thu 04/13/2017	(Import)	
0500 Continuous 1630	2925 MW	
CENTRAL EAST - VC	Impacts Total Transfer Capability	50 MW
Work scheduled by: NYPA	TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Thursday ,February 16, 2017 to Saturday ,August 18, 2018

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___345KV_CSC & ILCTLIMIT_MARCY_SO_COMP_I/S

Mon 03/27/2017 to Thu 04/13/2017
0500 1630

Work scheduled by:

FWD
(Import)
CENTRAL EAST - VC **2690 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MA2

Mon 03/27/2017 to Sat 04/01/2017 **UPDATED by NYPA 10/23/2016**
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FRASER___-GILBOA___345_GF5-35

Mon 03/27/2017 to Fri 04/07/2017
0900 Continuous 1430

Work scheduled by: NYSEG

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

LINDN_CG-LNDVFT___345_V-3022

Sun 04/02/2017 to Fri 04/07/2017
1400 Continuous 1800

Work scheduled by: PJM

FWD REV
(Import) (Export)
SCH - PJM_VFT **0 MW 0 MW**
Impacts Total Transfer Capability 315 MW 315 MW
TTC with All Lines In Service 315 MW 315 MW

MOSES___-ADIRNDCK_230_MA1

Mon 04/03/2017 to Sat 04/08/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

HOMRC_NY-MAINS_NY_345_47

Mon 04/03/2017 to Fri 04/14/2017 **UPDATED by PJM 01/26/2017**
0800 Continuous 1600

Work scheduled by: NYSEG

FWD REV
(Import) (Export)
SCH - PJ - NY **2300 MW 1450 MW**
Impacts Total Transfer Capability 0 MW 0 MW
TTC with All Lines In Service 2300 MW 1450 MW

MAINESEBG-WATRCURE_345_30

Mon 04/03/2017 to Fri 04/14/2017 **UPDATED by PJM 01/26/2017**
0800 Continuous 1600

Work scheduled by: NYSEG

FWD REV
(Import) (Export)
SCH - PJ - NY **2200 MW 1450 MW**
Impacts Total Transfer Capability 100 MW 0 MW
TTC with All Lines In Service 2300 MW 1450 MW

NYISO TRANSFER LIMITATIONS

Thursday ,February 16, 2017 to Saturday ,August 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6

Wed 04/05/2017 to Sun 04/09/2017
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 02/07/2017

SCH - PJM_HTP **315 MW**
Impacts Total Transfer Capability 345 MW
TTC with All Lines In Service 660 MW

FWD
(Import)

SCH-IMO-NYISO_LIMIT_500

Fri 04/07/2017 to Fri 04/07/2017
0700 Continuous 1530

Work scheduled by: NYPA

SCH - OH - NY **800 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 1750 MW

FWD
(Import)

COOPERS_-ROCKTVRN_345_CCRT-42

Mon 04/10/2017 to Mon 04/24/2017
0630 Continuous 1700

Work scheduled by: NYPA

CENTRAL EAST - VC **2720 MW**
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 2975 MW

FWD
(Import)

MOSES_-ADIRNDCK_230_MA1

Mon 04/10/2017 to Thu 04/13/2017
0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

N.SCTLND-LEEDS_345_93

Mon 04/10/2017 to Mon 04/10/2017
1100 Daily(No Weekends) 1500

Work scheduled by: NGrid

CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

FWD
(Import)

LEEDS_-PLSNTVLY_345_92

Tue 04/11/2017 to Thu 04/13/2017
0730 Continuous 1600

Work scheduled by: NGrid

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5100 MW

FWD
(Import)

SHOR_NPX-SHOREHAM_138_CSC

Mon 04/17/2017 to Sat 04/22/2017
0500 Continuous 1600

Work scheduled by: LI

SCH - NPX_CSC **0 MW** **0 MW**
Impacts Total Transfer Capability 330 MW 330 MW
TTC with All Lines In Service 330 MW 330 MW

FWD REV
(Import) (Export)

NYISO TRANSFER LIMITATIONS

Thursday ,February 16, 2017 to Saturday ,August 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA2					FWD	
Mon 04/17/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/23/2016</u>	(Import)
0700	Continuous	1530				MOSES SOUTH 2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW	
					TTC with All Lines In Service 3150 MW	
FRASER -COOPERS_345_33					FWD	
Mon 04/17/2017	to	Fri 04/21/2017	<u>UPDATED</u>	<u>by NY</u>	<u>01/12/2017</u>	(Import)
0900	Continuous	1400				CENTRAL EAST - VC 2395 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability 580 MW	
					TTC with All Lines In Service 2975 MW	
W49TH_ST_345KV_6					FWD	
Thu 04/20/2017	to	Thu 04/20/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>02/07/2017</u>	(Import)
0230	Continuous	0300				SCH - PJM_HTP 315 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 345 MW	
					TTC with All Lines In Service 660 MW	
MARION -FARRAGUT_345_C3403					FWD	
Fri 04/21/2017	to	Sat 05/20/2017	<u>UPDATED</u>	<u>by CE</u>	<u>01/28/2017</u>	(Import) (Export)
0001	Continuous	2359				SCH - PJ - NY 2300 MW 1450 MW
Work scheduled by: PJM					Impacts Total Transfer Capability 0 MW 0 MW	
					TTC with All Lines In Service 2300 MW 1450 MW	
ILCTLIMIT_MARCY_SO_COMP_I/S					FWD	
Fri 04/21/2017	to	Sat 05/27/2017				(Import)
1400	Continuous	0459				CENTRAL EAST - VC 2740 MW
Work scheduled by: NYISO					Impacts Total Transfer Capability 235 MW	
					TTC with All Lines In Service 2975 MW	
BERKSHIR-ALPS_345_393					FWD	
Sat 04/22/2017	to	Sat 04/22/2017				(Import) (Export)
1500	Daily	1600				SCH - NE - NY 1300 MW 1300 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 100 MW 300 MW	
ARR: 78					TTC with All Lines In Service 1400 MW 1600 MW	
BERKSHIR-ALPS_345_393					FWD	
Sat 04/22/2017	to	Sat 04/22/2017				(Import) (Export)
1500	Daily	1600				SCH - NPX_1385 100 MW 100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 100 MW 100 MW	
ARR: 78					TTC with All Lines In Service 200 MW 200 MW	

NYISO TRANSFER LIMITATIONS

Thursday ,February 16, 2017 to Saturday ,August 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS _____ 345_393 & BERKSHIR-NORTHFLD 345_312		FWD	REV
Sat 04/22/2017	to Sat 04/22/2017	(Import)	(Export)
1500	1600	SCH - NE - NY	1300 MW 1300 MW
Work scheduled by:		Impacts Total Transfer Capability	100 MW 300 MW
ARR: 78		TTC with All Lines In Service	1400 MW 1600 MW
ROSETON _____ -EFISHKIL 345_RFK305		FWD	
Mon 04/24/2017	to Fri 05/05/2017	(Import)	
0001	Continuous 1900	UPNY CONED	4100 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1000 MW
		TTC with All Lines In Service	5100 MW
CLAY _____ -EDIC _____ 345_1-16		FWD	
Mon 04/24/2017	to Tue 04/25/2017	(Import)	
0630	Continuous 1530	OSWEGO EXPORT	4850 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	5250 MW
STLAWRNC-MOSES _____ 230_L34P		FWD	REV
Mon 04/24/2017	to Fri 04/28/2017	(Import)	(Export)
0700	Continuous 1530	SCH - OH - NY	1750 MW 1900 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	0 MW 0 MW
		TTC with All Lines In Service	1750 MW 1900 MW
MOSES _____ -ADIRNDCK 230_MA2		FWD	
Mon 04/24/2017	to Sat 04/29/2017	(Import)	
0700	Continuous 1530	UPDATED by NYPA 10/23/2016	MOSES SOUTH
Work scheduled by: NYPA		Impacts Total Transfer Capability	2300 MW
		TTC with All Lines In Service	850 MW 3150 MW
ALCOA _____ -DENNISON 115_12		FWD	REV
Wed 04/26/2017	to Wed 04/26/2017	(Import)	(Export)
0700	Daily(No Weekends) 1800	SCH - HQ_CEDARS	100 MW 100 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	99 MW 0 MW
ARR: 38		TTC with All Lines In Service	199 MW 100 MW
ALCOA _____ -DENNISON 115_12 & ALCOA _____ -NOGDNBRG 115_13		FWD	REV
Wed 04/26/2017	to Wed 04/26/2017	(Import)	(Export)
0700	1800	SCH - HQ_CEDARS	100 MW 60 MW
Work scheduled by:		Impacts Total Transfer Capability	99 MW 40 MW
ARR: 38		TTC with All Lines In Service	199 MW 100 MW

NYISO TRANSFER LIMITATIONS

Thursday ,February 16, 2017 to Saturday ,August 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>ILCTLIMIT_115KV_ALCOA_R8105_TIE_B</p> <p>Wed 04/26/2017 to Wed 04/26/2017</p> <p>0700 Daily(No Weekends) 1800</p> <p>Work scheduled by: NGrid</p>	<p>FWD</p> <p>(Import)</p> <p>MOSES SOUTH 3100 MW</p> <p>Impacts Total Transfer Capability 50 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>ILCTLIMIT_115KV_ALCOA_R8105_TIE_B</p> <p>Wed 04/26/2017 to Wed 04/26/2017</p> <p>0700 Daily(No Weekends) 1800</p> <p>Work scheduled by: NGrid</p>	<p>FWD REV</p> <p>(Import) (Export)</p> <p>SCH - HQ_CEDARS 100 MW 60 MW</p> <p>Impacts Total Transfer Capability 99 MW 40 MW</p> <p>TTC with All Lines In Service 199 MW 100 MW</p>
<p>NIAGARA_-ROCHESTR_345_NR2</p> <p>Fri 04/28/2017 to Fri 04/28/2017</p> <p>0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p>FWD</p> <p>(Import)</p> <p>DYSINGER EAST 1700 MW</p> <p>Impacts Total Transfer Capability 1450 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>NEPTUNE_-DUFFYAVE_345_NEPTUNE</p> <p>Mon 05/01/2017 to Tue 05/16/2017</p> <p>0400 Continuous 1800</p> <p>Work scheduled by: LI</p>	<p>FWD</p> <p>(Import)</p> <p>SCH - PJM_NEPTUNE 0 MW</p> <p>Impacts Total Transfer Capability 660 MW</p> <p>TTC with All Lines In Service 660 MW</p>
<p>NEWBRDGE-DUFFYAVE_345_501</p> <p>Mon 05/01/2017 to Tue 05/16/2017</p> <p>0400 Continuous 1800</p> <p>Work scheduled by: LI</p>	<p>FWD</p> <p>(Import)</p> <p>SCH - PJM_NEPTUNE 0 MW</p> <p>Impacts Total Transfer Capability 660 MW</p> <p>TTC with All Lines In Service 660 MW</p>
<p>MARCY_-N.SCTLND_345_18</p> <p>Mon 05/01/2017 to Fri 05/05/2017</p> <p>0600 Continuous 1630</p> <p>Work scheduled by: NYPA</p>	<p>FWD</p> <p>(Import)</p> <p>CENTRAL EAST - VC 2090 MW</p> <p>Impacts Total Transfer Capability 885 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>MARCY_-N.SCTLND_345_18 & ILCTLIMIT_MARCY_SO_COMP_I/S</p> <p>Mon 05/01/2017 to Fri 05/05/2017</p> <p>0600 1630</p> <p>Work scheduled by:</p>	<p>FWD</p> <p>(Import)</p> <p>CENTRAL EAST - VC 1855 MW</p> <p>Impacts Total Transfer Capability 1120 MW</p> <p>TTC with All Lines In Service 2975 MW</p>

ARR: 19

ARR: 19

NYISO TRANSFER LIMITATIONS

Thursday ,February 16, 2017 to Saturday ,August 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BROWNFLS-TAYLORVL_115_3			FWD	REV
			(Import)	(Export)
Mon 05/01/2017	to	Fri 05/26/2017		
0600	Continuous	1900	SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	120 MW 0 MW
			TTC with All Lines In Service	190 MW 40 MW
ARR: 38				
ROCHESTR-PANNELL_345_RP2			FWD	
			(Import)	
Mon 05/01/2017	to	Mon 05/01/2017		
0630	Continuous	0700	DYSINGER EAST	2300 MW
Work scheduled by: RGE			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
PANNELL_-CLAY_345_2			FWD	
			(Import)	
Mon 05/01/2017	to	Fri 05/05/2017		
0630	Continuous	1530	WEST CENTRAL	1300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	950 MW
			TTC with All Lines In Service	2250 MW
ROCHESTR-PANNELL_345_RP2			FWD	
			(Import)	
Fri 05/05/2017	to	Fri 05/05/2017		
1500	Continuous	1530	DYSINGER EAST	2300 MW
Work scheduled by: RGE			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
PANNELL_-CLAY_345_2			FWD	
			(Import)	
Mon 05/08/2017	to	Mon 05/08/2017		
0700	Continuous	0730	WEST CENTRAL	1300 MW
Work scheduled by: RGE			Impacts Total Transfer Capability	950 MW
			TTC with All Lines In Service	2250 MW
ROCHESTR-PANNELL_345_RP2			FWD	
			(Import)	
Mon 05/08/2017	to	Wed 05/10/2017		
0700	Continuous	1530	DYSINGER EAST	2300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
ROSETON_-ROCKTVRN_345_311			FWD	
			(Import)	
Mon 05/08/2017	to	Fri 05/26/2017		
0800	Continuous	1600	UPNY CONED	4400 MW
Work scheduled by: CHGE			Impacts Total Transfer Capability	700 MW
			TTC with All Lines In Service	5100 MW

NYISO TRANSFER LIMITATIONS

Thursday ,February 16, 2017 to Saturday ,August 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_ 345_2

Wed 05/10/2017 to Wed 05/10/2017
 1500 Continuous 1530
 Work scheduled by: RGE

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

FRASER_-GILBOA_ 345_GF5-35

Mon 05/15/2017 to Fri 05/19/2017
 0630 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

STONYRDG-HILLSIDE_230_72

Mon 05/15/2017 to Mon 05/15/2017
 0800 Continuous 1700
 Work scheduled by: NYSEG

FWD
 (Import)
 DYSINGER EAST **2850 MW**
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

FRASER_ 345_FRASER SVC

Mon 05/15/2017 to Fri 05/19/2017
 0900 Continuous 1430
 Work scheduled by: NYSEG

FWD
 (Import)
 CENTRAL EAST - VC **2935 MW**
 Impacts Total Transfer Capability 40 MW
 TTC with All Lines In Service 2975 MW

FRASER_ 345_FRASER SVC & ILCTLIMIT_MARCY_SO_COMP_I/S

Mon 05/15/2017 to Fri 05/19/2017
 0900 1430
 Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC **2700 MW**
 Impacts Total Transfer Capability 275 MW
 TTC with All Lines In Service 2975 MW

RAMAPO_-LADENTWN_345_W72

Tue 05/16/2017 to Tue 05/16/2017
 0001 Continuous 2330
 Work scheduled by: ORU

FWD
 (Import)
 UPNY CONED **4400 MW**
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 5100 MW

MARCY_ 765_345_AT1

Mon 05/22/2017 to Fri 05/26/2017
 0500 Continuous 1630
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **1750 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 3150 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Thursday ,February 16, 2017 to Saturday ,August 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
LINDEN__-GOETHALS_230_A2253							
Fri 05/26/2017	to	Sat 05/27/2017	<u>UPDATED</u>	<u>by CE</u>	<u>02/01/2017</u>		
0001	Continuous	2359				SCH - PJ - NY	2050 MW
Work scheduled by: PJM						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	2050 MW
							1300 MW
MARCY__-N.SCTLND_345_18							
Sat 05/27/2017	to	Sat 05/27/2017				CENTRAL EAST - VC	2090 MW
0500	Continuous	1530				Impacts Total Transfer Capability	885 MW
Work scheduled by: NYPA						TTC with All Lines In Service	2975 MW
ILCTLIMIT_MARCY_SO_COMP_I/S							
Sat 05/27/2017	to	Sat 08/05/2017				CENTRAL EAST - VC	2740 MW
1600	Continuous	0459				Impacts Total Transfer Capability	235 MW
Work scheduled by: NYISO						TTC with All Lines In Service	2975 MW
BROWNFLS-TAYLORVL_115_4							
Tue 05/30/2017	to	Sat 06/24/2017				SCH - HQ_CEDARS	70 MW
0600	Continuous	1900				Impacts Total Transfer Capability	120 MW
Work scheduled by: NGrid						TTC with All Lines In Service	190 MW
							40 MW
STONYRDG-HILLSIDE_230_72							
Mon 06/05/2017	to	Mon 06/05/2017				DYSINGER EAST	2850 MW
0800	Continuous	1000				Impacts Total Transfer Capability	300 MW
Work scheduled by: NYSEG						TTC with All Lines In Service	3150 MW
STONYRDG-HILLSIDE_230_72							
Fri 06/09/2017	to	Fri 06/09/2017				DYSINGER EAST	2850 MW
1500	Continuous	1700				Impacts Total Transfer Capability	300 MW
Work scheduled by: NYSEG						TTC with All Lines In Service	3150 MW
BROWNFLS-TAYLORVL_115_3							
Mon 06/26/2017	to	Sat 07/01/2017				SCH - HQ_CEDARS	70 MW
0600	Continuous	1900				Impacts Total Transfer Capability	120 MW
Work scheduled by: NGrid						TTC with All Lines In Service	190 MW
							40 MW

NYISO TRANSFER LIMITATIONS

Thursday ,February 16, 2017 to Saturday ,August 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BROWNFLS-TAYLORVL_115_3			FWD	REV
			(Import)	(Export)
Wed 07/05/2017	to	Sat 07/22/2017		
0600	Continuous	1900	SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	120 MW 0 MW
			TTC with All Lines In Service	190 MW 40 MW
ARR: 38				
BROWNFLS-TAYLORVL_115_4			FWD	REV
			(Import)	(Export)
Mon 07/24/2017	to	Sat 08/19/2017		
0600	Continuous	1900	SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	120 MW 0 MW
			TTC with All Lines In Service	190 MW 40 MW
ARR: 38				
MARCY___-N.SCTLND_345_18			FWD	
			(Import)	
Sat 08/05/2017	to	Sat 08/05/2017		
0500	Continuous	1530	CENTRAL EAST - VC	2090 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	885 MW
			TTC with All Lines In Service	2975 MW
ARR: 19				
MARCY___765_345_AT2			FWD	
			(Import)	
Sat 08/05/2017	to	Sat 08/05/2017		
0500	Continuous	1530	MOSES SOUTH	1700 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW
			TTC with All Lines In Service	3150 MW
ARR: 19				
ILCTLIMIT_MARCY_SO_COMP_I/S			FWD	
			(Import)	
Sat 08/05/2017	to	Mon 11/06/2017		
1600	Continuous	0559	CENTRAL EAST - VC	2740 MW
Work scheduled by: NYISO			Impacts Total Transfer Capability	235 MW
			TTC with All Lines In Service	2975 MW
ARR: 19				
BROWNFLS-TAYLORVL_115_3			FWD	REV
			(Import)	(Export)
Mon 08/21/2017	to	Fri 09/01/2017		
0600	Continuous	1900	SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	120 MW 0 MW
			TTC with All Lines In Service	190 MW 40 MW
ARR: 38				
MARCY___765_345_AT2			FWD	
			(Import)	
Tue 09/05/2017	to	Sun 09/10/2017		
0500	Continuous	1630	MOSES SOUTH	1700 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW
			TTC with All Lines In Service	3150 MW
ARR: 19				

NYISO TRANSFER LIMITATIONS

Thursday ,February 16, 2017 to Saturday ,August 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
BROWNFLS-TAYLORVL_115_3					
Tue 09/05/2017	to	Sat 09/16/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
HURLYAVE-ROSETON_345_303					
Mon 09/11/2017	to	Fri 09/29/2017			
0800	Continuous	1600			
Work scheduled by: CHGE					
				UPNY CONED	4100 MW
				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	5100 MW
SPRNBRK_-DUNWODIE_345_W75					
Fri 09/15/2017	to	Sun 09/17/2017			
2200	Continuous	0200			
Work scheduled by: ConEd					
				SPR/DUN-SOUTH	3800 MW
				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
SPRNBRK_345KV_RNS3					
Fri 09/15/2017	to	Sun 09/17/2017			
2200	Continuous	0200			
Work scheduled by: ConEd					
				SPR/DUN-SOUTH	3800 MW
				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
BROWNFLS-TAYLORVL_115_4					
Mon 09/18/2017	to	Fri 10/13/2017			
0600	Continuous	1600			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
GILBOA_-N.SCTLND_345_GNS-1					
Mon 09/18/2017	to	Fri 10/06/2017			
0630	Continuous	1700			
Work scheduled by: NYPA					
				CENTRAL EAST - VC	2520 MW
				Impacts Total Transfer Capability	455 MW
				TTC with All Lines In Service	2975 MW
NIAGARA_345_230_AT4					
Mon 09/18/2017	to	Tue 09/19/2017			
0700	Continuous	1530			
Work scheduled by: NYPA					
				SCH - OH - NY	1750 MW 1300 MW
				Impacts Total Transfer Capability	0 MW 300 MW
				TTC with All Lines In Service	1750 MW 1600 MW

NYISO TRANSFER LIMITATIONS

Thursday ,February 16, 2017 to Saturday ,August 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-ROCHESTR_345_NR2			FWD	
Mon 10/02/2017	to	Fri 10/06/2017	(Import)	
0700	Continuous	1530	DYSINGER EAST	1700 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW
			TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA_765_7040			FWD	
Sat 10/14/2017	to	Sat 10/28/2017	(Import)	
0700	Continuous	1530	MOSES SOUTH	1550 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1600 MW
			TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA_765_7040			FWD	REV
Sat 10/14/2017	to	Sat 10/28/2017	(Import)	(Export)
0700	Continuous	1530	SCH - HQ - NY	0 MW 0 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1500 MW 1000 MW
			TTC with All Lines In Service	1500 MW 1000 MW
MARCY_765_345_AT1			FWD	
Sat 10/14/2017	to	Sat 10/28/2017	(Import)	
0700	Continuous	1530	MOSES SOUTH	1750 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1400 MW
			TTC with All Lines In Service	3150 MW
			ARR: 19	
MARCY_765_345_AT2			FWD	
Sat 10/14/2017	to	Sat 10/28/2017	(Import)	
0700	Continuous	1530	MOSES SOUTH	1700 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW
			TTC with All Lines In Service	3150 MW
			ARR: 19	
MASSENA_-MARCY_765_MSU1			FWD	
Sat 10/14/2017	to	Sat 10/28/2017	(Import)	
0700	Continuous	1530	CENTRAL EAST - VC	2265 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	710 MW
			TTC with All Lines In Service	2975 MW
MASSENA_-MARCY_765_MSU1			FWD	
Sat 10/14/2017	to	Sat 10/28/2017	(Import)	
0700	Continuous	1530	MOSES SOUTH	500 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Thursday ,February 16, 2017 to Saturday ,August 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>MASSENA_-MARCY___765_MSU1</p> <p>Sat 10/14/2017 to Sat 10/28/2017 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - HQ - NY 475 MW 1000 MW</p> <p>Impacts Total Transfer Capability 1025 MW 0 MW</p> <p>TTC with All Lines In Service 1500 MW 1000 MW</p>
<p>MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040</p> <p>Sat 10/14/2017 to Sat 10/28/2017 0700 1530</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 500 MW</p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>MASSENA_-MARCY___765_MSU1 & ILCTLIMIT_MARCY_SO_COMP_I/S</p> <p>Sat 10/14/2017 to Sat 10/28/2017 0700 1530</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2080 MW</p> <p>Impacts Total Transfer Capability 895 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2</p> <p>Sat 10/14/2017 to Sat 10/28/2017 0700 1530</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - HQ - NY 850 MW 0 MW</p> <p>Impacts Total Transfer Capability 650 MW 1000 MW</p> <p>TTC with All Lines In Service 1500 MW 1000 MW</p>
<p>LEEDS_-HURLYAVE_345_301</p> <p>Mon 10/16/2017 to Fri 11/03/2017 0800 Continuous 1600</p> <p>Work scheduled by: CHGE</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED 4100 MW</p> <p>Impacts Total Transfer Capability 1000 MW</p> <p>TTC with All Lines In Service 5100 MW</p>
<p>BROWNFLS-TAYLORVL_115_3</p> <p>Mon 10/30/2017 to Sat 11/11/2017 UPDATED by NGRID 09/01/2016 0700 Continuous 1900</p> <p>Work scheduled by: NGrid ARR: 38</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - HQ_CEDARS 70 MW 40 MW</p> <p>Impacts Total Transfer Capability 120 MW 0 MW</p> <p>TTC with All Lines In Service 190 MW 40 MW</p>
<p>FRASANX-COOPERS_345_UCC2-41</p> <p>Mon 11/06/2017 to Fri 11/17/2017 0600 Continuous 1700</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2500 MW</p> <p>Impacts Total Transfer Capability 475 MW</p> <p>TTC with All Lines In Service 2975 MW</p>

NYISO TRANSFER LIMITATIONS

Thursday ,February 16, 2017 to Saturday ,August 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
MARCY___-FRASANNX_345_UCC2-41			FWD
Mon 11/06/2017	to	Fri 11/17/2017	(Import)
0600	Continuous	1700	CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA		ARR: 19	Impacts Total Transfer Capability 475 MW
			TTC with All Lines In Service 2975 MW
<hr/>			
BROWNFLS-TAYLORVL_115_4			FWD REV
Mon 11/13/2017	to	Thu 11/30/2017	(Import) (Export)
0600	Continuous	1900	SCH - HQ_CEDARS 100 MW 100 MW
Work scheduled by: NGrid		ARR: 38	Impacts Total Transfer Capability 99 MW 0 MW
			TTC with All Lines In Service 199 MW 100 MW
<hr/>			
ILCTLIMIT_MARCY_SO_COMP_I/S			FWD
Fri 11/17/2017	to	Sat 02/01/2020	(Import)
1700	Continuous	0000	CENTRAL EAST - VC 2740 MW
Work scheduled by: NYISO			Impacts Total Transfer Capability 235 MW
			TTC with All Lines In Service 2975 MW
<hr/>			
MARCY___765_345_AT2			FWD
Mon 12/04/2017	to	Fri 12/08/2017	(Import)
0500	Continuous	1630	MOSES SOUTH 1700 MW
Work scheduled by: NYPA		ARR: 19	Impacts Total Transfer Capability 1450 MW
			TTC with All Lines In Service 3150 MW
<hr/>			
MOSES___-ADIRNDCK_230_MA2			FWD
Mon 12/11/2017	to	Fri 12/15/2017	(Import)
0700	Continuous	1530	MOSES SOUTH 2300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 850 MW
			TTC with All Lines In Service 3150 MW
<hr/>			
MOSES___-ADIRNDCK_230_MA2			FWD
Mon 12/18/2017	to	Fri 12/22/2017	(Import)
0700	Continuous	1530	MOSES SOUTH 2300 MW
Work scheduled by: NYPA		ARR: 19	Impacts Total Transfer Capability 850 MW
			TTC with All Lines In Service 3150 MW
<hr/>			
MOSES___-ADIRNDCK_230_MA2			FWD
Tue 12/26/2017	to	Thu 12/28/2017	(Import)
0700	Continuous	1530	MOSES SOUTH 2300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 850 MW
			TTC with All Lines In Service 3150 MW