

NYISO TRANSFER LIMITATIONS

Tuesday ,February 14, 2017 to Thursday ,August 16, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event ID	Start Date	End Date	Reason	By	Effective Date	SCH	FWD	REV	
RAMAPO___345_345_PAR3500	Fri 06/24/2016	Thu 06/01/2017	EXT FORCE	by CONED	01/11/2017	SCH - PJ - NY	(Import)	(Export)	
	1940	Continuous					2200 MW	1450 MW	
	Work scheduled by: ConEd						Impacts Total Transfer Capability	100 MW	0 MW
							TTC with All Lines In Service	2300 MW	1450 MW
PLSNTVLE-DUNWODIE_345_W89	Sun 10/30/2016	Sat 04/15/2017	EXT FORCE	by CONED	02/01/2017	UPNY CONED	(Import)		
	0728	Continuous					4000 MW		
	Work scheduled by: ConEd						Impacts Total Transfer Capability	1100 MW	
							TTC with All Lines In Service	5100 MW	
HUDSONTP-W49TH_ST_345_Y56	Thu 11/24/2016	Mon 05/01/2017	EXTENDED	by PJM	01/27/2017	SCH - PJM_HTP	(Import)		
	1500	Continuous					0 MW		
	Work scheduled by: ConEd						Impacts Total Transfer Capability	660 MW	
							TTC with All Lines In Service	660 MW	
E13THSTA-FARRAGUT_345_46	Tue 12/20/2016	Thu 04/20/2017	UPDATED	by CONED	02/07/2017	SPR/DUN-SOUTH	(Import)		
	0001	Continuous					3800 MW		
	Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW	
							TTC with All Lines In Service	4600 MW	
W49TH_ST-E13THSTA_345_M55	Tue 12/20/2016	Thu 04/20/2017	UPDATED	by CONED	02/07/2017	SPR/DUN-SOUTH	(Import)		
	0001	Continuous					3800 MW		
	Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW	
							TTC with All Lines In Service	4600 MW	
SCH-IMO-NYISO_LIMIT_1200	Thu 01/19/2017	Tue 02/21/2017	UPDATED	by NYPA	01/13/2017	SCH - OH - NY	(Import)		
	1900	Continuous					1500 MW		
	Work scheduled by: NYPA						Impacts Total Transfer Capability	250 MW	
							TTC with All Lines In Service	1750 MW	
LEEDS___345_LEEDS SVC	Mon 01/30/2017	Fri 02/24/2017				CENTRAL EAST - VC	(Import)		
	0800	Continuous					2950 MW		
	Work scheduled by: NGrid						Impacts Total Transfer Capability	25 MW	
							TTC with All Lines In Service	2975 MW	

NYISO TRANSFER LIMITATIONS

Tuesday ,February 14, 2017 to Thursday ,August 16, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD		
MOSES -ADIRNDCK_230_MA2						(Import)		
Mon 02/06/2017	to	Fri 02/10/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/23/2016</u>	MOSES SOUTH	2300 MW	
0700	Continuous	1530				Impacts Total Transfer Capability	850 MW	
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW	
NRTH1385-NOR HBR_138_601						FWD	REV	
Mon 02/06/2017	to	Sat 02/25/2017		<u>by LI</u>	<u>01/11/2017</u>	(Import) (Export)		
0700	Continuous	2359				SCH - NPX_1385	100 MW	100 MW
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW	100 MW
						TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_602						FWD	REV	
Mon 02/06/2017	to	Sat 02/25/2017				(Import) (Export)		
0700		2359				SCH - NPX_1385	0 MW	0 MW
Work scheduled by:						Impacts Total Transfer Capability	200 MW	200 MW
						TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_603						FWD	REV	
Mon 02/06/2017	to	Sat 02/25/2017				(Import) (Export)		
0700		2359				SCH - NPX_1385	0 MW	0 MW
Work scheduled by:						Impacts Total Transfer Capability	200 MW	200 MW
						TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR_138_602						FWD	REV	
Mon 02/06/2017	to	Sat 02/25/2017		<u>by LI</u>	<u>01/11/2017</u>	(Import) (Export)		
0700	Continuous	2359				SCH - NPX_1385	100 MW	100 MW
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW	100 MW
						TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR_138_602 & NRTH1385-NOR HBR_138_603						FWD	REV	
Mon 02/06/2017	to	Sat 02/25/2017				(Import) (Export)		
0700		2359				SCH - NPX_1385	0 MW	0 MW
Work scheduled by:						Impacts Total Transfer Capability	200 MW	200 MW
						TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR_138_603						FWD	REV	
Mon 02/06/2017	to	Sat 02/25/2017		<u>by LI</u>	<u>01/11/2017</u>	(Import) (Export)		
0700	Continuous	2359				SCH - NPX_1385	100 MW	100 MW
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW	100 MW
						TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,February 14, 2017 to Thursday ,August 16, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD	REV
NRTH1385-NRTHPORT_138_1385					(Import)	(Export)
Mon 02/06/2017	to	Sat 02/25/2017	<u>by LI</u>	<u>01/11/2017</u>	SCH - NPX_1385	0 MW
0700	Continuous	2359			Impacts Total Transfer Capability	200 MW
Work scheduled by: LI					TTC with All Lines In Service	200 MW
<hr/>					FWD	REV
BROWNFLS-TAYLORVL_115_4					(Import)	(Export)
Sat 02/11/2017	to	Sat 02/11/2017			SCH - HQ_CEDARS	100 MW
0600	Daily	1900			Impacts Total Transfer Capability	99 MW
Work scheduled by: NGrid					TTC with All Lines In Service	199 MW
<hr/>					FWD	REV
VOLNEY_-MARCY_345_19					(Import)	(Export)
Mon 02/13/2017	to	Mon 02/13/2017	<u>CANCELLED</u>	<u>by NGrid</u>	<u>02/13/2017</u>	CENTRAL EAST - VC
0700	Daily(No Weekends)	1630				2825 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	150 MW
<hr/>					FWD	REV
VOLNEY_-MARCY_345_19					(Import)	(Export)
Mon 02/13/2017	to	Mon 02/13/2017	<u>CANCELLED</u>	<u>by NGrid</u>	<u>02/13/2017</u>	OSWEGO EXPORT
0700	Daily(No Weekends)	1630				4900 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	350 MW
<hr/>					FWD	REV
MOSES_-ADIRNDCK_230_MAI					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017			MOSES SOUTH	2300 MW
0700	Continuous	1530			Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA					TTC with All Lines In Service	3150 MW
<hr/>					FWD	REV
SCH-IMO-NYISO_LIMIT_1000					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - OH - NY
0800	Continuous	1600				1300 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	450 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
<hr/>					FWD	REV
SCH-NYISO-PJM_LIMIT_100					(Import)	(Export)
Tue 02/14/2017	to	Fri 02/17/2017	<u>CANCELLED</u>	<u>by PJM</u>	<u>02/14/2017</u>	SCH - PJ - NY
0800	Continuous	1600				400 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,February 14, 2017 to Thursday ,August 16, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

VOLNEY__-MARCY___345_19		FWD	
Wed 02/15/2017	to Wed 02/15/2017	(Import)	
0630	Daily(No Weekends) 1459	CENTRAL EAST - VC	2825 MW
Work scheduled by: NGrid	ARR: 19	Impacts Total Transfer Capability	150 MW
		TTC with All Lines In Service	2975 MW
VOLNEY__-MARCY___345_19		FWD	
Wed 02/15/2017	to Wed 02/15/2017	(Import)	
0630	Daily(No Weekends) 1459	OSWEGO EXPORT	4900 MW
Work scheduled by: NGrid	ARR: 19	Impacts Total Transfer Capability	350 MW
		TTC with All Lines In Service	5250 MW
BULYMO__-BOONVLE_115_6		FWD	REV
Wed 02/15/2017	to Wed 02/15/2017	(Import)	(Export)
1300	Daily(No Weekends) 1530	SCH - HQ_CEDARS	199 MW 100 MW
Work scheduled by: NGrid	ARR: 38	Impacts Total Transfer Capability	0 MW 0 MW
		TTC with All Lines In Service	199 MW 100 MW
TAYLORVL-BULYMO___115_6		FWD	REV
Wed 02/15/2017	to Wed 02/15/2017	(Import)	(Export)
1300	Daily(No Weekends) 1530	SCH - HQ_CEDARS	199 MW 100 MW
Work scheduled by: NGrid	ARR: 38	Impacts Total Transfer Capability	0 MW 0 MW
		TTC with All Lines In Service	199 MW 100 MW
GILBOA__-LEEDS___345_GL3		FWD	
Thu 02/16/2017	to Fri 02/17/2017	(Import)	
0600	Continuous 1600	CENTRAL EAST - VC	2200 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	775 MW
		TTC with All Lines In Service	2975 MW
LEEDS___345KV_R395		FWD	
Thu 02/16/2017	to Fri 02/17/2017	(Import)	
0600	Continuous 1600	UPNY CONED	3800 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	1300 MW
		TTC with All Lines In Service	5100 MW
OSWEGO__-VOLNEY___345_12		FWD	
Thu 02/16/2017	to Thu 02/16/2017	(Import)	
0630	Daily(No Weekends) 1630	OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	0 MW
		TTC with All Lines In Service	5250 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,February 14, 2017 to Thursday ,August 16, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6					FWD	
Fri 02/17/2017	to	Thu 03/30/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>02/07/2017</u>	(Import)
0001	Continuous	0300				315 MW
Work scheduled by: ConEd					SCH - PJM_HTP	Impacts Total Transfer Capability 345 MW
					TTC with All Lines In Service	660 MW
BROWNFLS-TAYLORVL_115_3					FWD	REV
Sat 02/18/2017	to	Sat 02/18/2017				(Import) (Export)
0600	Daily	1900				100 MW 100 MW
Work scheduled by: NGrid					SCH - HQ_CEDARS	Impacts Total Transfer Capability 99 MW 0 MW
					TTC with All Lines In Service	199 MW 100 MW
FITZPTRK-EDIC 345_FE-1					FWD	
Sun 02/19/2017	to	Mon 02/20/2017	<u>UPDATED</u>	<u>by PA</u>	<u>02/12/2017</u>	(Import)
1800	Continuous	0800				2825 MW
Work scheduled by: NYPA					CENTRAL EAST - VC	Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service	2975 MW
FITZPTRK-EDIC 345_FE-1					FWD	
Sun 02/19/2017	to	Mon 02/20/2017	<u>UPDATED</u>	<u>by PA</u>	<u>02/12/2017</u>	(Import)
1800	Continuous	0800				4800 MW
Work scheduled by: NYPA					OSWEGO EXPORT	Impacts Total Transfer Capability 450 MW
					TTC with All Lines In Service	5250 MW
LEEDS 345_LEEDS SVC & ILCTLIMIT_MARCY_SO_COMP_I/S					FWD	
Mon 02/20/2017	to	Fri 02/24/2017				(Import)
0900		1600				2715 MW
Work scheduled by:					CENTRAL EAST - VC	Impacts Total Transfer Capability 260 MW
					TTC with All Lines In Service	2975 MW
ILCTLIMIT_MARCY_SO_COMP_I/S					FWD	
Mon 02/20/2017	to	Mon 03/06/2017				(Import)
0900	Continuous	0559				2740 MW
Work scheduled by: NYISO					CENTRAL EAST - VC	Impacts Total Transfer Capability 235 MW
					TTC with All Lines In Service	2975 MW
BECK -NIAGARA 230_PA27					FWD	REV
Tue 02/21/2017	to	Sat 02/25/2017				(Import) (Export)
0645	Continuous	1700				1750 MW 1900 MW
Work scheduled by: IESO					SCH - OH - NY	Impacts Total Transfer Capability 0 MW 0 MW
					TTC with All Lines In Service	1750 MW 1900 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,February 14, 2017 to Thursday ,August 16, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer ID	Start Date	End Date	Time	Day	Duration	Work by	Transfer Type	Impact	TTC
MOSES - ADIRNDCK_230_MA1	Tue 02/21/2017	Fri 02/24/2017	0700	Continuous	1530	NYPA	FWD (Import)	MOSES SOUTH	2300 MW
								Impacts Total Transfer Capability	850 MW
								TTC with All Lines In Service	3150 MW
BROWNFLS-TAYLORVL_115_4	Sat 02/25/2017	Sat 02/25/2017	0600	Daily	1900	NGrid	FWD (Import)	SCH - HQ_CEDARS	100 MW
								Impacts Total Transfer Capability	99 MW
								TTC with All Lines In Service	199 MW
									ARR: 38
CHAT_DC_GC2	Sat 02/25/2017	Sat 02/25/2017	0800	Continuous	1700	HQ	FWD (Import)	MOSES SOUTH	2850 MW
								Impacts Total Transfer Capability	300 MW
								TTC with All Lines In Service	3150 MW
CHAT_DC_GC2	Sat 02/25/2017	Sat 02/25/2017	0800	Continuous	1700	HQ	REV (Export)	SCH - HQ - NY	500 MW
								Impacts Total Transfer Capability	500 MW
								TTC with All Lines In Service	1000 MW
MOSES - ADIRNDCK_230_MA1	Mon 02/27/2017	Fri 03/03/2017	0700	Continuous	1530	NYPA	FWD (Import)	MOSES SOUTH	2300 MW
								Impacts Total Transfer Capability	850 MW
								TTC with All Lines In Service	3150 MW
LAFAYTTE-CLRKSCRN_345_4-46	Tue 02/28/2017	Tue 02/28/2017	0700	Daily(No Weekends)	1300	NGRID	FWD (Import)	CENTRAL EAST - VC	2650 MW
								Impacts Total Transfer Capability	325 MW
								TTC with All Lines In Service	2975 MW
DUNWODIE-SHORE_RD_345_Y50	Wed 03/01/2017	Mon 03/20/2017	0001	Continuous	2359	LI	FWD (Import)	CONED - LIPA	800 MW
								Impacts Total Transfer Capability	700 MW
								TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,February 14, 2017 to Thursday ,August 16, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
<p>SHORE_RD_345_138_BK 1</p> <p>Wed 03/01/2017 to Mon 03/20/2017 0001 Continuous 2359</p> <p>Work scheduled by: LI</p>	<p style="text-align: right;">FWD (Import)</p> <p>CONED - LIPA 1350 MW</p> <p>Impacts Total Transfer Capability 150 MW</p> <p>TTC with All Lines In Service 1500 MW</p>		
<hr/>			
<p>SHORE_RD_345_138_BK 2</p> <p>Wed 03/01/2017 to Mon 03/20/2017 0001 Continuous 2359</p> <p>Work scheduled by: LI</p>	<p style="text-align: right;">FWD (Import)</p> <p>CONED - LIPA 1350 MW</p> <p>Impacts Total Transfer Capability 150 MW</p> <p>TTC with All Lines In Service 1500 MW</p>		
<hr/>			
<p>COOPERS_-ROCKTVRN_345_CCRT-42</p> <p>Wed 03/01/2017 to Fri 03/24/2017 0500 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2720 MW</p> <p>Impacts Total Transfer Capability 255 MW</p> <p>TTC with All Lines In Service 2975 MW</p>		
<hr/>			
<p>CLRKSCRN-OAKDALE__345_36</p> <p>Wed 03/01/2017 to Wed 03/01/2017 0700 Continuous 1500</p> <p>Work scheduled by: NYSEG</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2650 MW</p> <p>Impacts Total Transfer Capability 325 MW</p> <p>TTC with All Lines In Service 2975 MW</p>		
<hr/>			
<p>BECK___-PACKARD__230_BP76</p> <p>Wed 03/01/2017 to Wed 03/01/2017 0700 Daily(No Weekends) 1700</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>CANCELLED by NGrid 02/09/2017</p> <p>SCH - OH - NY 1000 MW 1400 MW</p> <p>Impacts Total Transfer Capability 750 MW 500 MW</p> <p>TTC with All Lines In Service 1750 MW 1900 MW</p>		
<hr/>			
<p>BECK___-NIAGARA__345_PA302</p> <p>Sat 03/04/2017 to Sat 03/04/2017 0400 Continuous 1700</p> <p>Work scheduled by: IESO</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>UPDATED by OH 02/08/2017</p> <p>SCH - OH - NY 1100 MW 950 MW</p> <p>Impacts Total Transfer Capability 650 MW 950 MW</p> <p>TTC with All Lines In Service 1750 MW 1900 MW</p>		
<hr/>			
<p>BROWNFLS-TAYLORVL_115_3</p> <p>Sat 03/04/2017 to Sat 03/04/2017 0600 Daily 1900</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - HQ_CEDARS 100 MW 100 MW</p> <p>Impacts Total Transfer Capability 99 MW 0 MW</p> <p>TTC with All Lines In Service 199 MW 100 MW</p>		

ARR: 38

NYISO TRANSFER LIMITATIONS

Tuesday ,February 14, 2017 to Thursday ,August 16, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_8					FWD	
Mon 03/06/2017	to	Mon 03/06/2017			(Import)	
0001	Continuous	0030		SCH - PJM_HTP	315 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	345 MW
					TTC with All Lines In Service	660 MW
EDIC -FRASER 345_EF24-40					FWD	
Mon 03/06/2017	to	Fri 03/17/2017	<u>UPDATED</u>	<u>by NY</u>	<u>12/02/2016</u>	(Import)
0630	Continuous	1700			CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW
MOSES -ADIRNDCK_230_MA1					FWD	
Mon 03/06/2017	to	Fri 03/10/2017			(Import)	
0700	Continuous	1530			MOSES SOUTH	2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
W49TH_ST_345KV_8					FWD	
Wed 03/08/2017	to	Wed 03/08/2017			(Import)	
2130	Continuous	2200			SCH - PJM_HTP	315 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	345 MW
					TTC with All Lines In Service	660 MW
BROWNFLS-TAYLORVL_115_4					FWD	REV
Sat 03/11/2017	to	Sat 03/11/2017			(Import)	(Export)
0600	Daily	1900			SCH - HQ_CEDARS	100 MW 100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	99 MW 0 MW
					TTC with All Lines In Service	199 MW 100 MW
CHAT_DC_GC1					FWD	
Sun 03/12/2017	to	Sun 03/12/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>02/14/2017</u>	(Import)
0001	Continuous	0200			MOSES SOUTH	2850 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
CHAT_DC_GC1					FWD	REV
Sun 03/12/2017	to	Sun 03/12/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>02/14/2017</u>	(Export)
0001	Continuous	0200			SCH - HQ - NY	500 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,February 14, 2017 to Thursday ,August 16, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1 & CHAT_DC_GC2

Sun 03/12/2017 to Sun 03/12/2017
0001 0200

Work scheduled by:

FWD
(Import)
MOSES SOUTH **2550 MW**
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC1 & CHAT_DC_GC2

Sun 03/12/2017 to Sun 03/12/2017
0001 0200

Work scheduled by:

FWD REV
(Import) (Export)
SCH - HQ - NY **1370 MW 0 MW**
Impacts Total Transfer Capability 130 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

CHAT_DC_GC2

Sun 03/12/2017 to Sun 03/12/2017 **UPDATED by HQ 02/14/2017**
0001 Continuous 0200

Work scheduled by: HQ

FWD
(Import)
MOSES SOUTH **2850 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC2

Sun 03/12/2017 to Sun 03/12/2017 **UPDATED by HQ 02/14/2017**
0001 Continuous 0200

Work scheduled by: HQ

REV
(Export)
SCH - HQ - NY **500 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1000 MW

SCH-HQ-NYISO_LIMIT_1100

Sun 03/12/2017 to Sun 03/12/2017 **UPDATED by HQ 02/14/2017**
0001 Continuous 0200

Work scheduled by: HQ

FWD
(Import)
SCH - HQ - NY **1100 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1500 MW

NIAGARA_-ROCHESTR_345_NR2

Mon 03/13/2017 to Wed 03/15/2017
0500 Continuous 1200

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

BECK_-NIAGARA_345_PA302

Mon 03/13/2017 to Fri 03/17/2017
0700 Continuous 1600

Work scheduled by: IESO

FWD REV
(Import) (Export)
SCH - OH - NY **1100 MW 950 MW**
Impacts Total Transfer Capability 650 MW 950 MW
TTC with All Lines In Service 1750 MW 1900 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,February 14, 2017 to Thursday ,August 16, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA2

Mon 03/13/2017 to Sat 03/18/2017
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 10/23/2016

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

MILLWOOD_345KV_18

Tue 03/14/2017 to Fri 03/17/2017
0001 Continuous 2359

Work scheduled by: ConEd

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 750 MW
TTC with All Lines In Service 5100 MW

FWD
(Import)

ILCTLIMIT_MARCY_SO_COMP_I/S

Fri 03/17/2017 to Mon 03/20/2017
1700 Continuous 0459

Work scheduled by: NYISO

CENTRAL EAST - VC **2740 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 2975 MW

FWD
(Import)

LADENTWN-BUCHAN_S_345_Y88

Sat 03/18/2017 to Mon 03/20/2017
0001 Continuous 2359

Work scheduled by: ConEd

UPNY CONED **4150 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 5100 MW

FWD
(Import)

NINEMILE-CLAY_345_8

Mon 03/20/2017 to Wed 03/22/2017
0001 Continuous 0400

Work scheduled by: NGrid

UPDATED by NGRID 01/25/2017

OSWEGO EXPORT **5150 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 5250 MW

FWD
(Import)

FRASANX-COOPERS_345_UCC2-41

Mon 03/20/2017 to Fri 03/24/2017
0500 Continuous 1630

Work scheduled by: NYPA

UPDATED by NYISO 10/27/2016

CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

FWD
(Import)

MARCY-FRASANX_345_UCC2-41

Mon 03/20/2017 to Fri 03/24/2017
0500 Continuous 1630

Work scheduled by: NYPA

UPDATED by NYISO 10/27/2016

ARR: 19

CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

FWD
(Import)

NYISO TRANSFER LIMITATIONS

Tuesday ,February 14, 2017 to Thursday ,August 16, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA2					FWD
Mon 03/20/2017	to	Sat 03/25/2017			(Import)
0700	Continuous	1530			MOSES SOUTH 2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW
					TTC with All Lines In Service 3150 MW
BERKSHIR-ALPS 345_393					FWD REV
Fri 03/24/2017	to	Fri 03/24/2017	<u>UPDATED</u>	<u>by NG</u>	<u>12/27/2016</u>
0800	Daily(No Weekends)	0900			(Import) (Export)
Work scheduled by: NGrid					SCH - NE - NY 1300 MW 1300 MW
					Impacts Total Transfer Capability 100 MW 300 MW
					TTC with All Lines In Service 1400 MW 1600 MW
BERKSHIR-ALPS 345_393					FWD REV
Fri 03/24/2017	to	Fri 03/24/2017	<u>UPDATED</u>	<u>by NG</u>	<u>12/27/2016</u>
0800	Daily(No Weekends)	0900			(Import) (Export)
Work scheduled by: NGrid					SCH - NPX_1385 100 MW 100 MW
					Impacts Total Transfer Capability 100 MW 100 MW
					TTC with All Lines In Service 200 MW 200 MW
BERKSHIR-ALPS 345_393 & BERKSHIR-NORTHFLD_345_312					FWD REV
Fri 03/24/2017	to	Fri 03/24/2017			(Import) (Export)
0800		0900			SCH - NE - NY 1300 MW 1300 MW
Work scheduled by:					Impacts Total Transfer Capability 100 MW 300 MW
					TTC with All Lines In Service 1400 MW 1600 MW
BERKSHIR-NORTHFLD_345_312					FWD REV
Fri 03/24/2017	to	Sat 04/22/2017			(Import) (Export)
0800	Continuous	1600			SCH - NE - NY 1400 MW 1450 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability 0 MW 150 MW
					TTC with All Lines In Service 1400 MW 1600 MW
BERKSHIR-NORTHFLD_345_312					FWD REV
Fri 03/24/2017	to	Sat 04/22/2017			(Import) (Export)
0800	Continuous	1600			SCH - NPX_1385 100 MW 100 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability 100 MW 100 MW
					TTC with All Lines In Service 200 MW 200 MW
ILCTLMT_MARCY_SO_COMP_I/S					FWD
Fri 03/24/2017	to	Mon 04/17/2017			(Import)
1700	Continuous	0900			CENTRAL EAST - VC 2740 MW
Work scheduled by: NYISO					Impacts Total Transfer Capability 235 MW
					TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,February 14, 2017 to Thursday ,August 16, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_8

Sat 03/25/2017 to Thu 03/30/2017 **UPDATED by CONED 02/07/2017**
 0201 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
315 MW
 SCH - PJM_HTP
 Impacts Total Transfer Capability 345 MW
 TTC with All Lines In Service 660 MW

MARCY___345KV_CSC

Mon 03/27/2017 to Thu 04/13/2017
 0500 Continuous 1630
 Work scheduled by: NYPA

FWD
 (Import)
2925 MW
 CENTRAL EAST - VC
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

MARCY___345KV_CSC & ILCTLIMIT_MARCY_SO_COMP_I/S

Mon 03/27/2017 to Thu 04/13/2017
 0500 1630
 Work scheduled by:

FWD
 (Import)
2690 MW
 CENTRAL EAST - VC
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MA2

Mon 03/27/2017 to Sat 04/01/2017 **UPDATED by NYPA 10/23/2016**
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
2300 MW
 MOSES SOUTH
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

FRASER___-GILBOA___345_GF5-35

Mon 03/27/2017 to Fri 04/07/2017
 0900 Continuous 1430
 Work scheduled by: NYSEG

FWD
 (Import)
2650 MW
 CENTRAL EAST - VC
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

LINDN_CG-LNDVFT___345_V-3022

Sun 04/02/2017 to Fri 04/07/2017
 1400 Continuous 1800
 Work scheduled by: PJM

FWD REV
 (Import) (Export)
0 MW 0 MW
 SCH - PJM_VFT
 Impacts Total Transfer Capability 315 MW 315 MW
 TTC with All Lines In Service 315 MW 315 MW

MOSES___-ADIRNDCK_230_MA1

Mon 04/03/2017 to Sat 04/08/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
2300 MW
 MOSES SOUTH
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,February 14, 2017 to Thursday ,August 16, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
HOMRC_NY-MAINS_NY_345_47							
Mon 04/03/2017	to	Fri 04/14/2017	<u>UPDATED</u>	<u>by PJM</u>	<u>01/26/2017</u>		
0800	Continuous	1600					
Work scheduled by: NYSEG						SCH - PJ - NY	2300 MW
						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	2300 MW
							1450 MW
MAINESBG-WATRCURE_345_30							
Mon 04/03/2017	to	Fri 04/14/2017	<u>UPDATED</u>	<u>by PJM</u>	<u>01/26/2017</u>		
0800	Continuous	1600					
Work scheduled by: NYSEG						SCH - PJ - NY	2200 MW
						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	2300 MW
							1450 MW
W49TH_ST_345KV_6							
Wed 04/05/2017	to	Sun 04/09/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>02/07/2017</u>		
0001	Continuous	0200					
Work scheduled by: ConEd						SCH - PJM_HTP	315 MW
						Impacts Total Transfer Capability	345 MW
						TTC with All Lines In Service	660 MW
SCH-IMO-NYISO_LIMIT_500							
Fri 04/07/2017	to	Fri 04/07/2017					
0700	Continuous	1530					
Work scheduled by: NYPA						SCH - OH - NY	800 MW
						Impacts Total Transfer Capability	950 MW
						TTC with All Lines In Service	1750 MW
COOPERS_-ROCKTVRN_345_CCRT-42							
Mon 04/10/2017	to	Mon 04/24/2017					
0630	Continuous	1700					
Work scheduled by: NYPA						CENTRAL EAST - VC	2720 MW
						Impacts Total Transfer Capability	255 MW
						TTC with All Lines In Service	2975 MW
MOSES_-ADIRNDCK_230_MAI							
Mon 04/10/2017	to	Thu 04/13/2017					
0700	Continuous	1530					
Work scheduled by: NYPA						MOSES SOUTH	2300 MW
						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
N.SCTLND-LEEDS_345_93							
Mon 04/10/2017	to	Mon 04/10/2017					
1100	Daily(No Weekends)	1500					
Work scheduled by: NGrid						CENTRAL EAST - VC	2650 MW
						Impacts Total Transfer Capability	325 MW
						TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,February 14, 2017 to Thursday ,August 16, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS__-PLSNTVLY_345_92

Tue 04/11/2017 to Thu 04/13/2017
 0730 Continuous 1600
 Work scheduled by: NGrid

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 1300 MW
 TTC with All Lines In Service 5100 MW

SHOR_NPX-SHOREHAM_138_CSC

Mon 04/17/2017 to Sat 04/22/2017
 0500 Continuous 1600
 Work scheduled by: LI

FWD REV
 (Import) (Export)
 SCH - NPX_CSC **0 MW 0 MW**
 Impacts Total Transfer Capability 330 MW 330 MW
 TTC with All Lines In Service 330 MW 330 MW

MOSES__-ADIRNDCK_230_MA2

Mon 04/17/2017 to Sat 04/22/2017 **UPDATED by NYPA 10/23/2016**
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

FRASER__-COOPERS__345_33

Mon 04/17/2017 to Fri 04/21/2017 **UPDATED by NY 01/12/2017**
 0900 Continuous 1400
 Work scheduled by: NYSEG

FWD
 (Import)
 CENTRAL EAST - VC **2395 MW**
 Impacts Total Transfer Capability 580 MW
 TTC with All Lines In Service 2975 MW

W49TH_ST_345KV_6

Thu 04/20/2017 to Thu 04/20/2017 **UPDATED by CONED 02/07/2017**
 0230 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **315 MW**
 Impacts Total Transfer Capability 345 MW
 TTC with All Lines In Service 660 MW

MARION__-FARRAGUT_345_C3403

Fri 04/21/2017 to Sat 05/20/2017 **UPDATED by CE 01/28/2017**
 0001 Continuous 2359
 Work scheduled by: PJM

FWD REV
 (Import) (Export)
 SCH - PJ - NY **2300 MW 1450 MW**
 Impacts Total Transfer Capability 0 MW 0 MW
 TTC with All Lines In Service 2300 MW 1450 MW

ILCTLIMIT_MARCY_SO_COMP_I/S

Fri 04/21/2017 to Sat 05/27/2017
 1400 Continuous 0459
 Work scheduled by: NYISO

FWD
 (Import)
 CENTRAL EAST - VC **2740 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,February 14, 2017 to Thursday ,August 16, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS _____ 345_393		FWD	REV
Sat 04/22/2017 to Sat 04/22/2017		(Import)	(Export)
1500 Daily 1600		SCH - NE - NY	1300 MW 1300 MW
Work scheduled by: NGrid	ARR: 78	Impacts Total Transfer Capability	100 MW 300 MW
		TTC with All Lines In Service	1400 MW 1600 MW
<hr/>			
BERKSHIR-ALPS _____ 345_393		FWD	REV
Sat 04/22/2017 to Sat 04/22/2017		(Import)	(Export)
1500 Daily 1600		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: NGrid	ARR: 78	Impacts Total Transfer Capability	100 MW 100 MW
		TTC with All Lines In Service	200 MW 200 MW
<hr/>			
BERKSHIR-ALPS _____ 345_393 & BERKSHIR-NORTHFLD 345_312		FWD	REV
Sat 04/22/2017 to Sat 04/22/2017		(Import)	(Export)
1500 1600		SCH - NE - NY	1300 MW 1300 MW
Work scheduled by:	ARR: 78	Impacts Total Transfer Capability	100 MW 300 MW
		TTC with All Lines In Service	1400 MW 1600 MW
<hr/>			
CLAY _____ -EDIC _____ 345_1-16		FWD	
Mon 04/24/2017 to Tue 04/25/2017		(Import)	
0630 Continuous 1530		OSWEGO EXPORT	4850 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	5250 MW
<hr/>			
STLAWRNC-MOSES _____ 230_L34P		FWD	REV
Mon 04/24/2017 to Fri 04/28/2017		(Import)	(Export)
0700 Continuous 1530		SCH - OH - NY	1750 MW 1900 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	0 MW 0 MW
		TTC with All Lines In Service	1750 MW 1900 MW
<hr/>			
MOSES _____ -ADIRNDCK 230_MA2		FWD	
Mon 04/24/2017 to Sat 04/29/2017		(Import)	
0700 Continuous 1530	UPDATED by NYPA 10/23/2016	MOSES SOUTH	2300 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	850 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
ALCOA _____ -DENNISON 115_12		FWD	REV
Wed 04/26/2017 to Wed 04/26/2017		(Import)	(Export)
0700 Daily(No Weekends) 1800		SCH - HQ_CEDARS	100 MW 100 MW
Work scheduled by: NGrid	ARR: 38	Impacts Total Transfer Capability	99 MW 0 MW
		TTC with All Lines In Service	199 MW 100 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,February 14, 2017 to Thursday ,August 16, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ALCOA___-DENNISON_115_12 & ALCOA___-NOGDNRG_115_13

Wed 04/26/2017 to Wed 04/26/2017
0700 1800

Work scheduled by:

ARR: 38

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	100 MW	60 MW
Impacts Total Transfer Capability	99 MW	40 MW
TTC with All Lines In Service	199 MW	100 MW

ILCTLIMIT_115KV_ALCOA_R8105_TIE_B

Wed 04/26/2017 to Wed 04/26/2017
0700 Daily(No Weekends) 1800

Work scheduled by: NGrid

	FWD
	(Import)
MOSES SOUTH	3100 MW
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	3150 MW

ILCTLIMIT_115KV_ALCOA_R8105_TIE_B

Wed 04/26/2017 to Wed 04/26/2017
0700 Daily(No Weekends) 1800

Work scheduled by: NGrid

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	100 MW	60 MW
Impacts Total Transfer Capability	99 MW	40 MW
TTC with All Lines In Service	199 MW	100 MW

NIAGARA_-ROCHESTR_345_NR2

Fri 04/28/2017 to Fri 04/28/2017
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	1700 MW
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 05/01/2017 to Tue 05/16/2017 **UPDATED by LI 02/14/2017**
0400 Continuous 1800

Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	0 MW
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 05/01/2017 to Tue 05/16/2017 **UPDATED by LI 02/14/2017**
0400 Continuous 1800

Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	0 MW
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	660 MW

MARCY___-N.SCTLND_345_18

Mon 05/01/2017 to Fri 05/05/2017
0600 Continuous 1630

Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
CENTRAL EAST - VC	2090 MW
Impacts Total Transfer Capability	885 MW
TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,February 14, 2017 to Thursday ,August 16, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-N.SCTLND_345_18 & ILCTLIMIT_MARCY_SO_COMP_I/S

Mon 05/01/2017 to Fri 05/05/2017
0600 1630

Work scheduled by:

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **1855 MW**
Impacts Total Transfer Capability 1120 MW
TTC with All Lines In Service 2975 MW

BROWNFLS-TAYLORVL_115_3

Mon 05/01/2017 to Fri 05/26/2017
0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

FWD REV
(Import) (Export)
SCH - HQ_CEDARS **70 MW 40 MW**
Impacts Total Transfer Capability 120 MW 0 MW
TTC with All Lines In Service 190 MW 40 MW

ROCHESTR-PANNELL__345_RP2

Mon 05/01/2017 to Mon 05/01/2017
0630 Continuous 0700

Work scheduled by: RGE

FWD
(Import)
DYSINGER EAST **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

PANNELL_-CLAY_____345_2

Mon 05/01/2017 to Fri 05/05/2017
0630 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

ROCHESTR-PANNELL__345_RP2

Fri 05/05/2017 to Fri 05/05/2017
1500 Continuous 1530

Work scheduled by: RGE

FWD
(Import)
DYSINGER EAST **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

PANNELL_-CLAY_____345_2

Mon 05/08/2017 to Mon 05/08/2017
0700 Continuous 0730

Work scheduled by: RGE

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

ROCHESTR-PANNELL__345_RP2

Mon 05/08/2017 to Wed 05/10/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,February 14, 2017 to Thursday ,August 16, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROSETON_-ROCKTVRN_345_311

FWD

Mon 05/08/2017 to Fri 05/26/2017

(Import)

0800 Continuous 1600

UPNY CONED

4400 MW

Work scheduled by: CHGE

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 5100 MW

PANNELL_-CLAY_345_2

FWD

Wed 05/10/2017 to Wed 05/10/2017

(Import)

1500 Continuous 1530

WEST CENTRAL

1300 MW

Work scheduled by: RGE

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

FRASER_-GILBOA_345_GF5-35

FWD

Mon 05/15/2017 to Fri 05/19/2017

(Import)

0630 Continuous 1700

CENTRAL EAST - VC

2650 MW

Work scheduled by: NYPA

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

STONYRDG-HILLSIDE_230_72

FWD

Mon 05/15/2017 to Mon 05/15/2017

(Import)

0800 Continuous 1700

DYSINGER EAST

2850 MW

Work scheduled by: NYSEG

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

FRASER_345_FRASER SVC

FWD

Mon 05/15/2017 to Fri 05/19/2017

(Import)

0900 Continuous 1430

CENTRAL EAST - VC

2935 MW

Work scheduled by: NYSEG

Impacts Total Transfer Capability 40 MW

TTC with All Lines In Service 2975 MW

FRASER_345_FRASER SVC & ILCTLIMIT_MARCY_SO_COMP_I/S

FWD

Mon 05/15/2017 to Fri 05/19/2017

(Import)

0900 1430

CENTRAL EAST - VC

2700 MW

Work scheduled by:

Impacts Total Transfer Capability 275 MW

TTC with All Lines In Service 2975 MW

RAMAPO_-LADENTWN_345_W72

FWD

Tue 05/16/2017 to Tue 05/16/2017

(Import)

0001 Continuous 2330

UPNY CONED

4400 MW

Work scheduled by: ORU

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,February 14, 2017 to Thursday ,August 16, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
MARCY___765_345_AT1			FWD
Mon 05/22/2017	to	Fri 05/26/2017	(Import)
0500	Continuous	1630	
Work scheduled by: NYPA		ARR: 19	
		MOSES SOUTH	1750 MW
		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
LINDEN_-GOETHALS_230_A2253			FWD REV
Fri 05/26/2017	to	Sat 05/27/2017	(Import) (Export)
0001	Continuous	2359	
Work scheduled by: PJM		UPDATED by CE 02/01/2017	
		SCH - PJ - NY	2050 MW 1300 MW
		Impacts Total Transfer Capability	0 MW 0 MW
		TTC with All Lines In Service	2050 MW 1300 MW
<hr/>			
MARCY___-N.SCTLND_345_18			FWD
Sat 05/27/2017	to	Sat 05/27/2017	(Import)
0500	Continuous	1530	
Work scheduled by: NYPA		ARR: 19	
		CENTRAL EAST - VC	2090 MW
		Impacts Total Transfer Capability	885 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
ILCTLIMIT_MARCY_SO_COMP_I/S			FWD
Sat 05/27/2017	to	Sat 08/05/2017	(Import)
1600	Continuous	0459	
Work scheduled by: NYISO			
		CENTRAL EAST - VC	2740 MW
		Impacts Total Transfer Capability	235 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
BROWNFLS-TAYLORVL_115_4			FWD REV
Tue 05/30/2017	to	Sat 06/24/2017	(Import) (Export)
0600	Continuous	1900	
Work scheduled by: NGrid		ARR: 38	
		SCH - HQ_CEDARS	70 MW 40 MW
		Impacts Total Transfer Capability	120 MW 0 MW
		TTC with All Lines In Service	190 MW 40 MW
<hr/>			
STONYRDG-HILLSIDE_230_72			FWD
Mon 06/05/2017	to	Mon 06/05/2017	(Import)
0800	Continuous	1000	
Work scheduled by: NYSEG			
		DYSINGER EAST	2850 MW
		Impacts Total Transfer Capability	300 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
STONYRDG-HILLSIDE_230_72			FWD
Fri 06/09/2017	to	Fri 06/09/2017	(Import)
1500	Continuous	1700	
Work scheduled by: NYSEG			
		DYSINGER EAST	2850 MW
		Impacts Total Transfer Capability	300 MW
		TTC with All Lines In Service	3150 MW
<hr/>			

NYISO TRANSFER LIMITATIONS

Tuesday ,February 14, 2017 to Thursday ,August 16, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
BROWNFLS-TAYLORVL_115_3					
Mon 06/26/2017	to	Sat 07/01/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_3					
Wed 07/05/2017	to	Sat 07/22/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_4					
Mon 07/24/2017	to	Sat 08/19/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
MARCY___-N.SCTLND_345_18					
Sat 08/05/2017	to	Sat 08/05/2017			
0500	Continuous	1530			
Work scheduled by: NYPA			ARR: 19		
				FWD	
				(Import)	
				CENTRAL EAST - VC	2090 MW
				Impacts Total Transfer Capability	885 MW
				TTC with All Lines In Service	2975 MW
MARCY___765_345_AT2					
Sat 08/05/2017	to	Sat 08/05/2017			
0500	Continuous	1530			
Work scheduled by: NYPA			ARR: 19		
				FWD	
				(Import)	
				MOSES SOUTH	1700 MW
				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
ILCTLIMIT_MARCY_SO_COMP_I/S					
Sat 08/05/2017	to	Mon 11/06/2017			
1600	Continuous	0559			
Work scheduled by: NYISO					
				FWD	
				(Import)	
				CENTRAL EAST - VC	2740 MW
				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	2975 MW
BROWNFLS-TAYLORVL_115_3					
Mon 08/21/2017	to	Fri 09/01/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,February 14, 2017 to Thursday ,August 16, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2

Tue 09/05/2017 to Sun 09/10/2017
0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

BROWNFLS-TAYLORVL_115_3

Tue 09/05/2017 to Sat 09/16/2017
0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

FWD REV
(Import) (Export)
SCH - HQ_CEDARS **70 MW 40 MW**
Impacts Total Transfer Capability 120 MW 0 MW
TTC with All Lines In Service 190 MW 40 MW

HURLYAVE-ROSETON__345_303

Mon 09/11/2017 to Fri 09/29/2017
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 5100 MW

SPRNBRK_-DUNWODIE_345_W75

Fri 09/15/2017 to Sun 09/17/2017
2200 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

SPRNBRK__345KV_RNS3

Fri 09/15/2017 to Sun 09/17/2017
2200 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

BROWNFLS-TAYLORVL_115_4

Mon 09/18/2017 to Fri 10/13/2017
0600 Continuous 1600

Work scheduled by: NGrid

ARR: 38

FWD REV
(Import) (Export)
SCH - HQ_CEDARS **70 MW 40 MW**
Impacts Total Transfer Capability 120 MW 0 MW
TTC with All Lines In Service 190 MW 40 MW

GILBOA_-N.SCTLND_345_GNS-1

Mon 09/18/2017 to Fri 10/06/2017
0630 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2520 MW**
Impacts Total Transfer Capability 455 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,February 14, 2017 to Thursday ,August 16, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA__345_230_AT4

Mon 09/18/2017 to Tue 09/19/2017
0700 Continuous 1530

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1750 MW	1300 MW
Impacts Total Transfer Capability	0 MW	300 MW
TTC with All Lines In Service	1750 MW	1600 MW

NIAGARA_-ROCHESTR_345_NR2

Mon 10/02/2017 to Fri 10/06/2017
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	1700 MW
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

CHATGUAY-MASSENA__765_7040

Sat 10/14/2017 to Sat 10/28/2017
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	1550 MW
Impacts Total Transfer Capability	1600 MW
TTC with All Lines In Service	3150 MW

CHATGUAY-MASSENA__765_7040

Sat 10/14/2017 to Sat 10/28/2017
0700 Continuous 1530

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	0 MW	0 MW
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

MARCY___765_345_AT1

Sat 10/14/2017 to Sat 10/28/2017
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
MOSES SOUTH	1750 MW
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	3150 MW

MARCY___765_345_AT2

Sat 10/14/2017 to Sat 10/28/2017
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
MOSES SOUTH	1700 MW
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

MASSENA_-MARCY___765_MSU1

Sat 10/14/2017 to Sat 10/28/2017
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	2265 MW
Impacts Total Transfer Capability	710 MW
TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,February 14, 2017 to Thursday ,August 16, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>MASSENA_-MARCY___765_MSU1</p> <p>Sat 10/14/2017 to Sat 10/28/2017 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import) MOSES SOUTH 500 MW Impacts Total Transfer Capability 2650 MW TTC with All Lines In Service 3150 MW</p>
<p>MASSENA_-MARCY___765_MSU1</p> <p>Sat 10/14/2017 to Sat 10/28/2017 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p>FWD REV (Import) (Export) SCH - HQ - NY 475 MW 1000 MW Impacts Total Transfer Capability 1025 MW 0 MW TTC with All Lines In Service 1500 MW 1000 MW</p>
<p>MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040</p> <p>Sat 10/14/2017 to Sat 10/28/2017 0700 1530</p> <p>Work scheduled by:</p>	<p>FWD (Import) MOSES SOUTH 500 MW Impacts Total Transfer Capability 2650 MW TTC with All Lines In Service 3150 MW</p>
<p>MASSENA_-MARCY___765_MSU1 & ILCTLIMIT_MARCY_SO_COMP_I/S</p> <p>Sat 10/14/2017 to Sat 10/28/2017 0700 1530</p> <p>Work scheduled by:</p>	<p>FWD (Import) CENTRAL EAST - VC 2080 MW Impacts Total Transfer Capability 895 MW TTC with All Lines In Service 2975 MW</p>
<p>MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2</p> <p>Sat 10/14/2017 to Sat 10/28/2017 0700 1530</p> <p>Work scheduled by:</p>	<p>FWD REV (Import) (Export) SCH - HQ - NY 850 MW 0 MW Impacts Total Transfer Capability 650 MW 1000 MW TTC with All Lines In Service 1500 MW 1000 MW</p>
<p>LEEDS_-HURLYAVE_345_301</p> <p>Mon 10/16/2017 to Fri 11/03/2017 0800 Continuous 1600</p> <p>Work scheduled by: CHGE</p>	<p>FWD (Import) UPNY CONED 4100 MW Impacts Total Transfer Capability 1000 MW TTC with All Lines In Service 5100 MW</p>
<p>BROWNFLS-TAYLORVL_115_3</p> <p>Mon 10/30/2017 to Sat 11/11/2017 0700 Continuous 1900</p> <p>Work scheduled by: NGrid</p>	<p>FWD REV (Import) (Export) SCH - HQ_CEDARS 70 MW 40 MW Impacts Total Transfer Capability 120 MW 0 MW TTC with All Lines In Service 190 MW 40 MW</p>

UPDATED by NGRID 09/01/2016

ARR: 38

NYISO TRANSFER LIMITATIONS

Tuesday ,February 14, 2017 to Thursday ,August 16, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASANX-COOPERS__345_UCC2-41				FWD	
Mon 11/06/2017	to	Fri 11/17/2017		(Import)	
0600	Continuous	1700	CENTRAL EAST - VC	2500 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	475 MW	
			TTC with All Lines In Service	2975 MW	
MARCY__-FRASANX_345_UCC2-41				FWD	
Mon 11/06/2017	to	Fri 11/17/2017		(Import)	
0600	Continuous	1700	CENTRAL EAST - VC	2500 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	475 MW	
			TTC with All Lines In Service	2975 MW	
BROWNFLS-TAYLORVL_115_4				FWD	REV
Mon 11/13/2017	to	Thu 11/30/2017	<u>UPDATED</u>	(Import)	(Export)
0600	Continuous	1900	<u>by NGRID</u>	SCH - HQ_CEDARS	100 MW
Work scheduled by: NGrid			<u>08/25/2016</u>	Impacts Total Transfer Capability	99 MW
			ARR: 19	TTC with All Lines In Service	199 MW
			ARR: 38	100 MW	100 MW
ILCTLIMIT_MARCY_SO_COMP_I/S				FWD	
Fri 11/17/2017	to	Sat 02/01/2020		(Import)	
1700	Continuous	0000		CENTRAL EAST - VC	2740 MW
Work scheduled by: NYISO				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	2975 MW
MARCY__765_345_AT2				FWD	
Mon 12/04/2017	to	Fri 12/08/2017		(Import)	
0500	Continuous	1630		MOSES SOUTH	1700 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1450 MW
			ARR: 19	TTC with All Lines In Service	3150 MW
MOSES__-ADIRNDCK_230_MA2				FWD	
Mon 12/11/2017	to	Fri 12/15/2017		(Import)	
0700	Continuous	1530		MOSES SOUTH	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
MOSES__-ADIRNDCK_230_MA2				FWD	
Mon 12/18/2017	to	Fri 12/22/2017	<u>UPDATED</u>	(Import)	
0700	Continuous	1530	<u>by NYPA</u>	MOSES SOUTH	2300 MW
Work scheduled by: NYPA			<u>10/23/2016</u>	Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,February 14, 2017 to Thursday ,August 16, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

FWD

Tue 12/26/2017 to Thu 12/28/2017
 0700 Continuous 1530

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW