

NYISO TRANSFER LIMITATIONS

Monday ,February 13, 2017 to Wednesday, August 15, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Outage ID	Start Date	End Date	Reason	By	Effective Date	SCH	FWD (Import)	REV (Export)
RAMAPO___345_345_PAR3500	Fri 06/24/2016	Thu 06/01/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>01/11/2017</u>	SCH - PJ - NY	2200 MW	1450 MW
1940	Continuous	2359				Impacts Total Transfer Capability	100 MW	0 MW
Work scheduled by: ConEd						TTC with All Lines In Service	2300 MW	1450 MW
PLSNTVLE-DUNWODIE_345_W89	Sun 10/30/2016	Sat 04/15/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>02/01/2017</u>	UPNY CONED	4000 MW	
0728	Continuous	2359				Impacts Total Transfer Capability	1100 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	5100 MW	
HUDSONTP-W49TH_ST_345_Y56	Thu 11/24/2016	Mon 05/01/2017	<u>EXTENDED</u>	<u>by PJM</u>	<u>01/27/2017</u>	SCH - PJM_HTP	0 MW	
1500	Continuous	2359				Impacts Total Transfer Capability	660 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	660 MW	
E13THSTA-FARRAGUT_345_46	Tue 12/20/2016	Thu 04/20/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>02/07/2017</u>	SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0300				Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	4600 MW	
W49TH_ST-E13THSTA_345_M55	Tue 12/20/2016	Thu 04/20/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>02/07/2017</u>	SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0300				Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	4600 MW	
SCH-IMO-NYISO_LIMIT_1200	Thu 01/19/2017	Tue 02/21/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>01/13/2017</u>	SCH - OH - NY	1500 MW	
1900	Continuous	1700				Impacts Total Transfer Capability	250 MW	
Work scheduled by: NYPA						TTC with All Lines In Service	1750 MW	
LEEDS___345_LEEDS SVC	Mon 01/30/2017	Fri 02/24/2017				CENTRAL EAST - VC	2950 MW	
0800	Continuous	1600				Impacts Total Transfer Capability	25 MW	
Work scheduled by: NGrid						TTC with All Lines In Service	2975 MW	

NYISO TRANSFER LIMITATIONS

Monday ,February 13, 2017 to Wednesday, August 15, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD		
MOSES -ADIRNDCK_230_MA2						(Import)		
Mon 02/06/2017	to	Fri 02/10/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/23/2016</u>	MOSES SOUTH	2300 MW	
0700	Continuous	1530				Impacts Total Transfer Capability	850 MW	
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW	
NRTH1385-NOR HBR_138_601						FWD	REV	
Mon 02/06/2017	to	Sat 02/25/2017		<u>by LI</u>	<u>01/11/2017</u>	(Import)	(Export)	
0700	Continuous	2359				SCH - NPX_1385	100 MW	100 MW
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW	100 MW
						TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_602						FWD	REV	
Mon 02/06/2017	to	Sat 02/25/2017				(Import)	(Export)	
0700		2359				SCH - NPX_1385	0 MW	0 MW
Work scheduled by:						Impacts Total Transfer Capability	200 MW	200 MW
						TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_603						FWD	REV	
Mon 02/06/2017	to	Sat 02/25/2017				(Import)	(Export)	
0700		2359				SCH - NPX_1385	0 MW	0 MW
Work scheduled by:						Impacts Total Transfer Capability	200 MW	200 MW
						TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR_138_602						FWD	REV	
Mon 02/06/2017	to	Sat 02/25/2017		<u>by LI</u>	<u>01/11/2017</u>	(Import)	(Export)	
0700	Continuous	2359				SCH - NPX_1385	100 MW	100 MW
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW	100 MW
						TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR_138_602 & NRTH1385-NOR HBR_138_603						FWD	REV	
Mon 02/06/2017	to	Sat 02/25/2017				(Import)	(Export)	
0700		2359				SCH - NPX_1385	0 MW	0 MW
Work scheduled by:						Impacts Total Transfer Capability	200 MW	200 MW
						TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR_138_603						FWD	REV	
Mon 02/06/2017	to	Sat 02/25/2017		<u>by LI</u>	<u>01/11/2017</u>	(Import)	(Export)	
0700	Continuous	2359				SCH - NPX_1385	100 MW	100 MW
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW	100 MW
						TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Monday ,February 13, 2017 to Wednesday, August 15, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
NRTH1385-NRTHPORT_138_1385					
Mon 02/06/2017	to	Sat 02/25/2017	<u>by LI</u>	<u>01/11/2017</u>	
0700	Continuous	2359			
Work scheduled by: LI				SCH - NPX_1385	0 MW
				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW
BROWNFLS-TAYLORVL_115_4					
Sat 02/11/2017	to	Sat 02/11/2017			
0600	Daily	1900			
Work scheduled by: NGrid				ARR: 38	
				SCH - HQ_CEDARS	100 MW
				Impacts Total Transfer Capability	99 MW
				TTC with All Lines In Service	199 MW
VOLNEY__-MARCY___345_19					
Mon 02/13/2017	to	Mon 02/13/2017	CANCELLED	<u>by NGrid</u>	<u>02/13/2017</u>
0700	Daily(No Weekends)	1630			
Work scheduled by: NGrid				ARR: 19	
				CENTRAL EAST - VC	2825 MW
				Impacts Total Transfer Capability	150 MW
				TTC with All Lines In Service	2975 MW
VOLNEY__-MARCY___345_19					
Mon 02/13/2017	to	Mon 02/13/2017	CANCELLED	<u>by NGrid</u>	<u>02/13/2017</u>
0700	Daily(No Weekends)	1630			
Work scheduled by: NGrid				ARR: 19	
				OSWEGO EXPORT	4900 MW
				Impacts Total Transfer Capability	350 MW
				TTC with All Lines In Service	5250 MW
MOSES__-ADIRNDCK_230_MAI					
Tue 02/14/2017	to	Fri 02/17/2017			
0700	Continuous	1530			
Work scheduled by: NYPA					
				MOSES SOUTH	2300 MW
				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
SCH-IMO-NYISO_LIMIT_1000					
Tue 02/14/2017	to	Fri 02/17/2017			
0800	Continuous	1600			
Work scheduled by: PJM					
				SCH - OH - NY	1300 MW
				Impacts Total Transfer Capability	450 MW
				TTC with All Lines In Service	1750 MW
SCH-NYISO-PJM_LIMIT_100					
Tue 02/14/2017	to	Fri 02/17/2017			
0800	Continuous	1600			
Work scheduled by: PJM					
				SCH - PJ - NY	400 MW
				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	1450 MW

NYISO TRANSFER LIMITATIONS

Monday ,February 13, 2017 to Wednesday, August 15, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GILBOA -LEEDS 345_GL3				FWD	
Wed 02/15/2017	to	Thu 02/16/2017		(Import)	
0600	Continuous	1600	CENTRAL EAST - VC	2200 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	775 MW	
			TTC with All Lines In Service	2975 MW	
LEEDS 345KV_R395				FWD	
Wed 02/15/2017	to	Thu 02/16/2017		(Import)	
0600	Continuous	1600	UPNY CONED	3800 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	1300 MW	
			TTC with All Lines In Service	5100 MW	
VOLNEY -MARCY 345_19				FWD	
Wed 02/15/2017	to	Wed 02/15/2017		(Import)	
0630	Daily(No Weekends)	1459	CENTRAL EAST - VC	2825 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	150 MW	
			TTC with All Lines In Service	2975 MW	ARR: 19
VOLNEY -MARCY 345_19				FWD	
Wed 02/15/2017	to	Wed 02/15/2017		(Import)	
0630	Daily(No Weekends)	1459	OSWEGO EXPORT	4900 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	350 MW	
			TTC with All Lines In Service	5250 MW	ARR: 19
BULYMO -BOONVILLE 115_6				FWD	REV
Wed 02/15/2017	to	Wed 02/15/2017		(Import)	(Export)
1300	Daily(No Weekends)	1530	SCH - HQ_CEDARS	199 MW	100 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	0 MW	0 MW
			TTC with All Lines In Service	199 MW	100 MW
TAYLORVL-BULYMO 115_6				FWD	REV
Wed 02/15/2017	to	Wed 02/15/2017		(Import)	(Export)
1300	Daily(No Weekends)	1530	SCH - HQ_CEDARS	199 MW	100 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	0 MW	0 MW
			TTC with All Lines In Service	199 MW	100 MW
FITZPTRK-EDIC 345_FE-1				FWD	
Wed 02/15/2017	to	Thu 02/16/2017	UPDATED	(Import)	
1500	Continuous	0500	by PA	CENTRAL EAST - VC	2825 MW
Work scheduled by: NYPA			02/12/2017	Impacts Total Transfer Capability	150 MW
				TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Monday ,February 13, 2017 to Wednesday, August 15, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FITZPTRK-EDIC _____ 345_FE-1					FWD	
Wed 02/15/2017	to	Thu 02/16/2017	UPDATED	by PA	02/12/2017	(Import)
1500	Continuous	0500				OSWEGO EXPORT 4800 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 450 MW
						TTC with All Lines In Service 5250 MW
LEEDS _____ 345_LEEDS SVC & ILCTLIMIT_MARCY_SO_COMP_I/S					FWD	
Thu 02/16/2017	to	Fri 02/24/2017				(Import)
0600		1600				CENTRAL EAST - VC 2715 MW
Work scheduled by:						Impacts Total Transfer Capability 260 MW
						TTC with All Lines In Service 2975 MW
ILCTLIMIT_MARCY_SO_COMP_I/S					FWD	
Thu 02/16/2017	to	Mon 03/06/2017				(Import)
0600	Continuous	0559				CENTRAL EAST - VC 2740 MW
Work scheduled by: NYISO						Impacts Total Transfer Capability 235 MW
						TTC with All Lines In Service 2975 MW
OSWEGO _____ -VOLNEY _____ 345_12					FWD	
Thu 02/16/2017	to	Thu 02/16/2017				(Import)
0630	Daily(No Weekends)	1630				OSWEGO EXPORT 5250 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 0 MW
						TTC with All Lines In Service 5250 MW
W49TH_ST_345KV_6					FWD	
Fri 02/17/2017	to	Thu 03/30/2017	UPDATED	by CONED	02/07/2017	(Import)
0001	Continuous	0300				SCH - PJM_HTP 315 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 345 MW
						TTC with All Lines In Service 660 MW
BROWNFLS-TAYLORVL_115_3					FWD	REV
Sat 02/18/2017	to	Sat 02/18/2017				(Import) (Export)
0600	Daily	1900				SCH - HQ_CEDARS 100 MW 100 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 99 MW 0 MW
				ARR: 38		TTC with All Lines In Service 199 MW 100 MW
BECK _____ -NIAGARA _____ 230_PA27					FWD	REV
Tue 02/21/2017	to	Sat 02/25/2017				(Import) (Export)
0645	Continuous	1700				SCH - OH - NY 1750 MW 1900 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 0 MW 0 MW
						TTC with All Lines In Service 1750 MW 1900 MW

NYISO TRANSFER LIMITATIONS

Monday ,February 13, 2017 to Wednesday, August 15, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA1

Tue 02/21/2017 to Fri 02/24/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

BROWNFLS-TAYLORVL_115_4

Sat 02/25/2017 to Sat 02/25/2017
 0600 Daily 1900
 Work scheduled by: NGrid

ARR: 38

FWD REV
 (Import) (Export)
SCH - HQ_CEDARS 100 MW 100 MW
 Impacts Total Transfer Capability 99 MW 0 MW
 TTC with All Lines In Service 199 MW 100 MW

MOSES -ADIRNDCK_230_MA1

Mon 02/27/2017 to Fri 03/03/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

LAFAYTTE-CLRKSCRN_345_4-46

Tue 02/28/2017 to Tue 02/28/2017 **UPDATED by NGRID 02/10/2017**
 0700 Daily(No Weekends) 1300
 Work scheduled by: NGrid

FWD
 (Import)
CENTRAL EAST - VC 2650 MW
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

DUNWODIE-SHORE_RD_345_Y50

Wed 03/01/2017 to Mon 03/20/2017
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
CONED - LIPA 800 MW
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 1500 MW

SHORE_RD_345_138_BK 1

Wed 03/01/2017 to Mon 03/20/2017
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
CONED - LIPA 1350 MW
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 1500 MW

SHORE_RD_345_138_BK 2

Wed 03/01/2017 to Mon 03/20/2017
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
CONED - LIPA 1350 MW
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 1500 MW

NYISO TRANSFER LIMITATIONS

Monday ,February 13, 2017 to Wednesday, August 15, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

COOPERS_-ROCKTVRN_345_CCRT-42

Wed 03/01/2017 to Wed 03/15/2017
 0500 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2720 MW**
 Impacts Total Transfer Capability 255 MW
 TTC with All Lines In Service 2975 MW

CLRKSCRN-OAKDALE_345_36

Wed 03/01/2017 to Wed 03/01/2017
 0700 Continuous 1500
 Work scheduled by: NYSEG

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

BECK_-PACKARD_230_BP76

Wed 03/01/2017 to Wed 03/01/2017 **CANCELLED by NGrid 02/09/2017**
 0700 Daily(No Weekends) 1700
 Work scheduled by: NGrid

FWD REV
 (Import) (Export)
 SCH - OH - NY **1000 MW 1400 MW**
 Impacts Total Transfer Capability 750 MW 500 MW
 TTC with All Lines In Service 1750 MW 1900 MW

BECK_-NIAGARA_345_PA302

Sat 03/04/2017 to Sat 03/04/2017 **UPDATED by OH 02/08/2017**
 0400 Continuous 1700
 Work scheduled by: IESO

FWD REV
 (Import) (Export)
 SCH - OH - NY **1100 MW 950 MW**
 Impacts Total Transfer Capability 650 MW 950 MW
 TTC with All Lines In Service 1750 MW 1900 MW

BROWNFLS-TAYLORVL_115_3

Sat 03/04/2017 to Sat 03/04/2017
 0600 Daily 1900
 Work scheduled by: NGrid **ARR: 38**

FWD REV
 (Import) (Export)
 SCH - HQ_CEDARS **100 MW 100 MW**
 Impacts Total Transfer Capability 99 MW 0 MW
 TTC with All Lines In Service 199 MW 100 MW

CHAT_DC_GC1

Sun 03/05/2017 to Sun 03/05/2017
 0001 Continuous 0200
 Work scheduled by: HQ

FWD
 (Import)
 MOSES SOUTH **2850 MW**
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

CHAT_DC_GC1

Sun 03/05/2017 to Sun 03/05/2017
 0001 Continuous 0200
 Work scheduled by: HQ

REV
 (Export)
 SCH - HQ - NY **500 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 1000 MW

NYISO TRANSFER LIMITATIONS

Monday ,February 13, 2017 to Wednesday, August 15, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1 & CHAT_DC_GC2				FWD
Sun 03/05/2017	to	Sun 03/05/2017		(Import)
0001		0200	MOSES SOUTH	2550 MW
Work scheduled by:				Impacts Total Transfer Capability 600 MW
				TTC with All Lines In Service 3150 MW
CHAT_DC_GC1 & CHAT_DC_GC2				FWD
Sun 03/05/2017	to	Sun 03/05/2017		(Import) (Export)
0001		0200	SCH - HQ - NY	1370 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability 130 MW 1000 MW
				TTC with All Lines In Service 1500 MW 1000 MW
CHAT_DC_GC2				FWD
Sun 03/05/2017	to	Sun 03/05/2017		(Import)
0001	Continuous	0200	MOSES SOUTH	2850 MW
Work scheduled by: HQ				Impacts Total Transfer Capability 300 MW
				TTC with All Lines In Service 3150 MW
CHAT_DC_GC2				REV
Sun 03/05/2017	to	Sun 03/05/2017		(Export)
0001	Continuous	0200	SCH - HQ - NY	500 MW
Work scheduled by: HQ				Impacts Total Transfer Capability 500 MW
				TTC with All Lines In Service 1000 MW
SCH-HQ-NYISO_LIMIT_1100				FWD
Sun 03/05/2017	to	Sun 03/05/2017		(Import)
0001	Continuous	0200	SCH - HQ - NY	1100 MW
Work scheduled by: HQ				Impacts Total Transfer Capability 400 MW
				TTC with All Lines In Service 1500 MW
EDIC -FRASER 345_EF24-40				FWD
Mon 03/06/2017	to	Fri 03/17/2017	UPDATED by NY 12/02/2016	(Import)
0630	Continuous	1700	CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 475 MW
				TTC with All Lines In Service 2975 MW
MOSES -ADIRNDCK_230_MAL				FWD
Mon 03/06/2017	to	Fri 03/10/2017		(Import)
0700	Continuous	1530	MOSES SOUTH	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,February 13, 2017 to Wednesday, August 15, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
BROWNFLS-TAYLORVL_115_4					
Sat 03/11/2017	to	Sat 03/11/2017			
0600	Daily	1900	SCH - HQ_CEDARS	100 MW	100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	99 MW 0 MW
ARR: 38				TTC with All Lines In Service	199 MW 100 MW
NIAGARA - ROCHESTR_345_NR2				FWD	
Mon 03/13/2017	to	Wed 03/15/2017		(Import)	
0500	Continuous	1200	DYSINGER EAST	1700 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
BECK - NIAGARA_345_PA302				FWD	REV
Mon 03/13/2017	to	Fri 03/17/2017		(Import)	(Export)
0700	Continuous	1600	SCH - OH - NY	1100 MW	950 MW
Work scheduled by: IESO				Impacts Total Transfer Capability	650 MW 950 MW
				TTC with All Lines In Service	1750 MW 1900 MW
MOSES - ADIRNDCK_230_MA2				FWD	
Mon 03/13/2017	to	Sat 03/18/2017	UPDATED by NYPA 10/23/2016	(Import)	
0700	Continuous	1530	MOSES SOUTH	2300 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
MILLWOOD_345KV_18				FWD	
Tue 03/14/2017	to	Fri 03/17/2017		(Import)	
0001	Continuous	2359	UPNY CONED	4350 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	750 MW
				TTC with All Lines In Service	5100 MW
ILCTLIMIT_MARCY_SO_COMP_I/S				FWD	
Fri 03/17/2017	to	Mon 03/20/2017		(Import)	
1700	Continuous	0459	CENTRAL EAST - VC	2740 MW	
Work scheduled by: NYISO				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	2975 MW
LADENTWN-BUCHAN_S_345_Y88				FWD	
Sat 03/18/2017	to	Mon 03/20/2017		(Import)	
0001	Continuous	2359	UPNY CONED	4150 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	950 MW
				TTC with All Lines In Service	5100 MW

NYISO TRANSFER LIMITATIONS

Monday ,February 13, 2017 to Wednesday, August 15, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NINEMILE-CLAY _____ 345_8			FWD
Mon 03/20/2017 to Wed 03/22/2017	UPDATED	by NGRID 01/25/2017	(Import)
0001 Continuous 0400		OSWEGO EXPORT	5150 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	100 MW
		TTC with All Lines In Service	5250 MW
<hr/>			
FRASANX-COOPERS __ 345_UCC2-41			FWD
Mon 03/20/2017 to Fri 03/24/2017	UPDATED	by NYISO 10/27/2016	(Import)
0500 Continuous 1630		CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	475 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
MARCY ___- FRASANX_345_UCC2-41			FWD
Mon 03/20/2017 to Fri 03/24/2017	UPDATED	by NYISO 10/27/2016	(Import)
0500 Continuous 1630		CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	475 MW
	ARR: 19	TTC with All Lines In Service	2975 MW
<hr/>			
MOSES ___- ADIRNDCK_230_MA2			FWD
Mon 03/20/2017 to Sat 03/25/2017			(Import)
0700 Continuous 1530		MOSES SOUTH	2300 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	850 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
BERKSHIR-ALPS _____ 345_393			FWD
Fri 03/24/2017 to Fri 03/24/2017	UPDATED	by NG 12/27/2016	(Import) (Export)
0800 Daily(No Weekends) 0900		SCH - NE - NY	1300 MW 1300 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	100 MW 300 MW
	ARR: 78	TTC with All Lines In Service	1400 MW 1600 MW
<hr/>			
BERKSHIR-ALPS _____ 345_393			FWD
Fri 03/24/2017 to Fri 03/24/2017	UPDATED	by NG 12/27/2016	(Import) (Export)
0800 Daily(No Weekends) 0900		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	100 MW 100 MW
	ARR: 78	TTC with All Lines In Service	200 MW 200 MW
<hr/>			
BERKSHIR-ALPS _____ 345_393 & BERKSHIR-NORTHFLD_345_312			FWD
Fri 03/24/2017 to Fri 03/24/2017			(Import) (Export)
0800 0900		SCH - NE - NY	1300 MW 1300 MW
Work scheduled by:	ARR: 78	Impacts Total Transfer Capability	100 MW 300 MW
		TTC with All Lines In Service	1400 MW 1600 MW

NYISO TRANSFER LIMITATIONS

Monday ,February 13, 2017 to Wednesday, August 15, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
BERKSHIR-NORTHFLD_345_312					
Fri 03/24/2017	to	Sat 04/22/2017			
0800	Continuous	1600		1400 MW	1450 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	0 MW 150 MW
				TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-NORTHFLD_345_312					
Fri 03/24/2017	to	Sat 04/22/2017			
0800	Continuous	1600		100 MW	100 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
ILCTLIMIT_MARCY_SO_COMP_I/S					
Fri 03/24/2017	to	Mon 04/17/2017			
1700	Continuous	0900		2740 MW	
Work scheduled by: NYISO				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	2975 MW
W49TH_ST_345KV_8					
Sat 03/25/2017	to	Thu 03/30/2017	UPDATED by CONED 02/07/2017		
0201	Continuous	0200		315 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	345 MW
				TTC with All Lines In Service	660 MW
MARCY___345KV_CSC					
Mon 03/27/2017	to	Thu 04/13/2017			
0500	Continuous	1630		2925 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	50 MW
				TTC with All Lines In Service	2975 MW
MARCY___345KV_CSC & ILCTLIMIT_MARCY_SO_COMP_I/S					
Mon 03/27/2017	to	Thu 04/13/2017			
0500		1630		2690 MW	
Work scheduled by:				Impacts Total Transfer Capability	285 MW
				TTC with All Lines In Service	2975 MW
MOSES___-ADIRNDCK_230_MA2					
Mon 03/27/2017	to	Sat 04/01/2017	UPDATED by NYPA 10/23/2016		
0700	Continuous	1530		2300 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,February 13, 2017 to Wednesday, August 15, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>FRASER__-GILBOA__345_GF5-35</p> <p>Mon 03/27/2017 to Fri 04/07/2017</p> <p style="padding-left: 40px;">0900 Continuous 1430</p> <p>Work scheduled by: NYSEG</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>CENTRAL EAST - VC 2650 MW</p> <p>Impacts Total Transfer Capability 325 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>LINDN_CG-LNDVFT__345_V-3022</p> <p>Sun 04/02/2017 to Fri 04/07/2017</p> <p style="padding-left: 40px;">1400 Continuous 1800</p> <p>Work scheduled by: PJM</p>	<p style="text-align: right;">FWD REV</p> <p style="text-align: right;">(Import) (Export)</p> <p>SCH - PJM_VFT 0 MW 0 MW</p> <p>Impacts Total Transfer Capability 315 MW 315 MW</p> <p>TTC with All Lines In Service 315 MW 315 MW</p>
<p>MOSES__-ADIRNDCK_230_MA1</p> <p>Mon 04/03/2017 to Sat 04/08/2017</p> <p style="padding-left: 40px;">0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>MOSES SOUTH 2300 MW</p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>HOMRC_NY-MAINS_NY_345_47</p> <p>Mon 04/03/2017 to Fri 04/14/2017 <u>UPDATED</u> by PJM <u>01/26/2017</u></p> <p style="padding-left: 40px;">0800 Continuous 1600</p> <p>Work scheduled by: NYSEG</p>	<p style="text-align: right;">FWD REV</p> <p style="text-align: right;">(Import) (Export)</p> <p>SCH - PJ - NY 2300 MW 1450 MW</p> <p>Impacts Total Transfer Capability 0 MW 0 MW</p> <p>TTC with All Lines In Service 2300 MW 1450 MW</p>
<p>MAINESBG-WATRCURE_345_30</p> <p>Mon 04/03/2017 to Fri 04/14/2017 <u>UPDATED</u> by PJM <u>01/26/2017</u></p> <p style="padding-left: 40px;">0800 Continuous 1600</p> <p>Work scheduled by: NYSEG</p>	<p style="text-align: right;">FWD REV</p> <p style="text-align: right;">(Import) (Export)</p> <p>SCH - PJ - NY 2200 MW 1450 MW</p> <p>Impacts Total Transfer Capability 100 MW 0 MW</p> <p>TTC with All Lines In Service 2300 MW 1450 MW</p>
<p>W49TH_ST_345KV_6</p> <p>Wed 04/05/2017 to Sun 04/09/2017 <u>UPDATED</u> by CONED <u>02/07/2017</u></p> <p style="padding-left: 40px;">0001 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>SCH - PJM_HTP 315 MW</p> <p>Impacts Total Transfer Capability 345 MW</p> <p>TTC with All Lines In Service 660 MW</p>
<p>SCH-IMO-NYISO_LIMIT_500</p> <p>Fri 04/07/2017 to Fri 04/07/2017</p> <p style="padding-left: 40px;">0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>SCH - OH - NY 800 MW</p> <p>Impacts Total Transfer Capability 950 MW</p> <p>TTC with All Lines In Service 1750 MW</p>

NYISO TRANSFER LIMITATIONS

Monday ,February 13, 2017 to Wednesday, August 15, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

COOPERS_-ROCKTVRN_345_CCRT-42				FWD	
Mon 04/10/2017	to	Mon 04/24/2017		(Import)	
0630	Continuous	1700	CENTRAL EAST - VC	2720 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	255 MW	
			TTC with All Lines In Service	2975 MW	
MOSES_-ADIRNDCK_230_MA1				FWD	
Mon 04/10/2017	to	Thu 04/13/2017		(Import)	
0700	Continuous	1530	MOSES SOUTH	2300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
LEEDS_-PLSNTVLY_345_92				FWD	
Tue 04/11/2017	to	Thu 04/13/2017		(Import)	
0730	Continuous	1600	UPNY CONED	3800 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	1300 MW	
			TTC with All Lines In Service	5100 MW	
SHOR_NPX-SHOREHAM_138_CSC				FWD	REV
Mon 04/17/2017	to	Sat 04/22/2017		(Import)	(Export)
0500	Continuous	1600	SCH - NPX_CSC	0 MW	0 MW
Work scheduled by: LI			Impacts Total Transfer Capability	330 MW	330 MW
			TTC with All Lines In Service	330 MW	330 MW
MOSES_-ADIRNDCK_230_MA2				FWD	
Mon 04/17/2017	to	Sat 04/22/2017	UPDATED by NYPA 10/23/2016	(Import)	
0700	Continuous	1530	MOSES SOUTH	2300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
FRASER_-COOPERS_345_33				FWD	
Mon 04/17/2017	to	Fri 04/21/2017	UPDATED by NY 01/12/2017	(Import)	
0900	Continuous	1400	CENTRAL EAST - VC	2395 MW	
Work scheduled by: NYSEG			Impacts Total Transfer Capability	580 MW	
			TTC with All Lines In Service	2975 MW	
W49TH_ST_345KV_6				FWD	
Thu 04/20/2017	to	Thu 04/20/2017	UPDATED by CONED 02/07/2017	(Import)	
0230	Continuous	0300	SCH - PJM_HTP	315 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	345 MW	
			TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Monday ,February 13, 2017 to Wednesday, August 15, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA2					FWD	
Mon 04/24/2017	to	Sat 04/29/2017	UPDATED	by NYPA	10/23/2016	(Import)
0700	Continuous	1530				MOSES SOUTH 2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
NEWBRDGE_345_138_BK_1					FWD	
Wed 04/26/2017	to	Sun 04/30/2017	UPDATED	by LI	01/31/2017	(Import)
0001	Continuous	2359				SCH - PJM_NEPTUNE 375 MW
Work scheduled by: LI					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_2					FWD	
Wed 04/26/2017	to	Sun 04/30/2017	UPDATED	by LI	01/31/2017	(Import)
0001	Continuous	2359				SCH - PJM_NEPTUNE 375 MW
Work scheduled by: LI					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	660 MW
NEPTUNE -DUFFYAVE_345_NEPTUNE					FWD	
Wed 04/26/2017	to	Tue 05/16/2017	UPDATED	by LI	01/31/2017	(Import)
0001	Continuous	1800				SCH - PJM_NEPTUNE 0 MW
Work scheduled by: LI					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
NEWBRDGE-DUFFYAVE_345_501					FWD	
Wed 04/26/2017	to	Tue 05/16/2017	UPDATED	by LI	01/31/2017	(Import)
0001	Continuous	1800				SCH - PJM_NEPTUNE 0 MW
Work scheduled by: LI					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
ALCOA -DENNISON_115_12					FWD	REV
Wed 04/26/2017	to	Wed 04/26/2017				(Import) (Export)
0700	Daily(No Weekends)	1800				SCH - HQ_CEDARS 100 MW 100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	99 MW 0 MW
					TTC with All Lines In Service	199 MW 100 MW
ALCOA -DENNISON_115_12 & ALCOA -NOGDNRG_115_13					FWD	REV
Wed 04/26/2017	to	Wed 04/26/2017				(Import) (Export)
0700		1800				SCH - HQ_CEDARS 100 MW 60 MW
Work scheduled by:					Impacts Total Transfer Capability	99 MW 40 MW
					TTC with All Lines In Service	199 MW 100 MW

ARR: 38

ARR: 38

NYISO TRANSFER LIMITATIONS

Monday ,February 13, 2017 to Wednesday, August 15, 2018

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ILCTLIMIT_115KV_ALCOA_R8105_TIE_B	FWD	REV
Wed 04/26/2017 to Wed 04/26/2017	(Import)	
0700 Daily(No Weekends) 1800	MOSES SOUTH 3100 MW	
Work scheduled by: NGrid	Impacts Total Transfer Capability 50 MW	
	TTC with All Lines In Service 3150 MW	
<hr/>		
ILCTLIMIT_115KV_ALCOA_R8105_TIE_B	FWD	REV
Wed 04/26/2017 to Wed 04/26/2017	(Import)	(Export)
0700 Daily(No Weekends) 1800	SCH - HQ_CEDARS 100 MW	60 MW
Work scheduled by: NGrid	Impacts Total Transfer Capability 99 MW	40 MW
	TTC with All Lines In Service 199 MW	100 MW
<hr/>		
NIAGARA_-ROCHESTR_345_NR2	FWD	
Fri 04/28/2017 to Fri 04/28/2017	(Import)	
0700 Continuous 1530	DYSINGER EAST 1700 MW	
Work scheduled by: NYPA	Impacts Total Transfer Capability 1450 MW	
	TTC with All Lines In Service 3150 MW	
<hr/>		
MARCY_-N.SCTLND_345_18	FWD	
Mon 05/01/2017 to Fri 05/05/2017	(Import)	
0600 Continuous 1630	CENTRAL EAST - VC 2090 MW	
Work scheduled by: NYPA	Impacts Total Transfer Capability 885 MW	
	TTC with All Lines In Service 2975 MW	
	ARR: 19	
<hr/>		
MARCY_-N.SCTLND_345_18 & ILCTLIMIT_MARCY_SO_COMP_I/S	FWD	
Mon 05/01/2017 to Fri 05/05/2017	(Import)	
0600 1630	CENTRAL EAST - VC 1855 MW	
Work scheduled by:	Impacts Total Transfer Capability 1120 MW	
	TTC with All Lines In Service 2975 MW	
	ARR: 19	
<hr/>		
BROWNFLS-TAYLORVL_115_3	FWD	REV
Mon 05/01/2017 to Fri 05/26/2017	(Import)	(Export)
0600 Continuous 1900	SCH - HQ_CEDARS 70 MW	40 MW
Work scheduled by: NGrid	Impacts Total Transfer Capability 120 MW	0 MW
	TTC with All Lines In Service 190 MW	40 MW
	ARR: 38	
<hr/>		
ROCHESTR-PANNELL_345_RP2	FWD	
Mon 05/01/2017 to Mon 05/01/2017	(Import)	
0630 Continuous 0700	DYSINGER EAST 2300 MW	
Work scheduled by: RGE	Impacts Total Transfer Capability 850 MW	
	TTC with All Lines In Service 3150 MW	

NYISO TRANSFER LIMITATIONS

Monday ,February 13, 2017 to Wednesday, August 15, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_____345_2

Mon 05/01/2017 to Fri 05/05/2017
 0630 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

ROCHESTR-PANNELL___345_RP2

Fri 05/05/2017 to Fri 05/05/2017
 1500 Continuous 1530
 Work scheduled by: RGE

FWD
 (Import)
 DYSINGER EAST **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

PANNELL_-CLAY_____345_2

Mon 05/08/2017 to Mon 05/08/2017
 0700 Continuous 0730
 Work scheduled by: RGE

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

ROCHESTR-PANNELL___345_RP2

Mon 05/08/2017 to Wed 05/10/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

ROSETON_-ROCKTVRN_345_311

Mon 05/08/2017 to Fri 05/26/2017
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4400 MW**
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 5100 MW

PANNELL_-CLAY_____345_2

Wed 05/10/2017 to Wed 05/10/2017
 1500 Continuous 1530
 Work scheduled by: RGE

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

FRASER_-GILBOA___345_GF5-35

Mon 05/15/2017 to Fri 05/19/2017
 0630 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Monday ,February 13, 2017 to Wednesday, August 15, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STONYRDG-HILLSIDE_230_72				FWD	
Mon 05/15/2017	to	Mon 05/15/2017		(Import)	
0800	Continuous	1700	DYSINGER EAST	2850 MW	
Work scheduled by: NYSEG				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	3150 MW
FRASER_345_FRASER SVC				FWD	
Mon 05/15/2017	to	Fri 05/19/2017		(Import)	
0900	Continuous	1430	CENTRAL EAST - VC	2935 MW	
Work scheduled by: NYSEG				Impacts Total Transfer Capability	40 MW
				TTC with All Lines In Service	2975 MW
FRASER_345_FRASER SVC & ILCTLIMT_MARCY_SO_COMP_I/S				FWD	
Mon 05/15/2017	to	Fri 05/19/2017		(Import)	
0900		1430	CENTRAL EAST - VC	2700 MW	
Work scheduled by:				Impacts Total Transfer Capability	275 MW
				TTC with All Lines In Service	2975 MW
RAMAPO_-LADENTWN_345_W72				FWD	
Tue 05/16/2017	to	Tue 05/16/2017		(Import)	
0001	Continuous	2330	UPNY CONED	4400 MW	
Work scheduled by: ORU				Impacts Total Transfer Capability	700 MW
				TTC with All Lines In Service	5100 MW
MARCY_765_345_AT1				FWD	
Mon 05/22/2017	to	Fri 05/26/2017		(Import)	
0500	Continuous	1630	MOSES SOUTH	1750 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	3150 MW
LINDEN_-GOETHALS_230_A2253				FWD	REV
Fri 05/26/2017	to	Sat 05/27/2017	UPDATED	(Import)	(Export)
0001	Continuous	2359	by CE	SCH - PJ - NY	2050 MW 1300 MW
Work scheduled by: PJM				Impacts Total Transfer Capability	0 MW 0 MW
				TTC with All Lines In Service	2050 MW 1300 MW
MARCY_-N.SCTLND_345_18				FWD	
Sat 05/27/2017	to	Sat 05/27/2017		(Import)	
0500	Continuous	1530	CENTRAL EAST - VC	2090 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	885 MW
				TTC with All Lines In Service	2975 MW

ARR: 19

ARR: 19

NYISO TRANSFER LIMITATIONS

Monday ,February 13, 2017 to Wednesday, August 15, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ILCTLIMIT_MARCY_SO_COMP_I/S			FWD		
Sat 05/27/2017	to	Sat 08/05/2017	(Import)		
1600	Continuous	0459		CENTRAL EAST - VC	2740 MW
Work scheduled by: NYISO				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	2975 MW
<hr/>					
BROWNFLS-TAYLORVL_115_4			FWD	REV	
Tue 05/30/2017	to	Sat 06/24/2017	(Import)	(Export)	
0600	Continuous	1900		SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
ARR: 38					
<hr/>					
BROWNFLS-TAYLORVL_115_3			FWD	REV	
Mon 06/26/2017	to	Sat 07/01/2017	(Import)	(Export)	
0600	Continuous	1900		SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
ARR: 38					
<hr/>					
BROWNFLS-TAYLORVL_115_3			FWD	REV	
Wed 07/05/2017	to	Sat 07/22/2017	(Import)	(Export)	
0600	Continuous	1900		SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
ARR: 38					
<hr/>					
BROWNFLS-TAYLORVL_115_4			FWD	REV	
Mon 07/24/2017	to	Sat 08/19/2017	(Import)	(Export)	
0600	Continuous	1900		SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
ARR: 38					
<hr/>					
MARCY___-N.SCTLND_345_18			FWD		
Sat 08/05/2017	to	Sat 08/05/2017	(Import)		
0500	Continuous	1530		CENTRAL EAST - VC	2090 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	885 MW
				TTC with All Lines In Service	2975 MW
ARR: 19					
<hr/>					
MARCY___765_345_AT2			FWD		
Sat 08/05/2017	to	Sat 08/05/2017	(Import)		
0500	Continuous	1530		MOSES SOUTH	1700 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
ARR: 19					

NYISO TRANSFER LIMITATIONS

Monday ,February 13, 2017 to Wednesday, August 15, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ILCTLIMIT_MARCY_SO_COMP_I/S	FWD	REV
Sat 08/05/2017 to Mon 11/06/2017	(Import)	
1600 Continuous 0559	CENTRAL EAST - VC	2740 MW
Work scheduled by: NYISO	Impacts Total Transfer Capability	235 MW
	TTC with All Lines In Service	2975 MW
BROWNFLS-TAYLORVL_115_3	FWD	REV
Mon 08/21/2017 to Fri 09/01/2017	(Import)	(Export)
0600 Continuous 1900	SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid	Impacts Total Transfer Capability	120 MW 0 MW
ARR: 38	TTC with All Lines In Service	190 MW 40 MW
MARCY___765_345_AT2	FWD	
Tue 09/05/2017 to Sun 09/10/2017	(Import)	
0500 Continuous 1630	MOSES SOUTH	1700 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	1450 MW
ARR: 19	TTC with All Lines In Service	3150 MW
BROWNFLS-TAYLORVL_115_3	FWD	REV
Tue 09/05/2017 to Sat 09/16/2017	(Import)	(Export)
0600 Continuous 1900	SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid	Impacts Total Transfer Capability	120 MW 0 MW
ARR: 38	TTC with All Lines In Service	190 MW 40 MW
HURLYAVE-ROSETON__345_303	FWD	
Mon 09/11/2017 to Fri 09/29/2017	(Import)	
0800 Continuous 1600	UPNY CONED	4100 MW
Work scheduled by: CHGE	Impacts Total Transfer Capability	1000 MW
	TTC with All Lines In Service	5100 MW
SPRNBRK_-DUNWODIE_345_W75	FWD	
Fri 09/15/2017 to Sun 09/17/2017	(Import)	
2200 Continuous 0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd	Impacts Total Transfer Capability	800 MW
	TTC with All Lines In Service	4600 MW
SPRNBRK__345KV_RNS3	FWD	
Fri 09/15/2017 to Sun 09/17/2017	(Import)	
2200 Continuous 0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd	Impacts Total Transfer Capability	800 MW
	TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,February 13, 2017 to Wednesday, August 15, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

			FWD	REV
			(Import)	(Export)
BROWNFLS-TAYLORVL_115_4				
Mon 09/18/2017	to	Fri 10/13/2017		
0600	Continuous	1600		
Work scheduled by: NGrid				
			SCH - HQ_CEDARS	70 MW 40 MW
			Impacts Total Transfer Capability	120 MW 0 MW
			TTC with All Lines In Service	190 MW 40 MW
			ARR: 38	
GILBOA -N.SCTLND_345_GNS-1				
Mon 09/18/2017	to	Fri 10/06/2017		
0630	Continuous	1700		
Work scheduled by: NYPA				
			CENTRAL EAST - VC	2520 MW
			Impacts Total Transfer Capability	455 MW
			TTC with All Lines In Service	2975 MW
NIAGARA_345_230_AT4				
Mon 09/18/2017	to	Tue 09/19/2017		
0700	Continuous	1530		
Work scheduled by: NYPA				
			SCH - OH - NY	1750 MW 1300 MW
			Impacts Total Transfer Capability	0 MW 300 MW
			TTC with All Lines In Service	1750 MW 1600 MW
NIAGARA -ROCHESTR_345_NR2				
Mon 10/02/2017	to	Fri 10/06/2017		
0700	Continuous	1530		
Work scheduled by: NYPA				
			DYSINGER EAST	1700 MW
			Impacts Total Transfer Capability	1450 MW
			TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA_765_7040				
Sat 10/14/2017	to	Sat 10/28/2017		
0700	Continuous	1530		
Work scheduled by: NYPA				
			MOSES SOUTH	1550 MW
			Impacts Total Transfer Capability	1600 MW
			TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA_765_7040				
Sat 10/14/2017	to	Sat 10/28/2017		
0700	Continuous	1530		
Work scheduled by: NYPA				
			SCH - HQ - NY	0 MW 0 MW
			Impacts Total Transfer Capability	1500 MW 1000 MW
			TTC with All Lines In Service	1500 MW 1000 MW
MARCY_765_345_AT1				
Sat 10/14/2017	to	Sat 10/28/2017		
0700	Continuous	1530		
Work scheduled by: NYPA				
			MOSES SOUTH	1750 MW
			Impacts Total Transfer Capability	1400 MW
			TTC with All Lines In Service	3150 MW
			ARR: 19	

NYISO TRANSFER LIMITATIONS

Monday ,February 13, 2017 to Wednesday, August 15, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2

Sat 10/14/2017 to Sat 10/28/2017
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MASSENA_-MARCY___765_MSU1

Sat 10/14/2017 to Sat 10/28/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2265 MW**
Impacts Total Transfer Capability 710 MW
TTC with All Lines In Service 2975 MW

MASSENA_-MARCY___765_MSU1

Sat 10/14/2017 to Sat 10/28/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

MASSENA_-MARCY___765_MSU1

Sat 10/14/2017 to Sat 10/28/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - HQ - NY **475 MW 1000 MW**
Impacts Total Transfer Capability 1025 MW 0 MW
TTC with All Lines In Service 1500 MW 1000 MW

MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040

Sat 10/14/2017 to Sat 10/28/2017
0700 1530

Work scheduled by:

FWD
(Import)
MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

MASSENA_-MARCY___765_MSU1 & ILCTLIMIT_MARCY_SO_COMP_I/S

Sat 10/14/2017 to Sat 10/28/2017
0700 1530

Work scheduled by:

FWD
(Import)
CENTRAL EAST - VC **2080 MW**
Impacts Total Transfer Capability 895 MW
TTC with All Lines In Service 2975 MW

MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2

Sat 10/14/2017 to Sat 10/28/2017
0700 1530

Work scheduled by:

FWD REV
(Import) (Export)
SCH - HQ - NY **850 MW 0 MW**
Impacts Total Transfer Capability 650 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Monday ,February 13, 2017 to Wednesday, August 15, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS___-HURLYAVE_345_301				FWD	
Mon 10/16/2017	to	Fri 11/03/2017		(Import)	
0800	Continuous	1600	UPNY CONED	4100 MW	
Work scheduled by: CHGE			Impacts Total Transfer Capability	1000 MW	
			TTC with All Lines In Service	5100 MW	
BROWNFLS-TAYLORVL_115_3				FWD	REV
Mon 10/30/2017	to	Sat 11/11/2017	<u>UPDATED</u> <u>by NGRID</u> <u>09/01/2016</u>	(Import)	(Export)
0700	Continuous	1900	SCH - HQ_CEDARS	70 MW	40 MW
Work scheduled by: NGrid			ARR: 38	Impacts Total Transfer Capability	120 MW 0 MW
			TTC with All Lines In Service	190 MW	40 MW
FRASANNX-COOPERS__345_UCC2-41				FWD	
Mon 11/06/2017	to	Fri 11/17/2017		(Import)	
0600	Continuous	1700	CENTRAL EAST - VC	2500 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	475 MW	
			TTC with All Lines In Service	2975 MW	
MARCY___-FRASANNX_345_UCC2-41				FWD	
Mon 11/06/2017	to	Fri 11/17/2017		(Import)	
0600	Continuous	1700	CENTRAL EAST - VC	2500 MW	
Work scheduled by: NYPA			ARR: 19	Impacts Total Transfer Capability	475 MW
			TTC with All Lines In Service	2975 MW	
BROWNFLS-TAYLORVL_115_4				FWD	REV
Mon 11/13/2017	to	Thu 11/30/2017	<u>UPDATED</u> <u>by NGRID</u> <u>08/25/2016</u>	(Import)	(Export)
0600	Continuous	1900	SCH - HQ_CEDARS	100 MW	100 MW
Work scheduled by: NGrid			ARR: 38	Impacts Total Transfer Capability	99 MW 0 MW
			TTC with All Lines In Service	199 MW	100 MW
ILCTLIMIT_MARCY_SO_COMP_I/S				FWD	
Fri 11/17/2017	to	Sat 02/01/2020		(Import)	
1700	Continuous	0000	CENTRAL EAST - VC	2740 MW	
Work scheduled by: NYISO			Impacts Total Transfer Capability	235 MW	
			TTC with All Lines In Service	2975 MW	
MARCY___765_345_AT2				FWD	
Mon 12/04/2017	to	Fri 12/08/2017		(Import)	
0500	Continuous	1630	MOSES SOUTH	1700 MW	
Work scheduled by: NYPA			ARR: 19	Impacts Total Transfer Capability	1450 MW
			TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Monday ,February 13, 2017 to Wednesday, August 15, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

Mon 12/11/2017 to Fri 12/15/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/18/2017 to Fri 12/22/2017 **UPDATED by NYPA 10/23/2016**
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Tue 12/26/2017 to Thu 12/28/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW