

NYISO TRANSFER LIMITATIONS

Sunday ,February 12, 2017 to Tuesday ,August 14, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO___345_345_PAR3500					FWD	REV
					(Import)	(Export)
Fri 06/24/2016	to	Thu 06/01/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>01/11/2017</u>	
1940	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	2200 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	2300 MW
						1450 MW
PLSNTVLE-DUNWODIE_345_W89					FWD	
					(Import)	
Sun 10/30/2016	to	Sat 04/15/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>02/01/2017</u>	
0728	Continuous	2359				
Work scheduled by: ConEd					UPNY CONED	4000 MW
					Impacts Total Transfer Capability	1100 MW
					TTC with All Lines In Service	5100 MW
HUDSONTP-W49TH_ST_345_Y56					FWD	
					(Import)	
Thu 11/24/2016	to	Mon 05/01/2017	<u>EXTENDED</u>	<u>by PJM</u>	<u>01/27/2017</u>	
1500	Continuous	2359				
Work scheduled by: ConEd					SCH - PJM_HTP	0 MW
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
E13THSTA-FARRAGUT_345_46					FWD	
					(Import)	
Tue 12/20/2016	to	Thu 04/20/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>02/07/2017</u>	
0001	Continuous	0300				
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
W49TH_ST-E13THSTA_345_M55					FWD	
					(Import)	
Tue 12/20/2016	to	Thu 04/20/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>02/07/2017</u>	
0001	Continuous	0300				
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
SCH-IMO-NYISO_LIMIT_1200					FWD	
					(Import)	
Thu 01/19/2017	to	Tue 02/21/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>01/13/2017</u>	
1900	Continuous	1700				
Work scheduled by: NYPA					SCH - OH - NY	1500 MW
					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1750 MW
LEEDS___345_LEEDS SVC					FWD	
					(Import)	
Mon 01/30/2017	to	Fri 02/24/2017				
0800	Continuous	1600				
Work scheduled by: NGrid					CENTRAL EAST - VC	2950 MW
					Impacts Total Transfer Capability	25 MW
					TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 12, 2017 to Tuesday ,August 14, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA2					FWD	
Mon 02/06/2017	to	Fri 02/10/2017	UPDATED	by NYPA	10/23/2016	(Import)
0700	Continuous	1530				2300 MW
Work scheduled by: NYPA					MOSES SOUTH	
					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW

NRTH1385-NOR HBR_138_601					FWD	REV
Mon 02/06/2017	to	Sat 02/25/2017		by LI	01/11/2017	(Import) (Export)
0700	Continuous	2359				100 MW 100 MW
Work scheduled by: LI					SCH - NPX_1385	
					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW

NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_602					FWD	REV
Mon 02/06/2017	to	Sat 02/25/2017				(Import) (Export)
0700		2359				0 MW 0 MW
Work scheduled by:					SCH - NPX_1385	
					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW

NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_603					FWD	REV
Mon 02/06/2017	to	Sat 02/25/2017				(Import) (Export)
0700		2359				0 MW 0 MW
Work scheduled by:					SCH - NPX_1385	
					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW

NRTH1385-NOR HBR_138_602					FWD	REV
Mon 02/06/2017	to	Sat 02/25/2017		by LI	01/11/2017	(Import) (Export)
0700	Continuous	2359				100 MW 100 MW
Work scheduled by: LI					SCH - NPX_1385	
					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW

NRTH1385-NOR HBR_138_602 & NRTH1385-NOR HBR_138_603					FWD	REV
Mon 02/06/2017	to	Sat 02/25/2017				(Import) (Export)
0700		2359				0 MW 0 MW
Work scheduled by:					SCH - NPX_1385	
					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW

NRTH1385-NOR HBR_138_603					FWD	REV
Mon 02/06/2017	to	Sat 02/25/2017		by LI	01/11/2017	(Import) (Export)
0700	Continuous	2359				100 MW 100 MW
Work scheduled by: LI					SCH - NPX_1385	
					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 12, 2017 to Tuesday ,August 14, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
NRTH1385-NRTHPORT_138_1385		FWD	REV
Mon 02/06/2017 to Sat 02/25/2017	<u>by LI</u> <u>01/11/2017</u>	(Import)	(Export)
0700 Continuous 2359		0 MW	0 MW
Work scheduled by: LI		SCH - NPX_1385	
		Impacts Total Transfer Capability	200 MW
		TTC with All Lines In Service	200 MW
<hr/>			
BROWNFLS-TAYLORVL_115_4		FWD	REV
Sat 02/11/2017 to Sat 02/11/2017		(Import)	(Export)
0600 Daily 1900		100 MW	100 MW
Work scheduled by: NGrid	ARR: 38	SCH - HQ_CEDARS	
		Impacts Total Transfer Capability	99 MW
		TTC with All Lines In Service	199 MW
<hr/>			
GILBOA -LEEDS 345_GL3		FWD	
Mon 02/13/2017 to Tue 02/14/2017		(Import)	
0600 Continuous 1600		2200 MW	
Work scheduled by: NGrid		CENTRAL EAST - VC	
		Impacts Total Transfer Capability	775 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
LEEDS 345KV_R395		FWD	
Mon 02/13/2017 to Tue 02/14/2017		(Import)	
0600 Continuous 1600		3800 MW	
Work scheduled by: NGrid		UPNY CONED	
		Impacts Total Transfer Capability	1300 MW
		TTC with All Lines In Service	5100 MW
<hr/>			
VOLNEY -MARCY 345_19		FWD	
Mon 02/13/2017 to Mon 02/13/2017		(Import)	
0700 Daily(No Weekends) 1630		2825 MW	
Work scheduled by: NGrid	ARR: 19	CENTRAL EAST - VC	
		Impacts Total Transfer Capability	150 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
VOLNEY -MARCY 345_19		FWD	
Mon 02/13/2017 to Mon 02/13/2017		(Import)	
0700 Daily(No Weekends) 1630		4900 MW	
Work scheduled by: NGrid	ARR: 19	OSWEGO EXPORT	
		Impacts Total Transfer Capability	350 MW
		TTC with All Lines In Service	5250 MW
<hr/>			
MOSES -ADIRNDCK_230_MAL		FWD	
Mon 02/13/2017 to Fri 02/17/2017		(Import)	
0700 Continuous 1530		2300 MW	
Work scheduled by: NYPA		MOSES SOUTH	
		Impacts Total Transfer Capability	850 MW
		TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 12, 2017 to Tuesday ,August 14, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1000

Mon 02/13/2017 to Thu 02/16/2017
 0800 Continuous 1600
 Work scheduled by: PJM

FWD
 (Import)
 SCH - OH - NY **1300 MW**
 Impacts Total Transfer Capability 450 MW
 TTC with All Lines In Service 1750 MW

SCH-NYISO-PJM_LIMIT_100

Mon 02/13/2017 to Thu 02/16/2017
 0800 Continuous 1600
 Work scheduled by: PJM

REV
 (Export)
 SCH - PJ - NY **400 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 1450 MW

LEEDS___345_LEEDS SVC & ILCTLIMIT_MARCY_SO_COMP_I/S

Wed 02/15/2017 to Fri 02/24/2017
 0600 1600
 Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC **2715 MW**
 Impacts Total Transfer Capability 260 MW
 TTC with All Lines In Service 2975 MW

ILCTLIMIT_MARCY_SO_COMP_I/S

Wed 02/15/2017 to Mon 03/06/2017
 0600 Continuous 0559
 Work scheduled by: NYISO

FWD
 (Import)
 CENTRAL EAST - VC **2740 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 2975 MW

FITZPTRK-EDIC___345_FE-1

Wed 02/15/2017 to Thu 02/16/2017 **UPDATED by PA 02/12/2017**
 1500 Continuous 0500
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2825 MW**
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 2975 MW

FITZPTRK-EDIC___345_FE-1

Wed 02/15/2017 to Thu 02/16/2017 **UPDATED by PA 02/12/2017**
 1500 Continuous 0500
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4800 MW**
 Impacts Total Transfer Capability 450 MW
 TTC with All Lines In Service 5250 MW

OSWEGO_-VOLNEY___345_12

Thu 02/16/2017 to Thu 02/16/2017
 0630 Daily(No Weekends) 1630
 Work scheduled by: NGrid

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 12, 2017 to Tuesday ,August 14, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6				FWD
Fri 02/17/2017	to	Thu 03/30/2017	UPDATED	(Import)
0001	Continuous	0300	by CONED	315 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 345 MW
				TTC with All Lines In Service 660 MW
BROWNFLS-TAYLORVL_115_3				FWD REV
Sat 02/18/2017	to	Sat 02/18/2017		(Import) (Export)
0600	Daily	1900		100 MW 100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 99 MW 0 MW
				TTC with All Lines In Service 199 MW 100 MW
BECK -NIAGARA_230_PA27				FWD REV
Tue 02/21/2017	to	Sat 02/25/2017		(Import) (Export)
0645	Continuous	1700		1750 MW 1900 MW
Work scheduled by: IESO				Impacts Total Transfer Capability 0 MW 0 MW
				TTC with All Lines In Service 1750 MW 1900 MW
MOSES -ADIRNDCK_230_MA1				FWD
Tue 02/21/2017	to	Fri 02/24/2017		(Import)
0700	Continuous	1530		2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
BROWNFLS-TAYLORVL_115_4				FWD REV
Sat 02/25/2017	to	Sat 02/25/2017		(Import) (Export)
0600	Daily	1900		100 MW 100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 99 MW 0 MW
				TTC with All Lines In Service 199 MW 100 MW
MOSES -ADIRNDCK_230_MA1				FWD
Mon 02/27/2017	to	Fri 03/03/2017		(Import)
0700	Continuous	1530		2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
LAFAYTTE-CLRKSCRN_345_4-46				FWD
Tue 02/28/2017	to	Tue 02/28/2017	UPDATED	(Import)
0700	Daily(No Weekends)	1300	by NGRID	2650 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 325 MW
				TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 12, 2017 to Tuesday ,August 14, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

COOPERS_-ROCKTVRN_345_CCRT-42

Wed 03/01/2017 to Wed 03/15/2017
 0500 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2720 MW**
 Impacts Total Transfer Capability 255 MW
 TTC with All Lines In Service 2975 MW

BECK_-PACKARD_230_BP76

Wed 03/01/2017 to Wed 03/01/2017 **CANCELLED by NGrid 02/09/2017**
 0700 Daily(No Weekends) 1700
 Work scheduled by: NGrid

FWD REV
 (Import) (Export)
 SCH - OH - NY **1000 MW 1400 MW**
 Impacts Total Transfer Capability 750 MW 500 MW
 TTC with All Lines In Service 1750 MW 1900 MW

BECK_-NIAGARA_345_PA302

Sat 03/04/2017 to Sat 03/04/2017 **UPDATED by OH 02/08/2017**
 0400 Continuous 1700
 Work scheduled by: IESO

FWD REV
 (Import) (Export)
 SCH - OH - NY **1100 MW 950 MW**
 Impacts Total Transfer Capability 650 MW 950 MW
 TTC with All Lines In Service 1750 MW 1900 MW

BROWNFLS-TAYLORVL_115_3

Sat 03/04/2017 to Sat 03/04/2017
 0600 Daily 1900
 Work scheduled by: NGrid **ARR: 38**

FWD REV
 (Import) (Export)
 SCH - HQ_CEDARS **100 MW 100 MW**
 Impacts Total Transfer Capability 99 MW 0 MW
 TTC with All Lines In Service 199 MW 100 MW

CHAT_DC_GC1

Sun 03/05/2017 to Sun 03/05/2017
 0001 Continuous 0200
 Work scheduled by: HQ

FWD
 (Import)
 MOSES SOUTH **2850 MW**
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

CHAT_DC_GC1

Sun 03/05/2017 to Sun 03/05/2017
 0001 Continuous 0200
 Work scheduled by: HQ

REV
 (Export)
 SCH - HQ - NY **500 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 1000 MW

CHAT_DC_GC1 & CHAT_DC_GC2

Sun 03/05/2017 to Sun 03/05/2017
 0001 0200
 Work scheduled by:

FWD
 (Import)
 MOSES SOUTH **2550 MW**
 Impacts Total Transfer Capability 600 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 12, 2017 to Tuesday ,August 14, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1 & CHAT_DC_GC2				FWD	REV
Sun 03/05/2017	to	Sun 03/05/2017		(Import)	(Export)
0001		0200		SCH - HQ - NY	1370 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	130 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
CHAT_DC_GC2				FWD	
Sun 03/05/2017	to	Sun 03/05/2017		(Import)	
0001	Continuous	0200		MOSES SOUTH	2850 MW
Work scheduled by: HQ				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	3150 MW
CHAT_DC_GC2					REV
Sun 03/05/2017	to	Sun 03/05/2017			(Export)
0001	Continuous	0200		SCH - HQ - NY	500 MW
Work scheduled by: HQ				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	1000 MW
SCH-HQ-NYISO_LIMIT_1100				FWD	
Sun 03/05/2017	to	Sun 03/05/2017		(Import)	
0001	Continuous	0200		SCH - HQ - NY	1100 MW
Work scheduled by: HQ				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	1500 MW
EDIC___-FRASER___345_EF24-40				FWD	
Mon 03/06/2017	to	Fri 03/17/2017	UPDATED by NY 12/02/2016	(Import)	
0630	Continuous	1700		CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	475 MW
				TTC with All Lines In Service	2975 MW
MOSES___-ADIRNDCK_230_MAI				FWD	
Mon 03/06/2017	to	Fri 03/10/2017		(Import)	
0700	Continuous	1530		MOSES SOUTH	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
BROWNFLS-TAYLORVL_115_4				FWD	REV
Sat 03/11/2017	to	Sat 03/11/2017		(Import)	(Export)
0600	Daily	1900		SCH - HQ_CEDARS	100 MW 100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	99 MW 0 MW
				TTC with All Lines In Service	199 MW 100 MW

ARR: 38

NYISO TRANSFER LIMITATIONS

Sunday ,February 12, 2017 to Tuesday ,August 14, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-ROCHESTR_345_NR2

Mon 03/13/2017 to Wed 03/15/2017
 0500 Continuous 1200
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

BECK_-NIAGARA_345_PA302

Mon 03/13/2017 to Fri 03/17/2017
 0700 Continuous 1600
 Work scheduled by: IESO

FWD REV
 (Import) (Export)
 SCH - OH - NY **1100 MW 950 MW**
 Impacts Total Transfer Capability 650 MW 950 MW
 TTC with All Lines In Service 1750 MW 1900 MW

MOSES_-ADIRNDCK_230_MA2

Mon 03/13/2017 to Sat 03/18/2017 **UPDATED by NYPA 10/23/2016**
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MILLWOOD_345KV_18

Tue 03/14/2017 to Fri 03/17/2017
 0001 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 750 MW
 TTC with All Lines In Service 5100 MW

ILCTLIMIT_MARCY_SO_COMP_I/S

Fri 03/17/2017 to Mon 03/20/2017
 1700 Continuous 0459
 Work scheduled by: NYISO

FWD
 (Import)
 CENTRAL EAST - VC **2740 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 2975 MW

LADENTWN-BUCHAN_S_345_Y88

Sat 03/18/2017 to Mon 03/20/2017
 0001 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4150 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 5100 MW

NINEMILE-CLAY_345_8

Mon 03/20/2017 to Wed 03/22/2017 **UPDATED by NGRID 01/25/2017**
 0001 Continuous 0400
 Work scheduled by: NGrid

FWD
 (Import)
 OSWEGO EXPORT **5150 MW**
 Impacts Total Transfer Capability 100 MW
 TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 12, 2017 to Tuesday ,August 14, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASANX-COOPERS__345_UCC2-41					FWD	
Mon 03/20/2017	to	Fri 03/24/2017	UPDATED	by NYISO	10/27/2016	(Import)
0500	Continuous	1630				CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW
MARCY__-FRASANX_345_UCC2-41					FWD	
Mon 03/20/2017	to	Fri 03/24/2017	UPDATED	by NYISO	10/27/2016	(Import)
0500	Continuous	1630				CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW
MOSES__-ADIRNDCK_230_MA2					FWD	
Mon 03/20/2017	to	Sat 03/25/2017				(Import)
0700	Continuous	1530				MOSES SOUTH 2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
BERKSHIR-ALPS____345_393					FWD	REV
Fri 03/24/2017	to	Fri 03/24/2017	UPDATED	by NG	12/27/2016	(Import) (Export)
0800	Daily(No Weekends)	0900				SCH - NE - NY 1300 MW 1300 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW 300 MW
					TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-ALPS____345_393					FWD	REV
Fri 03/24/2017	to	Fri 03/24/2017	UPDATED	by NG	12/27/2016	(Import) (Export)
0800	Daily(No Weekends)	0900				SCH - NPX_1385 100 MW 100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
BERKSHIR-ALPS____345_393 & BERKSHIR-NORTHFLD_345_312					FWD	REV
Fri 03/24/2017	to	Fri 03/24/2017				(Import) (Export)
0800		0900				SCH - NE - NY 1300 MW 1300 MW
Work scheduled by:					Impacts Total Transfer Capability	100 MW 300 MW
					TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-NORTHFLD_345_312					FWD	REV
Fri 03/24/2017	to	Sat 04/22/2017				(Import) (Export)
0800	Continuous	1600				SCH - NE - NY 1400 MW 1450 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability	0 MW 150 MW
					TTC with All Lines In Service	1400 MW 1600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 12, 2017 to Tuesday ,August 14, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event ID	Start Date	End Date	Time	Duration	Work Scheduled by	Transfer Capability	FWD	REV	
BERKSHIR-NORTHFLD_345_312	Fri 03/24/2017	Sat 04/22/2017	0800	Continuous	1600	ISONE	SCH - NPX_1385	100 MW	100 MW
							Impacts Total Transfer Capability	100 MW	100 MW
							TTC with All Lines In Service	200 MW	200 MW
ILCTLIMIT_MARCY_SO_COMP_I/S	Fri 03/24/2017	Mon 04/17/2017	1700	Continuous	0900	NYISO	CENTRAL EAST - VC	2740 MW	
							Impacts Total Transfer Capability	235 MW	
							TTC with All Lines In Service	2975 MW	
W49TH_ST_345KV_8	Sat 03/25/2017	Thu 03/30/2017	0201	Continuous	0200	ConEd	SCH - PJM_HTP	315 MW	
							Impacts Total Transfer Capability	345 MW	
							TTC with All Lines In Service	660 MW	
MARCY___345KV_CSC	Mon 03/27/2017	Thu 04/13/2017	0500	Continuous	1630	NYPA	CENTRAL EAST - VC	2925 MW	
							Impacts Total Transfer Capability	50 MW	
							TTC with All Lines In Service	2975 MW	
MARCY___345KV_CSC & ILCTLIMIT_MARCY_SO_COMP_I/S	Mon 03/27/2017	Thu 04/13/2017	0500		1630		CENTRAL EAST - VC	2690 MW	
							Impacts Total Transfer Capability	285 MW	
							TTC with All Lines In Service	2975 MW	
MOSES___-ADIRNDCK_230_MA2	Mon 03/27/2017	Sat 04/01/2017	0700	Continuous	1530	NYPA	MOSES SOUTH	2300 MW	
							Impacts Total Transfer Capability	850 MW	
							TTC with All Lines In Service	3150 MW	
FRASER___-GILBOA___345_GF5-35	Mon 03/27/2017	Fri 04/07/2017	0900	Continuous	1430	NYSEG	CENTRAL EAST - VC	2650 MW	
							Impacts Total Transfer Capability	325 MW	
							TTC with All Lines In Service	2975 MW	

NYISO TRANSFER LIMITATIONS

Sunday ,February 12, 2017 to Tuesday ,August 14, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDN_CG-LNDVFT___345_V-3022					FWD	REV
Sun 04/02/2017	to	Fri 04/07/2017			(Import)	(Export)
1400	Continuous	1800			0 MW	0 MW
Work scheduled by: PJM					SCH - PJM_VFT	
					Impacts Total Transfer Capability	315 MW
					TTC with All Lines In Service	315 MW
MOSES___-ADIRNDCK_230_MAI					FWD	
Mon 04/03/2017	to	Sat 04/08/2017			(Import)	
0700	Continuous	1530			2300 MW	
Work scheduled by: NYPA					MOSES SOUTH	
					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
HOMRC_NY-MAINS_NY_345_47					FWD	REV
Mon 04/03/2017	to	Fri 04/14/2017	UPDATED	by PJM	01/26/2017	(Import) (Export)
0800	Continuous	1600				
Work scheduled by: NYSEG					SCH - PJ - NY	2300 MW 1450 MW
					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	2300 MW 1450 MW
MAINESBG-WATRCURE_345_30					FWD	REV
Mon 04/03/2017	to	Fri 04/14/2017	UPDATED	by PJM	01/26/2017	(Import) (Export)
0800	Continuous	1600				
Work scheduled by: NYSEG					SCH - PJ - NY	2200 MW 1450 MW
					Impacts Total Transfer Capability	100 MW 0 MW
					TTC with All Lines In Service	2300 MW 1450 MW
W49TH_ST_345KV_6					FWD	
Wed 04/05/2017	to	Sun 04/09/2017	UPDATED	by CONED	02/07/2017	(Import)
0001	Continuous	0200				
Work scheduled by: ConEd					SCH - PJM_HTP	315 MW
					Impacts Total Transfer Capability	345 MW
					TTC with All Lines In Service	660 MW
SCH-IMO-NYISO_LIMIT_500					FWD	
Fri 04/07/2017	to	Fri 04/07/2017			(Import)	
0700	Continuous	1530			800 MW	
Work scheduled by: NYPA					SCH - OH - NY	
					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	1750 MW
COOPERS_-ROCKTVRN_345_CCRT-42					FWD	
Mon 04/10/2017	to	Mon 04/24/2017			(Import)	
0630	Continuous	1700			2720 MW	
Work scheduled by: NYPA					CENTRAL EAST - VC	
					Impacts Total Transfer Capability	255 MW
					TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 12, 2017 to Tuesday ,August 14, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES__-ADIRNDCK_230_MA1					FWD	
Mon 04/10/2017	to	Thu 04/13/2017			(Import)	
0700	Continuous	1530		MOSES SOUTH	2300 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
LEEDS__-PLSNTVLY_345_92					FWD	
Tue 04/11/2017	to	Thu 04/13/2017			(Import)	
0730	Continuous	1600		UPNY CONED	3800 MW	
Work scheduled by: NGrid					Impacts Total Transfer Capability	1300 MW
					TTC with All Lines In Service	5100 MW
SHOR_NPX-SHOREHAM_138_CSC					FWD	REV
Mon 04/17/2017	to	Sat 04/22/2017			(Import)	(Export)
0500	Continuous	1600		SCH - NPX_CSC	0 MW	0 MW
Work scheduled by: LI					Impacts Total Transfer Capability	330 MW 330 MW
					TTC with All Lines In Service	330 MW 330 MW
MOSES__-ADIRNDCK_230_MA2					FWD	
Mon 04/17/2017	to	Sat 04/22/2017	UPDATED	by NYPA	10/23/2016	
0700	Continuous	1530			MOSES SOUTH	2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
FRASER__-COOPERS_345_33					FWD	
Mon 04/17/2017	to	Fri 04/21/2017	UPDATED	by NY	01/12/2017	
0900	Continuous	1400			CENTRAL EAST - VC	2395 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability	580 MW
					TTC with All Lines In Service	2975 MW
W49TH_ST_345KV_6					FWD	
Thu 04/20/2017	to	Thu 04/20/2017	UPDATED	by CONED	02/07/2017	
0230	Continuous	0300			SCH - PJM_HTP	315 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	345 MW
					TTC with All Lines In Service	660 MW
MARION__-FARRAGUT_345_C3403					FWD	REV
Fri 04/21/2017	to	Sat 05/20/2017	UPDATED	by CE	01/28/2017	
0001	Continuous	2359			SCH - PJ - NY	2300 MW 1450 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	2300 MW 1450 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 12, 2017 to Tuesday ,August 14, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ILCTLIMIT_MARCY_SO_COMP_I/S				FWD	
Fri 04/21/2017	to	Sat 05/27/2017		(Import)	
1400	Continuous	0459		CENTRAL EAST - VC	2740 MW
Work scheduled by: NYISO				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	2975 MW
BERKSHIR-ALPS 345_393				FWD	REV
Sat 04/22/2017	to	Sat 04/22/2017		(Import)	(Export)
1500	Daily	1600		SCH - NE - NY	1300 MW 1300 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	100 MW 300 MW
				TTC with All Lines In Service	1400 MW 1600 MW
ARR: 78					
BERKSHIR-ALPS 345_393				FWD	REV
Sat 04/22/2017	to	Sat 04/22/2017		(Import)	(Export)
1500	Daily	1600		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
ARR: 78					
BERKSHIR-ALPS 345_393 & BERKSHIR-NORTHFLD 345_312				FWD	REV
Sat 04/22/2017	to	Sat 04/22/2017		(Import)	(Export)
1500		1600		SCH - NE - NY	1300 MW 1300 MW
Work scheduled by:				Impacts Total Transfer Capability	100 MW 300 MW
				TTC with All Lines In Service	1400 MW 1600 MW
ARR: 78					
CLAY -EDIC 345_1-16				FWD	
Mon 04/24/2017	to	Tue 04/25/2017		(Import)	
0630	Continuous	1530		OSWEGO EXPORT	4850 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	5250 MW
STLAWRNC-MOSES 230_L34P				FWD	REV
Mon 04/24/2017	to	Fri 04/28/2017		(Import)	(Export)
0700	Continuous	1530		SCH - OH - NY	1750 MW 1900 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	0 MW 0 MW
				TTC with All Lines In Service	1750 MW 1900 MW
MOSES -ADIRNDCK 230_MA2				FWD	
Mon 04/24/2017	to	Sat 04/29/2017		(Import)	
0700	Continuous	1530	UPDATED by NYPA 10/23/2016	MOSES SOUTH	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 12, 2017 to Tuesday ,August 14, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE_345_138_BK_1					FWD	
Wed 04/26/2017	to	Sun 04/30/2017	<u>UPDATED</u>	<u>by LI</u>	<u>01/31/2017</u>	(Import)
0001	Continuous	2359				375 MW
Work scheduled by: LI					SCH - PJM_NEPTUNE	Impacts Total Transfer Capability 285 MW
					TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_2					FWD	
Wed 04/26/2017	to	Sun 04/30/2017	<u>UPDATED</u>	<u>by LI</u>	<u>01/31/2017</u>	(Import)
0001	Continuous	2359				375 MW
Work scheduled by: LI					SCH - PJM_NEPTUNE	Impacts Total Transfer Capability 285 MW
					TTC with All Lines In Service	660 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE					FWD	
Wed 04/26/2017	to	Tue 05/16/2017	<u>UPDATED</u>	<u>by LI</u>	<u>01/31/2017</u>	(Import)
0001	Continuous	1800				0 MW
Work scheduled by: LI					SCH - PJM_NEPTUNE	Impacts Total Transfer Capability 660 MW
					TTC with All Lines In Service	660 MW
NEWBRDGE-DUFFYAVE_345_501					FWD	
Wed 04/26/2017	to	Tue 05/16/2017	<u>UPDATED</u>	<u>by LI</u>	<u>01/31/2017</u>	(Import)
0001	Continuous	1800				0 MW
Work scheduled by: LI					SCH - PJM_NEPTUNE	Impacts Total Transfer Capability 660 MW
					TTC with All Lines In Service	660 MW
ALCOA_-DENNISON_115_12					FWD	REV
Wed 04/26/2017	to	Wed 04/26/2017				(Import) (Export)
0700	Daily(No Weekends)	1800				100 MW 100 MW
Work scheduled by: NGrid					SCH - HQ_CEDARS	Impacts Total Transfer Capability 99 MW 0 MW
					TTC with All Lines In Service	199 MW 100 MW
ALCOA_-DENNISON_115_12 & ALCOA_-NOGDNRG_115_13					FWD	REV
Wed 04/26/2017	to	Wed 04/26/2017				(Import) (Export)
0700		1800				100 MW 60 MW
Work scheduled by:					SCH - HQ_CEDARS	Impacts Total Transfer Capability 99 MW 40 MW
					TTC with All Lines In Service	199 MW 100 MW
ILCTLIMIT_115KV_ALCOA_R8105_TIE_B					FWD	
Wed 04/26/2017	to	Wed 04/26/2017				(Import)
0700	Daily(No Weekends)	1800				3100 MW
Work scheduled by: NGrid					MOSES SOUTH	Impacts Total Transfer Capability 50 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 12, 2017 to Tuesday ,August 14, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ILCTLIMIT_115KV_ALCOA_R8105_TIE_B

Wed 04/26/2017 to Wed 04/26/2017
 0700 Daily(No Weekends) 1800
 Work scheduled by: NGrid

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	100 MW	60 MW
Impacts Total Transfer Capability	99 MW	40 MW
TTC with All Lines In Service	199 MW	100 MW

NIAGARA -ROCHESTR_345_NR2

Fri 04/28/2017 to Fri 04/28/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	1700 MW
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

MARCY -N.SCTLND_345_18

Mon 05/01/2017 to Fri 05/05/2017
 0600 Continuous 1630
 Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
CENTRAL EAST - VC	2090 MW
Impacts Total Transfer Capability	885 MW
TTC with All Lines In Service	2975 MW

MARCY -N.SCTLND_345_18 & ILCTLIMIT_MARCY_SO_COMP_I/S

Mon 05/01/2017 to Fri 05/05/2017
 0600 1630
 Work scheduled by:

ARR: 19

	FWD
	(Import)
CENTRAL EAST - VC	1855 MW
Impacts Total Transfer Capability	1120 MW
TTC with All Lines In Service	2975 MW

BROWNFLS-TAYLORVL_115_3

Mon 05/01/2017 to Fri 05/26/2017
 0600 Continuous 1900
 Work scheduled by: NGrid

ARR: 38

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	70 MW	40 MW
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

ROCHESTR-PANNELL_345_RP2

Mon 05/01/2017 to Mon 05/01/2017
 0630 Continuous 0700
 Work scheduled by: RGE

	FWD
	(Import)
DYSINGER EAST	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

PANNELL -CLAY_345_2

Mon 05/01/2017 to Fri 05/05/2017
 0630 Continuous 1530
 Work scheduled by: NYPA

	FWD
	(Import)
WEST CENTRAL	1300 MW
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	2250 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 12, 2017 to Tuesday ,August 14, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCHESTR-PANNELL__345_RP2			FWD
Fri 05/05/2017	to	Fri 05/05/2017	(Import)
1500	Continuous	1530	DYSINGER EAST 2300 MW
Work scheduled by: RGE			Impacts Total Transfer Capability 850 MW
			TTC with All Lines In Service 3150 MW
PANNELL_-CLAY____345_2			FWD
Mon 05/08/2017	to	Mon 05/08/2017	(Import)
0700	Continuous	0730	WEST CENTRAL 1300 MW
Work scheduled by: RGE			Impacts Total Transfer Capability 950 MW
			TTC with All Lines In Service 2250 MW
ROCHESTR-PANNELL__345_RP2			FWD
Mon 05/08/2017	to	Wed 05/10/2017	(Import)
0700	Continuous	1530	DYSINGER EAST 2300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 850 MW
			TTC with All Lines In Service 3150 MW
ROSETON_-ROCKTVRN_345_311			FWD
Mon 05/08/2017	to	Fri 05/26/2017	(Import)
0800	Continuous	1600	UPNY CONED 4400 MW
Work scheduled by: CHGE			Impacts Total Transfer Capability 700 MW
			TTC with All Lines In Service 5100 MW
PANNELL_-CLAY____345_2			FWD
Wed 05/10/2017	to	Wed 05/10/2017	(Import)
1500	Continuous	1530	WEST CENTRAL 1300 MW
Work scheduled by: RGE			Impacts Total Transfer Capability 950 MW
			TTC with All Lines In Service 2250 MW
FRASER_-GILBOA____345_GF5-35			FWD
Mon 05/15/2017	to	Fri 05/19/2017	(Import)
0630	Continuous	1700	CENTRAL EAST - VC 2650 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 325 MW
			TTC with All Lines In Service 2975 MW
STONYRDG-HILLSIDE_230_72			FWD
Mon 05/15/2017	to	Mon 05/15/2017	(Import)
0800	Continuous	1700	DYSINGER EAST 2850 MW
Work scheduled by: NYSEG			Impacts Total Transfer Capability 300 MW
			TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 12, 2017 to Tuesday ,August 14, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER___345_FRASER SVC				FWD	
Mon 05/15/2017	to	Fri 05/19/2017		(Import)	
0900	Continuous	1430	CENTRAL EAST - VC	2935 MW	
Work scheduled by: NYSEG			Impacts Total Transfer Capability	40 MW	
			TTC with All Lines In Service	2975 MW	
FRASER___345_FRASER SVC & ILCTLIMIT_MARCY_SO_COMP_I/S				FWD	
Mon 05/15/2017	to	Fri 05/19/2017		(Import)	
0900		1430	CENTRAL EAST - VC	2700 MW	
Work scheduled by:			Impacts Total Transfer Capability	275 MW	
			TTC with All Lines In Service	2975 MW	
RAMAPO__-LADENTWN_345_W72				FWD	
Tue 05/16/2017	to	Tue 05/16/2017		(Import)	
0001	Continuous	2330	UPNY CONED	4400 MW	
Work scheduled by: ORU			Impacts Total Transfer Capability	700 MW	
			TTC with All Lines In Service	5100 MW	
MARCY___765_345_AT1				FWD	
Mon 05/22/2017	to	Fri 05/26/2017		(Import)	
0500	Continuous	1630	MOSES SOUTH	1750 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1400 MW	
			TTC with All Lines In Service	3150 MW	
LINDEN__-GOETHALS_230_A2253				FWD	REV
Fri 05/26/2017	to	Sat 05/27/2017	UPDATED	(Import)	(Export)
0001	Continuous	2359	by CE	SCH - PJ - NY	2050 MW 1300 MW
Work scheduled by: PJM			02/01/2017	Impacts Total Transfer Capability	0 MW 0 MW
				TTC with All Lines In Service	2050 MW 1300 MW
MARCY___-N.SCTLND_345_18				FWD	
Sat 05/27/2017	to	Sat 05/27/2017		(Import)	
0500	Continuous	1530	CENTRAL EAST - VC	2090 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	885 MW	
			TTC with All Lines In Service	2975 MW	
ILCTLIMIT_MARCY_SO_COMP_I/S				FWD	
Sat 05/27/2017	to	Sat 08/05/2017		(Import)	
1600	Continuous	0459	CENTRAL EAST - VC	2740 MW	
Work scheduled by: NYISO			Impacts Total Transfer Capability	235 MW	
			TTC with All Lines In Service	2975 MW	

NYISO TRANSFER LIMITATIONS

Sunday ,February 12, 2017 to Tuesday ,August 14, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
BROWNFLS-TAYLORVL_115_4					
Tue 05/30/2017	to	Sat 06/24/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_3					
Mon 06/26/2017	to	Sat 07/01/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_3					
Wed 07/05/2017	to	Sat 07/22/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_4					
Mon 07/24/2017	to	Sat 08/19/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
MARCY___-N.SCTLND_345_18					
Sat 08/05/2017	to	Sat 08/05/2017			
0500	Continuous	1530			
Work scheduled by: NYPA			ARR: 19		
				CENTRAL EAST - VC	2090 MW
				Impacts Total Transfer Capability	885 MW
				TTC with All Lines In Service	2975 MW
MARCY___765_345_AT2					
Sat 08/05/2017	to	Sat 08/05/2017			
0500	Continuous	1530			
Work scheduled by: NYPA			ARR: 19		
				MOSES SOUTH	1700 MW
				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
ILCTLIMIT_MARCY_SO_COMP_I/S					
Sat 08/05/2017	to	Mon 11/06/2017			
1600	Continuous	0559			
Work scheduled by: NYISO					
				CENTRAL EAST - VC	2740 MW
				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 12, 2017 to Tuesday ,August 14, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
BROWNFLS-TAYLORVL_115_3					
Mon 08/21/2017	to	Fri 09/01/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
MARCY_765_345_AT2					
Tue 09/05/2017	to	Sun 09/10/2017			
0500	Continuous	1630			
Work scheduled by: NYPA			ARR: 19		
				MOSES SOUTH	1700 MW
				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
BROWNFLS-TAYLORVL_115_3					
Tue 09/05/2017	to	Sat 09/16/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
HURLYAVE-ROSETON_345_303					
Mon 09/11/2017	to	Fri 09/29/2017			
0800	Continuous	1600			
Work scheduled by: CHGE					
				UPNY CONED	4100 MW
				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	5100 MW
SPRNBK_-DUNWODIE_345_W75					
Fri 09/15/2017	to	Sun 09/17/2017			
2200	Continuous	0200			
Work scheduled by: ConEd					
				SPR/DUN-SOUTH	3800 MW
				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
SPRNBK_345KV_RNS3					
Fri 09/15/2017	to	Sun 09/17/2017			
2200	Continuous	0200			
Work scheduled by: ConEd					
				SPR/DUN-SOUTH	3800 MW
				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
BROWNFLS-TAYLORVL_115_4					
Mon 09/18/2017	to	Fri 10/13/2017			
0600	Continuous	1600			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 12, 2017 to Tuesday ,August 14, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GILBOA__-N.SCTLND_345_GNS-1

Mon 09/18/2017 to Fri 10/06/2017
 0630 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2520 MW**
 Impacts Total Transfer Capability 455 MW
 TTC with All Lines In Service 2975 MW

NIAGARA_345_230_AT4

Mon 09/18/2017 to Tue 09/19/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - OH - NY **1750 MW 1300 MW**
 Impacts Total Transfer Capability 0 MW 300 MW
 TTC with All Lines In Service 1750 MW 1600 MW

NIAGARA_-ROCHESTR_345_NR2

Mon 10/02/2017 to Fri 10/06/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA_765_7040

Sat 10/14/2017 to Sat 10/28/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **1550 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA_765_7040

Sat 10/14/2017 to Sat 10/28/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - HQ - NY **0 MW 0 MW**
 Impacts Total Transfer Capability 1500 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

MARCY___765_345_AT1

Sat 10/14/2017 to Sat 10/28/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1750 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Sat 10/14/2017 to Sat 10/28/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 12, 2017 to Tuesday ,August 14, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>MASSENA -MARCY 765_MSU1</p> <p>Sat 10/14/2017 to Sat 10/28/2017 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2265 MW</p> <p>Impacts Total Transfer Capability 710 MW</p> <p>TTC with All Lines In Service 2975 MW</p>															
<p>MASSENA -MARCY 765_MSU1</p> <p>Sat 10/14/2017 to Sat 10/28/2017 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 500 MW</p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p>MASSENA -MARCY 765_MSU1</p> <p>Sat 10/14/2017 to Sat 10/28/2017 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;"></td> <td style="width: 20%; text-align: right;">FWD</td> <td style="width: 20%; text-align: right;">REV</td> </tr> <tr> <td></td> <td style="text-align: right;">(Import)</td> <td style="text-align: right;">(Export)</td> </tr> <tr> <td>SCH - HQ - NY</td> <td style="text-align: right;">475 MW</td> <td style="text-align: right;">1000 MW</td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">1025 MW</td> <td style="text-align: right;">0 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td style="text-align: right;">1500 MW</td> <td style="text-align: right;">1000 MW</td> </tr> </table>		FWD	REV		(Import)	(Export)	SCH - HQ - NY	475 MW	1000 MW	Impacts Total Transfer Capability	1025 MW	0 MW	TTC with All Lines In Service	1500 MW	1000 MW
	FWD	REV														
	(Import)	(Export)														
SCH - HQ - NY	475 MW	1000 MW														
Impacts Total Transfer Capability	1025 MW	0 MW														
TTC with All Lines In Service	1500 MW	1000 MW														
<p>MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040</p> <p>Sat 10/14/2017 to Sat 10/28/2017 0700 1530</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 500 MW</p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p>MASSENA -MARCY 765_MSU1 & ILCTLIMIT_MARCY_SO_COMP_I/S</p> <p>Sat 10/14/2017 to Sat 10/28/2017 0700 1530</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2080 MW</p> <p>Impacts Total Transfer Capability 895 MW</p> <p>TTC with All Lines In Service 2975 MW</p>															
<p>MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2</p> <p>Sat 10/14/2017 to Sat 10/28/2017 0700 1530</p> <p>Work scheduled by:</p>	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;"></td> <td style="width: 20%; text-align: right;">FWD</td> <td style="width: 20%; text-align: right;">REV</td> </tr> <tr> <td></td> <td style="text-align: right;">(Import)</td> <td style="text-align: right;">(Export)</td> </tr> <tr> <td>SCH - HQ - NY</td> <td style="text-align: right;">850 MW</td> <td style="text-align: right;">0 MW</td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">650 MW</td> <td style="text-align: right;">1000 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td style="text-align: right;">1500 MW</td> <td style="text-align: right;">1000 MW</td> </tr> </table>		FWD	REV		(Import)	(Export)	SCH - HQ - NY	850 MW	0 MW	Impacts Total Transfer Capability	650 MW	1000 MW	TTC with All Lines In Service	1500 MW	1000 MW
	FWD	REV														
	(Import)	(Export)														
SCH - HQ - NY	850 MW	0 MW														
Impacts Total Transfer Capability	650 MW	1000 MW														
TTC with All Lines In Service	1500 MW	1000 MW														
<p>LEEDS -HURLYAVE 345_301</p> <p>Mon 10/16/2017 to Fri 11/03/2017 0800 Continuous 1600</p> <p>Work scheduled by: CHGE</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED 4100 MW</p> <p>Impacts Total Transfer Capability 1000 MW</p> <p>TTC with All Lines In Service 5100 MW</p>															

NYISO TRANSFER LIMITATIONS

Sunday ,February 12, 2017 to Tuesday ,August 14, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
BROWNFLS-TAYLORVL_115_3		FWD	REV
Mon 10/30/2017 to Sat 11/11/2017	UPDATED by NGRID 09/01/2016	(Import)	(Export)
0700 Continuous 1900		SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid	ARR: 38	Impacts Total Transfer Capability	120 MW 0 MW
		TTC with All Lines In Service	190 MW 40 MW
<hr/>			
FRASANX-COOPERS_345_UCC2-41		FWD	
Mon 11/06/2017 to Fri 11/17/2017		(Import)	
0600 Continuous 1700		CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	475 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
MARCY_-FRASANX_345_UCC2-41		FWD	
Mon 11/06/2017 to Fri 11/17/2017		(Import)	
0600 Continuous 1700		CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA	ARR: 19	Impacts Total Transfer Capability	475 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
BROWNFLS-TAYLORVL_115_4		FWD	REV
Mon 11/13/2017 to Thu 11/30/2017	UPDATED by NGRID 08/25/2016	(Import)	(Export)
0600 Continuous 1900		SCH - HQ_CEDARS	100 MW 100 MW
Work scheduled by: NGrid	ARR: 38	Impacts Total Transfer Capability	99 MW 0 MW
		TTC with All Lines In Service	199 MW 100 MW
<hr/>			
ILCTLIMIT_MARCY_SO_COMP_I/S		FWD	
Fri 11/17/2017 to Sat 02/01/2020		(Import)	
1700 Continuous 0000		CENTRAL EAST - VC	2740 MW
Work scheduled by: NYISO		Impacts Total Transfer Capability	235 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
MARCY_765_345_AT2		FWD	
Mon 12/04/2017 to Fri 12/08/2017		(Import)	
0500 Continuous 1630		MOSES SOUTH	1700 MW
Work scheduled by: NYPA	ARR: 19	Impacts Total Transfer Capability	1450 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
MOSES_-ADIRNDCK_230_MA2		FWD	
Mon 12/11/2017 to Fri 12/15/2017		(Import)	
0700 Continuous 1530		MOSES SOUTH	2300 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	850 MW
		TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 12, 2017 to Tuesday ,August 14, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

FWD

Mon 12/18/2017 to Fri 12/22/2017
0700 Continuous 1530

UPDATED by NYPA 10/23/2016

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

FWD

Tue 12/26/2017 to Thu 12/28/2017
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW