

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 21, 2017 to Thursday ,August 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Outage ID	Start Date	End Date	Reason	By	Effective Date	SCH	FWD (Import)	REV (Export)
<b>RAMAPO___345_345_PAR3500</b>	Fri 06/24/2016	Thu 06/01/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>01/11/2017</u>	SCH - PJ - NY	2200 MW	1450 MW
1940	Continuous	2359				Impacts Total Transfer Capability	100 MW	0 MW
Work scheduled by: ConEd						TTC with All Lines In Service	2300 MW	1450 MW
<b>PLSNTVLE-DUNWODIE_345_W89</b>	Sun 10/30/2016	Sat 04/15/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>02/01/2017</u>	UPNY CONED	4000 MW	
0728	Continuous	2359				Impacts Total Transfer Capability	1100 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	5100 MW	
<b>HUDSONTP-W49TH_ST_345_Y56</b>	Thu 11/24/2016	Mon 05/01/2017	<u>EXTENDED</u>	<u>by PJM</u>	<u>01/27/2017</u>	SCH - PJM_HTP	0 MW	
1500	Continuous	2359				Impacts Total Transfer Capability	660 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	660 MW	
<b>E13THSTA-FARRAGUT_345_46</b>	Tue 12/20/2016	Thu 04/20/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>02/07/2017</u>	SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0300				Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	4600 MW	
<b>W49TH_ST-E13THSTA_345_M55</b>	Tue 12/20/2016	Thu 04/20/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>02/07/2017</u>	SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0300				Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	4600 MW	
<b>SCH-IMO-NYISO_LIMIT_1200</b>	Thu 01/19/2017	Fri 02/17/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/17/2017</u>	SCH - OH - NY	1500 MW	
1900	Continuous	1030				Impacts Total Transfer Capability	250 MW	
Work scheduled by: NYPA						TTC with All Lines In Service	1750 MW	
<b>LEEDS___345_LEEDS SVC</b>	Mon 01/30/2017	Fri 02/24/2017				CENTRAL EAST - VC	2950 MW	
0800	Continuous	1600				Impacts Total Transfer Capability	25 MW	
Work scheduled by: NGrid						TTC with All Lines In Service	2975 MW	

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 21, 2017 to Thursday ,August 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
<b>NRTH1385-NOR HBR__138_601</b>						
Mon 02/06/2017	to	Sat 02/25/2017	<u>by LI</u>	<u>01/11/2017</u>		
0700	Continuous	2359			SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_601 &amp; NRTH1385-NOR HBR__138_602</b>						
Mon 02/06/2017	to	Sat 02/25/2017			SCH - NPX_1385	<b>0 MW</b>
0700		2359			Impacts Total Transfer Capability	200 MW
Work scheduled by:					TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_601 &amp; NRTH1385-NOR HBR__138_603</b>						
Mon 02/06/2017	to	Sat 02/25/2017			SCH - NPX_1385	<b>0 MW</b>
0700		2359			Impacts Total Transfer Capability	200 MW
Work scheduled by:					TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_602</b>						
Mon 02/06/2017	to	Sat 02/25/2017	<u>by LI</u>	<u>01/11/2017</u>		
0700	Continuous	2359			SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_602 &amp; NRTH1385-NOR HBR__138_603</b>						
Mon 02/06/2017	to	Sat 02/25/2017			SCH - NPX_1385	<b>0 MW</b>
0700		2359			Impacts Total Transfer Capability	200 MW
Work scheduled by:					TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_603</b>						
Mon 02/06/2017	to	Sat 02/25/2017	<u>by LI</u>	<u>01/11/2017</u>		
0700	Continuous	2359			SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
<b>NRTH1385-NRTHPORT_138_1385</b>						
Mon 02/06/2017	to	Sat 02/25/2017	<u>by LI</u>	<u>01/11/2017</u>		
0700	Continuous	2359			SCH - NPX_1385	<b>0 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	200 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 21, 2017 to Thursday ,August 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MOSES -ADIRNDCK_230_MA1</b>				FWD
Tue 02/14/2017	to	Fri 02/17/2017		(Import)
0700	Continuous	1530		MOSES SOUTH <b>2300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
<b>GILBOA -LEEDS_345_GL3</b>				FWD
Thu 02/16/2017	to	Fri 02/17/2017	<b><u>EXTENDED</u> by NGRID <u>02/18/2017</u></b>	(Import)
0600	Continuous	1600		CENTRAL EAST - VC <b>2200 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 775 MW
				TTC with All Lines In Service 2975 MW
<b>LEEDS_345KV_R395</b>				FWD
Thu 02/16/2017	to	Fri 02/17/2017	<b><u>EXTENDED</u> by NGRID <u>02/18/2017</u></b>	(Import)
0600	Continuous	1600		UPNY CONED <b>3800 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 1300 MW
				TTC with All Lines In Service 5100 MW
<b>OSWEGO -VOLNEY_345_12</b>				FWD
Thu 02/16/2017	to	Thu 02/16/2017		(Import)
0630	Daily(No Weekends)	1630		OSWEGO EXPORT <b>5250 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 0 MW
				TTC with All Lines In Service 5250 MW
<b>W49TH_ST_345KV_6</b>				FWD
Fri 02/17/2017	to	Thu 03/30/2017	<b><u>UPDATED</u> by CONED <u>02/07/2017</u></b>	(Import)
0001	Continuous	0300		SCH - PJM_HTP <b>315 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 345 MW
				TTC with All Lines In Service 660 MW
<b>BROWNFLS-TAYLORVL_115_3</b>				FWD REV
Sat 02/18/2017	to	Sat 02/18/2017		(Import) (Export)
0600	Daily	1900		SCH - HQ_CEDARS <b>100 MW 100 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 99 MW 0 MW
<b>ARR: 38</b>				TTC with All Lines In Service 199 MW 100 MW
<b>FITZPTRK-EDIC_345_FE-1</b>				FWD
Sat 02/18/2017	to	Sat 02/18/2017		(Import)
0700	Daily	1500		CENTRAL EAST - VC <b>2825 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 150 MW
				TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 21, 2017 to Thursday ,August 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>FITZPTRK-EDIC</b> _____ <b>345_FE-1</b>				FWD	
Sat 02/18/2017	to	Sat 02/18/2017		(Import)	
0700	Daily	1500	OSWEGO EXPORT	<b>4800 MW</b>	
Work scheduled by: NGrid			Impacts Total Transfer Capability	450 MW	
			TTC with All Lines In Service	5250 MW	
<b>OSWEGO</b> _____ <b>-VOLNEY</b> _____ <b>345_12</b>				FWD	
Tue 02/21/2017	to	Tue 02/21/2017		(Import)	
0630	Daily(No Weekends)	1630	OSWEGO EXPORT	<b>5250 MW</b>	
Work scheduled by: NGrid			Impacts Total Transfer Capability	0 MW	
			TTC with All Lines In Service	5250 MW	
<b>BECK</b> _____ <b>-NIAGARA</b> _____ <b>230_PA27</b>				FWD	REV
Tue 02/21/2017	to	Sat 02/25/2017		(Import)	(Export)
0645	Continuous	1700	SCH - OH - NY	<b>1750 MW</b>	<b>1900 MW</b>
Work scheduled by: IESO			Impacts Total Transfer Capability	0 MW	0 MW
			TTC with All Lines In Service	1750 MW	1900 MW
<b>MOSES</b> _____ <b>-ADIRNDCK</b> _____ <b>230_MA1</b>				FWD	
Tue 02/21/2017	to	Fri 02/24/2017		(Import)	
0700	Continuous	1530	MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
<b>NINEMILE-CLAY</b> _____ <b>345_8</b>				FWD	
Tue 02/21/2017	to	Wed 02/22/2017		(Import)	
1231	Continuous	1800	OSWEGO EXPORT	<b>5150 MW</b>	
Work scheduled by: NGrid			Impacts Total Transfer Capability	100 MW	
			TTC with All Lines In Service	5250 MW	
<b>SCH-IMO-NYISO_LIMIT</b> _____ <b>900</b>				FWD	
Wed 02/22/2017	to	Wed 02/22/2017	<b>UPDATED</b>	(Import)	
0500	Continuous	1700	<b>by NYISO</b> <b>02/17/2017</b>	SCH - OH - NY	<b>1200 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	550 MW	
			TTC with All Lines In Service	1750 MW	
<b>FITZPTRK-EDIC</b> _____ <b>345_FE-1</b>				FWD	
Fri 02/24/2017	to	Fri 02/24/2017	<b>UPDATED</b>	(Import)	
0100	Continuous	0900	<b>by PA</b> <b>02/20/2017</b>	CENTRAL EAST - VC	<b>2825 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	150 MW	
			TTC with All Lines In Service	2975 MW	

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 21, 2017 to Thursday ,August 23, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p><b>FITZPTRK-EDIC</b> _____ <b>345_FE-1</b></p> <p>Fri 02/24/2017 to Fri 02/24/2017 <b>UPDATED by PA 02/20/2017</b></p> <p>0100 Continuous 0900</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>OSWEGO EXPORT <b>4800 MW</b></p> <p>Impacts Total Transfer Capability 450 MW</p> <p>TTC with All Lines In Service 5250 MW</p>
<p><b>LEEDS</b> _____ <b>345_LEEDS SVC &amp; ILCTLIMIT_MARCY_SO_COMP_I/S</b></p> <p>Fri 02/24/2017 to Fri 02/24/2017</p> <p>0900 1600</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC <b>2715 MW</b></p> <p>Impacts Total Transfer Capability 260 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p><b>ILCTLIMIT_MARCY_SO_COMP_I/S</b></p> <p>Fri 02/24/2017 to Mon 03/06/2017</p> <p>0900 Continuous 0559</p> <p>Work scheduled by: NYISO</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC <b>2740 MW</b></p> <p>Impacts Total Transfer Capability 235 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p><b>BROWNFLS-TAYLORVL_115_4</b></p> <p>Sat 02/25/2017 to Sat 02/25/2017</p> <p>0600 Daily 1900</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - HQ_CEDARS <b>100 MW 100 MW</b></p> <p>Impacts Total Transfer Capability 99 MW 0 MW</p> <p>TTC with All Lines In Service 199 MW 100 MW</p>
<p><b>CHAT_DC_GC2</b></p> <p>Sat 02/25/2017 to Sat 02/25/2017</p> <p>0800 Continuous 1700</p> <p>Work scheduled by: HQ</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH <b>2850 MW</b></p> <p>Impacts Total Transfer Capability 300 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p><b>CHAT_DC_GC2</b></p> <p>Sat 02/25/2017 to Sat 02/25/2017</p> <p>0800 Continuous 1700</p> <p>Work scheduled by: HQ</p>	<p style="text-align: right;">REV (Export)</p> <p>SCH - HQ - NY <b>500 MW</b></p> <p>Impacts Total Transfer Capability 500 MW</p> <p>TTC with All Lines In Service 1000 MW</p>
<p><b>MOSES</b> _____ <b>-ADIRNDCK_230_MAL</b></p> <p>Mon 02/27/2017 to Fri 03/03/2017</p> <p>0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH <b>2300 MW</b></p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 21, 2017 to Thursday ,August 23, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**LAFAYTTE-CLRKSCRN\_345\_4-46**

Tue 02/28/2017 to Tue 02/28/2017  
0700 Daily(No Weekends) 1300

Work scheduled by: NGrid

**UPDATED by NGRID 02/10/2017**

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

**DUNWODIE-SHORE\_RD\_345\_Y50**

Wed 03/01/2017 to Mon 03/20/2017  
0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **800 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1500 MW

**SHORE\_RD\_345\_138\_BK 1**

Wed 03/01/2017 to Mon 03/20/2017  
0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

**SHORE\_RD\_345\_138\_BK 2**

Wed 03/01/2017 to Mon 03/20/2017  
0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

**COOPERS\_-ROCKTVRN\_345\_CCRT-42**

Wed 03/01/2017 to Fri 03/24/2017  
0500 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2720 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

**CLRKSCRN-OAKDALE\_345\_36**

Wed 03/01/2017 to Wed 03/01/2017  
0700 Continuous 1500

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

**BECK\_-NIAGARA\_345\_PA302**

Sat 03/04/2017 to Sat 03/04/2017  
0400 Continuous 1700

Work scheduled by: IESO

**UPDATED by OH 02/08/2017**

FWD REV  
(Import) (Export)  
SCH - OH - NY **1100 MW 950 MW**  
Impacts Total Transfer Capability 650 MW 950 MW  
TTC with All Lines In Service 1750 MW 1900 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 21, 2017 to Thursday ,August 23, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BROWNFLS-TAYLORVL_115_3</b>					FWD	REV
Sat 03/04/2017	to	Sat 03/04/2017			(Import)	(Export)
0600	Daily	1900		SCH - HQ_CEDARS	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	99 MW
					TTC with All Lines In Service	199 MW
						100 MW
<b>W49TH_ST_345KV_8</b>					FWD	
Mon 03/06/2017	to	Mon 03/06/2017			(Import)	
0001	Continuous	0030		SCH - PJM_HTP	<b>315 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	345 MW
					TTC with All Lines In Service	660 MW
<b>HUDSONP_-FARRAGUT_345_B3402</b>					FWD	REV
Mon 03/06/2017	to	Thu 04/20/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>02/17/2017</u>	(Import) (Export)
0001	Continuous	2359		SCH - PJ - NY	<b>2300 MW</b>	<b>1450 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	2300 MW
						1450 MW
<b>HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>					FWD	REV
Mon 03/06/2017	to	Thu 04/20/2017			(Import) (Export)	
0001		2359		SCH - PJ - NY	<b>2050 MW</b>	<b>1450 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	2300 MW
						1450 MW
<b>MARION_-FARRAGUT_345_C3403</b>					FWD	REV
Mon 03/06/2017	to	Thu 04/20/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>02/17/2017</u>	(Import) (Export)
0001	Continuous	2359		SCH - PJ - NY	<b>2300 MW</b>	<b>1450 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	2300 MW
						1450 MW
<b>SCH-HQ_CEDARS-NYISO_LIMIT_160</b>					FWD	
Mon 03/06/2017	to	Fri 03/24/2017	<u>CANCELLED</u>	<u>by HQ</u>	<u>02/17/2017</u>	(Import)
0200	Continuous	0400		SCH - HQ_CEDARS	<b>160 MW</b>	
Work scheduled by: HQ					Impacts Total Transfer Capability	39 MW
					TTC with All Lines In Service	199 MW
<b>EDIC_-FRASER_345_EF24-40</b>					FWD	
Mon 03/06/2017	to	Fri 03/17/2017	<u>UPDATED</u>	<u>by NY</u>	<u>12/02/2016</u>	(Import)
0630	Continuous	1700		CENTRAL EAST - VC	<b>2500 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 21, 2017 to Thursday ,August 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MOSES -ADIRNDCK_230_MA1</b>					FWD		
Mon 03/06/2017	to	Fri 03/10/2017			(Import)		
0700	Continuous	1530			MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW	
					TTC with All Lines In Service	3150 MW	
<b>W49TH_ST_345KV_8</b>					FWD		
Wed 03/08/2017	to	Wed 03/08/2017			(Import)		
2130	Continuous	2200			SCH - PJM_HTP	<b>315 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	345 MW	
					TTC with All Lines In Service	660 MW	
<b>BROWNFLS-TAYLORVL_115_4</b>					FWD	REV	
Sat 03/11/2017	to	Sat 03/11/2017			(Import)	(Export)	
0600	Daily	1900			SCH - HQ_CEDARS	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	99 MW	0 MW
					TTC with All Lines In Service	199 MW	100 MW
<b>CHAT_DC_GC1</b>					FWD		
Sun 03/12/2017	to	Sun 03/12/2017	<b>UPDATED</b>	<b>by HQ</b>	<b>02/14/2017</b>	(Import)	
0001	Continuous	0200			MOSES SOUTH	<b>2850 MW</b>	
Work scheduled by: HQ					Impacts Total Transfer Capability	300 MW	
					TTC with All Lines In Service	3150 MW	
<b>CHAT_DC_GC1</b>						REV	
Sun 03/12/2017	to	Sun 03/12/2017	<b>UPDATED</b>	<b>by HQ</b>	<b>02/14/2017</b>	(Export)	
0001	Continuous	0200			SCH - HQ - NY	<b>500 MW</b>	
Work scheduled by: HQ					Impacts Total Transfer Capability	500 MW	
					TTC with All Lines In Service	1000 MW	
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>					FWD		
Sun 03/12/2017	to	Sun 03/12/2017			(Import)		
0001		0200			MOSES SOUTH	<b>2550 MW</b>	
Work scheduled by:					Impacts Total Transfer Capability	600 MW	
					TTC with All Lines In Service	3150 MW	
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>					FWD	REV	
Sun 03/12/2017	to	Sun 03/12/2017			(Import)	(Export)	
0001		0200			SCH - HQ - NY	<b>1370 MW</b>	<b>0 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	130 MW	1000 MW
					TTC with All Lines In Service	1500 MW	1000 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 21, 2017 to Thursday ,August 23, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC2</b>					FWD		
Sun 03/12/2017	to	Sun 03/12/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>02/14/2017</u>	(Import)	
0001	Continuous	0200				<b>2850 MW</b>	
Work scheduled by: HQ					MOSES SOUTH		
					Impacts Total Transfer Capability	300 MW	
					TTC with All Lines In Service	3150 MW	
<b>CHAT_DC_GC2</b>					REV		
Sun 03/12/2017	to	Sun 03/12/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>02/14/2017</u>	(Export)	
0001	Continuous	0200				<b>500 MW</b>	
Work scheduled by: HQ					SCH - HQ - NY		
					Impacts Total Transfer Capability	500 MW	
					TTC with All Lines In Service	1000 MW	
<b>SCH-HQ-NYISO_LIMIT_1100</b>					FWD		
Sun 03/12/2017	to	Sun 03/12/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>02/14/2017</u>	(Import)	
0001	Continuous	0200				<b>1100 MW</b>	
Work scheduled by: HQ					SCH - HQ - NY		
					Impacts Total Transfer Capability	400 MW	
					TTC with All Lines In Service	1500 MW	
<b>NIAGARA_-ROCHESTR_345_NR2</b>					FWD		
Mon 03/13/2017	to	Wed 03/15/2017				(Import)	
0500	Continuous	1200				<b>1700 MW</b>	
Work scheduled by: NYPA					DYSINGER EAST		
					Impacts Total Transfer Capability	1450 MW	
					TTC with All Lines In Service	3150 MW	
<b>BECK___-NIAGARA_345_PA302</b>					FWD	REV	
Mon 03/13/2017	to	Fri 03/17/2017				(Import)	(Export)
0700	Continuous	1600				<b>1100 MW</b>	<b>950 MW</b>
Work scheduled by: IESO					SCH - OH - NY		
					Impacts Total Transfer Capability	650 MW	950 MW
					TTC with All Lines In Service	1750 MW	1900 MW
<b>MOSES___-ADIRNDCK_230_MA2</b>					FWD		
Mon 03/13/2017	to	Sat 03/18/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/23/2016</u>	(Import)	
0700	Continuous	1530				<b>2300 MW</b>	
Work scheduled by: NYPA					MOSES SOUTH		
					Impacts Total Transfer Capability	850 MW	
					TTC with All Lines In Service	3150 MW	
<b>MILLWOOD_345KV_18</b>					FWD		
Tue 03/14/2017	to	Fri 03/17/2017				(Import)	
0001	Continuous	2359				<b>4350 MW</b>	
Work scheduled by: ConEd					UPNY CONED		
					Impacts Total Transfer Capability	750 MW	
					TTC with All Lines In Service	5100 MW	

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 21, 2017 to Thursday ,August 23, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>								
<b>ILCTLIMIT_MARCY_SO_COMP_I/S</b>							FWD	
Fri 03/17/2017	to	Mon 03/20/2017					(Import)	
1700	Continuous	0459			CENTRAL EAST - VC		<b>2740 MW</b>	
Work scheduled by: NYISO					Impacts Total Transfer Capability		235 MW	
					TTC with All Lines In Service		2975 MW	
<hr/>								
<b>LADENTWN-BUCHAN_S_345_Y88</b>							FWD	
Sat 03/18/2017	to	Mon 03/20/2017					(Import)	
0001	Continuous	2359			UPNY CONED		<b>4150 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability		950 MW	
					TTC with All Lines In Service		5100 MW	
<hr/>								
<b>NINEMILE-CLAY_____345_8</b>							FWD	
Mon 03/20/2017	to	Wed 03/22/2017	<b>UPDATED</b>	<b>by NGRID</b>	<b>01/25/2017</b>		(Import)	
0001	Continuous	0400				OSWEGO EXPORT	<b>5150 MW</b>	
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW	
						TTC with All Lines In Service	5250 MW	
<hr/>								
<b>FRASANX-COOPERS__345_UCC2-41</b>							FWD	
Mon 03/20/2017	to	Fri 03/24/2017	<b>UPDATED</b>	<b>by NYISO</b>	<b>10/27/2016</b>		(Import)	
0500	Continuous	1630				CENTRAL EAST - VC	<b>2500 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	475 MW	
						TTC with All Lines In Service	2975 MW	
<hr/>								
<b>MARCY___-FRASANX_345_UCC2-41</b>							FWD	
Mon 03/20/2017	to	Fri 03/24/2017	<b>UPDATED</b>	<b>by NYISO</b>	<b>10/27/2016</b>		(Import)	
0500	Continuous	1630				CENTRAL EAST - VC	<b>2500 MW</b>	
Work scheduled by: NYPA					<b>ARR: 19</b>	Impacts Total Transfer Capability	475 MW	
						TTC with All Lines In Service	2975 MW	
<hr/>								
<b>MOSES___-ADIRNDCK_230_MA2</b>							FWD	
Mon 03/20/2017	to	Sat 03/25/2017					(Import)	
0700	Continuous	1530				MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW	
						TTC with All Lines In Service	3150 MW	
<hr/>								
<b>BERKSHIR-ALPS_____345_393</b>							FWD	REV
Fri 03/24/2017	to	Fri 03/24/2017	<b>UPDATED</b>	<b>by NG</b>	<b>12/27/2016</b>		(Import)	(Export)
0800	Daily(No Weekends)	0900				SCH - NE - NY	<b>1300 MW</b>	<b>1300 MW</b>
Work scheduled by: NGrid					<b>ARR: 78</b>	Impacts Total Transfer Capability	100 MW	300 MW
						TTC with All Lines In Service	1400 MW	1600 MW
<hr/>								

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 21, 2017 to Thursday ,August 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
<b>BERKSHIR-ALPS_____345_393</b>						
Fri 03/24/2017	to	Fri 03/24/2017	<b>UPDATED</b>	<b>by NG</b>	<b>12/27/2016</b>	
0800	Daily(No Weekends)	0900				
Work scheduled by: NGrid					<b>ARR: 78</b>	
					SCH - NPX_1385	<b>100 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
<b>BERKSHIR-ALPS_____345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>						
Fri 03/24/2017	to	Fri 03/24/2017				
0800		0900				
Work scheduled by:					<b>ARR: 78</b>	
					SCH - NE - NY	<b>1300 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1400 MW
<b>BERKSHIR-NORTHFLD_345_312</b>						
Fri 03/24/2017	to	Sat 04/22/2017				
0800	Continuous	1600				
Work scheduled by: ISONE						
					SCH - NE - NY	<b>1400 MW</b>
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	1400 MW
<b>BERKSHIR-NORTHFLD_345_312</b>						
Fri 03/24/2017	to	Sat 04/22/2017				
0800	Continuous	1600				
Work scheduled by: ISONE						
					SCH - NPX_1385	<b>100 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
<b>ILCTLIMIT_MARCY_SO_COMP_I/S</b>						
Fri 03/24/2017	to	Mon 04/17/2017				
1700	Continuous	0900				
Work scheduled by: NYISO						
					CENTRAL EAST - VC	<b>2740 MW</b>
					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	2975 MW
<b>W49TH_ST_345KV_8</b>						
Sat 03/25/2017	to	Thu 03/30/2017	<b>UPDATED</b>	<b>by CONED</b>	<b>02/07/2017</b>	
0201	Continuous	0200				
Work scheduled by: ConEd						
					SCH - PJM_HTP	<b>315 MW</b>
					Impacts Total Transfer Capability	345 MW
					TTC with All Lines In Service	660 MW
<b>MARCY_____345KV_CSC</b>						
Mon 03/27/2017	to	Thu 04/13/2017				
0500	Continuous	1630				
Work scheduled by: NYPA						
					CENTRAL EAST - VC	<b>2925 MW</b>
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 21, 2017 to Thursday ,August 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>								
MARCY___345KV_CSC & ILCTLIMIT_MARCY_SO_COMP_I/S							FWD	
Mon 03/27/2017	to	Thu 04/13/2017					(Import)	
0500		1630			CENTRAL EAST - VC		<b>2690 MW</b>	
Work scheduled by:					Impacts Total Transfer Capability		285 MW	
					TTC with All Lines In Service		2975 MW	
<hr/>								
MOSES___-ADIRNDCK_230_MA2							FWD	
Mon 03/27/2017	to	Sat 04/01/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/23/2016</u>		(Import)	
0700	Continuous	1530			MOSES SOUTH		<b>2300 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability		850 MW	
					TTC with All Lines In Service		3150 MW	
<hr/>								
FRASER___-GILBOA___345_GF5-35							FWD	
Mon 03/27/2017	to	Fri 04/07/2017					(Import)	
0900	Continuous	1430			CENTRAL EAST - VC		<b>2650 MW</b>	
Work scheduled by: NYSEG					Impacts Total Transfer Capability		325 MW	
					TTC with All Lines In Service		2975 MW	
<hr/>								
LINDN_CG-LNDVFT___345_V-3022							FWD	REV
Sun 04/02/2017	to	Fri 04/07/2017					(Import)	(Export)
1400	Continuous	1800			SCH - PJM_VFT		<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: PJM					Impacts Total Transfer Capability		315 MW	315 MW
					TTC with All Lines In Service		315 MW	315 MW
<hr/>								
MOSES___-ADIRNDCK_230_MA1							FWD	
Mon 04/03/2017	to	Sat 04/08/2017					(Import)	
0700	Continuous	1530			MOSES SOUTH		<b>2300 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability		850 MW	
					TTC with All Lines In Service		3150 MW	
<hr/>								
HOMRC_NY-MAINS_NY_345_47							FWD	REV
Mon 04/03/2017	to	Fri 04/14/2017	<u>UPDATED</u>	<u>by PJM</u>	<u>01/26/2017</u>		(Import)	(Export)
0800	Continuous	1600			SCH - PJ - NY		<b>2300 MW</b>	<b>1450 MW</b>
Work scheduled by: NYSEG					Impacts Total Transfer Capability		0 MW	0 MW
					TTC with All Lines In Service		2300 MW	1450 MW
<hr/>								
MAINESEBG-WATRCURE_345_30							FWD	REV
Mon 04/03/2017	to	Fri 04/14/2017	<u>UPDATED</u>	<u>by PJM</u>	<u>01/26/2017</u>		(Import)	(Export)
0800	Continuous	1600			SCH - PJ - NY		<b>2200 MW</b>	<b>1450 MW</b>
Work scheduled by: NYSEG					Impacts Total Transfer Capability		100 MW	0 MW
					TTC with All Lines In Service		2300 MW	1450 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 21, 2017 to Thursday ,August 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_6**

Wed 04/05/2017 to Sun 04/09/2017  
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 02/07/2017

SCH - PJM\_HTP **315 MW**  
Impacts Total Transfer Capability 345 MW  
TTC with All Lines In Service 660 MW

FWD  
(Import)

**SCH-IMO-NYISO\_LIMIT\_500**

Fri 04/07/2017 to Fri 04/07/2017  
0700 Continuous 1530

Work scheduled by: NYPA

SCH - OH - NY **800 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 1750 MW

FWD  
(Import)

**COOPERS\_-ROCKTVRN\_345\_CCRT-42**

Mon 04/10/2017 to Mon 04/24/2017  
0630 Continuous 1700

Work scheduled by: NYPA

CENTRAL EAST - VC **2720 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

FWD  
(Import)

**MOSES\_-ADIRNDCK\_230\_MA1**

Mon 04/10/2017 to Thu 04/13/2017  
0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

FWD  
(Import)

**N.SCTLND-LEEDS\_345\_93**

Mon 04/10/2017 to Mon 04/10/2017  
1100 Daily(No Weekends) 1500

Work scheduled by: NGrid

CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

FWD  
(Import)

**LEEDS\_-PLSNTVLY\_345\_92**

Tue 04/11/2017 to Thu 04/13/2017  
0730 Continuous 1600

Work scheduled by: NGrid

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

FWD  
(Import)

**SHOR\_NPX-SHOREHAM\_138\_CSC**

Mon 04/17/2017 to Sat 04/22/2017  
0500 Continuous 1600

Work scheduled by: LI

SCH - NPX\_CSC **0 MW** **0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

FWD REV  
(Import) (Export)

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 21, 2017 to Thursday ,August 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MOSES -ADIRNDCK_230_MA2</b>					FWD	
Mon 04/17/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/23/2016</u>	(Import)
0700	Continuous	1530				MOSES SOUTH <b>2300 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
<b>FRASER -COOPERS_345_33</b>					FWD	
Mon 04/17/2017	to	Fri 04/21/2017	<u>UPDATED</u>	<u>by NY</u>	<u>01/12/2017</u>	(Import)
0900	Continuous	1400				CENTRAL EAST - VC <b>2395 MW</b>
Work scheduled by: NYSEG					Impacts Total Transfer Capability	580 MW
					TTC with All Lines In Service	2975 MW
<b>W49TH_ST_345KV_6</b>					FWD	
Thu 04/20/2017	to	Thu 04/20/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>02/07/2017</u>	(Import)
0230	Continuous	0300				SCH - PJM_HTP <b>315 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	345 MW
					TTC with All Lines In Service	660 MW
<b>MARION -FARRAGUT_345_C3403</b>					FWD	REV
Fri 04/21/2017	to	Sat 05/20/2017	<u>UPDATED</u>	<u>by CE</u>	<u>01/28/2017</u>	(Import) (Export)
0001	Continuous	2359				SCH - PJ - NY <b>2300 MW 1450 MW</b>
Work scheduled by: PJM					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	2300 MW 1450 MW
<b>ILCTLIMIT_MARCY_SO_COMP_I/S</b>					FWD	
Fri 04/21/2017	to	Sat 05/27/2017				(Import)
1400	Continuous	0459				CENTRAL EAST - VC <b>2740 MW</b>
Work scheduled by: NYISO					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	2975 MW
<b>BERKSHIR-ALPS_345_393</b>					FWD	REV
Sat 04/22/2017	to	Sat 04/22/2017				(Import) (Export)
1500	Daily	1600				SCH - NE - NY <b>1300 MW 1300 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW 300 MW
					TTC with All Lines In Service	1400 MW 1600 MW
<b>BERKSHIR-ALPS_345_393</b>					FWD	REV
Sat 04/22/2017	to	Sat 04/22/2017				(Import) (Export)
1500	Daily	1600				SCH - NPX_1385 <b>100 MW 100 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW

ARR: 78

ARR: 78

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 21, 2017 to Thursday ,August 23, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
<b>BERKSHIR-ALPS</b> _____ <b>345_393</b> & <b>BERKSHIR-NORTHFLD</b> <b>345_312</b>		FWD	REV
Sat 04/22/2017 to Sat 04/22/2017		(Import)	(Export)
1500 1600		<b>SCH - NE - NY</b>	<b>1300 MW 1300 MW</b>
Work scheduled by:	<b>ARR: 78</b>	Impacts Total Transfer Capability	100 MW 300 MW
		TTC with All Lines In Service	1400 MW 1600 MW
<hr/>			
<b>ROSETON_-EFISHKIL</b> <b>345_RFK305</b>		FWD	
Mon 04/24/2017 to Fri 05/05/2017		(Import)	
0001 Continuous 1900		<b>UPNY CONED</b>	<b>4100 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	1000 MW
		TTC with All Lines In Service	5100 MW
<hr/>			
<b>CLAY_-EDIC</b> _____ <b>345_1-16</b>		FWD	
Mon 04/24/2017 to Tue 04/25/2017		(Import)	
0630 Continuous 1530		<b>OSWEGO EXPORT</b>	<b>4850 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	5250 MW
<hr/>			
<b>STLAWRNC-MOSES</b> _____ <b>230_L34P</b>		FWD	REV
Mon 04/24/2017 to Fri 04/28/2017		(Import)	(Export)
0700 Continuous 1530		<b>SCH - OH - NY</b>	<b>1750 MW 1900 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	0 MW 0 MW
		TTC with All Lines In Service	1750 MW 1900 MW
<hr/>			
<b>MOSES_-ADIRNDCK</b> <b>230_MA2</b>		FWD	
Mon 04/24/2017 to Sat 04/29/2017	<b>UPDATED by NYPA 10/23/2016</b>	(Import)	
0700 Continuous 1530		<b>MOSES SOUTH</b>	<b>2300 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	850 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
<b>ALCOA_-DENNISON</b> <b>115_12</b>		FWD	REV
Wed 04/26/2017 to Wed 04/26/2017		(Import)	(Export)
0700 Daily(No Weekends) 1800		<b>SCH - HQ_CEDARS</b>	<b>100 MW 100 MW</b>
Work scheduled by: NGrid	<b>ARR: 38</b>	Impacts Total Transfer Capability	99 MW 0 MW
		TTC with All Lines In Service	199 MW 100 MW
<hr/>			
<b>ALCOA_-DENNISON</b> <b>115_12</b> & <b>ALCOA_-NOGDNBRG</b> <b>115_13</b>		FWD	REV
Wed 04/26/2017 to Wed 04/26/2017		(Import)	(Export)
0700 1800		<b>SCH - HQ_CEDARS</b>	<b>100 MW 60 MW</b>
Work scheduled by:	<b>ARR: 38</b>	Impacts Total Transfer Capability	99 MW 40 MW
		TTC with All Lines In Service	199 MW 100 MW
<hr/>			

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 21, 2017 to Thursday ,August 23, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p><b>ILCTLIMIT_115KV_ALCOA_R8105_TIE_B</b></p> <p>Wed 04/26/2017 to Wed 04/26/2017</p> <p>0700 Daily(No Weekends) 1800</p> <p>Work scheduled by: NGrid</p>	<p>FWD</p> <p>(Import)</p> <p><b>MOSES SOUTH 3100 MW</b></p> <p>Impacts Total Transfer Capability 50 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p><b>ILCTLIMIT_115KV_ALCOA_R8105_TIE_B</b></p> <p>Wed 04/26/2017 to Wed 04/26/2017</p> <p>0700 Daily(No Weekends) 1800</p> <p>Work scheduled by: NGrid</p>	<p>FWD REV</p> <p>(Import) (Export)</p> <p><b>SCH - HQ_CEDARS 100 MW 60 MW</b></p> <p>Impacts Total Transfer Capability 99 MW 40 MW</p> <p>TTC with All Lines In Service 199 MW 100 MW</p>
<p><b>NIAGARA_-ROCHESTR_345_NR2</b></p> <p>Fri 04/28/2017 to Fri 04/28/2017</p> <p>0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p>FWD</p> <p>(Import)</p> <p><b>DYSINGER EAST 1700 MW</b></p> <p>Impacts Total Transfer Capability 1450 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p><b>NEPTUNE_-DUFFYAVE_345_NEPTUNE</b></p> <p>Mon 05/01/2017 to Tue 05/16/2017 <b>UPDATED by LI 02/14/2017</b></p> <p>0400 Continuous 1800</p> <p>Work scheduled by: LI</p>	<p>FWD</p> <p>(Import)</p> <p><b>SCH - PJM_NEPTUNE 0 MW</b></p> <p>Impacts Total Transfer Capability 660 MW</p> <p>TTC with All Lines In Service 660 MW</p>
<p><b>NEWBRDGE-DUFFYAVE_345_501</b></p> <p>Mon 05/01/2017 to Tue 05/16/2017 <b>UPDATED by LI 02/14/2017</b></p> <p>0400 Continuous 1800</p> <p>Work scheduled by: LI</p>	<p>FWD</p> <p>(Import)</p> <p><b>SCH - PJM_NEPTUNE 0 MW</b></p> <p>Impacts Total Transfer Capability 660 MW</p> <p>TTC with All Lines In Service 660 MW</p>
<p><b>MARCY_-N.SCTLND_345_18</b></p> <p>Mon 05/01/2017 to Fri 05/05/2017</p> <p>0600 Continuous 1630</p> <p>Work scheduled by: NYPA</p>	<p>FWD</p> <p>(Import)</p> <p><b>CENTRAL EAST - VC 2090 MW</b></p> <p>Impacts Total Transfer Capability 885 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p><b>MARCY_-N.SCTLND_345_18 &amp; ILCTLIMIT_MARCY_SO_COMP_I/S</b></p> <p>Mon 05/01/2017 to Fri 05/05/2017</p> <p>0600 1630</p> <p>Work scheduled by: <b>ARR: 19</b></p>	<p>FWD</p> <p>(Import)</p> <p><b>CENTRAL EAST - VC 1855 MW</b></p> <p>Impacts Total Transfer Capability 1120 MW</p> <p>TTC with All Lines In Service 2975 MW</p>

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 21, 2017 to Thursday ,August 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BROWNFLS-TAYLORVL_115_3			FWD	REV
			(Import)	(Export)
Mon 05/01/2017	to	Fri 05/26/2017		
0600	Continuous	1900	SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	120 MW    0 MW
			TTC with All Lines In Service	190 MW    40 MW
ARR: 38				
ROCHESTR-PANNELL_345_RP2			FWD	
			(Import)	
Mon 05/01/2017	to	Mon 05/01/2017		
0630	Continuous	0700	DYSINGER EAST	<b>2300 MW</b>
Work scheduled by: RGE			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
PANNELL_-CLAY_345_2			FWD	
			(Import)	
Mon 05/01/2017	to	Fri 05/05/2017		
0630	Continuous	1530	WEST CENTRAL	<b>1300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	950 MW
			TTC with All Lines In Service	2250 MW
ROCHESTR-PANNELL_345_RP2			FWD	
			(Import)	
Fri 05/05/2017	to	Fri 05/05/2017		
1500	Continuous	1530	DYSINGER EAST	<b>2300 MW</b>
Work scheduled by: RGE			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
PANNELL_-CLAY_345_2			FWD	
			(Import)	
Mon 05/08/2017	to	Mon 05/08/2017		
0700	Continuous	0730	WEST CENTRAL	<b>1300 MW</b>
Work scheduled by: RGE			Impacts Total Transfer Capability	950 MW
			TTC with All Lines In Service	2250 MW
ROCHESTR-PANNELL_345_RP2			FWD	
			(Import)	
Mon 05/08/2017	to	Wed 05/10/2017		
0700	Continuous	1530	DYSINGER EAST	<b>2300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
ROSETON_-ROCKTVRN_345_311			FWD	
			(Import)	
Mon 05/08/2017	to	Fri 05/26/2017		
0800	Continuous	1600	UPNY CONED	<b>4400 MW</b>
Work scheduled by: CHGE			Impacts Total Transfer Capability	700 MW
			TTC with All Lines In Service	5100 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 21, 2017 to Thursday ,August 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PANNELL\_-CLAY\_ 345\_2**

Wed 05/10/2017 to Wed 05/10/2017  
 1500 Continuous 1530  
 Work scheduled by: RGE

FWD  
 (Import)  
 WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

**FRASER\_-GILBOA\_ 345\_GF5-35**

Mon 05/15/2017 to Fri 05/19/2017  
 0630 Continuous 1700  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

**STONYRDG-HILLSIDE\_230\_72**

Mon 05/15/2017 to Mon 05/15/2017  
 0800 Continuous 1700  
 Work scheduled by: NYSEG

FWD  
 (Import)  
 DYSINGER EAST **2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

**FRASER\_ 345\_FRASER SVC**

Mon 05/15/2017 to Fri 05/19/2017  
 0900 Continuous 1430  
 Work scheduled by: NYSEG

FWD  
 (Import)  
 CENTRAL EAST - VC **2935 MW**  
 Impacts Total Transfer Capability 40 MW  
 TTC with All Lines In Service 2975 MW

**FRASER\_ 345\_FRASER SVC & ILCTLIMIT\_MARCY\_SO\_COMP\_I/S**

Mon 05/15/2017 to Fri 05/19/2017  
 0900 1430  
 Work scheduled by:

FWD  
 (Import)  
 CENTRAL EAST - VC **2700 MW**  
 Impacts Total Transfer Capability 275 MW  
 TTC with All Lines In Service 2975 MW

**RAMAPO\_-LADENTWN\_345\_W72**

Tue 05/16/2017 to Tue 05/16/2017  
 0001 Continuous 2330  
 Work scheduled by: ORU

FWD  
 (Import)  
 UPNY CONED **4400 MW**  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 5100 MW

**MARCY\_ 765\_345\_AT1**

Mon 05/22/2017 to Fri 05/26/2017  
 0500 Continuous 1630  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **1750 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 3150 MW

**ARR: 19**

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 21, 2017 to Thursday ,August 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>LINDEN__-GOETHALS_230_A2253</b>						FWD	REV
Fri 05/26/2017 to Sat 05/27/2017 <b>UPDATED by CE 02/01/2017</b>						(Import)	(Export)
0001	Continuous	2359			SCH - PJ - NY	<b>2050 MW</b>	<b>1300 MW</b>
Work scheduled by: PJM						Impacts Total Transfer Capability	0 MW 0 MW
						TTC with All Lines In Service	2050 MW 1300 MW
<b>MARCY__-N.SCTLND_345_18</b>						FWD	
Sat 05/27/2017 to Sat 05/27/2017						(Import)	
0500	Continuous	1530			CENTRAL EAST - VC	<b>2090 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	885 MW
						TTC with All Lines In Service	2975 MW
<b>ILCTLIMIT_MARCY_SO_COMP_I/S</b>						FWD	
Sat 05/27/2017 to Sat 08/05/2017						(Import)	
1600	Continuous	0459			CENTRAL EAST - VC	<b>2740 MW</b>	
Work scheduled by: NYISO						Impacts Total Transfer Capability	235 MW
						TTC with All Lines In Service	2975 MW
<b>BROWNFLS-TAYLORVL_115_4</b>						FWD	REV
Tue 05/30/2017 to Sat 06/24/2017						(Import)	(Export)
0600	Continuous	1900			SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	120 MW 0 MW
						TTC with All Lines In Service	190 MW 40 MW
<b>STONYRDG-HILLSIDE_230_72</b>						FWD	
Mon 06/05/2017 to Mon 06/05/2017						(Import)	
0800	Continuous	1000			DYSINGER EAST	<b>2850 MW</b>	
Work scheduled by: NYSEG						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	3150 MW
<b>STONYRDG-HILLSIDE_230_72</b>						FWD	
Fri 06/09/2017 to Fri 06/09/2017						(Import)	
1500	Continuous	1700			DYSINGER EAST	<b>2850 MW</b>	
Work scheduled by: NYSEG						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	3150 MW
<b>BROWNFLS-TAYLORVL_115_3</b>						FWD	REV
Mon 06/26/2017 to Sat 07/01/2017						(Import)	(Export)
0600	Continuous	1900			SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	120 MW 0 MW
						TTC with All Lines In Service	190 MW 40 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 21, 2017 to Thursday ,August 23, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BROWNFLS-TAYLORVL_115_3</b>			FWD	REV
Wed 07/05/2017	to	Sat 07/22/2017	(Import) (Export)	
0600	Continuous	1900	SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	120 MW 0 MW
<b>ARR: 38</b>			TTC with All Lines In Service	190 MW 40 MW
<b>BROWNFLS-TAYLORVL_115_4</b>			FWD	REV
Mon 07/24/2017	to	Sat 08/19/2017	(Import) (Export)	
0600	Continuous	1900	SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	120 MW 0 MW
<b>ARR: 38</b>			TTC with All Lines In Service	190 MW 40 MW
<b>MARCY___-N.SCTLND_345_18</b>			FWD	
Sat 08/05/2017	to	Sat 08/05/2017	(Import)	
0500	Continuous	1530	CENTRAL EAST - VC	<b>2090 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	885 MW
<b>ARR: 19</b>			TTC with All Lines In Service	2975 MW
<b>MARCY___765_345_AT2</b>			FWD	
Sat 08/05/2017	to	Sat 08/05/2017	(Import)	
0500	Continuous	1530	MOSES SOUTH	<b>1700 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW
<b>ARR: 19</b>			TTC with All Lines In Service	3150 MW
<b>ILCTLIMIT_MARCY_SO_COMP_I/S</b>			FWD	
Sat 08/05/2017	to	Mon 11/06/2017	(Import)	
1600	Continuous	0559	CENTRAL EAST - VC	<b>2740 MW</b>
Work scheduled by: NYISO			Impacts Total Transfer Capability	235 MW
<b>ARR: 19</b>			TTC with All Lines In Service	2975 MW
<b>BROWNFLS-TAYLORVL_115_3</b>			FWD	REV
Mon 08/21/2017	to	Fri 09/01/2017	(Import) (Export)	
0600	Continuous	1900	SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	120 MW 0 MW
<b>ARR: 38</b>			TTC with All Lines In Service	190 MW 40 MW
<b>MARCY___765_345_AT2</b>			FWD	
Tue 09/05/2017	to	Sun 09/10/2017	(Import)	
0500	Continuous	1630	MOSES SOUTH	<b>1700 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW
<b>ARR: 19</b>			TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 21, 2017 to Thursday ,August 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BROWNFLS-TAYLORVL\_115\_3**

Tue 09/05/2017 to Sat 09/16/2017  
0600 Continuous 1900

Work scheduled by: NGrid

**ARR: 38**

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

**HURLYAVE-ROSETON\_345\_303**

Mon 09/11/2017 to Fri 09/29/2017  
0800 Continuous 1600

Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	<b>4100 MW</b>
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

**SPRNBRK\_-DUNWODIE\_345\_W75**

Fri 09/15/2017 to Sun 09/17/2017  
2200 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	<b>3800 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

**SPRNBRK\_345KV\_RNS3**

Fri 09/15/2017 to Sun 09/17/2017  
2200 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	<b>3800 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

**BROWNFLS-TAYLORVL\_115\_4**

Mon 09/18/2017 to Fri 10/13/2017  
0600 Continuous 1600

Work scheduled by: NGrid

**ARR: 38**

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

**GILBOA\_-N.SCTLND\_345\_GNS-1**

Mon 09/18/2017 to Fri 10/06/2017  
0630 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2520 MW</b>
Impacts Total Transfer Capability	455 MW
TTC with All Lines In Service	2975 MW

**NIAGARA\_345\_230\_AT4**

Mon 09/18/2017 to Tue 09/19/2017  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1750 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	0 MW	300 MW
TTC with All Lines In Service	1750 MW	1600 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 21, 2017 to Thursday ,August 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_-ROCHESTR\_345\_NR2**

Mon 10/02/2017 to Fri 10/06/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**CHATGUAY-MASSENA\_765\_7040**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

**CHATGUAY-MASSENA\_765\_7040**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - HQ - NY **0 MW 0 MW**  
Impacts Total Transfer Capability 1500 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

**MARCY\_765\_345\_AT1**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1750 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

**MARCY\_765\_345\_AT2**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**MASSENA\_-MARCY\_765\_MSU1**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2265 MW**  
Impacts Total Transfer Capability 710 MW  
TTC with All Lines In Service 2975 MW

**MASSENA\_-MARCY\_765\_MSU1**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 21, 2017 to Thursday ,August 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event ID	Start Date	End Date	Time	Duration	Work Scheduled by	Zone	FWD	REV	
MASSENA_-MARCY___765_MSU1	Sat 10/14/2017	Sat 10/28/2017	0700	Continuous	NYPA	SCH - HQ - NY	475 MW	1000 MW	
							(Import)	(Export)	
							Impacts Total Transfer Capability	1025 MW	0 MW
							TTC with All Lines In Service	1500 MW	1000 MW
MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040	Sat 10/14/2017	Sat 10/28/2017	0700	Continuous		MOSES SOUTH	500 MW		
							(Import)		
							Impacts Total Transfer Capability	2650 MW	
							TTC with All Lines In Service	3150 MW	
MASSENA_-MARCY___765_MSU1 & ILCTLIMIT_MARCY_SO_COMP_I/S	Sat 10/14/2017	Sat 10/28/2017	0700	Continuous		CENTRAL EAST - VC	2080 MW		
							(Import)		
							Impacts Total Transfer Capability	895 MW	
							TTC with All Lines In Service	2975 MW	
MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2	Sat 10/14/2017	Sat 10/28/2017	0700	Continuous		SCH - HQ - NY	850 MW	0 MW	
							(Import)	(Export)	
							Impacts Total Transfer Capability	650 MW	1000 MW
							TTC with All Lines In Service	1500 MW	1000 MW
LEEDS_-HURLYAVE_345_301	Mon 10/16/2017	Fri 11/03/2017	0800	Continuous	CHGE	UPNY CONED	4100 MW		
							(Import)		
							Impacts Total Transfer Capability	1000 MW	
							TTC with All Lines In Service	5100 MW	
BROWNFLS-TAYLORVL_115_3	Mon 10/30/2017	Sat 11/11/2017	0700	Continuous	NGrid	SCH - HQ_CEDARS	70 MW	40 MW	
							(Import)	(Export)	
							Impacts Total Transfer Capability	120 MW	0 MW
							TTC with All Lines In Service	190 MW	40 MW
							<b>ARR: 38</b>		
FRASANX-COOPERS_345_UCC2-41	Mon 11/06/2017	Fri 11/17/2017	0600	Continuous	NYPA	CENTRAL EAST - VC	2500 MW		
							(Import)		
							Impacts Total Transfer Capability	475 MW	
							TTC with All Lines In Service	2975 MW	

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 21, 2017 to Thursday ,August 23, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
<b>MARCY___-FRASANNX_345_UCC2-41</b>			FWD
Mon 11/06/2017	to	Fri 11/17/2017	(Import)
0600	Continuous	1700	<b>CENTRAL EAST - VC</b> <b>2500 MW</b>
Work scheduled by: NYPA		<b>ARR: 19</b>	Impacts Total Transfer Capability 475 MW TTC with All Lines In Service 2975 MW
<hr/>			
<b>BROWNFLS-TAYLORVL_115_4</b>			FWD REV
Mon 11/13/2017	to	Thu 11/30/2017	(Import) (Export)
0600	Continuous	1900	<b>SCH - HQ_CEDARS</b> <b>100 MW 100 MW</b>
Work scheduled by: NGrid		<b>UPDATED by NGRID 08/25/2016</b> <b>ARR: 38</b>	Impacts Total Transfer Capability 99 MW 0 MW TTC with All Lines In Service 199 MW 100 MW
<hr/>			
<b>ILCTLIMIT_MARCY_SO_COMP_I/S</b>			FWD
Fri 11/17/2017	to	Sat 02/01/2020	(Import)
1700	Continuous	0000	<b>CENTRAL EAST - VC</b> <b>2740 MW</b>
Work scheduled by: NYISO			Impacts Total Transfer Capability 235 MW TTC with All Lines In Service 2975 MW
<hr/>			
<b>MARCY___765_345_AT2</b>			FWD
Mon 12/04/2017	to	Fri 12/08/2017	(Import)
0500	Continuous	1630	<b>MOSES SOUTH</b> <b>1700 MW</b>
Work scheduled by: NYPA		<b>ARR: 19</b>	Impacts Total Transfer Capability 1450 MW TTC with All Lines In Service 3150 MW
<hr/>			
<b>MOSES___-ADIRNDCK_230_MA2</b>			FWD
Mon 12/11/2017	to	Fri 12/15/2017	(Import)
0700	Continuous	1530	<b>MOSES SOUTH</b> <b>2300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 850 MW TTC with All Lines In Service 3150 MW
<hr/>			
<b>MOSES___-ADIRNDCK_230_MA2</b>			FWD
Mon 12/18/2017	to	Fri 12/22/2017	(Import)
0700	Continuous	1530	<b>MOSES SOUTH</b> <b>2300 MW</b>
Work scheduled by: NYPA		<b>UPDATED by NYPA 10/23/2016</b>	Impacts Total Transfer Capability 850 MW TTC with All Lines In Service 3150 MW
<hr/>			
<b>MOSES___-ADIRNDCK_230_MA2</b>			FWD
Tue 12/26/2017	to	Thu 12/28/2017	(Import)
0700	Continuous	1530	<b>MOSES SOUTH</b> <b>2300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 850 MW TTC with All Lines In Service 3150 MW