

# NYISO TRANSFER LIMITATIONS

Saturday ,February 04, 2017 to Monday ,August 06, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event ID	Start Date	End Date	Time	Duration	Category	By	Effective Date	Impact	FWD	REV	
RAMAPO___345_345_PAR3500	Fri 06/24/2016	Thu 06/01/2017	1940	Continuous	2359	<u>EXT FORCE</u>	<u>by CONED</u>	<u>01/11/2017</u>	SCH - PJ - NY	(Import)	(Export)
									2200 MW	1450 MW	
									Impacts Total Transfer Capability	100 MW	0 MW
									TTC with All Lines In Service	2300 MW	1450 MW
									Work scheduled by: ConEd		
PLSNTVLE-DUNWODIE_345_W89	Sun 10/30/2016	Sat 04/15/2017	0728	Continuous	2359	<u>EXT FORCE</u>	<u>by CONED</u>	<u>02/01/2017</u>	UPNY CONED	(Import)	
									4000 MW		
									Impacts Total Transfer Capability	1100 MW	
									TTC with All Lines In Service	5100 MW	
									Work scheduled by: ConEd		
HUDSONTP-W49TH_ST_345_Y56	Thu 11/24/2016	Mon 05/01/2017	1500	Continuous	2359	<u>EXTENDED</u>	<u>by PJM</u>	<u>01/27/2017</u>	SCH - PJM_HTP	(Import)	
									0 MW		
									Impacts Total Transfer Capability	660 MW	
									TTC with All Lines In Service	660 MW	
									Work scheduled by: ConEd		
E13THSTA-FARRAGUT_345_46	Tue 12/20/2016	Mon 04/10/2017	0001	Continuous	2300	<u>UPDATED</u>	<u>by CONED</u>	<u>01/27/2017</u>	SPR/DUN-SOUTH	(Import)	
									3800 MW		
									Impacts Total Transfer Capability	800 MW	
									TTC with All Lines In Service	4600 MW	
									Work scheduled by: ConEd		
W49TH_ST-E13THSTA_345_M55	Tue 12/20/2016	Mon 04/10/2017	0001	Continuous	2300	<u>UPDATED</u>	<u>by CONED</u>	<u>01/27/2017</u>	SPR/DUN-SOUTH	(Import)	
									3800 MW		
									Impacts Total Transfer Capability	800 MW	
									TTC with All Lines In Service	4600 MW	
									Work scheduled by: ConEd		
FITZPTRK-EDIC___345_FE-1	Sat 01/14/2017	Wed 02/08/2017	0200	Continuous	0100	<u>EXTENDED</u>	<u>by PA</u>	<u>02/03/2017</u>	CENTRAL EAST - VC	(Import)	
									2825 MW		
									Impacts Total Transfer Capability	150 MW	
									TTC with All Lines In Service	2975 MW	
									Work scheduled by: NYPA		
FITZPTRK-EDIC___345_FE-1	Sat 01/14/2017	Wed 02/08/2017	0200	Continuous	0100	<u>EXTENDED</u>	<u>by PA</u>	<u>02/03/2017</u>	OSWEGO EXPORT	(Import)	
									4800 MW		
									Impacts Total Transfer Capability	450 MW	
									TTC with All Lines In Service	5250 MW	
									Work scheduled by: NYPA		

# NYISO TRANSFER LIMITATIONS

Saturday ,February 04, 2017 to Monday ,August 06, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>								
<b>SCH-IMO-NYISO_LIMIT_1200</b>							FWD	
Thu 01/19/2017	to	Tue 02/21/2017	<b>UPDATED</b>	<b>by NYPA</b>	<b>01/13/2017</b>		(Import)	
1900	Continuous	1700				SCH - OH - NY	<b>1500 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	250 MW	
						TTC with All Lines In Service	1750 MW	
<hr/>								
<b>MOSES -ADIRNDCK_230_MA2</b>							FWD	
Mon 01/30/2017	to	Fri 02/03/2017	<b>UPDATED</b>	<b>by NYPA</b>	<b>10/23/2016</b>		(Import)	
0700	Continuous	1530				MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW	
						TTC with All Lines In Service	3150 MW	
<hr/>								
<b>LEEDS 345 LEEDS SVC</b>							FWD	
Mon 01/30/2017	to	Fri 02/24/2017					(Import)	
0800	Continuous	1600				CENTRAL EAST - VC	<b>2950 MW</b>	
Work scheduled by: NGrid						Impacts Total Transfer Capability	25 MW	
						TTC with All Lines In Service	2975 MW	
<hr/>								
<b>CHAT_DC_GC1</b>							FWD	
Mon 01/30/2017	to	Wed 02/01/2017	<b>FORCED</b>	<b>by HQ</b>	<b>01/31/2017</b>		(Import)	
2002	Continuous	1800				MOSES SOUTH	<b>2850 MW</b>	
Work scheduled by: HQ						Impacts Total Transfer Capability	300 MW	
						TTC with All Lines In Service	3150 MW	
<hr/>								
<b>CHAT_DC_GC1</b>								REV
Mon 01/30/2017	to	Wed 02/01/2017	<b>FORCED</b>	<b>by HQ</b>	<b>01/31/2017</b>			(Export)
2002	Continuous	1800				SCH - HQ - NY	<b>500 MW</b>	
Work scheduled by: HQ						Impacts Total Transfer Capability	500 MW	
						TTC with All Lines In Service	1000 MW	
<hr/>								
<b>BERKSHIR-ALPS 345_393</b>							FWD	REV
Thu 02/02/2017	to	Thu 02/02/2017	<b>UPDATED</b>	<b>by ISONE</b>	<b>01/31/2017</b>		(Import)	(Export)
0800	Continuous	1700				SCH - NE - NY	<b>1300 MW</b>	<b>1300 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW	300 MW
						TTC with All Lines In Service	1400 MW	1600 MW
<hr/>								
<b>BERKSHIR-ALPS 345_393</b>							FWD	REV
Thu 02/02/2017	to	Thu 02/02/2017	<b>UPDATED</b>	<b>by ISONE</b>	<b>01/31/2017</b>		(Import)	(Export)
0800	Continuous	1700				SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW	100 MW
						TTC with All Lines In Service	200 MW	200 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 04, 2017 to Monday ,August 06, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD	REV
<b>N. SCTLND-ALPS_____345_2</b>					(Import)	(Export)
Thu 02/02/2017	to	Thu 02/02/2017	<b><u>UPDATED</u></b>	<b><u>by ISONE</u></b>	<b><u>01/31/2017</u></b>	
0800	Continuous	1700				
Work scheduled by: NGrid					SCH - NE - NY	<b>900 MW</b>
					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1400 MW
<hr/>					FWD	REV
<b>N. SCTLND-ALPS_____345_2</b>					(Import)	(Export)
Thu 02/02/2017	to	Thu 02/02/2017	<b><u>UPDATED</u></b>	<b><u>by ISONE</u></b>	<b><u>01/31/2017</u></b>	
0800	Continuous	1700				
Work scheduled by: NGrid					SCH - NPX_1385	<b>100 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
<hr/>						REV
<b>SCH-NYISO-NE_LIMIT_600</b>						(Export)
Thu 02/02/2017	to	Thu 02/02/2017	<b><u>UPDATED</u></b>	<b><u>by ISONE</u></b>	<b><u>01/31/2017</u></b>	
0800	Continuous	1700				
Work scheduled by: NGrid					SCH - NE - NY	<b>800 MW</b>
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	1600 MW
<hr/>						FWD
<b>MARCY_____765_345_AT2</b>					(Import)	
Sat 02/04/2017	to	Sat 02/04/2017	<b><u>UPDATED</u></b>	<b><u>by NYPA</u></b>	<b><u>02/01/2017</u></b>	
0500	Continuous	1530				
Work scheduled by: NYPA					MOSES SOUTH	<b>1700 MW</b>
					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
<hr/>						FWD
<b>MOSES___-ADIRNDCK_230_MA2</b>					(Import)	
Mon 02/06/2017	to	Fri 02/10/2017	<b><u>UPDATED</u></b>	<b><u>by NYPA</u></b>	<b><u>10/23/2016</u></b>	
0700	Continuous	1530				
Work scheduled by: NYPA					MOSES SOUTH	<b>2300 MW</b>
					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
<hr/>						FWD
<b>NRTH1385-NOR HBR_138_601</b>					(Import)	REV
Mon 02/06/2017	to	Sat 02/25/2017		<b><u>by LI</u></b>	<b><u>01/11/2017</u></b>	
0700	Continuous	2359				
Work scheduled by: LI					SCH - NPX_1385	<b>100 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
<hr/>						FWD
<b>NRTH1385-NOR HBR_138_601 &amp; NRTH1385-NOR HBR_138_602</b>					(Import)	REV
Mon 02/06/2017	to	Sat 02/25/2017				
0700		2359				
Work scheduled by:					SCH - NPX_1385	<b>0 MW</b>
					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	200 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 04, 2017 to Monday ,August 06, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603 Mon 02/06/2017 to Sat 02/25/2017 0700 2359 Work scheduled by:		SCH - NPX_1385 Impacts Total Transfer Capability TTC with All Lines In Service	FWD REV (Import) (Export) <b>0 MW 0 MW</b> 200 MW 200 MW 200 MW 200 MW
<hr/>			
NRTH1385-NOR HBR__138_602 Mon 02/06/2017 to Sat 02/25/2017 0700 Continuous 2359 Work scheduled by: LI		SCH - NPX_1385 Impacts Total Transfer Capability TTC with All Lines In Service	FWD REV (Import) (Export) <b>100 MW 100 MW</b> 100 MW 100 MW 200 MW 200 MW
<hr/>			
NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603 Mon 02/06/2017 to Sat 02/25/2017 0700 2359 Work scheduled by:		SCH - NPX_1385 Impacts Total Transfer Capability TTC with All Lines In Service	FWD REV (Import) (Export) <b>0 MW 0 MW</b> 200 MW 200 MW 200 MW 200 MW
<hr/>			
NRTH1385-NOR HBR__138_603 Mon 02/06/2017 to Sat 02/25/2017 0700 Continuous 2359 Work scheduled by: LI		SCH - NPX_1385 Impacts Total Transfer Capability TTC with All Lines In Service	FWD REV (Import) (Export) <b>100 MW 100 MW</b> 100 MW 100 MW 200 MW 200 MW
<hr/>			
NRTH1385-NRTHPORT_138_1385 Mon 02/06/2017 to Sat 02/25/2017 0700 Continuous 2359 Work scheduled by: LI		SCH - NPX_1385 Impacts Total Transfer Capability TTC with All Lines In Service	FWD REV (Import) (Export) <b>0 MW 0 MW</b> 200 MW 200 MW 200 MW 200 MW
<hr/>			
ILCTLIMIT_MARCY_SO_COMP_I/S Tue 02/07/2017 to Mon 03/06/2017 1300 Continuous 0559 Work scheduled by: NYSEG		CANCELLED by NYISO CENTRAL EAST - VC Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) <b>2740 MW</b> 235 MW 2975 MW
<hr/>			
LEEDS__345_LEEDS SVC & ILCTLIMIT_MARCY_SO_COMP_I/S Wed 02/08/2017 to Fri 02/24/2017 0200 1600 Work scheduled by:		CENTRAL EAST - VC Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) <b>2715 MW</b> 260 MW 2975 MW
<hr/>			

# NYISO TRANSFER LIMITATIONS

Saturday ,February 04, 2017 to Monday ,August 06, 2018

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ILCTLIMIT_MARCY_SO_COMP_I/S					FWD	
Wed 02/08/2017	to	Mon 03/06/2017			(Import)	
0200	Continuous	0559			CENTRAL EAST - VC	<b>2740 MW</b>
Work scheduled by: NYISO					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	2975 MW
<hr/>						
CHAT_DC_GC1					FWD	
Wed 02/08/2017	to	Thu 02/09/2017	<b>CANCELLED</b>	<b>by HQ</b>	<b>02/01/2017</b>	(Import)
2000	Continuous	0600			MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
<hr/>						
CHAT_DC_GC1						REV
Wed 02/08/2017	to	Thu 02/09/2017	<b>CANCELLED</b>	<b>by HQ</b>	<b>02/01/2017</b>	(Export)
2000	Continuous	0600			SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
<hr/>						
BROWNFLS-TAYLORVL_115_4					FWD	REV
Sat 02/11/2017	to	Sat 02/11/2017			(Import)	(Export)
0600	Daily	1900			SCH - HQ_CEDARS	<b>100 MW 100 MW</b>
Work scheduled by: NGrid				<b>ARR: 38</b>	Impacts Total Transfer Capability	99 MW 0 MW
					TTC with All Lines In Service	199 MW 100 MW
<hr/>						
BECK___-NIAGARA_345_PA302					FWD	REV
Mon 02/13/2017	to	Mon 02/13/2017			(Import)	(Export)
0400	Continuous	1700			SCH - OH - NY	<b>1100 MW 950 MW</b>
Work scheduled by: IESO					Impacts Total Transfer Capability	650 MW 950 MW
					TTC with All Lines In Service	1750 MW 1900 MW
<hr/>						
GILBOA_-LEEDS_345_GL3					FWD	
Mon 02/13/2017	to	Tue 02/14/2017			(Import)	
0600	Continuous	1600			CENTRAL EAST - VC	<b>2200 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	775 MW
					TTC with All Lines In Service	2975 MW
<hr/>						
LEEDS___345KV_R395					FWD	
Mon 02/13/2017	to	Tue 02/14/2017			(Import)	
0600	Continuous	1600			UPNY CONED	<b>3800 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	1300 MW
					TTC with All Lines In Service	5100 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 04, 2017 to Monday ,August 06, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MOSES -ADIRNDCK_230_MA1</b>			FWD	
Mon 02/13/2017	to	Fri 02/17/2017	(Import)	
0700	Continuous	1530	MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
<b>BROWNFLS-TAYLORVL_115_3</b>			FWD	REV
Sat 02/18/2017	to	Sat 02/18/2017	(Import)	(Export)
0600	Daily	1900	SCH - HQ_CEDARS	<b>100 MW 100 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	99 MW 0 MW
			TTC with All Lines In Service	199 MW 100 MW
<b>BECK -NIAGARA_230_PA27</b>			FWD	REV
Tue 02/21/2017	to	Sat 02/25/2017	(Import)	(Export)
0645	Continuous	1700	SCH - OH - NY	<b>1750 MW 1900 MW</b>
Work scheduled by: IESO			Impacts Total Transfer Capability	0 MW 0 MW
			TTC with All Lines In Service	1750 MW 1900 MW
<b>MOSES -ADIRNDCK_230_MA1</b>			FWD	
Tue 02/21/2017	to	Fri 02/24/2017	(Import)	
0700	Continuous	1530	MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
<b>BROWNFLS-TAYLORVL_115_4</b>			FWD	REV
Sat 02/25/2017	to	Sat 02/25/2017	(Import)	(Export)
0600	Daily	1900	SCH - HQ_CEDARS	<b>100 MW 100 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	99 MW 0 MW
			TTC with All Lines In Service	199 MW 100 MW
<b>MOSES -ADIRNDCK_230_MA1</b>			FWD	
Mon 02/27/2017	to	Fri 03/03/2017	(Import)	
0700	Continuous	1530	MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
<b>COOPERS -ROCKTVRN_345_CCRT-42</b>			FWD	
Wed 03/01/2017	to	Wed 03/15/2017	(Import)	
0500	Continuous	1530	CENTRAL EAST - VC	<b>2720 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	255 MW
			TTC with All Lines In Service	2975 MW



# NYISO TRANSFER LIMITATIONS

Saturday ,February 04, 2017 to Monday ,August 06, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK -NIAGARA 345_PA302	FWD	REV
Mon 03/13/2017 to Fri 03/17/2017	(Import)	(Export)
0700 Continuous 1600	SCH - OH - NY	<b>1100 MW 950 MW</b>
Work scheduled by: IESO	Impacts Total Transfer Capability	650 MW 950 MW
	TTC with All Lines In Service	1750 MW 1900 MW
<hr/>		
MOSES -ADIRNDCK 230_MA2	FWD	
Mon 03/13/2017 to Sat 03/18/2017	(Import)	
0700 Continuous 1530	MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA	Impacts Total Transfer Capability	850 MW
	TTC with All Lines In Service	3150 MW
<hr/>		
MILLWOOD_345KV_18	FWD	
Tue 03/14/2017 to Fri 03/17/2017	(Import)	
0001 Continuous 2359	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd	Impacts Total Transfer Capability	750 MW
	TTC with All Lines In Service	5100 MW
<hr/>		
ILCTLIMIT_MARCY_SO_COMP_I/S	FWD	
Fri 03/17/2017 to Mon 03/20/2017	(Import)	
1700 Continuous 0559	CENTRAL EAST - VC	<b>2740 MW</b>
Work scheduled by: NYISO	Impacts Total Transfer Capability	235 MW
	TTC with All Lines In Service	2975 MW
<hr/>		
LADENTWN-BUCHAN_S_345_Y88	FWD	
Sat 03/18/2017 to Mon 03/20/2017	(Import)	
0001 Continuous 2359	UPNY CONED	<b>4150 MW</b>
Work scheduled by: ConEd	Impacts Total Transfer Capability	950 MW
	TTC with All Lines In Service	5100 MW
<hr/>		
NINEMILE-CLAY 345_8	FWD	
Mon 03/20/2017 to Fri 03/24/2017	(Import)	
0001 Continuous 0400	OSWEGO EXPORT	<b>5150 MW</b>
Work scheduled by: NGrid	Impacts Total Transfer Capability	100 MW
	TTC with All Lines In Service	5250 MW
<hr/>		
FRASANNX-COOPERS_345_UCC2-41	FWD	
Mon 03/20/2017 to Fri 03/24/2017	(Import)	
0600 Continuous 1630	CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYPA	Impacts Total Transfer Capability	475 MW
	TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 04, 2017 to Monday ,August 06, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY___-FRASANNX_345_UCC2-41</b>					FWD	
Mon 03/20/2017	to	Fri 03/24/2017	<b>UPDATED</b>	<b>by NYISO</b>	<b>10/27/2016</b>	(Import)
0600	Continuous	1630				CENTRAL EAST - VC <b>2500 MW</b>
Work scheduled by: NYPA			<b>ARR: 19</b>			Impacts Total Transfer Capability 475 MW
						TTC with All Lines In Service 2975 MW
<b>MOSES___-ADIRNDCK_230_MA2</b>					FWD	
Mon 03/20/2017	to	Sat 03/25/2017				(Import)
0700	Continuous	1530				MOSES SOUTH <b>2300 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 850 MW
						TTC with All Lines In Service 3150 MW
<b>BERKSHIR-ALPS___345_393</b>					FWD	REV
Fri 03/24/2017	to	Fri 03/24/2017	<b>UPDATED</b>	<b>by NG</b>	<b>12/27/2016</b>	(Import) (Export)
0800	Daily(No Weekends)	0900				SCH - NE - NY <b>1300 MW 1300 MW</b>
Work scheduled by: NGrid			<b>ARR: 78</b>			Impacts Total Transfer Capability 100 MW 300 MW
						TTC with All Lines In Service 1400 MW 1600 MW
<b>BERKSHIR-ALPS___345_393</b>					FWD	REV
Fri 03/24/2017	to	Fri 03/24/2017	<b>UPDATED</b>	<b>by NG</b>	<b>12/27/2016</b>	(Import) (Export)
0800	Daily(No Weekends)	0900				SCH - NPX_1385 <b>100 MW 100 MW</b>
Work scheduled by: NGrid			<b>ARR: 78</b>			Impacts Total Transfer Capability 100 MW 100 MW
						TTC with All Lines In Service 200 MW 200 MW
<b>BERKSHIR-ALPS___345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Fri 03/24/2017	to	Fri 03/24/2017				(Import) (Export)
0800		0900				SCH - NE - NY <b>1300 MW 1300 MW</b>
Work scheduled by:			<b>ARR: 78</b>			Impacts Total Transfer Capability 100 MW 300 MW
						TTC with All Lines In Service 1400 MW 1600 MW
<b>BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Fri 03/24/2017	to	Sat 04/22/2017				(Import) (Export)
0800	Continuous	1600				SCH - NE - NY <b>1400 MW 1450 MW</b>
Work scheduled by: ISONE						Impacts Total Transfer Capability 0 MW 150 MW
						TTC with All Lines In Service 1400 MW 1600 MW
<b>BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Fri 03/24/2017	to	Sat 04/22/2017				(Import) (Export)
0800	Continuous	1600				SCH - NPX_1385 <b>100 MW 100 MW</b>
Work scheduled by: ISONE						Impacts Total Transfer Capability 100 MW 100 MW
						TTC with All Lines In Service 200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 04, 2017 to Monday ,August 06, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ILCTLIMIT_MARCY_SO_COMP_I/S			FWD	
Fri 03/24/2017	to	Mon 04/17/2017	(Import)	
1700	Continuous	0900		CENTRAL EAST - VC <b>2740 MW</b>
Work scheduled by: NYISO			Impacts Total Transfer Capability	235 MW
			TTC with All Lines In Service	2975 MW
<hr/>				
MARCY___345KV_CSC			FWD	
Mon 03/27/2017	to	Thu 04/13/2017	(Import)	
0500	Continuous	1630		CENTRAL EAST - VC <b>2925 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	50 MW
			TTC with All Lines In Service	2975 MW
<hr/>				
MARCY___345KV_CSC & ILCTLIMIT_MARCY_SO_COMP_I/S			FWD	
Mon 03/27/2017	to	Thu 04/13/2017	(Import)	
0500		1630		CENTRAL EAST - VC <b>2690 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	285 MW
			TTC with All Lines In Service	2975 MW
<hr/>				
MOSES___-ADIRNDCK_230_MA2			FWD	
Mon 03/27/2017	to	Sat 04/01/2017	(Import)	
0700	Continuous	1530		MOSES SOUTH <b>2300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
<hr/>				
FRASER___-GILBOA___345_GF5-35			FWD	
Mon 03/27/2017	to	Fri 04/07/2017	(Import)	
0900	Continuous	1430		CENTRAL EAST - VC <b>2650 MW</b>
Work scheduled by: NYSEG			Impacts Total Transfer Capability	325 MW
			TTC with All Lines In Service	2975 MW
<hr/>				
LINDN_CG-LNDVFT___345_V-3022			FWD	REV
Sun 04/02/2017	to	Fri 04/07/2017	(Import)	(Export)
1400	Continuous	1800		
Work scheduled by: PJM			SCH - PJM_VFT	<b>0 MW</b> <b>0 MW</b>
			Impacts Total Transfer Capability	315 MW 315 MW
			TTC with All Lines In Service	315 MW 315 MW
<hr/>				
MOSES___-ADIRNDCK_230_MA1			FWD	
Mon 04/03/2017	to	Sat 04/08/2017	(Import)	
0700	Continuous	1530		MOSES SOUTH <b>2300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 04, 2017 to Monday ,August 06, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>HOMRC_NY-MAINS_NY_345_47</b>							
Mon 04/03/2017	to	Fri 04/14/2017	<u>UPDATED</u>	<u>by PJM</u>	<u>01/26/2017</u>		
0800	Continuous	1600				SCH - PJ - NY	<b>2300 MW</b>
Work scheduled by: NYSEG						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	2300 MW
							1450 MW
<b>MAINESBG-WATRCURE_345_30</b>							
Mon 04/03/2017	to	Fri 04/14/2017	<u>UPDATED</u>	<u>by PJM</u>	<u>01/26/2017</u>		
0800	Continuous	1600				SCH - PJ - NY	<b>2200 MW</b>
Work scheduled by: NYSEG						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	2300 MW
							1450 MW
<b>W49TH_ST_345KV_6</b>							
Wed 04/05/2017	to	Sun 04/09/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>01/27/2017</u>		
0001	Continuous	0200				SCH - PJM_HTP	<b>315 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	345 MW
						TTC with All Lines In Service	660 MW
<b>SCH-IMO-NYISO_LIMIT_500</b>							
Fri 04/07/2017	to	Fri 04/07/2017					
0700	Continuous	1530				SCH - OH - NY	<b>800 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	950 MW
						TTC with All Lines In Service	1750 MW
<b>COOPERS_-ROCKTVRN_345_CCRT-42</b>							
Mon 04/10/2017	to	Mon 04/24/2017					
0630	Continuous	1700				CENTRAL EAST - VC	<b>2720 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	255 MW
						TTC with All Lines In Service	2975 MW
<b>MOSES_-ADIRNDCK_230_MAI</b>							
Mon 04/10/2017	to	Thu 04/13/2017					
0700	Continuous	1530				MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
<b>W49TH_ST_345KV_6</b>							
Mon 04/10/2017	to	Mon 04/10/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>01/27/2017</u>		
2230	Continuous	2300				SCH - PJM_HTP	<b>315 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	345 MW
						TTC with All Lines In Service	660 MW



# NYISO TRANSFER LIMITATIONS

Saturday ,February 04, 2017 to Monday ,August 06, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312		FWD	REV
Sat 04/22/2017	to Sat 04/22/2017	(Import)	(Export)
1500	1600	SCH - NE - NY	<b>1300 MW 1300 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	100 MW 300 MW
<b>ARR: 78</b>		TTC with All Lines In Service	1400 MW 1600 MW
CLAY_____EDIC_____345_1-16		FWD	
Mon 04/24/2017	to Tue 04/25/2017	(Import)	
0630	Continuous 1530	OSWEGO EXPORT	<b>4850 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	5250 MW
STLAWRNC-MOSES_____230_L34P		FWD	REV
Mon 04/24/2017	to Fri 04/28/2017	(Import)	(Export)
0700	Continuous 1530	SCH - OH - NY	<b>1750 MW 1900 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	0 MW 0 MW
		TTC with All Lines In Service	1750 MW 1900 MW
MOSES_____ADIRNDCK_230_MA2		FWD	
Mon 04/24/2017	to Sat 04/29/2017	(Import)	
0700	Continuous 1530	MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	850 MW
		TTC with All Lines In Service	3150 MW
NEWBRDGE_345_138_BK_1		FWD	
Wed 04/26/2017	to Sun 04/30/2017	(Import)	
0001	Continuous 2359	SCH - PJM_NEPTUNE	<b>375 MW</b>
Work scheduled by: LI		Impacts Total Transfer Capability	285 MW
		TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_2		FWD	
Wed 04/26/2017	to Sun 04/30/2017	(Import)	
0001	Continuous 2359	SCH - PJM_NEPTUNE	<b>375 MW</b>
Work scheduled by: LI		Impacts Total Transfer Capability	285 MW
		TTC with All Lines In Service	660 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE		FWD	
Wed 04/26/2017	to Tue 05/16/2017	(Import)	
0001	Continuous 1800	SCH - PJM_NEPTUNE	<b>0 MW</b>
Work scheduled by: LI		Impacts Total Transfer Capability	660 MW
		TTC with All Lines In Service	660 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 04, 2017 to Monday ,August 06, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD
NEWBRDGE-DUFFYAVE_345_501					(Import)
Wed 04/26/2017	to	Tue 05/16/2017	<u>UPDATED</u>	<u>by LI</u>	<u>01/31/2017</u>
0001	Continuous	1800			
Work scheduled by: LI					SCH - PJM_NEPTUNE <b>0 MW</b>
					Impacts Total Transfer Capability 660 MW
					TTC with All Lines In Service 660 MW
<hr/>					FWD
NIAGARA -ROCHESTR_345_NR2					(Import)
Fri 04/28/2017	to	Fri 04/28/2017			
0700	Continuous	1530			
Work scheduled by: NYPA					DYSINGER EAST <b>1700 MW</b>
					Impacts Total Transfer Capability 1450 MW
					TTC with All Lines In Service 3150 MW
<hr/>					FWD
MARCY -N.SCTLND_345_18					(Import)
Mon 05/01/2017	to	Fri 05/05/2017			
0600	Continuous	1630			
Work scheduled by: NYPA					CENTRAL EAST - VC <b>2090 MW</b>
					Impacts Total Transfer Capability 885 MW
					TTC with All Lines In Service 2975 MW
<hr/>					FWD
MARCY -N.SCTLND_345_18 & ILCTLIMIT_MARCY_SO_COMP_I/S					(Import)
Mon 05/01/2017	to	Fri 05/05/2017			
0600		1630			
Work scheduled by:					CENTRAL EAST - VC <b>1855 MW</b>
					Impacts Total Transfer Capability 1120 MW
					TTC with All Lines In Service 2975 MW
<hr/>					FWD
BROWNFLS-TAYLORVL_115_3					REV
Mon 05/01/2017	to	Fri 05/26/2017			
0600	Continuous	1900			
Work scheduled by: NGrid					SCH - HQ_CEDARS <b>70 MW</b> <b>40 MW</b>
					Impacts Total Transfer Capability 120 MW 0 MW
					TTC with All Lines In Service 190 MW 40 MW
<hr/>					FWD
ROCHESTR-PANNELL_345_RP2					(Import)
Mon 05/01/2017	to	Mon 05/01/2017			
0630	Continuous	0700			
Work scheduled by: RGE					DYSINGER EAST <b>2300 MW</b>
					Impacts Total Transfer Capability 850 MW
					TTC with All Lines In Service 3150 MW
<hr/>					FWD
PANNELL -CLAY_345_2					(Import)
Mon 05/01/2017	to	Fri 05/05/2017			
0630	Continuous	1530			
Work scheduled by: NYPA					WEST CENTRAL <b>1300 MW</b>
					Impacts Total Transfer Capability 950 MW
					TTC with All Lines In Service 2250 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 04, 2017 to Monday ,August 06, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>ROCHESTR-PANNELL__345_RP2</b>			FWD
Fri 05/05/2017	to	Fri 05/05/2017	(Import)
1500	Continuous	1530	DYSINGER EAST <b>2300 MW</b>
Work scheduled by: RGE			Impacts Total Transfer Capability 850 MW
			TTC with All Lines In Service 3150 MW
<b>PANNELL_-CLAY____345_2</b>			FWD
Mon 05/08/2017	to	Mon 05/08/2017	(Import)
0700	Continuous	0730	WEST CENTRAL <b>1300 MW</b>
Work scheduled by: RGE			Impacts Total Transfer Capability 950 MW
			TTC with All Lines In Service 2250 MW
<b>ROCHESTR-PANNELL__345_RP2</b>			FWD
Mon 05/08/2017	to	Wed 05/10/2017	(Import)
0700	Continuous	1530	DYSINGER EAST <b>2300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 850 MW
			TTC with All Lines In Service 3150 MW
<b>ROSETON_-ROCKTVRN_345_311</b>			FWD
Mon 05/08/2017	to	Fri 05/26/2017	(Import)
0800	Continuous	1600	UPNY CONED <b>4400 MW</b>
Work scheduled by: CHGE			Impacts Total Transfer Capability 700 MW
			TTC with All Lines In Service 5100 MW
<b>PANNELL_-CLAY____345_2</b>			FWD
Wed 05/10/2017	to	Wed 05/10/2017	(Import)
1500	Continuous	1530	WEST CENTRAL <b>1300 MW</b>
Work scheduled by: RGE			Impacts Total Transfer Capability 950 MW
			TTC with All Lines In Service 2250 MW
<b>FRASER_-GILBOA__345_GF5-35</b>			FWD
Mon 05/15/2017	to	Fri 05/19/2017	(Import)
0630	Continuous	1700	CENTRAL EAST - VC <b>2650 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 325 MW
			TTC with All Lines In Service 2975 MW
<b>FRASER__345_FRASER SVC</b>			FWD
Mon 05/15/2017	to	Fri 05/19/2017	(Import)
0900	Continuous	1430	CENTRAL EAST - VC <b>2935 MW</b>
Work scheduled by: NYSEG			Impacts Total Transfer Capability 40 MW
			TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 04, 2017 to Monday ,August 06, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**FRASER\_\_\_345\_FRASER SVC & ILCTLIMIT\_MARCY\_SO\_COMP\_I/S**

Mon 05/15/2017 to Fri 05/19/2017  
 0900 1430

Work scheduled by:

FWD  
 (Import)  
 CENTRAL EAST - VC **2700 MW**  
 Impacts Total Transfer Capability 275 MW  
 TTC with All Lines In Service 2975 MW

-----  
**RAMAPO\_\_-LADENTWN\_345\_W72**

Tue 05/16/2017 to Tue 05/16/2017  
 0001 Continuous 2330

Work scheduled by: ORU

FWD  
 (Import)  
 UPNY CONED **4400 MW**  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 5100 MW

-----  
**MARCY\_\_\_765\_345\_AT1**

Mon 05/22/2017 to Fri 05/26/2017  
 0500 Continuous 1630

Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 MOSES SOUTH **1750 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 3150 MW

-----  
**LINDEN\_\_-GOETHALS\_230\_A2253**

Fri 05/26/2017 to Sat 05/27/2017  
 0001 Continuous 2359

Work scheduled by: PJM

**UPDATED by CE 02/01/2017**

FWD REV  
 (Import) (Export)  
 SCH - PJ - NY **2050 MW 1300 MW**  
 Impacts Total Transfer Capability 0 MW 0 MW  
 TTC with All Lines In Service 2050 MW 1300 MW

-----  
**MARCY\_\_\_-N.SCTLND\_345\_18**

Sat 05/27/2017 to Sat 05/27/2017  
 0500 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2090 MW**  
 Impacts Total Transfer Capability 885 MW  
 TTC with All Lines In Service 2975 MW

-----  
**ILCTLIMIT\_MARCY\_SO\_COMP\_I/S**

Sat 05/27/2017 to Sat 08/05/2017  
 1600 Continuous 0459

Work scheduled by: NYISO

FWD  
 (Import)  
 CENTRAL EAST - VC **2740 MW**  
 Impacts Total Transfer Capability 235 MW  
 TTC with All Lines In Service 2975 MW

-----  
**BROWNEFLS-TAYLORVL\_115\_4**

Tue 05/30/2017 to Sat 06/24/2017  
 0600 Continuous 1900

Work scheduled by: NGrid

**ARR: 38**

FWD REV  
 (Import) (Export)  
 SCH - HQ\_CEDARS **70 MW 40 MW**  
 Impacts Total Transfer Capability 120 MW 0 MW  
 TTC with All Lines In Service 190 MW 40 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 04, 2017 to Monday ,August 06, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
<b>BROWNFLS-TAYLORVL_115_3</b>					
Mon 06/26/2017	to	Sat 07/01/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			<b>ARR: 38</b>		
				SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
<b>BROWNFLS-TAYLORVL_115_3</b>					
Wed 07/05/2017	to	Sat 07/22/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			<b>ARR: 38</b>		
				SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
<b>BROWNFLS-TAYLORVL_115_4</b>					
Mon 07/24/2017	to	Sat 08/19/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			<b>ARR: 38</b>		
				SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
<b>MARCY___-N.SCTLND_345_18</b>					
Sat 08/05/2017	to	Sat 08/05/2017			
0500	Continuous	1530			
Work scheduled by: NYPA			<b>ARR: 19</b>		
				FWD	
				(Import)	
				CENTRAL EAST - VC	<b>2090 MW</b>
				Impacts Total Transfer Capability	885 MW
				TTC with All Lines In Service	2975 MW
<b>MARCY___765_345_AT2</b>					
Sat 08/05/2017	to	Sat 08/05/2017			
0500	Continuous	1530			
Work scheduled by: NYPA			<b>ARR: 19</b>		
				FWD	
				(Import)	
				MOSES SOUTH	<b>1700 MW</b>
				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
<b>ILCTLIMIT_MARCY_SO_COMP_I/S</b>					
Sat 08/05/2017	to	Mon 11/06/2017			
1600	Continuous	0559			
Work scheduled by: NYISO					
				FWD	
				(Import)	
				CENTRAL EAST - VC	<b>2740 MW</b>
				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	2975 MW
<b>BROWNFLS-TAYLORVL_115_3</b>					
Mon 08/21/2017	to	Fri 09/01/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			<b>ARR: 38</b>		
				SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 04, 2017 to Monday ,August 06, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_765\_345\_AT2**

Tue 09/05/2017 to Sun 09/10/2017  
0500 Continuous 1630

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**BROWNFLS-TAYLORVL\_115\_3**

Tue 09/05/2017 to Sat 09/16/2017  
0600 Continuous 1900

Work scheduled by: NGrid

**ARR: 38**

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **70 MW 40 MW**  
Impacts Total Transfer Capability 120 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

**HURLYAVE-ROSETON\_\_345\_303**

Mon 09/11/2017 to Fri 09/29/2017  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 5100 MW

**SPRNBRK\_-DUNWODIE\_345\_W75**

Fri 09/15/2017 to Sun 09/17/2017  
2200 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**SPRNBRK\_\_345KV\_RNS3**

Fri 09/15/2017 to Sun 09/17/2017  
2200 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**BROWNFLS-TAYLORVL\_115\_4**

Mon 09/18/2017 to Fri 10/13/2017  
0600 Continuous 1600

Work scheduled by: NGrid

**ARR: 38**

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **70 MW 40 MW**  
Impacts Total Transfer Capability 120 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

**GILBOA\_-N.SCTLND\_345\_GNS-1**

Mon 09/18/2017 to Fri 10/06/2017  
0630 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2520 MW**  
Impacts Total Transfer Capability 455 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 04, 2017 to Monday ,August 06, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_\_345\_230\_AT4**

Mon 09/18/2017 to Tue 09/19/2017  
 0700 Continuous 1530  
 Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1750 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	0 MW	300 MW
TTC with All Lines In Service	1750 MW	1600 MW

**NIAGARA\_-ROCHESTR\_345\_NR2**

Mon 09/25/2017 to Fri 09/29/2017 **CANCELLED by NYPA 02/02/2017**  
 0700 Continuous 1530  
 Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>1700 MW</b>
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

**NIAGARA\_-ROCHESTR\_345\_NR2**

Mon 10/02/2017 to Fri 10/06/2017  
 0700 Continuous 1530  
 Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>1700 MW</b>
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

**CHATGUAY-MASSENA\_\_765\_7040**

Sat 10/14/2017 to Sat 10/28/2017  
 0700 Continuous 1530  
 Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>1550 MW</b>
Impacts Total Transfer Capability	1600 MW
TTC with All Lines In Service	3150 MW

**CHATGUAY-MASSENA\_\_765\_7040**

Sat 10/14/2017 to Sat 10/28/2017  
 0700 Continuous 1530  
 Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

**MARCY\_\_765\_345\_AT1**

Sat 10/14/2017 to Sat 10/28/2017  
 0700 Continuous 1530  
 Work scheduled by: NYPA

**ARR: 19**

	FWD
	(Import)
MOSES SOUTH	<b>1750 MW</b>
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	3150 MW

**MARCY\_\_765\_345\_AT2**

Sat 10/14/2017 to Sat 10/28/2017  
 0700 Continuous 1530  
 Work scheduled by: NYPA

**ARR: 19**

	FWD
	(Import)
MOSES SOUTH	<b>1700 MW</b>
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 04, 2017 to Monday ,August 06, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA -MARCY 765_MSU1</b>			FWD	
Sat 10/14/2017	to	Sat 10/28/2017	(Import)	
0700	Continuous	1530	CENTRAL EAST - VC	<b>2265 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	710 MW
			TTC with All Lines In Service	2975 MW
<b>MASSENA -MARCY 765_MSU1</b>			FWD	
Sat 10/14/2017	to	Sat 10/28/2017	(Import)	
0700	Continuous	1530	MOSES SOUTH	<b>500 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
<b>MASSENA -MARCY 765_MSU1</b>			FWD	REV
Sat 10/14/2017	to	Sat 10/28/2017	(Import)	(Export)
0700	Continuous	1530	SCH - HQ - NY	<b>475 MW 1000 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1025 MW 0 MW
			TTC with All Lines In Service	1500 MW 1000 MW
<b>MASSENA -MARCY 765_MSU1 &amp; CHATGUAY-MASSENA 765_7040</b>			FWD	
Sat 10/14/2017	to	Sat 10/28/2017	(Import)	
0700		1530	MOSES SOUTH	<b>500 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
<b>MASSENA -MARCY 765_MSU1 &amp; ILCTLIMIT_MARCY_SO_COMP_I/S</b>			FWD	
Sat 10/14/2017	to	Sat 10/28/2017	(Import)	
0700		1530	CENTRAL EAST - VC	<b>2080 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	895 MW
			TTC with All Lines In Service	2975 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>			FWD	REV
Sat 10/14/2017	to	Sat 10/28/2017	(Import)	(Export)
0700		1530	SCH - HQ - NY	<b>850 MW 0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	650 MW 1000 MW
			TTC with All Lines In Service	1500 MW 1000 MW
<b>LEEDS -HURLYAVE 345_301</b>			FWD	
Mon 10/16/2017	to	Fri 11/03/2017	(Import)	
0800	Continuous	1600	UPNY CONED	<b>4100 MW</b>
Work scheduled by: CHGE			Impacts Total Transfer Capability	1000 MW
			TTC with All Lines In Service	5100 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 04, 2017 to Monday ,August 06, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BROWNFLS-TAYLORVL_115_3</b>			
Mon 10/30/2017 to Sat 11/11/2017	<b>UPDATED</b>	<b>by NGRID</b>	<b>09/01/2016</b>
0700 Continuous 1900			
Work scheduled by: NGrid	<b>ARR: 38</b>		
		SCH - HQ_CEDARS	FWD (Import) REV (Export)
		Impacts Total Transfer Capability	<b>70 MW 40 MW</b>
		TTC with All Lines In Service	120 MW 0 MW
			190 MW 40 MW
<b>FRASANX-COOPERS_345_UCC2-41</b>			
Mon 11/06/2017 to Fri 11/17/2017			
0600 Continuous 1700			
Work scheduled by: NYPA			
		CENTRAL EAST - VC	FWD (Import)
		Impacts Total Transfer Capability	<b>2500 MW</b>
		TTC with All Lines In Service	475 MW
			2975 MW
<b>MARCY_-FRASANX_345_UCC2-41</b>			
Mon 11/06/2017 to Fri 11/17/2017			
0600 Continuous 1700			
Work scheduled by: NYPA	<b>ARR: 19</b>		
		CENTRAL EAST - VC	FWD (Import)
		Impacts Total Transfer Capability	<b>2500 MW</b>
		TTC with All Lines In Service	475 MW
			2975 MW
<b>BROWNFLS-TAYLORVL_115_4</b>			
Mon 11/13/2017 to Thu 11/30/2017	<b>UPDATED</b>	<b>by NGRID</b>	<b>08/25/2016</b>
0600 Continuous 1900			
Work scheduled by: NGrid	<b>ARR: 38</b>		
		SCH - HQ_CEDARS	FWD (Import) REV (Export)
		Impacts Total Transfer Capability	<b>100 MW 100 MW</b>
		TTC with All Lines In Service	99 MW 0 MW
			199 MW 100 MW
<b>ILCTLIMIT_MARCY_SO_COMP_I/S</b>			
Fri 11/17/2017 to Sat 02/01/2020			
1700 Continuous 0000			
Work scheduled by: NYISO			
		CENTRAL EAST - VC	FWD (Import)
		Impacts Total Transfer Capability	<b>2740 MW</b>
		TTC with All Lines In Service	235 MW
			2975 MW
<b>MARCY_765_345_AT2</b>			
Mon 12/04/2017 to Fri 12/08/2017			
0500 Continuous 1630			
Work scheduled by: NYPA	<b>ARR: 19</b>		
		MOSES SOUTH	FWD (Import)
		Impacts Total Transfer Capability	<b>1700 MW</b>
		TTC with All Lines In Service	1450 MW
			3150 MW
<b>MOSES_-ADIRNDCK_230_MA2</b>			
Mon 12/11/2017 to Fri 12/15/2017			
0700 Continuous 1530			
Work scheduled by: NYPA			
		MOSES SOUTH	FWD (Import)
		Impacts Total Transfer Capability	<b>2300 MW</b>
		TTC with All Lines In Service	850 MW
			3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 04, 2017 to Monday ,August 06, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES\_\_\_-ADIRNDCK\_230\_MA2

FWD

Mon 12/18/2017 to Fri 12/22/2017 UPDATED by NYPA 10/23/2016  
 0700 Continuous 1530

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA2

FWD

Tue 12/26/2017 to Thu 12/28/2017  
 0700 Continuous 1530

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW