

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 28, 2017 to Thursday ,August 30, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event ID	Start Date	End Date	Reason	By	Effective Date	SCH	FWD (Import)	REV (Export)
<b>RAMAPO___345_345_PAR3500</b>	Fri 06/24/2016	Thu 06/01/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>01/11/2017</u>	SCH - PJ - NY	2200 MW	1450 MW
1940	Continuous	2359				Impacts Total Transfer Capability	100 MW	0 MW
Work scheduled by: ConEd						TTC with All Lines In Service	2300 MW	1450 MW
<b>PLSNTVLE-DUNWODIE_345_W89</b>	Sun 10/30/2016	Sat 04/15/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>02/01/2017</u>	UPNY CONED	4000 MW	
0728	Continuous	2359				Impacts Total Transfer Capability	1100 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	5100 MW	
<b>HUDSONTP-W49TH_ST_345_Y56</b>	Thu 11/24/2016	Mon 05/01/2017	<u>EXTENDED</u>	<u>by PJM</u>	<u>01/27/2017</u>	SCH - PJM_HTP	0 MW	
1500	Continuous	2359				Impacts Total Transfer Capability	660 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	660 MW	
<b>E13THSTA-FARRAGUT_345_46</b>	Tue 12/20/2016	Thu 04/20/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>02/07/2017</u>	SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0300				Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	4600 MW	
<b>W49TH_ST-E13THSTA_345_M55</b>	Tue 12/20/2016	Thu 04/20/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>02/07/2017</u>	SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0300				Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	4600 MW	
<b>LEEDS___345_LEEDS SVC</b>	Mon 01/30/2017	Fri 02/24/2017				CENTRAL EAST - VC	2950 MW	
0800	Continuous	1600				Impacts Total Transfer Capability	25 MW	
Work scheduled by: NGrid						TTC with All Lines In Service	2975 MW	
<b>NRTH1385-NOR HBR__138_601</b>	Mon 02/06/2017	Sat 02/25/2017		<u>by LI</u>	<u>01/11/2017</u>	SCH - NPX_1385	100 MW	100 MW
0700	Continuous	2359				Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: LI						TTC with All Lines In Service	200 MW	200 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 28, 2017 to Thursday ,August 30, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
<b>NRTH1385-NOR HBR__138_601 &amp; NRTH1385-NOR HBR__138_602</b>					
Mon 02/06/2017	to	Sat 02/25/2017			
0700		2359			
Work scheduled by:				SCH - NPX_1385	<b>0 MW 0 MW</b>
				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR__138_601 &amp; NRTH1385-NOR HBR__138_603</b>					
Mon 02/06/2017	to	Sat 02/25/2017			
0700		2359			
Work scheduled by:				SCH - NPX_1385	<b>0 MW 0 MW</b>
				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR__138_602</b>					
Mon 02/06/2017	to	Sat 02/25/2017	<u>by LI</u>	<u>01/11/2017</u>	
0700	Continuous	2359			
Work scheduled by: LI				SCH - NPX_1385	<b>100 MW 100 MW</b>
				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR__138_602 &amp; NRTH1385-NOR HBR__138_603</b>					
Mon 02/06/2017	to	Sat 02/25/2017			
0700		2359			
Work scheduled by:				SCH - NPX_1385	<b>0 MW 0 MW</b>
				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR__138_603</b>					
Mon 02/06/2017	to	Sat 02/25/2017	<u>by LI</u>	<u>01/11/2017</u>	
0700	Continuous	2359			
Work scheduled by: LI				SCH - NPX_1385	<b>100 MW 100 MW</b>
				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NRTHPORT_138_1385</b>					
Mon 02/06/2017	to	Sat 02/25/2017	<u>by LI</u>	<u>01/11/2017</u>	
0700	Continuous	2359			
Work scheduled by: LI				SCH - NPX_1385	<b>0 MW 0 MW</b>
				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
<b>W49TH_ST_345KV_6</b>					
Fri 02/17/2017	to	Thu 03/30/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>02/07/2017</u>
0001	Continuous	0300			
Work scheduled by: ConEd				SCH - PJM_HTP	<b>315 MW</b>
				Impacts Total Transfer Capability	345 MW
				TTC with All Lines In Service	660 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 28, 2017 to Thursday ,August 30, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK	-	NIAGARA	230	PA27			FWD	REV	
							(Import)	(Export)	
Tue 02/21/2017	to	Thu 03/02/2017							
0645	Continuous	1700				SCH - OH - NY	1750 MW	1900 MW	
Work scheduled by: IESO							Impacts Total Transfer Capability	0 MW	0 MW
							TTC with All Lines In Service	1750 MW	1900 MW
MOSES	-	ADIRNDCK	230	MA1			FWD		
							(Import)		
Tue 02/21/2017	to	Fri 02/24/2017							
0700	Continuous	1530				MOSES SOUTH	2300 MW		
Work scheduled by: NYPA							Impacts Total Transfer Capability	850 MW	
							TTC with All Lines In Service	3150 MW	
FITZPTRK-EDIC		345	FE-1				FWD		
							(Import)		
Fri 02/24/2017	to	Fri 02/24/2017			<u>UPDATED</u>	<u>by PA</u>	<u>02/24/2017</u>		
1600	Continuous	2359							
Work scheduled by: NYPA							CENTRAL EAST - VC	2825 MW	
							Impacts Total Transfer Capability	150 MW	
							TTC with All Lines In Service	2975 MW	
FITZPTRK-EDIC		345	FE-1				FWD		
							(Import)		
Fri 02/24/2017	to	Fri 02/24/2017			<u>UPDATED</u>	<u>by PA</u>	<u>02/24/2017</u>		
1600	Continuous	2359							
Work scheduled by: NYPA							OSWEGO EXPORT	4800 MW	
							Impacts Total Transfer Capability	450 MW	
							TTC with All Lines In Service	5250 MW	
BROWNFLS-TAYLORVL		115	4				FWD	REV	
							(Import)	(Export)	
Sat 02/25/2017	to	Sat 02/25/2017			<u>CANCELLED</u>	<u>by NGrid</u>	<u>02/23/2017</u>		
0600	Daily	1900							
Work scheduled by: NGrid							SCH - HQ_CEDARS	100 MW	100 MW
							Impacts Total Transfer Capability	99 MW	0 MW
							TTC with All Lines In Service	199 MW	100 MW
CHAT_DC_GC2							FWD		
							(Import)		
Sat 02/25/2017	to	Sat 02/25/2017							
0800	Continuous	1700							
Work scheduled by: HQ							MOSES SOUTH	2850 MW	
							Impacts Total Transfer Capability	300 MW	
							TTC with All Lines In Service	3150 MW	
CHAT_DC_GC2								REV	
							(Export)		
Sat 02/25/2017	to	Sat 02/25/2017							
0800	Continuous	1700							
Work scheduled by: HQ							SCH - HQ - NY	500 MW	
							Impacts Total Transfer Capability	500 MW	
							TTC with All Lines In Service	1000 MW	

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 28, 2017 to Thursday ,August 30, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>ILCTLIMIT_MARCY_SO_COMP_I/S</b>			FWD
Sun 02/26/2017	to	Mon 03/06/2017	(Import)
0218	Continuous	0559	CENTRAL EAST - VC <b>2740 MW</b>
Work scheduled by: NYISO			Impacts Total Transfer Capability 235 MW
			TTC with All Lines In Service 2975 MW
<b>MOSES -ADIRNDCK_230_MAI</b>			FWD
Mon 02/27/2017	to	Fri 03/03/2017	(Import)
0700	Continuous	1530	MOSES SOUTH <b>2300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 850 MW
			TTC with All Lines In Service 3150 MW
<b>LAFAYTTE-CLRKSCRN_345_4-46</b>			FWD
Tue 02/28/2017	to	Tue 02/28/2017	(Import)
0700	Daily(No Weekends)	1300	<b>CANCELLED by NYISO 02/28/2017</b> CENTRAL EAST - VC <b>2650 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability 325 MW
			TTC with All Lines In Service 2975 MW
<b>DUNWODIE-SHORE_RD_345_Y50</b>			FWD
Wed 03/01/2017	to	Mon 03/20/2017	(Import)
0001	Continuous	2359	CONED - LIPA <b>800 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability 700 MW
			TTC with All Lines In Service 1500 MW
<b>SHORE_RD_345_138_BK 1</b>			FWD
Wed 03/01/2017	to	Mon 03/20/2017	(Import)
0001	Continuous	2359	CONED - LIPA <b>1350 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability 150 MW
			TTC with All Lines In Service 1500 MW
<b>SHORE_RD_345_138_BK 2</b>			FWD
Wed 03/01/2017	to	Mon 03/20/2017	(Import)
0001	Continuous	2359	CONED - LIPA <b>1350 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability 150 MW
			TTC with All Lines In Service 1500 MW
<b>CLRKSCRN-OAKDALE_345_36</b>			FWD
Wed 03/01/2017	to	Wed 03/01/2017	(Import)
0700	Continuous	1500	<b>CANCELLED by NYSEG 02/28/2017</b> CENTRAL EAST - VC <b>2650 MW</b>
Work scheduled by: NYSEG			Impacts Total Transfer Capability 325 MW
			TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 28, 2017 to Thursday ,August 30, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-IMO-NYISO_LIMIT_1000</b>					FWD	
Wed 03/01/2017	to	Wed 03/01/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>02/25/2017</u>	(Import)
0800	Continuous	1059				1300 MW
Work scheduled by: PJM					SCH - OH - NY	Impacts Total Transfer Capability 450 MW
					TTC with All Lines In Service	1750 MW
<b>SCH-NYISO-PJM_LIMIT_100</b>						REV
Wed 03/01/2017	to	Wed 03/01/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>02/25/2017</u>	(Export)
0800	Continuous	1059				400 MW
Work scheduled by: PJM					SCH - PJ - NY	Impacts Total Transfer Capability 1050 MW
					TTC with All Lines In Service	1450 MW
<b>COOPERS_-DOLSONAV_345_CCDA42</b>					FWD	
Thu 03/02/2017	to	Fri 03/24/2017	<u>UPDATED</u>	<u>by NYSEG</u>	<u>02/28/2017</u>	(Import)
0500	Continuous	1530				2720 MW
Work scheduled by: NYPA					CENTRAL EAST - VC	Impacts Total Transfer Capability 255 MW
					TTC with All Lines In Service	2975 MW
<b>DOLSONAV-ROCKTVRN_345_DART44</b>					FWD	
Thu 03/02/2017	to	Fri 03/24/2017	<u>UPDATED</u>	<u>by NYSEG</u>	<u>02/28/2017</u>	(Import)
0500	Continuous	1530				2720 MW
Work scheduled by: NYPA					CENTRAL EAST - VC	Impacts Total Transfer Capability 255 MW
					TTC with All Lines In Service	2975 MW
<b>BECK___-NIAGARA_345_PA302</b>					FWD	REV
Sat 03/04/2017	to	Sat 03/04/2017	<u>UPDATED</u>	<u>by OH</u>	<u>02/08/2017</u>	(Import) (Export)
0400	Continuous	1700				1100 MW 950 MW
Work scheduled by: IESO					SCH - OH - NY	Impacts Total Transfer Capability 650 MW 950 MW
					TTC with All Lines In Service	1750 MW 1900 MW
<b>BROWNFLS-TAYLORVL_115_3</b>					FWD	REV
Sat 03/04/2017	to	Sat 03/04/2017				(Import) (Export)
0600	Daily	1900				100 MW 100 MW
Work scheduled by: NGrid					SCH - HQ_CEDARS	Impacts Total Transfer Capability 99 MW 0 MW
					TTC with All Lines In Service	199 MW 100 MW
<b>W49TH_ST_345KV_8</b>					FWD	
Mon 03/06/2017	to	Mon 03/06/2017				(Import)
0001	Continuous	0030				315 MW
Work scheduled by: ConEd					SCH - PJM_HTP	Impacts Total Transfer Capability 345 MW
					TTC with All Lines In Service	660 MW

ARR: 38

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 28, 2017 to Thursday ,August 30, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>HUDSONP_-FARRAGUT_345_B3402</b>					FWD	REV
Mon 03/06/2017	to	Thu 04/20/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>02/17/2017</u>	(Import) (Export)
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	<b>2300 MW 1450 MW</b>
					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	2300 MW 1450 MW
<hr/>						
<b>HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>					FWD	REV
Mon 03/06/2017	to	Thu 04/20/2017				(Import) (Export)
0001		2359				
Work scheduled by:					SCH - PJ - NY	<b>2050 MW 1450 MW</b>
					Impacts Total Transfer Capability	250 MW 0 MW
					TTC with All Lines In Service	2300 MW 1450 MW
<hr/>						
<b>MARION_-FARRAGUT_345_C3403</b>					FWD	REV
Mon 03/06/2017	to	Thu 04/20/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>02/17/2017</u>	(Import) (Export)
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	<b>2300 MW 1450 MW</b>
					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	2300 MW 1450 MW
<hr/>						
<b>EDIC_-FRASER_345_EF24-40</b>					FWD	
Mon 03/06/2017	to	Fri 03/17/2017	<u>UPDATED</u>	<u>by NY</u>	<u>12/02/2016</u>	(Import)
0630	Continuous	1700				
Work scheduled by: NYPA					CENTRAL EAST - VC	<b>2500 MW</b>
					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW
<hr/>						
<b>MOSES_-ADIRNDCK_230_MAI</b>					FWD	
Mon 03/06/2017	to	Fri 03/10/2017				(Import)
0700	Continuous	1530				
Work scheduled by: NYPA					MOSES SOUTH	<b>2300 MW</b>
					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
<hr/>						
<b>W49TH_ST_345KV_8</b>					FWD	
Wed 03/08/2017	to	Wed 03/08/2017				(Import)
2130	Continuous	2200				
Work scheduled by: ConEd					SCH - PJM_HTP	<b>315 MW</b>
					Impacts Total Transfer Capability	345 MW
					TTC with All Lines In Service	660 MW
<hr/>						
<b>BROWNEFLS-TAYLORVL_115_4</b>					FWD	REV
Sat 03/11/2017	to	Sat 03/11/2017				(Import) (Export)
0600	Daily	1900				
Work scheduled by: NGrid					SCH - HQ_CEDARS	<b>100 MW 100 MW</b>
					Impacts Total Transfer Capability	99 MW 0 MW
					TTC with All Lines In Service	199 MW 100 MW

**ARR: 38**

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 28, 2017 to Thursday ,August 30, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT\_DC\_GC1

Sun 03/12/2017 to Sun 03/12/2017  
0001 Continuous 0200

UPDATED by HQ 02/14/2017

Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

CHAT\_DC\_GC1

Sun 03/12/2017 to Sun 03/12/2017  
0001 Continuous 0200

UPDATED by HQ 02/14/2017

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Sun 03/12/2017 to Sun 03/12/2017  
0001 0200

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **2550 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 3150 MW

CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Sun 03/12/2017 to Sun 03/12/2017  
0001 0200

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY **1370 MW 0 MW**  
Impacts Total Transfer Capability 130 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

CHAT\_DC\_GC2

Sun 03/12/2017 to Sun 03/12/2017  
0001 Continuous 0200

UPDATED by HQ 02/14/2017

Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

CHAT\_DC\_GC2

Sun 03/12/2017 to Sun 03/12/2017  
0001 Continuous 0200

UPDATED by HQ 02/14/2017

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

SCH-HQ-NYISO\_LIMIT\_1100

Sun 03/12/2017 to Sun 03/12/2017  
0001 Continuous 0200

UPDATED by HQ 02/14/2017

Work scheduled by: HQ

FWD  
(Import)  
SCH - HQ - NY **1100 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 28, 2017 to Thursday ,August 30, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**NIAGARA\_-ROCHESTR\_345\_NR2**

Mon 03/13/2017 to Wed 03/15/2017  
 0500 Continuous 1200  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

-----  
**BECK\_-NIAGARA\_345\_PA302**

Mon 03/13/2017 to Fri 03/17/2017  
 0700 Continuous 1600  
 Work scheduled by: IESO

FWD REV  
 (Import) (Export)  
 SCH - OH - NY **1100 MW 950 MW**  
 Impacts Total Transfer Capability 650 MW 950 MW  
 TTC with All Lines In Service 1750 MW 1900 MW

-----  
**MOSES\_-ADIRNDCK\_230\_MA2**

Mon 03/13/2017 to Sat 03/18/2017 **UPDATED by NYPA 10/23/2016**  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MILLWOOD\_345KV\_18**

Tue 03/14/2017 to Fri 03/17/2017  
 0001 Continuous 2359  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 750 MW  
 TTC with All Lines In Service 5100 MW

-----  
**ILCTLIMIT\_115KV\_ALCOA\_R8105\_TIE\_B**

Tue 03/14/2017 to Tue 03/14/2017  
 0700 Daily(No Weekends) 1600  
 Work scheduled by: NGrid

FWD  
 (Import)  
 MOSES SOUTH **3100 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 3150 MW

-----  
**ILCTLIMIT\_115KV\_ALCOA\_R8105\_TIE\_B**

Tue 03/14/2017 to Tue 03/14/2017  
 0700 Daily(No Weekends) 1600  
 Work scheduled by: NGrid

FWD REV  
 (Import) (Export)  
 SCH - HQ\_CEDARS **100 MW 60 MW**  
 Impacts Total Transfer Capability 99 MW 40 MW  
 TTC with All Lines In Service 199 MW 100 MW

-----  
**ILCTLIMIT\_115KV\_ALCOA\_R8105\_TIE\_B**

Wed 03/15/2017 to Wed 03/15/2017  
 0700 Daily(No Weekends) 1600  
 Work scheduled by: NGrid

FWD  
 (Import)  
 MOSES SOUTH **3100 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 28, 2017 to Thursday ,August 30, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ILCTLIMIT	Start	End	Time	Work by	Area	FWD	REV
ILCTLIMIT_115KV_ALCOA_R8105_TIE_B	Wed 03/15/2017	Wed 03/15/2017	0700 Daily(No Weekends) 1600	NGrid	SCH - HQ_CEDARS	100 MW	60 MW
					Impacts Total Transfer Capability	99 MW	40 MW
					TTC with All Lines In Service	199 MW	100 MW
ILCTLIMIT_MARCY_SO_COMP_I/S	Fri 03/17/2017	Mon 03/20/2017	1700 Continuous 0459	NYISO	CENTRAL EAST - VC	2740 MW	
					Impacts Total Transfer Capability	235 MW	
					TTC with All Lines In Service	2975 MW	
LADENTWN-BUCHAN_S_345_Y88	Sat 03/18/2017	Mon 03/20/2017	0001 Continuous 2359	ConEd	UPNY CONED	4150 MW	
					Impacts Total Transfer Capability	950 MW	
					TTC with All Lines In Service	5100 MW	
NINEMILE-CLAY_345_8	Mon 03/20/2017	Wed 03/22/2017	0001 Continuous 0400	NGrid	OSWEGO EXPORT	5150 MW	
					Impacts Total Transfer Capability	100 MW	
					TTC with All Lines In Service	5250 MW	
FRASANNX-COOPERS_345_UCC2-41	Mon 03/20/2017	Fri 03/24/2017	0500 Continuous 1630	NYPA	CENTRAL EAST - VC	2500 MW	
					Impacts Total Transfer Capability	475 MW	
					TTC with All Lines In Service	2975 MW	
MARCY-FRASANNX_345_UCC2-41	Mon 03/20/2017	Fri 03/24/2017	0500 Continuous 1630	NYPA	CENTRAL EAST - VC	2500 MW	
					Impacts Total Transfer Capability	475 MW	
					TTC with All Lines In Service	2975 MW	
					ARR: 19		
MOSES-ADIRNDCK_230_MA2	Mon 03/20/2017	Sat 03/25/2017	0700 Continuous 1530	NYPA	MOSES SOUTH	2300 MW	
					Impacts Total Transfer Capability	850 MW	
					TTC with All Lines In Service	3150 MW	

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 28, 2017 to Thursday ,August 30, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BERKSHIR-ALPS</b> _____ <b>345_393</b>					FWD	REV
Fri 03/24/2017	to	Fri 03/24/2017	<b>UPDATED</b>	<b>by NG</b>	<b>12/27/2016</b>	(Import) (Export)
0800	Daily(No Weekends)	0900				
Work scheduled by: NGrid					<b>ARR: 78</b>	
					SCH - NE - NY	<b>1300 MW 1300 MW</b>
					Impacts Total Transfer Capability	100 MW 300 MW
					TTC with All Lines In Service	1400 MW 1600 MW
<b>BERKSHIR-ALPS</b> _____ <b>345_393</b>					FWD	REV
Fri 03/24/2017	to	Fri 03/24/2017	<b>UPDATED</b>	<b>by NG</b>	<b>12/27/2016</b>	(Import) (Export)
0800	Daily(No Weekends)	0900				
Work scheduled by: NGrid					<b>ARR: 78</b>	
					SCH - NPX_1385	<b>100 MW 100 MW</b>
					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
<b>BERKSHIR-ALPS</b> _____ <b>345_393</b> & <b>BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Fri 03/24/2017	to	Fri 03/24/2017				(Import) (Export)
0800		0900				
Work scheduled by:					<b>ARR: 78</b>	
					SCH - NE - NY	<b>1300 MW 1300 MW</b>
					Impacts Total Transfer Capability	100 MW 300 MW
					TTC with All Lines In Service	1400 MW 1600 MW
<b>BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Fri 03/24/2017	to	Sat 04/22/2017				(Import) (Export)
0800	Continuous	1600				
Work scheduled by: ISONE						
					SCH - NE - NY	<b>1400 MW 1450 MW</b>
					Impacts Total Transfer Capability	0 MW 150 MW
					TTC with All Lines In Service	1400 MW 1600 MW
<b>BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Fri 03/24/2017	to	Sat 04/22/2017				(Import) (Export)
0800	Continuous	1600				
Work scheduled by: ISONE						
					SCH - NPX_1385	<b>100 MW 100 MW</b>
					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
<b>ILCTLIMIT_MARCY_SO_COMP_I/S</b>					FWD	
Fri 03/24/2017	to	Mon 04/17/2017				(Import)
1700	Continuous	0900				
Work scheduled by: NYISO						
					CENTRAL EAST - VC	<b>2740 MW</b>
					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	2975 MW
<b>W49TH_ST_345KV_8</b>					FWD	
Sat 03/25/2017	to	Thu 03/30/2017	<b>UPDATED</b>	<b>by CONED</b>	<b>02/07/2017</b>	(Import)
0201	Continuous	0200				
Work scheduled by: ConEd						
					SCH - PJM_HTP	<b>315 MW</b>
					Impacts Total Transfer Capability	345 MW
					TTC with All Lines In Service	660 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 28, 2017 to Thursday ,August 30, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY___345KV_CSC</b>				FWD	
Mon 03/27/2017	to	Thu 04/13/2017		(Import)	
0500	Continuous	1630	CENTRAL EAST - VC	<b>2925 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	50 MW	
			TTC with All Lines In Service	2975 MW	
<b>MARCY___345KV_CSC &amp; ILCTLIMIT_MARCY_SO_COMP_I/S</b>				FWD	
Mon 03/27/2017	to	Thu 04/13/2017		(Import)	
0500		1630	CENTRAL EAST - VC	<b>2690 MW</b>	
Work scheduled by:			Impacts Total Transfer Capability	285 MW	
			TTC with All Lines In Service	2975 MW	
<b>MOSES___-ADIRNDCK_230_MA2</b>				FWD	
Mon 03/27/2017	to	Sat 04/01/2017	<u>UPDATED</u>		
0700	Continuous	1530	<u>by NYPA</u>		<u>10/23/2016</u>
Work scheduled by: NYPA			MOSES SOUTH	<b>2300 MW</b>	
			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
<b>FRASER___-GILBOA___345_GF5-35</b>				FWD	
Mon 03/27/2017	to	Fri 04/07/2017		(Import)	
0900	Continuous	1430	CENTRAL EAST - VC	<b>2650 MW</b>	
Work scheduled by: NYSEG			Impacts Total Transfer Capability	325 MW	
			TTC with All Lines In Service	2975 MW	
<b>SCRIBA___-VOLNEY___345_20</b>				FWD	
Tue 03/28/2017	to	Tue 03/28/2017		(Import)	
0730	Daily(No Weekends)	1630	OSWEGO EXPORT	<b>5250 MW</b>	
Work scheduled by: NGrid			Impacts Total Transfer Capability	0 MW	
			TTC with All Lines In Service	5250 MW	
<b>LINDN_CG-LNDVFT___345_V-3022</b>				FWD	REV
Sun 04/02/2017	to	Fri 04/07/2017		(Import)	(Export)
1400	Continuous	1800	SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: PJM			Impacts Total Transfer Capability	315 MW	315 MW
			TTC with All Lines In Service	315 MW	315 MW
<b>MOSES___-ADIRNDCK_230_MA1</b>				FWD	
Mon 04/03/2017	to	Sat 04/08/2017		(Import)	
0700	Continuous	1530	MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 28, 2017 to Thursday ,August 30, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**BERKSHIR-NORTHFLD\_345\_312 & NRTH1385-NOR HBR\_\_138\_601**

Mon 04/03/2017 to Wed 04/12/2017  
 0700 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**BERKSHIR-NORTHFLD\_345\_312 & NRTH1385-NOR HBR\_\_138\_602**

Mon 04/03/2017 to Wed 04/12/2017  
 0700 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**BERKSHIR-NORTHFLD\_345\_312 & NRTH1385-NOR HBR\_\_138\_603**

Mon 04/03/2017 to Wed 04/12/2017  
 0700 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NOR HBR\_\_138\_601**

Mon 04/03/2017 to Wed 04/12/2017  
 0700 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_602**

Mon 04/03/2017 to Wed 04/12/2017  
 0700 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_603**

Mon 04/03/2017 to Wed 04/12/2017  
 0700 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NOR HBR\_\_138\_602**

Mon 04/03/2017 to Wed 04/12/2017  
 0700 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 28, 2017 to Thursday ,August 30, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**NRTH1385-NOR HBR\_\_138\_602 & NRTH1385-NOR HBR\_\_138\_603**

Mon 04/03/2017 to Wed 04/12/2017  
 0700 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NOR HBR\_\_138\_603**

Mon 04/03/2017 to Wed 04/12/2017  
 0700 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NRTHPORT\_138\_1385**

Mon 04/03/2017 to Wed 04/12/2017  
 0700 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**HOMRC\_NY-MAINS\_NY\_345\_47**

Mon 04/03/2017 to Fri 04/14/2017 **UPDATED by PJM 01/26/2017**  
 0800 Continuous 1600

Work scheduled by: NYSEG

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2300 MW</b>	<b>1450 MW</b>
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2300 MW	1450 MW

-----  
**MAINESBG-WATRCURE\_345\_30**

Mon 04/03/2017 to Fri 04/14/2017 **UPDATED by PJM 01/26/2017**  
 0800 Continuous 1600

Work scheduled by: NYSEG

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2200 MW</b>	<b>1450 MW</b>
Impacts Total Transfer Capability	100 MW	0 MW
TTC with All Lines In Service	2300 MW	1450 MW

-----  
**W49TH\_ST\_345KV\_6**

Wed 04/05/2017 to Sun 04/09/2017 **UPDATED by CONED 02/07/2017**  
 0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
SCH - PJM_HTP	<b>315 MW</b>
Impacts Total Transfer Capability	345 MW
TTC with All Lines In Service	660 MW

-----  
**SCH-IMO-NYISO\_LIMIT\_500**

Fri 04/07/2017 to Fri 04/07/2017  
 0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
SCH - OH - NY	<b>800 MW</b>
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	1750 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 28, 2017 to Thursday ,August 30, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>COOPERS_-DOLSONAV_345_CCDA42</b>				FWD	
Mon 04/10/2017	to	Mon 04/24/2017		(Import)	
0630	Continuous	1700	CENTRAL EAST - VC	<b>2720 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	255 MW	
			TTC with All Lines In Service	2975 MW	
<b>DOLSONAV-ROCKTVRN_345_DART44</b>				FWD	
Mon 04/10/2017	to	Mon 04/24/2017		(Import)	
0630	Continuous	1700	CENTRAL EAST - VC	<b>2720 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	255 MW	
			TTC with All Lines In Service	2975 MW	
<b>MOSES_-ADIRNDCK_230_MAL</b>				FWD	
Mon 04/10/2017	to	Thu 04/13/2017		(Import)	
0700	Continuous	1530	MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
<b>N.SCTLND-LEEDS_345_93</b>				FWD	
Mon 04/10/2017	to	Mon 04/10/2017		(Import)	
1100	Daily(No Weekends)	1500	CENTRAL EAST - VC	<b>2650 MW</b>	
Work scheduled by: NGrid			Impacts Total Transfer Capability	325 MW	
			TTC with All Lines In Service	2975 MW	
<b>LEEDS_-PLSNTVLY_345_92</b>				FWD	
Tue 04/11/2017	to	Thu 04/13/2017		(Import)	
0730	Continuous	1600	UPNY CONED	<b>3800 MW</b>	
Work scheduled by: NGrid			Impacts Total Transfer Capability	1300 MW	
			TTC with All Lines In Service	5100 MW	
<b>SHOR_NPX-SHOREHAM_138_CSC</b>				FWD	REV
Mon 04/17/2017	to	Sat 04/22/2017		(Import)	(Export)
0500	Continuous	1600	SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability	330 MW	330 MW
			TTC with All Lines In Service	330 MW	330 MW
<b>MOSES_-ADIRNDCK_230_MA2</b>				FWD	
Mon 04/17/2017	to	Sat 04/22/2017	<b>UPDATED</b>	(Import)	
0700	Continuous	1530	<b>by NYPA</b>	MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA			<b>10/23/2016</b>	Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 28, 2017 to Thursday ,August 30, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>FRASER__-COOPERS__345_33</b>					FWD
Mon 04/17/2017	to	Fri 04/21/2017	<b>UPDATED</b>	<b>by NY</b>	(Import)
0900	Continuous	1400		<b>01/12/2017</b>	<b>2395 MW</b>
Work scheduled by: NYSEG					CENTRAL EAST - VC
					Impacts Total Transfer Capability 580 MW
					TTC with All Lines In Service 2975 MW
<hr/>					
<b>W49TH_ST_345KV_6</b>					FWD
Thu 04/20/2017	to	Thu 04/20/2017	<b>UPDATED</b>	<b>by CONED</b>	(Import)
0230	Continuous	0300		<b>02/07/2017</b>	<b>315 MW</b>
Work scheduled by: ConEd					SCH - PJM_HTP
					Impacts Total Transfer Capability 345 MW
					TTC with All Lines In Service 660 MW
<hr/>					
<b>DUNWODIE_345KV_6</b>					FWD
Fri 04/21/2017	to	Fri 04/21/2017			(Import)
0001	Continuous	0100			<b>3800 MW</b>
Work scheduled by: ConEd					SPR/DUN-SOUTH
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<hr/>					
<b>DUNWODIE_345KV_8</b>					FWD
Fri 04/21/2017	to	Fri 04/21/2017			(Import)
0001	Continuous	0100			<b>3800 MW</b>
Work scheduled by: ConEd					SPR/DUN-SOUTH
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<hr/>					
<b>PLSNTVLE-DUNWODIE_345_W90</b>					FWD
Fri 04/21/2017	to	Sun 04/23/2017			(Import)
0001	Continuous	0200			<b>4000 MW</b>
Work scheduled by: ConEd					UPNY CONED
					Impacts Total Transfer Capability 1100 MW
					TTC with All Lines In Service 5100 MW
<hr/>					
<b>WOOD_ST_-PLSNTVLE_345_Y87</b>					FWD
Fri 04/21/2017	to	Sun 04/23/2017			(Import)
0001	Continuous	0200			<b>4000 MW</b>
Work scheduled by: ConEd					UPNY CONED
					Impacts Total Transfer Capability 1100 MW
					TTC with All Lines In Service 5100 MW
<hr/>					
<b>MARION__-FARRAGUT_345_C3403</b>					FWD
Fri 04/21/2017	to	Sat 05/20/2017	<b>UPDATED</b>	<b>by CE</b>	(Import) (Export)
0001	Continuous	2359		<b>01/28/2017</b>	<b>2300 MW 1450 MW</b>
Work scheduled by: PJM					SCH - PJ - NY
					Impacts Total Transfer Capability 0 MW 0 MW
					TTC with All Lines In Service 2300 MW 1450 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 28, 2017 to Thursday ,August 30, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ILCTLIMIT_MARCY_SO_COMP_I/S			FWD	REV
Fri 04/21/2017	to	Sat 05/27/2017	(Import)	
1400	Continuous	0459	CENTRAL EAST - VC	<b>2740 MW</b>
Work scheduled by: NYISO			Impacts Total Transfer Capability	235 MW
			TTC with All Lines In Service	2975 MW
<b>BERKSHIR-ALPS 345_393</b>			FWD	REV
Sat 04/22/2017	to	Sat 04/22/2017	(Import)	(Export)
1500	Daily	1600	SCH - NE - NY	<b>1300 MW 1300 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	100 MW 300 MW
<b>ARR: 78</b>			TTC with All Lines In Service	1400 MW 1600 MW
<b>BERKSHIR-ALPS 345_393</b>			FWD	REV
Sat 04/22/2017	to	Sat 04/22/2017	(Import)	(Export)
1500	Daily	1600	SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	100 MW 100 MW
<b>ARR: 78</b>			TTC with All Lines In Service	200 MW 200 MW
<b>BERKSHIR-ALPS 345_393 &amp; BERKSHIR-NORTHFLD 345_312</b>			FWD	REV
Sat 04/22/2017	to	Sat 04/22/2017	(Import)	(Export)
1500		1600	SCH - NE - NY	<b>1300 MW 1300 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	100 MW 300 MW
<b>ARR: 78</b>			TTC with All Lines In Service	1400 MW 1600 MW
<b>DUNWODIE_345KV_6</b>			FWD	
Sun 04/23/2017	to	Sun 04/23/2017	(Import)	
0100	Continuous	0200	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_8</b>			FWD	
Sun 04/23/2017	to	Sun 04/23/2017	(Import)	
0100	Continuous	0200	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
<b>ROSETON_EFISHKIL 345_RFK305</b>			FWD	
Mon 04/24/2017	to	Fri 05/05/2017	(Import)	
0001	Continuous	1900	UPNY CONED	<b>4100 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1000 MW
			TTC with All Lines In Service	5100 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 28, 2017 to Thursday ,August 30, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer Capability	FWD	REV
<b>CLAY -EDIC 345_1-16</b>		
Mon 04/24/2017 to Tue 04/25/2017	(Import)	
0630 Continuous 1530	OSWEGO EXPORT	<b>4850 MW</b>
Work scheduled by: NYPA	Impacts Total Transfer Capability	400 MW
	TTC with All Lines In Service	5250 MW
<b>STLAWRNC-MOSES 230_L34P</b>		
Mon 04/24/2017 to Fri 04/28/2017	(Import)	(Export)
0700 Continuous 1530	SCH - OH - NY	<b>1750 MW 1900 MW</b>
Work scheduled by: NYPA	Impacts Total Transfer Capability	0 MW 0 MW
	TTC with All Lines In Service	1750 MW 1900 MW
<b>MOSES -ADIRNDCK 230_MA2</b>		
Mon 04/24/2017 to Sat 04/29/2017	(Import)	
0700 Continuous 1530	MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA	Impacts Total Transfer Capability	850 MW
	TTC with All Lines In Service	3150 MW
<b>ALCOA -DENNISON 115_12</b>		
Wed 04/26/2017 to Wed 04/26/2017	(Import)	(Export)
0700 Daily(No Weekends) 1800	SCH - HQ_CEDARS	<b>100 MW 100 MW</b>
Work scheduled by: NGrid	Impacts Total Transfer Capability	99 MW 0 MW
<b>ARR: 38</b>	TTC with All Lines In Service	199 MW 100 MW
<b>ALCOA -DENNISON 115_12 &amp; ALCOA -NOGDNRG 115_13</b>		
Wed 04/26/2017 to Wed 04/26/2017	(Import)	(Export)
0700 1800	SCH - HQ_CEDARS	<b>100 MW 60 MW</b>
Work scheduled by:	Impacts Total Transfer Capability	99 MW 40 MW
<b>ARR: 38</b>	TTC with All Lines In Service	199 MW 100 MW
<b>ILCTLIMIT 115KV_ALCOA_R8105_TIE_B</b>		
Wed 04/26/2017 to Wed 04/26/2017	(Import)	
0700 Daily(No Weekends) 1800	MOSES SOUTH	<b>3100 MW</b>
Work scheduled by: NGrid	Impacts Total Transfer Capability	50 MW
	TTC with All Lines In Service	3150 MW
<b>ILCTLIMIT 115KV_ALCOA_R8105_TIE_B</b>		
Wed 04/26/2017 to Wed 04/26/2017	(Import)	(Export)
0700 Daily(No Weekends) 1800	SCH - HQ_CEDARS	<b>100 MW 60 MW</b>
Work scheduled by: NGrid	Impacts Total Transfer Capability	99 MW 40 MW
	TTC with All Lines In Service	199 MW 100 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 28, 2017 to Thursday ,August 30, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA\_-ROCHESTR\_345\_NR2

Fri 04/28/2017 to Fri 04/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 05/01/2017 to Tue 05/16/2017 UPDATED by LI 02/14/2017  
0400 Continuous 1800

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE\_345\_501

Mon 05/01/2017 to Tue 05/16/2017 UPDATED by LI 02/14/2017  
0400 Continuous 1800

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

MARCY\_-N.SCTLND\_345\_18

Mon 05/01/2017 to Fri 05/05/2017  
0600 Continuous 1630

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2090 MW**  
Impacts Total Transfer Capability 885 MW  
TTC with All Lines In Service 2975 MW

MARCY\_-N.SCTLND\_345\_18 & ILCTLIMIT\_MARCY\_SO\_COMP\_I/S

Mon 05/01/2017 to Fri 05/05/2017  
0600 1630

Work scheduled by:

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **1855 MW**  
Impacts Total Transfer Capability 1120 MW  
TTC with All Lines In Service 2975 MW

BROWNFLS-TAYLORVL\_115\_3

Mon 05/01/2017 to Fri 05/26/2017  
0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **70 MW 40 MW**  
Impacts Total Transfer Capability 120 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

ROCHESTR-PANNELL\_345\_RP2

Mon 05/01/2017 to Mon 05/01/2017  
0630 Continuous 0700

Work scheduled by: RGE

FWD  
(Import)  
DYSINGER EAST **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 28, 2017 to Thursday ,August 30, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PANNELL\_-CLAY\_\_\_\_\_345\_2**

Mon 05/01/2017 to Fri 05/05/2017  
0630 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**ROCHESTR-PANNELL\_\_\_345\_RP2**

Fri 05/05/2017 to Fri 05/05/2017  
1500 Continuous 1530

Work scheduled by: RGE

FWD

(Import)

DYSINGER EAST **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**PANNELL\_-CLAY\_\_\_\_\_345\_2**

Mon 05/08/2017 to Mon 05/08/2017  
0700 Continuous 0730

Work scheduled by: RGE

FWD

(Import)

WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**ROCHESTR-PANNELL\_\_\_345\_RP2**

Mon 05/08/2017 to Wed 05/10/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**ROSETON\_-ROCKTVRN\_345\_311**

Mon 05/08/2017 to Fri 05/26/2017  
0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 5100 MW

**PANNELL\_-CLAY\_\_\_\_\_345\_2**

Wed 05/10/2017 to Wed 05/10/2017  
1500 Continuous 1530

Work scheduled by: RGE

FWD

(Import)

WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**FRASER\_-GILBOA\_\_\_345\_GF5-35**

Mon 05/15/2017 to Fri 05/19/2017  
0630 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 28, 2017 to Thursday ,August 30, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>STONYRDG-HILLSIDE_230_72</b>				FWD	
Mon 05/15/2017	to	Mon 05/15/2017		(Import)	
0800	Continuous	1700	DYSINGER EAST	<b>2850 MW</b>	
Work scheduled by: NYSEG			Impacts Total Transfer Capability	300 MW	
			TTC with All Lines In Service	3150 MW	
<b>FRASER_345_FRASER SVC</b>				FWD	
Mon 05/15/2017	to	Fri 05/19/2017		(Import)	
0900	Continuous	1430	CENTRAL EAST - VC	<b>2935 MW</b>	
Work scheduled by: NYSEG			Impacts Total Transfer Capability	40 MW	
			TTC with All Lines In Service	2975 MW	
<b>FRASER_345_FRASER SVC &amp; ILCTLIMIT_MARCY_SO_COMP_I/S</b>				FWD	
Mon 05/15/2017	to	Fri 05/19/2017		(Import)	
0900		1430	CENTRAL EAST - VC	<b>2700 MW</b>	
Work scheduled by:			Impacts Total Transfer Capability	275 MW	
			TTC with All Lines In Service	2975 MW	
<b>RAMAPO_-LADENTWN_345_W72</b>				FWD	
Tue 05/16/2017	to	Tue 05/16/2017		(Import)	
0001	Continuous	2330	UPNY CONED	<b>4400 MW</b>	
Work scheduled by: ORU			Impacts Total Transfer Capability	700 MW	
			TTC with All Lines In Service	5100 MW	
<b>MARCY_765_345_AT1</b>				FWD	
Mon 05/22/2017	to	Fri 05/26/2017		(Import)	
0500	Continuous	1630	MOSES SOUTH	<b>1750 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1400 MW	
			TTC with All Lines In Service	3150 MW	
<b>LINDEN_-GOETHALS_230_A2253</b>				FWD	REV
Fri 05/26/2017	to	Sat 05/27/2017	<b>UPDATED</b>	<b>by CE</b>	<b>02/01/2017</b>
0001	Continuous	2359	SCH - PJ - NY	<b>2050 MW</b>	<b>1300 MW</b>
Work scheduled by: PJM			Impacts Total Transfer Capability	0 MW	0 MW
			TTC with All Lines In Service	2050 MW	1300 MW
<b>MARCY_-N.SCTLND_345_18</b>				FWD	
Sat 05/27/2017	to	Sat 05/27/2017		(Import)	
0500	Continuous	1530	CENTRAL EAST - VC	<b>2090 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	885 MW	
			TTC with All Lines In Service	2975 MW	

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 28, 2017 to Thursday ,August 30, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ILCTLIMIT_MARCY_SO_COMP_I/S			FWD		
Sat 05/27/2017	to	Sat 08/05/2017	(Import)		
1600	Continuous	0459	CENTRAL EAST - VC	<b>2740 MW</b>	
Work scheduled by: NYISO			Impacts Total Transfer Capability	235 MW	
			TTC with All Lines In Service	2975 MW	
BROWNFLS-TAYLORVL_115_4			FWD	REV	
Tue 05/30/2017	to	Sat 06/24/2017	(Import)	(Export)	
0600	Continuous	1900	SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	120 MW	0 MW
			TTC with All Lines In Service	190 MW	40 MW
			<b>ARR: 38</b>		
STONYRDG-HILLSIDE_230_72			FWD		
Mon 06/05/2017	to	Mon 06/05/2017	(Import)		
0800	Continuous	1000	DYSINGER EAST	<b>2850 MW</b>	
Work scheduled by: NYSEG			Impacts Total Transfer Capability	300 MW	
			TTC with All Lines In Service	3150 MW	
STONYRDG-HILLSIDE_230_72			FWD		
Fri 06/09/2017	to	Fri 06/09/2017	(Import)		
1500	Continuous	1700	DYSINGER EAST	<b>2850 MW</b>	
Work scheduled by: NYSEG			Impacts Total Transfer Capability	300 MW	
			TTC with All Lines In Service	3150 MW	
BROWNFLS-TAYLORVL_115_3			FWD	REV	
Mon 06/26/2017	to	Sat 07/01/2017	(Import)	(Export)	
0600	Continuous	1900	SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	120 MW	0 MW
			TTC with All Lines In Service	190 MW	40 MW
			<b>ARR: 38</b>		
BROWNFLS-TAYLORVL_115_3			FWD	REV	
Wed 07/05/2017	to	Sat 07/22/2017	(Import)	(Export)	
0600	Continuous	1900	SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	120 MW	0 MW
			TTC with All Lines In Service	190 MW	40 MW
			<b>ARR: 38</b>		
BROWNFLS-TAYLORVL_115_4			FWD	REV	
Mon 07/24/2017	to	Sat 08/19/2017	(Import)	(Export)	
0600	Continuous	1900	SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	120 MW	0 MW
			TTC with All Lines In Service	190 MW	40 MW
			<b>ARR: 38</b>		

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 28, 2017 to Thursday ,August 30, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY___-N.SCTLND_345_18</b>			FWD
Sat 08/05/2017	to	Sat 08/05/2017	(Import)
0500	Continuous	1530	<b>CENTRAL EAST - VC</b> <b>2090 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 885 MW
<b>ARR: 19</b>			TTC with All Lines In Service 2975 MW
<b>MARCY___765_345_AT2</b>			FWD
Sat 08/05/2017	to	Sat 08/05/2017	(Import)
0500	Continuous	1530	<b>MOSES SOUTH</b> <b>1700 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 1450 MW
<b>ARR: 19</b>			TTC with All Lines In Service 3150 MW
<b>ILCTLIMIT_MARCY_SO_COMP_I/S</b>			FWD
Sat 08/05/2017	to	Mon 11/06/2017	(Import)
1600	Continuous	0559	<b>CENTRAL EAST - VC</b> <b>2740 MW</b>
Work scheduled by: NYISO			Impacts Total Transfer Capability 235 MW
			TTC with All Lines In Service 2975 MW
<b>BROWNFLS-TAYLORVL_115_3</b>			FWD      REV
Mon 08/21/2017	to	Fri 09/01/2017	(Import) (Export)
0600	Continuous	1900	<b>SCH - HQ_CEDARS</b> <b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability 120 MW 0 MW
<b>ARR: 38</b>			TTC with All Lines In Service 190 MW 40 MW
<b>MARCY___765_345_AT2</b>			FWD
Tue 09/05/2017	to	Sun 09/10/2017	(Import)
0500	Continuous	1630	<b>MOSES SOUTH</b> <b>1700 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 1450 MW
<b>ARR: 19</b>			TTC with All Lines In Service 3150 MW
<b>BROWNFLS-TAYLORVL_115_3</b>			FWD      REV
Tue 09/05/2017	to	Sat 09/16/2017	(Import) (Export)
0600	Continuous	1900	<b>SCH - HQ_CEDARS</b> <b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability 120 MW 0 MW
<b>ARR: 38</b>			TTC with All Lines In Service 190 MW 40 MW
<b>HURLYAVE-ROSETON__345_303</b>			FWD
Mon 09/11/2017	to	Fri 09/29/2017	(Import)
0800	Continuous	1600	<b>UPNY CONED</b> <b>4100 MW</b>
Work scheduled by: CHGE			Impacts Total Transfer Capability 1000 MW
			TTC with All Lines In Service 5100 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 28, 2017 to Thursday ,August 30, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE_345KV_5</b>				FWD	
Fri 09/15/2017	to	Sun 09/17/2017		(Import)	
2200	Continuous	0200	SPR/DUN-SOUTH	<b>3800 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
<b>DUNWODIE_345KV_7</b>				FWD	
Fri 09/15/2017	to	Sun 09/17/2017		(Import)	
2200	Continuous	0200	SPR/DUN-SOUTH	<b>3800 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
<b>SPRNBRK_-DUNWODIE_345_W75</b>				FWD	
Fri 09/15/2017	to	Sun 09/17/2017		(Import)	
2200	Continuous	0200	SPR/DUN-SOUTH	<b>3800 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
<b>SPRNBRK__345KV_RNS3</b>				FWD	
Fri 09/15/2017	to	Sun 09/17/2017		(Import)	
2200	Continuous	0200	SPR/DUN-SOUTH	<b>3800 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
<b>BROWNFLS-TAYLORVL_115_4</b>				FWD	REV
Mon 09/18/2017	to	Fri 10/13/2017		(Import)	(Export)
0600	Continuous	1600	SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	120 MW	0 MW
			TTC with All Lines In Service	190 MW	40 MW
<b>GILBOA_-N.SCTLND_345_GNS-1</b>				FWD	
Mon 09/18/2017	to	Fri 10/06/2017		(Import)	
0630	Continuous	1700	CENTRAL EAST - VC	<b>2520 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	455 MW	
			TTC with All Lines In Service	2975 MW	
<b>NIAGARA__345_230_AT4</b>				FWD	REV
Mon 09/18/2017	to	Tue 09/19/2017		(Import)	(Export)
0700	Continuous	1530	SCH - OH - NY	<b>1750 MW</b>	<b>1300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	0 MW	300 MW
			TTC with All Lines In Service	1750 MW	1600 MW

ARR: 38

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 28, 2017 to Thursday ,August 30, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_-ROCHESTR\_345\_NR2**

Mon 10/02/2017 to Fri 10/06/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**CHATGUAY-MASSENA\_765\_7040**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

**CHATGUAY-MASSENA\_765\_7040**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - HQ - NY **0 MW 0 MW**  
Impacts Total Transfer Capability 1500 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

**MARCY\_765\_345\_AT1**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1750 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

**MARCY\_765\_345\_AT2**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**MASSENA\_-MARCY\_765\_MSU1**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2265 MW**  
Impacts Total Transfer Capability 710 MW  
TTC with All Lines In Service 2975 MW

**MASSENA\_-MARCY\_765\_MSU1**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 28, 2017 to Thursday ,August 30, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event	Start	End	Time	Day	Zone	FWD	REV	
MASSENA -MARCY 765_MSU1	Sat 10/14/2017	Sat 10/28/2017	0700	Continuous	1530	(Import)	(Export)	
Work scheduled by:	NYPA					SCH - HQ - NY	475 MW	1000 MW
						Impacts Total Transfer Capability	1025 MW	0 MW
						TTC with All Lines In Service	1500 MW	1000 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040	Sat 10/14/2017	Sat 10/28/2017	0700	Continuous	1530	(Import)		
Work scheduled by:						MOSES SOUTH	500 MW	
						Impacts Total Transfer Capability	2650 MW	
						TTC with All Lines In Service	3150 MW	
MASSENA -MARCY 765_MSU1 & ILCTLIMIT_MARCY_SO_COMP_I/S	Sat 10/14/2017	Sat 10/28/2017	0700	Continuous	1530	(Import)		
Work scheduled by:						CENTRAL EAST - VC	2080 MW	
						Impacts Total Transfer Capability	895 MW	
						TTC with All Lines In Service	2975 MW	
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	Sat 10/14/2017	Sat 10/28/2017	0700	Continuous	1530	(Import)	(Export)	
Work scheduled by:						SCH - HQ - NY	850 MW	0 MW
						Impacts Total Transfer Capability	650 MW	1000 MW
						TTC with All Lines In Service	1500 MW	1000 MW
LEEDS -HURLYAVE 345_301	Mon 10/16/2017	Fri 11/03/2017	0800	Continuous	1600	(Import)		
Work scheduled by:	CHGE					UPNY CONED	4100 MW	
						Impacts Total Transfer Capability	1000 MW	
						TTC with All Lines In Service	5100 MW	
BROWNFLS-TAYLORVL 115_3	Mon 10/30/2017	Sat 11/11/2017	0700	Continuous	1900	(Import)	(Export)	
Work scheduled by:	NGrid					SCH - HQ_CEDARS	70 MW	40 MW
						Impacts Total Transfer Capability	120 MW	0 MW
						TTC with All Lines In Service	190 MW	40 MW
						<b>ARR: 38</b>		
FRASANX-COOPERS 345_UCC2-41	Mon 11/06/2017	Fri 11/17/2017	0600	Continuous	1700	(Import)		
Work scheduled by:	NYPA					CENTRAL EAST - VC	2500 MW	
						Impacts Total Transfer Capability	475 MW	
						TTC with All Lines In Service	2975 MW	

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 28, 2017 to Thursday ,August 30, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
<b>MARCY___-FRASANNX_345_UCC2-41</b>			FWD
Mon 11/06/2017	to	Fri 11/17/2017	(Import)
0600	Continuous	1700	CENTRAL EAST - VC <b>2500 MW</b>
Work scheduled by: NYPA		<b>ARR: 19</b>	Impacts Total Transfer Capability 475 MW
			TTC with All Lines In Service 2975 MW
<hr/>			
<b>BROWNFLS-TAYLORVL_115_4</b>			FWD REV
Mon 11/13/2017	to	Thu 11/30/2017	(Import) (Export)
0600	Continuous	1900	SCH - HQ_CEDARS <b>100 MW 100 MW</b>
Work scheduled by: NGrid		<b>ARR: 38</b>	Impacts Total Transfer Capability 99 MW 0 MW
			TTC with All Lines In Service 199 MW 100 MW
<hr/>			
<b>ILCTLIMIT_MARCY_SO_COMP_I/S</b>			FWD
Fri 11/17/2017	to	Sat 02/01/2020	(Import)
1700	Continuous	0000	CENTRAL EAST - VC <b>2740 MW</b>
Work scheduled by: NYISO			Impacts Total Transfer Capability 235 MW
			TTC with All Lines In Service 2975 MW
<hr/>			
<b>MARCY___765_345_AT2</b>			FWD
Mon 12/04/2017	to	Fri 12/08/2017	(Import)
0500	Continuous	1630	MOSES SOUTH <b>1700 MW</b>
Work scheduled by: NYPA		<b>ARR: 19</b>	Impacts Total Transfer Capability 1450 MW
			TTC with All Lines In Service 3150 MW
<hr/>			
<b>MOSES___-ADIRNDCK_230_MA2</b>			FWD
Mon 12/11/2017	to	Fri 12/15/2017	(Import)
0700	Continuous	1530	MOSES SOUTH <b>2300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 850 MW
			TTC with All Lines In Service 3150 MW
<hr/>			
<b>MOSES___-ADIRNDCK_230_MA2</b>			FWD
Mon 12/18/2017	to	Fri 12/22/2017	(Import)
0700	Continuous	1530	MOSES SOUTH <b>2300 MW</b>
Work scheduled by: NYPA		<b>ARR: 19</b>	Impacts Total Transfer Capability 850 MW
			TTC with All Lines In Service 3150 MW
<hr/>			
<b>MOSES___-ADIRNDCK_230_MA2</b>			FWD
Tue 12/26/2017	to	Thu 12/28/2017	(Import)
0700	Continuous	1530	MOSES SOUTH <b>2300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 850 MW
			TTC with All Lines In Service 3150 MW