

# NYISO TRANSFER LIMITATIONS

Saturday ,April 29, 2017 to Monday ,October 29, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>RAMAPO___345_345_PAR3500</b>							
Fri 06/24/2016	to	Fri 09/15/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>03/22/2017</u>	SCH - PJ - NY	<b>1700 MW</b>
1940	Continuous	2359				Impacts Total Transfer Capability	1300 MW
Work scheduled by: ConEd						TTC with All Lines In Service	2300 MW
<b>PLSNTVLE-DUNWODIE_345_W89</b>						FWD	
						(Import)	
Sun 10/30/2016	to	Tue 05/02/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/25/2017</u>	UPNY CONED	<b>4000 MW</b>
0728	Continuous	1600				Impacts Total Transfer Capability	1100 MW
Work scheduled by: ConEd						TTC with All Lines In Service	5100 MW
<b>HUDSONTP-W49TH_ST_345_Y56</b>						FWD	
						(Import)	
Thu 11/24/2016	to	Sat 07/15/2017	<u>EXTENDED</u>	<u>by PJM</u>	<u>01/27/2017</u>	SCH - PJM_HTP	<b>0 MW</b>
1500	Continuous	2359				Impacts Total Transfer Capability	660 MW
Work scheduled by: ConEd						TTC with All Lines In Service	660 MW
<b>E13THSTA-FARRAGUT_345_46</b>						FWD	
						(Import)	
Tue 12/20/2016	to	Sat 05/06/2017	<u>EXTENDED</u>	<u>by CONED</u>	<u>04/25/2017</u>	SPR/DUN-SOUTH	<b>3800 MW</b>
0001	Continuous	0300				Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd						TTC with All Lines In Service	4600 MW
<b>W49TH_ST-E13THSTA_345_M55</b>						FWD	
						(Import)	
Tue 12/20/2016	to	Sat 05/06/2017	<u>EXTENDED</u>	<u>by CONED</u>	<u>04/25/2017</u>	SPR/DUN-SOUTH	<b>3800 MW</b>
0001	Continuous	0300				Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd						TTC with All Lines In Service	4600 MW
<b>HUDSONP_-FARRAGUT_345_B3402</b>						FWD	REV
						(Import)	(Export)
Tue 03/21/2017	to	Wed 05/03/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/03/2017</u>	SCH - PJ - NY	<b>2050 MW</b>
0001	Continuous	2359				Impacts Total Transfer Capability	1300 MW
Work scheduled by: ConEd						TTC with All Lines In Service	250 MW
<b>HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>						FWD	REV
						(Import)	(Export)
Tue 03/21/2017	to	Wed 05/03/2017				SCH - PJ - NY	<b>2050 MW</b>
0001		2359				Impacts Total Transfer Capability	1300 MW
Work scheduled by:						TTC with All Lines In Service	250 MW
							150 MW
							2300 MW
							1450 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 29, 2017 to Monday ,October 29, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARION\_\_-FARRAGUT\_345\_C3403**

Tue 03/21/2017 to Wed 05/03/2017  
0001 Continuous 2359

UPDATED by CONED 04/03/2017

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2050 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	250 MW	150 MW
TTC with All Lines In Service	2300 MW	1450 MW

**DUNWODIE\_345KV\_3**

Fri 04/07/2017 to Tue 05/02/2017  
0001 Continuous 1600

UPDATED by CONED 04/25/2017

Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	<b>3800 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

**DUNWODIE\_345KV\_4**

Fri 04/07/2017 to Tue 05/02/2017  
0001 Continuous 1600

UPDATED by CONED 04/25/2017

Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	<b>3800 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

**HOMRC\_NY-MAINS\_NY\_345\_47**

Fri 04/14/2017 to Mon 04/24/2017  
1600 Continuous 1600

RETURNED by PJM 04/24/2017

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2300 MW</b>	<b>1450 MW</b>
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2300 MW	1450 MW

**DUNWODIE-MOTTHAVN\_345\_71**

Mon 04/17/2017 to Wed 05/31/2017  
2120 Continuous 2359

EXT FORCE by CE 04/21/2017

Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	<b>3800 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

**ILCTLIMIT\_MARCY\_SO\_COMP\_I/S**

Fri 04/21/2017 to Fri 04/28/2017  
1400 Continuous 0045

Work scheduled by: NYISO

	FWD
	(Import)
CENTRAL EAST - VC	<b>2740 MW</b>
Impacts Total Transfer Capability	235 MW
TTC with All Lines In Service	2975 MW

**SCH-NYISO-HQ\_LIMIT\_900**

Sat 04/22/2017 to Sun 04/30/2017  
2200 Continuous 0600

Work scheduled by: HQ

	REV
	(Export)
SCH - HQ - NY	<b>900 MW</b>
Impacts Total Transfer Capability	100 MW
TTC with All Lines In Service	1000 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 29, 2017 to Monday ,October 29, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## ROSETON\_-EFISHKIL\_345\_RFK305

Mon 04/24/2017 to Fri 05/05/2017

0600 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

UPNY CONED

4100 MW

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 5100 MW

## CLAY\_-EDIC\_345\_1-16

Mon 04/24/2017 to Tue 04/25/2017

0630 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

OSWEGO EXPORT

4850 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

## STLAWRNC-MOSES\_230\_L34P

Mon 04/24/2017 to Fri 04/28/2017

0700 Continuous 1559

Work scheduled by: NYPA

FWD

(Import)

REV

(Export)

SCH - OH - NY

1750 MW

1900 MW

Impacts Total Transfer Capability 0 MW

0 MW

TTC with All Lines In Service 1750 MW

1900 MW

## MOSES\_-ADIRNDCK\_230\_MAI

Mon 04/24/2017 to Sat 04/29/2017

0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## BEAR SWP-EASTOVER\_230\_E205W

Mon 04/24/2017 to Tue 05/30/2017

0700 Continuous 0659

Work scheduled by: NGrid

UPDATED

by NE

04/24/2017

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## ALCOA\_-DENNISON\_115\_12

Mon 04/24/2017 to Wed 04/26/2017

0800 Continuous 0659

Work scheduled by: NGrid

ARR: 38

FWD

(Import)

REV

(Export)

SCH - HQ\_CEDARS

100 MW

100 MW

Impacts Total Transfer Capability 99 MW

0 MW

TTC with All Lines In Service 199 MW

100 MW

## ALCOA\_-DENNISON\_115\_12 & ALCOA\_-NOGDNBRG\_115\_13

Wed 04/26/2017 to Wed 04/26/2017

0700 1800

Work scheduled by:

ARR: 38

FWD

(Import)

REV

(Export)

SCH - HQ\_CEDARS

100 MW

60 MW

Impacts Total Transfer Capability 99 MW

40 MW

TTC with All Lines In Service 199 MW

100 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 29, 2017 to Monday ,October 29, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>ILCTLIMIT_115KV_ALCOA_R8105_TIE_B</b>					FWD	
Wed 04/26/2017	to	Wed 04/26/2017	<b>EXTENDED</b>	<b>by NGRID</b>	<b>04/27/2017</b>	(Import)
0700	Daily(No Weekends)	1800				
Work scheduled by: NGrid					MOSES SOUTH	<b>3100 MW</b>
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	3150 MW
<b>ILCTLIMIT_115KV_ALCOA_R8105_TIE_B</b>					FWD	REV
Wed 04/26/2017	to	Wed 04/26/2017	<b>EXTENDED</b>	<b>by NGRID</b>	<b>04/27/2017</b>	(Import) (Export)
0700	Daily(No Weekends)	1800				
Work scheduled by: NGrid					SCH - HQ_CEDARS	<b>100 MW 60 MW</b>
					Impacts Total Transfer Capability	99 MW 40 MW
					TTC with All Lines In Service	199 MW 100 MW
<b>ALCOA__-DENNISON_115_12</b>					FWD	REV
Wed 04/26/2017	to	Fri 04/28/2017	<b>EXTENDED</b>	<b>by NGRID</b>	<b>04/27/2017</b>	(Import) (Export)
0700	Daily(No Weekends)	1800				
Work scheduled by: NGrid					SCH - HQ_CEDARS	<b>100 MW 100 MW</b>
					Impacts Total Transfer Capability	99 MW 0 MW
					TTC with All Lines In Service	199 MW 100 MW
<b>SCH-NYISO-HQ_CEDARS_LIMIT_0</b>						REV
Thu 04/27/2017	to	Thu 04/27/2017				(Export)
0800	Continuous	1500				
Work scheduled by: HQ					SCH - HQ_CEDARS	<b>0 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	100 MW
<b>SCRIBA__-VOLNEY__345_21</b>					FWD	
Thu 04/27/2017	to	Thu 04/27/2017				(Import)
0800	Daily(No Weekends)	1630				
Work scheduled by: NGrid					OSWEGO EXPORT	<b>5250 MW</b>
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	5250 MW
<b>NIAGARA_-ROCHESTR_345_NR2</b>					FWD	
Fri 04/28/2017	to	Fri 04/28/2017	<b>UPDATED</b>	<b>by PA</b>	<b>03/29/2017</b>	(Import)
0500	Continuous	1700				
Work scheduled by: NYPA					DYSINGER EAST	<b>1700 MW</b>
					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
<b>SCH-IMO-NYISO_LIMIT_1000</b>					FWD	
Fri 04/28/2017	to	Fri 04/28/2017	<b>UPDATED</b>	<b>by PJM</b>	<b>04/26/2017</b>	(Import)
1100	Continuous	1300				
Work scheduled by: PJM					SCH - OH - NY	<b>1300 MW</b>
					Impacts Total Transfer Capability	450 MW
					TTC with All Lines In Service	1750 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 29, 2017 to Monday ,October 29, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NYISO-PJM\_LIMIT\_100

Fri 04/28/2017 to Fri 04/28/2017 UPDATED by PJM 04/26/2017

1100 Continuous 1300

Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1050 MW  
1450 MW

## STLAWRNC-MOSES\_230\_L34P

Fri 04/28/2017 to Sun 04/30/2017

1600 Continuous 1530

Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability 1750 MW 1900 MW  
TTC with All Lines In Service 0 MW 0 MW  
1750 MW 1900 MW

## ILCTLIMIT\_MARCY\_SO\_COMP\_I/S

Fri 04/28/2017 to Mon 05/01/2017

1759 Continuous 0400

Work scheduled by: NYISO

CENTRAL EAST - VC  
Impacts Total Transfer Capability 2740 MW  
TTC with All Lines In Service 235 MW  
2975 MW

## CLAY\_-EDIC\_345\_2-15

Sat 04/29/2017 to Sat 04/29/2017

0630 Daily 1730

Work scheduled by: NGrid

OSWEGO EXPORT  
Impacts Total Transfer Capability 4850 MW  
TTC with All Lines In Service 400 MW  
5250 MW

## NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 05/01/2017 to Tue 05/16/2017 UPDATED by LI 02/14/2017

0400 Continuous 1800

Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 660 MW  
660 MW

## NEWBRDGE-DUFFYAVE\_345\_501

Mon 05/01/2017 to Tue 05/16/2017 UPDATED by LI 02/14/2017

0400 Continuous 1800

Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 660 MW  
660 MW

## MARCY\_-N.SCTLND\_345\_18

Mon 05/01/2017 to Fri 05/05/2017 UPDATED by NYPA 04/10/2017

0500 Continuous 1700

Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability 2090 MW  
TTC with All Lines In Service 885 MW  
2975 MW

ARR: 19

# NYISO TRANSFER LIMITATIONS

Saturday ,April 29, 2017 to Monday ,October 29, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BROWNFLS-TAYLORVL\_115\_3**

Mon 05/01/2017 to Fri 05/05/2017  
0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	70 MW	40 MW
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

**PANNELL -CLAY\_345\_2**

Mon 05/01/2017 to Fri 05/05/2017  
0630 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
WEST CENTRAL	1300 MW
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	2250 MW

**SCH-NYISO-HQ\_LIMIT\_800**

Mon 05/01/2017 to Wed 05/10/2017  
2200 Continuous 0300

Work scheduled by: HQ

	REV
	(Export)
SCH - HQ - NY	800 MW
Impacts Total Transfer Capability	200 MW
TTC with All Lines In Service	1000 MW

**W49TH\_ST\_345KV\_6**

Thu 05/04/2017 to Sat 05/06/2017 EXTENDED by CONED 04/25/2017  
0001 Continuous 0300

Work scheduled by: ConEd

	FWD
	(Import)
SCH - PJM_HTP	320 MW
Impacts Total Transfer Capability	340 MW
TTC with All Lines In Service	660 MW

**MARION -FARRAGUT\_345\_C3403**

Thu 05/04/2017 to Wed 05/31/2017 UPDATED by CE 04/03/2017  
0001 Continuous 2359

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2050 MW	1300 MW
Impacts Total Transfer Capability	250 MW	150 MW
TTC with All Lines In Service	2300 MW	1450 MW

**ELBRIDGE-LAFAYTTE\_345\_17-LE**

Thu 05/04/2017 to Thu 05/04/2017  
0730 Daily(No Weekends) 0800

Work scheduled by: NGrid

ARR: 75

	FWD
	(Import)
OSWEGO EXPORT	5250 MW
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	5250 MW

**OSWEGO -ELBRIDGE\_345\_17**

Thu 05/04/2017 to Thu 05/04/2017  
0730 Daily(No Weekends) 1700

Work scheduled by: NGrid

ARR: 75

	FWD
	(Import)
OSWEGO EXPORT	5250 MW
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	5250 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 29, 2017 to Monday ,October 29, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**ELBRIDGE-LAFAYTTE\_345\_17-LE**

Thu 05/04/2017 to Thu 05/04/2017

1630 Daily(No Weekends) 1700

Work scheduled by: NGrid

**ARR: 75**

FWD

(Import)

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

**ILCTLIMIT\_MARCY\_SO\_COMP\_I/S**

Fri 05/05/2017 to Sat 05/27/2017

1700 Continuous 0459

Work scheduled by: NYISO

FWD

(Import)

CENTRAL EAST - VC

**2740 MW**

Impacts Total Transfer Capability 235 MW

TTC with All Lines In Service 2975 MW

**PLSNTVLE-DUNWODIE\_345\_W90**

Sat 05/06/2017 to Wed 05/10/2017

0001 Continuous 2130

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

**BROWNFLS-TAYLORVL\_115\_3**

Mon 05/08/2017 to Fri 05/12/2017

0600 Continuous 1900

Work scheduled by: NGrid

**ARR: 38**

FWD

REV

(Import) (Export)

SCH - HQ\_CEDARS

**70 MW****40 MW**

Impacts Total Transfer Capability 120 MW

0 MW

TTC with All Lines In Service 190 MW

40 MW

**ROSETON\_-ROCKTVRN\_345\_311**

Mon 05/08/2017 to Fri 05/26/2017

0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED

**4400 MW**

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 5100 MW

**ROCHESTR-PANNELL\_345\_RP2**

Mon 05/08/2017 to Wed 05/10/2017

1000 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

**EFISHKIL-WOOD\_ST\_345\_F39**

Thu 05/11/2017 to Sat 05/13/2017

2100 Continuous 0200

Work scheduled by: ConEd

**UPDATED****by CE****04/13/2017**

FWD

(Import)

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 29, 2017 to Monday ,October 29, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## WOOD\_ST\_-PLSNTVLE\_345\_Y87

FWD

Thu 05/11/2017 to Sat 05/13/2017

UPDATEDby CE04/13/2017

(Import)

2100 Continuous 0200

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

## SCH-NYISO-HQ\_LIMIT\_900

REV

Thu 05/11/2017 to Sun 05/14/2017

(Export)

2200 Continuous 0300

SCH - HQ - NY

**900 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 1000 MW

Work scheduled by: HQ

## DENNISON-ROSEMNTB\_115\_2/22

FWD

REV

Mon 05/15/2017 to Wed 05/17/2017

(Import) (Export)

0600 Continuous 1900

SCH - HQ\_CEDARS

**95 MW****40 MW**

Impacts Total Transfer Capability 95 MW

0 MW

TTC with All Lines In Service 190 MW

40 MW

Work scheduled by: HQ

**ARR: 38**

## SCH-HQ\_CEDARS-NYISO\_LIMIT\_80

FWD

Mon 05/15/2017 to Wed 05/17/2017

(Import)

0600 Continuous 1900

SCH - HQ\_CEDARS

**80 MW**

Impacts Total Transfer Capability 110 MW

TTC with All Lines In Service 190 MW

Work scheduled by: HQ

## BROWNFLS-TAYLORVL\_115\_3

FWD

REV

Mon 05/15/2017 to Fri 05/19/2017

(Import) (Export)

0600 Continuous 1900

SCH - HQ\_CEDARS

**70 MW****40 MW**

Impacts Total Transfer Capability 120 MW

0 MW

TTC with All Lines In Service 190 MW

40 MW

Work scheduled by: NGrid

**ARR: 38**

## FRASER\_-GILBOA\_345\_GF5-35

FWD

Mon 05/15/2017 to Fri 05/19/2017

(Import)

0630 Continuous 1700

UPDATEDby NYPA04/13/2017

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

## STONYRDG-HILLSIDE\_230\_72

FWD

Mon 05/15/2017 to Mon 05/15/2017

(Import)

0800 Continuous 1700

DYSINGER EAST

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYSEG

# NYISO TRANSFER LIMITATIONS

Saturday ,April 29, 2017 to Monday ,October 29, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## FRASER\_\_345\_FRASER SVC

Mon 05/15/2017 to Fri 05/19/2017 UPDATED by NY 04/06/2017  
0900 Continuous 1430

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2935 MW**  
Impacts Total Transfer Capability 40 MW  
TTC with All Lines In Service 2975 MW

## FRASER\_\_345\_FRASER SVC &amp; ILCTLIMIT\_MARCY\_SO\_COMP\_I/S

Mon 05/15/2017 to Fri 05/19/2017  
0900 1430

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **2700 MW**  
Impacts Total Transfer Capability 275 MW  
TTC with All Lines In Service 2975 MW

## RAMAPO\_\_-LADENTWN\_345\_W72

Tue 05/16/2017 to Tue 05/16/2017  
0001 Continuous 2330

Work scheduled by: ORU

FWD  
(Import)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 5100 MW

## CHATGUAY-MASSENA\_\_765\_7040

Thu 05/18/2017 to Thu 05/18/2017 UPDATED by HQ 04/26/2017  
0000 Continuous 0600

Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

## CHATGUAY-MASSENA\_\_765\_7040

Thu 05/18/2017 to Thu 05/18/2017 UPDATED by HQ 04/26/2017  
0000 Continuous 0600

Work scheduled by: HQ

FWD REV  
(Import) (Export)  
SCH - HQ - NY **0 MW 0 MW**  
Impacts Total Transfer Capability 1500 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

## CHAT\_DC\_GC2

Thu 05/18/2017 to Thu 05/18/2017 UPDATED by HQ 04/26/2017  
0000 Continuous 0600

Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC2

Thu 05/18/2017 to Thu 05/18/2017 UPDATED by HQ 04/26/2017  
0000 Continuous 0600

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MILLWOOD-EASTVIEW\_345\_W82**

Fri 05/19/2017 to Fri 05/19/2017  
0001 Continuous 0030  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

**SPRNBRK\_\_345KV\_RNS4**

Fri 05/19/2017 to Fri 05/19/2017  
0001 Continuous 0030  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

**EASTVIEW-SPRNBRK\_\_345\_W65**

Fri 05/19/2017 to Fri 05/19/2017  
0001 Continuous 2100  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

**MILLWOOD-EASTVIEW\_345\_W82**

Fri 05/19/2017 to Fri 05/19/2017  
2030 Continuous 2100  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

**SPRNBRK\_\_345KV\_RNS4**

Fri 05/19/2017 to Fri 05/19/2017  
2030 Continuous 2100  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

**E13THSTA-FARRAGUT\_345\_45**

Sat 05/20/2017 to Sun 05/21/2017  
0001 Continuous 2359  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**W49TH\_ST-E13THSTA\_345\_M54**

Sat 05/20/2017 to Sun 05/21/2017  
0001 Continuous 2359  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 29, 2017 to Monday ,October 29, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EASTVIEW-SPRNBK\_\_345\_W64**

Sun 05/21/2017 to Sun 05/21/2017  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

**SPRNBK\_\_345KV\_RNS5**

Sun 05/21/2017 to Sun 05/21/2017  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

**MILLWOOD-EASTVIEW\_345\_W99**

Sun 05/21/2017 to Sun 05/21/2017  
0001 Continuous 2130

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

**EASTVIEW-SPRNBK\_\_345\_W64**

Sun 05/21/2017 to Sun 05/21/2017  
2100 Continuous 2130

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

**SPRNBK\_\_345KV\_RNS5**

Sun 05/21/2017 to Sun 05/21/2017  
2100 Continuous 2130

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

**MARCY\_\_\_\_765\_345\_AT1**

Mon 05/22/2017 to Fri 05/26/2017  
0500 Continuous 1630

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1750 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

**BROWNFLS-TAYLORVL\_115\_3**

Mon 05/22/2017 to Fri 05/26/2017  
0600 Continuous 1900

Work scheduled by: NGrid

**ARR: 38**

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 29, 2017 to Monday ,October 29, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CHAT\_DC\_GC1

FWD

Tue 05/23/2017 to Wed 05/31/2017 UPDATED by HQ 04/13/2017  
0600 Continuous 2100

(Import)

MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

## CHAT\_DC\_GC1

REV

Tue 05/23/2017 to Wed 05/31/2017 UPDATED by HQ 04/13/2017  
0600 Continuous 2100

(Export)

SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

Work scheduled by: HQ

## MARCY\_\_-N.SCTLND\_345\_18

FWD

Sat 05/27/2017 to Sat 05/27/2017  
0500 Continuous 1530

(Import)

CENTRAL EAST - VC **2090 MW**  
Impacts Total Transfer Capability 885 MW  
TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

ARR: 19

## SCH-HQ-NYISO\_LIMIT\_1150

FWD

Sat 05/27/2017 to Sat 05/27/2017 UPDATED by HQ 04/13/2017  
0500 Continuous 1530

(Import)

SCH - HQ - NY **1150 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 1500 MW

Work scheduled by: HQ

## ILCTLIMIT\_MARCY\_SO\_COMP\_I/S

FWD

Sat 05/27/2017 to Mon 06/05/2017  
1600 Continuous 0659

(Import)

CENTRAL EAST - VC **2740 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 2975 MW

Work scheduled by: NYISO

## BROWNFLS-TAYLORVL\_115\_4

FWD

REV

Tue 05/30/2017 to Fri 06/02/2017  
0600 Continuous 1900

(Import) (Export)

SCH - HQ\_CEDARS **70 MW 40 MW**  
Impacts Total Transfer Capability 120 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

Work scheduled by: NGrid

ARR: 38

## BROWNFLS-TAYLORVL\_115\_4

FWD

REV

Mon 06/05/2017 to Fri 06/09/2017  
0600 Continuous 1900

(Import) (Export)

SCH - HQ\_CEDARS **70 MW 40 MW**  
Impacts Total Transfer Capability 120 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

Work scheduled by: NGrid

ARR: 38

# NYISO TRANSFER LIMITATIONS

Saturday ,April 29, 2017 to Monday ,October 29, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC -FRASER 345\_EF24-40

FWD

Mon 06/05/2017 to Sat 06/10/2017

(Import)

0700 Continuous 1659

CENTRAL EAST - VC

2500 MW

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

STONYRDG-HILLSIDE\_230\_72

FWD

Mon 06/05/2017 to Mon 06/05/2017

(Import)

0800 Continuous 1000

DYSINGER EAST

2850 MW

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYSEG

BECK -PACKARD\_230\_BP76

FWD

REV

Tue 06/06/2017 to Wed 06/07/2017

(Import) (Export)

0600 Continuous 1800

UPDATED

by NGRID 04/27/2017

SCH - OH - NY

900 MW

1150 MW

Impacts Total Transfer Capability 850 MW

750 MW

TTC with All Lines In Service 1750 MW

1900 MW

Work scheduled by: NGrid

LINDEN -GOETHALS\_230\_A2253

FWD

REV

Fri 06/09/2017 to Sun 06/11/2017

(Import) (Export)

0200 Continuous 2300

UPDATED

by CE

04/04/2017

SCH - PJ - NY

2050 MW

1300 MW

Impacts Total Transfer Capability 250 MW

150 MW

TTC with All Lines In Service 2300 MW

1450 MW

Work scheduled by: PJM

STONYRDG-HILLSIDE\_230\_72

FWD

Fri 06/09/2017 to Fri 06/09/2017

(Import)

1500 Continuous 1700

DYSINGER EAST

2850 MW

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYSEG

ILCTLIMIT\_MARCY\_SO\_COMP\_I/S

FWD

Sat 06/10/2017 to Sat 08/05/2017

(Import)

1700 Continuous 0459

CENTRAL EAST - VC

2740 MW

Impacts Total Transfer Capability 235 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYISO

BROWNFLS-TAYLORVL\_115\_4

FWD

REV

Mon 06/12/2017 to Fri 06/16/2017

(Import) (Export)

0600 Continuous 1900

SCH - HQ\_CEDARS

70 MW

40 MW

Impacts Total Transfer Capability 120 MW

0 MW

TTC with All Lines In Service 190 MW

40 MW

Work scheduled by: NGrid

ARR: 38

# NYISO TRANSFER LIMITATIONS

Saturday ,April 29, 2017 to Monday ,October 29, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BROWNFLS-TAYLORVL_115_4</b>					FWD	REV
Mon 06/19/2017	to	Fri 06/23/2017			(Import)	(Export)
0600	Continuous	1900			SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	120 MW 0 MW
ARR: 38					TTC with All Lines In Service	190 MW 40 MW
<b>BROWNFLS-TAYLORVL_115_3</b>					FWD	REV
Mon 06/26/2017	to	Fri 06/30/2017			(Import)	(Export)
0600	Continuous	1900			SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	120 MW 0 MW
ARR: 38					TTC with All Lines In Service	190 MW 40 MW
<b>BROWNFLS-TAYLORVL_115_3</b>					FWD	REV
Wed 07/05/2017	to	Fri 07/07/2017	<u>UPDATED</u>	<u>by NGRID</u> <u>03/02/2017</u>	(Import)	(Export)
0600	Continuous	1900			SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	120 MW 0 MW
ARR: 38					TTC with All Lines In Service	190 MW 40 MW
<b>BROWNFLS-TAYLORVL_115_3</b>					FWD	REV
Mon 07/10/2017	to	Fri 07/14/2017	<u>UPDATED</u>	<u>by NGRID</u> <u>03/02/2017</u>	(Import)	(Export)
0600	Continuous	1900			SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	120 MW 0 MW
ARR: 38					TTC with All Lines In Service	190 MW 40 MW
<b>BROWNFLS-TAYLORVL_115_3</b>					FWD	REV
Mon 07/17/2017	to	Fri 07/21/2017	<u>UPDATED</u>	<u>by NGRID</u> <u>03/02/2017</u>	(Import)	(Export)
0600	Continuous	1900			SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	120 MW 0 MW
ARR: 38					TTC with All Lines In Service	190 MW 40 MW
<b>BROWNFLS-TAYLORVL_115_4</b>					FWD	REV
Mon 07/24/2017	to	Fri 07/28/2017			(Import)	(Export)
0600	Continuous	1900			SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	120 MW 0 MW
ARR: 38					TTC with All Lines In Service	190 MW 40 MW
<b>MARCY___-N.SCTLND_345_18</b>					FWD	
Sat 08/05/2017	to	Sat 08/05/2017			(Import)	
0500	Continuous	1530			CENTRAL EAST - VC	<b>2090 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	885 MW
ARR: 19					TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 29, 2017 to Monday ,October 29, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MARCY\_\_\_765\_345\_AT2

Sat 08/05/2017 to Sat 08/05/2017  
0500 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH 1700 MW  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## ILCTLIMIT MARCY\_SO\_COMP\_I/S

Sat 08/05/2017 to Mon 10/02/2017  
1600 Continuous 0659

Work scheduled by: NYISO

FWD  
(Import)  
CENTRAL EAST - VC 2740 MW  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 2975 MW

## MARCY\_\_\_765\_345\_AT2

Tue 09/05/2017 to Sun 09/10/2017  
0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH 1700 MW  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 09/11/2017 to Sat 09/16/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2100 MW  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## HURLYAVE-ROSETON\_\_\_345\_303

Mon 09/11/2017 to Fri 09/29/2017  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED 4100 MW  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 5100 MW

## DUNWODIE\_345KV\_5

Fri 09/15/2017 to Sun 09/17/2017  
2200 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH 3800 MW  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## DUNWODIE\_345KV\_7

Fri 09/15/2017 to Sun 09/17/2017  
2200 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH 3800 MW  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 29, 2017 to Monday ,October 29, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-DUNWODIE_345_W75				FWD	
Fri 09/15/2017	to	Sun 09/17/2017		(Import)	
2200	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
SPRNBK_345KV_RNS3				FWD	
Fri 09/15/2017	to	Sun 09/17/2017		(Import)	
2200	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
GILBOA_-N.SCTLND_345_GNS-1				FWD	
Mon 09/18/2017	to	Fri 10/06/2017		(Import)	
0630	Continuous	1700	CENTRAL EAST - VC	2520 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	455 MW	
			TTC with All Lines In Service	2975 MW	
NIAGARA_345_230_AT4				FWD	REV
Mon 09/18/2017	to	Tue 09/19/2017		(Import)	(Export)
0700	Continuous	1530	SCH - OH - NY	1750 MW	1300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	0 MW	600 MW
			TTC with All Lines In Service	1750 MW	1900 MW
MOSES_-ADIRNDCK_230_MAI				FWD	
Mon 09/18/2017	to	Sat 09/23/2017		(Import)	
0700	Continuous	1530	MOSES SOUTH	2100 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW	
			TTC with All Lines In Service	3150 MW	
MOSES_-ADIRNDCK_230_MAI				FWD	
Mon 09/25/2017	to	Sat 09/30/2017		(Import)	
0700	Continuous	1530	MOSES SOUTH	2100 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW	
			TTC with All Lines In Service	3150 MW	
NIAGARA_-ROCHESTR_345_NR2				FWD	
Mon 10/02/2017	to	Fri 10/06/2017		(Import)	
0700	Continuous	1530	DYSINGER EAST	1700 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW	
			TTC with All Lines In Service	3150 MW	

# NYISO TRANSFER LIMITATIONS

Saturday ,April 29, 2017 to Monday ,October 29, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## FRASER\_\_-COOPERS\_\_345\_33

Mon 10/02/2017 to Fri 10/13/2017  
0700 Continuous 1900

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2395 MW**  
Impacts Total Transfer Capability 580 MW  
TTC with All Lines In Service 2975 MW

## HOMR\_NYW-PIERC\_NY\_345\_48

Mon 10/02/2017 to Tue 10/17/2017  
0800 Continuous 1600

Work scheduled by: NYSEG

CANCELLED by NYSEG 04/25/2017

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2050 MW 1300 MW**  
Impacts Total Transfer Capability 250 MW 150 MW  
TTC with All Lines In Service 2300 MW 1450 MW

## WETHSRFD-MEYER\_\_230\_85/87

Mon 10/09/2017 to Fri 10/20/2017  
0700 Continuous 1400

Work scheduled by: NYSEG

FWD  
(Import)  
DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

## ILCTLIMIT\_MARCY\_SO\_COMP\_I/S

Fri 10/13/2017 to Mon 11/06/2017  
1900 Continuous 0559

Work scheduled by: NYISO

FWD  
(Import)  
CENTRAL EAST - VC **2740 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 2975 MW

## CHATGUAY-MASSENA\_\_765\_7040

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYISO 03/24/2017

FWD  
(Import)  
MOSES SOUTH **1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

## CHATGUAY-MASSENA\_\_765\_7040

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYISO 03/24/2017

FWD REV  
(Import) (Export)  
SCH - HQ - NY **0 MW 0 MW**  
Impacts Total Transfer Capability 1500 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

## MARCY\_\_765\_345\_AT1

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYISO 03/24/2017

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1750 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 29, 2017 to Monday ,October 29, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY____765_345_AT2					FWD			
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u> <u>03/24/2017</u>	(Import)			
0700	Continuous	1530			MOSES SOUTH	<b>1700 MW</b>		
Work scheduled by: NYPA					Impacts Total Transfer Capability	1450 MW		
					TTC with All Lines In Service	3150 MW		
MASSENA_-MARCY____765_MSU1					FWD			
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u> <u>03/24/2017</u>	(Import)			
0700	Continuous	1530			CENTRAL EAST - VC	<b>2265 MW</b>		
Work scheduled by: NYPA					Impacts Total Transfer Capability	710 MW		
					TTC with All Lines In Service	2975 MW		
MASSENA_-MARCY____765_MSU1					FWD			
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u> <u>03/24/2017</u>	(Import)			
0700	Continuous	1530			MOSES SOUTH	<b>500 MW</b>		
Work scheduled by: NYPA					Impacts Total Transfer Capability	2650 MW		
					TTC with All Lines In Service	3150 MW		
MASSENA_-MARCY____765_MSU1					FWD	REV		
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u> <u>03/24/2017</u>	(Import)	(Export)		
0700	Continuous	1530			SCH - HQ - NY	<b>475 MW</b>	<b>1000 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	1025 MW 0 MW		
					TTC with All Lines In Service	1500 MW 1000 MW		
MASSENA_-MARCY____765_MSU1 & CHATGUAY-MASSENA__765_7040					FWD			
Sat 10/14/2017	to	Sat 10/28/2017			(Import)			
0700		1530			MOSES SOUTH	<b>500 MW</b>		
Work scheduled by:					Impacts Total Transfer Capability	2650 MW		
					TTC with All Lines In Service	3150 MW		
MASSENA_-MARCY____765_MSU1 & ILCTLIMIT_MARCY_SO_COMP_I/S					FWD			
Sat 10/14/2017	to	Sat 10/28/2017			(Import)			
0700		1530			CENTRAL EAST - VC	<b>2080 MW</b>		
Work scheduled by:					Impacts Total Transfer Capability	895 MW		
					TTC with All Lines In Service	2975 MW		
MOSES____-MASSENA__230_MMS1 & MOSES____-MASSENA__230_MMS2					FWD	REV		
Sat 10/14/2017	to	Sat 10/28/2017			(Import)	(Export)		
0700		1530			SCH - HQ - NY	<b>850 MW</b>	<b>0 MW</b>	
Work scheduled by:					Impacts Total Transfer Capability	650 MW 1000 MW		
					TTC with All Lines In Service	1500 MW 1000 MW		

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LEEDS\_\_\_-HURLYAVE\_345\_301

Mon 10/16/2017 to Fri 11/03/2017

0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED

4100 MW

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 5100 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 10/30/2017 to Fri 11/03/2017

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

2100 MW

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

## FRASANNX-COOPERS\_\_\_345\_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017

0600 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC

2500 MW

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

## MARCY\_\_\_-FRASANNX\_345\_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017

0600 Continuous 1700

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

CENTRAL EAST - VC

2500 MW

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 11/06/2017 to Thu 11/09/2017

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## LINDN\_CG-LNDVFT\_\_\_345\_V-3022

Mon 11/06/2017 to Thu 11/09/2017

0800 Continuous 1500

Work scheduled by: PJM

FWD

(Import) (Export)

SCH - PJM\_VFT

0 MW

0 MW

Impacts Total Transfer Capability 315 MW

315 MW

TTC with All Lines In Service 315 MW

315 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 11/13/2017 to Fri 11/17/2017

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 29, 2017 to Monday ,October 29, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**ILCTLIMIT\_MARCY\_SO\_COMP\_I/S**

FWD

Fri 11/17/2017 to Sat 02/01/2020

(Import)

1700 Continuous 0000

CENTRAL EAST - VC

**2740 MW**

Impacts Total Transfer Capability 235 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYISO

---

**MOSES\_\_-ADIRNDCK\_230\_MA1**

FWD

Mon 11/20/2017 to Wed 11/22/2017

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

---

**MOSES\_\_-ADIRNDCK\_230\_MA1**

FWD

Mon 11/27/2017 to Fri 12/01/2017

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

---

**MARCY\_\_765\_345\_AT2**

FWD

Mon 12/04/2017 to Fri 12/08/2017

(Import)

0500 Continuous 1630

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19**


---

**MOSES\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 12/11/2017 to Fri 12/15/2017

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

---

**MOSES\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 12/18/2017 to Fri 12/22/2017

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**UPDATED by NYPA 10/23/2016**


---

**MARCY\_\_765\_345\_AT2**

FWD

Wed 12/27/2017 to Thu 12/28/2017

(Import)

0500 Continuous 1630

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19**