

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | FWD | REV |
|------------------------------------|------------|----------------|------------------|-----------------|-------------------|-----------------------------------|----------------|
| | | | | | | (Import) | (Export) |
| RAMAPO___345_345_PAR3500 | | | | | | | |
| Fri 06/24/2016 | to | Fri 09/15/2017 | <u>EXT FORCE</u> | <u>by CONED</u> | <u>03/22/2017</u> | SCH - PJ - NY | 2200 MW |
| 1940 | Continuous | 2359 | | | | Impacts Total Transfer Capability | 100 MW |
| Work scheduled by: ConEd | | | | | | TTC with All Lines In Service | 2300 MW |
| PLSNTVLE-DUNWODIE_345_W89 | | | | | | FWD | |
| | | | | | | (Import) | |
| Sun 10/30/2016 | to | Tue 04/18/2017 | <u>EXT FORCE</u> | <u>by CONED</u> | <u>04/05/2017</u> | UPNY CONED | 4000 MW |
| 0728 | Continuous | 2059 | | | | Impacts Total Transfer Capability | 1100 MW |
| Work scheduled by: ConEd | | | | | | TTC with All Lines In Service | 5100 MW |
| HUDSONTP-W49TH_ST_345_Y56 | | | | | | FWD | |
| | | | | | | (Import) | |
| Thu 11/24/2016 | to | Sat 07/15/2017 | <u>EXTENDED</u> | <u>by PJM</u> | <u>01/27/2017</u> | SCH - PJM_HTP | 0 MW |
| 1500 | Continuous | 2359 | | | | Impacts Total Transfer Capability | 660 MW |
| Work scheduled by: ConEd | | | | | | TTC with All Lines In Service | 660 MW |
| E13THSTA-FARRAGUT_345_46 | | | | | | FWD | |
| | | | | | | (Import) | |
| Tue 12/20/2016 | to | Wed 05/03/2017 | <u>UPDATED</u> | <u>by CONED</u> | <u>04/03/2017</u> | SPR/DUN-SOUTH | 3800 MW |
| 0001 | Continuous | 0300 | | | | Impacts Total Transfer Capability | 800 MW |
| Work scheduled by: ConEd | | | | | | TTC with All Lines In Service | 4600 MW |
| W49TH_ST-E13THSTA_345_M55 | | | | | | FWD | |
| | | | | | | (Import) | |
| Tue 12/20/2016 | to | Wed 05/03/2017 | <u>UPDATED</u> | <u>by CONED</u> | <u>04/03/2017</u> | SPR/DUN-SOUTH | 3800 MW |
| 0001 | Continuous | 0300 | | | | Impacts Total Transfer Capability | 800 MW |
| Work scheduled by: ConEd | | | | | | TTC with All Lines In Service | 4600 MW |
| W49TH_ST_345KV_6 | | | | | | FWD | |
| | | | | | | (Import) | |
| Fri 02/17/2017 | to | Thu 04/13/2017 | <u>UPDATED</u> | <u>by CONED</u> | <u>04/03/2017</u> | SCH - PJM_HTP | 315 MW |
| 0001 | Continuous | 0300 | | | | Impacts Total Transfer Capability | 345 MW |
| Work scheduled by: ConEd | | | | | | TTC with All Lines In Service | 660 MW |
| HUDSONP_-FARRAGUT_345_B3402 | | | | | | FWD | REV |
| | | | | | | (Import) | (Export) |
| Tue 03/21/2017 | to | Wed 05/03/2017 | <u>UPDATED</u> | <u>by CONED</u> | <u>04/03/2017</u> | SCH - PJ - NY | 2300 MW |
| 0001 | Continuous | 2359 | | | | Impacts Total Transfer Capability | 0 MW |
| Work scheduled by: ConEd | | | | | | TTC with All Lines In Service | 2300 MW |

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Tue 03/21/2017 to Wed 05/03/2017
0001 2359

Work scheduled by:

| | | |
|-----------------------------------|----------|----------|
| | FWD | REV |
| | (Import) | (Export) |
| SCH - PJ - NY | 2050 MW | 1450 MW |
| Impacts Total Transfer Capability | 250 MW | 0 MW |
| TTC with All Lines In Service | 2300 MW | 1450 MW |

MARION_-FARRAGUT_345_C3403

Tue 03/21/2017 to Wed 05/03/2017
0001 Continuous 2359

Work scheduled by: ConEd

| | | |
|-----------------------------------|----------|----------|
| | FWD | REV |
| | (Import) | (Export) |
| SCH - PJ - NY | 2300 MW | 1450 MW |
| Impacts Total Transfer Capability | 0 MW | 0 MW |
| TTC with All Lines In Service | 2300 MW | 1450 MW |

BERKSHIR-NORTHFLD_345_312

Fri 03/24/2017 to Sat 04/22/2017
0800 Continuous 1600

Work scheduled by: ISONE

| | | |
|-----------------------------------|----------|----------|
| | FWD | REV |
| | (Import) | (Export) |
| SCH - NE - NY | 1400 MW | 1450 MW |
| Impacts Total Transfer Capability | 0 MW | 150 MW |
| TTC with All Lines In Service | 1400 MW | 1600 MW |

BERKSHIR-NORTHFLD_345_312

Fri 03/24/2017 to Sat 04/22/2017
0800 Continuous 1600

Work scheduled by: ISONE

| | | |
|-----------------------------------|----------|----------|
| | FWD | REV |
| | (Import) | (Export) |
| SCH - NPX_1385 | 100 MW | 100 MW |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

SCH-NE-NYISO_LIMIT_900

Fri 03/24/2017 to Sat 04/22/2017
0800 Continuous 1600

Work scheduled by: ISONE

| | |
|-----------------------------------|----------|
| | FWD |
| | (Import) |
| SCH - NE - NY | 1100 MW |
| Impacts Total Transfer Capability | 300 MW |
| TTC with All Lines In Service | 1400 MW |

SCH-NYISO-NE_LIMIT_900

Fri 03/24/2017 to Sat 04/22/2017
0800 Continuous 1600

Work scheduled by: ISONE

| | |
|-----------------------------------|----------|
| | REV |
| | (Export) |
| SCH - NE - NY | 1100 MW |
| Impacts Total Transfer Capability | 500 MW |
| TTC with All Lines In Service | 1600 MW |

MARCY_345KV_CSC

Mon 03/27/2017 to Thu 04/13/2017
0500 Continuous 1630

Work scheduled by: NYPA

| | |
|-----------------------------------|----------|
| | FWD |
| | (Import) |
| CENTRAL EAST - VC | 2925 MW |
| Impacts Total Transfer Capability | 50 MW |
| TTC with All Lines In Service | 2975 MW |

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER__ -GILBOA__ 345_GF5-35

Mon 03/27/2017 to Fri 04/07/2017

0900 Continuous 1430

Work scheduled by: NYSEG

FWD

(Import)

CENTRAL EAST - VC

2650 MW

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

HOMRC_NY-MAINS_NY_345_47

Fri 03/31/2017 to Fri 04/14/2017

1600 Continuous 1600

Work scheduled by: NYSEG

UPDATEDby NYSEG 03/03/2017

FWD

(Import)

REV

(Export)

SCH - PJ - NY

2300 MW 1450 MW

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 2300 MW 1450 MW

MAINESBG-WATRCURE_345_30

Fri 03/31/2017 to Fri 04/14/2017

1600 Continuous 1600

Work scheduled by: NYSEG

UPDATEDby NYSEG 03/03/2017

FWD

(Import)

REV

(Export)

SCH - PJ - NY

2200 MW 1450 MW

Impacts Total Transfer Capability 100 MW 0 MW

TTC with All Lines In Service 2300 MW 1450 MW

EFISHKIL-WOOD_ST__345_F38

Sun 04/02/2017 to Wed 04/05/2017

0001 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

4000 MW

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

WOOD_ST_-PLSNTVLE_345_Y86

Sun 04/02/2017 to Wed 04/05/2017

0001 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

4000 MW

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

LINDN_CG-LNDVFT__345_V-3022

Sun 04/02/2017 to Fri 04/07/2017

1400 Continuous 1800

Work scheduled by: PJM

UPDATEDby PJM 04/08/2017

FWD

(Import)

REV

(Export)

SCH - PJM_VFT

0 MW 0 MW

Impacts Total Transfer Capability 315 MW 315 MW

TTC with All Lines In Service 315 MW 315 MW

SCH-NE-NYISO_LIMIT_500

Mon 04/03/2017 to Wed 04/05/2017

0500 Continuous 2359

Work scheduled by: ISONE

UPDATEDby ISONE 04/04/2017

FWD

(Import)

SCH - NE - NY

700 MW

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 1400 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_600

Mon 04/03/2017 to Wed 04/05/2017 UPDATED by ISONE 04/04/2017

0500 Continuous 2359

Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 1600 MW

REV
(Export)

SCH-NYISO-HQ_LIMIT_800

Mon 04/03/2017 to Thu 04/13/2017

0600 Continuous 1800

Work scheduled by: HQ

SCH - HQ - NY
Impacts Total Transfer Capability 200 MW
TTC with All Lines In Service 1000 MW

REV
(Export)

SCH-IMO-NYISO_NIAG_CB_3008_W/BB

Mon 04/03/2017 to Fri 04/07/2017 UPDATED by NYISO 03/29/2017

0700 Continuous 1530

Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 1750 MW

FWD REV
(Import) (Export)
1750 MW 1750 MW

BERKSHIR-NORTHFLD_345_312 & NRTH1385-NOR HBR_138_601

Mon 04/03/2017 to Wed 04/12/2017

0700 2359

Work scheduled by:

SCH - NPX_1385
Impacts Total Transfer Capability 200 MW
TTC with All Lines In Service 200 MW

FWD REV
(Import) (Export)
0 MW 0 MW

BERKSHIR-NORTHFLD_345_312 & NRTH1385-NOR HBR_138_602

Mon 04/03/2017 to Wed 04/12/2017

0700 2359

Work scheduled by:

SCH - NPX_1385
Impacts Total Transfer Capability 200 MW
TTC with All Lines In Service 200 MW

FWD REV
(Import) (Export)
0 MW 0 MW

BERKSHIR-NORTHFLD_345_312 & NRTH1385-NOR HBR_138_603

Mon 04/03/2017 to Wed 04/12/2017

0700 2359

Work scheduled by:

SCH - NPX_1385
Impacts Total Transfer Capability 200 MW
TTC with All Lines In Service 200 MW

FWD REV
(Import) (Export)
0 MW 0 MW

NRTH1385-NOR HBR_138_601

Mon 04/03/2017 to Wed 04/12/2017

0700 Continuous 2359

Work scheduled by: LI

by NE 04/04/2017

SCH - NPX_1385
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 200 MW

FWD REV
(Import) (Export)
100 MW 100 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602

Mon 04/03/2017 to Wed 04/12/2017
0700 2359

Work scheduled by:

| | FWD | REV |
|-----------------------------------|-------------|-------------|
| | (Import) | (Export) |
| SCH - NPX_1385 | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 200 MW | 200 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603

Mon 04/03/2017 to Wed 04/12/2017
0700 2359

Work scheduled by:

| | FWD | REV |
|-----------------------------------|-------------|-------------|
| | (Import) | (Export) |
| SCH - NPX_1385 | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 200 MW | 200 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

NRTH1385-NOR HBR__138_602

Mon 04/03/2017 to Wed 04/12/2017
0700 Continuous 2359

Work scheduled by: LI

by NE 04/04/2017

| | FWD | REV |
|-----------------------------------|---------------|---------------|
| | (Import) | (Export) |
| SCH - NPX_1385 | 100 MW | 100 MW |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603

Mon 04/03/2017 to Wed 04/12/2017
0700 2359

Work scheduled by:

| | FWD | REV |
|-----------------------------------|-------------|-------------|
| | (Import) | (Export) |
| SCH - NPX_1385 | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 200 MW | 200 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

NRTH1385-NOR HBR__138_603

Mon 04/03/2017 to Wed 04/12/2017
0700 Continuous 2359

Work scheduled by: LI

by NE 04/04/2017

| | FWD | REV |
|-----------------------------------|---------------|---------------|
| | (Import) | (Export) |
| SCH - NPX_1385 | 100 MW | 100 MW |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

NRTH1385-NRTHPORT_138_1385

Mon 04/03/2017 to Wed 04/12/2017
0700 Continuous 2359

Work scheduled by: LI

by NE 04/04/2017

| | FWD | REV |
|-----------------------------------|-------------|-------------|
| | (Import) | (Export) |
| SCH - NPX_1385 | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 200 MW | 200 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

SCH-NE-NYISO_LIMIT_800

Mon 04/03/2017 to Wed 04/12/2017
0700 Continuous 2359

Work scheduled by: LI

by NE 04/04/2017

| | FWD |
|-----------------------------------|----------------|
| | (Import) |
| SCH - NE - NY | 1000 MW |
| Impacts Total Transfer Capability | 400 MW |
| TTC with All Lines In Service | 1400 MW |

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES____-ADIRNDCK_230_MAI

FWD

Mon 04/03/2017 to Thu 04/13/2017 UPDATED by NYPA 03/27/2017

(Import)

0700 Continuous 1730

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

STLAWRNC-MOSES____230_L33P

FWD

REV

Mon 04/03/2017 to Thu 04/13/2017

(Import) (Export)

0800 Continuous 1800

SCH - OH - NY

1750 MW 1900 MW

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 1750 MW 1900 MW

Work scheduled by: IESO

SCH-NYISO-PJM_LIMIT_100

REV

Tue 04/04/2017 to Thu 04/20/2017 EXTENDED by PJM 04/07/2017

(Export)

0800 Continuous 1600

SCH - PJ - NY

400 MW

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 1450 MW

Work scheduled by: PJM

SHOR_NPX-SHOREHAM_138_CSC

FWD

REV

Tue 04/04/2017 to Thu 04/06/2017 FORCED by LI 04/05/2017

(Import) (Export)

1800 Continuous 2359

SCH - NPX_CSC

0 MW 0 MW

Impacts Total Transfer Capability 330 MW 330 MW

TTC with All Lines In Service 330 MW 330 MW

Work scheduled by: LI

NINEMILE-CLAY____345_8

FWD

Thu 04/06/2017 to Thu 04/06/2017

(Import)

0000 Daily 0100

OSWEGO EXPORT

5150 MW

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

SCH-NYISO-NE_LIMIT_700

REV

Thu 04/06/2017 to Thu 04/06/2017 by NE 04/04/2017

(Export)

0001 Continuous 0759

SCH - NE - NY

900 MW

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 1600 MW

Work scheduled by: LI

SCRIBA____-VOLNEY____345_20

FWD

Thu 04/06/2017 to Thu 04/06/2017

(Import)

0730 Daily(No Weekends) 1630

OSWEGO EXPORT

5250 MW

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_800

Thu 04/06/2017 to Wed 04/12/2017
0800 Continuous 2300

by NE04/04/2017

Work scheduled by: LI

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

1000 MW

600 MW

1600 MW

SCH-NYISO-NE_LIMIT_700

Thu 04/06/2017 to Fri 04/07/2017
2300 Continuous 0759

by NE04/04/2017

Work scheduled by: LI

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

900 MW

700 MW

1600 MW

DUNWODIE_345KV_3

Fri 04/07/2017 to Tue 04/18/2017
0001 Continuous 2059

EXT FORCEby CONED04/05/2017

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

FWD

(Import)

3800 MW

DUNWODIE_345KV_4

Fri 04/07/2017 to Tue 04/18/2017
0001 Continuous 2059

EXT FORCEby CONED04/05/2017

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

FWD

(Import)

3800 MW

SCH-NYISO-NE_LIMIT_700

Fri 04/07/2017 to Sat 04/08/2017
2301 Continuous 0800

by NE04/04/2017

Work scheduled by: LI

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

900 MW

700 MW

1600 MW

LADENTWN-BUCHAN_S_345_Y88

Sat 04/08/2017 to Sat 04/08/2017
0600 Continuous 1800

UPDATEDby OR04/05/2017

Work scheduled by: ORU

UPNY CONED

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 5100 MW

FWD

(Import)

4150 MW

SCH-NYISO-NE_LIMIT_700

Sat 04/08/2017 to Wed 04/12/2017
2301 Continuous 0759

by NE04/04/2017

Work scheduled by: LI

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

900 MW

700 MW

1600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_700

Sun 04/09/2017 to Sun 04/09/2017 UPDATED by NYPA 04/07/2017
0500 Continuous 1659

Work scheduled by: NYPA

FWD
(Import)
SCH - OH - NY **1000 MW**
Impacts Total Transfer Capability 750 MW
TTC with All Lines In Service 1750 MW

SCH-IMO-NYISO_LIMIT_1350

Mon 04/10/2017 to Thu 04/13/2017 UPDATED by NYISO 04/07/2017
0500 Continuous 0459

Work scheduled by: NGrid

FWD
(Import)
SCH - OH - NY **1650 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 1750 MW

SCH-IMO-NYISO_LIMIT_1400

Mon 04/10/2017 to Mon 04/10/2017 CANCELLED by NGrid 04/07/2017
0615 Daily(No Weekends) 1530

Work scheduled by: NGrid

FWD
(Import)
SCH - OH - NY **1700 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 1750 MW

N.SCTLND-LEEDS____345_93

Mon 04/10/2017 to Mon 04/10/2017
1100 Daily(No Weekends) 1500

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

W49TH_ST_345KV_8

Tue 04/11/2017 to Sun 04/16/2017 UPDATED by CONED 04/03/2017
0201 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **315 MW**
Impacts Total Transfer Capability 345 MW
TTC with All Lines In Service 660 MW

LEEDS____-PLSNTVLY_345_92

Tue 04/11/2017 to Thu 04/13/2017 UPDATED by CE 04/06/2017
0730 Continuous 1600

Work scheduled by: NGrid

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5100 MW

PORTER____-ROTTRDAM_230_30

Tue 04/11/2017 to Tue 04/11/2017
0800 Daily(No Weekends) 1100

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2805 MW**
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY -EDIC 345_2-15

Wed 04/12/2017 to Wed 04/12/2017

0630 Continuous 1630

Work scheduled by: NGrid

FWD
(Import)
OSWEGO EXPORT 4850 MW
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

MARCY 345KV_CSC & ILCTLIMIT_MARCY_SO_COMP_I/S

Wed 04/12/2017 to Thu 04/13/2017

1600 1630

Work scheduled by:

FWD
(Import)
CENTRAL EAST - VC 2690 MW
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 2975 MW

ILCTLIMIT_MARCY_SO_COMP_I/S

Wed 04/12/2017 to Mon 04/17/2017

1600 Continuous 0900

Work scheduled by: NYISO

FWD
(Import)
CENTRAL EAST - VC 2740 MW
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 2975 MW

SCH-IMO-NYISO_LIMIT_1400

Thu 04/13/2017 to Fri 04/14/2017

0500 Continuous 1730

Work scheduled by: NGrid

UPDATED by NYISO 04/07/2017

FWD
(Import)
SCH - OH - NY 1700 MW
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 1750 MW

BECK -NIAGARA_345_PA302

Sat 04/15/2017 to Sat 04/15/2017

0800 Continuous 1600

Work scheduled by: IESO

FWD REV
(Import) (Export)
SCH - OH - NY 1100 MW 950 MW
Impacts Total Transfer Capability 650 MW 950 MW
TTC with All Lines In Service 1750 MW 1900 MW

W49TH_ST_345KV_6

Sun 04/16/2017 to Tue 05/02/2017

0001 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 04/03/2017

FWD
(Import)
SCH - PJM_HTP 315 MW
Impacts Total Transfer Capability 345 MW
TTC with All Lines In Service 660 MW

SHOR_NPX-SHOREHAM_138_CSC

Mon 04/17/2017 to Sat 04/22/2017

0500 Continuous 1600

Work scheduled by: LI

FWD REV
(Import) (Export)
SCH - NPX_CSC 0 MW 0 MW
Impacts Total Transfer Capability 330 MW 330 MW
TTC with All Lines In Service 330 MW 330 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

COOPERS_-DOLSONAV_345_CCDA42

FWD

Mon 04/17/2017 to Mon 04/24/2017
0500 Continuous 1530

CANCELLED by NYPA 04/07/2017

(Import)

Work scheduled by: NYPA

CENTRAL EAST - VC **2720 MW**
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 2975 MW

DOLSONAV-ROCKTVRN_345_DART44

FWD

Mon 04/17/2017 to Mon 04/24/2017
0500 Continuous 1530

CANCELLED by NYPA 04/07/2017

(Import)

Work scheduled by: NYPA

CENTRAL EAST - VC **2720 MW**
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 2975 MW

MOSES_-ADIRNDCK_230_MA2

FWD

Mon 04/17/2017 to Thu 04/20/2017
0700 Continuous 1730

UPDATED by NYPA 03/19/2017

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FRASER_-COOPERS_345_33

FWD

Mon 04/17/2017 to Fri 04/21/2017
0900 Continuous 1400

UPDATED by NY 01/12/2017

(Import)

Work scheduled by: NYSEG

CENTRAL EAST - VC **2395 MW**
Impacts Total Transfer Capability 580 MW
TTC with All Lines In Service 2975 MW

CHAT_DC_GC1

FWD

Tue 04/18/2017 to Wed 05/31/2017
0700 Continuous 1800

(Import)

Work scheduled by: HQ

MOSES SOUTH **2850 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC1

REV

Tue 04/18/2017 to Wed 05/31/2017
0700 Continuous 1800

(Export)

Work scheduled by: HQ

SCH - HQ - NY **500 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1000 MW

PORTER_-ROTTDAM_230_31

FWD

Tue 04/18/2017 to Tue 04/18/2017
0800 Daily(No Weekends) 1500

(Import)

Work scheduled by: NGrid

CENTRAL EAST - VC **2805 MW**
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EFISHKIL-WOOD_ST__345_F39

Tue 04/18/2017 to Thu 04/20/2017
2100 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 04/07/2017

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 5100 MW

WOOD_ST_-PLSNTVLE_345_Y87

Tue 04/18/2017 to Thu 04/20/2017
2100 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 04/07/2017

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 5100 MW

VOLNEY_-CLAY____345_6

Wed 04/19/2017 to Wed 04/19/2017
0730 Daily(No Weekends) 1700

Work scheduled by: NGrid

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

PLSNTVLY-WOOD_ST__345_F30

Thu 04/20/2017 to Sat 04/22/2017
2200 Continuous 0159

Work scheduled by: ConEd

UPDATED by CE 04/07/2017

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 5100 MW

PLSNTVLY_345KV_RNS5

Thu 04/20/2017 to Sat 04/22/2017
2200 Continuous 0159

Work scheduled by: ConEd

UPDATED by CE 04/07/2017

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5100 MW

ILCTLIMIT_MARCY_SO_COMP_I/S

Fri 04/21/2017 to Sat 05/27/2017
1400 Continuous 0459

Work scheduled by: NYISO

FWD
(Import)
CENTRAL EAST - VC **2740 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 2975 MW

DUNWODIE_345KV_6

Sat 04/22/2017 to Sat 04/22/2017
0200 Continuous 0230

Work scheduled by: ConEd

UPDATED by CE 04/07/2017

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_8

FWD

Sat 04/22/2017 to Sat 04/22/2017 UPDATED by CE 04/07/2017
0200 Continuous 0230

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

PLSNTVLE-DUNWODIE_345_W90

FWD

Sat 04/22/2017 to Sun 04/23/2017 UPDATED by CE 04/07/2017
0200 Continuous 2359

(Import)

Work scheduled by: ConEd

UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 5100 MW

WOOD_ST_-PLSNTVLE_345_Y87

FWD

Sat 04/22/2017 to Sun 04/23/2017 UPDATED by CE 04/07/2017
0200 Continuous 2359

(Import)

Work scheduled by: ConEd

UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 5100 MW

BERKSHIR-ALPS_____345_393

FWD

REV

Sat 04/22/2017 to Sat 04/22/2017 UPDATED by NGRID 03/06/2017
1500 Daily 1600

(Import) (Export)

Work scheduled by: NGrid

ARR: 78

SCH - NE - NY **1300 MW 1300 MW**
Impacts Total Transfer Capability 100 MW 300 MW
TTC with All Lines In Service 1400 MW 1600 MW

BERKSHIR-ALPS_____345_393

FWD

REV

Sat 04/22/2017 to Sat 04/22/2017 UPDATED by NGRID 03/06/2017
1500 Daily 1600

(Import) (Export)

Work scheduled by: NGrid

ARR: 78

SCH - NPX_1385 **100 MW 100 MW**
Impacts Total Transfer Capability 100 MW 100 MW
TTC with All Lines In Service 200 MW 200 MW

BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312

FWD

REV

Sat 04/22/2017 to Sat 04/22/2017
1500 1600

(Import) (Export)

Work scheduled by:

ARR: 78

SCH - NE - NY **1300 MW 1300 MW**
Impacts Total Transfer Capability 100 MW 300 MW
TTC with All Lines In Service 1400 MW 1600 MW

SCH-NE-NYISO_LIMIT_1000

FWD

Sat 04/22/2017 to Sat 04/22/2017 UPDATED by NGRID 03/06/2017
1500 Daily 1600

(Import)

Work scheduled by: NGrid

SCH - NE - NY **1200 MW**
Impacts Total Transfer Capability 200 MW
TTC with All Lines In Service 1400 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | | |
|------------------------------|------------|----------------|----------------|-----------------|-------------------|-----------------------------------|-----------------|
| SCH-NYISO-NE_LIMIT_700 | | | | | | REV | |
| Sat 04/22/2017 | to | Sat 04/22/2017 | <u>UPDATED</u> | <u>by NGRID</u> | <u>03/06/2017</u> | (Export) | |
| 1500 | Daily | 1600 | | | | | |
| Work scheduled by: NGrid | | | | | | SCH - NE - NY | 900 MW |
| | | | | | | Impacts Total Transfer Capability | 700 MW |
| | | | | | | TTC with All Lines In Service | 1600 MW |
| DUNWODIE_345KV_6 | | | | | | FWD | |
| Sun 04/23/2017 | to | Sun 04/23/2017 | <u>UPDATED</u> | <u>by CE</u> | <u>04/07/2017</u> | (Import) | |
| 2330 | Continuous | 2359 | | | | | |
| Work scheduled by: ConEd | | | | | | SPR/DUN-SOUTH | 3800 MW |
| | | | | | | Impacts Total Transfer Capability | 800 MW |
| | | | | | | TTC with All Lines In Service | 4600 MW |
| DUNWODIE_345KV_8 | | | | | | FWD | |
| Sun 04/23/2017 | to | Sun 04/23/2017 | <u>UPDATED</u> | <u>by CE</u> | <u>04/07/2017</u> | (Import) | |
| 2330 | Continuous | 2359 | | | | | |
| Work scheduled by: ConEd | | | | | | SPR/DUN-SOUTH | 3800 MW |
| | | | | | | Impacts Total Transfer Capability | 800 MW |
| | | | | | | TTC with All Lines In Service | 4600 MW |
| ROSETON_-EFISHKIL_345_RFK305 | | | | | | FWD | |
| Mon 04/24/2017 | to | Fri 05/05/2017 | | | | (Import) | |
| 0001 | Continuous | 1900 | | | | | |
| Work scheduled by: NYPA | | | | | | UPNY CONED | 4100 MW |
| | | | | | | Impacts Total Transfer Capability | 1000 MW |
| | | | | | | TTC with All Lines In Service | 5100 MW |
| CLAY____-EDIC____345_1-16 | | | | | | FWD | |
| Mon 04/24/2017 | to | Tue 04/25/2017 | | | | (Import) | |
| 0630 | Continuous | 1530 | | | | | |
| Work scheduled by: NYPA | | | | | | OSWEGO EXPORT | 4850 MW |
| | | | | | | Impacts Total Transfer Capability | 400 MW |
| | | | | | | TTC with All Lines In Service | 5250 MW |
| STLAWRNC-MOSES____230_L34P | | | | | | FWD | REV |
| Mon 04/24/2017 | to | Fri 04/28/2017 | | | | (Import) | (Export) |
| 0700 | Continuous | 1530 | | | | | |
| Work scheduled by: NYPA | | | | | | SCH - OH - NY | 1750 MW 1900 MW |
| | | | | | | Impacts Total Transfer Capability | 0 MW 0 MW |
| | | | | | | TTC with All Lines In Service | 1750 MW 1900 MW |
| MOSES____-ADIRNDCK_230_MAZ | | | | | | FWD | |
| Mon 04/24/2017 | to | Sat 04/29/2017 | <u>UPDATED</u> | <u>by NYPA</u> | <u>10/23/2016</u> | (Import) | |
| 0700 | Continuous | 1730 | | | | | |
| Work scheduled by: NYPA | | | | | | MOSES SOUTH | 2300 MW |
| | | | | | | Impacts Total Transfer Capability | 850 MW |
| | | | | | | TTC with All Lines In Service | 3150 MW |

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | |
|--|--------------------|----------------|---------------------------------|-----------------------------------|----------------|
| ALCOA___-DENNISON_115_12 | | | | FWD | REV |
| Mon 04/24/2017 | to | Wed 04/26/2017 | | (Import) | (Export) |
| 0800 | Continuous | 0659 | | SCH - HQ_CEDARS | 100 MW |
| Work scheduled by: NGrid | | | | Impacts Total Transfer Capability | 99 MW |
| ARR: 38 | | | | TTC with All Lines In Service | 199 MW |
| ALCOA___-DENNISON_115_12 | | | | FWD | REV |
| Wed 04/26/2017 | to | Wed 04/26/2017 | | (Import) | (Export) |
| 0700 | Daily(No Weekends) | 1800 | | SCH - HQ_CEDARS | 100 MW |
| Work scheduled by: NGrid | | | | Impacts Total Transfer Capability | 99 MW |
| ARR: 38 | | | | TTC with All Lines In Service | 199 MW |
| ALCOA___-DENNISON_115_12 & ALCOA___-NOGDNBRG_115_13 | | | | FWD | REV |
| Wed 04/26/2017 | to | Wed 04/26/2017 | | (Import) | (Export) |
| 0700 | | 1800 | | SCH - HQ_CEDARS | 100 MW |
| Work scheduled by: | | | | Impacts Total Transfer Capability | 99 MW |
| ARR: 38 | | | | TTC with All Lines In Service | 199 MW |
| ILCTLIMIT_115KV_ALCOA_R8105_TIE_B | | | | FWD | |
| Wed 04/26/2017 | to | Wed 04/26/2017 | | (Import) | |
| 0700 | Daily(No Weekends) | 1800 | | MOSES SOUTH | 3100 MW |
| Work scheduled by: NGrid | | | | Impacts Total Transfer Capability | 50 MW |
| | | | | TTC with All Lines In Service | 3150 MW |
| ILCTLIMIT_115KV_ALCOA_R8105_TIE_B | | | | FWD | REV |
| Wed 04/26/2017 | to | Wed 04/26/2017 | | (Import) | (Export) |
| 0700 | Daily(No Weekends) | 1800 | | SCH - HQ_CEDARS | 100 MW |
| Work scheduled by: NGrid | | | | Impacts Total Transfer Capability | 99 MW |
| | | | | TTC with All Lines In Service | 199 MW |
| SCRIBA___-VOLNEY___345_21 | | | | FWD | |
| Thu 04/27/2017 | to | Thu 04/27/2017 | | (Import) | |
| 0800 | Daily(No Weekends) | 1630 | | OSWEGO EXPORT | 5250 MW |
| Work scheduled by: NGrid | | | | Impacts Total Transfer Capability | 0 MW |
| | | | | TTC with All Lines In Service | 5250 MW |
| NIAGARA_-ROCHESTR_345_NR2 | | | | FWD | |
| Fri 04/28/2017 | to | Fri 04/28/2017 | | (Import) | |
| 0500 | Continuous | 1700 | UPDATED by PA 03/29/2017 | DYSINGER EAST | 1700 MW |
| Work scheduled by: NYPA | | | | Impacts Total Transfer Capability | 1450 MW |
| | | | | TTC with All Lines In Service | 3150 MW |

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

CENTRAL EAST 3100MW
 CENTRAL EAST - VC 2975MW
 TOTAL EAST 6500MW
 UPNY CONED 5100MW
 SPR/DUN-SOUTH 4600MW
 DYSINGER EAST 3150MW
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 05/01/2017 to Tue 05/16/2017
 0400 Continuous 1800

UPDATED by LI 02/14/2017

Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE 0 MW
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 05/01/2017 to Tue 05/16/2017
 0400 Continuous 1800

UPDATED by LI 02/14/2017

Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE 0 MW
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

MARCY_-N.SCTLND_345_18

Mon 05/01/2017 to Fri 05/05/2017
 0600 Continuous 1630

ARR: 19

Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC 2090 MW
 Impacts Total Transfer Capability 885 MW
 TTC with All Lines In Service 2975 MW

MARCY_-N.SCTLND_345_18 & ILCTLIMIT_MARCY_SO_COMP_I/S

Mon 05/01/2017 to Fri 05/05/2017
 0600 1630

ARR: 19

Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC 1855 MW
 Impacts Total Transfer Capability 1120 MW
 TTC with All Lines In Service 2975 MW

SCH-HQ-NYISO_LIMIT_1150

Mon 05/01/2017 to Fri 05/05/2017
 0600 Continuous 1630

Work scheduled by: HQ

FWD
 (Import)
 SCH - HQ - NY 1150 MW
 Impacts Total Transfer Capability 350 MW
 TTC with All Lines In Service 1500 MW

BROWNFLS-TAYLORVL_115_3

Mon 05/01/2017 to Fri 05/05/2017
 0600 Continuous 1900

ARR: 38

Work scheduled by: NGrid

FWD REV
 (Import) (Export)
 SCH - HQ_CEDARS 70 MW 40 MW
 Impacts Total Transfer Capability 120 MW 0 MW
 TTC with All Lines In Service 190 MW 40 MW

ROCHESTR-PANNELL_345_RP2

Mon 05/01/2017 to Mon 05/01/2017
 0630 Continuous 0700

Work scheduled by: RGE

FWD
 (Import)
 DYSINGER EAST 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | |
|-----------------------------|--------------------|----------------|----------------|--------------------------------|-----------------------------------|-----------------|
| PANNELL_-CLAY_345_2 | | | | | FWD | |
| Mon 05/01/2017 | to | Fri 05/05/2017 | | | (Import) | |
| 0630 | Continuous | 1530 | | | WEST CENTRAL | 1300 MW |
| Work scheduled by: NYPA | | | | | Impacts Total Transfer Capability | 950 MW |
| | | | | | TTC with All Lines In Service | 2250 MW |
| MARION_-FARRAGUT_345_C3403 | | | | | FWD | REV |
| Thu 05/04/2017 | to | Wed 05/31/2017 | <u>UPDATED</u> | <u>by CE</u> <u>04/03/2017</u> | (Import) | (Export) |
| 0001 | Continuous | 2359 | | | SCH - PJ - NY | 2050 MW 1300 MW |
| Work scheduled by: PJM | | | | | Impacts Total Transfer Capability | 0 MW 0 MW |
| | | | | | TTC with All Lines In Service | 2050 MW 1300 MW |
| ELBRIDGE-LAFAYTTE_345_17-LE | | | | | FWD | |
| Thu 05/04/2017 | to | Thu 05/04/2017 | | | (Import) | |
| 0730 | Daily(No Weekends) | 0800 | | | OSWEGO EXPORT | 5250 MW |
| Work scheduled by: NGrid | | | | | Impacts Total Transfer Capability | 0 MW |
| | | | | | TTC with All Lines In Service | 5250 MW |
| OSWEGO_-ELBRIDGE_345_17 | | | | | FWD | |
| Thu 05/04/2017 | to | Thu 05/04/2017 | | | (Import) | |
| 0730 | Daily(No Weekends) | 1700 | | | OSWEGO EXPORT | 5250 MW |
| Work scheduled by: NGrid | | | | | Impacts Total Transfer Capability | 0 MW |
| | | | | | TTC with All Lines In Service | 5250 MW |
| ELBRIDGE-LAFAYTTE_345_17-LE | | | | | FWD | |
| Thu 05/04/2017 | to | Thu 05/04/2017 | | | (Import) | |
| 1630 | Daily(No Weekends) | 1700 | | | OSWEGO EXPORT | 5250 MW |
| Work scheduled by: NGrid | | | | | Impacts Total Transfer Capability | 0 MW |
| | | | | | TTC with All Lines In Service | 5250 MW |
| ROCHESTR-PANNELL_345_RP2 | | | | | FWD | |
| Fri 05/05/2017 | to | Fri 05/05/2017 | | | (Import) | |
| 1500 | Continuous | 1530 | | | DYSINGER EAST | 2300 MW |
| Work scheduled by: RGE | | | | | Impacts Total Transfer Capability | 850 MW |
| | | | | | TTC with All Lines In Service | 3150 MW |
| PLSNTVLE-DUNWODIE_345_W90 | | | | | FWD | |
| Sat 05/06/2017 | to | Wed 05/10/2017 | | | (Import) | |
| 0001 | Continuous | 2130 | | | UPNY CONED | 4000 MW |
| Work scheduled by: ConEd | | | | | Impacts Total Transfer Capability | 1100 MW |
| | | | | | TTC with All Lines In Service | 5100 MW |

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-W49TH_ST_345_M51

Sat 05/06/2017 to Tue 05/16/2017
0700 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

SCH-HQ-NYISO_LIMIT_1150

Mon 05/08/2017 to Fri 05/19/2017
0500 Continuous 1530

Work scheduled by: HQ

FWD
(Import)
SCH - HQ - NY **1150 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 1500 MW

BROWNFLS-TAYLORVL_115_3

Mon 05/08/2017 to Fri 05/12/2017
0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

FWD REV
(Import) (Export)
SCH - HQ_CEDARS **70 MW 40 MW**
Impacts Total Transfer Capability 120 MW 0 MW
TTC with All Lines In Service 190 MW 40 MW

PANNELL_-CLAY____345_2

Mon 05/08/2017 to Mon 05/08/2017
0700 Continuous 0730

Work scheduled by: RGE

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

ROCHESTR-PANNELL__345_RP2

Mon 05/08/2017 to Wed 05/10/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

ROSETON_-ROCKTVRN_345_311

Mon 05/08/2017 to Fri 05/26/2017
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4400 MW**
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 5100 MW

LAFAYTTE-CLRKSCRN_345_4-46

Tue 05/09/2017 to Tue 05/09/2017
0700 Daily(No Weekends) 1700

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

CENTRAL EAST 3100MW
 CENTRAL EAST - VC 2975MW
 TOTAL EAST 6500MW
 UPNY CONED 5100MW
 SPR/DUN-SOUTH 4600MW
 DYSINGER EAST 3150MW
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_____345_2

Wed 05/10/2017 to Wed 05/10/2017
 1500 Continuous 1530

Work scheduled by: RGE

FWD
 (Import)
 WEST CENTRAL 1300 MW
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

BECK_-PACKARD__230_BP76

Sat 05/13/2017 to Sun 05/14/2017
 0500 Continuous 1700

Work scheduled by: NGrid

FWD REV
 (Import) (Export)
 SCH - OH - NY 900 MW 1150 MW
 Impacts Total Transfer Capability 850 MW 450 MW
 TTC with All Lines In Service 1750 MW 1600 MW

BROWNFLS-TAYLORVL_115_3

Mon 05/15/2017 to Fri 05/19/2017
 0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

FWD REV
 (Import) (Export)
 SCH - HQ_CEDARS 70 MW 40 MW
 Impacts Total Transfer Capability 120 MW 0 MW
 TTC with All Lines In Service 190 MW 40 MW

FRASER_-GILBOA_____345_GF5-35

Mon 05/15/2017 to Fri 05/19/2017
 0630 Continuous 1700

Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC 2650 MW
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

STONYRDG-HILLSIDE_230_72

Mon 05/15/2017 to Mon 05/15/2017
 0800 Continuous 1700

Work scheduled by: NYSEG

FWD
 (Import)
 DYSINGER EAST 2850 MW
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

FRASER_345_FRASER SVC

Mon 05/15/2017 to Fri 05/19/2017 UPDATED by NY 04/06/2017
 0900 Continuous 1430

Work scheduled by: NYSEG

FWD
 (Import)
 CENTRAL EAST - VC 2935 MW
 Impacts Total Transfer Capability 40 MW
 TTC with All Lines In Service 2975 MW

FRASER_345_FRASER SVC & ILCTLIMIT_MARCY_SO_COMP_I/S

Mon 05/15/2017 to Fri 05/19/2017
 0900 1430

Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC 2700 MW
 Impacts Total Transfer Capability 275 MW
 TTC with All Lines In Service 2975 MW

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO__-LADENTWN_345_W72

Tue 05/16/2017 to Tue 05/16/2017
0001 Continuous 2330
Work scheduled by: ORU

FWD
(Import)
UPNY CONED **4400 MW**
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 5100 MW

MILLWOOD-EASTVIEW_345_W82

Fri 05/19/2017 to Fri 05/19/2017
0001 Continuous 0030
Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 750 MW
TTC with All Lines In Service 5100 MW

SPRNBK__345KV_RNS4

Fri 05/19/2017 to Fri 05/19/2017
0001 Continuous 0030
Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBK__345_W65

Fri 05/19/2017 to Fri 05/19/2017
0001 Continuous 2100
Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 750 MW
TTC with All Lines In Service 5100 MW

MILLWOOD-EASTVIEW_345_W82

Fri 05/19/2017 to Fri 05/19/2017
2030 Continuous 2100
Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 750 MW
TTC with All Lines In Service 5100 MW

SPRNBK__345KV_RNS4

Fri 05/19/2017 to Fri 05/19/2017
2030 Continuous 2100
Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBK__345_W64

Sun 05/21/2017 to Sun 05/21/2017
0001 Continuous 0030
Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 750 MW
TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK__345KV_RNS5

Sun 05/21/2017 to Sun 05/21/2017

0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W99

Sun 05/21/2017 to Sun 05/21/2017

0001 Continuous 2130

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

4350 MW

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

EASTVIEW-SPRNBRK__345_W64

Sun 05/21/2017 to Sun 05/21/2017

2100 Continuous 2130

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

4350 MW

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

SPRNBRK__345KV_RNS5

Sun 05/21/2017 to Sun 05/21/2017

2100 Continuous 2130

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

MARCY____765_345_AT1

Mon 05/22/2017 to Fri 05/26/2017

0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

MOSES SOUTH

1750 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

BROWNFLS-TAYLORVL_115_3

Mon 05/22/2017 to Fri 05/26/2017

0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

FWD

(Import) (Export)

SCH - HQ_CEDARS

70 MW 40 MW

Impacts Total Transfer Capability 120 MW 0 MW

TTC with All Lines In Service 190 MW 40 MW

MARCY____-N.SCTLND_345_18

Sat 05/27/2017 to Sat 05/27/2017

0500 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

CENTRAL EAST - VC

2090 MW

Impacts Total Transfer Capability 885 MW

TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ-NYISO_LIMIT_1150

Sat 05/27/2017 to Sat 05/27/2017
0500 Continuous 1530

Work scheduled by: HQ

FWD
(Import)
SCH - HQ - NY 1150 MW
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 1500 MW

ILCTLIMIT_MARCY_SO_COMP_I/S

Sat 05/27/2017 to Sat 08/05/2017
1600 Continuous 0459

Work scheduled by: NYISO

FWD
(Import)
CENTRAL EAST - VC 2740 MW
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 2975 MW

BROWNFLS-TAYLORVL_115_4

Tue 05/30/2017 to Fri 06/02/2017
0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

FWD REV
(Import) (Export)
SCH - HQ_CEDARS 70 MW 40 MW
Impacts Total Transfer Capability 120 MW 0 MW
TTC with All Lines In Service 190 MW 40 MW

BROWNFLS-TAYLORVL_115_4

Mon 06/05/2017 to Fri 06/09/2017
0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

FWD REV
(Import) (Export)
SCH - HQ_CEDARS 70 MW 40 MW
Impacts Total Transfer Capability 120 MW 0 MW
TTC with All Lines In Service 190 MW 40 MW

STONYRDG-HILLSIDE_230_72

Mon 06/05/2017 to Mon 06/05/2017
0800 Continuous 1000

Work scheduled by: NYSEG

FWD
(Import)
DYSINGER EAST 2850 MW
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

LINDEN_-GOETHALS_230_A2253

Fri 06/09/2017 to Sun 06/11/2017
0200 Continuous 2300

Work scheduled by: PJM

UPDATED by CE 04/04/2017

FWD REV
(Import) (Export)
SCH - PJ - NY 2050 MW 1300 MW
Impacts Total Transfer Capability 0 MW 0 MW
TTC with All Lines In Service 2050 MW 1300 MW

STONYRDG-HILLSIDE_230_72

Fri 06/09/2017 to Fri 06/09/2017
1500 Continuous 1700

Work scheduled by: NYSEG

FWD
(Import)
DYSINGER EAST 2850 MW
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| BROWNFLS-TAYLORVL_115_4 | | | | | FWD | REV |
|----------------------------------|------------|------|----------------|----------------------------|-----------------------------------|--------------|
| Mon 06/12/2017 to Fri 06/16/2017 | | | | | (Import) | (Export) |
| 0600 | Continuous | 1900 | | | SCH - HQ_CEDARS | 70 MW 40 MW |
| Work scheduled by: NGrid | | | | | Impacts Total Transfer Capability | 120 MW 0 MW |
| ARR: 38 | | | | | TTC with All Lines In Service | 190 MW 40 MW |
| BROWNFLS-TAYLORVL_115_4 | | | | | FWD | REV |
| Mon 06/19/2017 to Fri 06/23/2017 | | | | | (Import) | (Export) |
| 0600 | Continuous | 1900 | | | SCH - HQ_CEDARS | 70 MW 40 MW |
| Work scheduled by: NGrid | | | | | Impacts Total Transfer Capability | 120 MW 0 MW |
| ARR: 38 | | | | | TTC with All Lines In Service | 190 MW 40 MW |
| BROWNFLS-TAYLORVL_115_3 | | | | | FWD | REV |
| Mon 06/26/2017 to Fri 06/30/2017 | | | | | (Import) | (Export) |
| 0600 | Continuous | 1900 | | | SCH - HQ_CEDARS | 70 MW 40 MW |
| Work scheduled by: NGrid | | | | | Impacts Total Transfer Capability | 120 MW 0 MW |
| ARR: 38 | | | | | TTC with All Lines In Service | 190 MW 40 MW |
| BROWNFLS-TAYLORVL_115_3 | | | | | FWD | REV |
| Wed 07/05/2017 to Fri 07/07/2017 | | | | | (Import) | (Export) |
| 0600 | Continuous | 1900 | <u>UPDATED</u> | <u>by NGRID 03/02/2017</u> | SCH - HQ_CEDARS | 70 MW 40 MW |
| Work scheduled by: NGrid | | | | | Impacts Total Transfer Capability | 120 MW 0 MW |
| ARR: 38 | | | | | TTC with All Lines In Service | 190 MW 40 MW |
| BROWNFLS-TAYLORVL_115_3 | | | | | FWD | REV |
| Mon 07/10/2017 to Fri 07/14/2017 | | | | | (Import) | (Export) |
| 0600 | Continuous | 1900 | <u>UPDATED</u> | <u>by NGRID 03/02/2017</u> | SCH - HQ_CEDARS | 70 MW 40 MW |
| Work scheduled by: NGrid | | | | | Impacts Total Transfer Capability | 120 MW 0 MW |
| ARR: 38 | | | | | TTC with All Lines In Service | 190 MW 40 MW |
| BROWNFLS-TAYLORVL_115_3 | | | | | FWD | REV |
| Mon 07/17/2017 to Fri 07/21/2017 | | | | | (Import) | (Export) |
| 0600 | Continuous | 1900 | <u>UPDATED</u> | <u>by NGRID 03/02/2017</u> | SCH - HQ_CEDARS | 70 MW 40 MW |
| Work scheduled by: NGrid | | | | | Impacts Total Transfer Capability | 120 MW 0 MW |
| ARR: 38 | | | | | TTC with All Lines In Service | 190 MW 40 MW |
| BROWNFLS-TAYLORVL_115_4 | | | | | FWD | REV |
| Mon 07/24/2017 to Fri 07/28/2017 | | | | | (Import) | (Export) |
| 0600 | Continuous | 1900 | | | SCH - HQ_CEDARS | 70 MW 40 MW |
| Work scheduled by: NGrid | | | | | Impacts Total Transfer Capability | 120 MW 0 MW |
| ARR: 38 | | | | | TTC with All Lines In Service | 190 MW 40 MW |

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-N.SCTLND_345_18

Sat 08/05/2017 to Sat 08/05/2017
0500 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC 2090 MW
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

MARCY___765_345_AT2

Sat 08/05/2017 to Sat 08/05/2017
0500 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH 1700 MW
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

ILCTLIMT_MARCY_SO_COMP_I/S

Sat 08/05/2017 to Mon 10/02/2017
1600 Continuous 0659

Work scheduled by: NYISO

FWD
(Import)
CENTRAL EAST - VC 2740 MW
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 2975 MW

BROWNFLS-TAYLORVL_115_3

Mon 08/21/2017 to Fri 08/25/2017
0600 Continuous 1900

Work scheduled by: NGrid

CANCELLED by NGrid 04/06/2017

ARR: 38

FWD REV
(Import) (Export)
SCH - HQ_CEDARS 70 MW 40 MW
Impacts Total Transfer Capability 120 MW 0 MW
TTC with All Lines In Service 190 MW 40 MW

BROWNFLS-TAYLORVL_115_3

Mon 08/28/2017 to Fri 09/01/2017
0600 Continuous 1900

Work scheduled by: NGrid

CANCELLED by NGrid 04/06/2017

ARR: 38

FWD REV
(Import) (Export)
SCH - HQ_CEDARS 70 MW 40 MW
Impacts Total Transfer Capability 120 MW 0 MW
TTC with All Lines In Service 190 MW 40 MW

MARCY___765_345_AT2

Tue 09/05/2017 to Sun 09/10/2017
0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH 1700 MW
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

BROWNFLS-TAYLORVL_115_3

Tue 09/05/2017 to Fri 09/08/2017
0600 Continuous 1900

Work scheduled by: NGrid

CANCELLED by NGrid 04/06/2017

ARR: 38

FWD REV
(Import) (Export)
SCH - HQ_CEDARS 70 MW 40 MW
Impacts Total Transfer Capability 120 MW 0 MW
TTC with All Lines In Service 190 MW 40 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BROWNFLS-TAYLORVL_115_3

Mon 09/11/2017 to Fri 09/15/2017 **CANCELLED by NGrid 04/06/2017**
0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

| | FWD | REV |
|-----------------------------------|--------------|--------------|
| | (Import) | (Export) |
| SCH - HQ_CEDARS | 70 MW | 40 MW |
| Impacts Total Transfer Capability | 120 MW | 0 MW |
| TTC with All Lines In Service | 190 MW | 40 MW |

MOSES-ADIRNDCK_230_MAI

Mon 09/11/2017 to Sat 09/16/2017
0700 Continuous 1530

Work scheduled by: NYPA

| | FWD |
|-----------------------------------|----------------|
| | (Import) |
| MOSES SOUTH | 2100 MW |
| Impacts Total Transfer Capability | 1050 MW |
| TTC with All Lines In Service | 3150 MW |

HURLYAVE-ROSETON_345_303

Mon 09/11/2017 to Fri 09/29/2017
0800 Continuous 1600

Work scheduled by: CHGE

| | FWD |
|-----------------------------------|----------------|
| | (Import) |
| UPNY CONED | 4100 MW |
| Impacts Total Transfer Capability | 1000 MW |
| TTC with All Lines In Service | 5100 MW |

DUNWODIE_345KV_5

Fri 09/15/2017 to Sun 09/17/2017
2200 Continuous 0200

Work scheduled by: ConEd

| | FWD |
|-----------------------------------|----------------|
| | (Import) |
| SPR/DUN-SOUTH | 3800 MW |
| Impacts Total Transfer Capability | 800 MW |
| TTC with All Lines In Service | 4600 MW |

DUNWODIE_345KV_7

Fri 09/15/2017 to Sun 09/17/2017
2200 Continuous 0200

Work scheduled by: ConEd

| | FWD |
|-----------------------------------|----------------|
| | (Import) |
| SPR/DUN-SOUTH | 3800 MW |
| Impacts Total Transfer Capability | 800 MW |
| TTC with All Lines In Service | 4600 MW |

SPRNBK-DUNWODIE_345_W75

Fri 09/15/2017 to Sun 09/17/2017
2200 Continuous 0200

Work scheduled by: ConEd

| | FWD |
|-----------------------------------|----------------|
| | (Import) |
| SPR/DUN-SOUTH | 3800 MW |
| Impacts Total Transfer Capability | 800 MW |
| TTC with All Lines In Service | 4600 MW |

SPRNBK_345KV_RNS3

Fri 09/15/2017 to Sun 09/17/2017
2200 Continuous 0200

Work scheduled by: ConEd

| | FWD |
|-----------------------------------|----------------|
| | (Import) |
| SPR/DUN-SOUTH | 3800 MW |
| Impacts Total Transfer Capability | 800 MW |
| TTC with All Lines In Service | 4600 MW |

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BROWNFLS-TAYLORVL_115_4

Mon 09/18/2017 to Fri 09/22/2017
0600 Continuous 1900

CANCELLED by NGrid 04/06/2017

Work scheduled by: NGrid

ARR: 38

| | FWD | REV |
|-----------------------------------|--------------|--------------|
| | (Import) | (Export) |
| SCH - HQ_CEDARS | 70 MW | 40 MW |
| Impacts Total Transfer Capability | 120 MW | 0 MW |
| TTC with All Lines In Service | 190 MW | 40 MW |

GILBOA__-N.SCTLND_345_GNS-1

Mon 09/18/2017 to Fri 10/06/2017
0630 Continuous 1700

Work scheduled by: NYPA

| | FWD |
|-----------------------------------|----------------|
| | (Import) |
| CENTRAL EAST - VC | 2520 MW |
| Impacts Total Transfer Capability | 455 MW |
| TTC with All Lines In Service | 2975 MW |

NIAGARA__345_230_AT4

Mon 09/18/2017 to Tue 09/19/2017
0700 Continuous 1530

Work scheduled by: NYPA

| | FWD | REV |
|-----------------------------------|----------------|----------------|
| | (Import) | (Export) |
| SCH - OH - NY | 1750 MW | 1300 MW |
| Impacts Total Transfer Capability | 0 MW | 300 MW |
| TTC with All Lines In Service | 1750 MW | 1600 MW |

MOSES__-ADIRNDCK_230_MAI

Mon 09/18/2017 to Sat 09/23/2017
0700 Continuous 1530

Work scheduled by: NYPA

| | FWD |
|-----------------------------------|----------------|
| | (Import) |
| MOSES SOUTH | 2100 MW |
| Impacts Total Transfer Capability | 1050 MW |
| TTC with All Lines In Service | 3150 MW |

BROWNFLS-TAYLORVL_115_4

Mon 09/25/2017 to Fri 09/29/2017
0600 Continuous 1900

CANCELLED by NGrid 04/06/2017

Work scheduled by: NGrid

ARR: 38

| | FWD | REV |
|-----------------------------------|--------------|--------------|
| | (Import) | (Export) |
| SCH - HQ_CEDARS | 70 MW | 40 MW |
| Impacts Total Transfer Capability | 120 MW | 0 MW |
| TTC with All Lines In Service | 190 MW | 40 MW |

MOSES__-ADIRNDCK_230_MAI

Mon 09/25/2017 to Sat 09/30/2017
0700 Continuous 1530

Work scheduled by: NYPA

| | FWD |
|-----------------------------------|----------------|
| | (Import) |
| MOSES SOUTH | 2100 MW |
| Impacts Total Transfer Capability | 1050 MW |
| TTC with All Lines In Service | 3150 MW |

BROWNFLS-TAYLORVL_115_4

Mon 10/02/2017 to Fri 10/06/2017
0600 Continuous 1900

CANCELLED by NGrid 04/06/2017

Work scheduled by: NGrid

ARR: 38

| | FWD | REV |
|-----------------------------------|--------------|--------------|
| | (Import) | (Export) |
| SCH - HQ_CEDARS | 70 MW | 40 MW |
| Impacts Total Transfer Capability | 120 MW | 0 MW |
| TTC with All Lines In Service | 190 MW | 40 MW |

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-ROCHESTR_345_NR2

Mon 10/02/2017 to Fri 10/06/2017
0700 Continuous 1530
Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST 1700 MW
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

FRASER_-COOPERS_345_33

Mon 10/02/2017 to Fri 10/13/2017
0700 Continuous 1900
Work scheduled by: NYSEG

FWD
(Import)
CENTRAL EAST - VC 2395 MW
Impacts Total Transfer Capability 580 MW
TTC with All Lines In Service 2975 MW

BROWNFLS-TAYLORVL_115_4

Mon 10/09/2017 to Fri 10/13/2017 **CANCELLED by NGrid 04/06/2017**
0600 Continuous 1900
Work scheduled by: NGrid **ARR: 38**

FWD REV
(Import) (Export)
SCH - HQ_CEDARS 70 MW 40 MW
Impacts Total Transfer Capability 120 MW 0 MW
TTC with All Lines In Service 190 MW 40 MW

ILCTLIMIT_MARCY_SO_COMP_I/S

Fri 10/13/2017 to Mon 11/06/2017
1900 Continuous 0559
Work scheduled by: NYISO

FWD
(Import)
CENTRAL EAST - VC 2740 MW
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 2975 MW

CHATGUAY-MASSENA_765_7040

Sat 10/14/2017 to Sat 10/28/2017 **UPDATED by NYISO 03/24/2017**
0700 Continuous 1530
Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 1550 MW
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA_765_7040

Sat 10/14/2017 to Sat 10/28/2017 **UPDATED by NYISO 03/24/2017**
0700 Continuous 1530
Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - HQ - NY 0 MW 0 MW
Impacts Total Transfer Capability 1500 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

MARCY_765_345_AT1

Sat 10/14/2017 to Sat 10/28/2017 **UPDATED by NYISO 03/24/2017**
0700 Continuous 1530
Work scheduled by: NYPA **ARR: 19**

FWD
(Import)
MOSES SOUTH 1750 MW
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | | | |
|--|------------|----------------|----------------|-----------------------------------|-----------------------------------|-----------------|---------|--|
| MARCY____765_345_AT2 | | | | | FWD | | | |
| Sat 10/14/2017 | to | Sat 10/28/2017 | <u>UPDATED</u> | <u>by NYISO</u> <u>03/24/2017</u> | (Import) | | | |
| 0700 | Continuous | 1530 | | | MOSES SOUTH | 1700 MW | | |
| Work scheduled by: NYPA | | | | | Impacts Total Transfer Capability | 1450 MW | | |
| | | | | | TTC with All Lines In Service | 3150 MW | | |
| MASSENA_-MARCY____765_MSU1 | | | | | FWD | | | |
| Sat 10/14/2017 | to | Sat 10/28/2017 | <u>UPDATED</u> | <u>by NYISO</u> <u>03/24/2017</u> | (Import) | | | |
| 0700 | Continuous | 1530 | | | CENTRAL EAST - VC | 2265 MW | | |
| Work scheduled by: NYPA | | | | | Impacts Total Transfer Capability | 710 MW | | |
| | | | | | TTC with All Lines In Service | 2975 MW | | |
| MASSENA_-MARCY____765_MSU1 | | | | | FWD | | | |
| Sat 10/14/2017 | to | Sat 10/28/2017 | <u>UPDATED</u> | <u>by NYISO</u> <u>03/24/2017</u> | (Import) | | | |
| 0700 | Continuous | 1530 | | | MOSES SOUTH | 500 MW | | |
| Work scheduled by: NYPA | | | | | Impacts Total Transfer Capability | 2650 MW | | |
| | | | | | TTC with All Lines In Service | 3150 MW | | |
| MASSENA_-MARCY____765_MSU1 | | | | | FWD | REV | | |
| Sat 10/14/2017 | to | Sat 10/28/2017 | <u>UPDATED</u> | <u>by NYISO</u> <u>03/24/2017</u> | (Import) | (Export) | | |
| 0700 | Continuous | 1530 | | | SCH - HQ - NY | 475 MW | 1000 MW | |
| Work scheduled by: NYPA | | | | | Impacts Total Transfer Capability | 1025 MW 0 MW | | |
| | | | | | TTC with All Lines In Service | 1500 MW 1000 MW | | |
| MASSENA_-MARCY____765_MSU1 & CHATGUAY-MASSENA_765_7040 | | | | | FWD | | | |
| Sat 10/14/2017 | to | Sat 10/28/2017 | | | (Import) | | | |
| 0700 | | 1530 | | | MOSES SOUTH | 500 MW | | |
| Work scheduled by: | | | | | Impacts Total Transfer Capability | 2650 MW | | |
| | | | | | TTC with All Lines In Service | 3150 MW | | |
| MASSENA_-MARCY____765_MSU1 & ILCTLIMIT_MARCY_SO_COMP_I/S | | | | | FWD | | | |
| Sat 10/14/2017 | to | Sat 10/28/2017 | | | (Import) | | | |
| 0700 | | 1530 | | | CENTRAL EAST - VC | 2080 MW | | |
| Work scheduled by: | | | | | Impacts Total Transfer Capability | 895 MW | | |
| | | | | | TTC with All Lines In Service | 2975 MW | | |
| MOSES____-MASSENA_230_MMS1 & MOSES____-MASSENA_230_MMS2 | | | | | FWD | REV | | |
| Sat 10/14/2017 | to | Sat 10/28/2017 | | | (Import) | (Export) | | |
| 0700 | | 1530 | | | SCH - HQ - NY | 850 MW | 0 MW | |
| Work scheduled by: | | | | | Impacts Total Transfer Capability | 650 MW 1000 MW | | |
| | | | | | TTC with All Lines In Service | 1500 MW 1000 MW | | |

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS___-HURLYAVE_345_301

Mon 10/16/2017 to Fri 11/03/2017

0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED

4100 MW

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 5100 MW

MOSES___-ADIRNDCK_230_MA2

Mon 10/30/2017 to Fri 11/03/2017

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

2100 MW

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

BROWNFLS-TAYLORVL_115_3

Mon 10/30/2017 to Fri 11/03/2017

0700 Continuous 1900

Work scheduled by: NGrid

CANCELLED by NGrid 04/06/2017

ARR: 38

FWD

(Import) (Export)

SCH - HQ_CEDARS

70 MW

40 MW

Impacts Total Transfer Capability 120 MW

0 MW

TTC with All Lines In Service 190 MW

40 MW

FRASANX-COOPERS___345_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017

0600 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC

2500 MW

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

MARCY___-FRASANX_345_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017

0600 Continuous 1700

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

CENTRAL EAST - VC

2500 MW

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/06/2017 to Thu 11/09/2017

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

BROWNFLS-TAYLORVL_115_3

Mon 11/06/2017 to Thu 11/09/2017

0700 Continuous 1900

Work scheduled by: NGrid

CANCELLED by NGrid 04/06/2017

ARR: 38

FWD

(Import) (Export)

SCH - HQ_CEDARS

100 MW

100 MW

Impacts Total Transfer Capability 99 MW

0 MW

TTC with All Lines In Service 199 MW

100 MW

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDN_CG-LNDVFT___345_V-3022

Mon 11/06/2017 to Thu 11/09/2017
0800 Continuous 1500

Work scheduled by: PJM

| | FWD | REV |
|-----------------------------------|----------|----------|
| | (Import) | (Export) |
| SCH - PJM_VFT | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 315 MW | 315 MW |
| TTC with All Lines In Service | 315 MW | 315 MW |

BROWNFLS-TAYLORVL_115_4

Mon 11/13/2017 to Fri 11/17/2017
0600 Continuous 1900

Work scheduled by: NGrid

CANCELLED by NGrid 04/06/2017

ARR: 38

| | FWD | REV |
|-----------------------------------|----------|----------|
| | (Import) | (Export) |
| SCH - HQ_CEDARS | 100 MW | 100 MW |
| Impacts Total Transfer Capability | 99 MW | 0 MW |
| TTC with All Lines In Service | 199 MW | 100 MW |

MOSES___-ADIRNDCK_230_MA2

Mon 11/13/2017 to Fri 11/17/2017
0700 Continuous 1530

Work scheduled by: NYPA

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| MOSES SOUTH | 2300 MW |
| Impacts Total Transfer Capability | 850 MW |
| TTC with All Lines In Service | 3150 MW |

ILCTLIMIT_MARCY_SO_COMP_I/S

Fri 11/17/2017 to Sat 02/01/2020
1700 Continuous 0000

Work scheduled by: NYISO

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| CENTRAL EAST - VC | 2740 MW |
| Impacts Total Transfer Capability | 235 MW |
| TTC with All Lines In Service | 2975 MW |

BROWNFLS-TAYLORVL_115_4

Mon 11/20/2017 to Wed 11/22/2017
0600 Continuous 1900

Work scheduled by: NGrid

CANCELLED by NGrid 04/06/2017

ARR: 38

| | FWD | REV |
|-----------------------------------|----------|----------|
| | (Import) | (Export) |
| SCH - HQ_CEDARS | 100 MW | 100 MW |
| Impacts Total Transfer Capability | 99 MW | 0 MW |
| TTC with All Lines In Service | 199 MW | 100 MW |

MOSES___-ADIRNDCK_230_MA1

Mon 11/20/2017 to Wed 11/22/2017
0700 Continuous 1530

Work scheduled by: NYPA

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| MOSES SOUTH | 2300 MW |
| Impacts Total Transfer Capability | 850 MW |
| TTC with All Lines In Service | 3150 MW |

MOSES___-ADIRNDCK_230_MA1

Mon 11/27/2017 to Fri 12/01/2017
0700 Continuous 1530

Work scheduled by: NYPA

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| MOSES SOUTH | 2300 MW |
| Impacts Total Transfer Capability | 850 MW |
| TTC with All Lines In Service | 3150 MW |

NYISO TRANSFER LIMITATIONS

Sunday ,April 09, 2017 to Tuesday ,October 09, 2018

CENTRAL EAST 3100MW
 CENTRAL EAST - VC 2975MW
 TOTAL EAST 6500MW
 UPNY CONED 5100MW
 SPR/DUN-SOUTH 4600MW
 DYSINGER EAST 3150MW
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY____765_345_AT2

FWD

Mon 12/04/2017 to Fri 12/08/2017

(Import)

0500 Continuous 1630

MOSES SOUTH

1700 MW

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

ARR: 19

MOSES____-ADIRNDCK_230_MA2

FWD

Mon 12/11/2017 to Fri 12/15/2017

(Import)

0700 Continuous 1530

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

MOSES____-ADIRNDCK_230_MA2

FWD

Mon 12/18/2017 to Fri 12/22/2017

(Import)

0700 Continuous 1530

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

UPDATEDby NYPA10/23/2016

MARCY____765_345_AT2

FWD

Wed 12/27/2017 to Thu 12/28/2017

(Import)

0500 Continuous 1630

MOSES SOUTH

1700 MW

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

ARR: 19