NYISO TRANSFER LIMITATIONS

Sunday ,May 07, 2017 to Tuesday ,November 06, 2018

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO___345_345_PAR3500

Fri 06/24/2016 to Fri 09/15/2017 **EXT FORCE** **by CONED** **03/22/2017**
1940 Continuous 2359
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	**1700 MW**	**1300 MW**
Impacts Total Transfer Capability	600 MW	150 MW
TTC with All Lines In Service	2300 MW	1450 MW

PLSNTVLE-DUNWODIE_345_W89

Sun 10/30/2016 to Wed 05/03/2017 **UPDATED** **by CONED** **04/25/2017**
0728 Continuous 1600
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**4000 MW**
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

HUDSONTP-W49TH_ST_345_Y56

Thu 11/24/2016 to Sat 07/15/2017 **EXTENDED** **by PJM** **01/27/2017**
1500 Continuous 2359
Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**0 MW**
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	660 MW

E13THSTA-FARRAGUT_345_46

Tue 12/20/2016 to Mon 05/08/2017 **UPDATED** **by CONED** **05/06/2017**
0001 Continuous 2200
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

W49TH_ST-E13THSTA_345_M55

Tue 12/20/2016 to Mon 05/08/2017 **UPDATED** **by CONED** **05/06/2017**
0001 Continuous 2200
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

HUDSONP_-FARRAGUT_345_B3402

Tue 03/21/2017 to Fri 05/05/2017 **EXTENDED** **by CONED** **05/04/2017**
0001 Continuous 2359
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	**2050 MW**	**1300 MW**
Impacts Total Transfer Capability	250 MW	150 MW
TTC with All Lines In Service	2300 MW	1450 MW

HUDSONP_-FARRAGUT_345_B3402 & MARION__-FARRAGUT_345_C3403

Tue 03/21/2017 to Fri 05/05/2017
0001 2359
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - PJ - NY	**2050 MW**	**1300 MW**
Impacts Total Transfer Capability	250 MW	150 MW
TTC with All Lines In Service	2300 MW	1450 MW

NYISO TRANSFER LIMITATIONS

Sunday ,May 07, 2017 to Tuesday ,November 06, 2018

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARION__-FARRAGUT_345_C3403

Tue 03/21/2017 to Fri 05/05/2017 **EXTENDED** **by CONED** **05/04/2017**
0001 Continuous 2359
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	**2050 MW**	**1300 MW**
Impacts Total Transfer Capability	250 MW	150 MW
TTC with All Lines In Service	2300 MW	1450 MW

DUNWODIE_345KV_3

Fri 04/07/2017 to Wed 05/03/2017 **UPDATED** **by CONED** **04/25/2017**
0001 Continuous 1600
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

DUNWODIE_345KV_4

Fri 04/07/2017 to Wed 05/03/2017 **UPDATED** **by CONED** **04/25/2017**
0001 Continuous 1600
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

DUNWODIE-MOTTHAVN_345_71

Mon 04/17/2017 to Wed 05/31/2017 **EXT FORCE** **by CE** **04/21/2017**
2120 Continuous 2359
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

ROSETON_-EFISHKIL_345_RFK305

Mon 04/24/2017 to Fri 05/05/2017
0600 Continuous 1900
Work scheduled by: NYPA

	FWD (Import)
UPNY CONED	**4100 MW**
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

BEAR SWP-EASTOVER_230_E205W

Mon 04/24/2017 to Tue 05/30/2017 **UPDATED** **by NE** **04/24/2017**
0700 Continuous 0659
Work scheduled by: NGrid

SCH - NE - NY	
Impacts Total Transfer Capability	
TTC with All Lines In Service	

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 05/01/2017 to Tue 05/16/2017 **UPDATED** **by LI** **02/14/2017**
0400 Continuous 1800
Work scheduled by: LI

	FWD (Import)
SCH - PJM_NEPTUNE	**0 MW**
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Sunday ,May 07, 2017 to Tuesday ,November 06, 2018

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501

Mon 05/01/2017 to Tue 05/16/2017 **UPDATED** **by LI** **02/14/2017**
0400 Continuous 1800
Work scheduled by: LI

	FWD (Import)
SCH - PJM_NEPTUNE	**0 MW**
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	660 MW

MARCY___-N.SCTLND_345_18

Mon 05/01/2017 to Fri 05/05/2017 **UPDATED** **by NYPA** **04/10/2017**
0500 Continuous 1700
Work scheduled by: NYPA **ARR: 19**

	FWD (Import)
CENTRAL EAST - VC	**2090 MW**
Impacts Total Transfer Capability	885 MW
TTC with All Lines In Service	2975 MW

BROWNFLS-TAYLORVL_115_3

Mon 05/01/2017 to Fri 05/05/2017
0600 Continuous 1900
Work scheduled by: NGrid **ARR: 38**

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**70 MW**	**40 MW**
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

NEWBRDGE_345_138_BK_1

Mon 05/01/2017 to Tue 05/16/2017 **UPDATED** **by LI** **02/14/2017**
0626 Continuous 1800
Work scheduled by: LI

	FWD (Import)
SCH - PJM_NEPTUNE	**375 MW**
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

NEWBRDGE_345_138_BK_2

Mon 05/01/2017 to Tue 05/16/2017 **UPDATED** **by LI** **02/14/2017**
0627 Continuous 1800
Work scheduled by: LI

	FWD (Import)
SCH - PJM_NEPTUNE	**375 MW**
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

PANNELL_-CLAY_____345_2

Mon 05/01/2017 to Wed 05/03/2017
0630 Continuous 1643
Work scheduled by: NYPA

	FWD (Import)
WEST CENTRAL	**1300 MW**
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	2250 MW

SCH-NYISO-HQ_LIMIT_800

Mon 05/01/2017 to Wed 05/10/2017
2200 Continuous 0300
Work scheduled by: HQ

	REV (Export)
SCH - HQ - NY	**800 MW**
Impacts Total Transfer Capability	200 MW
TTC with All Lines In Service	1000 MW

NYISO TRANSFER LIMITATIONS

Sunday ,May 07, 2017 to Tuesday ,November 06, 2018

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6

Wed 05/03/2017 to Sat 05/06/2017 **UPDATED** **by CONED** **05/06/2017**
0001 Continuous 0204
Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**320 MW**
Impacts Total Transfer Capability	340 MW
TTC with All Lines In Service	660 MW

ELBRIDGE-LAFAYTTE_345_17-LE

Thu 05/04/2017 to Thu 05/04/2017
0730 Daily(No Weekends) 0800
Work scheduled by: NGrid

ARR: 75

	FWD (Import)
OSWEGO EXPORT	**5250 MW**
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	5250 MW

OSWEGO__-ELBRIDGE_345_17

Thu 05/04/2017 to Thu 05/04/2017
0730 Daily(No Weekends) 1700
Work scheduled by: NGrid

ARR: 75

	FWD (Import)
OSWEGO EXPORT	**5250 MW**
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	5250 MW

ELBRIDGE-LAFAYTTE_345_17-LE

Thu 05/04/2017 to Thu 05/04/2017
1630 Daily(No Weekends) 1700
Work scheduled by: NGrid

ARR: 75

	FWD (Import)
OSWEGO EXPORT	**5250 MW**
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	5250 MW

ILCTLIMT_MARCY_SO_COMP_I/S

Fri 05/05/2017 to Sat 05/06/2017
1700 Continuous 2059
Work scheduled by: NYISO

	FWD (Import)
CENTRAL EAST - VC	**2740 MW**
Impacts Total Transfer Capability	235 MW
TTC with All Lines In Service	2975 MW

PLSNTVLE-DUNWODIE_345_W90

Sat 05/06/2017 to Wed 05/10/2017 **UPDATED** **by CE** **05/06/2017**
0001 Continuous 2130
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**4000 MW**
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

MARION__-FARRAGUT_345_C3403

Sat 05/06/2017 to Wed 05/31/2017 **CANCELLED** **by ConEd** **05/03/2017**
0001 Continuous 2359
Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJ - NY	**2050 MW**	**1300 MW**
Impacts Total Transfer Capability	250 MW	150 MW
TTC with All Lines In Service	2300 MW	1450 MW

NYISO TRANSFER LIMITATIONS

Sunday ,May 07, 2017 to Tuesday ,November 06, 2018

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD_ST_-PLSNTVLE_345_Y87

Sat 05/06/2017 to Sun 05/07/2017 **FORCED** **by CE** **05/06/2017**
0326 Continuous 2200
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**4000 MW**
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

OSWEGO_COMPLEX_AVR_O/S

Sun 05/07/2017 to Sun 05/07/2017
0900 Continuous 1100
Work scheduled by: Gen

	FWD (Import)
CENTRAL EAST - VC	**2870 MW**
Impacts Total Transfer Capability	105 MW
TTC with All Lines In Service	2975 MW

HURLYAVE-ROSETON__345_303

Mon 05/08/2017 to Mon 05/08/2017
0600 Daily 0700
Work scheduled by: CHGE

	FWD (Import)
UPNY CONED	**4100 MW**
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

LEEDS___-HURLYAVE_345_301

Mon 05/08/2017 to Mon 05/08/2017
0600 Daily 0700
Work scheduled by: CHGE

	FWD (Import)
UPNY CONED	**4100 MW**
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

BROWNFLS-TAYLORVL_115_3

Mon 05/08/2017 to Fri 05/12/2017
0600 Continuous 1900
Work scheduled by: NGrid **ARR: 38**

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**70 MW**	**40 MW**
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

LAFAYTTE-CLRKSCRN_345_4-46

Mon 05/08/2017 to Fri 05/12/2017 **UPDATED** **by NGRID** **05/05/2017**
0700 Continuous 1700
Work scheduled by: NGrid

	FWD (Import)
CENTRAL EAST - VC	**2650 MW**
Impacts Total Transfer Capability	325 MW
TTC with All Lines In Service	2975 MW

ROSETON_-ROCKTVRN_345_311

Mon 05/08/2017 to Fri 05/26/2017
0800 Continuous 1600
Work scheduled by: CHGE

	FWD (Import)
UPNY CONED	**4400 MW**
Impacts Total Transfer Capability	700 MW
TTC with All Lines In Service	5100 MW

NYISO TRANSFER LIMITATIONS

Sunday ,May 07, 2017 to Tuesday ,November 06, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCHESTR-PANNELL__345_RP2

Mon 05/08/2017 to Wed 05/10/2017 **UPDATED** **by PA** **05/04/2017**
1200 Continuous 1700
Work scheduled by: NYPA

	FWD (Import)
DYSINGER EAST	**2300 MW**
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

SCH-NYISO-NE_LIMIT_500

Tue 05/09/2017 to Fri 05/19/2017 **UPDATED** **by ISONE** **05/05/2017**
0700 Continuous 1559
Work scheduled by: ISONE

	REV (Export)
SCH - NE - NY	**700 MW**
Impacts Total Transfer Capability	900 MW
TTC with All Lines In Service	1600 MW

EFISHKIL-WOOD_ST__345_F39

Thu 05/11/2017 to Sat 05/13/2017 **UPDATED** **by CE** **04/13/2017**
2100 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**4000 MW**
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

WOOD_ST_-PLSNTVLE_345_Y87

Thu 05/11/2017 to Sat 05/13/2017 **UPDATED** **by CE** **04/13/2017**
2100 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**4000 MW**
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

SCH-NYISO-HQ_LIMIT_900

Thu 05/11/2017 to Sun 05/14/2017
2200 Continuous 0300
Work scheduled by: HQ

	REV (Export)
SCH - HQ - NY	**900 MW**
Impacts Total Transfer Capability	100 MW
TTC with All Lines In Service	1000 MW

MARCY____345KV_CSC

Sat 05/13/2017 to Sat 05/13/2017
0600 Continuous 1800
Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	**2925 MW**
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	2975 MW

CEDARS__-ROSEMNTB_115_2/22

Mon 05/15/2017 to Wed 05/17/2017 **UPDATED** **by NYISO** **05/03/2017**
0600 Continuous 1900
Work scheduled by: HQ

ARR: 38

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**95 MW**	**40 MW**
Impacts Total Transfer Capability	95 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

NYISO TRANSFER LIMITATIONS

Sunday ,May 07, 2017 to Tuesday ,November 06, 2018

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DENNISON-ROSEMNTB_115_2/22

Mon 05/15/2017 to Wed 05/17/2017 **UPDATED** **by NYISO** **05/03/2017**
0600 Continuous 1900
Work scheduled by: HQ
ARR: 38

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**95 MW**	**40 MW**
Impacts Total Transfer Capability	95 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

SCH-HQ_CEDARS-NYISO_LIMIT_80

Mon 05/15/2017 to Wed 05/17/2017 **UPDATED** **by NYISO** **05/03/2017**
0600 Continuous 1900
Work scheduled by: HQ

	FWD (Import)
SCH - HQ_CEDARS	**80 MW**
Impacts Total Transfer Capability	110 MW
TTC with All Lines In Service	190 MW

BROWNFLS-TAYLORVL_115_3

Mon 05/15/2017 to Fri 05/19/2017
0600 Continuous 1900
Work scheduled by: NGrid
ARR: 38

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**70 MW**	**40 MW**
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

FRASER__-GILBOA___345_GF5-35

Mon 05/15/2017 to Fri 05/19/2017 **UPDATED** **by NYPA** **04/13/2017**
0630 Continuous 1700
Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	**2650 MW**
Impacts Total Transfer Capability	325 MW
TTC with All Lines In Service	2975 MW

STONYRDG-HILLSIDE_230_72

Mon 05/15/2017 to Mon 05/15/2017
0800 Continuous 1700
Work scheduled by: NYSEG

	FWD (Import)
DYSINGER EAST	**2850 MW**
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

FRASER___345_FRASER SVC

Mon 05/15/2017 to Fri 05/19/2017 **UPDATED** **by NY** **04/06/2017**
0900 Continuous 1430
Work scheduled by: NYSEG

	FWD (Import)
CENTRAL EAST - VC	**2935 MW**
Impacts Total Transfer Capability	40 MW
TTC with All Lines In Service	2975 MW

RAMAPO__-LADENTWN_345_W72

Tue 05/16/2017 to Tue 05/16/2017
0001 Continuous 2330
Work scheduled by: ORU

	FWD (Import)
UPNY CONED	**4400 MW**
Impacts Total Transfer Capability	700 MW
TTC with All Lines In Service	5100 MW

NYISO TRANSFER LIMITATIONS

Sunday ,May 07, 2017 to Tuesday ,November 06, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BROWNFLS-HIGLEY___115_1

Tue 05/16/2017 to Thu 05/18/2017 **UPDATED** **by NGRID** **05/05/2017**
0700 Continuous 1900
Work scheduled by: NGrid
ARR: 38

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**100 MW**	**40 MW**
Impacts Total Transfer Capability	90 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

OSWEGO__-VOLNEY___345_12

Wed 05/17/2017 to Wed 05/17/2017
0800 Daily(No Weekends) 1630
Work scheduled by: NGrid

	FWD (Import)
OSWEGO EXPORT	**5250 MW**
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	5250 MW

CHAT_DC_GC1

Wed 05/17/2017 to Thu 05/18/2017 **by HQ** **05/04/2017**
1800 Continuous 0600
Work scheduled by: HQ

	FWD (Import)
MOSES SOUTH	**2850 MW**
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

CHAT_DC_GC1

Wed 05/17/2017 to Thu 05/18/2017 **by HQ** **05/04/2017**
1800 Continuous 0600
Work scheduled by: HQ

	REV (Export)
SCH - HQ - NY	**500 MW**
Impacts Total Transfer Capability	500 MW
TTC with All Lines In Service	1000 MW

CHAT_DC_GC1 & CHAT_DC_GC2

Wed 05/17/2017 to Thu 05/18/2017
1800 0600
Work scheduled by:

	FWD (Import)
MOSES SOUTH	**2550 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	3150 MW

CHAT_DC_GC1 & CHAT_DC_GC2

Wed 05/17/2017 to Thu 05/18/2017
1800 0600
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ - NY	**1370 MW**	**0 MW**
Impacts Total Transfer Capability	130 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

CHAT_DC_GC2

Wed 05/17/2017 to Thu 05/18/2017 **by HQ** **05/04/2017**
1800 Continuous 0600
Work scheduled by: HQ

	FWD (Import)
MOSES SOUTH	**2850 MW**
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,May 07, 2017 to Tuesday ,November 06, 2018

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC2

Wed 05/17/2017 to Thu 05/18/2017
1800 Continuous 0600
Work scheduled by: HQ

by HQ **05/04/2017**

	REV (Export)
SCH - HQ - NY	**500 MW**
Impacts Total Transfer Capability	500 MW
TTC with All Lines In Service	1000 MW

SCH-HQ-NYISO_LIMIT_1100

Wed 05/17/2017 to Thu 05/18/2017
1800 Continuous 0600
Work scheduled by: HQ

by HQ **05/04/2017**

	FWD (Import)
SCH - HQ - NY	**1100 MW**
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	1500 MW

CHATGUAY-MASSENA__765_7040

Thu 05/18/2017 to Thu 05/18/2017
0000 Continuous 0600
Work scheduled by: HQ

by HQ **05/04/2017**

	FWD (Import)
MOSES SOUTH	**1550 MW**
Impacts Total Transfer Capability	1600 MW
TTC with All Lines In Service	3150 MW

CHATGUAY-MASSENA__765_7040

Thu 05/18/2017 to Thu 05/18/2017
0000 Continuous 0600
Work scheduled by: HQ

by HQ **05/04/2017**

	FWD (Import)	REV (Export)
SCH - HQ - NY	**0 MW**	**0 MW**
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

OSWEGO__-ELBRIDGE_345_17

Thu 05/18/2017 to Thu 05/18/2017
0630 Continuous 0700
Work scheduled by: NGrid

ARR: 75

	FWD (Import)
OSWEGO EXPORT	**5250 MW**
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	5250 MW

ELBRIDGE-LAFAYTTE_345_17-LE

Thu 05/18/2017 to Fri 05/19/2017
0630 Continuous 1700
Work scheduled by: NGrid

ARR: 75

	FWD (Import)
OSWEGO EXPORT	**5250 MW**
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	5250 MW

MILLWOOD-EASTVIEW_345_W82

Fri 05/19/2017 to Fri 05/19/2017
0001 Continuous 0030
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**4350 MW**
Impacts Total Transfer Capability	750 MW
TTC with All Lines In Service	5100 MW

NYISO TRANSFER LIMITATIONS

Sunday ,May 07, 2017 to Tuesday ,November 06, 2018

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK__345KV_RNS4

Fri 05/19/2017 to Fri 05/19/2017
0001 Continuous 0030
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3200 MW**
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

EASTVIEW-SPRNBRK__345_W65

Fri 05/19/2017 to Fri 05/19/2017
0001 Continuous 2100
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**4350 MW**
Impacts Total Transfer Capability	750 MW
TTC with All Lines In Service	5100 MW

OSWEGO__-ELBRIDGE_345_17

Fri 05/19/2017 to Fri 05/19/2017
1630 Continuous 1700
Work scheduled by: NGrid

ARR: 75

	FWD (Import)
OSWEGO EXPORT	**5250 MW**
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	5250 MW

MILLWOOD-EASTVIEW_345_W82

Fri 05/19/2017 to Fri 05/19/2017
2030 Continuous 2100
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**4350 MW**
Impacts Total Transfer Capability	750 MW
TTC with All Lines In Service	5100 MW

SPRNBRK__345KV_RNS4

Fri 05/19/2017 to Fri 05/19/2017
2030 Continuous 2100
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3200 MW**
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

E13THSTA-FARRAGUT_345_45

Sat 05/20/2017 to Sun 05/21/2017
0001 Continuous 2359
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

W49TH_ST-E13THSTA_345_M54

Sat 05/20/2017 to Sun 05/21/2017
0001 Continuous 2359
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,May 07, 2017 to Tuesday ,November 06, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-WOOD_ST__345_F30

Sat 05/20/2017 to Mon 05/22/2017
2200 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**4000 MW**
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

PLSNTVLY_345KV_RNS5

Sat 05/20/2017 to Mon 05/22/2017
2200 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**3800 MW**
Impacts Total Transfer Capability	1300 MW
TTC with All Lines In Service	5100 MW

EASTVIEW-SPRNBRK__345_W64

Sun 05/21/2017 to Sun 05/21/2017
0001 Continuous 0030
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**4350 MW**
Impacts Total Transfer Capability	750 MW
TTC with All Lines In Service	5100 MW

SPRNBRK__345KV_RNS5

Sun 05/21/2017 to Sun 05/21/2017
0001 Continuous 0030
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3200 MW**
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

MILLWOOD-EASTVIEW_345_W99

Sun 05/21/2017 to Sun 05/21/2017
0001 Continuous 2130
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**4350 MW**
Impacts Total Transfer Capability	750 MW
TTC with All Lines In Service	5100 MW

EASTVIEW-SPRNBRK__345_W64

Sun 05/21/2017 to Sun 05/21/2017
2100 Continuous 2130
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**4350 MW**
Impacts Total Transfer Capability	750 MW
TTC with All Lines In Service	5100 MW

SPRNBRK__345KV_RNS5

Sun 05/21/2017 to Sun 05/21/2017
2100 Continuous 2130
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3200 MW**
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,May 07, 2017 to Tuesday ,November 06, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY____765_345_AT1

Mon 05/22/2017 to Fri 05/26/2017
0500 Continuous 1700
Work scheduled by: NYPA

ARR: 19

	FWD (Import)
MOSES SOUTH	**1750 MW**
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	3150 MW

BROWNFLS-TAYLORVL_115_3

Mon 05/22/2017 to Fri 05/26/2017
0600 Continuous 1900
Work scheduled by: NGrid

ARR: 38

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**70 MW**	**40 MW**
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

CHAT_DC_GC1

Tue 05/23/2017 to Wed 05/31/2017 **UPDATED** **by HQ** **04/13/2017**
0600 Continuous 2100
Work scheduled by: HQ

	FWD (Import)
MOSES SOUTH	**2850 MW**
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

CHAT_DC_GC1

Tue 05/23/2017 to Wed 05/31/2017 **UPDATED** **by HQ** **04/13/2017**
0600 Continuous 2100
Work scheduled by: HQ

	REV (Export)
SCH - HQ - NY	**500 MW**
Impacts Total Transfer Capability	500 MW
TTC with All Lines In Service	1000 MW

CEDARS__-ROSEMNTA_115_1/11

Tue 05/23/2017 to Thu 06/01/2017
0600 Continuous 1900
Work scheduled by: HQ

ARR: 38

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**95 MW**	**40 MW**
Impacts Total Transfer Capability	95 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

DENNISON-ROSEMNTA_115_1/11

Tue 05/23/2017 to Thu 06/01/2017
0600 Continuous 1900
Work scheduled by: HQ

ARR: 38

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**95 MW**	**40 MW**
Impacts Total Transfer Capability	95 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

SCH-HQ_CEDARS-NYISO_LIMIT_80

Tue 05/23/2017 to Thu 06/01/2017
0600 Continuous 1900
Work scheduled by: HQ

	FWD (Import)
SCH - HQ_CEDARS	**80 MW**
Impacts Total Transfer Capability	110 MW
TTC with All Lines In Service	190 MW

NYISO TRANSFER LIMITATIONS

Sunday ,May 07, 2017 to Tuesday ,November 06, 2018

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-N.SCTLND_345_18

Sat 05/27/2017 to Sat 05/27/2017
0500 Continuous 1530
Work scheduled by: NYPA

ARR: 19

	FWD (Import)
CENTRAL EAST - VC	**2090 MW**
Impacts Total Transfer Capability	885 MW
TTC with All Lines In Service	2975 MW

SCH-HQ-NYISO_LIMIT_1150

Sat 05/27/2017 to Sat 05/27/2017 **UPDATED** **by HQ** **04/13/2017**
0500 Continuous 1530
Work scheduled by: HQ

	FWD (Import)
SCH - HQ - NY	**1150 MW**
Impacts Total Transfer Capability	350 MW
TTC with All Lines In Service	1500 MW

ILCTLIMT_MARCY_SO_COMP_I/S

Sat 05/27/2017 to Mon 06/05/2017
1600 Continuous 0659
Work scheduled by: NYISO

	FWD (Import)
CENTRAL EAST - VC	**2740 MW**
Impacts Total Transfer Capability	235 MW
TTC with All Lines In Service	2975 MW

BROWNFLS-TAYLORVL_115_4

Tue 05/30/2017 to Fri 06/02/2017
0600 Continuous 1900
Work scheduled by: NGrid

ARR: 38

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**70 MW**	**40 MW**
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

BROWNFLS-TAYLORVL_115_4

Mon 06/05/2017 to Fri 06/09/2017
0600 Continuous 1900
Work scheduled by: NGrid

ARR: 38

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**70 MW**	**40 MW**
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

EDIC____-FRASER___345_EF24-40

Mon 06/05/2017 to Sat 06/10/2017
0700 Continuous 1659
Work scheduled by: NYSEG

	FWD (Import)
CENTRAL EAST - VC	**2500 MW**
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

STONYRDG-HILLSIDE_230_72

Mon 06/05/2017 to Mon 06/05/2017
0800 Continuous 1000
Work scheduled by: NYSEG

	FWD (Import)
DYSINGER EAST	**2850 MW**
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,May 07, 2017 to Tuesday ,November 06, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK____-PACKARD__230_BP76

Tue 06/06/2017 to Wed 06/07/2017 **UPDATED** **by NGRID** **04/27/2017**
0600 Continuous 1800
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
SCH - OH - NY	**900 MW**	**1150 MW**
Impacts Total Transfer Capability	850 MW	750 MW
TTC with All Lines In Service	1750 MW	1900 MW

LINDEN__-GOETHALS_230_A2253

Fri 06/09/2017 to Sun 06/11/2017 **UPDATED** **by CE** **04/04/2017**
0200 Continuous 2300
Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJ - NY	**2050 MW**	**1300 MW**
Impacts Total Transfer Capability	250 MW	150 MW
TTC with All Lines In Service	2300 MW	1450 MW

STONYRDG-HILLSIDE_230_72

Fri 06/09/2017 to Fri 06/09/2017
1500 Continuous 1700
Work scheduled by: NYSEG

	FWD (Import)
DYSINGER EAST	**2850 MW**
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

ILCTLIMT_MARCY_SO_COMP_I/S

Sat 06/10/2017 to Sat 08/05/2017
1700 Continuous 0459
Work scheduled by: NYISO

	FWD (Import)
CENTRAL EAST - VC	**2740 MW**
Impacts Total Transfer Capability	235 MW
TTC with All Lines In Service	2975 MW

BROWNFLS-TAYLORVL_115_4

Mon 06/12/2017 to Fri 06/16/2017
0600 Continuous 1900
Work scheduled by: NGrid **ARR: 38**

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**70 MW**	**40 MW**
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

BROWNFLS-TAYLORVL_115_4

Mon 06/19/2017 to Fri 06/23/2017
0600 Continuous 1900
Work scheduled by: NGrid **ARR: 38**

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**70 MW**	**40 MW**
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

BROWNFLS-TAYLORVL_115_3

Mon 06/26/2017 to Fri 06/30/2017
0600 Continuous 1900
Work scheduled by: NGrid **ARR: 38**

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**70 MW**	**40 MW**
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

NYISO TRANSFER LIMITATIONS

Sunday ,May 07, 2017 to Tuesday ,November 06, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BROWNFLS-TAYLORVL_115_3

Wed 07/05/2017 to Fri 07/07/2017 **UPDATED** **by NGRID** **03/02/2017**
0600 Continuous 1900
Work scheduled by: NGrid
ARR: 38

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**70 MW**	**40 MW**
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

BROWNFLS-TAYLORVL_115_3

Mon 07/10/2017 to Fri 07/14/2017 **UPDATED** **by NGRID** **03/02/2017**
0600 Continuous 1900
Work scheduled by: NGrid
ARR: 38

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**70 MW**	**40 MW**
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

BROWNFLS-TAYLORVL_115_3

Mon 07/17/2017 to Fri 07/21/2017 **UPDATED** **by NGRID** **03/02/2017**
0600 Continuous 1900
Work scheduled by: NGrid
ARR: 38

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**70 MW**	**40 MW**
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

BROWNFLS-TAYLORVL_115_4

Mon 07/24/2017 to Fri 07/28/2017
0600 Continuous 1900
Work scheduled by: NGrid
ARR: 38

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**70 MW**	**40 MW**
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

MARCY___-N.SCTLND_345_18

Sat 08/05/2017 to Sat 08/05/2017
0500 Continuous 1530
Work scheduled by: NYPA
ARR: 19

	FWD (Import)
CENTRAL EAST - VC	**2090 MW**
Impacts Total Transfer Capability	885 MW
TTC with All Lines In Service	2975 MW

MARCY____765_345_AT2

Sat 08/05/2017 to Sat 08/05/2017
0500 Continuous 1530
Work scheduled by: NYPA
ARR: 19

	FWD (Import)
MOSES SOUTH	**1700 MW**
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

ILCTLIMT_MARCY_SO_COMP_I/S

Sat 08/05/2017 to Mon 10/02/2017
1600 Continuous 0659
Work scheduled by: NYISO

	FWD (Import)
CENTRAL EAST - VC	**2740 MW**
Impacts Total Transfer Capability	235 MW
TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,May 07, 2017 to Tuesday ,November 06, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY____765_345_AT2

Tue 09/05/2017 to Sun 09/10/2017
0500 Continuous 1630
Work scheduled by: NYPA

ARR: 19

	FWD (Import)
MOSES SOUTH	**1700 MW**
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

MOSES___-ADIRNDCK_230_MA1

Mon 09/11/2017 to Sat 09/16/2017
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2100 MW**
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

HURLYAVE-ROSETON__345_303

Mon 09/11/2017 to Fri 09/29/2017
0800 Continuous 1600
Work scheduled by: CHGE

	FWD (Import)
UPNY CONED	**4100 MW**
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

DUNWODIE_345KV_5

Fri 09/15/2017 to Sun 09/17/2017
2200 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

DUNWODIE_345KV_7

Fri 09/15/2017 to Sun 09/17/2017
2200 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

SPRNBRK_-DUNWODIE_345_W75

Fri 09/15/2017 to Sun 09/17/2017
2200 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

SPRNBRK__345KV_RNS3

Fri 09/15/2017 to Sun 09/17/2017
2200 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,May 07, 2017 to Tuesday ,November 06, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GILBOA__-N.SCTLND_345_GNS-1

Mon 09/18/2017 to Fri 10/06/2017
0630 Continuous 1700
Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	**2520 MW**
Impacts Total Transfer Capability	455 MW
TTC with All Lines In Service	2975 MW

NIAGARA__345_230_AT4

Mon 09/18/2017 to Tue 09/19/2017
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	**1750 MW**	**1300 MW**
Impacts Total Transfer Capability	0 MW	600 MW
TTC with All Lines In Service	1750 MW	1900 MW

MOSES___-ADIRNDCK_230_MA1

Mon 09/18/2017 to Sat 09/23/2017
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2100 MW**
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

MOSES___-ADIRNDCK_230_MA1

Mon 09/25/2017 to Sat 09/30/2017
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2100 MW**
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

NIAGARA_-ROCHESTR_345_NR2

Mon 10/02/2017 to Fri 10/06/2017
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
DYSINGER EAST	**1700 MW**
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

FRASER__-COOPERS__345_33

Mon 10/02/2017 to Fri 10/13/2017
0700 Continuous 1900
Work scheduled by: NYSEG

	FWD (Import)
CENTRAL EAST - VC	**2395 MW**
Impacts Total Transfer Capability	580 MW
TTC with All Lines In Service	2975 MW

WETHSRFD-MEYER____230_85/87

Mon 10/09/2017 to Fri 10/20/2017
0700 Continuous 1400
Work scheduled by: NYSEG

	FWD (Import)
DYSINGER EAST	**2850 MW**
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,May 07, 2017 to Tuesday ,November 06, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EGRDNCTY_345_138_AT1

Fri 10/13/2017 to Fri 11/17/2017
0001 Continuous 2359
Work scheduled by: LI

	FWD (Import)
CONED - LIPA	**1250 MW**
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	1500 MW

EGRDNCTY_345_138_AT2

Fri 10/13/2017 to Fri 11/17/2017
0001 Continuous 2359
Work scheduled by: LI

	FWD (Import)
CONED - LIPA	**1250 MW**
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	1500 MW

SPRNBRK_-EGRDNCTR_345_Y49

Fri 10/13/2017 to Fri 11/17/2017
0001 Continuous 2359
Work scheduled by: LI

	FWD (Import)
CONED - LIPA	**775 MW**
Impacts Total Transfer Capability	725 MW
TTC with All Lines In Service	1500 MW

ILCTLIMT_MARCY_SO_COMP_I/S

Fri 10/13/2017 to Mon 11/06/2017
1900 Continuous 0559
Work scheduled by: NYISO

	FWD (Import)
CENTRAL EAST - VC	**2740 MW**
Impacts Total Transfer Capability	235 MW
TTC with All Lines In Service	2975 MW

CHATGUAY-MASSENA__765_7040

Sat 10/14/2017 to Sat 10/28/2017 **UPDATED** **by NYISO** **03/24/2017**
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**1550 MW**
Impacts Total Transfer Capability	1600 MW
TTC with All Lines In Service	3150 MW

CHATGUAY-MASSENA__765_7040

Sat 10/14/2017 to Sat 10/28/2017 **UPDATED** **by NYISO** **03/24/2017**
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ - NY	**0 MW**	**0 MW**
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

MARCY____765_345_AT1

Sat 10/14/2017 to Sat 10/28/2017 **UPDATED** **by NYISO** **03/24/2017**
0700 Continuous 1530
Work scheduled by: NYPA

ARR: 19

	FWD (Import)
MOSES SOUTH	**1750 MW**
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,May 07, 2017 to Tuesday ,November 06, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY____765_345_AT2

Sat 10/14/2017 to Sat 10/28/2017 **UPDATED** **by NYISO** **03/24/2017**
0700 Continuous 1530
Work scheduled by: NYPA

ARR: 19

	FWD (Import)
MOSES SOUTH	**1700 MW**
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

MASSENA_-MARCY____765_MSU1

Sat 10/14/2017 to Sat 10/28/2017 **UPDATED** **by NYISO** **03/24/2017**
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	**2265 MW**
Impacts Total Transfer Capability	710 MW
TTC with All Lines In Service	2975 MW

MASSENA_-MARCY____765_MSU1

Sat 10/14/2017 to Sat 10/28/2017 **UPDATED** **by NYISO** **03/24/2017**
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**500 MW**
Impacts Total Transfer Capability	2650 MW
TTC with All Lines In Service	3150 MW

MASSENA_-MARCY____765_MSU1

Sat 10/14/2017 to Sat 10/28/2017 **UPDATED** **by NYISO** **03/24/2017**
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ - NY	**475 MW**	**1000 MW**
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

MASSENA_-MARCY____765_MSU1 & CHATGUAY-MASSENA__765_7040

Sat 10/14/2017 to Sat 10/28/2017
0700 1530
Work scheduled by:

	FWD (Import)
MOSES SOUTH	**500 MW**
Impacts Total Transfer Capability	2650 MW
TTC with All Lines In Service	3150 MW

MASSENA_-MARCY____765_MSU1 & ILCTLIMT_MARCY_SO_COMP_I/S

Sat 10/14/2017 to Sat 10/28/2017
0700 1530
Work scheduled by:

	FWD (Import)
CENTRAL EAST - VC	**2080 MW**
Impacts Total Transfer Capability	895 MW
TTC with All Lines In Service	2975 MW

MOSES___-MASSENA__230_MMS1 & MOSES___-MASSENA__230_MMS2

Sat 10/14/2017 to Sat 10/28/2017
0700 1530
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ - NY	**850 MW**	**0 MW**
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

NYISO TRANSFER LIMITATIONS

Sunday ,May 07, 2017 to Tuesday ,November 06, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS___-HURLYAVE_345_301

Mon 10/16/2017 to Fri 11/03/2017
0800 Continuous 1600
Work scheduled by: CHGE

	FWD (Import)
UPNY CONED	**4100 MW**
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

MOSES___-ADIRNDCK_230_MA2

Mon 10/30/2017 to Fri 11/03/2017
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2100 MW**
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

FRASANNX-COOPERS__345_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017
0600 Continuous 1700
Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	**2500 MW**
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

MARCY___-FRASANNX_345_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017
0600 Continuous 1700
Work scheduled by: NYPA

ARR: 19

	FWD (Import)
CENTRAL EAST - VC	**2500 MW**
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/06/2017 to Thu 11/09/2017
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2300 MW**
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

LINDN_CG-LNDVFT___345_V-3022

Mon 11/06/2017 to Thu 11/09/2017
0800 Continuous 1500
Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJM_VFT	**0 MW**	**0 MW**
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/13/2017 to Fri 11/17/2017
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2300 MW**
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,May 07, 2017 to Tuesday ,November 06, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ILCTLIMT_MARCY_SO_COMP_I/S

Fri 11/17/2017 to Sat 02/01/2020
1700 Continuous 0000
Work scheduled by: NYISO

	FWD (Import)
CENTRAL EAST - VC	**2740 MW**
Impacts Total Transfer Capability	235 MW
TTC with All Lines In Service	2975 MW

MOSES___-ADIRNDCK_230_MA1

Mon 11/20/2017 to Wed 11/22/2017
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2300 MW**
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

MOSES___-ADIRNDCK_230_MA1

Mon 11/27/2017 to Fri 12/01/2017
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2300 MW**
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

MARCY____765_345_AT2

Mon 12/04/2017 to Fri 12/08/2017
0500 Continuous 1630
Work scheduled by: NYPA **ARR: 19**

	FWD (Import)
MOSES SOUTH	**1700 MW**
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/11/2017 to Fri 12/15/2017
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2300 MW**
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/18/2017 to Fri 12/22/2017 **UPDATED** **by NYPA** **10/23/2016**
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2300 MW**
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

MARCY____765_345_AT2

Wed 12/27/2017 to Thu 12/28/2017
0500 Continuous 1630
Work scheduled by: NYPA **ARR: 19**

	FWD (Import)
MOSES SOUTH	**1700 MW**
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW