# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**RAMAPO___345_345_PAR3500**

Fri 06/24/2016 to Thu 09/14/2017 **UPDATED** **by CONED** **09/13/2017**
1940 Continuous 2359
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **1650 MW** | **1250 MW** |
| Impacts Total Transfer Capability | 450 MW | 100 MW |
| TTC with All Lines In Service | 2100 MW | 1350 MW |

---

**HUDSONTP-W49TH_ST_345_Y56**

Thu 11/24/2016 to Sat 09/30/2017 **UPDATED** **by PJM** **05/18/2017**
1500 Continuous 2359
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SCH - PJM_HTP | **0 MW** |
| Impacts Total Transfer Capability | 660 MW |
| TTC with All Lines In Service | 660 MW |

---

**S.RIPLEY-DUNKIRK__230_68 & RAMAPO___345_345_PAR3500**

Tue 05/02/2017 to Thu 09/14/2017
1710 2359
Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **1450 MW** | **1250 MW** |
| Impacts Total Transfer Capability | 650 MW | 100 MW |
| TTC with All Lines In Service | 2100 MW | 1350 MW |

---

**S.RIPLEY-DUNKIRK__230_68**

Tue 05/02/2017 to Mon 10/23/2017 **UPDATED** **by NYISO** **05/17/2017**
1710 Continuous 0759
Work scheduled by: NYISO

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **1950 MW** | **1350 MW** |
| Impacts Total Transfer Capability | 150 MW | 0 MW |
| TTC with All Lines In Service | 2100 MW | 1350 MW |

---

**SCH-NYISO-HQ_LIMIT_800**

Thu 06/08/2017 to Fri 12/15/2017 **UPDATED** **by HQ** **08/03/2017**
0600 Continuous 1700
Work scheduled by: HQ

| | REV (Export) |
|---|---|
| SCH - HQ - NY | **800 MW** |
| Impacts Total Transfer Capability | 200 MW |
| TTC with All Lines In Service | 1000 MW |

---

**SCH-HQ-NYISO_LIMIT_1450**

Tue 08/01/2017 to Fri 12/15/2017
2100 Continuous 1600
Work scheduled by: HQ

| | FWD (Import) |
|---|---|
| SCH - HQ - NY | **1450 MW** |
| Impacts Total Transfer Capability | 50 MW |
| TTC with All Lines In Service | 1500 MW |

---

**HOPATCON-RAMAPO___500_5018**

Tue 08/29/2017 to Thu 09/14/2017 **UPDATED** **by CE** **09/14/2017**
0001 Continuous 2359
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **1150 MW** | **1000 MW** |
| Impacts Total Transfer Capability | 950 MW | 350 MW |
| TTC with All Lines In Service | 2100 MW | 1350 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**HOPATCON-RAMAPO___500_5018**

Tue 08/29/2017 to Thu 09/14/2017 **UPDATED** **by CE** **09/14/2017**
0001 Continuous 2359
Work scheduled by: ConEd

TOTAL EAST
Impacts Total Transfer Capability
TTC with All Lines In Service

---

**HOPATCON-RAMAPO___500_5018**

Tue 08/29/2017 to Thu 09/14/2017 **UPDATED** **by CE** **09/14/2017**
0001 Continuous 2359
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **5000 MW** |
| Impacts Total Transfer Capability | 100 MW |
| TTC with All Lines In Service | 5100 MW |

---

**HOPATCON-RAMAPO___500_5018 & S.RIPLEY-DUNKIRK__230_68**

Tue 08/29/2017 to Thu 09/14/2017
0001 2359
Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **1200 MW** | **1300 MW** |
| Impacts Total Transfer Capability | 900 MW | 50 MW |
| TTC with All Lines In Service | 2100 MW | 1350 MW |

---

**RAMAPO___345_345_PAR4500**

Tue 08/29/2017 to Thu 09/14/2017 **UPDATED** **by CE** **09/14/2017**
0001 Continuous 2359
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **1650 MW** | **1250 MW** |
| Impacts Total Transfer Capability | 450 MW | 100 MW |
| TTC with All Lines In Service | 2100 MW | 1350 MW |

---

**RAMAPO___500_345_BK 1500**

Tue 08/29/2017 to Thu 09/14/2017 **UPDATED** **by CE** **09/14/2017**
0001 Continuous 2359
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **1900 MW** | **1000 MW** |
| Impacts Total Transfer Capability | 200 MW | 350 MW |
| TTC with All Lines In Service | 2100 MW | 1350 MW |

---

**RAMAPO___500_345_BK 1500**

Tue 08/29/2017 to Thu 09/14/2017 **UPDATED** **by CE** **09/14/2017**
0001 Continuous 2359
Work scheduled by: ConEd

TOTAL EAST
Impacts Total Transfer Capability
TTC with All Lines In Service

---

**RAMAPO___500_345_BK 1500**

Tue 08/29/2017 to Thu 09/14/2017 **UPDATED** **by CE** **09/14/2017**
0001 Continuous 2359
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **5000 MW** |
| Impacts Total Transfer Capability | 100 MW |
| TTC with All Lines In Service | 5100 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**S.RIPLEY-DUNKIRK__230_68 & RAMAPO___345_345_PAR4500**

Tue 08/29/2017 to Thu 09/14/2017
0001 2359
Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **1450 MW** | **1250 MW** |
| Impacts Total Transfer Capability | 650 MW | 100 MW |
| TTC with All Lines In Service | 2100 MW | 1350 MW |

---

**SCH-IMO-NYISO_LIMIT_1450**

Tue 08/29/2017 to Tue 10/31/2017 **EXTENDED** **by NYISO** **07/28/2017**
1230 Continuous 2359
Work scheduled by: NYISO

| | FWD (Import) |
|---|---|
| SCH - OH - NY | **1750 MW** |
| Impacts Total Transfer Capability | 250 MW |
| TTC with All Lines In Service | 2000 MW |

---

**SCH-IMO-NYISO_LIMIT_1150**

Sat 09/09/2017 to Fri 10/06/2017 **UPDATED** **by NYISO** **08/30/2017**
0500 Continuous 1700
Work scheduled by: NGrid

| | FWD (Import) |
|---|---|
| SCH - OH - NY | **1450 MW** |
| Impacts Total Transfer Capability | 550 MW |
| TTC with All Lines In Service | 2000 MW |

---

**MOSES___-ADIRNDCK_230_MA1**

Mon 09/11/2017 to Sat 09/16/2017 **EXTENDED** **by NYPA** **08/14/2017**
0700 Continuous 1730
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2100 MW** |
| Impacts Total Transfer Capability | 1050 MW |
| TTC with All Lines In Service | 3150 MW |

---

**MARCY_SO_SERIES_COMP_I/S**

Mon 09/11/2017 to Sat 09/16/2017 **UPDATED** **by NYPA** **09/07/2017**
0846 Continuous 0759
Work scheduled by: NYISO

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2740 MW** |
| Impacts Total Transfer Capability | 235 MW |
| TTC with All Lines In Service | 2975 MW |

---

**NEPTUNE_-DUFFYAVE_345_NEPTUNE**

Tue 09/12/2017 to Wed 09/13/2017 **UPDATED** **by LI** **08/29/2017**
0001 Continuous 2359
Work scheduled by: LI

| | FWD (Import) |
|---|---|
| SCH - PJM_NEPTUNE | **0 MW** |
| Impacts Total Transfer Capability | 660 MW |
| TTC with All Lines In Service | 660 MW |

---

**NEWBRDGE-DUFFYAVE_345_501**

Tue 09/12/2017 to Wed 09/13/2017 **UPDATED** **by LI** **08/29/2017**
0001 Continuous 2359
Work scheduled by: LI

| | FWD (Import) |
|---|---|
| SCH - PJM_NEPTUNE | **0 MW** |
| Impacts Total Transfer Capability | 660 MW |
| TTC with All Lines In Service | 660 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**NEWBRDGE_345_138_BK_1**

Tue 09/12/2017 to Wed 09/13/2017 **UPDATED** **by LI** **08/29/2017**
0001 Continuous 2359
Work scheduled by: LI

| | FWD (Import) |
|---|---|
| SCH - PJM_NEPTUNE | **375 MW** |
| Impacts Total Transfer Capability | 285 MW |
| TTC with All Lines In Service | 660 MW |

---

**NEWBRDGE_345_138_BK_2**

Tue 09/12/2017 to Wed 09/13/2017 **UPDATED** **by LI** **08/29/2017**
0001 Continuous 2359
Work scheduled by: LI

| | FWD (Import) |
|---|---|
| SCH - PJM_NEPTUNE | **375 MW** |
| Impacts Total Transfer Capability | 285 MW |
| TTC with All Lines In Service | 660 MW |

---

**STONYRDG-HILLSIDE_230_72**

Wed 09/13/2017 to Wed 09/13/2017
0800 Continuous 1600
Work scheduled by: NYSEG

| | FWD (Import) |
|---|---|
| DYSINGER EAST | **2850 MW** |
| Impacts Total Transfer Capability | 300 MW |
| TTC with All Lines In Service | 3150 MW |

---

**SCH-NE-NYISO_LIMIT_1000**

Thu 09/14/2017 to Fri 09/15/2017 **UPDATED** **by ISONE** **09/12/2017**
0100 Continuous 1800
Work scheduled by: ISONE

| | FWD (Import) |
|---|---|
| SCH - NE - NY | **1200 MW** |
| Impacts Total Transfer Capability | 200 MW |
| TTC with All Lines In Service | 1400 MW |

---

**HOPATCON-RAMAPO___500_5018**

Fri 09/15/2017 to Fri 09/15/2017 **CANCELLED** **by ConEd** **09/14/2017**
0001 Continuous 0100
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **1150 MW** | **1000 MW** |
| Impacts Total Transfer Capability | 950 MW | 350 MW |
| TTC with All Lines In Service | 2100 MW | 1350 MW |

---

**HOPATCON-RAMAPO___500_5018**

Fri 09/15/2017 to Fri 09/15/2017 **CANCELLED** **by ConEd** **09/14/2017**
0001 Continuous 0100
Work scheduled by: ConEd

TOTAL EAST
Impacts Total Transfer Capability
TTC with All Lines In Service

---

**HOPATCON-RAMAPO___500_5018**

Fri 09/15/2017 to Fri 09/15/2017 **CANCELLED** **by ConEd** **09/14/2017**
0001 Continuous 0100
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **5000 MW** |
| Impacts Total Transfer Capability | 100 MW |
| TTC with All Lines In Service | 5100 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**RAMAPO___345_345_PAR4500**

Fri 09/15/2017 to Fri 09/15/2017 **CANCELLED** **by ConEd** **09/14/2017**
0001 Continuous 0100
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **1650 MW** | **1250 MW** |
| Impacts Total Transfer Capability | 450 MW | 100 MW |
| TTC with All Lines In Service | 2100 MW | 1350 MW |

---

**RAMAPO___500_345_BK 1500**

Fri 09/15/2017 to Fri 09/15/2017 **CANCELLED** **by ConEd** **09/14/2017**
0001 Continuous 0100
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **1900 MW** | **1000 MW** |
| Impacts Total Transfer Capability | 200 MW | 350 MW |
| TTC with All Lines In Service | 2100 MW | 1350 MW |

---

**RAMAPO___500_345_BK 1500**

Fri 09/15/2017 to Fri 09/15/2017 **CANCELLED** **by ConEd** **09/14/2017**
0001 Continuous 0100
Work scheduled by: ConEd

TOTAL EAST
Impacts Total Transfer Capability
TTC with All Lines In Service

---

**RAMAPO___500_345_BK 1500**

Fri 09/15/2017 to Fri 09/15/2017 **CANCELLED** **by ConEd** **09/14/2017**
0001 Continuous 0100
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **5000 MW** |
| Impacts Total Transfer Capability | 100 MW |
| TTC with All Lines In Service | 5100 MW |

---

**SPRNBRK__345KV_RNS5**

Sat 09/16/2017 to Sat 09/16/2017 **UPDATED** **by CONED** **09/11/2017**
0001 Continuous 1830
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SPR/DUN-SOUTH | **3200 MW** |
| Impacts Total Transfer Capability | 1400 MW |
| TTC with All Lines In Service | 4600 MW |

---

**SPRNBRK_-W49TH_ST_345_M51**

Sat 09/16/2017 to Fri 09/22/2017 **UPDATED** **by CONED** **09/11/2017**
0001 Continuous 0300
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SPR/DUN-SOUTH | **3200 MW** |
| Impacts Total Transfer Capability | 1400 MW |
| TTC with All Lines In Service | 4600 MW |

---

**SCH-IMO-NYISO_LIMIT_1050**

Sat 09/16/2017 to Sat 09/16/2017 **UPDATED** **by NGRID** **09/13/2017**
0700 Continuous 1730
Work scheduled by: NGrid

| | FWD (Import) |
|---|---|
| SCH - OH - NY | **1350 MW** |
| Impacts Total Transfer Capability | 650 MW |
| TTC with All Lines In Service | 2000 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MARCY___-N.SCTLND_345_18**

Sat 09/16/2017 to Sun 09/17/2017
0800 Continuous 1700
Work scheduled by: NGrid

**ARR: 19**

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2090 MW** |
| Impacts Total Transfer Capability | 885 MW |
| TTC with All Lines In Service | 2975 MW |

**CHAT_DC_GC1**

Sun 09/17/2017 to Sun 09/17/2017
0001 Continuous 0200
Work scheduled by: HQ

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2850 MW** |
| Impacts Total Transfer Capability | 300 MW |
| TTC with All Lines In Service | 3150 MW |

**CHAT_DC_GC1**

Sun 09/17/2017 to Sun 09/17/2017
0001 Continuous 0200
Work scheduled by: HQ

| | REV (Export) |
|---|---|
| SCH - HQ - NY | **500 MW** |
| Impacts Total Transfer Capability | 500 MW |
| TTC with All Lines In Service | 1000 MW |

**CHAT_DC_GC1 & CHAT_DC_GC2**

Sun 09/17/2017 to Sun 09/17/2017
0001 0200
Work scheduled by:

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2550 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 3150 MW |

**CHAT_DC_GC1 & CHAT_DC_GC2**

Sun 09/17/2017 to Sun 09/17/2017
0001 0200
Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ - NY | **1370 MW** | **0 MW** |
| Impacts Total Transfer Capability | 130 MW | 1000 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

**CHAT_DC_GC2**

Sun 09/17/2017 to Sun 09/17/2017
0001 Continuous 0200
Work scheduled by: HQ

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2850 MW** |
| Impacts Total Transfer Capability | 300 MW |
| TTC with All Lines In Service | 3150 MW |

**CHAT_DC_GC2**

Sun 09/17/2017 to Sun 09/17/2017
0001 Continuous 0200
Work scheduled by: HQ

| | REV (Export) |
|---|---|
| SCH - HQ - NY | **500 MW** |
| Impacts Total Transfer Capability | 500 MW |
| TTC with All Lines In Service | 1000 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**SCH-HQ-NYISO_LIMIT_700**

Sun 09/17/2017 to Sun 09/17/2017
0001 Continuous 0200
Work scheduled by: HQ

| | FWD (Import) |
|---|---|
| SCH - HQ - NY | **700 MW** |
| Impacts Total Transfer Capability | 800 MW |
| TTC with All Lines In Service | 1500 MW |

---

**MARCY_SO_SERIES_COMP_I/S**

Sun 09/17/2017 to Mon 10/02/2017
1700 Continuous 0659
Work scheduled by: NYISO

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2740 MW** |
| Impacts Total Transfer Capability | 235 MW |
| TTC with All Lines In Service | 2975 MW |

---

**NIAGARA__345_230_AT4**

Mon 09/18/2017 to Fri 09/22/2017
0500 Continuous 1900
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | **2000 MW** | **1400 MW** |
| Impacts Total Transfer Capability | 0 MW | 200 MW |
| TTC with All Lines In Service | 2000 MW | 1600 MW |

---

**GILBOA__-N.SCTLND_345_GNS-1**

Mon 09/18/2017 to Fri 10/13/2017 **EXTENDED** **by NYPA** **06/09/2017**
0630 Continuous 1700
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2520 MW** |
| Impacts Total Transfer Capability | 455 MW |
| TTC with All Lines In Service | 2975 MW |

---

**MOSES___-ADIRNDCK_230_MA1**

Mon 09/18/2017 to Sat 09/23/2017 **UPDATED** **by NYPA** **08/15/2017**
0700 Continuous 1730
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2100 MW** |
| Impacts Total Transfer Capability | 1050 MW |
| TTC with All Lines In Service | 3150 MW |

---

**ROCHESTR-PANNELL__345_RP1**

Mon 09/18/2017 to Sat 09/23/2017 **UPDATED** **by PA** **09/05/2017**
0730 Continuous 1530
Work scheduled by: RGE

| | FWD (Import) |
|---|---|
| DYSINGER EAST | **2300 MW** |
| Impacts Total Transfer Capability | 850 MW |
| TTC with All Lines In Service | 3150 MW |

---

**ALCOA_R8105_TIE_B**

Mon 09/18/2017 to Mon 09/25/2017
0800 Continuous 1500
Work scheduled by: NGrid

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **3100 MW** |
| Impacts Total Transfer Capability | 50 MW |
| TTC with All Lines In Service | 3150 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**ALCOA_R8105_TIE_B**

Mon 09/18/2017 to Mon 09/25/2017
0800 Continuous 1500
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ_CEDARS | **70 MW** | **0 MW** |
| Impacts Total Transfer Capability | 120 MW | 40 MW |
| TTC with All Lines In Service | 190 MW | 40 MW |

**SCH-HQ_CEDARS-NYISO_LIMIT_140**

Mon 09/18/2017 to Fri 09/29/2017
0800 Continuous 1700
Work scheduled by: HQ

| | FWD (Import) |
|---|---|
| SCH - HQ_CEDARS | **140 MW** |
| Impacts Total Transfer Capability | 50 MW |
| TTC with All Lines In Service | 190 MW |

**SCH-NYISO-HQ_CEDARS_LIMIT_0**

Mon 09/18/2017 to Fri 09/29/2017
0800 Continuous 1700
Work scheduled by: HQ

| | REV (Export) |
|---|---|
| SCH - HQ_CEDARS | **0 MW** |
| Impacts Total Transfer Capability | 40 MW |
| TTC with All Lines In Service | 40 MW |

**PLSNTVLY_345KV_RNS5**

Tue 09/19/2017 to Tue 09/19/2017 **UPDATED** **by CONED** **08/10/2017**
0001 Continuous 0100
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **3800 MW** |
| Impacts Total Transfer Capability | 1300 MW |
| TTC with All Lines In Service | 5100 MW |

**PLSNTVLY-WOOD_ST__345_F30**

Tue 09/19/2017 to Wed 09/20/2017 **UPDATED** **by CONED** **08/10/2017**
0001 Continuous 2359
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **4000 MW** |
| Impacts Total Transfer Capability | 1100 MW |
| TTC with All Lines In Service | 5100 MW |

**LINDEN__-GOETHALS_230_A2253**

Tue 09/19/2017 to Sun 10/01/2017 **EXTENDED** **by PJM** **07/28/2017**
0200 Continuous 0100
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **2100 MW** | **1350 MW** |
| Impacts Total Transfer Capability | 0 MW | 0 MW |
| TTC with All Lines In Service | 2100 MW | 1350 MW |

**HURLYAVE-ROSETON__345_303**

Wed 09/20/2017 to Fri 09/29/2017 **UPDATED** **by CHGE** **09/13/2017**
0800 Continuous 1600
Work scheduled by: CHGE

| | FWD (Import) |
|---|---|
| UPNY CONED | **4100 MW** |
| Impacts Total Transfer Capability | 1000 MW |
| TTC with All Lines In Service | 5100 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**PLSNTVLY_345KV_RNS5**

Wed 09/20/2017 to Wed 09/20/2017 **UPDATED** **by CONED** **08/10/2017**
2330 Continuous 2359
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **3800 MW** |
| Impacts Total Transfer Capability | 1300 MW |
| TTC with All Lines In Service | 5100 MW |

---

**SPRNBRK__345KV_RNS5**

Fri 09/22/2017 to Fri 09/22/2017 **UPDATED** **by CONED** **09/11/2017**
0230 Continuous 0300
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SPR/DUN-SOUTH | **3200 MW** |
| Impacts Total Transfer Capability | 1400 MW |
| TTC with All Lines In Service | 4600 MW |

---

**CEDARS__-ROSEMNTB_115_2/22**

Mon 09/25/2017 to Mon 09/25/2017 **by HQ** **09/14/2017**
0530 Continuous 1900
Work scheduled by: HQ

**ARR: 38**

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ_CEDARS | **95 MW** | **40 MW** |
| Impacts Total Transfer Capability | 95 MW | 0 MW |
| TTC with All Lines In Service | 190 MW | 40 MW |

---

**SCH-HQ_CEDARS-NYISO_LIMIT_80**

Mon 09/25/2017 to Mon 09/25/2017 **by HQ** **09/14/2017**
0530 Continuous 1900
Work scheduled by: HQ

| | FWD (Import) |
|---|---|
| SCH - HQ_CEDARS | **80 MW** |
| Impacts Total Transfer Capability | 110 MW |
| TTC with All Lines In Service | 190 MW |

---

**SCH-IMO_NY_NIAG_SOUTH_BUS_W/BB**

Mon 09/25/2017 to Fri 09/29/2017 **UPDATED** **by NYISO** **08/22/2017**
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | **1000 MW** | **1150 MW** |
| Impacts Total Transfer Capability | 1000 MW | 450 MW |
| TTC with All Lines In Service | 2000 MW | 1600 MW |

---

**MOSES___-ADIRNDCK_230_MA1**

Mon 09/25/2017 to Sat 09/30/2017 **UPDATED** **by NYPA** **08/15/2017**
0700 Continuous 1730
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2100 MW** |
| Impacts Total Transfer Capability | 1050 MW |
| TTC with All Lines In Service | 3150 MW |

---

**LEEDS____345KV_R395**

Mon 09/25/2017 to Mon 09/25/2017
0800 Daily(No Weekends) 1400
Work scheduled by: NGrid

| | FWD (Import) |
|---|---|
| UPNY CONED | **3800 MW** |
| Impacts Total Transfer Capability | 1300 MW |
| TTC with All Lines In Service | 5100 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**FIVEMILE-STOLLERD_345_29**

Mon 09/25/2017 to Mon 10/16/2017
0800 Continuous 1400
Work scheduled by: NYSEG

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **2100 MW** | **1350 MW** |
| Impacts Total Transfer Capability | 0 MW | 0 MW |
| TTC with All Lines In Service | 2100 MW | 1350 MW |

**SPRNBRK__345KV_RNS3**

Tue 09/26/2017 to Sat 09/30/2017
0001 Continuous 2130
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SPR/DUN-SOUTH | **3800 MW** |
| Impacts Total Transfer Capability | 800 MW |
| TTC with All Lines In Service | 4600 MW |

**PANNELL_-CLAY_____345_2**

Tue 09/26/2017 to Wed 09/27/2017
0730 Continuous 1500
Work scheduled by: RGE

| | FWD (Import) |
|---|---|
| WEST CENTRAL | **1300 MW** |
| Impacts Total Transfer Capability | 950 MW |
| TTC with All Lines In Service | 2250 MW |

**E13THSTA-FARRAGUT_345_46**

Wed 09/27/2017 to Wed 09/27/2017
0001 Continuous 0030
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SPR/DUN-SOUTH | **3800 MW** |
| Impacts Total Transfer Capability | 800 MW |
| TTC with All Lines In Service | 4600 MW |

**SCH-NYISO-NE_LIMIT_800**

Wed 09/27/2017 to Wed 09/27/2017
0600 Continuous 1600
Work scheduled by: ISONE

| | REV (Export) |
|---|---|
| SCH - NE - NY | **1000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 1600 MW |

**SPRNBRK__345KV_RS3 & SPRNBRK__345KV_RS4**

Sun 10/01/2017 to Tue 10/03/2017
0001 0300
Work scheduled by:

| | FWD (Import) |
|---|---|
| SPR/DUN-SOUTH | **3200 MW** |
| Impacts Total Transfer Capability | 1400 MW |
| TTC with All Lines In Service | 4600 MW |

**SPRNBRK__345KV_RNS4**

Mon 10/02/2017 to Mon 10/02/2017
0001 Continuous 1900
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SPR/DUN-SOUTH | **3200 MW** |
| Impacts Total Transfer Capability | 1400 MW |
| TTC with All Lines In Service | 4600 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**W49TH_ST_345KV_5**

Mon 10/02/2017 to Tue 10/03/2017
0001 Continuous 0300
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SCH - PJM_HTP | **315 MW** |
| Impacts Total Transfer Capability | 345 MW |
| TTC with All Lines In Service | 660 MW |

**PLSNTVLY-EFISHKIL_345_F36**

Mon 10/02/2017 to Mon 10/16/2017
0001 Continuous 0300
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **4000 MW** |
| Impacts Total Transfer Capability | 1100 MW |
| TTC with All Lines In Service | 5100 MW |

**SPRNBRK_-W49TH_ST_345_M52**

Mon 10/02/2017 to Wed 11/01/2017
0001 Continuous 0300
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SPR/DUN-SOUTH | **3200 MW** |
| Impacts Total Transfer Capability | 1400 MW |
| TTC with All Lines In Service | 4600 MW |

**CHAT_DC_GC2**

Mon 10/02/2017 to Wed 11/15/2017
0500 Continuous 2000
Work scheduled by: HQ

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2850 MW** |
| Impacts Total Transfer Capability | 300 MW |
| TTC with All Lines In Service | 3150 MW |

**CHAT_DC_GC2**

Mon 10/02/2017 to Wed 11/15/2017
0500 Continuous 2000
Work scheduled by: HQ

| | REV (Export) |
|---|---|
| SCH - HQ - NY | **500 MW** |
| Impacts Total Transfer Capability | 500 MW |
| TTC with All Lines In Service | 1000 MW |

**SCH-HQ-NYISO_LIMIT_1150**

Mon 10/02/2017 to Wed 11/15/2017
0500 Continuous 2000
Work scheduled by: HQ

| | FWD (Import) |
|---|---|
| SCH - HQ - NY | **1150 MW** |
| Impacts Total Transfer Capability | 350 MW |
| TTC with All Lines In Service | 1500 MW |

**SHOR_NPX-SHOREHAM_138_CSC**

Mon 10/02/2017 to Sat 10/07/2017
0600 Continuous 1400
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_CSC | **0 MW** | **0 MW** |
| Impacts Total Transfer Capability | 330 MW | 330 MW |
| TTC with All Lines In Service | 330 MW | 330 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**NIAGARA_-ROCHESTR_345_NR2**

Mon 10/02/2017 to Fri 10/06/2017
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| DYSINGER EAST | **1700 MW** |
| Impacts Total Transfer Capability | 1450 MW |
| TTC with All Lines In Service | 3150 MW |

**FRASER__-COOPERS__345_33**

Mon 10/02/2017 to Fri 10/13/2017
0700 Continuous 1900
Work scheduled by: NYSEG

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2395 MW** |
| Impacts Total Transfer Capability | 580 MW |
| TTC with All Lines In Service | 2975 MW |

**HOMRC_NY-MAINS_NY_345_47**

Mon 10/02/2017 to Fri 10/27/2017
0700 Continuous 1730
Work scheduled by: NYSEG

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **2100 MW** | **1350 MW** |
| Impacts Total Transfer Capability | 0 MW | 0 MW |
| TTC with All Lines In Service | 2100 MW | 1350 MW |

**ROTTRDAM-EASTOVER_230_38**

Mon 10/02/2017 to Wed 10/04/2017
0800 Continuous 1200
Work scheduled by: NGrid

**ARR: 77**

| | REV (Export) |
|---|---|
| SCH - NE - NY | **1400 MW** |
| Impacts Total Transfer Capability | 200 MW |
| TTC with All Lines In Service | 1600 MW |

**SPRNBRK__345KV_RNS4**

Mon 10/02/2017 to Fri 10/06/2017
1901 Continuous 0300
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SPR/DUN-SOUTH | **3200 MW** |
| Impacts Total Transfer Capability | 1400 MW |
| TTC with All Lines In Service | 4600 MW |

**W49TH_ST_345KV_5**

Tue 10/03/2017 to Fri 10/06/2017
0301 Continuous 2100
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SCH - PJM_HTP | **315 MW** |
| Impacts Total Transfer Capability | 345 MW |
| TTC with All Lines In Service | 660 MW |

**BECK____-NIAGARA__345_PA302**

Wed 10/04/2017 to Thu 10/05/2017 **UPDATED** **by PA** **08/11/2017**
0600 Continuous 1700
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | **900 MW** | **800 MW** |
| Impacts Total Transfer Capability | 1100 MW | 800 MW |
| TTC with All Lines In Service | 2000 MW | 1600 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**BERKSHIR-ALPS_____345_393**
Fri 10/06/2017 to Fri 10/06/2017
0700 Daily(No Weekends) 0800
Work scheduled by: NGrid
**ARR: 78**

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NE - NY | **950 MW** | **1000 MW** |
| Impacts Total Transfer Capability | 450 MW | 600 MW |
| TTC with All Lines In Service | 1400 MW | 1600 MW |

**BERKSHIR-ALPS_____345_393**
Fri 10/06/2017 to Fri 10/06/2017
0700 Daily(No Weekends) 0800
Work scheduled by: NGrid
**ARR: 78**

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **100 MW** | **100 MW** |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

**BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312**
Fri 10/06/2017 to Fri 10/06/2017
0700 0800
Work scheduled by:
**ARR: 78**

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NE - NY | **950 MW** | **1000 MW** |
| Impacts Total Transfer Capability | 450 MW | 600 MW |
| TTC with All Lines In Service | 1400 MW | 1600 MW |

**BERKSHIR-NORTHFLD_345_312**
Fri 10/06/2017 to Sat 10/28/2017
0700 Continuous 1600
Work scheduled by: ISONE

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NE - NY | **900 MW** | **1200 MW** |
| Impacts Total Transfer Capability | 500 MW | 400 MW |
| TTC with All Lines In Service | 1400 MW | 1600 MW |

**BERKSHIR-NORTHFLD_345_312**
Fri 10/06/2017 to Sat 10/28/2017
0700 Continuous 1600
Work scheduled by: ISONE

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **100 MW** | **100 MW** |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

**BERKSHIR-ALPS_____345_393**
Fri 10/06/2017 to Thu 10/12/2017
0800 Continuous 1700
Work scheduled by: NGrid
**ARR: 78**

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NE - NY | **950 MW** | **1000 MW** |
| Impacts Total Transfer Capability | 450 MW | 600 MW |
| TTC with All Lines In Service | 1400 MW | 1600 MW |

**BERKSHIR-ALPS_____345_393**
Fri 10/06/2017 to Thu 10/12/2017
0800 Continuous 1700
Work scheduled by: NGrid
**ARR: 78**

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **100 MW** | **100 MW** |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312**

Fri 10/06/2017 to Thu 10/12/2017
0800 1700
Work scheduled by:

**ARR: 78**

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NE - NY | **950 MW** | **1000 MW** |
| Impacts Total Transfer Capability | 450 MW | 600 MW |
| TTC with All Lines In Service | 1400 MW | 1600 MW |

---

**WETHSRFD-MEYER____230_85/87**

Fri 10/06/2017 to Fri 10/20/2017 **UPDATED** **by NYSEG** **09/13/2017**
1630 Continuous 1400
Work scheduled by: NYSEG

| | FWD (Import) |
|---|---|
| DYSINGER EAST | **2850 MW** |
| Impacts Total Transfer Capability | 300 MW |
| TTC with All Lines In Service | 3150 MW |

---

**SCH-NE-NYISO_LIMIT_800**

Mon 10/09/2017 to Thu 10/12/2017
0700 Continuous 1700
Work scheduled by: ISONE

| | FWD (Import) |
|---|---|
| SCH - NE - NY | **1000 MW** |
| Impacts Total Transfer Capability | 400 MW |
| TTC with All Lines In Service | 1400 MW |

---

**MARCY_SO_SERIES_COMP_I/S**

Fri 10/13/2017 to Tue 10/31/2017
1900 Continuous 2359
Work scheduled by: NYISO

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2740 MW** |
| Impacts Total Transfer Capability | 235 MW |
| TTC with All Lines In Service | 2975 MW |

---

**CHATGUAY-MASSENA__765_7040**

Sat 10/14/2017 to Sat 10/21/2017 **UPDATED** **by PA** **03/24/2017**
0100 Continuous 2000
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **1550 MW** |
| Impacts Total Transfer Capability | 1600 MW |
| TTC with All Lines In Service | 3150 MW |

---

**CHATGUAY-MASSENA__765_7040**

Sat 10/14/2017 to Sat 10/21/2017 **UPDATED** **by PA** **03/24/2017**
0100 Continuous 2000
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ - NY | **0 MW** | **0 MW** |
| Impacts Total Transfer Capability | 1500 MW | 1000 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

---

**MARCY____765_345_AT1**

Sat 10/14/2017 to Sat 10/21/2017 **UPDATED** **by PA** **03/24/2017**
0100 Continuous 2000
Work scheduled by: NYPA

**ARR: 19**

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **1750 MW** |
| Impacts Total Transfer Capability | 1400 MW |
| TTC with All Lines In Service | 3150 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**MARCY____765_345_AT2**

Sat 10/14/2017 to Sat 10/21/2017 **UPDATED** **by PA** **03/24/2017**
0100 Continuous 2000
Work scheduled by: NYPA **ARR: 19**

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **1700 MW** |
| Impacts Total Transfer Capability | 1450 MW |
| TTC with All Lines In Service | 3150 MW |

---

**MASSENA_-MARCY____765_MSU1**

Sat 10/14/2017 to Sat 10/21/2017 **UPDATED** **by PA** **03/24/2017**
0100 Continuous 2000
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2265 MW** |
| Impacts Total Transfer Capability | 710 MW |
| TTC with All Lines In Service | 2975 MW |

---

**MASSENA_-MARCY____765_MSU1**

Sat 10/14/2017 to Sat 10/21/2017 **UPDATED** **by PA** **03/24/2017**
0100 Continuous 2000
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **500 MW** |
| Impacts Total Transfer Capability | 2650 MW |
| TTC with All Lines In Service | 3150 MW |

---

**MASSENA_-MARCY____765_MSU1**

Sat 10/14/2017 to Sat 10/21/2017 **UPDATED** **by PA** **03/24/2017**
0100 Continuous 2000
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ - NY | **475 MW** | **1000 MW** |
| Impacts Total Transfer Capability | 1025 MW | 0 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

---

**MASSENA_-MARCY____765_MSU1 & CHATGUAY-MASSENA__765_7040**

Sat 10/14/2017 to Sat 10/21/2017
0100 2000
Work scheduled by:

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **500 MW** |
| Impacts Total Transfer Capability | 2650 MW |
| TTC with All Lines In Service | 3150 MW |

---

**MASSENA_-MARCY____765_MSU1 & MARCY_SO_SERIES_COMP_I/S**

Sat 10/14/2017 to Sat 10/21/2017
0100 2000
Work scheduled by:

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2080 MW** |
| Impacts Total Transfer Capability | 895 MW |
| TTC with All Lines In Service | 2975 MW |

---

**MOSES___-MASSENA__230_MMS1 & MOSES___-MASSENA__230_MMS2**

Sat 10/14/2017 to Sat 10/21/2017
0100 2000
Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ - NY | **850 MW** | **0 MW** |
| Impacts Total Transfer Capability | 650 MW | 1000 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**SCH-IMO_NY_NIAG_NRTH_BUS_W/BB**

Mon 10/16/2017 to Fri 10/20/2017
0500 Continuous 1700
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | **1000 MW** | **1150 MW** |
| Impacts Total Transfer Capability | 1000 MW | 450 MW |
| TTC with All Lines In Service | 2000 MW | 1600 MW |

**COOPERS_-MIDDLETP_345_CCRT34**

Mon 10/16/2017 to Sat 10/28/2017 **UPDATED** **by NYISO** **06/21/2017**
0700 Continuous 1500
Work scheduled by: NYSEG

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2720 MW** |
| Impacts Total Transfer Capability | 255 MW |
| TTC with All Lines In Service | 2975 MW |

**HURLYAVE-ROSETON__345_303**

Mon 10/16/2017 to Fri 11/03/2017 **UPDATED** **by CH** **06/07/2017**
0800 Continuous 1600
Work scheduled by: CHGE

| | FWD (Import) |
|---|---|
| UPNY CONED | **4100 MW** |
| Impacts Total Transfer Capability | 1000 MW |
| TTC with All Lines In Service | 5100 MW |

**LEEDS___-HURLYAVE_345_301**

Mon 10/16/2017 to Fri 11/03/2017
0800 Continuous 1600
Work scheduled by: CHGE

| | FWD (Import) |
|---|---|
| UPNY CONED | **4100 MW** |
| Impacts Total Transfer Capability | 1000 MW |
| TTC with All Lines In Service | 5100 MW |

**SPRNBRK__345KV_RNS4**

Tue 10/17/2017 to Sat 10/28/2017
0301 Continuous 0300
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SPR/DUN-SOUTH | **3200 MW** |
| Impacts Total Transfer Capability | 1400 MW |
| TTC with All Lines In Service | 4600 MW |

**BERKSHIR-ALPS_____345_393**

Wed 10/18/2017 to Wed 10/18/2017
0700 Continuous 1700
Work scheduled by: NGrid **ARR: 78**

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NE - NY | **950 MW** | **1000 MW** |
| Impacts Total Transfer Capability | 450 MW | 600 MW |
| TTC with All Lines In Service | 1400 MW | 1600 MW |

**BERKSHIR-ALPS_____345_393**

Wed 10/18/2017 to Wed 10/18/2017
0700 Continuous 1700
Work scheduled by: NGrid **ARR: 78**

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **100 MW** | **100 MW** |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312**

Wed 10/18/2017 0700 to Wed 10/18/2017 1700

Work scheduled by:

**ARR: 78**

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NE - NY | **950 MW** | **1000 MW** |
| Impacts Total Transfer Capability | 450 MW | 600 MW |
| TTC with All Lines In Service | 1400 MW | 1600 MW |

---

**NIAGARA_-KINTIGH__345_NS1-38**

Mon 10/23/2017 0600 to Thu 11/02/2017 1600 Continuous

**UPDATED** **by NYSEG** **09/05/2017**

Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| DYSINGER EAST | **1700 MW** |
| Impacts Total Transfer Capability | 1450 MW |
| TTC with All Lines In Service | 3150 MW |

---

**S.RIPLEY-DUNKIRK__230_68**

Mon 10/23/2017 0800 to Thu 10/26/2017 1500 Continuous

**UPDATED** **by NYISO** **08/01/2017**

Work scheduled by: PJM

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **1950 MW** | **1350 MW** |
| Impacts Total Transfer Capability | 150 MW | 0 MW |
| TTC with All Lines In Service | 2100 MW | 1350 MW |

---

**BERKSHIR-ALPS_____345_393**

Wed 10/25/2017 0700 to Wed 10/25/2017 1700 Continuous

Work scheduled by: NGrid

**ARR: 78**

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NE - NY | **950 MW** | **1000 MW** |
| Impacts Total Transfer Capability | 450 MW | 600 MW |
| TTC with All Lines In Service | 1400 MW | 1600 MW |

---

**BERKSHIR-ALPS_____345_393**

Wed 10/25/2017 0700 to Wed 10/25/2017 1700 Continuous

Work scheduled by: NGrid

**ARR: 78**

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **100 MW** | **100 MW** |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

---

**BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312**

Wed 10/25/2017 0700 to Wed 10/25/2017 1700

Work scheduled by:

**ARR: 78**

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NE - NY | **950 MW** | **1000 MW** |
| Impacts Total Transfer Capability | 450 MW | 600 MW |
| TTC with All Lines In Service | 1400 MW | 1600 MW |

---

**S.RIPLEY-DUNKIRK__230_68**

Thu 10/26/2017 1501 to Sat 02/01/2020 0000 Continuous

**UPDATED** **by NYISO** **05/17/2017**

Work scheduled by: NYISO

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **1950 MW** | **1350 MW** |
| Impacts Total Transfer Capability | 150 MW | 0 MW |
| TTC with All Lines In Service | 2100 MW | 1350 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**W49TH_ST_345KV_5**

Fri 10/27/2017 to Wed 11/01/2017
0001 Continuous 0300
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SCH - PJM_HTP | **315 MW** |
| Impacts Total Transfer Capability | 345 MW |
| TTC with All Lines In Service | 660 MW |

**SPRNBRK__345KV_RNS4**

Sat 10/28/2017 to Wed 11/01/2017
0301 Continuous 0300
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SPR/DUN-SOUTH | **3200 MW** |
| Impacts Total Transfer Capability | 1400 MW |
| TTC with All Lines In Service | 4600 MW |

**BERKSHIR-ALPS_____345_393**

Sat 10/28/2017 to Sat 10/28/2017
1500 Daily 1600
Work scheduled by: NGrid

**ARR: 78**

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NE - NY | **950 MW** | **1000 MW** |
| Impacts Total Transfer Capability | 450 MW | 600 MW |
| TTC with All Lines In Service | 1400 MW | 1600 MW |

**BERKSHIR-ALPS_____345_393**

Sat 10/28/2017 to Sat 10/28/2017
1500 Daily 1600
Work scheduled by: NGrid

**ARR: 78**

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **100 MW** | **100 MW** |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

**BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312**

Sat 10/28/2017 to Sat 10/28/2017
1500 1600
Work scheduled by:

**ARR: 78**

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NE - NY | **950 MW** | **1000 MW** |
| Impacts Total Transfer Capability | 450 MW | 600 MW |
| TTC with All Lines In Service | 1400 MW | 1600 MW |

**MOSES___-ADIRNDCK_230_MA2**

Mon 10/30/2017 to Fri 11/03/2017
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2100 MW** |
| Impacts Total Transfer Capability | 1050 MW |
| TTC with All Lines In Service | 3150 MW |

**PLSNTVLY-EFISHKIL_345_F36**

Wed 11/01/2017 to Sat 11/04/2017
0001 Continuous 0300
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **4000 MW** |
| Impacts Total Transfer Capability | 1100 MW |
| TTC with All Lines In Service | 5100 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**LAFAYTTE-CLRKSCRN_345_4-46**

Wed 11/01/2017 to Thu 11/02/2017
0630 Continuous 1630
Work scheduled by: NGrid

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2650 MW** |
| Impacts Total Transfer Capability | 325 MW |
| TTC with All Lines In Service | 2975 MW |

**MARION__-FARRAGUT_345_C3403**

Thu 11/02/2017 to Fri 11/03/2017
0200 Continuous 0100
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **2300 MW** | **1450 MW** |
| Impacts Total Transfer Capability | 0 MW | 0 MW |
| TTC with All Lines In Service | 2300 MW | 1450 MW |

**E13THSTA-FARRAGUT_345_46**

Thu 11/02/2017 to Thu 11/02/2017
0230 Continuous 0300
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SPR/DUN-SOUTH | **3800 MW** |
| Impacts Total Transfer Capability | 800 MW |
| TTC with All Lines In Service | 4600 MW |

**BERKSHIR-ALPS_____345_393**

Thu 11/02/2017 to Sat 11/04/2017 **UPDATED** **by NE** **08/02/2017**
0700 Continuous 1700
Work scheduled by: NGrid
**ARR: 78**

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NE - NY | **1300 MW** | **1300 MW** |
| Impacts Total Transfer Capability | 100 MW | 300 MW |
| TTC with All Lines In Service | 1400 MW | 1600 MW |

**BERKSHIR-ALPS_____345_393**

Thu 11/02/2017 to Sat 11/04/2017 **UPDATED** **by NE** **08/02/2017**
0700 Continuous 1700
Work scheduled by: NGrid
**ARR: 78**

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **100 MW** | **100 MW** |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

**BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312**

Thu 11/02/2017 to Sat 11/04/2017
0700 1700
Work scheduled by:
**ARR: 78**

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NE - NY | **1300 MW** | **1300 MW** |
| Impacts Total Transfer Capability | 100 MW | 300 MW |
| TTC with All Lines In Service | 1400 MW | 1600 MW |

**BERKSHIR-NORTHFLD_345_312**

Thu 11/02/2017 to Sat 11/04/2017 **UPDATED** **by NE** **08/02/2017**
0700 Continuous 1700
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NE - NY | **1400 MW** | **1450 MW** |
| Impacts Total Transfer Capability | 0 MW | 150 MW |
| TTC with All Lines In Service | 1400 MW | 1600 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**BERKSHIR-NORTHFLD_345_312**

Thu 11/02/2017 to Sat 11/04/2017 **UPDATED** **by NE** **08/02/2017**
0700 Continuous 1700
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **100 MW** | **100 MW** |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

---

**PLSNTVLY-EFISHKIL_345_F36**

Mon 11/06/2017 to Wed 11/08/2017
0001 Continuous 0300
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **4000 MW** |
| Impacts Total Transfer Capability | 1100 MW |
| TTC with All Lines In Service | 5100 MW |

---

**FRASANNX-COOPERS__345_UCC2-41**

Mon 11/06/2017 to Fri 11/17/2017
0600 Continuous 1700
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2500 MW** |
| Impacts Total Transfer Capability | 475 MW |
| TTC with All Lines In Service | 2975 MW |

---

**MARCY___-FRASANNX_345_UCC2-41**

Mon 11/06/2017 to Fri 11/17/2017
0600 Continuous 1700
Work scheduled by: NYPA

**ARR: 19**

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2500 MW** |
| Impacts Total Transfer Capability | 475 MW |
| TTC with All Lines In Service | 2975 MW |

---

**MOSES___-ADIRNDCK_230_MA2**

Mon 11/06/2017 to Thu 11/09/2017
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2300 MW** |
| Impacts Total Transfer Capability | 850 MW |
| TTC with All Lines In Service | 3150 MW |

---

**LINDN_CG-LNDVFT___345_V-3022**

Mon 11/06/2017 to Thu 11/09/2017
0800 Continuous 1500
Work scheduled by: PJM

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJM_VFT | **0 MW** | **0 MW** |
| Impacts Total Transfer Capability | 315 MW | 315 MW |
| TTC with All Lines In Service | 315 MW | 315 MW |

---

**SCRIBA__-VOLNEY___345_20**

Mon 11/06/2017 to Fri 11/17/2017
0800 Continuous 1630
Work scheduled by: NGrid

| | FWD (Import) |
|---|---|
| OSWEGO EXPORT | **5250 MW** |
| Impacts Total Transfer Capability | 0 MW |
| TTC with All Lines In Service | 5250 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**W49TH_ST_345KV_5**

Fri 11/10/2017 to Fri 11/10/2017
0001 Continuous 0030
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SCH - PJM_HTP | **315 MW** |
| Impacts Total Transfer Capability | 345 MW |
| TTC with All Lines In Service | 660 MW |

**SPRNBRK_-W49TH_ST_345_M52**

Fri 11/10/2017 to Mon 11/13/2017
0001 Continuous 0300
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SPR/DUN-SOUTH | **3200 MW** |
| Impacts Total Transfer Capability | 1400 MW |
| TTC with All Lines In Service | 4600 MW |

**SPRNBRK__345KV_RNS4**

Fri 11/10/2017 to Mon 11/13/2017
0001 Continuous 0300
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SPR/DUN-SOUTH | **3200 MW** |
| Impacts Total Transfer Capability | 1400 MW |
| TTC with All Lines In Service | 4600 MW |

**SPRNBRK__345KV_RS3 & SPRNBRK__345KV_RS4**

Sun 11/12/2017 to Wed 11/15/2017
0001 0300
Work scheduled by:

| | FWD (Import) |
|---|---|
| SPR/DUN-SOUTH | **3800 MW** |
| Impacts Total Transfer Capability | 800 MW |
| TTC with All Lines In Service | 4600 MW |

**W49TH_ST_345KV_5**

Mon 11/13/2017 to Mon 11/13/2017
0230 Continuous 0300
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SCH - PJM_HTP | **315 MW** |
| Impacts Total Transfer Capability | 345 MW |
| TTC with All Lines In Service | 660 MW |

**MOSES___-ADIRNDCK_230_MA2**

Mon 11/13/2017 to Fri 11/17/2017
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2300 MW** |
| Impacts Total Transfer Capability | 850 MW |
| TTC with All Lines In Service | 3150 MW |

**SPRNBRK__345KV_RNS4**

Wed 11/15/2017 to Fri 11/17/2017
0001 Continuous 0100
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SPR/DUN-SOUTH | **3200 MW** |
| Impacts Total Transfer Capability | 1400 MW |
| TTC with All Lines In Service | 4600 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**E13THSTA-FARRAGUT_345_45**

Sat 11/18/2017 to Tue 05/15/2018
0000 Continuous 2359
Work scheduled by: ConEd

FWD (Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

---

**W49TH_ST-E13THSTA_345_M54**

Sat 11/18/2017 to Tue 05/15/2018
0000 Continuous 2359
Work scheduled by: ConEd

FWD (Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

---

**EGRDNCTY_345_138_AT1**

Sun 11/19/2017 to Sat 12/23/2017 **UPDATED** **by LI** **08/01/2017**
0001 Continuous 2359
Work scheduled by: LI

FWD (Import)
CONED - LIPA **1250 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 1500 MW

---

**EGRDNCTY_345_138_AT2**

Sun 11/19/2017 to Sat 12/23/2017 **UPDATED** **by LI** **08/01/2017**
0001 Continuous 2359
Work scheduled by: LI

FWD (Import)
CONED - LIPA **1250 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 1500 MW

---

**SPRNBRK_-EGRDNCTR_345_Y49**

Sun 11/19/2017 to Sat 12/23/2017 **UPDATED** **by LI** **08/01/2017**
0001 Continuous 2359
Work scheduled by: LI

FWD (Import)
CONED - LIPA **775 MW**
Impacts Total Transfer Capability 725 MW
TTC with All Lines In Service 1500 MW

---

**MOSES___-ADIRNDCK_230_MA1**

Mon 11/20/2017 to Wed 11/22/2017
0700 Continuous 1530
Work scheduled by: NYPA

FWD (Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

---

**N.SCTLND-LEEDS____345_93**

Mon 11/20/2017 to Mon 11/20/2017
0800 Daily(No Weekends) 1430
Work scheduled by: NGrid

FWD (Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**MOSES___-ADIRNDCK_230_MA1**

Mon 11/27/2017 to Fri 12/01/2017
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2300 MW** |
| Impacts Total Transfer Capability | 850 MW |
| TTC with All Lines In Service | 3150 MW |

---

**ROSETON_-EFISHKIL_345_RFK305**

Mon 11/27/2017 to Fri 12/01/2017
0800 Continuous 1600
Work scheduled by: CHGE

| | FWD (Import) |
|---|---|
| UPNY CONED | **4800 MW** |
| Impacts Total Transfer Capability | 300 MW |
| TTC with All Lines In Service | 5100 MW |

---

**ROTTRDAM-EASTOVER_230_38**

Mon 11/27/2017 to Thu 11/30/2017
0900 Continuous 1500
Work scheduled by: NGrid

**ARR: 77**

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NE - NY | **1400 MW** | **1400 MW** |
| Impacts Total Transfer Capability | 0 MW | 200 MW |
| TTC with All Lines In Service | 1400 MW | 1600 MW |

---

**PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4**

Sun 12/03/2017 to Tue 12/05/2017
0001 0300
Work scheduled by:

| | FWD (Import) |
|---|---|
| UPNY CONED | **3800 MW** |
| Impacts Total Transfer Capability | 1300 MW |
| TTC with All Lines In Service | 5100 MW |

---

**LEEDS___-PLSNTVLY_345_92**

Mon 12/04/2017 to Mon 12/18/2017 **UPDATED** **by NYISO** **09/12/2017**
0001 Continuous 0300
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **3800 MW** |
| Impacts Total Transfer Capability | 1300 MW |
| TTC with All Lines In Service | 5100 MW |

---

**PLSNTVLY_345KV_RNS5**

Mon 12/04/2017 to Mon 12/18/2017 **UPDATED** **by NYISO** **09/12/2017**
0001 Continuous 0300
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **3800 MW** |
| Impacts Total Transfer Capability | 1300 MW |
| TTC with All Lines In Service | 5100 MW |

---

**MARCY____765_345_AT2**

Mon 12/04/2017 to Fri 12/08/2017
0500 Continuous 1630
Work scheduled by: NYPA

**ARR: 19**

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **1700 MW** |
| Impacts Total Transfer Capability | 1450 MW |
| TTC with All Lines In Service | 3150 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**MOSES___-ADIRNDCK_230_MA2**

Mon 12/11/2017 to Fri 12/15/2017
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2300 MW** |
| Impacts Total Transfer Capability | 850 MW |
| TTC with All Lines In Service | 3150 MW |

---

**MOSES___-ADIRNDCK_230_MA2**

Mon 12/18/2017 to Fri 12/22/2017 **UPDATED** **by NYPA** **10/23/2016**
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2300 MW** |
| Impacts Total Transfer Capability | 850 MW |
| TTC with All Lines In Service | 3150 MW |

---

**MARCY____765_345_AT2**

Wed 12/27/2017 to Thu 12/28/2017
0500 Continuous 1630
Work scheduled by: NYPA

**ARR: 19**

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **1700 MW** |
| Impacts Total Transfer Capability | 1450 MW |
| TTC with All Lines In Service | 3150 MW |

---

**DUNWODIE-SHORE_RD_345_Y50**

Tue 01/02/2018 to Wed 01/03/2018
0001 Continuous 0100
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| CONED - LIPA | **800 MW** |
| Impacts Total Transfer Capability | 700 MW |
| TTC with All Lines In Service | 1500 MW |

---

**DUNWODIE_345KV_4**

Tue 01/02/2018 to Wed 01/03/2018
0001 Continuous 0100
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SPR/DUN-SOUTH | **3800 MW** |
| Impacts Total Transfer Capability | 800 MW |
| TTC with All Lines In Service | 4600 MW |

---

**DUNWODIE_345KV_6**

Tue 01/02/2018 to Wed 01/03/2018
0001 Continuous 0100
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SPR/DUN-SOUTH | **3800 MW** |
| Impacts Total Transfer Capability | 800 MW |
| TTC with All Lines In Service | 4600 MW |

---

**SHORE_RD_345_138_BK 1**

Tue 01/02/2018 to Wed 01/03/2018
0001 Continuous 0100
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| CONED - LIPA | **1350 MW** |
| Impacts Total Transfer Capability | 150 MW |
| TTC with All Lines In Service | 1500 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**SHORE_RD_345_138_BK 2**

Tue 01/02/2018 to Wed 01/03/2018
0001 Continuous 0100
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| CONED - LIPA | **1350 MW** |
| Impacts Total Transfer Capability | 150 MW |
| TTC with All Lines In Service | 1500 MW |

---

**LEEDS___-PLSNTVLY_345_92**

Wed 01/03/2018 to Sat 01/06/2018 **UPDATED** **by NYISO** **09/12/2017**
0001 Continuous 0300
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **3800 MW** |
| Impacts Total Transfer Capability | 1300 MW |
| TTC with All Lines In Service | 5100 MW |

---

**PLSNTVLY_345KV_RNS5**

Wed 01/03/2018 to Sat 01/06/2018 **UPDATED** **by NYISO** **09/12/2017**
0001 Continuous 0300
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **3800 MW** |
| Impacts Total Transfer Capability | 1300 MW |
| TTC with All Lines In Service | 5100 MW |

---

**PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4**

Fri 01/05/2018 to Sun 01/07/2018
0001 2359
Work scheduled by:

| | FWD (Import) |
|---|---|
| UPNY CONED | **3800 MW** |
| Impacts Total Transfer Capability | 1300 MW |
| TTC with All Lines In Service | 5100 MW |

---

**PLSNTVLY_345KV_RNS5**

Mon 01/08/2018 to Wed 01/10/2018 **UPDATED** **by NYISO** **09/12/2017**
0001 Continuous 0300
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **3800 MW** |
| Impacts Total Transfer Capability | 1300 MW |
| TTC with All Lines In Service | 5100 MW |

---

**MARCY____765_345_AT2**

Sat 01/20/2018 to Sat 01/20/2018
0500 Continuous 1730
Work scheduled by: NYPA

**ARR: 19**

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **1700 MW** |
| Impacts Total Transfer Capability | 1450 MW |
| TTC with All Lines In Service | 3150 MW |

---

**MARCY____765_345_AT2**

Sat 02/03/2018 to Sat 02/03/2018
0500 Continuous 1730
Work scheduled by: NYPA

**ARR: 19**

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **1700 MW** |
| Impacts Total Transfer Capability | 1450 MW |
| TTC with All Lines In Service | 3150 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MARCY____765_345_AT2**

Mon 02/05/2018 to Fri 02/09/2018
0500 Continuous 1730
Work scheduled by: NYPA

**ARR: 19**

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **1700 MW** |
| Impacts Total Transfer Capability | 1450 MW |
| TTC with All Lines In Service | 3150 MW |

**HUDSONP_-FARRAGUT_345_B3402**

Sun 02/18/2018 to Sun 04/01/2018
0001 Continuous 2359
Work scheduled by: PJM

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **2300 MW** | **1450 MW** |
| Impacts Total Transfer Capability | 0 MW | 0 MW |
| TTC with All Lines In Service | 2300 MW | 1450 MW |

**MARCY___-EDIC_____345_UE1-7**

Tue 02/20/2018 to Fri 02/23/2018
0500 Continuous 1730
Work scheduled by: NYPA

**ARR: 19&16**

| | FWD (Import) |
|---|---|
| OSWEGO EXPORT | **5250 MW** |
| Impacts Total Transfer Capability | 0 MW |
| TTC with All Lines In Service | 5250 MW |

**DUNWODIE_345KV_7**

Thu 03/01/2018 to Thu 03/01/2018
0001 Continuous 0100
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SPR/DUN-SOUTH | **3800 MW** |
| Impacts Total Transfer Capability | 800 MW |
| TTC with All Lines In Service | 4600 MW |

**DUNWODIE_345KV_8**

Thu 03/01/2018 to Thu 03/01/2018
0001 Continuous 0100
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SPR/DUN-SOUTH | **3800 MW** |
| Impacts Total Transfer Capability | 800 MW |
| TTC with All Lines In Service | 4600 MW |

**DUNWODIE-MOTTHAVN_345_72**

Thu 03/01/2018 to Thu 04/05/2018
0001 Continuous 0300
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SPR/DUN-SOUTH | **3800 MW** |
| Impacts Total Transfer Capability | 800 MW |
| TTC with All Lines In Service | 4600 MW |

**S.RIPLEY-DUNKIRK__230_68**

Mon 03/19/2018 to Fri 04/20/2018
1000 Continuous 1559
Work scheduled by: PJM

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **1950 MW** | **1350 MW** |
| Impacts Total Transfer Capability | 350 MW | 100 MW |
| TTC with All Lines In Service | 2300 MW | 1450 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**DUNWODIE_345KV_7**

Thu 04/05/2018 to Thu 04/05/2018
0200 Continuous 0300
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SPR/DUN-SOUTH | **3800 MW** |
| Impacts Total Transfer Capability | 800 MW |
| TTC with All Lines In Service | 4600 MW |

**DUNWODIE_345KV_8**

Thu 04/05/2018 to Thu 04/05/2018
0200 Continuous 0300
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SPR/DUN-SOUTH | **3800 MW** |
| Impacts Total Transfer Capability | 800 MW |
| TTC with All Lines In Service | 4600 MW |

**NEPTUNE_-DUFFYAVE_345_NEPTUNE**

Mon 04/16/2018 to Tue 05/01/2018
0001 Continuous 1800
Work scheduled by: PJM

| | FWD (Import) |
|---|---|
| SCH - PJM_NEPTUNE | **0 MW** |
| Impacts Total Transfer Capability | 660 MW |
| TTC with All Lines In Service | 660 MW |

**NEWBRDGE-DUFFYAVE_345_501**

Mon 04/16/2018 to Tue 05/01/2018
0001 Continuous 1800
Work scheduled by: PJM

| | FWD (Import) |
|---|---|
| SCH - PJM_NEPTUNE | **0 MW** |
| Impacts Total Transfer Capability | 660 MW |
| TTC with All Lines In Service | 660 MW |

**NEWBRDGE_345_138_BK_1**

Mon 04/16/2018 to Tue 05/01/2018
0001 Continuous 1800
Work scheduled by: PJM

| | FWD (Import) |
|---|---|
| SCH - PJM_NEPTUNE | **375 MW** |
| Impacts Total Transfer Capability | 285 MW |
| TTC with All Lines In Service | 660 MW |

**NEWBRDGE_345_138_BK_2**

Mon 04/16/2018 to Tue 05/01/2018
0001 Continuous 1800
Work scheduled by: PJM

| | FWD (Import) |
|---|---|
| SCH - PJM_NEPTUNE | **375 MW** |
| Impacts Total Transfer Capability | 285 MW |
| TTC with All Lines In Service | 660 MW |

**MARCY____765_345_AT1**

Mon 04/23/2018 to Mon 04/23/2018
0500 Continuous 1730
Work scheduled by: NYPA

**ARR: 19**

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **1750 MW** |
| Impacts Total Transfer Capability | 1400 MW |
| TTC with All Lines In Service | 3150 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**HURLYAVE-ROSETON__345_303**

Mon 04/30/2018 to Fri 05/25/2018
0800 Continuous 1600
Work scheduled by: CHGE

| | FWD (Import) |
|---|---|
| UPNY CONED | **4100 MW** |
| Impacts Total Transfer Capability | 1000 MW |
| TTC with All Lines In Service | 5100 MW |

**MARCY_SO_SERIES_COMP_I/S**

Tue 05/01/2018 to Wed 10/31/2018
0001 Continuous 2359
Work scheduled by: NYISO

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2740 MW** |
| Impacts Total Transfer Capability | 235 MW |
| TTC with All Lines In Service | 2975 MW |

**MARCY____765_345_AT2**

Mon 05/21/2018 to Fri 05/25/2018
0500 Continuous 1730
Work scheduled by: NYPA

**ARR: 19**

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **1700 MW** |
| Impacts Total Transfer Capability | 1450 MW |
| TTC with All Lines In Service | 3150 MW |

**MARCY____765_345_AT1**

Sat 08/04/2018 to Sun 08/05/2018
0500 Continuous 1730
Work scheduled by: NYPA

**ARR: 19**

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **1750 MW** |
| Impacts Total Transfer Capability | 1400 MW |
| TTC with All Lines In Service | 3150 MW |

**MARCY____765_345_AT2**

Tue 09/04/2018 to Sun 09/09/2018
0500 Continuous 1730
Work scheduled by: NYPA

**ARR: 19**

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **1700 MW** |
| Impacts Total Transfer Capability | 1450 MW |
| TTC with All Lines In Service | 3150 MW |

**ROSETON_-ROCKTVRN_345_311**

Mon 09/10/2018 to Fri 09/28/2018
0800 Continuous 1600
Work scheduled by: CHGE

| | FWD (Import) |
|---|---|
| UPNY CONED | **4400 MW** |
| Impacts Total Transfer Capability | 700 MW |
| TTC with All Lines In Service | 5100 MW |

**MARCY____345KV_CSC**

Tue 09/11/2018 to Tue 09/11/2018
0500 Continuous 1730
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2925 MW** |
| Impacts Total Transfer Capability | 50 MW |
| TTC with All Lines In Service | 2975 MW |

# NYISO TRANSFER LIMITATIONS

Sunday ,September17, 2017 to Tuesday ,March 19, 2019

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**MARCY____345KV_CSC & MARCY_SO_SERIES_COMP_I/S**

Tue 09/11/2018 to Tue 09/11/2018
0500 1730
Work scheduled by:

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2690 MW** |
| Impacts Total Transfer Capability | 285 MW |
| TTC with All Lines In Service | 2975 MW |

---

**MARCY____765_345_AT2**

Tue 09/11/2018 to Tue 09/11/2018
0500 Continuous 1730
Work scheduled by: NYPA **ARR: 19**

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **1700 MW** |
| Impacts Total Transfer Capability | 1450 MW |
| TTC with All Lines In Service | 3150 MW |

---

**MARCY____765_345_AT2**

Thu 10/04/2018 to Fri 10/05/2018
0500 Continuous 1730
Work scheduled by: NYPA **ARR: 19**

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **1700 MW** |
| Impacts Total Transfer Capability | 1450 MW |
| TTC with All Lines In Service | 3150 MW |

---

**LEEDS___-HURLYAVE_345_301**

Mon 10/22/2018 to Fri 11/16/2018
0800 Continuous 1600
Work scheduled by: CHGE

| | FWD (Import) |
|---|---|
| UPNY CONED | **4100 MW** |
| Impacts Total Transfer Capability | 1000 MW |
| TTC with All Lines In Service | 5100 MW |

---

**MARCY____345KV_CSC**

Fri 11/16/2018 to Sat 11/17/2018
0500 Continuous 1730
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2925 MW** |
| Impacts Total Transfer Capability | 50 MW |
| TTC with All Lines In Service | 2975 MW |

---

**MARCY____765_345_AT2**

Fri 11/16/2018 to Sat 11/17/2018
0500 Continuous 1730
Work scheduled by: NYPA **ARR: 19**

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **1700 MW** |
| Impacts Total Transfer Capability | 1450 MW |
| TTC with All Lines In Service | 3150 MW |

---

**MARCY____765_345_AT2**

Mon 12/17/2018 to Fri 12/21/2018
0500 Continuous 1730
Work scheduled by: NYPA **ARR: 19**

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **1700 MW** |
| Impacts Total Transfer Capability | 1450 MW |
| TTC with All Lines In Service | 3150 MW |