NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO___345_345_PAR3500

Fri 06/24/2016 to Wed 09/13/2017 **EXT FORCE** **by CONED** **08/28/2017**
1940 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	**1650 MW**	**1250 MW**
Impacts Total Transfer Capability	450 MW	100 MW
TTC with All Lines In Service	2100 MW	1350 MW

HUDSONTP-W49TH_ST_345_Y56

Thu 11/24/2016 to Sat 09/30/2017 **UPDATED** **by PJM** **05/18/2017**
1500 Continuous 2359
Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**0 MW**
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	660 MW

S.RIPLEY-DUNKIRK__230_68 & RAMAPO___345_345_PAR3500

Tue 05/02/2017 to Wed 09/13/2017
1710 0200
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - PJ - NY	**1450 MW**	**1250 MW**
Impacts Total Transfer Capability	650 MW	100 MW
TTC with All Lines In Service	2100 MW	1350 MW

S.RIPLEY-DUNKIRK__230_68

Tue 05/02/2017 to Mon 10/23/2017 **UPDATED** **by NYISO** **05/17/2017**
1710 Continuous 0759
Work scheduled by: NYISO

	FWD (Import)	REV (Export)
SCH - PJ - NY	**1950 MW**	**1350 MW**
Impacts Total Transfer Capability	150 MW	0 MW
TTC with All Lines In Service	2100 MW	1350 MW

SCH-NYISO-HQ_LIMIT_800

Thu 06/08/2017 to Fri 12/15/2017 **UPDATED** **by HQ** **08/03/2017**
0600 Continuous 1700
Work scheduled by: HQ

	REV (Export)
SCH - HQ - NY	**800 MW**
Impacts Total Transfer Capability	200 MW
TTC with All Lines In Service	1000 MW

SCH-HQ-NYISO_LIMIT_1450

Tue 08/01/2017 to Fri 12/15/2017
2100 Continuous 1600
Work scheduled by: HQ

	FWD (Import)
SCH - HQ - NY	**1450 MW**
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	1500 MW

COOPERS_-DOLSONAV_345_CCDA42

Tue 08/22/2017 to Tue 09/05/2017 **UPDATED** **by PA** **09/05/2017**
1800 Continuous 1432
Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	**2720 MW**
Impacts Total Transfer Capability	255 MW
TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DOLSONAV-ROCKTVRN_345_DART44

Tue 08/22/2017 to Tue 09/05/2017 **UPDATED** **by PA** **09/05/2017**
1800 Continuous 1432
Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	**2720 MW**
Impacts Total Transfer Capability	255 MW
TTC with All Lines In Service	2975 MW

HOPATCON-RAMAPO___500_5018

Tue 08/29/2017 to Wed 09/13/2017 **EXTENDED** **by CE** **08/28/2017**
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	**1150 MW**	**1000 MW**
Impacts Total Transfer Capability	950 MW	350 MW
TTC with All Lines In Service	2100 MW	1350 MW

HOPATCON-RAMAPO___500_5018

Tue 08/29/2017 to Wed 09/13/2017 **EXTENDED** **by CE** **08/28/2017**
0001 Continuous 0200
Work scheduled by: ConEd

TOTAL EAST
Impacts Total Transfer Capability
TTC with All Lines In Service

HOPATCON-RAMAPO___500_5018

Tue 08/29/2017 to Wed 09/13/2017 **EXTENDED** **by CE** **08/28/2017**
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**5000 MW**
Impacts Total Transfer Capability	100 MW
TTC with All Lines In Service	5100 MW

HOPATCON-RAMAPO___500_5018 & S.RIPLEY-DUNKIRK__230_68

Tue 08/29/2017 to Wed 09/13/2017
0001 0200
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - PJ - NY	**1200 MW**	**1300 MW**
Impacts Total Transfer Capability	900 MW	50 MW
TTC with All Lines In Service	2100 MW	1350 MW

RAMAPO___345_345_PAR4500

Tue 08/29/2017 to Wed 09/13/2017 **EXTENDED** **by CE** **08/28/2017**
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	**1650 MW**	**1250 MW**
Impacts Total Transfer Capability	450 MW	100 MW
TTC with All Lines In Service	2100 MW	1350 MW

RAMAPO___500_345_BK 1500

Tue 08/29/2017 to Wed 09/13/2017 **EXTENDED** **by CE** **08/28/2017**
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	**1900 MW**	**1000 MW**
Impacts Total Transfer Capability	200 MW	350 MW
TTC with All Lines In Service	2100 MW	1350 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO___500_345_BK 1500

Tue 08/29/2017 to Wed 09/13/2017 **EXTENDED** **by CE** **08/28/2017**
0001 Continuous 0200
Work scheduled by: ConEd

TOTAL EAST
Impacts Total Transfer Capability
TTC with All Lines In Service

RAMAPO___500_345_BK 1500

Tue 08/29/2017 to Wed 09/13/2017 **EXTENDED** **by CE** **08/28/2017**
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**5000 MW**
Impacts Total Transfer Capability	100 MW
TTC with All Lines In Service	5100 MW

S.RIPLEY-DUNKIRK__230_68 & RAMAPO___345_345_PAR4500

Tue 08/29/2017 to Wed 09/13/2017
0001 0200
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - PJ - NY	**1450 MW**	**1250 MW**
Impacts Total Transfer Capability	650 MW	100 MW
TTC with All Lines In Service	2100 MW	1350 MW

SCH-IMO-NYISO_LIMIT_1450

Tue 08/29/2017 to Tue 10/31/2017 **EXTENDED** **by NYISO** **07/28/2017**
1230 Continuous 2359
Work scheduled by: NYISO

	FWD (Import)
SCH - OH - NY	**1750 MW**
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	2000 MW

MARCY_SO_SERIES_COMP_I/S

Fri 09/01/2017 to Sat 09/16/2017 **UPDATED** **by NYPA** **09/07/2017**
1512 Continuous 0759
Work scheduled by: NYISO

	FWD (Import)
CENTRAL EAST - VC	**2740 MW**
Impacts Total Transfer Capability	235 MW
TTC with All Lines In Service	2975 MW

SPRNBRK_-TREMONT__345_X28

Mon 09/04/2017 to Tue 09/05/2017 **UPDATED** **by CE** **08/30/2017**
0001 Continuous 0100
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**4200 MW**
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	4600 MW

SCH-HQ_CEDARS-NYISO_LIMIT_100

Tue 09/05/2017 to Thu 09/07/2017
0500 Continuous 2300
Work scheduled by: HQ

	FWD (Import)
SCH - HQ_CEDARS	**100 MW**
Impacts Total Transfer Capability	90 MW
TTC with All Lines In Service	190 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY____765_345_AT2

Tue 09/05/2017 0500 to Sun 09/10/2017 1700 Continuous

Work scheduled by: NYPA

UPDATED **by PA** **08/22/2017**

ARR: 19

FWD (Import)

MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

SCH-NYISO-PJM_LIMIT_100

Tue 09/05/2017 1600 to Fri 09/08/2017 1600 Continuous

Work scheduled by: PJM

UPDATED **by NYISO** **09/05/2017**

REV (Export)

SCH - PJ - NY **400 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 1350 MW

W49TH_ST_345KV_6

Tue 09/05/2017 1830 to Tue 09/05/2017 1900 Continuous

Work scheduled by: ConEd

UPDATED **by CE** **09/04/2017**

FWD (Import)

SCH - PJM_HTP **320 MW**
Impacts Total Transfer Capability 340 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Tue 09/05/2017 1830 to Tue 09/05/2017 1900 Continuous

Work scheduled by: ConEd

UPDATED **by CE** **09/04/2017**

FWD (Import)

SCH - PJM_HTP **315 MW**
Impacts Total Transfer Capability 345 MW
TTC with All Lines In Service 660 MW

COOPERS_-DOLSONAV_345_CCDA42

Wed 09/06/2017 0834 to Wed 09/06/2017 1627 Continuous

Work scheduled by: NYPA

UPDATED **by NYPA** **09/06/2017**

FWD (Import)

CENTRAL EAST - VC **2720 MW**
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 2975 MW

DOLSONAV-ROCKTVRN_345_DART44

Wed 09/06/2017 0834 to Wed 09/06/2017 1627 Continuous

Work scheduled by: NYPA

UPDATED **by NYPA** **09/06/2017**

FWD (Import)

CENTRAL EAST - VC **2720 MW**
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 2975 MW

CHAT_DC_GC1

Thu 09/07/2017 0001 to Thu 09/07/2017 0200 Continuous

Work scheduled by: ORU

CANCELLED **by HQ** **09/06/2017**

FWD (Import)

MOSES SOUTH **2850 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1

Thu 09/07/2017 to Thu 09/07/2017 **CANCELLED** **by HQ** **09/06/2017**
0001 Continuous 0200
Work scheduled by: ORU

	REV (Export)
SCH - HQ - NY	**500 MW**
Impacts Total Transfer Capability	500 MW
TTC with All Lines In Service	1000 MW

CHAT_DC_GC2

Thu 09/07/2017 to Thu 09/07/2017 **CANCELLED** **by HQ** **09/06/2017**
0001 Continuous 0200
Work scheduled by: ORU

	FWD (Import)
MOSES SOUTH	**2850 MW**
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

CHAT_DC_GC2

Thu 09/07/2017 to Thu 09/07/2017 **CANCELLED** **by HQ** **09/06/2017**
0001 Continuous 0200
Work scheduled by: ORU

	REV (Export)
SCH - HQ - NY	**500 MW**
Impacts Total Transfer Capability	500 MW
TTC with All Lines In Service	1000 MW

SCH-HQ-NYISO_LIMIT_700

Thu 09/07/2017 to Thu 09/07/2017 **CANCELLED** **by HQ** **09/06/2017**
0001 Continuous 0200
Work scheduled by: ORU

	FWD (Import)
SCH - HQ - NY	**700 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	1500 MW

COOPERS_-DOLSONAV_345_CCDA42

Fri 09/08/2017 to Fri 09/08/2017 **CANCELLED** **by NYPA** **09/08/2017**
0601 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	**2720 MW**
Impacts Total Transfer Capability	255 MW
TTC with All Lines In Service	2975 MW

DOLSONAV-ROCKTVRN_345_DART44

Fri 09/08/2017 to Fri 09/08/2017 **CANCELLED** **by NYPA** **09/08/2017**
0601 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	**2720 MW**
Impacts Total Transfer Capability	255 MW
TTC with All Lines In Service	2975 MW

E13THSTA-FARRAGUT_345_46

Sat 09/09/2017 to Sat 09/09/2017
0001 Continuous 0145
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6

Sat 09/09/2017 to Sat 09/09/2017 **CANCELLED by ConEd 09/09/2017**
0200 Continuous 0230
Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**320 MW**
Impacts Total Transfer Capability	340 MW
TTC with All Lines In Service	660 MW

W49TH_ST-E13THSTA_345_M55

Sat 09/09/2017 to Sat 09/09/2017 **CANCELLED by ConEd 09/09/2017**
0200 Continuous 0359
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

W49TH_ST_345KV_6

Sat 09/09/2017 to Sat 09/09/2017 **CANCELLED by ConEd 09/09/2017**
0345 Continuous 0359
Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**320 MW**
Impacts Total Transfer Capability	340 MW
TTC with All Lines In Service	660 MW

DUNWODIE_345KV_5

Sat 09/09/2017 to Sat 09/09/2017
0430 Continuous 2159
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

DUNWODIE_345KV_7

Sat 09/09/2017 to Sat 09/09/2017
0430 Continuous 2159
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

SPRNBRK_-DUNWODIE_345_W75

Sat 09/09/2017 to Sat 09/09/2017
0430 Continuous 2159
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

SPRNBRK__345KV_RNS3

Sat 09/09/2017 to Sat 09/09/2017
0430 Continuous 2159
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1150

Sat 09/09/2017 0500 to Fri 10/06/2017 1700 Continuous

UPDATED **by NYISO** **08/30/2017**

Work scheduled by: NGrid

	FWD (Import)
SCH - OH - NY	**1450 MW**
Impacts Total Transfer Capability	550 MW
TTC with All Lines In Service	2000 MW

DUNWODIE_345KV_5

Sat 09/09/2017 2200 to Sun 09/10/2017 0200 Continuous

UPDATED **by CE** **06/20/2017**

Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

DUNWODIE_345KV_7

Sat 09/09/2017 2200 to Sun 09/10/2017 0200 Continuous

UPDATED **by CE** **06/20/2017**

Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

SPRNBRK_-DUNWODIE_345_W75

Sat 09/09/2017 2200 to Sun 09/10/2017 0200 Continuous

UPDATED **by CE** **06/20/2017**

Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

SPRNBRK__345KV_RNS3

Sat 09/09/2017 2200 to Sun 09/10/2017 0200 Continuous

UPDATED **by CE** **06/20/2017**

Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

MOSES___-ADIRNDCK_230_MA1

Mon 09/11/2017 0700 to Sat 09/16/2017 1730 Continuous

EXTENDED **by NYPA** **08/14/2017**

Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2100 MW**
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

CANANDGA-STONYRDG_230_68

Mon 09/11/2017 0800 to Mon 09/11/2017 1600 Continuous

Work scheduled by: NYSEG

	FWD (Import)
DYSINGER EAST	**2850 MW**
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Tue 09/12/2017 to Wed 09/13/2017 **UPDATED** **by LI** **08/29/2017**
0001 Continuous 2359
Work scheduled by: LI

	FWD (Import)
SCH - PJM_NEPTUNE	**0 MW**
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	660 MW

NEWBRDGE-DUFFYAVE_345_501

Tue 09/12/2017 to Wed 09/13/2017 **UPDATED** **by LI** **08/29/2017**
0001 Continuous 2359
Work scheduled by: LI

	FWD (Import)
SCH - PJM_NEPTUNE	**0 MW**
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	660 MW

NEWBRDGE_345_138_BK_1

Tue 09/12/2017 to Wed 09/13/2017 **UPDATED** **by LI** **08/29/2017**
0001 Continuous 2359
Work scheduled by: LI

	FWD (Import)
SCH - PJM_NEPTUNE	**375 MW**
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

NEWBRDGE_345_138_BK_2

Tue 09/12/2017 to Wed 09/13/2017 **UPDATED** **by LI** **08/29/2017**
0001 Continuous 2359
Work scheduled by: LI

	FWD (Import)
SCH - PJM_NEPTUNE	**375 MW**
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

SCH-NE-NYISO_LIMIT_1000

Tue 09/12/2017 to Fri 09/15/2017 **UPDATED** **by ISONE** **09/08/2017**
0100 Continuous 1800
Work scheduled by: ISONE

	FWD (Import)
SCH - NE - NY	**1200 MW**
Impacts Total Transfer Capability	200 MW
TTC with All Lines In Service	1400 MW

STONYRDG-HILLSIDE_230_72

Wed 09/13/2017 to Wed 09/13/2017
0800 Continuous 1600
Work scheduled by: NYSEG

	FWD (Import)
DYSINGER EAST	**2850 MW**
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

HURLYAVE-ROSETON__345_303

Wed 09/13/2017 to Fri 09/29/2017 **UPDATED** **by CHGE** **08/28/2017**
0800 Continuous 1600
Work scheduled by: CHGE

	FWD (Import)
UPNY CONED	**4100 MW**
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK__345KV_RNS5

Sat 09/16/2017 to Sat 09/16/2017 **UPDATED** **by CE** **09/03/2017**
0001 Continuous 1830
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3200 MW**
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

SPRNBRK_-W49TH_ST_345_M51

Sat 09/16/2017 to Tue 09/26/2017 **UPDATED** **by CE** **09/03/2017**
0001 Continuous 0300
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3200 MW**
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

MARCY___-N.SCTLND_345_18

Sat 09/16/2017 to Sun 09/17/2017
0800 Continuous 1700
Work scheduled by: NGrid

ARR: 19

	FWD (Import)
CENTRAL EAST - VC	**2090 MW**
Impacts Total Transfer Capability	885 MW
TTC with All Lines In Service	2975 MW

MARCY_SO_SERIES_COMP_I/S

Sun 09/17/2017 to Mon 10/02/2017
1700 Continuous 0659
Work scheduled by: NYISO

	FWD (Import)
CENTRAL EAST - VC	**2740 MW**
Impacts Total Transfer Capability	235 MW
TTC with All Lines In Service	2975 MW

NIAGARA__345_230_AT4

Mon 09/18/2017 to Fri 09/22/2017
0500 Continuous 1900
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	**2000 MW**	**1400 MW**
Impacts Total Transfer Capability	0 MW	200 MW
TTC with All Lines In Service	2000 MW	1600 MW

CEDARS__-ROSEMNTB_115_2/22

Mon 09/18/2017 to Mon 09/18/2017 **UPDATED** **by HQ** **09/06/2017**
0530 Continuous 1900
Work scheduled by: HQ

ARR: 38

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**95 MW**	**40 MW**
Impacts Total Transfer Capability	95 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

SCH-HQ_CEDARS-NYISO_LIMIT_80

Mon 09/18/2017 to Mon 09/18/2017 **UPDATED** **by HQ** **09/06/2017**
0530 Continuous 1900
Work scheduled by: HQ

	FWD (Import)
SCH - HQ_CEDARS	**80 MW**
Impacts Total Transfer Capability	110 MW
TTC with All Lines In Service	190 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GILBOA__-N.SCTLND_345_GNS-1

Mon 09/18/2017 to Fri 10/13/2017 **EXTENDED** **by NYPA** **06/09/2017**
0630 Continuous 1700
Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	**2520 MW**
Impacts Total Transfer Capability	455 MW
TTC with All Lines In Service	2975 MW

MOSES___-ADIRNDCK_230_MA1

Mon 09/18/2017 to Sat 09/23/2017 **UPDATED** **by NYPA** **08/15/2017**
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2100 MW**
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

ROCHESTR-PANNELL__345_RP1

Mon 09/18/2017 to Sat 09/23/2017 **UPDATED** **by PA** **09/05/2017**
0730 Continuous 1530
Work scheduled by: RGE

	FWD (Import)
DYSINGER EAST	**2300 MW**
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

ALCOA_R8105_TIE_B

Mon 09/18/2017 to Mon 09/25/2017
0800 Continuous 1500
Work scheduled by: NGrid

	FWD (Import)
MOSES SOUTH	**3100 MW**
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	3150 MW

ALCOA_R8105_TIE_B

Mon 09/18/2017 to Mon 09/25/2017
0800 Continuous 1500
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**70 MW**	**0 MW**
Impacts Total Transfer Capability	120 MW	40 MW
TTC with All Lines In Service	190 MW	40 MW

SCH-HQ_CEDARS-NYISO_LIMIT_140

Mon 09/18/2017 to Fri 09/29/2017
0800 Continuous 1700
Work scheduled by: HQ

	FWD (Import)
SCH - HQ_CEDARS	**140 MW**
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	190 MW

SCH-NYISO-HQ_CEDARS_LIMIT_0

Mon 09/18/2017 to Fri 09/29/2017
0800 Continuous 1700
Work scheduled by: HQ

	REV (Export)
SCH - HQ_CEDARS	**0 MW**
Impacts Total Transfer Capability	40 MW
TTC with All Lines In Service	40 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS5

Tue 09/19/2017 to Tue 09/19/2017 **UPDATED** **by CONED** **08/10/2017**
0001 Continuous 0100
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**3800 MW**
Impacts Total Transfer Capability	1300 MW
TTC with All Lines In Service	5100 MW

PLSNTVLY-WOOD_ST__345_F30

Tue 09/19/2017 to Wed 09/20/2017 **UPDATED** **by CONED** **08/10/2017**
0001 Continuous 2359
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**4000 MW**
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

LINDEN__-GOETHALS_230_A2253

Tue 09/19/2017 to Sun 10/01/2017 **EXTENDED** **by PJM** **07/28/2017**
0200 Continuous 0100
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	**2100 MW**	**1350 MW**
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2100 MW	1350 MW

PLSNTVLY_345KV_RNS5

Wed 09/20/2017 to Wed 09/20/2017 **UPDATED** **by CONED** **08/10/2017**
2330 Continuous 2359
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**3800 MW**
Impacts Total Transfer Capability	1300 MW
TTC with All Lines In Service	5100 MW

SCH-IMO_NY_NIAG_SOUTH_BUS_W/BB

Mon 09/25/2017 to Fri 09/29/2017 **UPDATED** **by NYISO** **08/22/2017**
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	**1000 MW**	**1150 MW**
Impacts Total Transfer Capability	1000 MW	450 MW
TTC with All Lines In Service	2000 MW	1600 MW

MOSES___-ADIRNDCK_230_MA1

Mon 09/25/2017 to Sat 09/30/2017 **UPDATED** **by NYPA** **08/15/2017**
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2100 MW**
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

LEEDS____345KV_R395

Mon 09/25/2017 to Mon 09/25/2017
0800 Daily(No Weekends) 1400
Work scheduled by: NGrid

	FWD (Import)
UPNY CONED	**3800 MW**
Impacts Total Transfer Capability	1300 MW
TTC with All Lines In Service	5100 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FIVEMILE-STOLLERD_345_29

Mon 09/25/2017 to Mon 10/16/2017
0800 Continuous 1400
Work scheduled by: NYSEG

	FWD (Import)	REV (Export)
SCH - PJ - NY	**2100 MW**	**1350 MW**
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2100 MW	1350 MW

SPRNBRK__345KV_RNS5

Tue 09/26/2017 to Tue 09/26/2017 **UPDATED** **by CE** **09/03/2017**
0230 Continuous 0300
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3200 MW**
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

PANNELL_-CLAY_____345_2

Tue 09/26/2017 to Wed 09/27/2017
0730 Continuous 1500
Work scheduled by: RGE

	FWD (Import)
WEST CENTRAL	**1300 MW**
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	2250 MW

E13THSTA-FARRAGUT_345_46

Wed 09/27/2017 to Wed 09/27/2017
0001 Continuous 0030
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

SCH-NYISO-NE_LIMIT_800

Wed 09/27/2017 to Wed 09/27/2017
0600 Continuous 1600
Work scheduled by: ISONE

	REV (Export)
SCH - NE - NY	**1000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	1600 MW

SPRNBRK__345KV_RS3 & SPRNBRK__345KV_RS4

Sun 10/01/2017 to Tue 10/03/2017
0001 0300
Work scheduled by:

	FWD (Import)
SPR/DUN-SOUTH	**3200 MW**
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

SPRNBRK__345KV_RNS4

Mon 10/02/2017 to Mon 10/02/2017
0001 Continuous 1900
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3200 MW**
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5

Mon 10/02/2017 to Tue 10/03/2017
0001 Continuous 0300
Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**315 MW**
Impacts Total Transfer Capability	345 MW
TTC with All Lines In Service	660 MW

PLSNTVLY-EFISHKIL_345_F36

Mon 10/02/2017 to Mon 10/16/2017
0001 Continuous 0300
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**4000 MW**
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

SPRNBRK_-W49TH_ST_345_M52

Mon 10/02/2017 to Wed 11/01/2017
0001 Continuous 0300
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3200 MW**
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

CHAT_DC_GC2

Mon 10/02/2017 to Wed 11/15/2017
0500 Continuous 2000
Work scheduled by: HQ

	FWD (Import)
MOSES SOUTH	**2850 MW**
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

CHAT_DC_GC2

Mon 10/02/2017 to Wed 11/15/2017
0500 Continuous 2000
Work scheduled by: HQ

	REV (Export)
SCH - HQ - NY	**500 MW**
Impacts Total Transfer Capability	500 MW
TTC with All Lines In Service	1000 MW

SCH-HQ-NYISO_LIMIT_1150

Mon 10/02/2017 to Wed 11/15/2017
0500 Continuous 2000
Work scheduled by: HQ

	FWD (Import)
SCH - HQ - NY	**1150 MW**
Impacts Total Transfer Capability	350 MW
TTC with All Lines In Service	1500 MW

SHOR_NPX-SHOREHAM_138_CSC

Mon 10/02/2017 to Sat 10/07/2017
0600 Continuous 1400
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_CSC	**0 MW**	**0 MW**
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-ROCHESTR_345_NR2

Mon 10/02/2017 to Fri 10/06/2017
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
DYSINGER EAST	**1700 MW**
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

FRASER__-COOPERS__345_33

Mon 10/02/2017 to Fri 10/13/2017
0700 Continuous 1900
Work scheduled by: NYSEG

	FWD (Import)
CENTRAL EAST - VC	**2395 MW**
Impacts Total Transfer Capability	580 MW
TTC with All Lines In Service	2975 MW

HOMRC_NY-MAINS_NY_345_47

Mon 10/02/2017 to Fri 10/27/2017
0700 Continuous 1730
Work scheduled by: NYSEG

	FWD (Import)	REV (Export)
SCH - PJ - NY	**2100 MW**	**1350 MW**
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2100 MW	1350 MW

ROTTRDAM-EASTOVER_230_38

Mon 10/02/2017 to Wed 10/04/2017
0800 Continuous 1200
Work scheduled by: NGrid

ARR: 77

	REV (Export)
SCH - NE - NY	**1400 MW**
Impacts Total Transfer Capability	200 MW
TTC with All Lines In Service	1600 MW

SPRNBRK__345KV_RNS4

Mon 10/02/2017 to Fri 10/06/2017
1901 Continuous 0300
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3200 MW**
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

W49TH_ST_345KV_5

Tue 10/03/2017 to Fri 10/06/2017
0301 Continuous 2100
Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**315 MW**
Impacts Total Transfer Capability	345 MW
TTC with All Lines In Service	660 MW

BECK____-NIAGARA__345_PA302

Wed 10/04/2017 to Thu 10/05/2017 **UPDATED** **by PA** **08/11/2017**
0600 Continuous 1700
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	**900 MW**	**800 MW**
Impacts Total Transfer Capability	1100 MW	800 MW
TTC with All Lines In Service	2000 MW	1600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS_____345_393

Fri 10/06/2017 to Fri 10/06/2017
0700 Daily(No Weekends) 0800
Work scheduled by: NGrid

ARR: 78

	FWD (Import)	REV (Export)
SCH - NE - NY	**950 MW**	**1000 MW**
Impacts Total Transfer Capability	450 MW	600 MW
TTC with All Lines In Service	1400 MW	1600 MW

BERKSHIR-ALPS_____345_393

Fri 10/06/2017 to Fri 10/06/2017
0700 Daily(No Weekends) 0800
Work scheduled by: NGrid

ARR: 78

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312

Fri 10/06/2017 to Fri 10/06/2017
0700 0800
Work scheduled by:

ARR: 78

	FWD (Import)	REV (Export)
SCH - NE - NY	**950 MW**	**1000 MW**
Impacts Total Transfer Capability	450 MW	600 MW
TTC with All Lines In Service	1400 MW	1600 MW

BERKSHIR-NORTHFLD_345_312

Fri 10/06/2017 to Sat 10/28/2017
0700 Continuous 1600
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY	**900 MW**	**1200 MW**
Impacts Total Transfer Capability	500 MW	400 MW
TTC with All Lines In Service	1400 MW	1600 MW

BERKSHIR-NORTHFLD_345_312

Fri 10/06/2017 to Sat 10/28/2017
0700 Continuous 1600
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

BERKSHIR-ALPS_____345_393

Fri 10/06/2017 to Thu 10/12/2017
0800 Continuous 1700
Work scheduled by: NGrid

ARR: 78

	FWD (Import)	REV (Export)
SCH - NE - NY	**950 MW**	**1000 MW**
Impacts Total Transfer Capability	450 MW	600 MW
TTC with All Lines In Service	1400 MW	1600 MW

BERKSHIR-ALPS_____345_393

Fri 10/06/2017 to Thu 10/12/2017
0800 Continuous 1700
Work scheduled by: NGrid

ARR: 78

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312

Fri 10/06/2017 to Thu 10/12/2017
0800 1700
Work scheduled by:

ARR: 78

	FWD (Import)	REV (Export)
SCH - NE - NY	**950 MW**	**1000 MW**
Impacts Total Transfer Capability	450 MW	600 MW
TTC with All Lines In Service	1400 MW	1600 MW

SCH-NE-NYISO_LIMIT_800

Mon 10/09/2017 to Thu 10/12/2017
0700 Continuous 1700
Work scheduled by: ISONE

	FWD (Import)
SCH - NE - NY	**1000 MW**
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	1400 MW

WETHSRFD-MEYER____230_85/87

Mon 10/09/2017 to Fri 10/20/2017
0700 Continuous 1400
Work scheduled by: NYSEG

	FWD (Import)
DYSINGER EAST	**2850 MW**
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

MARCY_SO_SERIES_COMP_I/S

Fri 10/13/2017 to Tue 10/31/2017
1900 Continuous 2359
Work scheduled by: NYISO

	FWD (Import)
CENTRAL EAST - VC	**2740 MW**
Impacts Total Transfer Capability	235 MW
TTC with All Lines In Service	2975 MW

CHATGUAY-MASSENA__765_7040

Sat 10/14/2017 to Sat 10/28/2017 **UPDATED** **by NYISO** **03/24/2017**
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**1550 MW**
Impacts Total Transfer Capability	1600 MW
TTC with All Lines In Service	3150 MW

CHATGUAY-MASSENA__765_7040

Sat 10/14/2017 to Sat 10/28/2017 **UPDATED** **by NYISO** **03/24/2017**
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ - NY	**0 MW**	**0 MW**
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

MARCY____765_345_AT1

Sat 10/14/2017 to Sat 10/28/2017 **UPDATED** **by NYISO** **03/24/2017**
0700 Continuous 1530
Work scheduled by: NYPA

ARR: 19

	FWD (Import)
MOSES SOUTH	**1750 MW**
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY____765_345_AT2

Sat 10/14/2017 to Sat 10/28/2017 **UPDATED** **by NYISO** **03/24/2017**
0700 Continuous 1530
Work scheduled by: NYPA

ARR: 19

	FWD (Import)
MOSES SOUTH	**1700 MW**
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

MASSENA_-MARCY____765_MSU1

Sat 10/14/2017 to Sat 10/28/2017 **UPDATED** **by NYISO** **03/24/2017**
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	**2265 MW**
Impacts Total Transfer Capability	710 MW
TTC with All Lines In Service	2975 MW

MASSENA_-MARCY____765_MSU1

Sat 10/14/2017 to Sat 10/28/2017 **UPDATED** **by NYISO** **03/24/2017**
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**500 MW**
Impacts Total Transfer Capability	2650 MW
TTC with All Lines In Service	3150 MW

MASSENA_-MARCY____765_MSU1

Sat 10/14/2017 to Sat 10/28/2017 **UPDATED** **by NYISO** **03/24/2017**
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ - NY	**475 MW**	**1000 MW**
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

MASSENA_-MARCY____765_MSU1 & CHATGUAY-MASSENA__765_7040

Sat 10/14/2017 to Sat 10/28/2017
0700 1530
Work scheduled by:

	FWD (Import)
MOSES SOUTH	**500 MW**
Impacts Total Transfer Capability	2650 MW
TTC with All Lines In Service	3150 MW

MASSENA_-MARCY____765_MSU1 & MARCY_SO_SERIES_COMP_I/S

Sat 10/14/2017 to Sat 10/28/2017
0700 1530
Work scheduled by:

	FWD (Import)
CENTRAL EAST - VC	**2080 MW**
Impacts Total Transfer Capability	895 MW
TTC with All Lines In Service	2975 MW

MOSES___-MASSENA__230_MMS1 & MOSES___-MASSENA__230_MMS2

Sat 10/14/2017 to Sat 10/28/2017
0700 1530
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ - NY	**850 MW**	**0 MW**
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO_NY_NIAG_NRTH_BUS_W/BB

Mon 10/16/2017 to Fri 10/20/2017
0500 Continuous 1700
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	**1000 MW**	**1150 MW**
Impacts Total Transfer Capability	1000 MW	450 MW
TTC with All Lines In Service	2000 MW	1600 MW

COOPERS_-MIDDLETP_345_CCRT34

Mon 10/16/2017 to Sat 10/28/2017 **UPDATED** **by NYISO** **06/21/2017**
0700 Continuous 1500
Work scheduled by: NYSEG

	FWD (Import)
CENTRAL EAST - VC	**2720 MW**
Impacts Total Transfer Capability	255 MW
TTC with All Lines In Service	2975 MW

HURLYAVE-ROSETON__345_303

Mon 10/16/2017 to Fri 11/03/2017 **UPDATED** **by CH** **06/07/2017**
0800 Continuous 1600
Work scheduled by: CHGE

	FWD (Import)
UPNY CONED	**4100 MW**
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

LEEDS___-HURLYAVE_345_301

Mon 10/16/2017 to Fri 11/03/2017
0800 Continuous 1600
Work scheduled by: CHGE

	FWD (Import)
UPNY CONED	**4100 MW**
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

SPRNBRK__345KV_RNS4

Tue 10/17/2017 to Sat 10/28/2017
0301 Continuous 0300
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3200 MW**
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

BERKSHIR-ALPS_____345_393

Wed 10/18/2017 to Wed 10/18/2017
0700 Continuous 1700
Work scheduled by: NGrid **ARR: 78**

	FWD (Import)	REV (Export)
SCH - NE - NY	**950 MW**	**1000 MW**
Impacts Total Transfer Capability	450 MW	600 MW
TTC with All Lines In Service	1400 MW	1600 MW

BERKSHIR-ALPS_____345_393

Wed 10/18/2017 to Wed 10/18/2017
0700 Continuous 1700
Work scheduled by: NGrid **ARR: 78**

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312

Wed 10/18/2017 0700 to Wed 10/18/2017 1700

Work scheduled by:

ARR: 78

	FWD (Import)	REV (Export)
SCH - NE - NY	**950 MW**	**1000 MW**
Impacts Total Transfer Capability	450 MW	600 MW
TTC with All Lines In Service	1400 MW	1600 MW

NIAGARA_-KINTIGH__345_NS1-38

Mon 10/23/2017 0600 to Thu 11/02/2017 1600 Continuous

Work scheduled by: NYPA

UPDATED **by NYSEG** **09/05/2017**

	FWD (Import)
DYSINGER EAST	**1700 MW**
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

S.RIPLEY-DUNKIRK__230_68

Mon 10/23/2017 0800 to Thu 10/26/2017 1500 Continuous

Work scheduled by: PJM

UPDATED **by NYISO** **08/01/2017**

	FWD (Import)	REV (Export)
SCH - PJ - NY	**1950 MW**	**1350 MW**
Impacts Total Transfer Capability	150 MW	0 MW
TTC with All Lines In Service	2100 MW	1350 MW

BERKSHIR-ALPS_____345_393

Wed 10/25/2017 0700 to Wed 10/25/2017 1700 Continuous

Work scheduled by: NGrid

ARR: 78

	FWD (Import)	REV (Export)
SCH - NE - NY	**950 MW**	**1000 MW**
Impacts Total Transfer Capability	450 MW	600 MW
TTC with All Lines In Service	1400 MW	1600 MW

BERKSHIR-ALPS_____345_393

Wed 10/25/2017 0700 to Wed 10/25/2017 1700 Continuous

Work scheduled by: NGrid

ARR: 78

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312

Wed 10/25/2017 0700 to Wed 10/25/2017 1700

Work scheduled by:

ARR: 78

	FWD (Import)	REV (Export)
SCH - NE - NY	**950 MW**	**1000 MW**
Impacts Total Transfer Capability	450 MW	600 MW
TTC with All Lines In Service	1400 MW	1600 MW

S.RIPLEY-DUNKIRK__230_68

Thu 10/26/2017 1501 to Sat 02/01/2020 0000 Continuous

Work scheduled by: NYISO

UPDATED **by NYISO** **05/17/2017**

	FWD (Import)	REV (Export)
SCH - PJ - NY	**1950 MW**	**1350 MW**
Impacts Total Transfer Capability	150 MW	0 MW
TTC with All Lines In Service	2100 MW	1350 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5

Fri 10/27/2017 to Wed 11/01/2017
0001 Continuous 0300
Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**315 MW**
Impacts Total Transfer Capability	345 MW
TTC with All Lines In Service	660 MW

SPRNBRK__345KV_RNS4

Sat 10/28/2017 to Wed 11/01/2017
0301 Continuous 0300
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3200 MW**
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

BERKSHIR-ALPS_____345_393

Sat 10/28/2017 to Sat 10/28/2017
1500 Daily 1600
Work scheduled by: NGrid

ARR: 78

	FWD (Import)	REV (Export)
SCH - NE - NY	**950 MW**	**1000 MW**
Impacts Total Transfer Capability	450 MW	600 MW
TTC with All Lines In Service	1400 MW	1600 MW

BERKSHIR-ALPS_____345_393

Sat 10/28/2017 to Sat 10/28/2017
1500 Daily 1600
Work scheduled by: NGrid

ARR: 78

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312

Sat 10/28/2017 to Sat 10/28/2017
1500 1600
Work scheduled by:

ARR: 78

	FWD (Import)	REV (Export)
SCH - NE - NY	**950 MW**	**1000 MW**
Impacts Total Transfer Capability	450 MW	600 MW
TTC with All Lines In Service	1400 MW	1600 MW

MOSES___-ADIRNDCK_230_MA2

Mon 10/30/2017 to Fri 11/03/2017
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2100 MW**
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

PLSNTVLY-EFISHKIL_345_F36

Wed 11/01/2017 to Sat 11/04/2017
0001 Continuous 0300
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**4000 MW**
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARION__-FARRAGUT_345_C3403

Thu 11/02/2017 to Fri 11/03/2017
0200 Continuous 0100
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	**2300 MW**	**1450 MW**
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2300 MW	1450 MW

E13THSTA-FARRAGUT_345_46

Thu 11/02/2017 to Thu 11/02/2017
0230 Continuous 0300
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

BERKSHIR-ALPS_____345_393

Thu 11/02/2017 to Sat 11/04/2017 **UPDATED** **by NE** **08/02/2017**
0700 Continuous 1700
Work scheduled by: NGrid
ARR: 78

	FWD (Import)	REV (Export)
SCH - NE - NY	**1300 MW**	**1300 MW**
Impacts Total Transfer Capability	100 MW	300 MW
TTC with All Lines In Service	1400 MW	1600 MW

BERKSHIR-ALPS_____345_393

Thu 11/02/2017 to Sat 11/04/2017 **UPDATED** **by NE** **08/02/2017**
0700 Continuous 1700
Work scheduled by: NGrid
ARR: 78

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312

Thu 11/02/2017 to Sat 11/04/2017
0700 1700
Work scheduled by:
ARR: 78

	FWD (Import)	REV (Export)
SCH - NE - NY	**1300 MW**	**1300 MW**
Impacts Total Transfer Capability	100 MW	300 MW
TTC with All Lines In Service	1400 MW	1600 MW

BERKSHIR-NORTHFLD_345_312

Thu 11/02/2017 to Sat 11/04/2017 **UPDATED** **by NE** **08/02/2017**
0700 Continuous 1700
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
SCH - NE - NY	**1400 MW**	**1450 MW**
Impacts Total Transfer Capability	0 MW	150 MW
TTC with All Lines In Service	1400 MW	1600 MW

BERKSHIR-NORTHFLD_345_312

Thu 11/02/2017 to Sat 11/04/2017 **UPDATED** **by NE** **08/02/2017**
0700 Continuous 1700
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-EFISHKIL_345_F36

Mon 11/06/2017 to Wed 11/08/2017
0001 Continuous 0300
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**4000 MW**
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

FRASANNX-COOPERS__345_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017
0600 Continuous 1700
Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	**2500 MW**
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

MARCY___-FRASANNX_345_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017
0600 Continuous 1700
Work scheduled by: NYPA

ARR: 19

	FWD (Import)
CENTRAL EAST - VC	**2500 MW**
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/06/2017 to Thu 11/09/2017
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2300 MW**
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

LINDN_CG-LNDVFT___345_V-3022

Mon 11/06/2017 to Thu 11/09/2017
0800 Continuous 1500
Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJM_VFT	**0 MW**	**0 MW**
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

SCRIBA__-VOLNEY___345_20

Mon 11/06/2017 to Fri 11/17/2017
0800 Continuous 1630
Work scheduled by: NGrid

	FWD (Import)
OSWEGO EXPORT	**5250 MW**
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	5250 MW

W49TH_ST_345KV_5

Fri 11/10/2017 to Fri 11/10/2017
0001 Continuous 0030
Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**315 MW**
Impacts Total Transfer Capability	345 MW
TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK_-W49TH_ST_345_M52

Fri 11/10/2017 to Mon 11/13/2017
0001 Continuous 0300
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3200 MW**
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

SPRNBRK__345KV_RNS4

Fri 11/10/2017 to Mon 11/13/2017
0001 Continuous 0300
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3200 MW**
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

SPRNBRK__345KV_RS3 & SPRNBRK__345KV_RS4

Sun 11/12/2017 to Wed 11/15/2017
0001 0300
Work scheduled by:

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

W49TH_ST_345KV_5

Mon 11/13/2017 to Mon 11/13/2017
0230 Continuous 0300
Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**315 MW**
Impacts Total Transfer Capability	345 MW
TTC with All Lines In Service	660 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/13/2017 to Fri 11/17/2017
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2300 MW**
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

SPRNBRK__345KV_RNS4

Wed 11/15/2017 to Fri 11/17/2017
0001 Continuous 0100
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3200 MW**
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

E13THSTA-FARRAGUT_345_45

Sat 11/18/2017 to Tue 05/15/2018
0000 Continuous 2359
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST-E13THSTA_345_M54

Sat 11/18/2017 to Tue 05/15/2018
0000 Continuous 2359
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

EGRDNCTY_345_138_AT1

Sun 11/19/2017 to Sat 12/23/2017 **UPDATED** **by LI** **08/01/2017**
0001 Continuous 2359
Work scheduled by: LI

	FWD (Import)
CONED - LIPA	**1250 MW**
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	1500 MW

EGRDNCTY_345_138_AT2

Sun 11/19/2017 to Sat 12/23/2017 **UPDATED** **by LI** **08/01/2017**
0001 Continuous 2359
Work scheduled by: LI

	FWD (Import)
CONED - LIPA	**1250 MW**
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	1500 MW

SPRNBRK_-EGRDNCTR_345_Y49

Sun 11/19/2017 to Sat 12/23/2017 **UPDATED** **by LI** **08/01/2017**
0001 Continuous 2359
Work scheduled by: LI

	FWD (Import)
CONED - LIPA	**775 MW**
Impacts Total Transfer Capability	725 MW
TTC with All Lines In Service	1500 MW

MOSES___-ADIRNDCK_230_MA1

Mon 11/20/2017 to Wed 11/22/2017
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2300 MW**
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

N.SCTLND-LEEDS____345_93

Mon 11/20/2017 to Mon 11/20/2017
0800 Daily(No Weekends) 1430
Work scheduled by: NGrid

	FWD (Import)
CENTRAL EAST - VC	**2650 MW**
Impacts Total Transfer Capability	325 MW
TTC with All Lines In Service	2975 MW

MOSES___-ADIRNDCK_230_MA1

Mon 11/27/2017 to Fri 12/01/2017
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2300 MW**
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROSETON_-EFISHKIL_345_RFK305

Mon 11/27/2017 to Fri 12/01/2017
0800 Continuous 1600
Work scheduled by: CHGE

	FWD (Import)
UPNY CONED	**4800 MW**
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	5100 MW

ROTTRDAM-EASTOVER_230_38

Mon 11/27/2017 to Thu 11/30/2017
0900 Continuous 1500
Work scheduled by: NGrid

ARR: 77

	FWD (Import)	REV (Export)
SCH - NE - NY	**1400 MW**	**1400 MW**
Impacts Total Transfer Capability	0 MW	200 MW
TTC with All Lines In Service	1400 MW	1600 MW

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Sun 12/03/2017 to Tue 12/05/2017
0001 0300
Work scheduled by:

	FWD (Import)
UPNY CONED	**3800 MW**
Impacts Total Transfer Capability	1300 MW
TTC with All Lines In Service	5100 MW

LEEDS___-PLSNTVLY_345_92

Mon 12/04/2017 to Mon 12/18/2017
0001 Continuous 0300
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**3800 MW**
Impacts Total Transfer Capability	1300 MW
TTC with All Lines In Service	5100 MW

PLSNTVLY_345KV_RNS5

Mon 12/04/2017 to Mon 12/18/2017
0001 Continuous 0300
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**3800 MW**
Impacts Total Transfer Capability	1300 MW
TTC with All Lines In Service	5100 MW

MARCY____765_345_AT2

Mon 12/04/2017 to Fri 12/08/2017
0500 Continuous 1630
Work scheduled by: NYPA

ARR: 19

	FWD (Import)
MOSES SOUTH	**1700 MW**
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/11/2017 to Fri 12/15/2017
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2300 MW**
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

Mon 12/18/2017 to Fri 12/22/2017 **UPDATED** **by NYPA** **10/23/2016**
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2300 MW**
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

MARCY____765_345_AT2

Wed 12/27/2017 to Thu 12/28/2017
0500 Continuous 1630
Work scheduled by: NYPA **ARR: 19**

	FWD (Import)
MOSES SOUTH	**1700 MW**
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

LEEDS___-PLSNTVLY_345_92

Wed 01/03/2018 to Sat 01/06/2018
0001 Continuous 0300
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**3800 MW**
Impacts Total Transfer Capability	1300 MW
TTC with All Lines In Service	5100 MW

PLSNTVLY_345KV_RNS5

Wed 01/03/2018 to Sat 01/06/2018
0001 Continuous 0300
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**3800 MW**
Impacts Total Transfer Capability	1300 MW
TTC with All Lines In Service	5100 MW

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Fri 01/05/2018 to Mon 01/08/2018
0001 0300
Work scheduled by:

	FWD (Import)
UPNY CONED	**3800 MW**
Impacts Total Transfer Capability	1300 MW
TTC with All Lines In Service	5100 MW

PLSNTVLY_345KV_RNS5

Mon 01/08/2018 to Wed 01/10/2018
0001 Continuous 0300
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**3800 MW**
Impacts Total Transfer Capability	1300 MW
TTC with All Lines In Service	5100 MW

MARCY____765_345_AT2

Sat 01/20/2018 to Sat 01/20/2018
0500 Continuous 1730
Work scheduled by: NYPA **ARR: 19**

	FWD (Import)
MOSES SOUTH	**1700 MW**
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY____765_345_AT2

Sat 02/03/2018 to Sat 02/03/2018
0500 Continuous 1730
Work scheduled by: NYPA

ARR: 19

	FWD (Import)
MOSES SOUTH	**1700 MW**
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

MARCY____765_345_AT2

Mon 02/05/2018 to Fri 02/09/2018
0500 Continuous 1730
Work scheduled by: NYPA

ARR: 19

	FWD (Import)
MOSES SOUTH	**1700 MW**
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

HUDSONP_-FARRAGUT_345_B3402

Sun 02/18/2018 to Sun 04/01/2018
0001 Continuous 2359
Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJ - NY	**2300 MW**	**1450 MW**
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2300 MW	1450 MW

MARCY___-EDIC_____345_UE1-7

Tue 02/20/2018 to Fri 02/23/2018
0500 Continuous 1730
Work scheduled by: NYPA

ARR: 19&16

	FWD (Import)
OSWEGO EXPORT	**5250 MW**
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	5250 MW

DUNWODIE_345KV_7

Thu 03/01/2018 to Thu 03/01/2018
0001 Continuous 0100
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

DUNWODIE_345KV_8

Thu 03/01/2018 to Thu 03/01/2018
0001 Continuous 0100
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

DUNWODIE-MOTTHAVN_345_72

Thu 03/01/2018 to Thu 04/05/2018
0001 Continuous 0300
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

S.RIPLEY-DUNKIRK__230_68

Mon 03/19/2018 to Fri 04/20/2018
1000 Continuous 1559
Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJ - NY	**1950 MW**	**1350 MW**
Impacts Total Transfer Capability	350 MW	100 MW
TTC with All Lines In Service	2300 MW	1450 MW

DUNWODIE_345KV_7

Thu 04/05/2018 to Thu 04/05/2018
0200 Continuous 0300
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

DUNWODIE_345KV_8

Thu 04/05/2018 to Thu 04/05/2018
0200 Continuous 0300
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 04/16/2018 to Tue 05/01/2018
0001 Continuous 1800
Work scheduled by: PJM

	FWD (Import)
SCH - PJM_NEPTUNE	**0 MW**
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 04/16/2018 to Tue 05/01/2018
0001 Continuous 1800
Work scheduled by: PJM

	FWD (Import)
SCH - PJM_NEPTUNE	**0 MW**
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	660 MW

NEWBRDGE_345_138_BK_1

Mon 04/16/2018 to Tue 05/01/2018
0001 Continuous 1800
Work scheduled by: PJM

	FWD (Import)
SCH - PJM_NEPTUNE	**375 MW**
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

NEWBRDGE_345_138_BK_2

Mon 04/16/2018 to Tue 05/01/2018
0001 Continuous 1800
Work scheduled by: PJM

	FWD (Import)
SCH - PJM_NEPTUNE	**375 MW**
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY____765_345_AT1

Mon 04/23/2018 to Mon 04/23/2018
0500 Continuous 1730
Work scheduled by: NYPA

ARR: 19

	FWD (Import)
MOSES SOUTH	**1750 MW**
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	3150 MW

HURLYAVE-ROSETON__345_303

Mon 04/30/2018 to Fri 05/25/2018
0800 Continuous 1600
Work scheduled by: CHGE

	FWD (Import)
UPNY CONED	**4100 MW**
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

MARCY_SO_SERIES_COMP_I/S

Tue 05/01/2018 to Wed 10/31/2018
0001 Continuous 2359
Work scheduled by: NYISO

	FWD (Import)
CENTRAL EAST - VC	**2740 MW**
Impacts Total Transfer Capability	235 MW
TTC with All Lines In Service	2975 MW

MARCY____765_345_AT2

Mon 05/21/2018 to Fri 05/25/2018
0500 Continuous 1730
Work scheduled by: NYPA

ARR: 19

	FWD (Import)
MOSES SOUTH	**1700 MW**
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

MARCY____765_345_AT1

Sat 08/04/2018 to Sun 08/05/2018
0500 Continuous 1730
Work scheduled by: NYPA

ARR: 19

	FWD (Import)
MOSES SOUTH	**1750 MW**
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	3150 MW

MARCY____765_345_AT2

Tue 09/04/2018 to Sun 09/09/2018
0500 Continuous 1730
Work scheduled by: NYPA

ARR: 19

	FWD (Import)
MOSES SOUTH	**1700 MW**
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

ROSETON_-ROCKTVRN_345_311

Mon 09/10/2018 to Fri 09/28/2018
0800 Continuous 1600
Work scheduled by: CHGE

	FWD (Import)
UPNY CONED	**4400 MW**
Impacts Total Transfer Capability	700 MW
TTC with All Lines In Service	5100 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY____345KV_CSC

Tue 09/11/2018 to Tue 09/11/2018
0500 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	**2925 MW**
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	2975 MW

MARCY____345KV_CSC & MARCY_SO_SERIES_COMP_I/S

Tue 09/11/2018 to Tue 09/11/2018
0500 1730
Work scheduled by:

	FWD (Import)
CENTRAL EAST - VC	**2690 MW**
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	2975 MW

MARCY____765_345_AT2

Tue 09/11/2018 to Tue 09/11/2018
0500 Continuous 1730
Work scheduled by: NYPA **ARR: 19**

	FWD (Import)
MOSES SOUTH	**1700 MW**
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

MARCY____765_345_AT2

Thu 10/04/2018 to Fri 10/05/2018
0500 Continuous 1730
Work scheduled by: NYPA **ARR: 19**

	FWD (Import)
MOSES SOUTH	**1700 MW**
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

LEEDS___-HURLYAVE_345_301

Mon 10/22/2018 to Fri 11/16/2018
0800 Continuous 1600
Work scheduled by: CHGE

	FWD (Import)
UPNY CONED	**4100 MW**
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

MARCY____345KV_CSC

Fri 11/16/2018 to Sat 11/17/2018
0500 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	**2925 MW**
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	2975 MW

MARCY____765_345_AT2

Fri 11/16/2018 to Sat 11/17/2018
0500 Continuous 1730
Work scheduled by: NYPA **ARR: 19**

	FWD (Import)
MOSES SOUTH	**1700 MW**
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,September10, 2017 to Tuesday ,March 12, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY____765_345_AT2

Mon 12/17/2018 to Fri 12/21/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

	FWD (Import)
MOSES SOUTH	**1700 MW**
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW