

**NYISO TRANSFER LIMITATIONS**

Monday ,October 30, 2017 to Wednesday,May 01, 2019

**CENTRAL EAST** 3100MW  
**CENTRAL EAST - VC** 2975MW  
**TOTAL EAST** 6500MW  
**UPNY CONED** 5100MW  
**SPR/DUN-SOUTH** 4600MW  
**DYSINGER EAST** 3150MW  
**MOSES SOUTH** 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**HUDSONTP-W49TH\_ST\_345\_Y56**

FWD

Thu 11/24/2016 to Sun 11/05/2017

UPDATEDby PJM10/30/2017

(Import)

1500 Continuous 0300

Work scheduled by: ConEd

SCH - PJM\_HTP

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

**SCH-NYISO-HQ\_LIMIT\_800**

REV

Thu 06/08/2017 to Fri 12/15/2017

UPDATEDby HQ08/03/2017

(Export)

0600 Continuous 1700

Work scheduled by: HQ

SCH - HQ - NY

**800 MW**

Impacts Total Transfer Capability 200 MW

TTC with All Lines In Service 1000 MW

**SCH-HQ-NYISO\_LIMIT\_1450**

FWD

Tue 08/01/2017 to Fri 12/15/2017

(Import)

2100 Continuous 1600

Work scheduled by: HQ

SCH - HQ - NY

**1450 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 1500 MW

**SCH-IMO-NYISO\_LIMIT\_1450**

FWD

Tue 08/29/2017 to Tue 10/31/2017

EXTENDEDby NYISO07/28/2017

(Import)

1230 Continuous 2359

Work scheduled by: NYISO

SCH - OH - NY

**1750 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 2000 MW

**SPRNBK\_-W49TH\_ST\_345\_M52**

FWD

Sun 10/01/2017 to Sat 11/04/2017

(Import)

0001 Continuous 2359

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

**CHAT\_DC\_GC2**

FWD

Mon 10/02/2017 to Wed 11/15/2017

(Import)

0500 Continuous 2000

Work scheduled by: HQ

MOSES SOUTH

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC2**

REV

Mon 10/02/2017 to Wed 11/15/2017

(Export)

0500 Continuous 2000

Work scheduled by: HQ

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 30, 2017 to Wednesday,May 01, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-HQ-NYISO\_LIMIT\_1150

Mon 10/02/2017 to Wed 11/15/2017  
0500 Continuous 2000

Work scheduled by: HQ

FWD  
(Import)  
SCH - HQ - NY **1150 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 1500 MW

## SPRNBRK\_345KV\_RNS4

Mon 10/02/2017 to Sat 10/28/2017  
1901 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 10/03/2017

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

## BERKSHIR-NORTHFLD\_345\_312

Fri 10/06/2017 to Sat 10/28/2017  
0700 Continuous 1600

Work scheduled by: ISONE

UPDATED by ISONE 10/10/2017

FWD REV  
(Import) (Export)  
SCH - NE - NY **900 MW 1200 MW**  
Impacts Total Transfer Capability 500 MW 400 MW  
TTC with All Lines In Service 1400 MW 1600 MW

## BERKSHIR-NORTHFLD\_345\_312

Fri 10/06/2017 to Sat 10/28/2017  
0700 Continuous 1600

Work scheduled by: ISONE

UPDATED by ISONE 10/10/2017

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **100 MW 100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

## SCH-NYISO-NE\_LIMIT\_600

Sun 10/08/2017 to Sat 10/28/2017  
0001 Continuous 1600

Work scheduled by: ISONE

UPDATED by ISONE 10/10/2017

REV  
(Export)  
SCH - NE - NY **800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 1600 MW

## BERKSHIR-ALPS\_345\_393

Fri 10/13/2017 to Sat 10/28/2017  
1516 Continuous 1600

Work scheduled by: NGrid

UPDATED by ISONE 10/13/2017

ARR: 78

FWD REV  
(Import) (Export)  
SCH - NE - NY **950 MW 1000 MW**  
Impacts Total Transfer Capability 450 MW 600 MW  
TTC with All Lines In Service 1400 MW 1600 MW

## BERKSHIR-ALPS\_345\_393

Fri 10/13/2017 to Sat 10/28/2017  
1516 Continuous 1600

Work scheduled by: NGrid

UPDATED by ISONE 10/13/2017

ARR: 78

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **100 MW 100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 30, 2017 to Wednesday,May 01, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## BERKSHIR-ALPS\_\_\_\_\_345\_393 & BERKSHIR-NORTHFLD\_345\_312

Fri 10/13/2017 to Sat 10/28/2017  
1516 1600

Work scheduled by:

ARR: 78

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	<b>950 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	450 MW	600 MW
TTC with All Lines In Service	1400 MW	1600 MW

## SCH-HQ-NYISO\_LIMIT\_700

Sat 10/14/2017 to Fri 10/27/2017  
0100 Continuous 0917

Work scheduled by: HQ

UPDATEDby HQ10/27/2017

	FWD
	(Import)
SCH - HQ - NY	<b>700 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	1500 MW

## CHAT\_DC\_GC1

Sat 10/14/2017 to Mon 10/30/2017  
0100 Continuous 2000

Work scheduled by: HQ

UPDATEDby HQ10/27/2017

	FWD
	(Import)
MOSES SOUTH	<b>2850 MW</b>
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

## CHAT\_DC\_GC1

Sat 10/14/2017 to Mon 10/30/2017  
0100 Continuous 2000

Work scheduled by: HQ

UPDATEDby HQ10/27/2017

	REV
	(Export)
SCH - HQ - NY	<b>500 MW</b>
Impacts Total Transfer Capability	500 MW
TTC with All Lines In Service	1000 MW

## CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Sat 10/14/2017 to Mon 10/30/2017  
0100 2000

Work scheduled by:

	FWD
	(Import)
MOSES SOUTH	<b>2550 MW</b>
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	3150 MW

## CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Sat 10/14/2017 to Mon 10/30/2017  
0100 2000

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>1370 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	130 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

## HOMRC\_NY-MAINS\_NY\_345\_47

Sat 10/14/2017 to Mon 10/30/2017  
0700 Continuous 1730

Work scheduled by: NYSEG

EXTENDEDby NYSEG10/27/2017

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2100 MW</b>	<b>1350 MW</b>
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2100 MW	1350 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,October 30, 2017 to Wednesday,May 01, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>HURLYAVE-ROSETON__345_303</b>					FWD	
Mon 10/16/2017	to	Fri 11/03/2017	<u>UPDATED</u>	<u>by CH</u>	<u>06/07/2017</u>	(Import)
0800	Continuous	1600				
Work scheduled by: CHGE					UPNY CONED	<b>4100 MW</b>
					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	5100 MW
<b>LEEDS__-HURLYAVE_345_301</b>					FWD	
Mon 10/16/2017	to	Fri 11/03/2017				(Import)
0800	Continuous	1600				
Work scheduled by: CHGE					UPNY CONED	<b>4100 MW</b>
					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	5100 MW
<b>COOPERS_-MIDDLETP_345_CCRT34</b>					FWD	
Tue 10/17/2017	to	Fri 10/27/2017	<u>UPDATED</u>	<u>by NY</u>	<u>10/26/2017</u>	(Import)
0700	Continuous	1500				
Work scheduled by: NYSEG					CENTRAL EAST - VC	<b>2720 MW</b>
					Impacts Total Transfer Capability	255 MW
					TTC with All Lines In Service	2975 MW
<b>S.RIPLEY-DUNKIRK__230_68</b>					FWD	REV
Mon 10/23/2017	to	Sat 10/28/2017	<u>EXTENDED</u>	<u>by PJM</u>	<u>10/28/2017</u>	(Import) (Export)
0800	Continuous	1500				
Work scheduled by: PJM					SCH - PJ - NY	<b>1950 MW 1350 MW</b>
					Impacts Total Transfer Capability	150 MW 0 MW
					TTC with All Lines In Service	2100 MW 1350 MW
<b>BECK__-NIAGARA__345_PA301</b>					FWD	REV
Tue 10/24/2017	to	Wed 10/25/2017				(Import) (Export)
0500	Continuous	1700				
Work scheduled by: NYPA					SCH - OH - NY	<b>900 MW 800 MW</b>
					Impacts Total Transfer Capability	1100 MW 800 MW
					TTC with All Lines In Service	2000 MW 1600 MW
<b>NIAGARA_-KINTIGH__345_NS1-38</b>					FWD	
Tue 10/24/2017	to	Wed 10/25/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/25/2017</u>	(Import)
0600	Continuous	1654				
Work scheduled by: NYPA					DYSINGER EAST	<b>1700 MW</b>
					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
<b>CHASLAKE-PORTER__230_11</b>					FWD	
Wed 10/25/2017	to	Thu 10/26/2017				(Import)
0730	Continuous	1900				
Work scheduled by: NGrid					MOSES SOUTH	<b>2100 MW</b>
					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-HQ-NYISO\_LIMIT\_600**

FWD

Wed 10/25/2017 to Wed 10/25/2017

(Import)

1000 Continuous 1600

Work scheduled by: HQ

SCH - HQ - NY

**600 MW**

Impacts Total Transfer Capability 900 MW

TTC with All Lines In Service 1500 MW

**FRASER\_\_-COOPERS\_\_345\_33**

FWD

Thu 10/26/2017 to Thu 10/26/2017

(Import)

0800 Continuous 1700

Work scheduled by: NYSEG

**CANCELLED by NYSEG 10/25/2017**

CENTRAL EAST - VC

**2395 MW**

Impacts Total Transfer Capability 580 MW

TTC with All Lines In Service 2975 MW

**W49TH\_ST\_345KV\_5**

FWD

Fri 10/27/2017 to Sat 11/04/2017

(Import)

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJM\_HTP

**315 MW**

Impacts Total Transfer Capability 345 MW

TTC with All Lines In Service 660 MW

**VOLNEY\_\_-CLAY\_\_\_\_345\_6**

FWD

Fri 10/27/2017 to Fri 10/27/2017

(Import)

0800 Daily(No Weekends) 1800

Work scheduled by: NGrid

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

**SCH-NYISO-HQ\_CEDARS\_LIMIT\_40**

REV

Fri 10/27/2017 to Mon 10/30/2017

(Export)

1600 Continuous 0559

Work scheduled by: HQ

**UPDATED by HQ 10/30/2017**

SCH - HQ\_CEDARS

**40 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 40 MW

**SPRNBK\_\_345KV\_RNS4**

FWD

Sat 10/28/2017 to Sat 11/04/2017

(Import)

0301 Continuous 2359

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

**FRASER\_\_-COOPERS\_\_345\_33**

FWD

Sat 10/28/2017 to Sat 10/28/2017

(Import)

0800 Continuous 1700

Work scheduled by: NYSEG

CENTRAL EAST - VC

**2395 MW**

Impacts Total Transfer Capability 580 MW

TTC with All Lines In Service 2975 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,October 30, 2017 to Wednesday,May 01, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
<b>S.RIPLEY-DUNKIRK__230_68</b>						
Sat 10/28/2017	to	Mon 03/19/2018	<u>UPDATED</u>	<u>by NYISO</u> <u>10/09/2017</u>	SCH - PJ - NY	<b>1950 MW</b>
1501	Continuous	0959			Impacts Total Transfer Capability	1350 MW
Work scheduled by: NYISO					TTC with All Lines In Service	2300 MW
<b>MARCY_SO_SERIES_COMP_I/S</b>						
Sat 10/28/2017	to	Fri 11/03/2017			CENTRAL EAST - VC	<b>2740 MW</b>
1700	Continuous	1600			Impacts Total Transfer Capability	235 MW
Work scheduled by: NYISO					TTC with All Lines In Service	2975 MW
<b>SCH-HQ-NYISO_LIMIT_800</b>						
Sun 10/29/2017	to	Mon 10/30/2017	<u>UPDATED</u>	<u>by HQ</u> <u>10/27/2017</u>	SCH - HQ - NY	<b>800 MW</b>
1230	Continuous	1200			Impacts Total Transfer Capability	700 MW
Work scheduled by: HQ					TTC with All Lines In Service	1500 MW
<b>SCH-HQ_CEDARS-NYISO_LIMIT_0</b>						
Mon 10/30/2017	to	Mon 10/30/2017	<u>UPDATED</u>	<u>by HQ</u> <u>10/30/2017</u>	SCH - HQ_CEDARS	<b>0 MW</b>
0600	Continuous	1100			Impacts Total Transfer Capability	190 MW
Work scheduled by: HQ					TTC with All Lines In Service	190 MW
<b>SCH-HQ_CEDARS-NYISO_LIMIT_100</b>						
Mon 10/30/2017	to	Mon 10/30/2017	<u>UPDATED</u>	<u>by HQ</u> <u>10/30/2017</u>	SCH - HQ_CEDARS	<b>100 MW</b>
0600	Continuous	1100			Impacts Total Transfer Capability	90 MW
Work scheduled by: HQ					TTC with All Lines In Service	190 MW
<b>NEPTUNE_-DUFFYAVE_345_NEPTUNE</b>						
Tue 10/31/2017	to	Thu 11/02/2017			SCH - PJM_NEPTUNE	<b>0 MW</b>
0001	Continuous	2359			Impacts Total Transfer Capability	660 MW
Work scheduled by: LI					TTC with All Lines In Service	660 MW
<b>NEWBRDGE-DUFFYAVE_345_501</b>						
Tue 10/31/2017	to	Thu 11/02/2017			SCH - PJM_NEPTUNE	<b>0 MW</b>
0001	Continuous	2359			Impacts Total Transfer Capability	660 MW
Work scheduled by: LI					TTC with All Lines In Service	660 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,October 30, 2017 to Wednesday,May 01, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NEWBRDGE\_345\_138\_BK\_1**

Tue 10/31/2017 to Thu 11/02/2017  
0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

**NEWBRDGE\_345\_138\_BK\_2**

Tue 10/31/2017 to Thu 11/02/2017  
0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Tue 10/31/2017 to Sat 11/04/2017  
0700 Continuous 1530

Work scheduled by: NYPA

**UPDATED by NYPA 10/30/2017**

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**PLSNTVLY-EFISHKIL\_345\_F36**

Wed 11/01/2017 to Sat 11/04/2017  
0001 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

**SCH-NYISO-IMO\_LIMIT\_1400**

Wed 11/01/2017 to Mon 04/30/2018  
0001 Continuous 2359

Work scheduled by: IESO

REV  
(Export)  
SCH - OH - NY **1700 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1900 MW

**SCH-HQ\_CEDARS-NYISO\_LIMIT\_0**

Wed 11/01/2017 to Wed 11/01/2017  
0600 Continuous 1230

Work scheduled by: HQ

**UPDATED by HQ 10/30/2017**

FWD  
(Import)  
SCH - HQ\_CEDARS **0 MW**  
Impacts Total Transfer Capability 199 MW  
TTC with All Lines In Service 199 MW

**CEDARS\_\_-ROSEMNTA\_115\_1/11**

Wed 11/01/2017 to Sat 11/11/2017  
0600 Continuous 1600

Work scheduled by: HQ

**UPDATED by HQ 10/30/2017****ARR: 38**

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **95 MW 100 MW**  
Impacts Total Transfer Capability 104 MW 0 MW  
TTC with All Lines In Service 199 MW 100 MW

# NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday ,October 30, 2017 to Wednesday,May 01, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ_CEDARS-NYISO_LIMIT_100					FWD	
Wed 11/01/2017	to	Sat 11/11/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>10/30/2017</u>	(Import)
0600	Continuous	1600				
Work scheduled by: HQ					SCH - HQ_CEDARS	100 MW
					Impacts Total Transfer Capability	99 MW
					TTC with All Lines In Service	199 MW
LAFAYTTE-CLRKSCRN_345_4-46					FWD	
Wed 11/01/2017	to	Thu 11/02/2017				(Import)
0630	Continuous	1630				
Work scheduled by: NGrid					CENTRAL EAST - VC	2650 MW
					Impacts Total Transfer Capability	325 MW
					TTC with All Lines In Service	2975 MW
COOPERS_-DOLSONAV_345_CCDA42					FWD	
Wed 11/01/2017	to	Sat 11/04/2017				(Import)
0830	Continuous	1800				
Work scheduled by: NYSEG					CENTRAL EAST - VC	2720 MW
					Impacts Total Transfer Capability	255 MW
					TTC with All Lines In Service	2975 MW
MARION_-FARRAGUT_345_C3403					FWD	REV
Thu 11/02/2017	to	Sat 12/02/2017	<u>UPDATED</u>	<u>by CE</u>	<u>09/29/2017</u>	(Import) (Export)
0001	Continuous	0100				
Work scheduled by: ConEd					SCH - PJ - NY	2300 MW 1450 MW
					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	2300 MW 1450 MW
BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312					FWD	REV
Thu 11/02/2017	to	Thu 11/02/2017				(Import) (Export)
0700		0900				
Work scheduled by:					SCH - NE - NY	1300 MW 1300 MW
					Impacts Total Transfer Capability	100 MW 300 MW
					TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-NORTHFLD_345_312					FWD	REV
Thu 11/02/2017	to	Thu 11/02/2017	<u>UPDATED</u>	<u>by NE</u>	<u>10/17/2017</u>	(Import) (Export)
0700	Continuous	0900				
Work scheduled by: NGrid					SCH - NE - NY	1400 MW 1450 MW
					Impacts Total Transfer Capability	0 MW 150 MW
					TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-NORTHFLD_345_312					FWD	REV
Thu 11/02/2017	to	Thu 11/02/2017	<u>UPDATED</u>	<u>by NE</u>	<u>10/17/2017</u>	(Import) (Export)
0700	Continuous	0900				
Work scheduled by: NGrid					SCH - NPX_1385	100 MW 100 MW
					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW



**NYISO TRANSFER LIMITATIONS**

Monday ,October 30, 2017 to Wednesday,May 01, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BERKSHIR-ALPS_____345_393</b>						FWD	REV
Thu 11/02/2017	to	Sat 11/04/2017	<u>UPDATED</u>	<u>by NE</u>	<u>10/17/2017</u>	(Import)	(Export)
0700	Continuous	1900				<b>1300 MW</b>	<b>1300 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	1400 MW
						ARR: 78	1600 MW
<b>BERKSHIR-ALPS_____345_393</b>						FWD	REV
Thu 11/02/2017	to	Sat 11/04/2017	<u>UPDATED</u>	<u>by NE</u>	<u>10/17/2017</u>	(Import)	(Export)
0700	Continuous	1900				<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
						ARR: 78	200 MW
<b>SCH-NE-NYISO_LIMIT_500</b>						FWD	
Thu 11/02/2017	to	Sat 11/04/2017	<u>UPDATED</u>	<u>by NE</u>	<u>10/17/2017</u>	(Import)	
0700	Continuous	1900				<b>700 MW</b>	
Work scheduled by: NGrid						Impacts Total Transfer Capability	700 MW
						TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_700</b>							REV
Thu 11/02/2017	to	Sat 11/04/2017	<u>UPDATED</u>	<u>by NE</u>	<u>10/17/2017</u>		(Export)
0700	Continuous	1900				<b>900 MW</b>	
Work scheduled by: NGrid						Impacts Total Transfer Capability	700 MW
						TTC with All Lines In Service	1600 MW
<b>DENNISON-ROSEMNTA_115_1/11</b>						FWD	REV
Thu 11/02/2017	to	Thu 11/09/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>10/30/2017</u>	(Import)	(Export)
0800	Continuous	1530				<b>95 MW</b>	<b>100 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	104 MW
						TTC with All Lines In Service	199 MW
						ARR: 38	100 MW
<b>BERKSHIR-ALPS_____345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>						FWD	REV
Sat 11/04/2017	to	Sat 11/04/2017				(Import)	(Export)
1800		1900				<b>1300 MW</b>	<b>1300 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	1400 MW
						ARR: 78	1600 MW
<b>BERKSHIR-NORTHFLD_345_312</b>						FWD	REV
Sat 11/04/2017	to	Sat 11/04/2017	<u>UPDATED</u>	<u>by NE</u>	<u>10/17/2017</u>	(Import)	(Export)
1800	Continuous	1900				<b>1400 MW</b>	<b>1450 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	150 MW
							1600 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BERKSHIR-NORTHFLD\_345\_312**

Sat 11/04/2017 to Sat 11/04/2017  
1800 Continuous 1900

**UPDATED****by NE****10/17/2017**

Work scheduled by: NGrid

	FWD (Import)	REV (Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

**PLSNTVLY-EFISHKIL\_345\_F36**

Mon 11/06/2017 to Wed 11/08/2017  
0001 Continuous 0300

Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	4000 MW
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

**MOSES\_\_-ADIRNDCK\_230\_MA1**

Mon 11/06/2017 to Thu 11/09/2017  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

**FRASANNX-COOPERS\_\_345\_UCC2-41**

Mon 11/06/2017 to Fri 11/17/2017  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	2500 MW
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

**MARCY\_\_-FRASANNX\_345\_UCC2-41**

Mon 11/06/2017 to Fri 11/17/2017  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

	FWD (Import)
CENTRAL EAST - VC	2500 MW
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

**LINDN\_CG-LNDVFT\_\_345\_V-3022**

Mon 11/06/2017 to Thu 11/09/2017  
0800 Continuous 1500

Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJM_VFT	0 MW	0 MW
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

**SCRIBA\_\_-VOLNEY\_\_345\_20**

Mon 11/06/2017 to Fri 11/17/2017  
0800 Continuous 1630

Work scheduled by: NGrid

	FWD (Import)
OSWEGO EXPORT	5250 MW
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	5250 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 30, 2017 to Wednesday,May 01, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## ROCHESTR-PANNELL\_\_345\_RP1

FWD

Mon 11/06/2017 to Tue 11/07/2017

(Import)

0900 Continuous 1500

DYSINGER EAST **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: RGE

## W49TH\_ST\_345KV\_5

FWD

Fri 11/10/2017 to Fri 11/10/2017

(Import)

0001 Continuous 0030

UPDATED by CONED 10/03/2017SCH - PJM\_HTP **315 MW**

Impacts Total Transfer Capability 345 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

## SPRNBK\_-W49TH\_ST\_345\_M52

FWD

Fri 11/10/2017 to Mon 11/13/2017

(Import)

0001 Continuous 0300

UPDATED by CONED 10/03/2017SPR/DUN-SOUTH **3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## SPRNBK\_\_345KV\_RNS4

FWD

Fri 11/10/2017 to Mon 11/13/2017

(Import)

0001 Continuous 0300

UPDATED by CONED 10/03/2017SPR/DUN-SOUTH **3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## SPRNBK\_\_345KV\_RS3 & SPRNBK\_\_345KV\_RS4

FWD

Sun 11/12/2017 to Wed 11/15/2017

(Import)

0001 0300

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by:

## E13THSTA-FARRAGUT\_345\_46

FWD

Sun 11/12/2017 to Sun 11/12/2017

(Import)

0230 Continuous 0300

UPDATED by CE 10/20/2017SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## W49TH\_ST\_345KV\_5

FWD

Mon 11/13/2017 to Mon 11/13/2017

(Import)

0230 Continuous 0300

UPDATED by CONED 10/03/2017SCH - PJM\_HTP **315 MW**

Impacts Total Transfer Capability 345 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**NYISO TRANSFER LIMITATIONS**

Monday ,October 30, 2017 to Wednesday,May 01, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_Ma1**

FWD

Mon 11/13/2017 to Sat 11/18/2017

EXTENDEDby PA10/26/2017

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**PORTER\_\_\_-ROTTRDAM\_230\_30**

FWD

Mon 11/13/2017 to Wed 11/15/2017

(Import)

0800 Daily(No Weekends) 1830

CENTRAL EAST - VC

**2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**SPRNBK\_\_\_345KV\_RNS4**

FWD

Wed 11/15/2017 to Fri 11/17/2017

UPDATEDby CONED10/03/2017

(Import)

0001 Continuous 0100

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**W49TH\_ST-E13THSTA\_345\_M55**

FWD

Fri 11/17/2017 to Fri 11/17/2017

UPDATEDby NYISO10/20/2017

(Import)

0101 Continuous 0301

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: NYPA

**W49TH\_ST\_345KV\_6**

FWD

Fri 11/17/2017 to Fri 11/17/2017

UPDATEDby NYISO10/20/2017

(Import)

0101 Continuous 0301

SCH - PJM\_HTP

**310 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 660 MW

Work scheduled by: NYPA

**E13THSTA-FARRAGUT\_345\_45**

FWD

Sat 11/18/2017 to Tue 05/15/2018

(Import)

0000 Continuous 2359

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**W49TH\_ST-E13THSTA\_345\_M54**

FWD

Sat 11/18/2017 to Tue 05/15/2018

(Import)

0000 Continuous 2359

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**NYISO TRANSFER LIMITATIONS**

Monday ,October 30, 2017 to Wednesday,May 01, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EGRDNCTY\_345\_138\_AT1**

FWD

Sun 11/19/2017 to Sun 12/24/2017 **UPDATED** **by LI** **08/01/2017**

(Import)

0001 Continuous 0300

CONED - LIPA

**1250 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI

**EGRDNCTY\_345\_138\_AT2**

FWD

Sun 11/19/2017 to Sun 12/24/2017 **UPDATED** **by LI** **08/01/2017**

(Import)

0001 Continuous 0300

CONED - LIPA

**1250 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI

**SPRNBK\_-EGRDNCTR\_345\_Y49**

FWD

Sun 11/19/2017 to Sun 12/24/2017 **UPDATED** **by LI** **08/01/2017**

(Import)

0001 Continuous 0300

CONED - LIPA

**775 MW**

Impacts Total Transfer Capability 725 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI

**CEDARS\_-ROSEMNTB\_115\_2/22**

FWD

REV

Mon 11/20/2017 to Thu 12/07/2017 **UPDATED** **by HQ** **10/25/2017**

(Import) (Export)

0515 Continuous 1600

SCH - HQ\_CEDARS

**95 MW****100 MW**

Impacts Total Transfer Capability 104 MW 0 MW

TTC with All Lines In Service 199 MW 100 MW

Work scheduled by: HQ

**ARR: 38****DENNISON-ROSEMNTB\_115\_2/22**

FWD

REV

Mon 11/20/2017 to Thu 12/07/2017 **UPDATED** **by HQ** **10/25/2017**

(Import) (Export)

0515 Continuous 1600

SCH - HQ\_CEDARS

**95 MW****100 MW**

Impacts Total Transfer Capability 104 MW 0 MW

TTC with All Lines In Service 199 MW 100 MW

Work scheduled by: HQ

**ARR: 38****SCH-HQ\_CEDARS-NYISO\_LIMIT\_100**

FWD

Mon 11/20/2017 to Thu 12/07/2017 **UPDATED** **by HQ** **10/25/2017**

(Import)

0515 Continuous 1600

SCH - HQ\_CEDARS

**100 MW**

Impacts Total Transfer Capability 99 MW

TTC with All Lines In Service 199 MW

Work scheduled by: HQ

**MOSES\_-ADIRNDCK\_230\_MAI**

FWD

Mon 11/20/2017 to Wed 11/22/2017 **UPDATED** **by NYPA** **10/13/2017**

(Import)

0700 Continuous 1730

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**NYISO TRANSFER LIMITATIONS**

Monday ,October 30, 2017 to Wednesday,May 01, 2019

**CENTRAL EAST** 3100MW  
**CENTRAL EAST - VC** 2975MW  
**TOTAL EAST** 6500MW  
**UPNY CONED** 5100MW  
**SPR/DUN-SOUTH** 4600MW  
**DYSINGER EAST** 3150MW  
**MOSES SOUTH** 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**WETHSRFD-MEYER** 230\_85/87

FWD

Mon 11/20/2017 to Fri 12/01/2017

UPDATEDby NYSEG 09/13/2017

(Import)

1630 Continuous 1400

Work scheduled by: NYSEG

DYSINGER EAST

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

**N.SCTLND-LEEDS** 345\_93

FWD

Tue 11/21/2017 to Wed 11/22/2017

UPDATEDby NGRID 10/09/2017

(Import)

0800 Continuous 1500

Work scheduled by: NGrid

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

**NINEMILE-CLAY** 345\_8

FWD

Tue 11/21/2017 to Tue 11/21/2017

0900 Daily(No Weekends) 1500

Work scheduled by: NGrid

OSWEGO EXPORT

**5150 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 5250 MW

**MOSES -ADIRNDCK** 230\_MAI

FWD

Mon 11/27/2017 to Fri 12/01/2017

0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

**ROSETON -EFISHKIL** 345\_RFK305

FWD

Mon 11/27/2017 to Fri 12/01/2017

0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED

**4800 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 5100 MW

**ROTTRDAM-EASTOVER** 230\_38

FWD

REV

Mon 11/27/2017 to Thu 11/30/2017

0900 Continuous 1500

Work scheduled by: NGrid

**ARR: 77**

SCH - NE - NY

**1400 MW 1400 MW**

Impacts Total Transfer Capability 0 MW 200 MW

TTC with All Lines In Service 1400 MW 1600 MW

**ROSETON -EFISHKIL** 345\_RFK305

FWD

Sat 12/02/2017 to Sat 12/02/2017

0001 Continuous 2359

Work scheduled by: ConEd

UPNY CONED

**4800 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 5100 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

FWD

Sun 12/03/2017 to Tue 12/05/2017  
0001 0300

(Import)

Work scheduled by:

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

**LEEDS -PLSNTVLY\_345\_92**

FWD

Mon 12/04/2017 to Mon 12/18/2017  
0001 Continuous 0300

(Import)

Work scheduled by: ConEd

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

**PLSNTVLY\_345KV\_RNS5**

FWD

Mon 12/04/2017 to Mon 12/18/2017  
0001 Continuous 0300

(Import)

Work scheduled by: ConEd

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

**MARCY 765\_345\_AT2**

FWD

Mon 12/04/2017 to Fri 12/08/2017  
0500 Continuous 1630

(Import)

Work scheduled by: NYPA

**ARR: 19**

MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**NRTH1385-NRTHPORT\_138\_NNC**

FWD

REV

Mon 12/04/2017 to Wed 12/13/2017  
0700 Continuous 2359

(Import) (Export)

Work scheduled by: LI

SCH - NPX\_1385 **0 MW 0 MW**  
Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 200 MW 200 MW

**MOSES -ADIRNDCK\_230\_MA2**

FWD

Mon 12/11/2017 to Fri 12/15/2017  
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**NIAGARA -KINTIGH\_345\_NS1-38**

FWD

Mon 12/11/2017 to Wed 12/20/2017  
0800 Continuous 1600

(Import)

Work scheduled by: NYSEG

DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,October 30, 2017 to Wednesday,May 01, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 12/18/2017 to Fri 12/22/2017  
0700 Continuous 1530

UPDATEDby NYPA10/23/2016

(Import)

Work scheduled by: NYPA

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

**N.SCTLND-LEEDS\_\_\_345\_94**

FWD

Tue 12/19/2017 to Wed 12/20/2017  
0800 Continuous 1500

(Import)

Work scheduled by: NGrid

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

**HOPATCON-RAMAPO\_\_\_500\_5018**

FWD

REV

Tue 12/26/2017 to Thu 12/28/2017  
0200 Continuous 1700

UPDATEDby CE10/27/2017

(Import) (Export)

Work scheduled by: PJM

SCH - PJ - NY

**2100 MW 1000 MW**

Impacts Total Transfer Capability 200 MW 450 MW

TTC with All Lines In Service 2300 MW 1450 MW

**HOPATCON-RAMAPO\_\_\_500\_5018**

FWD

Tue 12/26/2017 to Thu 12/28/2017  
0200 Continuous 1700

UPDATEDby CE10/27/2017

(Import)

Work scheduled by: PJM

UPNY CONED

**5000 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 5100 MW

**HOPATCON-RAMAPO\_\_\_500\_5018 & S.RIPLEY-DUNKIRK\_\_\_230\_68**

FWD

REV

Tue 12/26/2017 to Thu 12/28/2017  
0200 1700

(Import) (Export)

Work scheduled by:

SCH - PJ - NY

**1200 MW 1300 MW**

Impacts Total Transfer Capability 1100 MW 150 MW

TTC with All Lines In Service 2300 MW 1450 MW

**RAMAPO\_\_\_345\_345\_PAR3500**

FWD

REV

Tue 12/26/2017 to Thu 12/28/2017  
0200 Continuous 1700

UPDATEDby CE10/27/2017

(Import) (Export)

Work scheduled by: PJM

SCH - PJ - NY

**2200 MW 1450 MW**

Impacts Total Transfer Capability 100 MW 0 MW

TTC with All Lines In Service 2300 MW 1450 MW

**RAMAPO\_\_\_345\_345\_PAR4500**

FWD

REV

Tue 12/26/2017 to Thu 12/28/2017  
0200 Continuous 1700

UPDATEDby CE10/27/2017

(Import) (Export)

Work scheduled by: PJM

SCH - PJ - NY

**2200 MW 1450 MW**

Impacts Total Transfer Capability 100 MW 0 MW

TTC with All Lines In Service 2300 MW 1450 MW



**NYISO TRANSFER LIMITATIONS**

Monday ,October 30, 2017 to Wednesday,May 01, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**RAMAPO\_\_\_500\_345\_BK 1500**

Tue 12/26/2017 to Thu 12/28/2017  
 0200 Continuous 1700

**UPDATED by CE 10/27/2017**

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2100 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	200 MW	450 MW
TTC with All Lines In Service	2300 MW	1450 MW

**RAMAPO\_\_\_500\_345\_BK 1500**

Tue 12/26/2017 to Thu 12/28/2017  
 0200 Continuous 1700

**UPDATED by CE 10/27/2017**

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
UPNY CONED	<b>5000 MW</b>	
Impacts Total Transfer Capability	100 MW	
TTC with All Lines In Service	5100 MW	

**S.RIPLEY-DUNKIRK\_\_\_230\_68 & RAMAPO\_\_\_345\_345\_PAR3500**

Tue 12/26/2017 to Thu 12/28/2017  
 0200 1700

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>1450 MW</b>	<b>1250 MW</b>
Impacts Total Transfer Capability	850 MW	200 MW
TTC with All Lines In Service	2300 MW	1450 MW

**S.RIPLEY-DUNKIRK\_\_\_230\_68 & RAMAPO\_\_\_345\_345\_PAR4500**

Tue 12/26/2017 to Thu 12/28/2017  
 0200 1700

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>1450 MW</b>	<b>1250 MW</b>
Impacts Total Transfer Capability	850 MW	200 MW
TTC with All Lines In Service	2300 MW	1450 MW

**MARCY\_\_\_765\_345\_AT2**

Wed 12/27/2017 to Thu 12/28/2017  
 0500 Continuous 1630

Work scheduled by: NYPA

**ARR: 19**

	FWD	REV
	(Import)	(Export)
MOSES SOUTH	<b>1700 MW</b>	
Impacts Total Transfer Capability	1450 MW	
TTC with All Lines In Service	3150 MW	

**DUNWODIE-SHORE\_RD\_345\_Y50**

Tue 01/02/2018 to Thu 01/04/2018  
 0001 Continuous 2359

**EXTENDED by LI 09/22/2017**

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
CONED - LIPA	<b>800 MW</b>	
Impacts Total Transfer Capability	700 MW	
TTC with All Lines In Service	1500 MW	

**DUNWODIE\_345KV\_4**

Tue 01/02/2018 to Thu 01/04/2018  
 0001 Continuous 2359

**EXTENDED by LI 09/22/2017**

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

**NYISO TRANSFER LIMITATIONS**

Monday ,October 30, 2017 to Wednesday,May 01, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_6**

FWD

Tue 01/02/2018 to Thu 01/04/2018 **EXTENDED** **by LI** **09/22/2017**

(Import)

0001 Continuous 2359

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**SHORE\_RD\_345\_138\_BK 1**

FWD

Tue 01/02/2018 to Thu 01/04/2018 **EXTENDED** **by LI** **09/22/2017**

(Import)

0001 Continuous 2359

CONED - LIPA

**1350 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: ConEd

**SHORE\_RD\_345\_138\_BK 2**

FWD

Tue 01/02/2018 to Thu 01/04/2018 **EXTENDED** **by LI** **09/22/2017**

(Import)

0001 Continuous 2359

CONED - LIPA

**1350 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: ConEd

**MOSES\_\_-ADIRNDCK\_230\_MAL**

FWD

Tue 01/02/2018 to Fri 01/05/2018

(Import)

0700 Continuous 1730

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**LEEDS\_\_-PLSNTVLY\_345\_92**

FWD

Wed 01/03/2018 to Sat 01/06/2018 **UPDATED** **by NYISO** **09/12/2017**

(Import)

0001 Continuous 0300

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**PLSNTVLY\_345KV\_RNS5**

FWD

Wed 01/03/2018 to Sat 01/06/2018 **UPDATED** **by NYISO** **09/12/2017**

(Import)

0001 Continuous 0300

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

FWD

Fri 01/05/2018 to Sun 01/07/2018

(Import)

0001 2359

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by:

**NYISO TRANSFER LIMITATIONS**

Monday ,October 30, 2017 to Wednesday,May 01, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLY\_345KV\_RNS5**

FWD

Mon 01/08/2018 to Wed 01/10/2018 **UPDATED by NYISO 09/12/2017**

(Import)

0001 Continuous 0300

Work scheduled by: ConEd

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

**EASTVIEW-SPRNBK\_\_345\_W64**

FWD

Mon 01/08/2018 to Fri 02/23/2018

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

**MILLWOOD-EASTVIEW\_345\_W99**

FWD

Mon 01/08/2018 to Fri 02/23/2018

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

**SPRNBK\_\_345KV\_RNS5**

FWD

Mon 01/08/2018 to Fri 02/23/2018

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

**MOSES\_\_-ADIRNDCK\_230\_MAI**

FWD

Mon 01/08/2018 to Fri 01/12/2018

(Import)

0700 Continuous 1730

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**FRASER\_\_-COOPERS\_\_345\_33**

FWD

Mon 01/08/2018 to Thu 01/11/2018

(Import)

0800 Continuous 1500

Work scheduled by: NYSEG

CENTRAL EAST - VC **2395 MW**  
Impacts Total Transfer Capability 580 MW  
TTC with All Lines In Service 2975 MW

**N.SCTLND-ALPS\_\_\_\_\_345\_2**

FWD

REV

Mon 01/08/2018 to Fri 02/02/2018 **UPDATED by NG 10/17/2017**

(Import) (Export)

0800 Continuous 1400

Work scheduled by: NGrid

SCH - NE - NY **900 MW 1600 MW**  
Impacts Total Transfer Capability 500 MW 0 MW  
TTC with All Lines In Service 1400 MW 1600 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N.SCTLND-ALPS_____345_2					FWD	REV
Mon 01/08/2018 to Fri 02/02/2018					(Import)	(Export)
0800	Continuous	1400	<u>UPDATED</u>	<u>by NG</u>	<u>10/17/2017</u>	
Work scheduled by: NGrid					SCH - NPX_1385	100 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
MOSES____-ADIRNDCK_230_MAl					FWD	
Mon 01/15/2018 to Fri 01/19/2018					(Import)	
0700	Continuous	1530			MOSES SOUTH	2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
MARCY_____765_345_AT2					FWD	
Sat 01/20/2018 to Sat 01/20/2018					(Import)	
0500	Continuous	1730			MOSES SOUTH	1700 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
MOSES____-ADIRNDCK_230_MAl					FWD	
Mon 01/22/2018 to Fri 01/26/2018					(Import)	
0700	Continuous	1530			MOSES SOUTH	2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
MOSES____-ADIRNDCK_230_MAl					FWD	
Mon 01/29/2018 to Fri 02/02/2018					(Import)	
0700	Continuous	1530			MOSES SOUTH	2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
MARCY_____765_345_AT2					FWD	
Sat 02/03/2018 to Sat 02/03/2018					(Import)	
0500	Continuous	1730			MOSES SOUTH	1700 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
MARCY_____765_345_AT2					FWD	
Mon 02/05/2018 to Fri 02/09/2018					(Import)	
0500	Continuous	1730			MOSES SOUTH	1700 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 02/12/2018 to Fri 02/16/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**HUDSONP\_-FARRAGUT\_345\_B3402**

FWD

REV

Sun 02/18/2018 to Sun 04/01/2018

(Import) (Export)

0001 Continuous 2359

SCH - PJ - NY

**2300 MW 1450 MW**

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 2300 MW 1450 MW

Work scheduled by: PJM

**MARCY\_\_\_-EDIC\_\_\_345\_UE1-7**

FWD

Tue 02/20/2018 to Fri 02/23/2018

(Import)

0500 Continuous 1730

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19&16****MOSES\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Tue 02/20/2018 to Fri 02/23/2018

(Import)

0700 Continuous 1730

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**DUNWODIE\_345KV\_7**

FWD

Sat 02/24/2018 to Sat 02/24/2018

(Import)

0001 Continuous 0030

**UPDATED****by CE****09/22/2017**

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**DUNWODIE\_345KV\_8**

FWD

Sat 02/24/2018 to Sat 02/24/2018

(Import)

0001 Continuous 0030

**UPDATED****by CE****09/22/2017**

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**DUNWODIE-MOTTHAVN\_345\_72**

FWD

Sat 02/24/2018 to Sat 03/31/2018

(Import)

0001 Continuous 0300

**UPDATED****by CE****09/22/2017**

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday ,October 30, 2017 to Wednesday,May 01, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LONG\_MTN-PLSNTVLY\_345\_398

Mon 02/26/2018 to Wed 05/02/2018  
0001 Continuous 0300

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	700 MW	1300 MW
Impacts Total Transfer Capability	700 MW	300 MW
TTC with All Lines In Service	1400 MW	1600 MW

## LONG\_MTN-PLSNTVLY\_345\_398

Mon 02/26/2018 to Wed 05/02/2018  
0001 Continuous 0300

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

## MOSES\_\_-ADIRNDCK\_230\_MAl

Mon 02/26/2018 to Fri 03/02/2018  
0700 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## MOSES\_\_-ADIRNDCK\_230\_MAl

Mon 03/05/2018 to Fri 03/09/2018  
0700 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## MARCY\_\_-N.SCTLND\_345\_18

Tue 03/06/2018 to Wed 03/07/2018  
0600 Continuous 1530

Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
CENTRAL EAST - VC	2090 MW
Impacts Total Transfer Capability	885 MW
TTC with All Lines In Service	2975 MW

## MOSES\_\_-ADIRNDCK\_230\_MAl

Mon 03/12/2018 to Fri 03/16/2018  
0700 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## S.RIPLEY-DUNKIRK\_\_230\_68

Mon 03/19/2018 to Fri 04/20/2018  
1000 Continuous 1559

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	1950 MW	1350 MW
Impacts Total Transfer Capability	350 MW	100 MW
TTC with All Lines In Service	2300 MW	1450 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 03/26/2018 to Thu 03/29/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**DUNWODIE\_345KV\_7**

FWD

Sat 03/31/2018 to Sat 03/31/2018

(Import)

0230 Continuous 0300

UPDATEDby CE09/22/2017

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**DUNWODIE\_345KV\_8**

FWD

Sat 03/31/2018 to Sat 03/31/2018

(Import)

0230 Continuous 0300

UPDATEDby CE09/22/2017

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Mon 04/02/2018 to Fri 04/06/2018

(Import)

0700 Continuous 1730

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**LINDN\_CG-LNDVFT\_\_\_345\_V-3022**

FWD

REV

Sun 04/08/2018 to Fri 04/13/2018

(Import) (Export)

1400 Continuous 1800

SCH - PJM\_VFT

**0 MW****0 MW**

Impacts Total Transfer Capability 315 MW

315 MW

TTC with All Lines In Service 315 MW

315 MW

Work scheduled by: PJM

**FRASER\_\_\_-GILBOA\_\_\_345\_GF5-35**

FWD

Mon 04/09/2018 to Fri 04/20/2018

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**MALONE\_\_\_-WILLIS\_\_\_115\_1-910**

REV

Tue 04/10/2018 to Tue 04/10/2018

(Export)

0700 Continuous 1530

SCH - HQ\_CEDARS

**60 MW**

Impacts Total Transfer Capability 40 MW

40 MW

TTC with All Lines In Service 100 MW

100 MW

Work scheduled by: NYPA

**ARR: 38**

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Mon 04/16/2018 to Tue 05/01/2018

0001 Continuous 1800

Work scheduled by: PJM

FWD

(Import)

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

**NEWBRDGE-DUFFYAVE\_345\_501**

Mon 04/16/2018 to Tue 05/01/2018

0001 Continuous 1800

Work scheduled by: PJM

FWD

(Import)

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

**NEWBRDGE\_345\_138\_BK\_1**

Mon 04/16/2018 to Tue 05/01/2018

0001 Continuous 1800

Work scheduled by: PJM

FWD

(Import)

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

**NEWBRDGE\_345\_138\_BK\_2**

Mon 04/16/2018 to Tue 05/01/2018

0001 Continuous 1800

Work scheduled by: PJM

FWD

(Import)

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

**MOSES\_-ADIRNDCK\_230\_MAI**

Mon 04/16/2018 to Fri 04/20/2018

0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

**S.RIPLEY-DUNKIRK\_230\_68**

Fri 04/20/2018 to Sat 02/01/2020

1600 Continuous 0000

Work scheduled by: NYISO

**UPDATED by NYISO 10/09/2017**

FWD

(Import) (Export)

SCH - PJ - NY

**1950 MW 1350 MW**

Impacts Total Transfer Capability 350 MW 100 MW

TTC with All Lines In Service 2300 MW 1450 MW

**MARCY\_765\_345\_AT1**

Mon 04/23/2018 to Mon 04/23/2018

0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

**1750 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

**ARR: 19**



**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**WETHSRFD-MEYER 230\_85/87**

Mon 04/23/2018 to Fri 05/11/2018

0700 Continuous 1500

Work scheduled by: NYSEG

FWD

(Import)

DYSINGER EAST **2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

**MOSES -ADIRNDCK 230\_MA2**

Mon 04/30/2018 to Fri 05/04/2018

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

**HURLYAVE-ROSETON 345\_303**

Mon 04/30/2018 to Fri 05/25/2018

0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED **4100 MW**

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 5100 MW

**MARCY\_SO\_SERIES\_COMP\_I/S**

Tue 05/01/2018 to Wed 10/31/2018

0001 Continuous 2359

Work scheduled by: NYISO

FWD

(Import)

CENTRAL EAST - VC **2740 MW**

Impacts Total Transfer Capability 235 MW

TTC with All Lines In Service 2975 MW

**MOSES -ADIRNDCK 230\_MA2**

Mon 05/07/2018 to Fri 05/11/2018

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

**MOSES -ADIRNDCK 230\_MA2**

Mon 05/14/2018 to Fri 05/18/2018

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

**CLAY -EDIC 345\_1-16**

Mon 05/14/2018 to Fri 05/18/2018

0700 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

OSWEGO EXPORT **4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_\_765\_345\_AT2**

FWD

Mon 05/21/2018 to Fri 05/25/2018

(Import)

0500 Continuous 1730

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19****MOSES\_\_\_\_-ADIRNDCK\_230\_MAI**

FWD

Mon 05/28/2018 to Fri 06/01/2018

(Import)

0700 Continuous 1730

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**STLAWRNC-MOSES\_\_\_\_230\_L33P**

FWD

REV

Mon 05/28/2018 to Fri 06/01/2018

(Import) (Export)

0700 Continuous 2000

SCH - OH - NY

**2000 MW 1600 MW**

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 2000 MW 1600 MW

Work scheduled by: NYPA

**MARCY\_\_\_\_765\_345\_AT1**

FWD

Sat 08/04/2018 to Sun 08/05/2018

(Import)

0500 Continuous 1730

MOSES SOUTH

**1750 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19****MARCY\_\_\_\_765\_345\_AT2**

FWD

Tue 09/04/2018 to Sun 09/09/2018

(Import)

0500 Continuous 1730

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19****ROSETON\_-ROCKTVRN\_345\_311**

FWD

Mon 09/10/2018 to Fri 09/28/2018

(Import)

0800 Continuous 1600

UPNY CONED

**4400 MW**

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: CHGE

**MARCY\_\_\_\_345KV\_CSC**

FWD

Tue 09/11/2018 to Tue 09/11/2018

(Import)

0500 Continuous 1730

CENTRAL EAST - VC

**2925 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**MARCY\_\_\_\_345KV\_CSC & MARCY\_SO\_SERIES\_COMP\_I/S**

Tue 09/11/2018 to Tue 09/11/2018  
0500 1730

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **2690 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 2975 MW

---

**MARCY\_\_\_\_765\_345\_AT2**

Tue 09/11/2018 to Tue 09/11/2018  
0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

---

**NIAGARA\_\_345\_230\_AT4**

Fri 09/14/2018 to Fri 09/14/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **2000 MW 1400 MW**  
Impacts Total Transfer Capability 0 MW 200 MW  
TTC with All Lines In Service 2000 MW 1600 MW

---

**NIAGARA\_-ROCHESTR\_345\_NR2**

Mon 09/17/2018 to Fri 09/21/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

---

**MOSES\_\_-ADIRNDCK\_230\_MA1**

Mon 09/17/2018 to Fri 09/21/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

---

**MOSES\_\_-ADIRNDCK\_230\_MA1**

Mon 09/24/2018 to Fri 09/28/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

---

**CLAY\_\_\_\_-EDIC\_\_\_\_345\_2-15**

Mon 09/24/2018 to Fri 09/28/2018  
0700 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BECK\_\_\_-NIAGARA\_\_\_345\_PA302**

Mon 10/01/2018 to Fri 10/05/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **900 MW 800 MW**  
Impacts Total Transfer Capability 1100 MW 800 MW  
TTC with All Lines In Service 2000 MW 1600 MW

**PANNELL\_-CLAY\_\_\_345\_1**

Mon 10/01/2018 to Fri 10/05/2018  
0700 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**MARCY\_\_\_765\_345\_AT2**

Thu 10/04/2018 to Fri 10/05/2018  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MAL**

Mon 10/08/2018 to Fri 10/12/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**LEEDS\_\_\_-HURLYAVE\_345\_301**

Mon 10/22/2018 to Fri 11/16/2018  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 5100 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MAL**

Mon 10/29/2018 to Fri 11/02/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MAL**

Mon 11/05/2018 to Fri 11/09/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_\_345KV\_CSC**

FWD

Fri 11/16/2018 to Sat 11/17/2018

(Import)

0500 Continuous 1730

CENTRAL EAST - VC

**2925 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**MARCY\_\_\_\_765\_345\_AT2**

FWD

Fri 11/16/2018 to Sat 11/17/2018

(Import)

0500 Continuous 1730

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19****MOSES\_\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Mon 11/19/2018 to Wed 11/21/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**MOSES\_\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 11/26/2018 to Fri 11/30/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**MOSES\_\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 12/03/2018 to Fri 12/07/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**MOSES\_\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 12/10/2018 to Fri 12/14/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**MARCY\_\_\_\_765\_345\_AT2**

FWD

Mon 12/17/2018 to Fri 12/21/2018

(Import)

0500 Continuous 1730

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19**

# NYISO TRANSFER LIMITATIONS

Monday ,October 30, 2017 to Wednesday,May 01, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES\_\_\_\_-ADIRNDCK\_230\_Ma1

FWD

Wed 12/26/2018 to Fri 12/28/2018

( Import )

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA