

**NYISO TRANSFER LIMITATIONS**

Tuesday ,October 24, 2017 to Thursday ,April 25, 2019

**CENTRAL EAST** 3100MW  
**CENTRAL EAST - VC** 2975MW  
**TOTAL EAST** 6500MW  
**UPNY CONED** 5100MW  
**SPR/DUN-SOUTH** 4600MW  
**DYSINGER EAST** 3150MW  
**MOSES SOUTH** 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**HUDSONTP-W49TH\_ST\_345\_Y56**

FWD

Thu 11/24/2016 to Wed 11/15/2017

**EXT FORCE by PJM 10/20/2017**

(Import)

1500 Continuous 2359

Work scheduled by: ConEd

SCH - PJM\_HTP

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

**SCH-NYISO-HQ\_LIMIT\_800**

REV

Thu 06/08/2017 to Fri 12/15/2017

**UPDATED by HQ 08/03/2017**

(Export)

0600 Continuous 1700

Work scheduled by: HQ

SCH - HQ - NY

**800 MW**

Impacts Total Transfer Capability 200 MW

TTC with All Lines In Service 1000 MW

**SCH-HQ-NYISO\_LIMIT\_1450**

FWD

Tue 08/01/2017 to Fri 12/15/2017

(Import)

2100 Continuous 1600

Work scheduled by: HQ

SCH - HQ - NY

**1450 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 1500 MW

**SCH-IMO-NYISO\_LIMIT\_1450**

FWD

Tue 08/29/2017 to Tue 10/31/2017

(Import)

1230 Continuous 2359

Work scheduled by: NYISO

**EXTENDED by NYISO 07/28/2017**

SCH - OH - NY

**1750 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 2000 MW

**FIVEMILE-STOLLERD\_345\_29**

FWD

REV

Thu 09/28/2017 to Fri 10/20/2017

(Import) (Export)

0700 Continuous 1500

Work scheduled by: NYSEG

**UPDATED by NGRID 10/13/2017**

SCH - PJ - NY

**2100 MW 1350 MW**

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 2100 MW 1350 MW

**SPRNBRK\_-W49TH\_ST\_345\_M52**

FWD

Sun 10/01/2017 to Sat 11/04/2017

(Import)

0001 Continuous 2359

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

**CHAT\_DC\_GC2**

FWD

Mon 10/02/2017 to Wed 11/15/2017

(Import)

0500 Continuous 2000

Work scheduled by: HQ

MOSES SOUTH

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,October 24, 2017 to Thursday ,April 25, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CHAT\_DC\_GC2**

REV

Mon 10/02/2017 to Wed 11/15/2017

(Export)

0500 Continuous 2000

Work scheduled by: HQ

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1000 MW

**SCH-HQ-NYISO\_LIMIT\_1150**

FWD

Mon 10/02/2017 to Wed 11/15/2017

(Import)

0500 Continuous 2000

Work scheduled by: HQ

SCH - HQ - NY

**1150 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 1500 MW

**SPRNBRK\_\_345KV\_RNS4**

FWD

Mon 10/02/2017 to Sat 10/28/2017

(Import)

1901 Continuous 0300

Work scheduled by: ConEd

**UPDATED****by CONED 10/03/2017**

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

**BERKSHIR-NORTHFLD\_345\_312**

FWD

REV

Fri 10/06/2017 to Sat 10/28/2017

(Import) (Export)

0700 Continuous 1600

Work scheduled by: ISONE

**UPDATED****by ISONE 10/10/2017**

SCH - NE - NY

**900 MW 1200 MW**

Impacts Total Transfer Capability 500 MW 400 MW

TTC with All Lines In Service 1400 MW 1600 MW

**BERKSHIR-NORTHFLD\_345\_312**

FWD

REV

Fri 10/06/2017 to Sat 10/28/2017

(Import) (Export)

0700 Continuous 1600

Work scheduled by: ISONE

**UPDATED****by ISONE 10/10/2017**

SCH - NPX\_1385

**100 MW 100 MW**

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

**SCH-NYISO-NE\_LIMIT\_600**

REV

Sun 10/08/2017 to Sat 10/28/2017

(Export)

0001 Continuous 1600

Work scheduled by: ISONE

**UPDATED****by ISONE 10/10/2017**

SCH - NE - NY

**800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 1600 MW

**S.RIPLEY-DUNKIRK\_\_230\_68**

FWD

REV

Fri 10/13/2017 to Mon 10/23/2017

(Import) (Export)

1500 Continuous 0759

Work scheduled by: NYISO

**UPDATED****by NYISO 10/09/2017**

SCH - PJ - NY

**1950 MW 1350 MW**

Impacts Total Transfer Capability 150 MW 0 MW

TTC with All Lines In Service 2100 MW 1350 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,October 24, 2017 to Thursday ,April 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BERKSHIR-ALPS</b> _____345_393						FWD	REV
Fri 10/13/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/13/2017</u>	(Import)	(Export)
1516	Continuous	1600				<b>950 MW</b>	<b>1000 MW</b>
Work scheduled by: NGrid					ARR: 78		
					SCH - NE - NY	450 MW	600 MW
					Impacts Total Transfer Capability	1400 MW	1600 MW
					TTC with All Lines In Service		
<b>BERKSHIR-ALPS</b> _____345_393						FWD	REV
Fri 10/13/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/13/2017</u>	(Import)	(Export)
1516	Continuous	1600				<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: NGrid					ARR: 78		
					SCH - NPX_1385	100 MW	100 MW
					Impacts Total Transfer Capability	200 MW	200 MW
					TTC with All Lines In Service		
<b>BERKSHIR-ALPS</b> _____345_393 & <b>BERKSHIR-NORTHFLD</b> _345_312						FWD	REV
Fri 10/13/2017	to	Sat 10/28/2017				(Import)	(Export)
1516		1600				<b>950 MW</b>	<b>1000 MW</b>
Work scheduled by:					ARR: 78		
					SCH - NE - NY	450 MW	600 MW
					Impacts Total Transfer Capability	1400 MW	1600 MW
					TTC with All Lines In Service		
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2 &amp; MOSES</b> ____- <b>MASSENA</b> _230_MMS1 & <b>MOSES</b> ____- <b>MASSENA</b> _230_MMS2						FWD	
Sat 10/14/2017	to	Fri 10/20/2017				(Import)	
0100		2000				<b>1950 MW</b>	
Work scheduled by:							
					MOSES SOUTH	1200 MW	
					Impacts Total Transfer Capability	3150 MW	
					TTC with All Lines In Service		
<b>MARCY</b> _____765_345_AT1						FWD	
Sat 10/14/2017	to	Fri 10/20/2017	<u>UPDATED</u>	<u>by PA</u>	<u>10/22/2017</u>	(Import)	
0100	Continuous	2000				<b>1750 MW</b>	
Work scheduled by: NYPA					ARR: 19		
					MOSES SOUTH	1400 MW	
					Impacts Total Transfer Capability	3150 MW	
					TTC with All Lines In Service		
<b>MARCY</b> _____765_345_AT2						FWD	
Sat 10/14/2017	to	Fri 10/20/2017	<u>UPDATED</u>	<u>by PA</u>	<u>10/22/2017</u>	(Import)	
0100	Continuous	2000				<b>1700 MW</b>	
Work scheduled by: NYPA					ARR: 19		
					MOSES SOUTH	1450 MW	
					Impacts Total Transfer Capability	3150 MW	
					TTC with All Lines In Service		
<b>MASSENA -MARC</b> _____765_MSU1						FWD	
Sat 10/14/2017	to	Fri 10/20/2017	<u>UPDATED</u>	<u>by PA</u>	<u>10/22/2017</u>	(Import)	
0100	Continuous	2000				<b>2265 MW</b>	
Work scheduled by: NYPA							
					CENTRAL EAST - VC	710 MW	
					Impacts Total Transfer Capability	2975 MW	
					TTC with All Lines In Service		

**NYISO TRANSFER LIMITATIONS**

Tuesday ,October 24, 2017 to Thursday ,April 25, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA_-MARCY____765_MSU1</b>							FWD	
Sat 10/14/2017	to	Fri 10/20/2017	<u>UPDATED</u>	<u>by PA</u>	<u>10/22/2017</u>		(Import)	
0100	Continuous	2000				MOSES SOUTH	<b>500 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW	
						TTC with All Lines In Service	3150 MW	
<hr/>								
<b>MASSENA_-MARCY____765_MSU1</b>							FWD	REV
Sat 10/14/2017	to	Fri 10/20/2017	<u>UPDATED</u>	<u>by PA</u>	<u>10/22/2017</u>		(Import)	(Export)
0100	Continuous	2000				SCH - HQ - NY	<b>475 MW</b>	<b>1000 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW	0 MW
						TTC with All Lines In Service	1500 MW	1000 MW
<hr/>								
<b>MASSENA_-MARCY____765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>							FWD	
Sat 10/14/2017	to	Fri 10/20/2017					(Import)	
0100		2000				MOSES SOUTH	<b>500 MW</b>	
Work scheduled by:						Impacts Total Transfer Capability	2650 MW	
						TTC with All Lines In Service	3150 MW	
<hr/>								
<b>MOSES____-MASSENA_230_MMS1 &amp; MOSES____-MASSENA_230_MMS2</b>							FWD	REV
Sat 10/14/2017	to	Fri 10/20/2017					(Import)	(Export)
0100		2000				SCH - HQ - NY	<b>850 MW</b>	<b>0 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	650 MW	1000 MW
						TTC with All Lines In Service	1500 MW	1000 MW
<hr/>								
<b>CHATGUAY-MASSENA_765_7040</b>							FWD	
Sat 10/14/2017	to	Sat 10/21/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>10/22/2017</u>		(Import)	
0100	Continuous	2000				MOSES SOUTH	<b>1550 MW</b>	
Work scheduled by: HQ						Impacts Total Transfer Capability	1600 MW	
						TTC with All Lines In Service	3150 MW	
<hr/>								
<b>CHATGUAY-MASSENA_765_7040</b>							FWD	REV
Sat 10/14/2017	to	Sat 10/21/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>10/22/2017</u>		(Import)	(Export)
0100	Continuous	2000				SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability	1500 MW	1000 MW
						TTC with All Lines In Service	1500 MW	1000 MW
<hr/>								
<b>CHAT_DC_GC1</b>							FWD	
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>10/22/2017</u>		(Import)	
0100	Continuous	2000				MOSES SOUTH	<b>2850 MW</b>	
Work scheduled by: HQ						Impacts Total Transfer Capability	300 MW	
						TTC with All Lines In Service	3150 MW	

# NYISO TRANSFER LIMITATIONS

Tuesday ,October 24, 2017 to Thursday ,April 25, 2019

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC1</b>						REV	
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>10/22/2017</u>	(Export)	
0100	Continuous	2000				500 MW	
Work scheduled by: HQ						500 MW	
						1000 MW	
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>						FWD	
Sat 10/14/2017	to	Sat 10/28/2017				(Import)	
0100		2000				2550 MW	
Work scheduled by:						600 MW	
						3150 MW	
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>						FWD	REV
Sat 10/14/2017	to	Sat 10/28/2017				(Import)	(Export)
0100		2000				1370 MW	0 MW
Work scheduled by:						130 MW	1000 MW
						1500 MW	1000 MW
<b>SCH-HQ-NYISO_LIMIT_700</b>						FWD	
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>10/22/2017</u>	(Import)	
0100	Continuous	2000				700 MW	
Work scheduled by: HQ						800 MW	
						1500 MW	
<b>HOMRC_NY-MAINS_NY_345_47</b>						FWD	REV
Sat 10/14/2017	to	Fri 10/27/2017	<u>UPDATED</u>	<u>by NYSEG</u>	<u>10/11/2017</u>	(Import)	(Export)
0700	Continuous	1730				2100 MW	1350 MW
Work scheduled by: NYSEG						0 MW	0 MW
						2100 MW	1350 MW
<b>SCH-IMO-NYISO_LIMIT_600</b>						FWD	
Mon 10/16/2017	to	Fri 10/20/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/12/2017</u>	(Import)	
0500	Continuous	1700				900 MW	
Work scheduled by: NYPA						1100 MW	
						2000 MW	
<b>SCH-IMO_NY_NIAG_NRTH_BUS_W/BB</b>						FWD	REV
Mon 10/16/2017	to	Fri 10/20/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/12/2017</u>	(Import)	(Export)
0500	Continuous	1700				1000 MW	1150 MW
Work scheduled by: NYPA						1000 MW	450 MW
						2000 MW	1600 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,October 24, 2017 to Thursday ,April 25, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**HURLYAVE-ROSETON\_\_345\_303**

FWD

Mon 10/16/2017 to Fri 11/03/2017

UPDATEDby CH06/07/2017

(Import)

0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 5100 MW

**LEEDS\_\_-HURLYAVE\_345\_301**

FWD

Mon 10/16/2017 to Fri 11/03/2017

(Import)

0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 5100 MW

**COOPERS\_-MIDDLETP\_345\_CCRT34**

FWD

Tue 10/17/2017 to Sat 10/28/2017

UPDATEDby NY10/16/2017

(Import)

0700 Continuous 1500

Work scheduled by: NYSEG

CENTRAL EAST - VC

**2720 MW**

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

**SCH-NE-NYISO\_LIMIT\_700**

FWD

Fri 10/20/2017 to Wed 10/25/2017

UPDATEDby NE10/18/2017

(Import)

0700 Continuous 1600

Work scheduled by: ISONE

SCH - NE - NY

**900 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1400 MW

**MARCY\_SO\_SERIES\_COMP\_I/S**

FWD

Fri 10/20/2017 to Tue 10/31/2017

CANCELLEDby NYSEG10/20/2017

(Import)

2000 Continuous 2359

Work scheduled by: NYISO

CENTRAL EAST - VC

**2740 MW**

Impacts Total Transfer Capability 235 MW

TTC with All Lines In Service 2975 MW

**SCH-NE-NYISO\_LIMIT\_600**

FWD

Sat 10/21/2017 to Sun 10/22/2017

UPDATEDby NE10/18/2017

(Import)

0600 Continuous 1800

Work scheduled by: ISONE

SCH - NE - NY

**800 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 1400 MW

**SCH-IMO-NYISO\_LIMIT\_500**

FWD

Mon 10/23/2017 to Mon 10/23/2017

UPDATEDby NYSEG10/21/2017

(Import)

0800 Continuous 1410

Work scheduled by: NYSEG

SCH - OH - NY

**800 MW**

Impacts Total Transfer Capability 1200 MW

TTC with All Lines In Service 2000 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,October 24, 2017 to Thursday ,April 25, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**S.RIPLEY-DUNKIRK\_\_230\_68**Mon 10/23/2017 to Thu 10/26/2017 **UPDATED** **by NYISO** **08/01/2017**

0800 Continuous 1500

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>1950 MW</b>	<b>1350 MW</b>
Impacts Total Transfer Capability	150 MW	0 MW
TTC with All Lines In Service	2100 MW	1350 MW

**BECK\_\_-NIAGARA\_\_345\_PA301**

Tue 10/24/2017 to Wed 10/25/2017

0500 Continuous 1700

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>900 MW</b>	<b>800 MW</b>
Impacts Total Transfer Capability	1100 MW	800 MW
TTC with All Lines In Service	2000 MW	1600 MW

**NIAGARA\_-KINTIGH\_\_345\_NS1-38**Tue 10/24/2017 to Thu 10/26/2017 **UPDATED** **by NYPA** **10/09/2017**

0600 Continuous 1559

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>1700 MW</b>
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

**CHASLAKE-PORTER\_\_230\_11**

Wed 10/25/2017 to Thu 10/26/2017

0730 Continuous 1900

Work scheduled by: NGrid

	FWD
	(Import)
MOSES SOUTH	<b>2100 MW</b>
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

**SCH-HQ-NYISO\_LIMIT\_600**

Wed 10/25/2017 to Wed 10/25/2017

1000 Continuous 1600

Work scheduled by: HQ

	FWD
	(Import)
SCH - HQ - NY	<b>600 MW</b>
Impacts Total Transfer Capability	900 MW
TTC with All Lines In Service	1500 MW

**FRASER\_\_-COOPERS\_\_345\_33**

Thu 10/26/2017 to Thu 10/26/2017

0800 Continuous 1700

Work scheduled by: NYSEG

	FWD
	(Import)
CENTRAL EAST - VC	<b>2395 MW</b>
Impacts Total Transfer Capability	580 MW
TTC with All Lines In Service	2975 MW

**S.RIPLEY-DUNKIRK\_\_230\_68**Thu 10/26/2017 to Mon 03/19/2018 **UPDATED** **by NYISO** **10/09/2017**

1501 Continuous 0959

Work scheduled by: NYISO

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>1950 MW</b>	<b>1350 MW</b>
Impacts Total Transfer Capability	150 MW	0 MW
TTC with All Lines In Service	2100 MW	1350 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,October 24, 2017 to Thursday ,April 25, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_SO\_SERIES\_COMP\_I/S**

FWD

Thu 10/26/2017 to Fri 11/03/2017

(Import)

1700 Continuous 1600

CENTRAL EAST - VC

**2740 MW**

Impacts Total Transfer Capability 235 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYISO

**W49TH\_ST\_345KV\_5**

FWD

Fri 10/27/2017 to Sat 11/04/2017

(Import)

0001 Continuous 2359

SCH - PJM\_HTP

**315 MW**

Impacts Total Transfer Capability 345 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**VOLNEY\_\_-CLAY\_\_\_\_345\_6**

FWD

Fri 10/27/2017 to Fri 10/27/2017

(Import)

0800 Daily(No Weekends) 1800

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

**SPRNBK\_\_345KV\_RNS4**

FWD

Sat 10/28/2017 to Sat 11/04/2017

(Import)

0301 Continuous 2359

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**DENNISON-ROSEMNTA\_115\_1/11**

FWD

REV

Mon 10/30/2017 to Thu 11/09/2017

(Import) (Export)

0600 Continuous 1600

SCH - HQ\_CEDARS

**95 MW 40 MW**

Impacts Total Transfer Capability 95 MW 0 MW

TTC with All Lines In Service 190 MW 40 MW

Work scheduled by: HQ

**ARR: 38****SCH-HQ\_CEDARS-NYISO\_LIMIT\_100**

FWD

Mon 10/30/2017 to Thu 11/09/2017

(Import)

0600 Continuous 1600

SCH - HQ\_CEDARS

**100 MW**

Impacts Total Transfer Capability 90 MW

TTC with All Lines In Service 190 MW

Work scheduled by: HQ

**MOSES\_\_-ADIRNDCK\_230\_MAL**

FWD

Mon 10/30/2017 to Sat 11/04/2017

(Import)

0700 Continuous 1530

**CANCELLED by NYPA 10/24/2017**

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA



**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 10/30/2017 to Sat 11/04/2017

(Import)

0700 Continuous 1530

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

FWD

Tue 10/31/2017 to Thu 11/02/2017

(Import)

0001 Continuous 2359

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

**NEWBRDGE-DUFFYAVE\_345\_501**

FWD

Tue 10/31/2017 to Thu 11/02/2017

(Import)

0001 Continuous 2359

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

**NEWBRDGE\_345\_138\_BK\_1**

FWD

Tue 10/31/2017 to Thu 11/02/2017

(Import)

0001 Continuous 2359

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

**NEWBRDGE\_345\_138\_BK\_2**

FWD

Tue 10/31/2017 to Thu 11/02/2017

(Import)

0001 Continuous 2359

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

**PLSNTVLY-EFISHKIL\_345\_F36**

FWD

Wed 11/01/2017 to Sat 11/04/2017

(Import)

0001 Continuous 0300

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**LAFAYTTE-CLRKSCRN\_345\_4-46**

FWD

Wed 11/01/2017 to Thu 11/02/2017

(Import)

0630 Continuous 1630

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**NYISO TRANSFER LIMITATIONS**

Tuesday ,October 24, 2017 to Thursday ,April 25, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**COOPERS\_-DOLSONAV\_345\_CCDA42**

FWD

Wed 11/01/2017 to Sat 11/04/2017

(Import)

0830 Continuous 1800

CENTRAL EAST - VC

**2720 MW**

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

**MARION\_-FARRAGUT\_345\_C3403**

FWD

REV

Thu 11/02/2017 to Sat 12/02/2017

**UPDATED****by CE****09/29/2017**

(Import) (Export)

0001 Continuous 0100

SCH - PJ - NY

**2300 MW 1450 MW**

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 2300 MW 1450 MW

Work scheduled by: ConEd

**BERKSHIR-ALPS\_\_\_\_\_345\_393 & BERKSHIR-NORTHFLD\_345\_312**

FWD

REV

Thu 11/02/2017 to Thu 11/02/2017

(Import) (Export)

0700 0900

SCH - NE - NY

**1300 MW 1300 MW**

Impacts Total Transfer Capability 100 MW 300 MW

TTC with All Lines In Service 1400 MW 1600 MW

Work scheduled by:

**ARR: 78****BERKSHIR-NORTHFLD\_345\_312**

FWD

REV

Thu 11/02/2017 to Thu 11/02/2017

**UPDATED****by NE****10/17/2017**

(Import) (Export)

0700 Continuous 0900

SCH - NE - NY

**1400 MW 1450 MW**

Impacts Total Transfer Capability 0 MW 150 MW

TTC with All Lines In Service 1400 MW 1600 MW

Work scheduled by: NGrid

**BERKSHIR-NORTHFLD\_345\_312**

FWD

REV

Thu 11/02/2017 to Thu 11/02/2017

**UPDATED****by NE****10/17/2017**

(Import) (Export)

0700 Continuous 0900

SCH - NPX\_1385

**100 MW 100 MW**

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

Work scheduled by: NGrid

**BERKSHIR-ALPS\_\_\_\_\_345\_393**

FWD

REV

Thu 11/02/2017 to Sat 11/04/2017

**UPDATED****by NE****10/17/2017**

(Import) (Export)

0700 Continuous 1900

SCH - NE - NY

**1300 MW 1300 MW**

Impacts Total Transfer Capability 100 MW 300 MW

TTC with All Lines In Service 1400 MW 1600 MW

Work scheduled by: NGrid

**ARR: 78****BERKSHIR-ALPS\_\_\_\_\_345\_393**

FWD

REV

Thu 11/02/2017 to Sat 11/04/2017

**UPDATED****by NE****10/17/2017**

(Import) (Export)

0700 Continuous 1900

SCH - NPX\_1385

**100 MW 100 MW**

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

Work scheduled by: NGrid

**ARR: 78**

**NYISO TRANSFER LIMITATIONS**

Tuesday ,October 24, 2017 to Thursday ,April 25, 2019

**CENTRAL EAST** 3100MW  
**CENTRAL EAST - VC** 2975MW  
**TOTAL EAST** 6500MW  
**UPNY CONED** 5100MW  
**SPR/DUN-SOUTH** 4600MW  
**DYSINGER EAST** 3150MW  
**MOSES SOUTH** 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-NE-NYISO\_LIMIT\_500**

FWD

Thu 11/02/2017 to Sat 11/04/2017 **UPDATED** **by NE** **10/17/2017**

(Import)

0700 Continuous 1900

Work scheduled by: NGrid

SCH - NE - NY

**700 MW**

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 1400 MW

**SCH-NYISO-NE\_LIMIT\_700**

REV

Thu 11/02/2017 to Sat 11/04/2017 **UPDATED** **by NE** **10/17/2017**

(Export)

0700 Continuous 1900

Work scheduled by: NGrid

SCH - NE - NY

**900 MW**

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 1600 MW

**BERKSHIR-ALPS\_\_\_\_\_345\_393 & BERKSHIR-NORTHFLD\_345\_312**

FWD

REV

Sat 11/04/2017 to Sat 11/04/2017

(Import) (Export)

1800 1900

Work scheduled by:

**ARR: 78**

SCH - NE - NY

**1300 MW****1300 MW**

Impacts Total Transfer Capability 100 MW

300 MW

TTC with All Lines In Service 1400 MW

1600 MW

**BERKSHIR-NORTHFLD\_345\_312**

FWD

REV

Sat 11/04/2017 to Sat 11/04/2017 **UPDATED** **by NE** **10/17/2017**

(Import) (Export)

1800 Continuous 1900

Work scheduled by: NGrid

SCH - NE - NY

**1400 MW****1450 MW**

Impacts Total Transfer Capability 0 MW

150 MW

TTC with All Lines In Service 1400 MW

1600 MW

**BERKSHIR-NORTHFLD\_345\_312**

FWD

REV

Sat 11/04/2017 to Sat 11/04/2017 **UPDATED** **by NE** **10/17/2017**

(Import) (Export)

1800 Continuous 1900

Work scheduled by: NGrid

SCH - NPX\_1385

**100 MW****100 MW**

Impacts Total Transfer Capability 100 MW

100 MW

TTC with All Lines In Service 200 MW

200 MW

**PLSNTVLY-EFISHKIL\_345\_F36**

FWD

Mon 11/06/2017 to Wed 11/08/2017

(Import)

0001 Continuous 0300

Work scheduled by: ConEd

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

**MOSES\_\_\_\_-ADIRNDCK\_230\_MAI**

FWD

Mon 11/06/2017 to Thu 11/09/2017

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,October 24, 2017 to Thursday ,April 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 11/06/2017 to Thu 11/09/2017  
0700 Continuous 1530

**CANCELLED by NYPA 10/23/2017**

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## FRASANNX-COOPERS\_\_\_345\_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

## MARCY\_\_\_-FRASANNX\_345\_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

## LINDN\_CG-LNDVFT\_\_\_345\_V-3022

Mon 11/06/2017 to Thu 11/09/2017  
0800 Continuous 1500

Work scheduled by: PJM

FWD REV  
(Import) (Export)  
SCH - PJM\_VFT **0 MW 0 MW**  
Impacts Total Transfer Capability 315 MW 315 MW  
TTC with All Lines In Service 315 MW 315 MW

## SCRIBA\_\_\_-VOLNEY\_\_\_345\_20

Mon 11/06/2017 to Fri 11/17/2017  
0800 Continuous 1630

Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

## ROCHESTR-PANNELL\_\_\_345\_RP1

Mon 11/06/2017 to Tue 11/07/2017  
0900 Continuous 1500

Work scheduled by: RGE

FWD  
(Import)  
DYSINGER EAST **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## W49TH\_ST\_345KV\_5

Fri 11/10/2017 to Fri 11/10/2017  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **315 MW**  
Impacts Total Transfer Capability 345 MW  
TTC with All Lines In Service 660 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,October 24, 2017 to Thursday ,April 25, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SPRNBRK\_-W49TH\_ST\_345\_M52**

FWD

Fri 11/10/2017 to Mon 11/13/2017 **UPDATED** **by CONED** **10/03/2017**

(Import)

0001 Continuous 0300

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**SPRNBRK\_345KV\_RNS4**

FWD

Fri 11/10/2017 to Mon 11/13/2017 **UPDATED** **by CONED** **10/03/2017**

(Import)

0001 Continuous 0300

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**SPRNBRK\_345KV\_RS3 & SPRNBRK\_345KV\_RS4**

FWD

Sun 11/12/2017 to Wed 11/15/2017

(Import)

0001 0300

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

Work scheduled by:

**E13THSTA-FARRAGUT\_345\_46**

FWD

Sun 11/12/2017 to Sun 11/12/2017 **UPDATED** **by CE** **10/20/2017**

(Import)

0230 Continuous 0300

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**W49TH\_ST\_345KV\_5**

FWD

Mon 11/13/2017 to Mon 11/13/2017 **UPDATED** **by CONED** **10/03/2017**

(Import)

0230 Continuous 0300

SCH - PJM\_HTP **315 MW**  
 Impacts Total Transfer Capability 345 MW  
 TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**MOSES\_-ADIRNDCK\_230\_MAI**

FWD

Mon 11/13/2017 to Fri 11/17/2017 **UPDATED** **by PA** **10/24/2017**

(Import)

0700 Continuous 1530

MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**SPRNBRK\_345KV\_RNS4**

FWD

Wed 11/15/2017 to Fri 11/17/2017 **UPDATED** **by CONED** **10/03/2017**

(Import)

0001 Continuous 0100

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**NYISO TRANSFER LIMITATIONS**

Tuesday ,October 24, 2017 to Thursday ,April 25, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST-E13THSTA\_345\_M55**

FWD

Fri 11/17/2017 to Fri 11/17/2017 **UPDATED** **by NYISO** **10/20/2017**

(Import)

0101 Continuous 0301

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

Work scheduled by: NYPA

**W49TH\_ST\_345KV\_6**

FWD

Fri 11/17/2017 to Fri 11/17/2017 **UPDATED** **by NYISO** **10/20/2017**

(Import)

0101 Continuous 0301

SCH - PJM\_HTP **310 MW**  
 Impacts Total Transfer Capability 350 MW  
 TTC with All Lines In Service 660 MW

Work scheduled by: NYPA

**E13THSTA-FARRAGUT\_345\_45**

FWD

Sat 11/18/2017 to Tue 05/15/2018

(Import)

0000 Continuous 2359

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**W49TH\_ST-E13THSTA\_345\_M54**

FWD

Sat 11/18/2017 to Tue 05/15/2018

(Import)

0000 Continuous 2359

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**EGRDNCTY\_345\_138\_AT1**

FWD

Sun 11/19/2017 to Sun 12/24/2017 **UPDATED** **by LI** **08/01/2017**

(Import)

0001 Continuous 0300

CONED - LIPA **1250 MW**  
 Impacts Total Transfer Capability 250 MW  
 TTC with All Lines In Service 1500 MW

Work scheduled by: LI

**EGRDNCTY\_345\_138\_AT2**

FWD

Sun 11/19/2017 to Sun 12/24/2017 **UPDATED** **by LI** **08/01/2017**

(Import)

0001 Continuous 0300

CONED - LIPA **1250 MW**  
 Impacts Total Transfer Capability 250 MW  
 TTC with All Lines In Service 1500 MW

Work scheduled by: LI

**SPRNBK\_-EGRDNCTR\_345\_Y49**

FWD

Sun 11/19/2017 to Sun 12/24/2017 **UPDATED** **by LI** **08/01/2017**

(Import)

0001 Continuous 0300

CONED - LIPA **775 MW**  
 Impacts Total Transfer Capability 725 MW  
 TTC with All Lines In Service 1500 MW

Work scheduled by: LI

**NYISO TRANSFER LIMITATIONS**

Tuesday ,October 24, 2017 to Thursday ,April 25, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CEDARS\_\_-ROSEMNTB\_115\_2/22**

Mon 11/20/2017 to Thu 12/07/2017

0500 Continuous 1600

Work scheduled by: HQ

**ARR: 38**

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD REV  
 (Import) (Export)

**95 MW 100 MW**

104 MW 0 MW

199 MW 100 MW

**DENNISON-ROSEMNTB\_115\_2/22**

Mon 11/20/2017 to Thu 12/07/2017

0500 Continuous 1600

Work scheduled by: HQ

**ARR: 38**

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD REV  
 (Import) (Export)

**95 MW 100 MW**

104 MW 0 MW

199 MW 100 MW

**SCH-HQ\_CEDARS-NYISO\_LIMIT\_100**

Mon 11/20/2017 to Thu 12/07/2017

0500 Continuous 1600

Work scheduled by: HQ

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
 (Import)

**100 MW**

99 MW

199 MW

**MOSES\_\_-ADIRNDCK\_230\_MAI**

Mon 11/20/2017 to Wed 11/22/2017

0700 Continuous 1730

Work scheduled by: NYPA

**UPDATED****by NYPA****10/13/2017**

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
 (Import)

**2300 MW**

850 MW

3150 MW

**WETHSRFD-MEYER\_\_230\_85/87**

Mon 11/20/2017 to Fri 12/01/2017

1630 Continuous 1400

Work scheduled by: NYSEG

**UPDATED****by NYSEG****09/13/2017**

DYSINGER EAST

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
 (Import)

**2850 MW**

300 MW

3150 MW

**N.SCTLND-LEEDS\_\_345\_93**

Tue 11/21/2017 to Wed 11/22/2017

0800 Continuous 1500

Work scheduled by: NGrid

**UPDATED****by NGRID****10/09/2017**

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
 (Import)

**2650 MW**

325 MW

2975 MW

**MOSES\_\_-ADIRNDCK\_230\_MAI**

Mon 11/27/2017 to Fri 12/01/2017

0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
 (Import)

**2300 MW**

850 MW

3150 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**ROSETON\_-EFISHKIL\_345\_RFK305**

FWD

Mon 11/27/2017 to Fri 12/01/2017

(Import)

0800 Continuous 1600

UPNY CONED

**4800 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: CHGE

**ROTTRDAM-EASTOVER\_230\_38**

FWD

REV

Mon 11/27/2017 to Thu 11/30/2017

(Import) (Export)

0900 Continuous 1500

SCH - NE - NY

**1400 MW 1400 MW**

Impacts Total Transfer Capability 0 MW 200 MW

TTC with All Lines In Service 1400 MW 1600 MW

Work scheduled by: NGrid

**ARR: 77****ROSETON\_-EFISHKIL\_345\_RFK305**

FWD

Sat 12/02/2017 to Sat 12/02/2017

(Import)

0001 Continuous 2359

UPNY CONED

**4800 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

FWD

Sun 12/03/2017 to Tue 12/05/2017

(Import)

0001 0300

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by:

**LEEDS\_-PLSNTVLY\_345\_92**

FWD

Mon 12/04/2017 to Mon 12/18/2017

(Import)

0001 Continuous 0300

**UPDATED****by NYISO 09/12/2017**

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**PLSNTVLY\_345KV\_RNS5**

FWD

Mon 12/04/2017 to Mon 12/18/2017

(Import)

0001 Continuous 0300

**UPDATED****by NYISO 09/12/2017**

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**MARCY\_765\_345\_AT2**

FWD

Mon 12/04/2017 to Fri 12/08/2017

(Import)

0500 Continuous 1630

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19**



# NYISO TRANSFER LIMITATIONS

Tuesday ,October 24, 2017 to Thursday ,April 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NRTH1385-NRTHPORT\_138\_NNC

Mon 12/04/2017 to Wed 12/13/2017  
0700 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

## MOSES -ADIRNDCK\_230\_MA2

Mon 12/11/2017 to Fri 12/15/2017  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## NIAGARA -KINTIGH\_345\_NS1-38

Mon 12/11/2017 to Wed 12/20/2017  
0800 Continuous 1600

Work scheduled by: NYSEG

UPDATED by NYISO 10/20/2017

	FWD
	(Import)
DYSINGER EAST	1700 MW
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

## MOSES -ADIRNDCK\_230\_MA2

Mon 12/18/2017 to Fri 12/22/2017  
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 10/23/2016

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## N.SCTLND-LEEDS\_345\_94

Tue 12/19/2017 to Wed 12/20/2017  
0800 Continuous 1500

Work scheduled by: NGrid

	FWD
	(Import)
CENTRAL EAST - VC	2650 MW
Impacts Total Transfer Capability	325 MW
TTC with All Lines In Service	2975 MW

## MARCY\_765\_345\_AT2

Wed 12/27/2017 to Thu 12/28/2017  
0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
MOSES SOUTH	1700 MW
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

## DUNWODIE-SHORE\_RD\_345\_Y50

Tue 01/02/2018 to Thu 01/04/2018  
0001 Continuous 2359

Work scheduled by: ConEd

EXTENDED by LI 09/22/2017

	FWD
	(Import)
CONED - LIPA	800 MW
Impacts Total Transfer Capability	700 MW
TTC with All Lines In Service	1500 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,October 24, 2017 to Thursday ,April 25, 2019

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_4

FWD

Tue 01/02/2018 to Thu 01/04/2018 EXTENDED by LI 09/22/2017

(Import)

0001 Continuous 2359

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### DUNWODIE\_345KV\_6

FWD

Tue 01/02/2018 to Thu 01/04/2018 EXTENDED by LI 09/22/2017

(Import)

0001 Continuous 2359

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### SHORE\_RD\_345\_138\_BK 1

FWD

Tue 01/02/2018 to Thu 01/04/2018 EXTENDED by LI 09/22/2017

(Import)

0001 Continuous 2359

CONED - LIPA **1350 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: ConEd

### SHORE\_RD\_345\_138\_BK 2

FWD

Tue 01/02/2018 to Thu 01/04/2018 EXTENDED by LI 09/22/2017

(Import)

0001 Continuous 2359

CONED - LIPA **1350 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: ConEd

### MOSES\_\_-ADIRNDCK\_230\_MA1

FWD

Tue 01/02/2018 to Fri 01/05/2018

(Import)

0700 Continuous 1730

MOSES SOUTH **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

### LEEDS\_\_-PLSNTVLY\_345\_92

FWD

Wed 01/03/2018 to Sat 01/06/2018 UPDATED by NYISO 09/12/2017

(Import)

0001 Continuous 0300

UPNY CONED **3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

### PLSNTVLY\_345KV\_RNS5

FWD

Wed 01/03/2018 to Sat 01/06/2018 UPDATED by NYISO 09/12/2017

(Import)

0001 Continuous 0300

UPNY CONED **3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

FWD

Fri 01/05/2018 to Sun 01/07/2018  
0001 2359

(Import)

Work scheduled by:

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

**PLSNTVLY\_345KV\_RNS5**

FWD

Mon 01/08/2018 to Wed 01/10/2018  
0001 Continuous 0300

(Import)

Work scheduled by: ConEd

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

**EASTVIEW-SPRNBK\_\_345\_W64**

FWD

Mon 01/08/2018 to Fri 02/23/2018  
0001 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

**MILLWOOD-EASTVIEW\_345\_W99**

FWD

Mon 01/08/2018 to Fri 02/23/2018  
0001 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

**SPRNBK\_\_345KV\_RNS5**

FWD

Mon 01/08/2018 to Fri 02/23/2018  
0001 Continuous 0200

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

**MOSES\_\_-ADIRNDCK\_230\_MAL**

FWD

Mon 01/08/2018 to Fri 01/12/2018  
0700 Continuous 1730

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**FRASER\_\_-COOPERS\_\_345\_33**

FWD

Mon 01/08/2018 to Thu 01/11/2018  
0800 Continuous 1500

(Import)

Work scheduled by: NYSEG

CENTRAL EAST - VC **2395 MW**  
Impacts Total Transfer Capability 580 MW  
TTC with All Lines In Service 2975 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,October 24, 2017 to Thursday ,April 25, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>N.SCTLND-ALPS_____345_2</b>							
Mon 01/08/2018	to	Fri 02/02/2018	<u>UPDATED</u>	<u>by NG</u>	<u>10/17/2017</u>		
0800	Continuous	1400				<b>900 MW</b>	<b>1600 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	500 MW
						TTC with All Lines In Service	1400 MW
<b>N.SCTLND-ALPS_____345_2</b>							
Mon 01/08/2018	to	Fri 02/02/2018	<u>UPDATED</u>	<u>by NG</u>	<u>10/17/2017</u>		
0800	Continuous	1400				<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
<b>MOSES____-ADIRNDCK_230_MA1</b>							
Mon 01/15/2018	to	Fri 01/19/2018					
0700	Continuous	1530				<b>2300 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
<b>MARCY_____765_345_AT2</b>							
Sat 01/20/2018	to	Sat 01/20/2018					
0500	Continuous	1730				<b>1700 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1450 MW
						TTC with All Lines In Service	3150 MW
<b>MOSES____-ADIRNDCK_230_MA1</b>							
Mon 01/22/2018	to	Fri 01/26/2018					
0700	Continuous	1530				<b>2300 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
<b>MOSES____-ADIRNDCK_230_MA1</b>							
Mon 01/29/2018	to	Fri 02/02/2018					
0700	Continuous	1530				<b>2300 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
<b>MARCY_____765_345_AT2</b>							
Sat 02/03/2018	to	Sat 02/03/2018					
0500	Continuous	1730				<b>1700 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1450 MW
						TTC with All Lines In Service	3150 MW

ARR: 19

ARR: 19

**NYISO TRANSFER LIMITATIONS**

Tuesday ,October 24, 2017 to Thursday ,April 25, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_\_765\_345\_AT2**

FWD

Mon 02/05/2018 to Fri 02/09/2018

(Import)

0500 Continuous 1730

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19****MOSES\_\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 02/12/2018 to Fri 02/16/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**HUDSONP\_-FARRAGUT\_345\_B3402**

FWD

REV

Sun 02/18/2018 to Sun 04/01/2018

(Import) (Export)

0001 Continuous 2359

SCH - PJ - NY

**2300 MW 1450 MW**

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 2300 MW 1450 MW

Work scheduled by: PJM

**MARCY\_\_\_\_-EDIC\_\_\_\_345\_UE1-7**

FWD

Tue 02/20/2018 to Fri 02/23/2018

(Import)

0500 Continuous 1730

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19&16****MOSES\_\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Tue 02/20/2018 to Fri 02/23/2018

(Import)

0700 Continuous 1730

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**DUNWODIE\_345KV\_7**

FWD

Sat 02/24/2018 to Sat 02/24/2018

(Import)

0001 Continuous 0030

**UPDATED****by CE****09/22/2017**

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**DUNWODIE\_345KV\_8**

FWD

Sat 02/24/2018 to Sat 02/24/2018

(Import)

0001 Continuous 0030

**UPDATED****by CE****09/22/2017**

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Tuesday ,October 24, 2017 to Thursday ,April 25, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## DUNWODIE-MOTTHAVN\_345\_72

Sat 02/24/2018 to Sat 03/31/2018  
0001 Continuous 0300

UPDATEDby CE09/22/2017

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

## LONG\_MTN-PLSNTVLY\_345\_398

Mon 02/26/2018 to Wed 05/02/2018  
0001 Continuous 0300

Work scheduled by: ConEd

FWD

(Import)

REV

(Export)

SCH - NE - NY

**700 MW 1300 MW**

Impacts Total Transfer Capability 700 MW 300 MW

TTC with All Lines In Service 1400 MW 1600 MW

## LONG\_MTN-PLSNTVLY\_345\_398

Mon 02/26/2018 to Wed 05/02/2018  
0001 Continuous 0300

Work scheduled by: ConEd

FWD

(Import)

REV

(Export)

SCH - NPX\_1385

**100 MW 100 MW**

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

## MOSES\_\_-ADIRNDCK\_230\_MAI

Mon 02/26/2018 to Fri 03/02/2018  
0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## MOSES\_\_-ADIRNDCK\_230\_MAI

Mon 03/05/2018 to Fri 03/09/2018  
0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## MARCY\_\_-N.SCTLND\_345\_18

Tue 03/06/2018 to Wed 03/07/2018  
0600 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC

**2090 MW**

Impacts Total Transfer Capability 885 MW

TTC with All Lines In Service 2975 MW

ARR: 19

## MOSES\_\_-ADIRNDCK\_230\_MAI

Mon 03/12/2018 to Fri 03/16/2018  
0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,October 24, 2017 to Thursday ,April 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## S.RIPLEY-DUNKIRK\_\_230\_68

Mon 03/19/2018 to Fri 04/20/2018  
1000 Continuous 1559

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>1950 MW</b>	<b>1350 MW</b>
Impacts Total Transfer Capability	350 MW	100 MW
TTC with All Lines In Service	2300 MW	1450 MW

## MOSES\_\_-ADIRNDCK\_230\_MA2

Mon 03/26/2018 to Thu 03/29/2018  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2300 MW</b>
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## DUNWODIE\_345KV\_7

Sat 03/31/2018 to Sat 03/31/2018  
0230 Continuous 0300

Work scheduled by: ConEd

UPDATED by CE 09/22/2017

	FWD
	(Import)
SPR/DUN-SOUTH	<b>3800 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

## DUNWODIE\_345KV\_8

Sat 03/31/2018 to Sat 03/31/2018  
0230 Continuous 0300

Work scheduled by: ConEd

UPDATED by CE 09/22/2017

	FWD
	(Import)
SPR/DUN-SOUTH	<b>3800 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

## MOSES\_\_-ADIRNDCK\_230\_MA1

Mon 04/02/2018 to Fri 04/06/2018  
0700 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2300 MW</b>
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## LINDN\_CG-LNDVFT\_\_345\_V-3022

Sun 04/08/2018 to Fri 04/13/2018  
1400 Continuous 1800

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

## FRASER\_\_-GILBOA\_\_345\_GF5-35

Mon 04/09/2018 to Fri 04/20/2018  
0700 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2650 MW</b>
Impacts Total Transfer Capability	325 MW
TTC with All Lines In Service	2975 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,October 24, 2017 to Thursday ,April 25, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MALONE\_\_-WILLIS\_\_115\_1-910**

Tue 04/10/2018 to Tue 04/10/2018  
 0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 38**

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

**60 MW**

40 MW

100 MW

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Mon 04/16/2018 to Tue 05/01/2018  
 0001 Continuous 1800

Work scheduled by: PJM

SCH - PJM\_NEPTUNE

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

FWD

(Import)

**0 MW****NEWBRDGE-DUFFYAVE\_345\_501**

Mon 04/16/2018 to Tue 05/01/2018  
 0001 Continuous 1800

Work scheduled by: PJM

SCH - PJM\_NEPTUNE

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

FWD

(Import)

**0 MW****NEWBRDGE\_345\_138\_BK\_1**

Mon 04/16/2018 to Tue 05/01/2018  
 0001 Continuous 1800

Work scheduled by: PJM

SCH - PJM\_NEPTUNE

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

FWD

(Import)

**375 MW****NEWBRDGE\_345\_138\_BK\_2**

Mon 04/16/2018 to Tue 05/01/2018  
 0001 Continuous 1800

Work scheduled by: PJM

SCH - PJM\_NEPTUNE

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

FWD

(Import)

**375 MW****MOSES\_\_-ADIRNDCK\_230\_MAI**

Mon 04/16/2018 to Fri 04/20/2018  
 0700 Continuous 1730

Work scheduled by: NYPA

MOSES SOUTH

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

FWD

(Import)

**2300 MW****S.RIPLEY-DUNKIRK\_230\_68**

Fri 04/20/2018 to Sat 02/01/2020  
 1600 Continuous 0000

Work scheduled by: NYISO

**UPDATED****by NYISO 10/09/2017**

SCH - PJ - NY

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 2300 MW

FWD

(Import) (Export)

**1950 MW 1350 MW**

100 MW

1450 MW



**NYISO TRANSFER LIMITATIONS**

Tuesday ,October 24, 2017 to Thursday ,April 25, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_765\_345\_AT1**

FWD

Mon 04/23/2018 to Mon 04/23/2018

(Import)

0500 Continuous 1730

MOSES SOUTH

**1750 MW**

Work scheduled by: NYPA

**ARR: 19**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

**WETHSRFD-MEYER\_\_\_230\_85/87**

FWD

Mon 04/23/2018 to Fri 05/11/2018

(Import)

0700 Continuous 1500

DYSINGER EAST

**2850 MW**

Work scheduled by: NYSEG

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 04/30/2018 to Fri 05/04/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

**HURLYAVE-ROSETON\_\_\_345\_303**

FWD

Mon 04/30/2018 to Fri 05/25/2018

(Import)

0800 Continuous 1600

UPNY CONED

**4100 MW**

Work scheduled by: CHGE

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 5100 MW

**MARCY\_SO\_SERIES\_COMP\_I/S**

FWD

Tue 05/01/2018 to Wed 10/31/2018

(Import)

0001 Continuous 2359

CENTRAL EAST - VC

**2740 MW**

Work scheduled by: NYISO

Impacts Total Transfer Capability 235 MW

TTC with All Lines In Service 2975 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 05/07/2018 to Fri 05/11/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2100 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 05/14/2018 to Fri 05/18/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2100 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY\_\_\_\_-EDIC\_\_\_\_345\_1-16

Mon 05/14/2018 to Fri 05/18/2018

0700 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

OSWEGO EXPORT

**4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

MARCY\_\_\_\_765\_345\_AT2

Mon 05/21/2018 to Fri 05/25/2018

0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

MOSES\_\_\_\_-ADIRNDCK\_230\_MAI

Mon 05/28/2018 to Fri 06/01/2018

0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

STLAWRNC-MOSES\_\_\_\_230\_L33P

Mon 05/28/2018 to Fri 06/01/2018

0700 Continuous 2000

Work scheduled by: NYPA

FWD

REV

(Import) (Export)

SCH - OH - NY

**2000 MW 1600 MW**

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 2000 MW 1600 MW

MARCY\_\_\_\_765\_345\_AT1

Sat 08/04/2018 to Sun 08/05/2018

0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

MOSES SOUTH

**1750 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

MARCY\_\_\_\_765\_345\_AT2

Tue 09/04/2018 to Sun 09/09/2018

0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

ROSETON\_-ROCKTVRN\_345\_311

Mon 09/10/2018 to Fri 09/28/2018

0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED

**4400 MW**

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 5100 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,October 24, 2017 to Thursday ,April 25, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_345KV\_CSC**

FWD

Tue 09/11/2018 to Tue 09/11/2018  
 0500 Continuous 1730

Work scheduled by: NYPA

CENTRAL EAST - VC **2925 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 2975 MW

**MARCY\_\_\_345KV\_CSC & MARCY\_SO\_SERIES\_COMP\_I/S**

FWD

Tue 09/11/2018 to Tue 09/11/2018  
 0500 1730

Work scheduled by:

(Import)  
 CENTRAL EAST - VC **2690 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 2975 MW

**MARCY\_\_\_765\_345\_AT2**

FWD

Tue 09/11/2018 to Tue 09/11/2018  
 0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

(Import)  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

**NIAGARA\_\_345\_230\_AT4**

FWD

REV

Fri 09/14/2018 to Fri 09/14/2018  
 0500 Continuous 1700

Work scheduled by: NYPA

(Import) (Export)  
 SCH - OH - NY **2000 MW 1400 MW**  
 Impacts Total Transfer Capability 0 MW 200 MW  
 TTC with All Lines In Service 2000 MW 1600 MW

**NIAGARA\_-ROCHESTR\_345\_NR2**

FWD

Mon 09/17/2018 to Fri 09/21/2018  
 0500 Continuous 1700

Work scheduled by: NYPA

(Import)  
 DYSINGER EAST **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MAI**

FWD

Mon 09/17/2018 to Fri 09/21/2018  
 0700 Continuous 1530

Work scheduled by: NYPA

(Import)  
 MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MAI**

FWD

Mon 09/24/2018 to Fri 09/28/2018  
 0700 Continuous 1530

Work scheduled by: NYPA

(Import)  
 MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,October 24, 2017 to Thursday ,April 25, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CLAY\_\_\_\_-EDIC\_\_\_\_345\_2-15

Mon 09/24/2018 to Fri 09/28/2018

0700 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

OSWEGO EXPORT

4850 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

## BECK\_\_\_\_-NIAGARA\_\_345\_PA302

Mon 10/01/2018 to Fri 10/05/2018

0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import) (Export)

SCH - OH - NY

900 MW 800 MW

Impacts Total Transfer Capability 1100 MW 800 MW

TTC with All Lines In Service 2000 MW 1600 MW

## PANNELL\_-CLAY\_\_\_\_345\_1

Mon 10/01/2018 to Fri 10/05/2018

0700 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

WEST CENTRAL

1300 MW

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

## MARCY\_\_\_\_765\_345\_AT2

Thu 10/04/2018 to Fri 10/05/2018

0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

MOSES SOUTH

1700 MW

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

## LEEDS\_\_\_\_-HURLYAVE\_345\_301

Mon 10/22/2018 to Fri 11/16/2018

0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED

4100 MW

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 5100 MW

## MARCY\_\_\_\_345KV\_CSC

Fri 11/16/2018 to Sat 11/17/2018

0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC

2925 MW

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

## MARCY\_\_\_\_765\_345\_AT2

Fri 11/16/2018 to Sat 11/17/2018

0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

MOSES SOUTH

1700 MW

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,October 24, 2017 to Thursday ,April 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY\_\_\_\_765\_345\_AT2

FWD

Mon 12/17/2018 to Fri 12/21/2018

( Import )

0500 Continuous 1730

MOSES SOUTH

**1700 MW**

Work scheduled by: NYPA

**ARR: 19**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW