

# NYISO TRANSFER LIMITATIONS

Sunday ,October 29, 2017 to Tuesday ,April 30, 2019

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 5100MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HUDSONTP-W49TH\_ST\_345\_Y56

Thu 11/24/2016 to Wed 11/15/2017  
 1500 Continuous 2359

EXT FORCE by PJM 10/20/2017

Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP 0 MW  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

## SCH-NYISO-HQ\_LIMIT\_800

Thu 06/08/2017 to Fri 12/15/2017  
 0600 Continuous 1700

UPDATED by HQ 08/03/2017

Work scheduled by: HQ

REV  
 (Export)  
 SCH - HQ - NY 800 MW  
 Impacts Total Transfer Capability 200 MW  
 TTC with All Lines In Service 1000 MW

## SCH-HQ-NYISO\_LIMIT\_1450

Tue 08/01/2017 to Fri 12/15/2017  
 2100 Continuous 1600

Work scheduled by: HQ

FWD  
 (Import)  
 SCH - HQ - NY 1450 MW  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 1500 MW

## SCH-IMO-NYISO\_LIMIT\_1450

Tue 08/29/2017 to Tue 10/31/2017  
 1230 Continuous 2359

EXTENDED by NYISO 07/28/2017

Work scheduled by: NYISO

FWD  
 (Import)  
 SCH - OH - NY 1750 MW  
 Impacts Total Transfer Capability 250 MW  
 TTC with All Lines In Service 2000 MW

## SPRNBRK\_-W49TH\_ST\_345\_M52

Sun 10/01/2017 to Sat 11/04/2017  
 0001 Continuous 2359

Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH 3200 MW  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

## CHAT\_DC\_GC2

Mon 10/02/2017 to Wed 11/15/2017  
 0500 Continuous 2000

Work scheduled by: HQ

FWD  
 (Import)  
 MOSES SOUTH 2850 MW  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC2

Mon 10/02/2017 to Wed 11/15/2017  
 0500 Continuous 2000

Work scheduled by: HQ

REV  
 (Export)  
 SCH - HQ - NY 500 MW  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 1000 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 29, 2017 to Tuesday ,April 30, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-HQ-NYISO\_LIMIT\_1150

Mon 10/02/2017 to Wed 11/15/2017  
0500 Continuous 2000  
Work scheduled by: HQ

FWD  
(Import)  
SCH - HQ - NY **1150 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 1500 MW

## SPRNBRK\_345KV\_RNS4

Mon 10/02/2017 to Sat 10/28/2017 **UPDATED** **by CONED** **10/03/2017**  
1901 Continuous 0300  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

## BERKSHIR-NORTHFLD\_345\_312

Fri 10/06/2017 to Sat 10/28/2017 **UPDATED** **by ISONE** **10/10/2017**  
0700 Continuous 1600  
Work scheduled by: ISONE

FWD REV  
(Import) (Export)  
SCH - NE - NY **900 MW 1200 MW**  
Impacts Total Transfer Capability 500 MW 400 MW  
TTC with All Lines In Service 1400 MW 1600 MW

## BERKSHIR-NORTHFLD\_345\_312

Fri 10/06/2017 to Sat 10/28/2017 **UPDATED** **by ISONE** **10/10/2017**  
0700 Continuous 1600  
Work scheduled by: ISONE

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **100 MW 100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

## SCH-NYISO-NE\_LIMIT\_600

Sun 10/08/2017 to Sat 10/28/2017 **UPDATED** **by ISONE** **10/10/2017**  
0001 Continuous 1600  
Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY **800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 1600 MW

## BERKSHIR-ALPS\_345\_393

Fri 10/13/2017 to Sat 10/28/2017 **UPDATED** **by ISONE** **10/13/2017**  
1516 Continuous 1600  
Work scheduled by: NGrid **ARR: 78**

FWD REV  
(Import) (Export)  
SCH - NE - NY **950 MW 1000 MW**  
Impacts Total Transfer Capability 450 MW 600 MW  
TTC with All Lines In Service 1400 MW 1600 MW

## BERKSHIR-ALPS\_345\_393

Fri 10/13/2017 to Sat 10/28/2017 **UPDATED** **by ISONE** **10/13/2017**  
1516 Continuous 1600  
Work scheduled by: NGrid **ARR: 78**

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **100 MW 100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 29, 2017 to Tuesday ,April 30, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## BERKSHIR-ALPS\_\_\_\_\_345\_393 & BERKSHIR-NORTHFLD\_345\_312

Fri 10/13/2017 to Sat 10/28/2017  
1516 1600

Work scheduled by:

ARR: 78

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD REV  
(Import) (Export)

950 MW 1000 MW

450 MW 600 MW

1400 MW 1600 MW

## SCH-HQ-NYISO\_LIMIT\_700

Sat 10/14/2017 to Fri 10/27/2017  
0100 Continuous 0917

Work scheduled by: HQ

UPDATED

by HQ

10/27/2017

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
(Import)

700 MW

800 MW

1500 MW

## CHAT\_DC\_GC1

Sat 10/14/2017 to Mon 10/30/2017  
0100 Continuous 2000

Work scheduled by: HQ

UPDATED

by HQ

10/27/2017

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
(Import)

2850 MW

300 MW

3150 MW

## CHAT\_DC\_GC1

Sat 10/14/2017 to Mon 10/30/2017  
0100 Continuous 2000

Work scheduled by: HQ

UPDATED

by HQ

10/27/2017

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

REV  
(Export)

500 MW

500 MW

1000 MW

## CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Sat 10/14/2017 to Mon 10/30/2017  
0100 2000

Work scheduled by:

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
(Import)

2550 MW

600 MW

3150 MW

## CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Sat 10/14/2017 to Mon 10/30/2017  
0100 2000

Work scheduled by:

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD REV  
(Import) (Export)

1370 MW 0 MW

130 MW 1000 MW

1500 MW 1000 MW

## HOMRC\_NY-MAINS\_NY\_345\_47

Sat 10/14/2017 to Mon 10/30/2017  
0700 Continuous 1730

Work scheduled by: NYSEG

EXTENDED

by NYSEG

10/27/2017

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD REV  
(Import) (Export)

2100 MW 1350 MW

0 MW 0 MW

2100 MW 1350 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 29, 2017 to Tuesday ,April 30, 2019

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HURLYAVE-ROSETON__345_303					FWD	
Mon 10/16/2017	to	Fri 11/03/2017	<u>UPDATED</u>	<u>by CH</u>	<u>06/07/2017</u>	(Import)
0800	Continuous	1600				
Work scheduled by: CHGE					UPNY CONED	<b>4100 MW</b>
					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	5100 MW
LEEDS__-HURLYAVE_345_301					FWD	
Mon 10/16/2017	to	Fri 11/03/2017				(Import)
0800	Continuous	1600				
Work scheduled by: CHGE					UPNY CONED	<b>4100 MW</b>
					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	5100 MW
COOPERS_-MIDDLETP_345_CCRT34					FWD	
Tue 10/17/2017	to	Fri 10/27/2017	<u>UPDATED</u>	<u>by NY</u>	<u>10/26/2017</u>	(Import)
0700	Continuous	1500				
Work scheduled by: NYSEG					CENTRAL EAST - VC	<b>2720 MW</b>
					Impacts Total Transfer Capability	255 MW
					TTC with All Lines In Service	2975 MW
SCH-NE-NYISO_LIMIT_700					FWD	
Fri 10/20/2017	to	Tue 10/24/2017	<u>RETURNED</u>	<u>by NE</u>	<u>10/25/2017</u>	(Import)
0700	Continuous	2250				
Work scheduled by: ISONE					SCH - NE - NY	<b>900 MW</b>
					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1400 MW
S.RIPLEY-DUNKIRK__230_68					FWD	REV
Mon 10/23/2017	to	Sat 10/28/2017	<u>EXTENDED</u>	<u>by PJM</u>	<u>10/28/2017</u>	(Import) (Export)
0800	Continuous	1500				
Work scheduled by: PJM					SCH - PJ - NY	<b>1950 MW 1350 MW</b>
					Impacts Total Transfer Capability	150 MW 0 MW
					TTC with All Lines In Service	2100 MW 1350 MW
BECK__-NIAGARA_345_PA301					FWD	REV
Tue 10/24/2017	to	Wed 10/25/2017				(Import) (Export)
0500	Continuous	1700				
Work scheduled by: NYPA					SCH - OH - NY	<b>900 MW 800 MW</b>
					Impacts Total Transfer Capability	1100 MW 800 MW
					TTC with All Lines In Service	2000 MW 1600 MW
NIAGARA_-KINTIGH__345_NS1-38					FWD	
Tue 10/24/2017	to	Wed 10/25/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/25/2017</u>	(Import)
0600	Continuous	1654				
Work scheduled by: NYPA					DYSINGER EAST	<b>1700 MW</b>
					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 29, 2017 to Tuesday ,April 30, 2019

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 5100MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CHASLAKE-PORTER\_\_230\_11**

Wed 10/25/2017 to Thu 10/26/2017  
 0730 Continuous 1900

Work scheduled by: NGrid

FWD  
 (Import)  
 MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

**SCH-HQ-NYISO\_LIMIT\_600**

Wed 10/25/2017 to Wed 10/25/2017  
 1000 Continuous 1600

Work scheduled by: HQ

FWD  
 (Import)  
 SCH - HQ - NY **600 MW**  
 Impacts Total Transfer Capability 900 MW  
 TTC with All Lines In Service 1500 MW

**FRASER\_\_-COOPERS\_\_345\_33**

Thu 10/26/2017 to Thu 10/26/2017  
 0800 Continuous 1700

Work scheduled by: NYSEG

**CANCELLED by NYSEG 10/25/2017**

FWD  
 (Import)  
 CENTRAL EAST - VC **2395 MW**  
 Impacts Total Transfer Capability 580 MW  
 TTC with All Lines In Service 2975 MW

**W49TH\_ST\_345KV\_5**

Fri 10/27/2017 to Sat 11/04/2017  
 0001 Continuous 2359

Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **315 MW**  
 Impacts Total Transfer Capability 345 MW  
 TTC with All Lines In Service 660 MW

**VOLNEY\_\_-CLAY\_\_\_\_345\_6**

Fri 10/27/2017 to Fri 10/27/2017  
 0800 Daily(No Weekends) 1800

Work scheduled by: NGrid

FWD  
 (Import)  
 OSWEGO EXPORT **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

**SCH-NYISO-HQ\_CEDARS\_LIMIT\_40**

Fri 10/27/2017 to Mon 10/30/2017  
 1600 Continuous 0559

Work scheduled by: HQ

**UPDATED by HQ 10/27/2017**

REV  
 (Export)  
 SCH - HQ\_CEDARS **40 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 40 MW

**SPRNBRK\_\_345KV\_RNS4**

Sat 10/28/2017 to Sat 11/04/2017  
 0301 Continuous 2359

Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 29, 2017 to Tuesday ,April 30, 2019

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### FRASER\_\_-COOPERS\_\_345\_33

Sat 10/28/2017 to Sat 10/28/2017  
0800 Continuous 1700

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2395 MW**  
Impacts Total Transfer Capability 580 MW  
TTC with All Lines In Service 2975 MW

### S.RIPLEY-DUNKIRK\_\_230\_68

Sat 10/28/2017 to Mon 03/19/2018  
1501 Continuous 0959

Work scheduled by: NYISO

UPDATED by NYISO 10/09/2017

FWD REV  
(Import) (Export)  
SCH - PJ - NY **1950 MW 1350 MW**  
Impacts Total Transfer Capability 150 MW 0 MW  
TTC with All Lines In Service 2100 MW 1350 MW

### MARCY\_SO\_SERIES\_COMP\_I/S

Sat 10/28/2017 to Fri 11/03/2017  
1700 Continuous 1600

Work scheduled by: NYISO

FWD  
(Import)  
CENTRAL EAST - VC **2740 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 2975 MW

### SCH-HQ-NYISO\_LIMIT\_800

Sun 10/29/2017 to Mon 10/30/2017  
1230 Continuous 1200

Work scheduled by: HQ

UPDATED by HQ 10/27/2017

FWD  
(Import)  
SCH - HQ - NY **800 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1500 MW

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_0

Mon 10/30/2017 to Mon 10/30/2017  
0600 Continuous 1230

Work scheduled by: HQ

UPDATED by HQ 10/27/2017

FWD  
(Import)  
SCH - HQ\_CEDARS **0 MW**  
Impacts Total Transfer Capability 190 MW  
TTC with All Lines In Service 190 MW

### CEDARS\_\_-ROSEMNTA\_115\_1/11

Mon 10/30/2017 to Thu 11/09/2017  
0600 Continuous 1600

Work scheduled by: HQ

UPDATED by HQ 10/27/2017

ARR: 38

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **95 MW 40 MW**  
Impacts Total Transfer Capability 95 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_100

Mon 10/30/2017 to Thu 11/09/2017  
0600 Continuous 1600

Work scheduled by: HQ

UPDATED by HQ 10/27/2017

FWD  
(Import)  
SCH - HQ\_CEDARS **100 MW**  
Impacts Total Transfer Capability 90 MW  
TTC with All Lines In Service 190 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 29, 2017 to Tuesday ,April 30, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MA1

FWD

Mon 10/30/2017 to Sat 11/04/2017 **CANCELLED by NYPA 10/24/2017**

(Import)

0700 Continuous 1530

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

FWD

Mon 10/30/2017 to Sat 11/04/2017

(Import)

0700 Continuous 1530

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## SCH-NYISO-HQ\_CEDARS\_LIMIT\_40

REV

Mon 10/30/2017 to Tue 10/31/2017 **UPDATED by HQ 10/27/2017**

(Export)

1300 Continuous 2359

SCH - HQ\_CEDARS

**40 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 40 MW

Work scheduled by: HQ

## NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

FWD

Tue 10/31/2017 to Thu 11/02/2017

(Import)

0001 Continuous 2359

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

## NEWBRDGE-DUFFYAVE\_345\_501

FWD

Tue 10/31/2017 to Thu 11/02/2017

(Import)

0001 Continuous 2359

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

## NEWBRDGE\_345\_138\_BK\_1

FWD

Tue 10/31/2017 to Thu 11/02/2017

(Import)

0001 Continuous 2359

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

## NEWBRDGE\_345\_138\_BK\_2

FWD

Tue 10/31/2017 to Thu 11/02/2017

(Import)

0001 Continuous 2359

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

# NYISO TRANSFER LIMITATIONS

Sunday ,October 29, 2017 to Tuesday ,April 30, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## DENNISON-ROSEMNTA\_115\_1/11

Tue 10/31/2017 to Fri 11/03/2017  
0800 Continuous 1530

Work scheduled by: NGrid

ARR: 38

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	95 MW	100 MW
Impacts Total Transfer Capability	104 MW	0 MW
TTC with All Lines In Service	199 MW	100 MW

## PLSNTVLY-EFISHKIL\_345\_F36

Wed 11/01/2017 to Sat 11/04/2017  
0001 Continuous 0300

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	4000 MW
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

## SCH-NYISO-IMO\_LIMIT\_1400

Wed 11/01/2017 to Mon 04/30/2018  
0001 Continuous 2359

Work scheduled by: IESO

	REV
	(Export)
SCH - OH - NY	1700 MW
Impacts Total Transfer Capability	200 MW
TTC with All Lines In Service	1900 MW

## LAFAYTTE-CLRKSCRN\_345\_4-46

Wed 11/01/2017 to Thu 11/02/2017  
0630 Continuous 1630

Work scheduled by: NGrid

	FWD
	(Import)
CENTRAL EAST - VC	2650 MW
Impacts Total Transfer Capability	325 MW
TTC with All Lines In Service	2975 MW

## COOPERS\_-DOLSONAV\_345\_CCDA42

Wed 11/01/2017 to Sat 11/04/2017  
0830 Continuous 1800

Work scheduled by: NYSEG

	FWD
	(Import)
CENTRAL EAST - VC	2720 MW
Impacts Total Transfer Capability	255 MW
TTC with All Lines In Service	2975 MW

## MARION\_-FARRAGUT\_345\_C3403

Thu 11/02/2017 to Sat 12/02/2017 UPDATED by CE 09/29/2017  
0001 Continuous 0100

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2300 MW	1450 MW
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2300 MW	1450 MW

## BERKSHIR-ALPS\_345\_393 &amp; BERKSHIR-NORTHFLD\_345\_312

Thu 11/02/2017 to Thu 11/02/2017  
0700 0900

Work scheduled by:

ARR: 78

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	1300 MW	1300 MW
Impacts Total Transfer Capability	100 MW	300 MW
TTC with All Lines In Service	1400 MW	1600 MW



# NYISO TRANSFER LIMITATIONS

Sunday ,October 29, 2017 to Tuesday ,April 30, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>BERKSHIR-NORTHFLD_345_312</b>							
Thu 11/02/2017	to	Thu 11/02/2017	<u>UPDATED</u>	<u>by NE</u>	<u>10/17/2017</u>		
0700	Continuous	0900					
Work scheduled by: NGrid						SCH - NE - NY	<b>1400 MW</b>
						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	1400 MW
<b>BERKSHIR-NORTHFLD_345_312</b>							
Thu 11/02/2017	to	Thu 11/02/2017	<u>UPDATED</u>	<u>by NE</u>	<u>10/17/2017</u>		
0700	Continuous	0900					
Work scheduled by: NGrid						SCH - NPX_1385	<b>100 MW</b>
						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
<b>BERKSHIR-ALPS_____345_393</b>							
Thu 11/02/2017	to	Sat 11/04/2017	<u>UPDATED</u>	<u>by NE</u>	<u>10/17/2017</u>		
0700	Continuous	1900					
Work scheduled by: NGrid						SCH - NE - NY	<b>1300 MW</b>
						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	1400 MW
						ARR: 78	
<b>BERKSHIR-ALPS_____345_393</b>							
Thu 11/02/2017	to	Sat 11/04/2017	<u>UPDATED</u>	<u>by NE</u>	<u>10/17/2017</u>		
0700	Continuous	1900					
Work scheduled by: NGrid						SCH - NPX_1385	<b>100 MW</b>
						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
<b>SCH-NE-NYISO_LIMIT_500</b>							
Thu 11/02/2017	to	Sat 11/04/2017	<u>UPDATED</u>	<u>by NE</u>	<u>10/17/2017</u>		
0700	Continuous	1900					
Work scheduled by: NGrid						SCH - NE - NY	<b>700 MW</b>
						Impacts Total Transfer Capability	700 MW
						TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_700</b>							
Thu 11/02/2017	to	Sat 11/04/2017	<u>UPDATED</u>	<u>by NE</u>	<u>10/17/2017</u>		
0700	Continuous	1900					
Work scheduled by: NGrid						SCH - NE - NY	<b>900 MW</b>
						Impacts Total Transfer Capability	700 MW
						TTC with All Lines In Service	1600 MW
<b>BERKSHIR-ALPS_____345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>							
Sat 11/04/2017	to	Sat 11/04/2017					
1800		1900					
Work scheduled by:						SCH - NE - NY	<b>1300 MW</b>
						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	1400 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 29, 2017 to Tuesday ,April 30, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>BERKSHIR-NORTHFLD_345_312</b>							
Sat 11/04/2017	to	Sat 11/04/2017	<u>UPDATED</u>	<u>by NE</u>	<u>10/17/2017</u>		
1800	Continuous	1900				<b>1400 MW</b>	<b>1450 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	0 MW 150 MW
						TTC with All Lines In Service	1400 MW 1600 MW
<b>BERKSHIR-NORTHFLD_345_312</b>							
Sat 11/04/2017	to	Sat 11/04/2017	<u>UPDATED</u>	<u>by NE</u>	<u>10/17/2017</u>		
1800	Continuous	1900				<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW 100 MW
						TTC with All Lines In Service	200 MW 200 MW
<b>PLSNTVLY-EFISHKIL_345_F36</b>						FWD	
						(Import)	
Mon 11/06/2017	to	Wed 11/08/2017				UPNY CONED	<b>4000 MW</b>
0001	Continuous	0300				Impacts Total Transfer Capability	1100 MW
Work scheduled by: ConEd						TTC with All Lines In Service	5100 MW
<b>MOSES__-ADIRNDCK_230_MA1</b>						FWD	
						(Import)	
Mon 11/06/2017	to	Thu 11/09/2017				MOSES SOUTH	<b>2300 MW</b>
0700	Continuous	1530				Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW
<b>FRASANNX-COOPERS__345_UCC2-41</b>						FWD	
						(Import)	
Mon 11/06/2017	to	Fri 11/17/2017				CENTRAL EAST - VC	<b>2500 MW</b>
0700	Continuous	1530				Impacts Total Transfer Capability	475 MW
Work scheduled by: NYPA						TTC with All Lines In Service	2975 MW
<b>MARCY__-FRASANNX_345_UCC2-41</b>						FWD	
						(Import)	
Mon 11/06/2017	to	Fri 11/17/2017				CENTRAL EAST - VC	<b>2500 MW</b>
0700	Continuous	1530				Impacts Total Transfer Capability	475 MW
Work scheduled by: NYPA						TTC with All Lines In Service	2975 MW
<b>LINDN_CG-LNDVFT__345_V-3022</b>						FWD	REV
						(Import)	(Export)
Mon 11/06/2017	to	Thu 11/09/2017				SCH - PJM_VFT	<b>0 MW 0 MW</b>
0800	Continuous	1500				Impacts Total Transfer Capability	315 MW 315 MW
Work scheduled by: PJM						TTC with All Lines In Service	315 MW 315 MW

ARR: 19

# NYISO TRANSFER LIMITATIONS

Sunday ,October 29, 2017 to Tuesday ,April 30, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**SCRIBA\_\_ -VOLNEY\_\_ 345\_20**

FWD

Mon 11/06/2017 to Fri 11/17/2017

(Import)

0800 Continuous 1630

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

Work scheduled by: NGrid

TTC with All Lines In Service 5250 MW

---

**ROCHESTR-PANNELL\_\_ 345\_RP1**

FWD

Mon 11/06/2017 to Tue 11/07/2017

(Import)

0900 Continuous 1500

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 850 MW

Work scheduled by: RGE

TTC with All Lines In Service 3150 MW

---

**W49TH\_ST\_345KV\_5**

FWD

Fri 11/10/2017 to Fri 11/10/2017

(Import)

0001 Continuous 0030

UPDATEDby CONED 10/03/2017

SCH - PJM\_HTP

**315 MW**

Impacts Total Transfer Capability 345 MW

Work scheduled by: ConEd

TTC with All Lines In Service 660 MW

---

**SPRNBK\_-W49TH\_ST\_345\_M52**

FWD

Fri 11/10/2017 to Mon 11/13/2017

(Import)

0001 Continuous 0300

UPDATEDby CONED 10/03/2017

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

Work scheduled by: ConEd

TTC with All Lines In Service 4600 MW

---

**SPRNBK\_\_345KV\_RNS4**

FWD

Fri 11/10/2017 to Mon 11/13/2017

(Import)

0001 Continuous 0300

UPDATEDby CONED 10/03/2017

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

Work scheduled by: ConEd

TTC with All Lines In Service 4600 MW

---

**SPRNBK\_\_345KV\_RS3 & SPRNBK\_\_345KV\_RS4**

FWD

Sun 11/12/2017 to Wed 11/15/2017

(Import)

0001 0300

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

Work scheduled by:

TTC with All Lines In Service 4600 MW

---

**E13THSTA-FARRAGUT\_345\_46**

FWD

Sun 11/12/2017 to Sun 11/12/2017

(Import)

0230 Continuous 0300

UPDATEDby CE10/20/2017

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

Work scheduled by: ConEd

TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 29, 2017 to Tuesday ,April 30, 2019

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_5

FWD

Mon 11/13/2017 to Mon 11/13/2017 UPDATED by CONED 10/03/2017  
0230 Continuous 0300

Work scheduled by: ConEd

SCH - PJM\_HTP **315 MW**  
Impacts Total Transfer Capability 345 MW  
TTC with All Lines In Service 660 MW

### MOSES\_\_-ADIRNDCK\_230\_MAI

FWD

Mon 11/13/2017 to Sat 11/18/2017 EXTENDED by PA 10/26/2017  
0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### PORTER\_\_-ROTTRDAM\_230\_30

FWD

Mon 11/13/2017 to Wed 11/15/2017  
0800 Daily(No Weekends) 1830

Work scheduled by: NGrid

CENTRAL EAST - VC **2805 MW**  
Impacts Total Transfer Capability 170 MW  
TTC with All Lines In Service 2975 MW

### SPRNBRK\_\_345KV\_RNS4

FWD

Wed 11/15/2017 to Fri 11/17/2017 UPDATED by CONED 10/03/2017  
0001 Continuous 0100

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

### W49TH\_ST-E13THSTA\_345\_M55

FWD

Fri 11/17/2017 to Fri 11/17/2017 UPDATED by NYISO 10/20/2017  
0101 Continuous 0301

Work scheduled by: NYPA

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### W49TH\_ST\_345KV\_6

FWD

Fri 11/17/2017 to Fri 11/17/2017 UPDATED by NYISO 10/20/2017  
0101 Continuous 0301

Work scheduled by: NYPA

SCH - PJM\_HTP **310 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 660 MW

### E13THSTA-FARRAGUT\_345\_45

FWD

Sat 11/18/2017 to Tue 05/15/2018  
0000 Continuous 2359

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 29, 2017 to Tuesday ,April 30, 2019

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST-E13THSTA\_345\_M54

Sat 11/18/2017 to Tue 05/15/2018

0000 Continuous 2359

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

### EGRDNCTY\_345\_138\_AT1

Sun 11/19/2017 to Sun 12/24/2017

0001 Continuous 0300

Work scheduled by: LI

UPDATED

by LI

08/01/2017

FWD

(Import)

CONED - LIPA **1250 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

### EGRDNCTY\_345\_138\_AT2

Sun 11/19/2017 to Sun 12/24/2017

0001 Continuous 0300

Work scheduled by: LI

UPDATED

by LI

08/01/2017

FWD

(Import)

CONED - LIPA **1250 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

### SPRNBK\_-EGRDNCTR\_345\_Y49

Sun 11/19/2017 to Sun 12/24/2017

0001 Continuous 0300

Work scheduled by: LI

UPDATED

by LI

08/01/2017

FWD

(Import)

CONED - LIPA **775 MW**

Impacts Total Transfer Capability 725 MW

TTC with All Lines In Service 1500 MW

### CEDARS\_-ROSEMNTB\_115\_2/22

Mon 11/20/2017 to Thu 12/07/2017

0515 Continuous 1600

Work scheduled by: HQ

UPDATED

by HQ

10/25/2017

ARR: 38

FWD

(Import) (Export)

SCH - HQ\_CEDARS **95 MW** **100 MW**

Impacts Total Transfer Capability 104 MW 0 MW

TTC with All Lines In Service 199 MW 100 MW

### DENNISON-ROSEMNTB\_115\_2/22

Mon 11/20/2017 to Thu 12/07/2017

0515 Continuous 1600

Work scheduled by: HQ

UPDATED

by HQ

10/25/2017

ARR: 38

FWD

(Import) (Export)

SCH - HQ\_CEDARS **95 MW** **100 MW**

Impacts Total Transfer Capability 104 MW 0 MW

TTC with All Lines In Service 199 MW 100 MW

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_100

Mon 11/20/2017 to Thu 12/07/2017

0515 Continuous 1600

Work scheduled by: HQ

UPDATED

by HQ

10/25/2017

FWD

(Import)

SCH - HQ\_CEDARS **100 MW**

Impacts Total Transfer Capability 99 MW

TTC with All Lines In Service 199 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 29, 2017 to Tuesday ,April 30, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MA1

FWD

Mon 11/20/2017 to Wed 11/22/2017 UPDATED by NYPA 10/13/2017  
0700 Continuous 1730

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## WETHSRFD-MEYER\_\_\_230\_85/87

FWD

Mon 11/20/2017 to Fri 12/01/2017 UPDATED by NYSEG 09/13/2017  
1630 Continuous 1400

(Import)

Work scheduled by: NYSEG

DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

## N.SCTLND-LEEDS\_\_\_345\_93

FWD

Tue 11/21/2017 to Wed 11/22/2017 UPDATED by NGRID 10/09/2017  
0800 Continuous 1500

(Import)

Work scheduled by: NGrid

CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

## NINEMILE-CLAY\_\_\_345\_8

FWD

Tue 11/21/2017 to Tue 11/21/2017  
0900 Daily(No Weekends) 1500

(Import)

Work scheduled by: NGrid

OSWEGO EXPORT **5150 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 5250 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA1

FWD

Mon 11/27/2017 to Fri 12/01/2017  
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## ROSETON\_-EFISHKIL\_345\_RFK305

FWD

Mon 11/27/2017 to Fri 12/01/2017  
0800 Continuous 1600

(Import)

Work scheduled by: CHGE

UPNY CONED **4800 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 5100 MW

## ROTTDAM-EASTOVER\_230\_38

FWD

REV

Mon 11/27/2017 to Thu 11/30/2017  
0900 Continuous 1500

(Import) (Export)

Work scheduled by: NGrid

SCH - NE - NY **1400 MW 1400 MW**  
Impacts Total Transfer Capability 0 MW 200 MW  
TTC with All Lines In Service 1400 MW 1600 MW

ARR: 77

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## ROSETON\_-EFISHKIL\_345\_RFK305

FWD

Sat 12/02/2017 to Sat 12/02/2017

(Import)

0001 Continuous 2359

UPNY CONED

**4800 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

## PLSNTVLY\_345KV\_RN5 &amp; PLSNTVLY\_345KV\_RN4

FWD

Sun 12/03/2017 to Tue 12/05/2017

(Import)

0001 0300

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by:

## LEEDS\_\_\_-PLSNTVLY\_345\_92

FWD

Mon 12/04/2017 to Mon 12/18/2017

(Import)

0001 Continuous 0300

UPDATEDby NYISO 09/12/2017

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

## PLSNTVLY\_345KV\_RNS5

FWD

Mon 12/04/2017 to Mon 12/18/2017

(Import)

0001 Continuous 0300

UPDATEDby NYISO 09/12/2017

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

## MARCY\_\_\_765\_345\_AT2

FWD

Mon 12/04/2017 to Fri 12/08/2017

(Import)

0500 Continuous 1630

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19**

## NRTH1385-NRTHPORT\_138\_NNC

FWD

REV

Mon 12/04/2017 to Wed 12/13/2017

(Import) (Export)

0700 Continuous 2359

SCH - NPX\_1385

**0 MW****0 MW**

Impacts Total Transfer Capability 200 MW 200 MW

TTC with All Lines In Service 200 MW 200 MW

Work scheduled by: LI

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

FWD

Mon 12/11/2017 to Fri 12/15/2017

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Sunday ,October 29, 2017 to Tuesday ,April 30, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_-KINTIGH\_345\_NS1-38

Mon 12/11/2017 to Wed 12/20/2017  
0800 Continuous 1600

UPDATED by NYISO 10/20/2017

Work scheduled by: NYSEG

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## MOSES\_-ADIRNDCK\_230\_MA2

Mon 12/18/2017 to Fri 12/22/2017  
0700 Continuous 1530

UPDATED by NYPA 10/23/2016

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## N.SCTLND-LEEDS\_345\_94

Tue 12/19/2017 to Wed 12/20/2017  
0800 Continuous 1500

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

## HOPATCON-RAMAPO\_500\_5018

Tue 12/26/2017 to Thu 12/28/2017  
0200 Continuous 1700

UPDATED by CE 10/27/2017

Work scheduled by: PJM

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2100 MW 1000 MW**  
Impacts Total Transfer Capability 200 MW 450 MW  
TTC with All Lines In Service 2300 MW 1450 MW

## HOPATCON-RAMAPO\_500\_5018

Tue 12/26/2017 to Thu 12/28/2017  
0200 Continuous 1700

UPDATED by CE 10/27/2017

Work scheduled by: PJM

FWD  
(Import)  
UPNY CONED **5000 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 5100 MW

## HOPATCON-RAMAPO\_500\_5018 & S.RIPLEY-DUNKIRK\_230\_68

Tue 12/26/2017 to Thu 12/28/2017  
0200 1700

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - PJ - NY **1200 MW 1300 MW**  
Impacts Total Transfer Capability 1100 MW 150 MW  
TTC with All Lines In Service 2300 MW 1450 MW

## RAMAPO\_345\_345\_PAR3500

Tue 12/26/2017 to Thu 12/28/2017  
0200 Continuous 1700

UPDATED by CE 10/27/2017

Work scheduled by: PJM

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2200 MW 1450 MW**  
Impacts Total Transfer Capability 100 MW 0 MW  
TTC with All Lines In Service 2300 MW 1450 MW



# NYISO TRANSFER LIMITATIONS

Sunday ,October 29, 2017 to Tuesday ,April 30, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>RAMAPO___345_345_PAR4500</b>						FWD	REV
Tue 12/26/2017	to	Thu 12/28/2017	<u>UPDATED</u>	<u>by CE</u>	<u>10/27/2017</u>	(Import)	(Export)
0200	Continuous	1700				<b>2200 MW</b>	<b>1450 MW</b>
Work scheduled by: PJM						Impacts Total Transfer Capability	100 MW 0 MW
						TTC with All Lines In Service	2300 MW 1450 MW
<b>RAMAPO___500_345_BK 1500</b>						FWD	REV
Tue 12/26/2017	to	Thu 12/28/2017	<u>UPDATED</u>	<u>by CE</u>	<u>10/27/2017</u>	(Import)	(Export)
0200	Continuous	1700				<b>2100 MW</b>	<b>1000 MW</b>
Work scheduled by: PJM						Impacts Total Transfer Capability	200 MW 450 MW
						TTC with All Lines In Service	2300 MW 1450 MW
<b>RAMAPO___500_345_BK 1500</b>						FWD	
Tue 12/26/2017	to	Thu 12/28/2017	<u>UPDATED</u>	<u>by CE</u>	<u>10/27/2017</u>	(Import)	
0200	Continuous	1700				<b>5000 MW</b>	
Work scheduled by: PJM						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	5100 MW
<b>S.RIPLEY-DUNKIRK___230_68 &amp; RAMAPO___345_345_PAR3500</b>						FWD	REV
Tue 12/26/2017	to	Thu 12/28/2017				(Import)	(Export)
0200		1700				<b>1450 MW</b>	<b>1250 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	850 MW 200 MW
						TTC with All Lines In Service	2300 MW 1450 MW
<b>S.RIPLEY-DUNKIRK___230_68 &amp; RAMAPO___345_345_PAR4500</b>						FWD	REV
Tue 12/26/2017	to	Thu 12/28/2017				(Import)	(Export)
0200		1700				<b>1450 MW</b>	<b>1250 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	850 MW 200 MW
						TTC with All Lines In Service	2300 MW 1450 MW
<b>MARCY___765_345_AT2</b>						FWD	
Wed 12/27/2017	to	Thu 12/28/2017				(Import)	
0500	Continuous	1630				<b>1700 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1450 MW
						TTC with All Lines In Service	3150 MW
<b>DUNWODIE-SHORE_RD_345_Y50</b>						FWD	
Tue 01/02/2018	to	Thu 01/04/2018	<u>EXTENDED</u>	<u>by LI</u>	<u>09/22/2017</u>	(Import)	
0001	Continuous	2359				<b>800 MW</b>	
Work scheduled by: ConEd						Impacts Total Transfer Capability	700 MW
						TTC with All Lines In Service	1500 MW

ARR: 19

**NYISO TRANSFER LIMITATIONS**

Sunday ,October 29, 2017 to Tuesday ,April 30, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_4**

FWD

Tue 01/02/2018 to Thu 01/04/2018 **EXTENDED** **by LI** **09/22/2017**

(Import)

0001 Continuous 2359

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**DUNWODIE\_345KV\_6**

FWD

Tue 01/02/2018 to Thu 01/04/2018 **EXTENDED** **by LI** **09/22/2017**

(Import)

0001 Continuous 2359

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**SHORE\_RD\_345\_138\_BK 1**

FWD

Tue 01/02/2018 to Thu 01/04/2018 **EXTENDED** **by LI** **09/22/2017**

(Import)

0001 Continuous 2359

CONED - LIPA **1350 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: ConEd

**SHORE\_RD\_345\_138\_BK 2**

FWD

Tue 01/02/2018 to Thu 01/04/2018 **EXTENDED** **by LI** **09/22/2017**

(Import)

0001 Continuous 2359

CONED - LIPA **1350 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: ConEd

**MOSES\_\_-ADIRNDCK\_230\_MA1**

FWD

Tue 01/02/2018 to Fri 01/05/2018

(Import)

0700 Continuous 1730

MOSES SOUTH **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**LEEDS\_\_-PLSNTVLY\_345\_92**

FWD

Wed 01/03/2018 to Sat 01/06/2018 **UPDATED** **by NYISO** **09/12/2017**

(Import)

0001 Continuous 0300

UPNY CONED **3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**PLSNTVLY\_345KV\_RNS5**

FWD

Wed 01/03/2018 to Sat 01/06/2018 **UPDATED** **by NYISO** **09/12/2017**

(Import)

0001 Continuous 0300

UPNY CONED **3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Sunday ,October 29, 2017 to Tuesday ,April 30, 2019

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

FWD

Fri 01/05/2018 to Sun 01/07/2018  
0001 2359

(Import)

Work scheduled by:

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

### PLSNTVLY\_345KV\_RNS5

FWD

Mon 01/08/2018 to Wed 01/10/2018 UPDATED by NYISO 09/12/2017  
0001 Continuous 0300

(Import)

Work scheduled by: ConEd

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

### EASTVIEW-SPRNBK\_345\_W64

FWD

Mon 01/08/2018 to Fri 02/23/2018  
0001 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

### MILLWOOD-EASTVIEW\_345\_W99

FWD

Mon 01/08/2018 to Fri 02/23/2018  
0001 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

### SPRNBK\_345KV\_RNS5

FWD

Mon 01/08/2018 to Fri 02/23/2018  
0001 Continuous 0200

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

### MOSES\_-ADIRNDCK\_230\_MA1

FWD

Mon 01/08/2018 to Fri 01/12/2018  
0700 Continuous 1730

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### FRASER\_-COOPERS\_345\_33

FWD

Mon 01/08/2018 to Thu 01/11/2018  
0800 Continuous 1500

(Import)

Work scheduled by: NYSEG

CENTRAL EAST - VC **2395 MW**  
Impacts Total Transfer Capability 580 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 29, 2017 to Tuesday ,April 30, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N.SCTLND-ALPS_____345_2						FWD	REV
						(Import)	(Export)
Mon 01/08/2018	to	Fri 02/02/2018	<u>UPDATED</u>	<u>by NG</u>	<u>10/17/2017</u>	SCH - NE - NY	<b>900 MW</b>
0800	Continuous	1400				Impacts Total Transfer Capability	500 MW
Work scheduled by: NGrid						TTC with All Lines In Service	1400 MW
							1600 MW
N.SCTLND-ALPS_____345_2						FWD	REV
						(Import)	(Export)
Mon 01/08/2018	to	Fri 02/02/2018	<u>UPDATED</u>	<u>by NG</u>	<u>10/17/2017</u>	SCH - NPX_1385	<b>100 MW</b>
0800	Continuous	1400				Impacts Total Transfer Capability	100 MW
Work scheduled by: NGrid						TTC with All Lines In Service	200 MW
							200 MW
MOSES____-ADIRNDCK_230_MA1						FWD	
						(Import)	
Mon 01/15/2018	to	Fri 01/19/2018				MOSES SOUTH	<b>2300 MW</b>
0700	Continuous	1530				Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW
MARCY_____765_345_AT2						FWD	
						(Import)	
Sat 01/20/2018	to	Sat 01/20/2018				MOSES SOUTH	<b>1700 MW</b>
0500	Continuous	1730				Impacts Total Transfer Capability	1450 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW
MOSES____-ADIRNDCK_230_MA1						FWD	
						(Import)	
Mon 01/22/2018	to	Fri 01/26/2018				MOSES SOUTH	<b>2300 MW</b>
0700	Continuous	1530				Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW
MOSES____-ADIRNDCK_230_MA1						FWD	
						(Import)	
Mon 01/29/2018	to	Fri 02/02/2018				MOSES SOUTH	<b>2300 MW</b>
0700	Continuous	1530				Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW
MARCY_____765_345_AT2						FWD	
						(Import)	
Sat 02/03/2018	to	Sat 02/03/2018				MOSES SOUTH	<b>1700 MW</b>
0500	Continuous	1730				Impacts Total Transfer Capability	1450 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 29, 2017 to Tuesday ,April 30, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MARCY\_\_\_\_765\_345\_AT2

Mon 02/05/2018 to Fri 02/09/2018  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH 1700 MW  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 02/12/2018 to Fri 02/16/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2300 MW  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## HUDSONP\_-FARRAGUT\_345\_B3402

Sun 02/18/2018 to Sun 04/01/2018  
0001 Continuous 2359

Work scheduled by: PJM

FWD REV  
(Import) (Export)  
SCH - PJ - NY 2300 MW 1450 MW  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 2300 MW 1450 MW

## MARCY\_\_\_\_-EDIC\_\_\_\_345\_UE1-7

Tue 02/20/2018 to Fri 02/23/2018  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19&16

FWD  
(Import)  
OSWEGO EXPORT 5250 MW  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA1

Tue 02/20/2018 to Fri 02/23/2018  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2300 MW  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## DUNWODIE\_345KV\_7

Sat 02/24/2018 to Sat 02/24/2018  
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CE 09/22/2017

FWD  
(Import)  
SPR/DUN-SOUTH 3800 MW  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## DUNWODIE\_345KV\_8

Sat 02/24/2018 to Sat 02/24/2018  
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CE 09/22/2017

FWD  
(Import)  
SPR/DUN-SOUTH 3800 MW  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 29, 2017 to Tuesday ,April 30, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## DUNWODIE-MOTTHAVN\_345\_72

Sat 02/24/2018 to Sat 03/31/2018  
0001 Continuous 0300

Work scheduled by: ConEd

UPDATED by CE 09/22/2017

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD

(Import)

3800 MW

## LONG\_MTN-PLSNTVLY\_345\_398

Mon 02/26/2018 to Wed 05/02/2018  
0001 Continuous 0300

Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability 700 MW 300 MW  
TTC with All Lines In Service 1400 MW 1600 MW

FWD

(Import)

700 MW 1300 MW

700 MW 300 MW

1400 MW 1600 MW

## LONG\_MTN-PLSNTVLY\_345\_398

Mon 02/26/2018 to Wed 05/02/2018  
0001 Continuous 0300

Work scheduled by: ConEd

SCH - NPX\_1385  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

FWD

(Import)

100 MW 100 MW

100 MW 100 MW

200 MW 200 MW

## MOSES\_\_-ADIRNDCK\_230\_MAI

Mon 02/26/2018 to Fri 03/02/2018  
0700 Continuous 1730

Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

FWD

(Import)

2300 MW

850 MW

3150 MW

## MOSES\_\_-ADIRNDCK\_230\_MAI

Mon 03/05/2018 to Fri 03/09/2018  
0700 Continuous 1730

Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

FWD

(Import)

2300 MW

850 MW

3150 MW

## MARCY\_\_-N.SCTLND\_345\_18

Tue 03/06/2018 to Wed 03/07/2018  
0600 Continuous 1530

Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability 885 MW  
TTC with All Lines In Service 2975 MW

FWD

(Import)

2090 MW

885 MW

2975 MW

ARR: 19

## MOSES\_\_-ADIRNDCK\_230\_MAI

Mon 03/12/2018 to Fri 03/16/2018  
0700 Continuous 1730

Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

FWD

(Import)

2300 MW

850 MW

3150 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>S.RIPLEY-DUNKIRK__230_68</b>					FWD	REV
Mon 03/19/2018	to	Fri 04/20/2018			(Import)	(Export)
1000	Continuous	1559			SCH - PJ - NY	<b>1950 MW</b>
Work scheduled by: PJM					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1450 MW
<b>MOSES__-ADIRNDCK_230_MA2</b>					FWD	
Mon 03/26/2018	to	Thu 03/29/2018			(Import)	
0700	Continuous	1530			MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
<b>DUNWODIE_345KV_7</b>					FWD	
Sat 03/31/2018	to	Sat 03/31/2018	<b>UPDATED</b>	<b>by CE</b>	(Import)	
0230	Continuous	0300		<b>09/22/2017</b>	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_8</b>					FWD	
Sat 03/31/2018	to	Sat 03/31/2018	<b>UPDATED</b>	<b>by CE</b>	(Import)	
0230	Continuous	0300		<b>09/22/2017</b>	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>MOSES__-ADIRNDCK_230_MA1</b>					FWD	
Mon 04/02/2018	to	Fri 04/06/2018			(Import)	
0700	Continuous	1730			MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
<b>LINDN_CG-LNDVFT__345_V-3022</b>					FWD	REV
Sun 04/08/2018	to	Fri 04/13/2018			(Import)	(Export)
1400	Continuous	1800			SCH - PJM_VFT	<b>0 MW</b>
Work scheduled by: PJM					Impacts Total Transfer Capability	315 MW
					TTC with All Lines In Service	315 MW
<b>FRASER__-GILBOA__345_GF5-35</b>					FWD	
Mon 04/09/2018	to	Fri 04/20/2018			(Import)	
0700	Continuous	1730			CENTRAL EAST - VC	<b>2650 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	325 MW
					TTC with All Lines In Service	2975 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MALONE\_\_-WILLIS\_\_115\_1-910

Tue 04/10/2018 to Tue 04/10/2018  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 38

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

60 MW

40 MW

100 MW

## NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 04/16/2018 to Tue 05/01/2018  
0001 Continuous 1800

Work scheduled by: PJM

FWD

(Import)

SCH - PJM\_NEPTUNE

0 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

## NEWBRDGE-DUFFYAVE\_345\_501

Mon 04/16/2018 to Tue 05/01/2018  
0001 Continuous 1800

Work scheduled by: PJM

FWD

(Import)

SCH - PJM\_NEPTUNE

0 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

## NEWBRDGE\_345\_138\_BK\_1

Mon 04/16/2018 to Tue 05/01/2018  
0001 Continuous 1800

Work scheduled by: PJM

FWD

(Import)

SCH - PJM\_NEPTUNE

375 MW

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

## NEWBRDGE\_345\_138\_BK\_2

Mon 04/16/2018 to Tue 05/01/2018  
0001 Continuous 1800

Work scheduled by: PJM

FWD

(Import)

SCH - PJM\_NEPTUNE

375 MW

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

## MOSES\_-ADIRNDCK\_230\_MAI

Mon 04/16/2018 to Fri 04/20/2018  
0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## S.RIPLEY-DUNKIRK\_230\_68

Fri 04/20/2018 to Sat 02/01/2020  
1600 Continuous 0000

Work scheduled by: NYISO

UPDATED

by NYISO 10/09/2017

FWD

REV

(Import) (Export)

SCH - PJ - NY

1950 MW 1350 MW

Impacts Total Transfer Capability 350 MW 100 MW

TTC with All Lines In Service 2300 MW 1450 MW



# NYISO TRANSFER LIMITATIONS

Sunday ,October 29, 2017 to Tuesday ,April 30, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**MARCY\_\_\_765\_345\_AT1**

FWD

Mon 04/23/2018 to Mon 04/23/2018  
0500 Continuous 1730

(Import)

MOSES SOUTH **1750 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19**


---

**WETHSRFD-MEYER\_\_\_230\_85/87**

FWD

Mon 04/23/2018 to Fri 05/11/2018  
0700 Continuous 1500

(Import)

DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

Work scheduled by: NYSEG

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 04/30/2018 to Fri 05/04/2018  
0700 Continuous 1530

(Import)

MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

---

**HURLYAVE-ROSETON\_\_\_345\_303**

FWD

Mon 04/30/2018 to Fri 05/25/2018  
0800 Continuous 1600

(Import)

UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 5100 MW

Work scheduled by: CHGE

---

**MARCY\_SO\_SERIES\_COMP\_I/S**

FWD

Tue 05/01/2018 to Wed 10/31/2018  
0001 Continuous 2359

(Import)

CENTRAL EAST - VC **2740 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 2975 MW

Work scheduled by: NYISO

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 05/07/2018 to Fri 05/11/2018  
0700 Continuous 1530

(Import)

MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 05/14/2018 to Fri 05/18/2018  
0700 Continuous 1530

(Import)

MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY\_\_\_\_-EDIC\_\_\_\_345\_1-16

Mon 05/14/2018 to Fri 05/18/2018

0700 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

OSWEGO EXPORT

**4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

MARCY\_\_\_\_765\_345\_AT2

Mon 05/21/2018 to Fri 05/25/2018

0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

MOSES\_\_\_\_-ADIRNDCK\_230\_MAL

Mon 05/28/2018 to Fri 06/01/2018

0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

STLAWRNC-MOSES\_\_\_\_230\_L33P

Mon 05/28/2018 to Fri 06/01/2018

0700 Continuous 2000

Work scheduled by: NYPA

FWD

(Import) (Export)

SCH - OH - NY

**2000 MW 1600 MW**

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 2000 MW 1600 MW

MARCY\_\_\_\_765\_345\_AT1

Sat 08/04/2018 to Sun 08/05/2018

0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

MOSES SOUTH

**1750 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

MARCY\_\_\_\_765\_345\_AT2

Tue 09/04/2018 to Sun 09/09/2018

0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

ROSETON\_-ROCKTVRN\_345\_311

Mon 09/10/2018 to Fri 09/28/2018

0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED

**4400 MW**

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 5100 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MARCY\_\_\_\_345KV\_CSC

Tue 09/11/2018 to Tue 09/11/2018  
0500 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

## MARCY\_\_\_\_345KV\_CSC & MARCY\_SO\_SERIES\_COMP\_I/S

Tue 09/11/2018 to Tue 09/11/2018  
0500 1730

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **2690 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 2975 MW

## MARCY\_\_\_\_765\_345\_AT2

Tue 09/11/2018 to Tue 09/11/2018  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## NIAGARA\_\_345\_230\_AT4

Fri 09/14/2018 to Fri 09/14/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **2000 MW 1400 MW**  
Impacts Total Transfer Capability 0 MW 200 MW  
TTC with All Lines In Service 2000 MW 1600 MW

## NIAGARA\_-ROCHESTR\_345\_NR2

Mon 09/17/2018 to Fri 09/21/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MAI

Mon 09/17/2018 to Fri 09/21/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MAI

Mon 09/24/2018 to Fri 09/28/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CLAY\_\_\_\_-EDIC\_\_\_\_345\_2-15

Mon 09/24/2018 to Fri 09/28/2018  
0700 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT 4850 MW  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

## BECK\_\_\_\_-NIAGARA\_\_\_\_345\_PA302

Mon 10/01/2018 to Fri 10/05/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY 900 MW 800 MW  
Impacts Total Transfer Capability 1100 MW 800 MW  
TTC with All Lines In Service 2000 MW 1600 MW

## PANNELL\_\_\_\_-CLAY\_\_\_\_345\_1

Mon 10/01/2018 to Fri 10/05/2018  
0700 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL 1300 MW  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

## MARCY\_\_\_\_765\_345\_AT2

Thu 10/04/2018 to Fri 10/05/2018  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH 1700 MW  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MAL

Mon 10/08/2018 to Fri 10/12/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2100 MW  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## LEEDS\_\_\_\_-HURLYAVE\_345\_301

Mon 10/22/2018 to Fri 11/16/2018  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED 4100 MW  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 5100 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MAL

Mon 10/29/2018 to Fri 11/02/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2100 MW  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 29, 2017 to Tuesday ,April 30, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Mon 11/05/2018 to Fri 11/09/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

---

**MARCY\_\_\_345KV\_CSC**

FWD

Fri 11/16/2018 to Sat 11/17/2018

(Import)

0500 Continuous 1730

CENTRAL EAST - VC

**2925 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

---

**MARCY\_\_\_765\_345\_AT2**

FWD

Fri 11/16/2018 to Sat 11/17/2018

(Import)

0500 Continuous 1730

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19**


---

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Mon 11/19/2018 to Wed 11/21/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 11/26/2018 to Fri 11/30/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 12/03/2018 to Fri 12/07/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 12/10/2018 to Fri 12/14/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**NYISO TRANSFER LIMITATIONS**

Sunday ,October 29, 2017 to Tuesday ,April 30, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY\_\_\_\_765\_345\_AT2

FWD

Mon 12/17/2018 to Fri 12/21/2018

(Import)

0500 Continuous 1730

MOSES SOUTH

**1700 MW**

Work scheduled by: NYPA

**ARR: 19**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

MOSES\_\_\_\_-ADIRNDCK\_230\_MAL

FWD

Wed 12/26/2018 to Fri 12/28/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW