

**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 30, 2018 to Thursday ,August 01, 2019

**CENTRAL EAST** 3100MW  
**CENTRAL EAST - VC** 2975MW  
**TOTAL EAST** 6500MW  
**UPNY CONED** 5100MW  
**SPR/DUN-SOUTH** 4600MW  
**DYSINGER EAST** 3150MW  
**MOSES SOUTH** 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**E13THSTA-FARRAGUT\_345\_45**

Sun 11/26/2017 to Tue 05/15/2018  
 0001 Continuous 2359

**UPDATED****by CE****01/03/2018**

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**W49TH\_ST-E13THSTA\_345\_M54**

Sun 11/26/2017 to Tue 05/15/2018  
 0001 Continuous 2359

**UPDATED****by CE****01/03/2018**

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**S.RIPLEY-DUNKIRK\_230\_68**

Fri 12/15/2017 to Mon 04/30/2018  
 1400 Continuous 0959

**UPDATED****by NYISO****01/22/2018**

Work scheduled by: NYISO

FWD

(Import) (Export)

SCH - PJ - NY

**2600 MW 1300 MW**

Impacts Total Transfer Capability 150 MW 0 MW

TTC with All Lines In Service 2750 MW 1300 MW

**CHAT\_DC\_GC2**

Tue 12/19/2017 to Fri 02/02/2018  
 2257 Continuous 0900

**by HQ****01/26/2018**

Work scheduled by: HQ

FWD

(Import)

MOSES SOUTH

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC2**

Tue 12/19/2017 to Fri 02/02/2018  
 2257 Continuous 0900

**by HQ****01/26/2018**

Work scheduled by: HQ

FWD

(Export)

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

**HUDSONP\_-FARRAGUT\_345\_B3402**

Mon 01/15/2018 to Thu 02/15/2018  
 0001 Continuous 2359

**UPDATED****by CE****01/17/2018**

Work scheduled by: ConEd

FWD

(Import) (Export)

SCH - PJ - NY

**2600 MW 1300 MW**

Impacts Total Transfer Capability 150 MW 0 MW

TTC with All Lines In Service 2750 MW 1300 MW

**HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403**

Mon 01/15/2018 to Thu 02/15/2018  
 0001 2359

Work scheduled by:

FWD

(Import) (Export)

SCH - PJ - NY

**2000 MW 1300 MW**

Impacts Total Transfer Capability 750 MW 0 MW

TTC with All Lines In Service 2750 MW 1300 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 30, 2018 to Thursday ,August 01, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARION\_\_-FARRAGUT\_345\_C3403**

Mon 01/15/2018 to Thu 02/15/2018  
 0001 Continuous 2359

**UPDATED****by CE****01/17/2018**

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

REV

(Import) (Export)

**2600 MW 1300 MW**

150 MW 0 MW

2750 MW 1300 MW

**SCH-HQ-NYISO\_LIMIT\_1200**

Tue 01/16/2018 to Thu 02/08/2018  
 0001 Continuous 2359

**by HQ****01/26/2018**

Work scheduled by: HQ

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

**1200 MW**

300 MW

1500 MW

**EASTVIEW-SPRNBK\_\_345\_W64**

Tue 01/16/2018 to Mon 02/19/2018  
 0001 Continuous 0100

**UPDATED****by CE****01/25/2018**

Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

**4350 MW**

750 MW

5100 MW

**MILLWOOD-EASTVIEW\_345\_W99**

Tue 01/16/2018 to Mon 02/19/2018  
 0001 Continuous 0100

**UPDATED****by CE****01/25/2018**

Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

**4350 MW**

750 MW

5100 MW

**SPRNBK\_\_345KV\_RNS5**

Tue 01/16/2018 to Mon 02/19/2018  
 0001 Continuous 0100

**UPDATED****by CE****01/25/2018**

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

**3200 MW**

1400 MW

4600 MW

**N.SCTLND-ALPS\_\_\_\_345\_2**

Wed 01/17/2018 to Fri 02/16/2018  
 0800 Continuous 1400

**EXTENDED****by NGRID****01/30/2018**

Work scheduled by: NGrid

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

REV

(Import) (Export)

**900 MW 1600 MW**

500 MW 0 MW

1400 MW 1600 MW

**N.SCTLND-ALPS\_\_\_\_345\_2**

Wed 01/17/2018 to Fri 02/16/2018  
 0800 Continuous 1400

**EXTENDED****by NGRID****01/30/2018**

Work scheduled by: NGrid

SCH - NPX\_1385

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

REV

(Import) (Export)

**100 MW 100 MW**

100 MW 100 MW

200 MW 200 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 30, 2018 to Thursday ,August 01, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-NE-NYISO\_LIMIT\_400**

FWD

Wed 01/17/2018 to Fri 02/16/2018 **EXTENDED** **by NGRID** **01/30/2018**

(Import)

0800 Continuous 1400

SCH - NE - NY

**600 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: NGrid

**SCH-NYISO-NE\_LIMIT\_600**

REV

Wed 01/17/2018 to Fri 02/16/2018 **EXTENDED** **by NGRID** **01/30/2018**

(Export)

0800 Continuous 1400

SCH - NE - NY

**800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 1600 MW

Work scheduled by: NGrid

**MOSES\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 01/22/2018 to Fri 01/26/2018 **UPDATED** **by NYPA** **01/15/2018**

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**FRASER\_\_-COOPERS\_\_345\_33**

FWD

Mon 01/22/2018 to Thu 01/25/2018 **UPDATED** **by NYSEG** **01/22/2018**

(Import)

0800 Continuous 1500

CENTRAL EAST - VC

**2395 MW**

Impacts Total Transfer Capability 580 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

**SCH-IMO-NYISO\_LIMIT\_1250**

FWD

Tue 01/23/2018 to Thu 01/25/2018 **UPDATED** **by NGRID** **01/25/2018**

(Import)

0700 Continuous 1500

SCH - OH - NY

**1550 MW**

Impacts Total Transfer Capability 200 MW

TTC with All Lines In Service 1750 MW

Work scheduled by: NGrid

**SCH-NYISO-NE\_LIMIT\_1300**

REV

Wed 01/24/2018 to Fri 01/26/2018

(Export)

0600 Daily 1700

SCH - NE - NY

**1500 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 1600 MW

Work scheduled by: ISONE

**FIVEMILE-STOLLERD\_345\_29**

FWD

REV

Wed 01/24/2018 to Fri 01/26/2018 **UPDATED** **by NGRID** **01/25/2018**

(Import) (Export)

0826 Continuous 1500

SCH - PJ - NY

**2600 MW 1300 MW**

Impacts Total Transfer Capability 150 MW 0 MW

TTC with All Lines In Service 2750 MW 1300 MW

Work scheduled by: NGrid

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 30, 2018 to Thursday ,August 01, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOPATCON-RAMAPO___500_5018				FWD	REV
Fri 01/26/2018	to	Sun 01/28/2018		(Import)	(Export)
0001	Continuous	2000	SCH - PJ - NY	1250 MW	1200 MW
Work scheduled by: PJM				Impacts Total Transfer Capability	1500 MW
				TTC with All Lines In Service	2750 MW
HOPATCON-RAMAPO___500_5018				FWD	
Fri 01/26/2018	to	Sun 01/28/2018		(Import)	
0001	Continuous	2000	UPNY CONED	5000 MW	
Work scheduled by: PJM				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	5100 MW
HOPATCON-RAMAPO___500_5018 & S.RIPLEY-DUNKIRK___230_68				FWD	REV
Fri 01/26/2018	to	Sun 01/28/2018		(Import)	(Export)
0001		2000	SCH - PJ - NY	1250 MW	1200 MW
Work scheduled by:				Impacts Total Transfer Capability	1500 MW
				TTC with All Lines In Service	2750 MW
RAMAPO___345_345_PAR3500				FWD	REV
Fri 01/26/2018	to	Sun 01/28/2018		(Import)	(Export)
0001	Continuous	2000	SCH - PJ - NY	2150 MW	1250 MW
Work scheduled by: PJM				Impacts Total Transfer Capability	600 MW
				TTC with All Lines In Service	2750 MW
RAMAPO___345_345_PAR4500				FWD	REV
Fri 01/26/2018	to	Sun 01/28/2018		(Import)	(Export)
0001	Continuous	2000	SCH - PJ - NY	2150 MW	1250 MW
Work scheduled by: PJM				Impacts Total Transfer Capability	600 MW
				TTC with All Lines In Service	2750 MW
RAMAPO___500_345_BK 1500				FWD	REV
Fri 01/26/2018	to	Sun 01/28/2018		(Import)	(Export)
0001	Continuous	2000	SCH - PJ - NY	1250 MW	1200 MW
Work scheduled by: PJM				Impacts Total Transfer Capability	1500 MW
				TTC with All Lines In Service	2750 MW
RAMAPO___500_345_BK 1500				FWD	
Fri 01/26/2018	to	Sun 01/28/2018		(Import)	
0001	Continuous	2000	UPNY CONED	5000 MW	
Work scheduled by: PJM				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	5100 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 30, 2018 to Thursday ,August 01, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

S.RIPLEY-DUNKIRK\_\_230\_68 &amp; RAMAPO\_\_345\_345\_PAR3500

Fri 01/26/2018 to Sun 01/28/2018

0001 2000

Work scheduled by:

FWD REV  
 (Import) (Export)  
 SCH - PJ - NY **2150 MW 1250 MW**  
 Impacts Total Transfer Capability 600 MW 50 MW  
 TTC with All Lines In Service 2750 MW 1300 MW

S.RIPLEY-DUNKIRK\_\_230\_68 &amp; RAMAPO\_\_345\_345\_PAR4500

Fri 01/26/2018 to Sun 01/28/2018

0001 2000

Work scheduled by:

FWD REV  
 (Import) (Export)  
 SCH - PJ - NY **2150 MW 1250 MW**  
 Impacts Total Transfer Capability 600 MW 50 MW  
 TTC with All Lines In Service 2750 MW 1300 MW

FRASER\_\_-GILBOA\_\_345\_GF5-35

Mon 01/29/2018 to Mon 01/29/2018

0700 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

MOSES\_\_-ADIRNDCK\_230\_MA1

Mon 01/29/2018 to Fri 02/02/2018

0700 Continuous 1530

Work scheduled by: NYPA

**UPDATED by NYPA 01/29/2018**

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

SCH-NE-NYISO\_LIMIT\_1000

Mon 01/29/2018 to Sat 02/03/2018

0700 Continuous 1600

Work scheduled by: ISONE

**UPDATED by ISONE 01/25/2018**

FWD  
 (Import)  
 SCH - NE - NY **1200 MW**  
 Impacts Total Transfer Capability 200 MW  
 TTC with All Lines In Service 1400 MW

SCH-NYISO-NE\_LIMIT\_700

Mon 01/29/2018 to Sat 02/03/2018

0700 Continuous 1600

Work scheduled by: ISONE

**UPDATED by ISONE 01/25/2018**

REV  
 (Export)  
 SCH - NE - NY **900 MW**  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 1600 MW

HURLYAVE-ROSETON\_\_345\_303

Wed 01/31/2018 to Fri 02/02/2018

0700 Continuous 1600

Work scheduled by: CHGE

**UPDATED by CH 01/25/2018**

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 1000 MW  
 TTC with All Lines In Service 5100 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 30, 2018 to Thursday ,August 01, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NYISO-PJM\_LIMIT\_100

Wed 01/31/2018 to Fri 02/02/2018  
0900 Continuous 1400

UPDATED by PJM 01/29/2018

Work scheduled by: PJM

REV  
(Export)  
**400 MW**  
SCH - PJ - NY  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 1300 MW

## MARCY\_765\_345\_AT2

Sat 02/03/2018 to Sat 02/03/2018  
0500 Continuous 1730

UPDATED by NYPA 01/02/2018

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
**1700 MW**  
MOSES SOUTH  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## MOSES\_-ADIRNDCK\_230\_MA1

Mon 02/05/2018 to Fri 02/09/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
**2300 MW**  
MOSES SOUTH  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## SCH-NYISO-PJM\_LIMIT\_100

Mon 02/05/2018 to Fri 02/09/2018  
0900 Continuous 1400

UPDATED by NYISO 01/30/2018

Work scheduled by: PJM

REV  
(Export)  
**400 MW**  
SCH - PJ - NY  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 1300 MW

## SCH-IMO-NYISO\_LIMIT\_1100

Mon 02/12/2018 to Tue 02/13/2018  
0630 Continuous 1630

UPDATED by NGRID 01/26/2018

Work scheduled by: NGrid

FWD  
(Import)  
**1400 MW**  
SCH - OH - NY  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 1750 MW

## MOSES\_-ADIRNDCK\_230\_MA2

Mon 02/12/2018 to Fri 02/16/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
**2300 MW**  
MOSES SOUTH  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## HUDSONP\_-FARRAGUT\_345\_B3402

Sun 02/18/2018 to Sun 04/01/2018  
0001 Continuous 2359

UPDATED by PJM 12/13/2017

Work scheduled by: PJM

FWD REV  
(Import) (Export)  
**2600 MW 1300 MW**  
SCH - PJ - NY  
Impacts Total Transfer Capability 150 MW 0 MW  
TTC with All Lines In Service 2750 MW 1300 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 30, 2018 to Thursday ,August 01, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SPRNBK\_\_345KV\_RNS3**

FWD

Tue 02/20/2018 to Tue 02/20/2018 UPDATED by CONED 01/25/2018

(Import)

0001 Continuous 0130

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**EASTVIEW-SPRNBK\_\_345\_W78**

FWD

Tue 02/20/2018 to Thu 02/22/2018 UPDATED by CONED 01/25/2018

(Import)

0001 Continuous 0200

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**MILLWOOD-EASTVIEW\_345\_W85**

FWD

Tue 02/20/2018 to Thu 02/22/2018 UPDATED by CONED 01/25/2018

(Import)

0001 Continuous 0200

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**MARCY\_\_-EDIC\_\_345\_UE1-7**

FWD

Tue 02/20/2018 to Fri 02/23/2018

(Import)

0500 Continuous 1730

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19&16****MOSES\_\_-ADIRNDCK\_230\_MAI**

FWD

Tue 02/20/2018 to Fri 02/23/2018

(Import)

0700 Continuous 1730

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**N.SCTLND-LEEDS\_\_345\_93**

FWD

Wed 02/21/2018 to Wed 02/21/2018

(Import)

0800 Daily(No Weekends) 1500

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**SPRNBK\_\_345KV\_RNS3**

FWD

Thu 02/22/2018 to Thu 02/22/2018 UPDATED by CONED 01/25/2018

(Import)

0130 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 30, 2018 to Thursday ,August 01, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE_345KV_7</b>					FWD		
Sat 02/24/2018	to	Sat 02/24/2018	<u>UPDATED</u>	<u>by CE</u>	<u>09/22/2017</u>	(Import)	
0001	Continuous	0030					
Work scheduled by: ConEd					SPR/DUN-SOUTH	<b>3800 MW</b>	
					Impacts Total Transfer Capability	800 MW	
					TTC with All Lines In Service	4600 MW	
<b>DUNWODIE_345KV_8</b>					FWD		
Sat 02/24/2018	to	Sat 02/24/2018	<u>UPDATED</u>	<u>by CE</u>	<u>09/22/2017</u>	(Import)	
0001	Continuous	0030					
Work scheduled by: ConEd					SPR/DUN-SOUTH	<b>3800 MW</b>	
					Impacts Total Transfer Capability	800 MW	
					TTC with All Lines In Service	4600 MW	
<b>DUNWODIE-MOTTHAVN_345_72</b>					FWD		
Sat 02/24/2018	to	Sat 03/31/2018	<u>UPDATED</u>	<u>by CE</u>	<u>09/22/2017</u>	(Import)	
0001	Continuous	0300					
Work scheduled by: ConEd					SPR/DUN-SOUTH	<b>3800 MW</b>	
					Impacts Total Transfer Capability	800 MW	
					TTC with All Lines In Service	4600 MW	
<b>LONG_MTN-PLSNTVLY_345_398</b>					FWD	REV	
Sun 02/25/2018	to	Sun 02/25/2018				(Import)	(Export)
0001	Continuous	2359					
Work scheduled by: ConEd					SCH - NE - NY	<b>700 MW</b>	<b>1300 MW</b>
					Impacts Total Transfer Capability	700 MW	300 MW
					TTC with All Lines In Service	1400 MW	1600 MW
<b>LONG_MTN-PLSNTVLY_345_398</b>					FWD	REV	
Sun 02/25/2018	to	Sun 02/25/2018				(Import)	(Export)
0001	Continuous	2359					
Work scheduled by: ConEd					SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
					Impacts Total Transfer Capability	100 MW	100 MW
					TTC with All Lines In Service	200 MW	200 MW
<b>EGRDNCTY_345_138_AT1</b>					FWD		
Sun 02/25/2018	to	Thu 03/01/2018				(Import)	
0001	Continuous	2359					
Work scheduled by: LI					CONED - LIPA	<b>1250 MW</b>	
					Impacts Total Transfer Capability	250 MW	
					TTC with All Lines In Service	1500 MW	
<b>EGRDNCTY_345_138_AT2</b>					FWD		
Sun 02/25/2018	to	Thu 03/01/2018				(Import)	
0001	Continuous	2359					
Work scheduled by: LI					CONED - LIPA	<b>1250 MW</b>	
					Impacts Total Transfer Capability	250 MW	
					TTC with All Lines In Service	1500 MW	



**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 30, 2018 to Thursday ,August 01, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SPRNBK\_-EGRDNCTR\_345\_Y49**

FWD

Sun 02/25/2018 to Thu 03/01/2018

(Import)

0001 Continuous 2359

CONED - LIPA

**775 MW**

Impacts Total Transfer Capability 725 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI

**LONG\_MTN-PLSNTVLY\_345\_398**

FWD

REV

Mon 02/26/2018 to Tue 05/01/2018

(Import) (Export)

0001 Continuous 0300

SCH - NE - NY

**700 MW 1300 MW**

Impacts Total Transfer Capability 700 MW 300 MW

TTC with All Lines In Service 1400 MW 1600 MW

Work scheduled by: ConEd

**LONG\_MTN-PLSNTVLY\_345\_398**

FWD

REV

Mon 02/26/2018 to Tue 05/01/2018

(Import) (Export)

0001 Continuous 0300

SCH - NPX\_1385

**100 MW 100 MW**

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

Work scheduled by: ConEd

**MOSES\_-ADIRNDCK\_230\_MAI**

FWD

Mon 02/26/2018 to Fri 03/02/2018

(Import)

0700 Continuous 1730

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**PLSNTVLY-EFISHKIL\_345\_F37**

FWD

Thu 03/01/2018 to Thu 03/01/2018

(Import)

0001 Continuous 2230

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**MOSES\_-ADIRNDCK\_230\_MAI**

FWD

Mon 03/05/2018 to Fri 03/09/2018

(Import)

0700 Continuous 1730

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**MARCY\_-N.SCTLND\_345\_18**

FWD

Tue 03/06/2018 to Wed 03/07/2018

(Import)

0600 Continuous 1530

CENTRAL EAST - VC

**2090 MW**

Impacts Total Transfer Capability 885 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 19**

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 30, 2018 to Thursday ,August 01, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MA1

FWD

Mon 03/12/2018 to Fri 03/16/2018  
0700 Continuous 1730

(Import)

Work scheduled by: NYPA

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

FWD

Mon 03/19/2018 to Mon 03/19/2018 UPDATED by CONED 01/17/2018  
0001 Continuous 0030

(Import)

Work scheduled by: ConEd

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

## EASTVIEW-SPRNBK\_345\_W79

FWD

Mon 03/19/2018 to Mon 03/19/2018 UPDATED by CONED 01/17/2018  
0001 Continuous 0030

(Import)

Work scheduled by: ConEd

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

## RAMAPO\_\_\_-BUCHAN\_N\_345\_Y94

FWD

Mon 03/19/2018 to Fri 03/30/2018 UPDATED by CONED 01/17/2018  
0001 Continuous 0100

(Import)

Work scheduled by: ConEd

UPNY CONED

**4800 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 5100 MW

## W49TH\_ST\_345KV\_6

FWD

Mon 03/19/2018 to Tue 03/20/2018 UPDATED by CONED 01/02/2018  
0200 Continuous 0200

(Import)

Work scheduled by: ConEd

SCH - PJM\_HTP

**350 MW**

Impacts Total Transfer Capability 310 MW

TTC with All Lines In Service 660 MW

## W49TH\_ST\_345KV\_8

FWD

Mon 03/19/2018 to Tue 03/20/2018 UPDATED by CONED 01/02/2018  
0200 Continuous 0200

(Import)

Work scheduled by: ConEd

SCH - PJM\_HTP

**350 MW**

Impacts Total Transfer Capability 310 MW

TTC with All Lines In Service 660 MW

## W49TH\_ST\_345KV\_6

FWD

Wed 03/21/2018 to Wed 03/21/2018 UPDATED by CONED 01/02/2018  
0100 Continuous 0200

(Import)

Work scheduled by: ConEd

SCH - PJM\_HTP

**350 MW**

Impacts Total Transfer Capability 310 MW

TTC with All Lines In Service 660 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 30, 2018 to Thursday ,August 01, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_8**

FWD

Wed 03/21/2018 to Wed 03/21/2018 **UPDATED** **by CONED** **01/02/2018**  
 0100 Continuous 0200

Work scheduled by: ConEd

SCH - PJM\_HTP **350 MW**  
 Impacts Total Transfer Capability 310 MW  
 TTC with All Lines In Service 660 MW

**MARCY\_345KV\_CSC**

FWD

Mon 03/26/2018 to Fri 04/13/2018  
 0500 Continuous 1730

Work scheduled by: NYPA

(Import)  
 CENTRAL EAST - VC **2925 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 2975 MW

**MOSES\_-ADIRNDCK\_230\_MA2**

FWD

Mon 03/26/2018 to Thu 03/29/2018  
 0700 Continuous 1530

Work scheduled by: NYPA

(Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

FWD

Fri 03/30/2018 to Fri 03/30/2018 **UPDATED** **by CONED** **01/17/2018**  
 0030 Continuous 0100

Work scheduled by: ConEd

(Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 750 MW  
 TTC with All Lines In Service 5100 MW

**EASTVIEW-SPRNBK\_345\_W79**

FWD

Fri 03/30/2018 to Fri 03/30/2018 **UPDATED** **by CONED** **01/17/2018**  
 0030 Continuous 0100

Work scheduled by: ConEd

(Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 750 MW  
 TTC with All Lines In Service 5100 MW

**DUNWODIE\_345KV\_7**

FWD

Sat 03/31/2018 to Sat 03/31/2018 **UPDATED** **by CE** **09/22/2017**  
 0230 Continuous 0300

Work scheduled by: ConEd

(Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_8**

FWD

Sat 03/31/2018 to Sat 03/31/2018 **UPDATED** **by CE** **09/22/2017**  
 0230 Continuous 0300

Work scheduled by: ConEd

(Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 30, 2018 to Thursday ,August 01, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MAL**

FWD

Mon 04/02/2018 to Fri 04/06/2018

(Import)

0700 Continuous 1730

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**MALONE\_\_\_-WILLIS\_\_\_115\_1-910**

REV

Tue 04/03/2018 to Tue 04/03/2018

(Export)

0700 Continuous 1530

UPDATEDby NYPA11/20/2017

SCH - HQ\_CEDARS

**60 MW**

Impacts Total Transfer Capability 40 MW

TTC with All Lines In Service 100 MW

Work scheduled by: NYPA

**ARR: 38****SHOR\_NPX-SHOREHAM\_138\_CSC**

FWD

REV

Wed 04/04/2018 to Thu 04/12/2018

(Import) (Export)

0600 Continuous 1800

UPDATEDby LI11/08/2017

SCH - NPX\_CSC

**0 MW****0 MW**

Impacts Total Transfer Capability 330 MW

330 MW

TTC with All Lines In Service 330 MW

330 MW

Work scheduled by: LI

**LINDN\_CG-LNDVFT\_\_\_345\_V-3022**

FWD

REV

Sun 04/08/2018 to Fri 04/13/2018

(Import) (Export)

1400 Continuous 1800

SCH - PJM\_VFT

**0 MW****0 MW**

Impacts Total Transfer Capability 315 MW

315 MW

TTC with All Lines In Service 315 MW

315 MW

Work scheduled by: PJM

**BECK\_\_\_-NIAGARA\_\_\_345\_PA302**

FWD

REV

Mon 04/09/2018 to Fri 04/13/2018

(Import) (Export)

0500 Continuous 1700

UPDATEDby NYPA01/22/2018

SCH - OH - NY

**1100 MW****950 MW**

Impacts Total Transfer Capability 650 MW

950 MW

TTC with All Lines In Service 1750 MW

1900 MW

Work scheduled by: NYPA

**MOSES\_\_\_-ADIRNDCK\_230\_MAL**

FWD

Mon 04/09/2018 to Fri 04/13/2018

(Import)

0700 Continuous 1730

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**FRASER\_\_\_-GILBOA\_\_\_345\_GF5-35**

FWD

Mon 04/09/2018 to Fri 04/20/2018

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 30, 2018 to Thursday ,August 01, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BUCHAN\_N-EASTVIEW\_345\_W93**

FWD

Wed 04/11/2018 to Thu 04/12/2018 UPDATED by CONED 01/17/2018

(Import)

0001 Continuous 0130

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**EASTVIEW-SPRNBK\_345\_W79**

FWD

Wed 04/11/2018 to Thu 04/12/2018 UPDATED by CONED 01/17/2018

(Import)

0001 Continuous 0130

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**RAMAPO\_-BUCHAN\_N\_345\_Y94**

FWD

Wed 04/11/2018 to Thu 04/12/2018 UPDATED by CONED 01/17/2018

(Import)

0001 Continuous 0130

UPNY CONED

**4800 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

FWD

Mon 04/16/2018 to Tue 05/01/2018

(Import)

0001 Continuous 1800

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: PJM

**NEWBRDGE-DUFFYAVE\_345\_501**

FWD

Mon 04/16/2018 to Tue 05/01/2018

(Import)

0001 Continuous 1800

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: PJM

**NEWBRDGE\_345\_138\_BK\_1**

FWD

Mon 04/16/2018 to Tue 05/01/2018

(Import)

0001 Continuous 1800

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

Work scheduled by: PJM

**NEWBRDGE\_345\_138\_BK\_2**

FWD

Mon 04/16/2018 to Tue 05/01/2018

(Import)

0001 Continuous 1800

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

Work scheduled by: PJM

**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 30, 2018 to Thursday ,August 01, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Mon 04/16/2018 to Fri 04/20/2018

(Import)

0700 Continuous 1730

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**BUCHAN\_N-EASTVIEW\_345\_W93**

FWD

Sat 04/21/2018 to Sat 04/21/2018

(Import)

0130 Continuous 0200

**UPDATED****by CONED 01/17/2018**

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**EASTVIEW-SPRNBK\_345\_W79**

FWD

Sat 04/21/2018 to Sat 04/21/2018

(Import)

0130 Continuous 0200

**UPDATED****by CONED 01/17/2018**

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**MARCY\_\_\_765\_345\_AT1**

FWD

Mon 04/23/2018 to Mon 04/23/2018

(Import)

0500 Continuous 1730

MOSES SOUTH

**1750 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19****LOWVILLE-BOONVILLE\_115\_5**

FWD

REV

Tue 04/24/2018 to Tue 04/24/2018

(Import) (Export)

0800 Daily(No Weekends) 1430

SCH - HQ\_CEDARS

**199 MW****100 MW**

Impacts Total Transfer Capability 0 MW

0 MW

TTC with All Lines In Service 199 MW

100 MW

Work scheduled by: NGrid

**ARR: 38****BULYMO\_\_\_-BOONVILLE\_115\_6**

FWD

REV

Wed 04/25/2018 to Wed 04/25/2018

(Import) (Export)

0800 Daily(No Weekends) 1430

SCH - HQ\_CEDARS

**199 MW****100 MW**

Impacts Total Transfer Capability 0 MW

0 MW

TTC with All Lines In Service 199 MW

100 MW

Work scheduled by: NGrid

**ARR: 38****MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 04/30/2018 to Fri 05/04/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 30, 2018 to Thursday ,August 01, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_SO\_SERIES\_COMP\_I/S**

FWD

Tue 05/01/2018 to Mon 05/21/2018

(Import)

0001 Continuous 0559

CENTRAL EAST - VC

**2740 MW**

Impacts Total Transfer Capability 235 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYISO

**S.RIPLEY-DUNKIRK\_\_230\_68**

FWD

REV

Tue 05/01/2018 to Sat 06/02/2018

(Import) (Export)

1000 Continuous 1600

UPDATEDby PJM01/22/2018

SCH - PJ - NY

**1950 MW 1350 MW**

Impacts Total Transfer Capability 150 MW 0 MW

TTC with All Lines In Service 2100 MW 1350 MW

Work scheduled by: PJM

**SCH-NYISO-NE\_LIMIT\_800**

REV

Sun 05/06/2018 to Sun 05/06/2018

(Export)

0600 Continuous 1900

SCH - NE - NY

**1000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 1600 MW

Work scheduled by: ISONE

**NIAGARA\_-KINTIGH\_\_345\_NS1-38**

FWD

Mon 05/07/2018 to Fri 05/11/2018

(Import)

0500 Continuous 1700

DYSINGER EAST

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**MOSES\_-ADIRNDCK\_230\_MA2**

FWD

Mon 05/07/2018 to Fri 05/11/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**MOSES\_-ADIRNDCK\_230\_MA2**

FWD

Mon 05/14/2018 to Fri 05/18/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**CLAY\_-EDIC\_\_345\_1-16**

FWD

Mon 05/14/2018 to Fri 05/18/2018

(Import)

0700 Continuous 1700

OSWEGO EXPORT

**4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 30, 2018 to Thursday ,August 01, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## ERIE E\_\_-S.RIPLEY\_230\_69 & WETHSRFD-MEYER\_\_\_\_230\_85/87

Tue 05/15/2018 to Fri 06/01/2018  
0700 1500

Work scheduled by:

FWD  
(Import)  
DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

## WETHSRFD-MEYER\_\_\_\_230\_85/87

Tue 05/15/2018 to Fri 06/01/2018  
0700 Continuous 1500

Work scheduled by: NYSEG

FWD  
(Import)  
DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

## MARCY\_\_\_\_765\_345\_AT2

Mon 05/21/2018 to Fri 05/25/2018  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## FRASANNX-COOPERS\_\_345\_UCC2-41

Mon 05/21/2018 to Fri 06/01/2018  
0600 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

## MARCY\_\_\_\_-FRASANNX\_345\_UCC2-41

Mon 05/21/2018 to Fri 06/01/2018  
0600 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MAI

Mon 05/28/2018 to Fri 06/01/2018  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## STLAWRNC-MOSES\_\_\_\_230\_L33P

Mon 05/28/2018 to Fri 06/01/2018  
0700 Continuous 2000

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>2000 MW</b>	<b>1600 MW</b>
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2000 MW	1600 MW



**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 30, 2018 to Thursday ,August 01, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_SO\_SERIES\_COMP\_I/S**

FWD

Fri 06/01/2018 to Wed 10/31/2018

(Import)

1800 Continuous 2359

CENTRAL EAST - VC

**2740 MW**

Impacts Total Transfer Capability 235 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYISO

**S.RIPLEY-DUNKIRK\_230\_68**

FWD

REV

Sat 06/02/2018 to Sat 02/01/2020

(Import) (Export)

1600 Continuous 0000

**UPDATED****by NYISO 01/22/2018**

SCH - PJ - NY

**1950 MW 1350 MW**

Impacts Total Transfer Capability 150 MW 0 MW

TTC with All Lines In Service 2100 MW 1350 MW

Work scheduled by: NYISO

**MARCY\_\_\_765\_345\_AT1**

FWD

Sat 08/04/2018 to Sun 08/05/2018

(Import)

0500 Continuous 1730

MOSES SOUTH

**1750 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19****MARCY\_\_\_765\_345\_AT2**

FWD

Tue 09/04/2018 to Sun 09/09/2018

(Import)

0500 Continuous 1730

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19****FRASER\_-GILBOA\_\_\_345\_GF5-35**

FWD

Mon 09/10/2018 to Fri 10/05/2018

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ROSETON\_-ROCKTVRN\_345\_311**

FWD

Mon 09/10/2018 to Fri 09/28/2018

(Import)

0800 Continuous 1600

UPNY CONED

**4400 MW**

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: CHGE

**MARCY\_\_\_345KV\_CSC**

FWD

Tue 09/11/2018 to Tue 09/11/2018

(Import)

0500 Continuous 1730

CENTRAL EAST - VC

**2925 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 30, 2018 to Thursday ,August 01, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MARCY\_\_\_\_345KV\_CSC & MARCY\_SO\_SERIES\_COMP\_I/S

Tue 09/11/2018 to Tue 09/11/2018  
0500 1730

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **2690 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 2975 MW

## MARCY\_\_\_\_765\_345\_AT2

Tue 09/11/2018 to Tue 09/11/2018  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## NIAGARA\_\_345\_230\_AT4

Fri 09/14/2018 to Fri 09/14/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **2000 MW 1400 MW**  
Impacts Total Transfer Capability 0 MW 200 MW  
TTC with All Lines In Service 2000 MW 1600 MW

## NIAGARA\_-ROCHESTR\_345\_NR2

Mon 09/17/2018 to Fri 09/21/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## MOSES\_\_-ADIRNDCK\_230\_MA1

Mon 09/17/2018 to Fri 09/21/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## MOSES\_\_-ADIRNDCK\_230\_MA1

Mon 09/24/2018 to Fri 09/28/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## CLAY\_\_\_\_-EDIC\_\_\_\_345\_2-15

Mon 09/24/2018 to Fri 09/28/2018  
0700 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 30, 2018 to Thursday ,August 01, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BECK\_\_\_\_-NIAGARA\_\_345\_PA302**

Mon 10/01/2018 to Fri 10/05/2018  
 0500 Continuous 1700

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>900 MW</b>	<b>800 MW</b>
Impacts Total Transfer Capability	1100 MW	800 MW
TTC with All Lines In Service	2000 MW	1600 MW

**MOSES\_\_\_\_-ADIRNDCK\_230\_MA2**

Mon 10/01/2018 to Wed 10/03/2018  
 0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2100 MW</b>
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

**PANNELL\_-CLAY\_\_\_\_345\_1**

Mon 10/01/2018 to Fri 10/05/2018  
 0700 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
WEST CENTRAL	<b>1300 MW</b>
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	2250 MW

**MARCY\_\_\_\_765\_345\_AT2**

Thu 10/04/2018 to Fri 10/05/2018  
 0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

	FWD
	(Import)
MOSES SOUTH	<b>1700 MW</b>
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

**MOSES\_\_\_\_-ADIRNDCK\_230\_MA1**

Mon 10/08/2018 to Fri 10/12/2018  
 0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2100 MW</b>
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

**CHATGUAY-MASSENA\_\_765\_7040**

Sat 10/13/2018 to Sat 10/27/2018  
 0100 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>1550 MW</b>
Impacts Total Transfer Capability	1600 MW
TTC with All Lines In Service	3150 MW

**CHATGUAY-MASSENA\_\_765\_7040**

Sat 10/13/2018 to Sat 10/27/2018  
 0100 Continuous 1730

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 30, 2018 to Thursday ,August 01, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_\_765\_345\_AT1**

Sat 10/13/2018 to Sat 10/27/2018  
 0100 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 MOSES SOUTH **1750 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 3150 MW

**MARCY\_\_\_\_765\_345\_AT2**

Sat 10/13/2018 to Sat 10/27/2018  
 0100 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

**MASSENA\_-MARCY\_\_\_\_765\_MSU1**

Sat 10/13/2018 to Sat 10/27/2018  
 0100 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2265 MW**  
 Impacts Total Transfer Capability 710 MW  
 TTC with All Lines In Service 2975 MW

**MASSENA\_-MARCY\_\_\_\_765\_MSU1**

Sat 10/13/2018 to Sat 10/27/2018  
 0100 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **500 MW**  
 Impacts Total Transfer Capability 2650 MW  
 TTC with All Lines In Service 3150 MW

**MASSENA\_-MARCY\_\_\_\_765\_MSU1**

Sat 10/13/2018 to Sat 10/27/2018  
 0100 Continuous 1730

Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
 SCH - HQ - NY **475 MW 1000 MW**  
 Impacts Total Transfer Capability 1025 MW 0 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

**MASSENA\_-MARCY\_\_\_\_765\_MSU1 & CHATGUAY-MASSENA\_765\_7040**

Sat 10/13/2018 to Sat 10/27/2018  
 0100 1730

Work scheduled by:

FWD  
 (Import)  
 MOSES SOUTH **500 MW**  
 Impacts Total Transfer Capability 2650 MW  
 TTC with All Lines In Service 3150 MW

**MASSENA\_-MARCY\_\_\_\_765\_MSU1 & MARCY\_SO\_SERIES\_COMP\_I/S**

Sat 10/13/2018 to Sat 10/27/2018  
 0100 1730

Work scheduled by:

FWD  
 (Import)  
 CENTRAL EAST - VC **2080 MW**  
 Impacts Total Transfer Capability 895 MW  
 TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 30, 2018 to Thursday ,August 01, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_\_-MASSENA\_230\_MMS1 & MOSES\_\_\_\_-MASSENA\_230\_MMS2

Sat 10/13/2018 to Sat 10/27/2018  
0100 1730

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY 850 MW 0 MW  
Impacts Total Transfer Capability 650 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

## LEEDS\_\_\_\_-HURLYAVE\_345\_301

Mon 10/22/2018 to Fri 11/16/2018  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED 4100 MW  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 5100 MW

## KINTIGH\_-ROCHESTR\_345\_SRI-39

Mon 10/29/2018 to Fri 11/02/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST 1700 MW  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MAI

Mon 10/29/2018 to Fri 11/02/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2100 MW  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MAI

Mon 11/05/2018 to Fri 11/09/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2300 MW  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## MARCY\_\_\_\_345KV\_CSC

Fri 11/16/2018 to Sat 11/17/2018  
0500 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC 2925 MW  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

## MARCY\_\_\_\_765\_345\_AT2

Fri 11/16/2018 to Sat 11/17/2018  
0500 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 1700 MW  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

ARR: 19

**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 30, 2018 to Thursday ,August 01, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Mon 11/19/2018 to Wed 11/21/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 11/26/2018 to Fri 11/30/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**HURLYAVE-ROSETON\_\_\_345\_303**

FWD

Mon 11/26/2018 to Fri 12/21/2018

(Import)

0800 Continuous 1600

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: CHGE

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 12/03/2018 to Fri 12/07/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 12/10/2018 to Fri 12/14/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**MARCY\_\_\_765\_345\_AT2**

FWD

Mon 12/17/2018 to Fri 12/21/2018

(Import)

0500 Continuous 1730

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19****MOSES\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Wed 12/26/2018 to Fri 12/28/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA