

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 16, 2018 to Thursday ,July 18, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**E13THSTA-FARRAGUT\_345\_45**

Sun 11/26/2017 to Tue 05/15/2018  
0001 Continuous 2359

UPDATED by CE 01/03/2018

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**W49TH\_ST-E13THSTA\_345\_M54**

Sun 11/26/2017 to Tue 05/15/2018  
0001 Continuous 2359

UPDATED by CE 01/03/2018

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**NRTH1385-NOR HBR\_138\_601**

Mon 12/04/2017 to Thu 01/11/2018  
0700 Continuous 2234

EXTENDED by LI 12/07/2017

Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **100 MW 100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

**NRTH1385-NOR HBR\_138\_601 & NRTH1385-NOR HBR\_138\_602**

Mon 12/04/2017 to Thu 01/11/2018  
0700 2234

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **0 MW 0 MW**  
Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 200 MW 200 MW

**NRTH1385-NOR HBR\_138\_601 & NRTH1385-NOR HBR\_138\_603**

Mon 12/04/2017 to Thu 01/11/2018  
0700 2234

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **0 MW 0 MW**  
Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 200 MW 200 MW

**NRTH1385-NRTHPORT\_138\_NNC**

Mon 12/04/2017 to Thu 01/11/2018  
0700 Continuous 2234

EXTENDED by LI 12/07/2017

Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **0 MW 0 MW**  
Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 200 MW 200 MW

**NRTH1385-NOR HBR\_138\_602**

Mon 12/04/2017 to Thu 01/11/2018  
0700 Continuous 2239

EXTENDED by LI 12/07/2017

Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **100 MW 100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 16, 2018 to Thursday ,July 18, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**NRTH1385-NOR HBR\_\_138\_602 & NRTH1385-NOR HBR\_\_138\_603**

Mon 12/04/2017 to Thu 01/11/2018  
0700 2239

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

---

**NRTH1385-NOR HBR\_\_138\_603**

Mon 12/04/2017 to Thu 01/11/2018  
0700 Continuous 2240

Work scheduled by: LI

**EXTENDED by LI 12/07/2017**

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

---

**S.RIPLEY-DUNKIRK\_\_230\_68**

Fri 12/15/2017 to Mon 03/19/2018  
1400 Continuous 0959

Work scheduled by: NYISO

**UPDATED by NYISO 12/08/2017**

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2600 MW</b>	<b>1350 MW</b>
Impacts Total Transfer Capability	150 MW	100 MW
TTC with All Lines In Service	2750 MW	1450 MW

---

**CHAT\_DC\_GC2**

Tue 12/19/2017 to Thu 03/01/2018  
2257 Continuous 2359

Work scheduled by: HQ

**by HQ 01/15/2018**

	FWD
	(Import)
MOSES SOUTH	<b>2850 MW</b>
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

---

**CHAT\_DC\_GC2**

Tue 12/19/2017 to Thu 03/01/2018  
2257 Continuous 2359

Work scheduled by: HQ

**by HQ 01/15/2018**

		REV
		(Export)
SCH - HQ - NY		<b>500 MW</b>
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1000 MW

---

**W49TH\_ST\_345KV\_6**

Tue 12/26/2017 to Fri 01/12/2018  
0001 Continuous 2200

Work scheduled by: ConEd

**EXTENDED by CE 01/02/2018**

	FWD
	(Import)
SCH - PJM_HTP	<b>350 MW</b>
Impacts Total Transfer Capability	310 MW
TTC with All Lines In Service	660 MW

---

**DUNWODIE\_345KV\_6**

Sun 01/07/2018 to Thu 01/11/2018  
2130 Continuous 2359

Work scheduled by: ConEd

**EXT FORCE by CE 01/09/2018**

	FWD
	(Import)
SPR/DUN-SOUTH	<b>3800 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 16, 2018 to Thursday ,July 18, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_\_765\_345\_AT2**

FWD

Mon 01/08/2018 to Sat 01/13/2018 **UPDATED** **by NYPA** **01/12/2018**

(Import)

0500 Continuous 2100

MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19****LEEDS\_\_\_\_-PLSNTVLY\_345\_92**

FWD

Tue 01/09/2018 to Fri 01/12/2018 **EXTENDED** **by NYISO** **01/16/2018**

(Import)

0001 Continuous 0300

UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 1300 MW  
 TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**PLSNTVLY\_345KV\_RNS5**

FWD

Tue 01/09/2018 to Fri 01/12/2018 **EXTENDED** **by NYISO** **01/16/2018**

(Import)

0001 Continuous 0300

UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 1300 MW  
 TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**SCH-HQ-NYISO\_LIMIT\_1100**

FWD

Wed 01/10/2018 to Fri 01/12/2018 **by HQ** **01/15/2018**

(Import)

2300 Continuous 1159

SCH - HQ - NY **1100 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 1500 MW

Work scheduled by: HQ

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

FWD

Thu 01/11/2018 to Sat 01/13/2018

(Import)

0001 2359

UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 1300 MW  
 TTC with All Lines In Service 5100 MW

Work scheduled by:

**MILLWOOD-EASTVIEW\_345\_W99**

FWD

Fri 01/12/2018 to Mon 01/15/2018 **FORCED** **by CE** **01/12/2018**

(Import)

0457 Continuous 2359

UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 750 MW  
 TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**SCH-IMO-NYISO\_LIMIT\_1400**

FWD

Fri 01/12/2018 to Fri 01/12/2018 **UPDATED** **by NYISO** **01/09/2018**

(Import)

0500 Continuous 1700

SCH - OH - NY **1700 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 1750 MW

Work scheduled by: NYPA

**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 16, 2018 to Thursday ,July 18, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**HUDSONP\_-FARRAGUT\_345\_B3402**

Fri 01/12/2018 to Fri 01/12/2018 **UPDATED** **by CE** **01/16/2018**  
 0738 Continuous 2359

Work scheduled by: ConEd

FWD REV  
 (Import) (Export)  
**2300 MW 1450 MW**  
 Impacts Total Transfer Capability 450 MW 0 MW  
 TTC with All Lines In Service 2750 MW 1450 MW

**SCH-HQ-NYISO\_LIMIT\_1250**

Fri 01/12/2018 to Fri 01/12/2018 **by HQ** **01/15/2018**  
 1200 Continuous 2359

Work scheduled by: HQ

FWD  
 (Import)  
**1250 MW**  
 Impacts Total Transfer Capability 250 MW  
 TTC with All Lines In Service 1500 MW

**SCH-HQ-NYISO\_LIMIT\_1100**

Sat 01/13/2018 to Mon 01/15/2018 **by HQ** **01/15/2018**  
 0001 Continuous 2359

Work scheduled by: HQ

FWD  
 (Import)  
**1100 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 1500 MW

**SCH-NYISO-PJM\_LIMIT\_100**

Sat 01/13/2018 to Sat 01/13/2018 **UPDATED** **by PJM** **01/11/2018**  
 0700 Continuous 1600

Work scheduled by: PJM

REV  
 (Export)  
**400 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 1450 MW

**COOPERS\_-MIDDLETP\_345\_CCRT34**

Sat 01/13/2018 to Sat 01/13/2018 **UPDATED** **by CH** **01/13/2018**  
 0800 Continuous 1429

Work scheduled by: CHGE

FWD  
 (Import)  
**2720 MW**  
 Impacts Total Transfer Capability 255 MW  
 TTC with All Lines In Service 2975 MW

**PLSNTVLY\_345KV\_RNS5**

Sun 01/14/2018 to Wed 01/17/2018 **EXTENDED** **by NYISO** **01/16/2018**  
 0001 Continuous 0300

Work scheduled by: ConEd

FWD  
 (Import)  
**3800 MW**  
 Impacts Total Transfer Capability 1300 MW  
 TTC with All Lines In Service 5100 MW

**LEEDS\_-PLSNTVLY\_345\_92**

Sun 01/14/2018 to Mon 01/15/2018 **FORCED** **by NG** **01/14/2018**  
 1405 Continuous 2359

Work scheduled by: NGrid

FWD  
 (Import)  
**3800 MW**  
 Impacts Total Transfer Capability 1300 MW  
 TTC with All Lines In Service 5100 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 16, 2018 to Thursday ,July 18, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## N.SCTLND-LEEDS\_\_\_\_345\_93

Sun 01/14/2018 to Mon 01/15/2018 **FORCED** **by NG** **01/14/2018**

1405 Continuous 2359

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

## HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Thu 02/15/2018 **UPDATED** **by CE** **01/16/2018**

0001 Continuous 2359

Work scheduled by: ConEd

FWD

REV

(Import) (Export)

SCH - PJ - NY

**2300 MW 1450 MW**

Impacts Total Transfer Capability 450 MW 0 MW

TTC with All Lines In Service 2750 MW 1450 MW

## HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Thu 02/15/2018

0001 2359

Work scheduled by:

FWD

REV

(Import) (Export)

SCH - PJ - NY

**2050 MW 1450 MW**

Impacts Total Transfer Capability 700 MW 0 MW

TTC with All Lines In Service 2750 MW 1450 MW

## MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Thu 02/15/2018 **UPDATED** **by CE** **01/16/2018**

0001 Continuous 2359

Work scheduled by: ConEd

FWD

REV

(Import) (Export)

SCH - PJ - NY

**2300 MW 1450 MW**

Impacts Total Transfer Capability 450 MW 0 MW

TTC with All Lines In Service 2750 MW 1450 MW

## FRASER\_-GILBOA\_\_\_\_345\_GF5-35

Mon 01/15/2018 to Mon 01/15/2018 **CANCELLED** **by NYISO** **01/14/2018**

0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

## EASTVIEW-SPRNBK\_\_\_\_345\_W64

Tue 01/16/2018 to Mon 02/19/2018 **UPDATED** **by CE** **12/13/2017**

0001 Continuous 0100

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

## MILLWOOD-EASTVIEW\_345\_W99

Tue 01/16/2018 to Mon 02/19/2018 **UPDATED** **by CE** **12/13/2017**

0001 Continuous 0100

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 16, 2018 to Thursday ,July 18, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS5						FWD				
Tue 01/16/2018	to	Mon 02/19/2018	<u>UPDATED</u>	<u>by CE</u>	<u>12/13/2017</u>	(Import)				
0001	Continuous	0100				SPR/DUN-SOUTH	<b>3200 MW</b>			
Work scheduled by: ConEd						Impacts Total Transfer Capability	1400 MW			
						TTC with All Lines In Service	4600 MW			
SCH-HQ-NYISO_LIMIT_1200						FWD				
Tue 01/16/2018	to	Thu 03/01/2018		<u>by HQ</u>	<u>01/15/2018</u>	(Import)				
0001	Continuous	2359				SCH - HQ - NY	<b>1200 MW</b>			
Work scheduled by: HQ						Impacts Total Transfer Capability	300 MW			
						TTC with All Lines In Service	1500 MW			
HOPATCON-RAMAPO__500_5018						FWD	REV			
Tue 01/16/2018	to	Thu 01/18/2018	<u>CANCELLED</u>	<u>by PJM</u>	<u>01/12/2018</u>	(Import)	(Export)			
0200	Continuous	2000				SCH - PJ - NY	<b>2100 MW</b>	<b>1000 MW</b>		
Work scheduled by: PJM						Impacts Total Transfer Capability	650 MW 450 MW			
						TTC with All Lines In Service	2750 MW 1450 MW			
HOPATCON-RAMAPO__500_5018						FWD				
Tue 01/16/2018	to	Thu 01/18/2018	<u>CANCELLED</u>	<u>by PJM</u>	<u>01/12/2018</u>	(Import)				
0200	Continuous	2000				UPNY CONED	<b>5000 MW</b>			
Work scheduled by: PJM						Impacts Total Transfer Capability	100 MW			
						TTC with All Lines In Service	5100 MW			
RAMAPO__345_345_PAR3500						FWD	REV			
Tue 01/16/2018	to	Thu 01/18/2018	<u>CANCELLED</u>	<u>by PJM</u>	<u>01/12/2018</u>	(Import)	(Export)			
0200	Continuous	2000				SCH - PJ - NY	<b>2200 MW</b>	<b>1450 MW</b>		
Work scheduled by: PJM						Impacts Total Transfer Capability	550 MW 0 MW			
						TTC with All Lines In Service	2750 MW 1450 MW			
RAMAPO__345_345_PAR4500						FWD	REV			
Tue 01/16/2018	to	Thu 01/18/2018	<u>CANCELLED</u>	<u>by PJM</u>	<u>01/12/2018</u>	(Import)	(Export)			
0200	Continuous	2000				SCH - PJ - NY	<b>2200 MW</b>	<b>1450 MW</b>		
Work scheduled by: PJM						Impacts Total Transfer Capability	550 MW 0 MW			
						TTC with All Lines In Service	2750 MW 1450 MW			
RAMAPO__500_345_BK_1500						FWD	REV			
Tue 01/16/2018	to	Thu 01/18/2018	<u>CANCELLED</u>	<u>by PJM</u>	<u>01/12/2018</u>	(Import)	(Export)			
0200	Continuous	2000				SCH - PJ - NY	<b>2100 MW</b>	<b>1000 MW</b>		
Work scheduled by: PJM						Impacts Total Transfer Capability	650 MW 450 MW			
						TTC with All Lines In Service	2750 MW 1450 MW			

**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 16, 2018 to Thursday ,July 18, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**RAMAPO\_\_\_500\_345\_BK 1500**

FWD

Tue 01/16/2018 to Thu 01/18/2018

**CANCELLED by PJM 01/12/2018**

(Import)

0200 Continuous 2000

UPNY CONED

**5000 MW**

Work scheduled by: PJM

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 5100 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Tue 01/16/2018 to Fri 01/19/2018

**UPDATED by NYPA 01/10/2018**

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

**DUNWODIE-SHORE\_RD\_345\_Y50**

FWD

Wed 01/17/2018 to Sun 01/21/2018

**CANCELLED by NYISO 01/12/2018**

(Import)

0200 Continuous 2359

CONED - LIPA

**800 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 1500 MW

**DUNWODIE\_345KV\_4**

FWD

Wed 01/17/2018 to Sun 01/21/2018

**CANCELLED by NYISO 01/12/2018**

(Import)

0200 Continuous 2359

SPR/DUN-SOUTH

**3800 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_6**

FWD

Wed 01/17/2018 to Sun 01/21/2018

**CANCELLED by NYISO 01/12/2018**

(Import)

0200 Continuous 2359

SPR/DUN-SOUTH

**3800 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**SHORE\_RD\_345\_138\_BK 1**

FWD

Wed 01/17/2018 to Sun 01/21/2018

**CANCELLED by NYISO 01/12/2018**

(Import)

0200 Continuous 2359

CONED - LIPA

**1350 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1500 MW

**SHORE\_RD\_345\_138\_BK 2**

FWD

Wed 01/17/2018 to Sun 01/21/2018

**CANCELLED by NYISO 01/12/2018**

(Import)

0200 Continuous 2359

CONED - LIPA

**1350 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1500 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 16, 2018 to Thursday ,July 18, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**FRASER -GILBOA 345\_GF5-35**

FWD

Wed 01/17/2018 to Wed 01/17/2018  
 0700 Continuous 1730

**UPDATED****by NYPA****01/15/2018**

(Import)

Work scheduled by: NYPA

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

**N.SCTLND-ALPS 345\_2**

FWD

REV

Wed 01/17/2018 to Fri 02/09/2018  
 0800 Continuous 1400

**by NYISO****01/14/2018**

(Import) (Export)

Work scheduled by: NGrid

SCH - NE - NY

**900 MW 1600 MW**

Impacts Total Transfer Capability 500 MW 0 MW

TTC with All Lines In Service 1400 MW 1600 MW

**N.SCTLND-ALPS 345\_2**

FWD

REV

Wed 01/17/2018 to Fri 02/09/2018  
 0800 Continuous 1400

**by NYISO****01/14/2018**

(Import) (Export)

Work scheduled by: NGrid

SCH - NPX\_1385

**100 MW 100 MW**

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

**SCH-NE-NYISO\_LIMIT\_400**

FWD

Wed 01/17/2018 to Fri 02/09/2018  
 0800 Continuous 1400

**by NYISO****01/14/2018**

(Import)

Work scheduled by: NGrid

SCH - NE - NY

**600 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 1400 MW

**SCH-NYISO-NE\_LIMIT\_600**

REV

Wed 01/17/2018 to Fri 02/09/2018  
 0800 Continuous 1400

**by NYISO****01/14/2018**

(Export)

Work scheduled by: NGrid

SCH - NE - NY

**800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 1600 MW

**PLSNTVLY-EFISHKIL\_345\_F37**

FWD

Fri 01/19/2018 to Sat 01/20/2018  
 0001 Continuous 0200

**UPDATED****by CONED****01/12/2018**

(Import)

Work scheduled by: ConEd

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

**HURLYAVE-ROSETON\_345\_303**

FWD

Fri 01/19/2018 to Sat 01/20/2018  
 0800 Continuous 1600

**UPDATED****by CHGE****01/04/2018**

(Import)

Work scheduled by: CHGE

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 5100 MW



# NYISO TRANSFER LIMITATIONS

Tuesday ,January 16, 2018 to Thursday ,July 18, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 01/22/2018 to Fri 01/26/2018 CANCELLED by NYPA 01/15/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 01/22/2018 to Fri 01/26/2018 UPDATED by NYPA 01/15/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## FRASER\_\_\_-COOPERS\_\_\_345\_33

Mon 01/22/2018 to Thu 01/25/2018 UPDATED by NYSEG 01/04/2018  
0800 Continuous 1500

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2395 MW**  
Impacts Total Transfer Capability 580 MW  
TTC with All Lines In Service 2975 MW

## SCH-NYISO-NE\_LIMIT\_1300

Wed 01/24/2018 to Fri 01/26/2018  
0600 Daily 1700

Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY **1500 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 1600 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 01/29/2018 to Fri 02/02/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## MARCY\_\_\_765\_345\_AT2

Sat 02/03/2018 to Sat 02/03/2018 UPDATED by NYPA 01/02/2018  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 02/05/2018 to Fri 02/09/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 16, 2018 to Thursday ,July 18, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 02/12/2018 to Fri 02/16/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2300 MW  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## HUDSONP\_-FARRAGUT\_345\_B3402

Sun 02/18/2018 to Sun 04/01/2018  
0001 Continuous 2359

Work scheduled by: PJM

UPDATED by PJM 12/13/2017

FWD REV  
(Import) (Export)  
SCH - PJ - NY 2300 MW 1450 MW  
Impacts Total Transfer Capability 450 MW 0 MW  
TTC with All Lines In Service 2750 MW 1450 MW

## MARCY\_\_\_\_-EDIC\_\_\_\_345\_UE1-7

Tue 02/20/2018 to Fri 02/23/2018  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19&16

FWD  
(Import)  
OSWEGO EXPORT 5250 MW  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA1

Tue 02/20/2018 to Fri 02/23/2018  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2300 MW  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## N.SCTLND-LEEDS\_\_\_\_345\_93

Wed 02/21/2018 to Wed 02/21/2018  
0800 Daily(No Weekends) 1500

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC 2650 MW  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

## DUNWODIE\_345KV\_7

Sat 02/24/2018 to Sat 02/24/2018  
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CE 09/22/2017

FWD  
(Import)  
SPR/DUN-SOUTH 3800 MW  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## DUNWODIE\_345KV\_8

Sat 02/24/2018 to Sat 02/24/2018  
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CE 09/22/2017

FWD  
(Import)  
SPR/DUN-SOUTH 3800 MW  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE-MOTTHAVN_345_72</b>					FWD		
Sat 02/24/2018	to	Sat 03/31/2018	<u>UPDATED</u>	<u>by CE</u>	<u>09/22/2017</u>	(Import)	
0001	Continuous	0300			SPR/DUN-SOUTH	<b>3800 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW	
					TTC with All Lines In Service	4600 MW	
<b>LONG_MTN-PLSNTVLY_345_398</b>					FWD	REV	
Sun 02/25/2018	to	Sun 02/25/2018			(Import)	(Export)	
0001	Continuous	2359			SCH - NE - NY	<b>700 MW</b>	<b>1300 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	700 MW	300 MW
					TTC with All Lines In Service	1400 MW	1600 MW
<b>LONG_MTN-PLSNTVLY_345_398</b>					FWD	REV	
Sun 02/25/2018	to	Sun 02/25/2018			(Import)	(Export)	
0001	Continuous	2359			SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	100 MW	100 MW
					TTC with All Lines In Service	200 MW	200 MW
<b>EGRDNCTY_345_138_AT1</b>					FWD		
Sun 02/25/2018	to	Thu 03/01/2018			(Import)		
0001	Continuous	2359			CONED - LIPA	<b>1250 MW</b>	
Work scheduled by: LI					Impacts Total Transfer Capability	250 MW	
					TTC with All Lines In Service	1500 MW	
<b>EGRDNCTY_345_138_AT2</b>					FWD		
Sun 02/25/2018	to	Thu 03/01/2018			(Import)		
0001	Continuous	2359			CONED - LIPA	<b>1250 MW</b>	
Work scheduled by: LI					Impacts Total Transfer Capability	250 MW	
					TTC with All Lines In Service	1500 MW	
<b>SPRNBK_-EGRDNCTR_345_Y49</b>					FWD		
Sun 02/25/2018	to	Thu 03/01/2018			(Import)		
0001	Continuous	2359			CONED - LIPA	<b>775 MW</b>	
Work scheduled by: LI					Impacts Total Transfer Capability	725 MW	
					TTC with All Lines In Service	1500 MW	
<b>LONG_MTN-PLSNTVLY_345_398</b>					FWD	REV	
Mon 02/26/2018	to	Wed 05/02/2018			(Import)	(Export)	
0001	Continuous	0300			SCH - NE - NY	<b>700 MW</b>	<b>1300 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	700 MW	300 MW
					TTC with All Lines In Service	1400 MW	1600 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 16, 2018 to Thursday ,July 18, 2019

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 5100MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LONG\_MTN-PLSNTVLY\_345\_398

Mon 02/26/2018 to Wed 05/02/2018  
 0001 Continuous 0300

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

## MOSES\_\_-ADIRNDCK\_230\_MAI

Mon 02/26/2018 to Fri 03/02/2018  
 0700 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## MOSES\_\_-ADIRNDCK\_230\_MAI

Mon 03/05/2018 to Fri 03/09/2018  
 0700 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## MARCY\_\_-N.SCTLND\_345\_18

Tue 03/06/2018 to Wed 03/07/2018  
 0600 Continuous 1530

Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
CENTRAL EAST - VC	2090 MW
Impacts Total Transfer Capability	885 MW
TTC with All Lines In Service	2975 MW

## MOSES\_\_-ADIRNDCK\_230\_MAI

Mon 03/12/2018 to Fri 03/16/2018  
 0700 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

Mon 03/19/2018 to Mon 03/19/2018  
 0001 Continuous 0030

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	4350 MW
Impacts Total Transfer Capability	750 MW
TTC with All Lines In Service	5100 MW

## EASTVIEW-SPRNBK\_\_345\_W79

Mon 03/19/2018 to Mon 03/19/2018  
 0001 Continuous 0030

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	4350 MW
Impacts Total Transfer Capability	750 MW
TTC with All Lines In Service	5100 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 16, 2018 to Thursday ,July 18, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_6**

FWD

Mon 03/19/2018 to Tue 03/20/2018 UPDATED by CONED 01/02/2018

(Import)

0200 Continuous 0200

SCH - PJM\_HTP

**350 MW**

Impacts Total Transfer Capability 310 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**W49TH\_ST\_345KV\_8**

FWD

Mon 03/19/2018 to Tue 03/20/2018 UPDATED by CONED 01/02/2018

(Import)

0200 Continuous 0200

SCH - PJM\_HTP

**350 MW**

Impacts Total Transfer Capability 310 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**S.RIPLEY-DUNKIRK\_\_230\_68**

FWD

REV

Mon 03/19/2018 to Fri 04/20/2018

(Import) (Export)

1000 Continuous 1559

SCH - PJ - NY

**2600 MW 1350 MW**

Impacts Total Transfer Capability 150 MW 100 MW

TTC with All Lines In Service 2750 MW 1450 MW

Work scheduled by: PJM

**W49TH\_ST\_345KV\_6**

FWD

Wed 03/21/2018 to Wed 03/21/2018 UPDATED by CONED 01/02/2018

(Import)

0100 Continuous 0200

SCH - PJM\_HTP

**350 MW**

Impacts Total Transfer Capability 310 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**W49TH\_ST\_345KV\_8**

FWD

Wed 03/21/2018 to Wed 03/21/2018 UPDATED by CONED 01/02/2018

(Import)

0100 Continuous 0200

SCH - PJM\_HTP

**350 MW**

Impacts Total Transfer Capability 310 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**MARCY\_\_\_\_345KV\_CSC**

FWD

Mon 03/26/2018 to Fri 04/13/2018

(Import)

0500 Continuous 1730

CENTRAL EAST - VC

**2925 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**MOSES\_\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 03/26/2018 to Thu 03/29/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 16, 2018 to Thursday ,July 18, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE_345KV_7</b>						FWD	
Sat 03/31/2018	to	Sat 03/31/2018	<u>UPDATED</u>	<u>by CE</u>	<u>09/22/2017</u>	(Import)	
0230	Continuous	0300				<b>3800 MW</b>	
Work scheduled by: ConEd						SPR/DUN-SOUTH	
						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
<hr/>							
<b>DUNWODIE_345KV_8</b>						FWD	
Sat 03/31/2018	to	Sat 03/31/2018	<u>UPDATED</u>	<u>by CE</u>	<u>09/22/2017</u>	(Import)	
0230	Continuous	0300				<b>3800 MW</b>	
Work scheduled by: ConEd						SPR/DUN-SOUTH	
						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
<hr/>							
<b>MOSES__-ADIRNDCK_230_MAL</b>						FWD	
Mon 04/02/2018	to	Fri 04/06/2018				(Import)	
0700	Continuous	1730				<b>2300 MW</b>	
Work scheduled by: NYPA						MOSES SOUTH	
						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
<hr/>							
<b>MALONE__-WILLIS__115_1-910</b>							REV
Tue 04/03/2018	to	Tue 04/03/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/20/2017</u>		(Export)
0700	Continuous	1530				<b>60 MW</b>	
Work scheduled by: NYPA				<b>ARR: 38</b>	SCH - HQ_CEDARS	40 MW	
						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	
<hr/>							
<b>SHOR_NPX-SHOREHAM_138_CSC</b>						FWD	REV
Wed 04/04/2018	to	Thu 04/12/2018	<u>UPDATED</u>	<u>by LI</u>	<u>11/08/2017</u>	(Import)	(Export)
0600	Continuous	1800				<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: LI						SCH - NPX_CSC	
						Impacts Total Transfer Capability	330 MW
						TTC with All Lines In Service	330 MW
<hr/>							
<b>LINDN_CG-LNDVFT__345_V-3022</b>						FWD	REV
Sun 04/08/2018	to	Fri 04/13/2018				(Import)	(Export)
1400	Continuous	1800				<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: PJM						SCH - PJM_VFT	
						Impacts Total Transfer Capability	315 MW
						TTC with All Lines In Service	315 MW
<hr/>							
<b>MOSES__-ADIRNDCK_230_MAL</b>						FWD	
Mon 04/09/2018	to	Fri 04/13/2018				(Import)	
0700	Continuous	1730				<b>2300 MW</b>	
Work scheduled by: NYPA						MOSES SOUTH	
						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 16, 2018 to Thursday ,July 18, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## FRASER -GILBOA 345\_GF5-35

Mon 04/09/2018 to Fri 04/20/2018  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

## NEPTUNE -DUFFYAVE 345\_NEPTUNE

Mon 04/16/2018 to Tue 05/01/2018  
0001 Continuous 1800

Work scheduled by: PJM

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

## NEWBRDGE-DUFFYAVE 345\_501

Mon 04/16/2018 to Tue 05/01/2018  
0001 Continuous 1800

Work scheduled by: PJM

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

## NEWBRDGE 345\_138\_BK\_1

Mon 04/16/2018 to Tue 05/01/2018  
0001 Continuous 1800

Work scheduled by: PJM

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

## NEWBRDGE 345\_138\_BK\_2

Mon 04/16/2018 to Tue 05/01/2018  
0001 Continuous 1800

Work scheduled by: PJM

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

## MOSES -ADIRNDCK 230\_MAI

Mon 04/16/2018 to Fri 04/20/2018  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## S.RIPLEY-DUNKIRK 230\_68

Fri 04/20/2018 to Sat 02/01/2020  
1600 Continuous 0000

Work scheduled by: NYISO

UPDATED by NYISO 12/08/2017

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2600 MW</b>	<b>1350 MW</b>
Impacts Total Transfer Capability	150 MW	100 MW
TTC with All Lines In Service	2750 MW	1450 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 16, 2018 to Thursday ,July 18, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## BUCHAN\_N-EASTVIEW\_345\_W93

Sat 04/21/2018 to Sat 04/21/2018  
0130 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

## EASTVIEW-SPRNBK\_345\_W79

Sat 04/21/2018 to Sat 04/21/2018  
0130 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

## MARCY\_765\_345\_AT1

Mon 04/23/2018 to Mon 04/23/2018  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1750 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

## MOSES-ADIRNDCK\_230\_MA2

Mon 04/30/2018 to Fri 05/04/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## MARCY\_SO\_SERIES\_COMP\_I/S

Tue 05/01/2018 to Mon 05/21/2018  
0001 Continuous 0559

Work scheduled by: NYISO

FWD  
(Import)  
CENTRAL EAST - VC **2740 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 2975 MW

## SCH-NYISO-NE\_LIMIT\_800

Sun 05/06/2018 to Sun 05/06/2018  
0600 Continuous 1900

Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1600 MW

## NIAGARA-KINTIGH\_345\_NS1-38

Mon 05/07/2018 to Fri 05/11/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW



# NYISO TRANSFER LIMITATIONS

Tuesday ,January 16, 2018 to Thursday ,July 18, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 05/07/2018 to Fri 05/11/2018

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH 2100 MW

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 05/14/2018 to Fri 05/18/2018

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH 2100 MW

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

## CLAY\_\_\_\_-EDIC\_\_\_\_345\_1-16

Mon 05/14/2018 to Fri 05/18/2018

0700 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

OSWEGO EXPORT 4850 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

## WETHSRFD-MEYER\_\_\_\_230\_85/87

Tue 05/15/2018 to Fri 06/01/2018

0700 Continuous 1500

Work scheduled by: NYSEG

FWD

(Import)

DYSINGER EAST 2850 MW

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

## MARCY\_\_\_\_765\_345\_AT2

Mon 05/21/2018 to Fri 05/25/2018

0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

MOSES SOUTH 1700 MW

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

## FRASANNX-COOPERS\_\_\_\_345\_UCC2-41

Mon 05/21/2018 to Fri 06/01/2018

0600 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC 2500 MW

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

## MARCY\_\_\_\_-FRASANNX\_345\_UCC2-41

Mon 05/21/2018 to Fri 06/01/2018

0600 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

CENTRAL EAST - VC 2500 MW

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**MOSES\_\_\_-ADIRNDCK\_230\_MAI**

FWD

Mon 05/28/2018 to Fri 06/01/2018

(Import)

0700 Continuous 1730

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

---

**STLAWRNC-MOSES\_\_\_230\_L33P**

FWD

REV

Mon 05/28/2018 to Fri 06/01/2018

(Import) (Export)

0700 Continuous 2000

SCH - OH - NY

**2000 MW 1600 MW**

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 2000 MW 1600 MW

Work scheduled by: NYPA

---

**MARCY\_SO\_SERIES\_COMP\_I/S**

FWD

Fri 06/01/2018 to Wed 10/31/2018

(Import)

1800 Continuous 2359

CENTRAL EAST - VC

**2740 MW**

Impacts Total Transfer Capability 235 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYISO

---

**MARCY\_\_\_765\_345\_AT1**

FWD

Sat 08/04/2018 to Sun 08/05/2018

(Import)

0500 Continuous 1730

MOSES SOUTH

**1750 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

ARR: 19

---

**MARCY\_\_\_765\_345\_AT2**

FWD

Tue 09/04/2018 to Sun 09/09/2018

(Import)

0500 Continuous 1730

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

ARR: 19

---

**FRASER\_-GILBOA\_\_\_345\_GF5-35**

FWD

Mon 09/10/2018 to Fri 10/05/2018

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

---

**ROSETON\_-ROCKTVRN\_345\_311**

FWD

Mon 09/10/2018 to Fri 09/28/2018

(Import)

0800 Continuous 1600

UPNY CONED

**4400 MW**

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: CHGE

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 16, 2018 to Thursday ,July 18, 2019

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 5100MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MARCY\_\_\_\_345KV\_CSC

Tue 09/11/2018 to Tue 09/11/2018  
 0500 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2925 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 2975 MW

## MARCY\_\_\_\_345KV\_CSC & MARCY\_SO\_SERIES\_COMP\_I/S

Tue 09/11/2018 to Tue 09/11/2018  
 0500 1730

Work scheduled by:

FWD  
 (Import)  
 CENTRAL EAST - VC **2690 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 2975 MW

## MARCY\_\_\_\_765\_345\_AT2

Tue 09/11/2018 to Tue 09/11/2018  
 0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
 (Import)  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

## NIAGARA\_\_345\_230\_AT4

Fri 09/14/2018 to Fri 09/14/2018  
 0500 Continuous 1700

Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
 SCH - OH - NY **2000 MW 1400 MW**  
 Impacts Total Transfer Capability 0 MW 200 MW  
 TTC with All Lines In Service 2000 MW 1600 MW

## NIAGARA\_-ROCHESTR\_345\_NR2

Mon 09/17/2018 to Fri 09/21/2018  
 0500 Continuous 1700

Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MAI

Mon 09/17/2018 to Fri 09/21/2018  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MAI

Mon 09/24/2018 to Fri 09/28/2018  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 16, 2018 to Thursday ,July 18, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**CLAY\_\_\_\_-EDIC\_\_\_\_345\_2-15**

Mon 09/24/2018 to Fri 09/28/2018

0700 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

---

**BECK\_\_\_\_-NIAGARA\_\_345\_PA302**

Mon 10/01/2018 to Fri 10/05/2018

0500 Continuous 1700

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **900 MW 800 MW**  
Impacts Total Transfer Capability 1100 MW 800 MW  
TTC with All Lines In Service 2000 MW 1600 MW

---

**MOSES\_\_\_\_-ADIRNDCK\_230\_MA2**

Mon 10/01/2018 to Wed 10/03/2018

0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

---

**PANNELL\_-CLAY\_\_\_\_345\_1**

Mon 10/01/2018 to Fri 10/05/2018

0700 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

---

**MARCY\_\_\_\_765\_345\_AT2**

Thu 10/04/2018 to Fri 10/05/2018

0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

---

**MOSES\_\_\_\_-ADIRNDCK\_230\_MA1**

Mon 10/08/2018 to Fri 10/12/2018

0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

---

**CHATGUAY-MASSENA\_\_765\_7040**

Sat 10/13/2018 to Sat 10/27/2018

0100 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 16, 2018 to Thursday ,July 18, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHATGUAY-MASSENA__765_7040</b>				FWD	REV
Sat 10/13/2018	to	Sat 10/27/2018		(Import)	(Export)
0100	Continuous	1730		SCH - HQ - NY	<b>0 MW</b> <b>0 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1500 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
<b>MARCY__765_345_AT1</b>				FWD	
Sat 10/13/2018	to	Sat 10/27/2018		(Import)	
0100	Continuous	1730		MOSES SOUTH	<b>1750 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1400 MW
<b>ARR: 19</b>				TTC with All Lines In Service	3150 MW
<b>MARCY__765_345_AT2</b>				FWD	
Sat 10/13/2018	to	Sat 10/27/2018		(Import)	
0100	Continuous	1730		MOSES SOUTH	<b>1700 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1450 MW
<b>ARR: 19</b>				TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY__765_MSU1</b>				FWD	
Sat 10/13/2018	to	Sat 10/27/2018		(Import)	
0100	Continuous	1730		CENTRAL EAST - VC	<b>2265 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	710 MW
				TTC with All Lines In Service	2975 MW
<b>MASSENA_-MARCY__765_MSU1</b>				FWD	
Sat 10/13/2018	to	Sat 10/27/2018		(Import)	
0100	Continuous	1730		MOSES SOUTH	<b>500 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY__765_MSU1</b>				FWD	REV
Sat 10/13/2018	to	Sat 10/27/2018		(Import)	(Export)
0100	Continuous	1730		SCH - HQ - NY	<b>475 MW</b> <b>1000 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1025 MW 0 MW
				TTC with All Lines In Service	1500 MW 1000 MW
<b>MASSENA_-MARCY__765_MSU1 &amp; CHATGUAY-MASSENA__765_7040</b>				FWD	
Sat 10/13/2018	to	Sat 10/27/2018		(Import)	
0100		1730		MOSES SOUTH	<b>500 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW

**CENTRAL EAST**      **3100MW**  
**CENTRAL EAST - VC**      **2975MW**  
**TOTAL EAST**      **6500MW**  
**UPNY CONED**      **5100MW**  
**SPR/DUN-SOUTH**      **4600MW**  
**DYSINGER EAST**      **3150MW**  
**MOSES SOUTH**      **3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MASSENA\_-MARCY\_ 765\_MSU1 & MARCY\_SO\_SERIES\_COMP\_I/S**

Sat 10/13/2018      to      Sat 10/27/2018  
0100      1730

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC      **2080 MW**  
Impacts Total Transfer Capability 895 MW  
TTC with All Lines In Service 2975 MW

**MOSES\_-MASSENA\_ 230\_MMS1 & MOSES\_-MASSENA\_ 230\_MMS2**

Sat 10/13/2018      to      Sat 10/27/2018  
0100      1730

Work scheduled by:

FWD      REV  
(Import) (Export)  
SCH - HQ - NY      **850 MW**      **0 MW**  
Impacts Total Transfer Capability 650 MW      1000 MW  
TTC with All Lines In Service 1500 MW      1000 MW

**LEEDS\_-HURLYAVE\_ 345\_301**

Mon 10/22/2018      to      Fri 11/16/2018  
0800      Continuous      1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED      **4100 MW**  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 5100 MW

**KINTIGH\_-ROCHESTR\_ 345\_SR1-39**

Mon 10/29/2018      to      Fri 11/02/2018  
0500      Continuous      1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST      **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**MOSES\_-ADIRNDCK\_ 230\_MAI**

Mon 10/29/2018      to      Fri 11/02/2018  
0700      Continuous      1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH      **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**MOSES\_-ADIRNDCK\_ 230\_MAI**

Mon 11/05/2018      to      Fri 11/09/2018  
0700      Continuous      1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH      **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**MARCY\_ 345KV\_CSC**

Fri 11/16/2018      to      Sat 11/17/2018  
0500      Continuous      1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC      **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 16, 2018 to Thursday ,July 18, 2019

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**MARCY\_\_\_765\_345\_AT2**

FWD

Fri 11/16/2018 to Sat 11/17/2018

(Import)

0500 Continuous 1730

MOSES SOUTH

**1700 MW**

Work scheduled by: NYPA

**ARR: 19**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Mon 11/19/2018 to Wed 11/21/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 11/26/2018 to Fri 11/30/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

---

**HURLYAVE-ROSETON\_\_\_345\_303**

FWD

Mon 11/26/2018 to Fri 12/21/2018

(Import)

0800 Continuous 1600

UPNY CONED

**4100 MW**

Work scheduled by: CHGE

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 5100 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 12/03/2018 to Fri 12/07/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 12/10/2018 to Fri 12/14/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

---

**MARCY\_\_\_765\_345\_AT2**

FWD

Mon 12/17/2018 to Fri 12/21/2018

(Import)

0500 Continuous 1730

MOSES SOUTH

**1700 MW**

Work scheduled by: NYPA

**ARR: 19**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 16, 2018 to Thursday ,July 18, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES\_\_\_\_-ADIRNDCK\_230\_Ma1

FWD

Wed 12/26/2018 to Fri 12/28/2018

( Import )

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA