

**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 23, 2018 to Thursday ,July 25, 2019

**CENTRAL EAST** 3100MW  
**CENTRAL EAST - VC** 2975MW  
**TOTAL EAST** 6500MW  
**UPNY CONED** 5100MW  
**SPR/DUN-SOUTH** 4600MW  
**DYSINGER EAST** 3150MW  
**MOSES SOUTH** 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**E13THSTA-FARRAGUT\_345\_45**

Sun 11/26/2017 to Tue 05/15/2018  
 0001 Continuous 2359

UPDATEDby CE01/03/2018

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**W49TH\_ST-E13THSTA\_345\_M54**

Sun 11/26/2017 to Tue 05/15/2018  
 0001 Continuous 2359

UPDATEDby CE01/03/2018

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**S.RIPLEY-DUNKIRK\_230\_68**

Fri 12/15/2017 to Mon 04/30/2018  
 1400 Continuous 0959

UPDATEDby NYISO01/22/2018

Work scheduled by: NYISO

FWD

REV

(Import) (Export)

SCH - PJ - NY

**2600 MW 1300 MW**

Impacts Total Transfer Capability 150 MW 0 MW

TTC with All Lines In Service 2750 MW 1300 MW

**CHAT\_DC\_GC2**

Tue 12/19/2017 to Thu 02/08/2018  
 2257 Continuous 2359

UPDATEDby HQ01/17/2018

Work scheduled by: HQ

FWD

(Import)

MOSES SOUTH

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC2**

Tue 12/19/2017 to Thu 02/08/2018  
 2257 Continuous 2359

UPDATEDby HQ01/17/2018

Work scheduled by: HQ

REV

(Export)

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

**HUDSONP\_-FARRAGUT\_345\_B3402**

Mon 01/15/2018 to Thu 02/15/2018  
 0001 Continuous 2359

UPDATEDby CE01/17/2018

Work scheduled by: ConEd

FWD

REV

(Import) (Export)

SCH - PJ - NY

**2600 MW 1300 MW**

Impacts Total Transfer Capability 150 MW 0 MW

TTC with All Lines In Service 2750 MW 1300 MW

**HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403**

Mon 01/15/2018 to Thu 02/15/2018  
 0001 2359

Work scheduled by:

FWD

REV

(Import) (Export)

SCH - PJ - NY

**2000 MW 1300 MW**

Impacts Total Transfer Capability 750 MW 0 MW

TTC with All Lines In Service 2750 MW 1300 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 23, 2018 to Thursday ,July 25, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARION\_\_-FARRAGUT\_345\_C3403**

Mon 01/15/2018 to Thu 02/15/2018  
 0001 Continuous 2359

**UPDATED****by CE****01/17/2018**

Work scheduled by: ConEd

FWD REV  
 (Import) (Export)  
 SCH - PJ - NY **2600 MW 1300 MW**  
 Impacts Total Transfer Capability 150 MW 0 MW  
 TTC with All Lines In Service 2750 MW 1300 MW

**SCH-HQ-NYISO\_LIMIT\_1200**

Tue 01/16/2018 to Thu 02/08/2018  
 0001 Continuous 2359

**UPDATED****by HQ****01/17/2018**

Work scheduled by: HQ

FWD  
 (Import)  
 SCH - HQ - NY **1200 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 1500 MW

**EASTVIEW-SPRNBK\_\_345\_W64**

Tue 01/16/2018 to Mon 02/19/2018  
 0001 Continuous 0100

**UPDATED****by CE****12/13/2017**

Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 750 MW  
 TTC with All Lines In Service 5100 MW

**MILLWOOD-EASTVIEW\_345\_W99**

Tue 01/16/2018 to Mon 02/19/2018  
 0001 Continuous 0100

**UPDATED****by CE****12/13/2017**

Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 750 MW  
 TTC with All Lines In Service 5100 MW

**SPRNBK\_\_345KV\_RNS5**

Tue 01/16/2018 to Mon 02/19/2018  
 0001 Continuous 0100

**UPDATED****by CE****12/13/2017**

Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Tue 01/16/2018 to Fri 01/19/2018  
 0700 Continuous 1530

**UPDATED****by NYPA****01/10/2018**

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**FRASER\_\_-GILBOA\_\_345\_GF5-35**

Wed 01/17/2018 to Thu 01/18/2018  
 0700 Continuous 1730

**EXTENDED****by NYPA****01/17/2018**

Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 23, 2018 to Thursday ,July 25, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>N.SCTLND-ALPS_____345_2</b>							
Wed 01/17/2018	to	Wed 02/14/2018	<b><u>EXTENDED</u></b>	<b><u>by NGRID</u></b>	<b><u>01/23/2018</u></b>		
0800	Continuous	1300				SCH - NE - NY	<b>900 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	500 MW
						TTC with All Lines In Service	1400 MW
<b>N.SCTLND-ALPS_____345_2</b>							
Wed 01/17/2018	to	Wed 02/14/2018	<b><u>EXTENDED</u></b>	<b><u>by NGRID</u></b>	<b><u>01/23/2018</u></b>		
0800	Continuous	1300				SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
<b>SCH-NE-NYISO_LIMIT_400</b>						FWD	
Wed 01/17/2018	to	Wed 02/14/2018	<b><u>EXTENDED</u></b>	<b><u>by NGRID</u></b>	<b><u>01/23/2018</u></b>	(Import)	
0800	Continuous	1300				SCH - NE - NY	<b>600 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_600</b>							REV
Wed 01/17/2018	to	Wed 02/14/2018	<b><u>EXTENDED</u></b>	<b><u>by NGRID</u></b>	<b><u>01/23/2018</u></b>		(Export)
0800	Continuous	1300				SCH - NE - NY	<b>800 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	1600 MW
<b>PLSNTVLY-EFISHKIL_345_F37</b>						FWD	
Fri 01/19/2018	to	Sat 01/20/2018	<b><u>UPDATED</u></b>	<b><u>by CONED</u></b>	<b><u>01/12/2018</u></b>	(Import)	
0001	Continuous	0200				UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	1100 MW
						TTC with All Lines In Service	5100 MW
<b>DUNWODIE_345KV_4</b>						FWD	
Fri 01/19/2018	to	Sat 01/20/2018	<b><u>UPDATED</u></b>	<b><u>by CONED</u></b>	<b><u>01/20/2018</u></b>	(Import)	
0200	Continuous	0147				SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_6</b>						FWD	
Fri 01/19/2018	to	Sat 01/20/2018	<b><u>UPDATED</u></b>	<b><u>by CONED</u></b>	<b><u>01/20/2018</u></b>	(Import)	
0200	Continuous	0147				SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 23, 2018 to Thursday ,July 25, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE-SHORE\_RD\_345\_Y50**

FWD

Fri 01/19/2018 to Tue 01/23/2018 **UPDATED** **by CONED** **01/20/2018**

(Import)

0200 Continuous 2359

CONED - LIPA

**800 MW**

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: ConEd

**SHORE\_RD\_345\_138\_BK 1**

FWD

Fri 01/19/2018 to Tue 01/23/2018 **UPDATED** **by CONED** **01/20/2018**

(Import)

0200 Continuous 2359

CONED - LIPA

**1350 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: ConEd

**SHORE\_RD\_345\_138\_BK 2**

FWD

Fri 01/19/2018 to Tue 01/23/2018 **UPDATED** **by CONED** **01/20/2018**

(Import)

0200 Continuous 2359

CONED - LIPA

**1350 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: ConEd

**HURLYAVE-ROSETON\_\_345\_303**

FWD

Fri 01/19/2018 to Sat 01/20/2018 **UPDATED** **by CHGE** **01/04/2018**

(Import)

0800 Continuous 1600

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: CHGE

**SCH-NYISO-PJM\_LIMIT\_100**

REV

Sat 01/20/2018 to Sat 01/20/2018 **UPDATED** **by PJM** **01/19/2018**

(Export)

0700 Continuous 1600

SCH - PJ - NY

**400 MW**

Impacts Total Transfer Capability 900 MW

TTC with All Lines In Service 1300 MW

Work scheduled by: PJM

**MOSES\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 01/22/2018 to Fri 01/26/2018 **UPDATED** **by NYPA** **01/15/2018**

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**FRASER\_\_-COOPERS\_\_345\_33**

FWD

Mon 01/22/2018 to Thu 01/25/2018 **UPDATED** **by NYSEG** **01/22/2018**

(Import)

0800 Continuous 1500

CENTRAL EAST - VC

**2395 MW**

Impacts Total Transfer Capability 580 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 23, 2018 to Thursday ,July 25, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-IMO-NYISO\_LIMIT\_1250**

FWD

Tue 01/23/2018 to Wed 01/24/2018 **UPDATED** **by NYISO** **01/09/2018**

(Import)

0700 Continuous 1700

SCH - OH - NY

**1550 MW**

Impacts Total Transfer Capability 200 MW

TTC with All Lines In Service 1750 MW

Work scheduled by: NGrid

**DUNWODIE\_345KV\_4**

FWD

Tue 01/23/2018 to Tue 01/23/2018 **UPDATED** **by CONED** **01/20/2018**

(Import)

2330 Continuous 2359

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**DUNWODIE\_345KV\_6**

FWD

Tue 01/23/2018 to Tue 01/23/2018 **UPDATED** **by CONED** **01/20/2018**

(Import)

2330 Continuous 2359

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**SCH-NYISO-NE\_LIMIT\_1300**

REV

Wed 01/24/2018 to Fri 01/26/2018

(Export)

0600 Daily 1700

SCH - NE - NY

**1500 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 1600 MW

Work scheduled by: ISONE

**MOSES\_\_-ADIRNDCK\_230\_MAI**

FWD

Mon 01/29/2018 to Fri 02/02/2018 **UPDATED** **by NYPA** **01/19/2018**

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**HURLYAVE-ROSETON\_\_345\_303**

FWD

Thu 02/01/2018 to Fri 02/02/2018 **UPDATED** **by CH** **01/23/2018**

(Import)

0700 Continuous 1600

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: CHGE

**MARCY\_\_\_\_765\_345\_AT2**

FWD

Sat 02/03/2018 to Sat 02/03/2018 **UPDATED** **by NYPA** **01/02/2018**

(Import)

0500 Continuous 1730

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19**

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 23, 2018 to Thursday ,July 25, 2019

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 02/05/2018 to Fri 02/09/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 02/05/2018 to Fri 02/09/2018  
0700 Continuous 1530

Work scheduled by: NYPA

CANCELLED by NYPA 01/19/2018

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 02/12/2018 to Fri 02/16/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### HUDSONP\_-FARRAGUT\_345\_B3402

Sun 02/18/2018 to Sun 04/01/2018  
0001 Continuous 2359

Work scheduled by: PJM

UPDATED by PJM 12/13/2017

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2600 MW 1300 MW**  
Impacts Total Transfer Capability 150 MW 0 MW  
TTC with All Lines In Service 2750 MW 1300 MW

### EASTVIEW-SPRNBK\_345\_W78

Tue 02/20/2018 to Wed 02/21/2018  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

### MILLWOOD-EASTVIEW\_345\_W85

Tue 02/20/2018 to Wed 02/21/2018  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

### SPRNBK\_345KV\_RNS3

Tue 02/20/2018 to Wed 02/21/2018  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 23, 2018 to Thursday ,July 25, 2019

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_\_-EDIC\_\_\_\_\_345\_UE1-7

Tue 02/20/2018 to Fri 02/23/2018  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19&16

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

### MOSES\_\_\_-ADIRNDCK\_230\_MAI

Tue 02/20/2018 to Fri 02/23/2018  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### N.SCTLND-LEEDS\_\_\_\_\_345\_93

Wed 02/21/2018 to Wed 02/21/2018  
0800 Daily(No Weekends) 1500

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

### DUNWODIE\_345KV\_7

Sat 02/24/2018 to Sat 02/24/2018  
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CE 09/22/2017

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### DUNWODIE\_345KV\_8

Sat 02/24/2018 to Sat 02/24/2018  
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CE 09/22/2017

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### DUNWODIE-MOTTHAVN\_345\_72

Sat 02/24/2018 to Sat 03/31/2018  
0001 Continuous 0300

Work scheduled by: ConEd

UPDATED by CE 09/22/2017

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### LONG\_MTN-PLSNTVLY\_345\_398

Sun 02/25/2018 to Sun 02/25/2018  
0001 Continuous 2359

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	<b>700 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	700 MW	300 MW
TTC with All Lines In Service	1400 MW	1600 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 23, 2018 to Thursday ,July 25, 2019

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LONG\_MTN-PLSNTVLY\_345\_398

Sun 02/25/2018 to Sun 02/25/2018

0001 Continuous 2359

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

### EGRDNCTY\_345\_138\_AT1

Sun 02/25/2018 to Thu 03/01/2018

0001 Continuous 2359

Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	1250 MW
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	1500 MW

### EGRDNCTY\_345\_138\_AT2

Sun 02/25/2018 to Thu 03/01/2018

0001 Continuous 2359

Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	1250 MW
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	1500 MW

### SPRNBRK\_-EGRDNCTR\_345\_Y49

Sun 02/25/2018 to Thu 03/01/2018

0001 Continuous 2359

Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	775 MW
Impacts Total Transfer Capability	725 MW
TTC with All Lines In Service	1500 MW

### LONG\_MTN-PLSNTVLY\_345\_398

Mon 02/26/2018 to Wed 05/02/2018

0001 Continuous 0300

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	700 MW	1300 MW
Impacts Total Transfer Capability	700 MW	300 MW
TTC with All Lines In Service	1400 MW	1600 MW

### LONG\_MTN-PLSNTVLY\_345\_398

Mon 02/26/2018 to Wed 05/02/2018

0001 Continuous 0300

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

### MOSES\_-ADIRNDCK\_230\_MAI

Mon 02/26/2018 to Fri 03/02/2018

0700 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW



# NYISO TRANSFER LIMITATIONS

Tuesday ,January 23, 2018 to Thursday ,July 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 03/05/2018 to Fri 03/09/2018  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## MARCY\_\_\_-N.SCTLND\_345\_18

Tue 03/06/2018 to Wed 03/07/2018  
0600 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2090 MW**  
Impacts Total Transfer Capability 885 MW  
TTC with All Lines In Service 2975 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 03/12/2018 to Fri 03/16/2018  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

Mon 03/19/2018 to Mon 03/19/2018  
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 01/17/2018

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

## EASTVIEW-SPRNBK\_345\_W79

Mon 03/19/2018 to Mon 03/19/2018  
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 01/17/2018

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

## RAMAPO\_\_\_-BUCHAN\_N\_345\_Y94

Mon 03/19/2018 to Fri 03/30/2018  
0001 Continuous 0100

Work scheduled by: ConEd

UPDATED by CONED 01/17/2018

FWD  
(Import)  
UPNY CONED **4800 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 5100 MW

## W49TH\_ST\_345KV\_6

Mon 03/19/2018 to Tue 03/20/2018  
0200 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 01/02/2018

FWD  
(Import)  
SCH - PJM\_HTP **350 MW**  
Impacts Total Transfer Capability 310 MW  
TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 23, 2018 to Thursday ,July 25, 2019

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_8

FWD

Mon 03/19/2018 to Tue 03/20/2018 UPDATED by CONED 01/02/2018  
0200 Continuous 0200

Work scheduled by: ConEd

SCH - PJM\_HTP **350 MW**  
Impacts Total Transfer Capability 310 MW  
TTC with All Lines In Service 660 MW

(Import)

### W49TH\_ST\_345KV\_6

FWD

Wed 03/21/2018 to Wed 03/21/2018 UPDATED by CONED 01/02/2018  
0100 Continuous 0200

Work scheduled by: ConEd

SCH - PJM\_HTP **350 MW**  
Impacts Total Transfer Capability 310 MW  
TTC with All Lines In Service 660 MW

(Import)

### W49TH\_ST\_345KV\_8

FWD

Wed 03/21/2018 to Wed 03/21/2018 UPDATED by CONED 01/02/2018  
0100 Continuous 0200

Work scheduled by: ConEd

SCH - PJM\_HTP **350 MW**  
Impacts Total Transfer Capability 310 MW  
TTC with All Lines In Service 660 MW

(Import)

### MARCY\_\_\_345KV\_CSC

FWD

Mon 03/26/2018 to Fri 04/13/2018  
0500 Continuous 1730

Work scheduled by: NYPA

CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

(Import)

### MOSES\_\_\_-ADIRNDCK\_230\_MA2

FWD

Mon 03/26/2018 to Thu 03/29/2018  
0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

(Import)

### BUCHAN\_N-EASTVIEW\_345\_W93

FWD

Fri 03/30/2018 to Fri 03/30/2018 UPDATED by CONED 01/17/2018  
0030 Continuous 0100

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

(Import)

### EASTVIEW-SPRNBK\_\_\_345\_W79

FWD

Fri 03/30/2018 to Fri 03/30/2018 UPDATED by CONED 01/17/2018  
0030 Continuous 0100

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

(Import)

**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 23, 2018 to Thursday ,July 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_7**

Sat 03/31/2018 to Sat 03/31/2018 **UPDATED** **by CE** **09/22/2017**  
0230 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
**3800 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_8**

Sat 03/31/2018 to Sat 03/31/2018 **UPDATED** **by CE** **09/22/2017**  
0230 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
**3800 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**MOSES\_\_-ADIRNDCK\_230\_MAl**

Mon 04/02/2018 to Fri 04/06/2018  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
**2300 MW**  
MOSES SOUTH  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**MALONE\_\_-WILLIS\_\_115\_1-910**

Tue 04/03/2018 to Tue 04/03/2018 **UPDATED** **by NYPA** **11/20/2017**  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 38**

REV  
(Export)  
**60 MW**  
SCH - HQ\_CEDARS  
Impacts Total Transfer Capability 40 MW  
TTC with All Lines In Service 100 MW

**SHOR\_NPX-SHOREHAM\_138\_CSC**

Wed 04/04/2018 to Thu 04/12/2018 **UPDATED** **by LI** **11/08/2017**  
0600 Continuous 1800

Work scheduled by: LI

FWD REV  
(Import) (Export)  
**0 MW 0 MW**  
SCH - NPX\_CSC  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

**LINDN\_CG-LNDVFT\_\_345\_V-3022**

Sun 04/08/2018 to Fri 04/13/2018  
1400 Continuous 1800

Work scheduled by: PJM

FWD REV  
(Import) (Export)  
**0 MW 0 MW**  
SCH - PJM\_VFT  
Impacts Total Transfer Capability 315 MW 315 MW  
TTC with All Lines In Service 315 MW 315 MW

**BECK\_\_-NIAGARA\_\_345\_PA302**

Mon 04/09/2018 to Fri 04/13/2018 **CANCELLED** **by NYISO** **01/18/2018**  
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
**1100 MW 950 MW**  
SCH - OH - NY  
Impacts Total Transfer Capability 650 MW 950 MW  
TTC with All Lines In Service 1750 MW 1900 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 23, 2018 to Thursday ,July 25, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BECK\_\_\_-NIAGARA\_\_\_345\_PA302**

Mon 04/09/2018 to Fri 04/13/2018  
 0500 Continuous 1700

**UPDATED by NYPA 01/22/2018**

Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
 SCH - OH - NY **1100 MW 950 MW**  
 Impacts Total Transfer Capability 650 MW 950 MW  
 TTC with All Lines In Service 1750 MW 1900 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MAI**

Mon 04/09/2018 to Fri 04/13/2018  
 0700 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**FRASER\_\_\_-GILBOA\_\_\_345\_GF5-35**

Mon 04/09/2018 to Fri 04/20/2018  
 0700 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

Wed 04/11/2018 to Thu 04/12/2018  
 0001 Continuous 0130

**UPDATED by CONED 01/17/2018**

Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 750 MW  
 TTC with All Lines In Service 5100 MW

**EASTVIEW-SPRNBK\_\_\_345\_W79**

Wed 04/11/2018 to Thu 04/12/2018  
 0001 Continuous 0130

**UPDATED by CONED 01/17/2018**

Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 750 MW  
 TTC with All Lines In Service 5100 MW

**RAMAPO\_\_\_-BUCHAN\_N\_345\_Y94**

Wed 04/11/2018 to Thu 04/12/2018  
 0001 Continuous 0130

**UPDATED by CONED 01/17/2018**

Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4800 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 5100 MW

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Mon 04/16/2018 to Tue 05/01/2018  
 0001 Continuous 1800

Work scheduled by: PJM

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NEWBRDGE-DUFFYAVE\_345\_501

Mon 04/16/2018 to Tue 05/01/2018

0001 Continuous 1800

Work scheduled by: PJM

FWD

(Import)

SCH - PJM\_NEPTUNE

0 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

## NEWBRDGE\_345\_138\_BK\_1

Mon 04/16/2018 to Tue 05/01/2018

0001 Continuous 1800

Work scheduled by: PJM

FWD

(Import)

SCH - PJM\_NEPTUNE

375 MW

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

## NEWBRDGE\_345\_138\_BK\_2

Mon 04/16/2018 to Tue 05/01/2018

0001 Continuous 1800

Work scheduled by: PJM

FWD

(Import)

SCH - PJM\_NEPTUNE

375 MW

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

## MOSES-ADIRNDCK\_230\_MA1

Mon 04/16/2018 to Fri 04/20/2018

0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

Sat 04/21/2018 to Sat 04/21/2018

0130 Continuous 0200

Work scheduled by: ConEd

UPDATEDby CONED 01/17/2018

FWD

(Import)

UPNY CONED

4350 MW

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

## EASTVIEW-SPRNBK\_345\_W79

Sat 04/21/2018 to Sat 04/21/2018

0130 Continuous 0200

Work scheduled by: ConEd

UPDATEDby CONED 01/17/2018

FWD

(Import)

UPNY CONED

4350 MW

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

## MARCY\_765\_345\_AT1

Mon 04/23/2018 to Mon 04/23/2018

0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

1750 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

ARR: 19

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 04/30/2018 to Fri 05/04/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## MARCY\_SO\_SERIES\_COMP\_I/S

Tue 05/01/2018 to Mon 05/21/2018  
0001 Continuous 0559

Work scheduled by: NYISO

FWD  
(Import)  
CENTRAL EAST - VC **2740 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 2975 MW

## S.RIPLEY-DUNKIRK\_\_230\_68

Tue 05/01/2018 to Sat 06/02/2018 UPDATED by PJM 01/22/2018  
1000 Continuous 1600

Work scheduled by: PJM

FWD REV  
(Import) (Export)  
SCH - PJ - NY **1950 MW 1350 MW**  
Impacts Total Transfer Capability 150 MW 0 MW  
TTC with All Lines In Service 2100 MW 1350 MW

## SCH-NYISO-NE\_LIMIT\_800

Sun 05/06/2018 to Sun 05/06/2018  
0600 Continuous 1900

Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1600 MW

## NIAGARA\_-KINTIGH\_\_345\_NS1-38

Mon 05/07/2018 to Fri 05/11/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 05/07/2018 to Fri 05/11/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 05/14/2018 to Fri 05/18/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,January 23, 2018 to Thursday ,July 25, 2019

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CLAY -EDIC 345\_1-16**

Mon 05/14/2018 to Fri 05/18/2018  
 0700 Continuous 1700

Work scheduled by: NYPA

FWD  
 (Import)  
 OSWEGO EXPORT **4850 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 5250 MW

**ERIE E -S.RIPLEY 230\_69 & WETHSRFD-MEYER 230\_85/87**

Tue 05/15/2018 to Fri 06/01/2018  
 0700 1500

Work scheduled by:

FWD  
 (Import)  
 DYSINGER EAST **2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

**WETHSRFD-MEYER 230\_85/87**

Tue 05/15/2018 to Fri 06/01/2018  
 0700 Continuous 1500

Work scheduled by: NYSEG

FWD  
 (Import)  
 DYSINGER EAST **2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

**MARCY 765\_345\_AT2**

Mon 05/21/2018 to Fri 05/25/2018  
 0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

**FRASANNX-COOPERS 345\_UCC2-41**

Mon 05/21/2018 to Fri 06/01/2018  
 0600 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

**MARCY -FRASANNX 345\_UCC2-41**

Mon 05/21/2018 to Fri 06/01/2018  
 0600 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

**MOSES -ADIRNDCK 230\_MAI**

Mon 05/28/2018 to Fri 06/01/2018  
 0700 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES___230_L33P				FWD	REV
Mon 05/28/2018	to	Fri 06/01/2018		(Import)	(Export)
0700	Continuous	2000		SCH - OH - NY	2000 MW 1600 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	0 MW 0 MW
				TTC with All Lines In Service	2000 MW 1600 MW
MARCY_SO_SERIES_COMP_I/S				FWD	
Fri 06/01/2018	to	Wed 10/31/2018		(Import)	
1800	Continuous	2359		CENTRAL EAST - VC	2740 MW
Work scheduled by: NYISO				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	2975 MW
S.RIPLEY-DUNKIRK___230_68				FWD	REV
Sat 06/02/2018	to	Sat 02/01/2020	<u>UPDATED</u> <u>by NYISO</u> <u>01/22/2018</u>	(Import)	(Export)
1600	Continuous	0000		SCH - PJ - NY	1950 MW 1350 MW
Work scheduled by: NYISO				Impacts Total Transfer Capability	150 MW 0 MW
				TTC with All Lines In Service	2100 MW 1350 MW
MARCY___765_345_AT1				FWD	
Sat 08/04/2018	to	Sun 08/05/2018		(Import)	
0500	Continuous	1730		MOSES SOUTH	1750 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	3150 MW
MARCY___765_345_AT2				FWD	
Tue 09/04/2018	to	Sun 09/09/2018		(Import)	
0500	Continuous	1730		MOSES SOUTH	1700 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
FRASER___-GILBOA___345_GF5-35				FWD	
Mon 09/10/2018	to	Fri 10/05/2018		(Import)	
0700	Continuous	1730		CENTRAL EAST - VC	2650 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	325 MW
				TTC with All Lines In Service	2975 MW
ROSETON_-ROCKTVRN_345_311				FWD	
Mon 09/10/2018	to	Fri 09/28/2018		(Import)	
0800	Continuous	1600		UPNY CONED	4400 MW
Work scheduled by: CHGE				Impacts Total Transfer Capability	700 MW
				TTC with All Lines In Service	5100 MW



# NYISO TRANSFER LIMITATIONS

Tuesday ,January 23, 2018 to Thursday ,July 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MARCY\_\_\_\_345KV\_CSC

Tue 09/11/2018 to Tue 09/11/2018  
0500 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

## MARCY\_\_\_\_345KV\_CSC & MARCY\_SO\_SERIES\_COMP\_I/S

Tue 09/11/2018 to Tue 09/11/2018  
0500 1730

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **2690 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 2975 MW

## MARCY\_\_\_\_765\_345\_AT2

Tue 09/11/2018 to Tue 09/11/2018  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## NIAGARA\_\_345\_230\_AT4

Fri 09/14/2018 to Fri 09/14/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **2000 MW 1400 MW**  
Impacts Total Transfer Capability 0 MW 200 MW  
TTC with All Lines In Service 2000 MW 1600 MW

## NIAGARA\_-ROCHESTR\_345\_NR2

Mon 09/17/2018 to Fri 09/21/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MAI

Mon 09/17/2018 to Fri 09/21/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MAI

Mon 09/24/2018 to Fri 09/28/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 23, 2018 to Thursday ,July 25, 2019

## Seasonal Limits

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CLAY\_\_\_\_-EDIC\_\_\_\_345\_2-15

Mon 09/24/2018 to Fri 09/28/2018  
0700 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

### BECK\_\_\_\_-NIAGARA\_\_345\_PA302

Mon 10/01/2018 to Fri 10/05/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **900 MW 800 MW**  
Impacts Total Transfer Capability 1100 MW 800 MW  
TTC with All Lines In Service 2000 MW 1600 MW

### MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 10/01/2018 to Wed 10/03/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

### PANNELL\_-CLAY\_\_\_\_345\_1

Mon 10/01/2018 to Fri 10/05/2018  
0700 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

### MARCY\_\_\_\_765\_345\_AT2

Thu 10/04/2018 to Fri 10/05/2018  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

### MOSES\_\_\_\_-ADIRNDCK\_230\_MA1

Mon 10/08/2018 to Fri 10/12/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

### CHATGUAY-MASSENA\_\_765\_7040

Sat 10/13/2018 to Sat 10/27/2018  
0100 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 23, 2018 to Thursday ,July 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHATGUAY-MASSENA__765_7040</b>			FWD	REV
Sat 10/13/2018	to	Sat 10/27/2018	(Import)	(Export)
0100	Continuous	1730	SCH - HQ - NY	<b>0 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1500 MW
			TTC with All Lines In Service	1500 MW
<b>MARCY__765_345_AT1</b>			FWD	
Sat 10/13/2018	to	Sat 10/27/2018	(Import)	
0100	Continuous	1730	MOSES SOUTH	<b>1750 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1400 MW
<b>ARR: 19</b>			TTC with All Lines In Service	3150 MW
<b>MARCY__765_345_AT2</b>			FWD	
Sat 10/13/2018	to	Sat 10/27/2018	(Import)	
0100	Continuous	1730	MOSES SOUTH	<b>1700 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW
<b>ARR: 19</b>			TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY__765_MSU1</b>			FWD	
Sat 10/13/2018	to	Sat 10/27/2018	(Import)	
0100	Continuous	1730	CENTRAL EAST - VC	<b>2265 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	710 MW
			TTC with All Lines In Service	2975 MW
<b>MASSENA_-MARCY__765_MSU1</b>			FWD	
Sat 10/13/2018	to	Sat 10/27/2018	(Import)	
0100	Continuous	1730	MOSES SOUTH	<b>500 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY__765_MSU1</b>			FWD	REV
Sat 10/13/2018	to	Sat 10/27/2018	(Import)	(Export)
0100	Continuous	1730	SCH - HQ - NY	<b>475 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1025 MW
			TTC with All Lines In Service	1500 MW
<b>MASSENA_-MARCY__765_MSU1 &amp; CHATGUAY-MASSENA__765_7040</b>			FWD	
Sat 10/13/2018	to	Sat 10/27/2018	(Import)	
0100		1730	MOSES SOUTH	<b>500 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**MASSENA\_-MARCY\_ 765\_MSU1 & MARCY\_SO\_SERIES\_COMP\_I/S**

Sat 10/13/2018 to Sat 10/27/2018  
 0100 1730

Work scheduled by:

FWD  
 (Import)  
**CENTRAL EAST - VC 2080 MW**  
 Impacts Total Transfer Capability 895 MW  
 TTC with All Lines In Service 2975 MW

---

**MOSES\_-MASSENA\_ 230\_MMS1 & MOSES\_-MASSENA\_ 230\_MMS2**

Sat 10/13/2018 to Sat 10/27/2018  
 0100 1730

Work scheduled by:

FWD REV  
 (Import) (Export)  
**SCH - HQ - NY 850 MW 0 MW**  
 Impacts Total Transfer Capability 650 MW 1000 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

---

**LEEDS\_-HURLYAVE\_ 345\_301**

Mon 10/22/2018 to Fri 11/16/2018  
 0800 Continuous 1600

Work scheduled by: CHGE

FWD  
 (Import)  
**UPNY CONED 4100 MW**  
 Impacts Total Transfer Capability 1000 MW  
 TTC with All Lines In Service 5100 MW

---

**KINTIGH\_-ROCHESTR\_ 345\_SR1-39**

Mon 10/29/2018 to Fri 11/02/2018  
 0500 Continuous 1700

Work scheduled by: NYPA

FWD  
 (Import)  
**DYSINGER EAST 1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

---

**MOSES\_-ADIRNDCK\_ 230\_MAI**

Mon 10/29/2018 to Fri 11/02/2018  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

---

**MOSES\_-ADIRNDCK\_ 230\_MAI**

Mon 11/05/2018 to Fri 11/09/2018  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

---

**MARCY\_ 345KV\_CSC**

Fri 11/16/2018 to Sat 11/17/2018  
 0500 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
**CENTRAL EAST - VC 2925 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 2975 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**MARCY\_\_\_765\_345\_AT2**

Fri 11/16/2018 to Sat 11/17/2018  
0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Mon 11/19/2018 to Wed 11/21/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 11/26/2018 to Fri 11/30/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

---

**HURLYAVE-ROSETON\_\_\_345\_303**

Mon 11/26/2018 to Fri 12/21/2018  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 5100 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 12/03/2018 to Fri 12/07/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 12/10/2018 to Fri 12/14/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

---

**MARCY\_\_\_765\_345\_AT2**

Mon 12/17/2018 to Fri 12/21/2018  
0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

---

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 23, 2018 to Thursday ,July 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES\_\_\_\_-ADIRNDCK\_230\_Ma1

FWD

Wed 12/26/2018 to Fri 12/28/2018

( Import )

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA