

# NYISO TRANSFER LIMITATIONS

Friday ,October 12, 2018 to Sunday ,April 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Sun 11/18/2018 EXT FORCE by CE 10/07/2018

0001 Continuous 2359

Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	<b>1950 MW</b>	<b>1200 MW</b>
Impacts Total Transfer Capability	150 MW	100 MW
TTC with All Lines In Service	2100 MW	1300 MW

## HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Sun 11/18/2018

0001 2359

Work scheduled by:

	FWD (Import)	REV (Export)
SCH - PJ - NY	<b>1800 MW</b>	<b>1100 MW</b>
Impacts Total Transfer Capability	300 MW	200 MW
TTC with All Lines In Service	2100 MW	1300 MW

## MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Sun 11/18/2018 EXT FORCE by CE 10/07/2018

0001 Continuous 2359

Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	<b>1950 MW</b>	<b>1200 MW</b>
Impacts Total Transfer Capability	150 MW	100 MW
TTC with All Lines In Service	2100 MW	1300 MW

## STLAWRNC-MOSES\_230\_L33P

Mon 04/30/2018 to Fri 12/31/2021 EXT FORCE by IESO 08/21/2018

0456 Continuous 2359

Work scheduled by: IESO

	FWD (Import)	REV (Export)
SCH - OH - NY	<b>1900 MW</b>	<b>1750 MW</b>
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	1900 MW	1750 MW

## DUNWODIE-MOTTHAVN\_345\_71

Sun 07/01/2018 to Wed 10/10/2018 EXTENDED by CE 10/09/2018

1248 Continuous 0300

Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	<b>3800 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

## S.RIPLEY-DUNKIRK\_230\_68

Thu 08/09/2018 to Fri 10/12/2018 UPDATED by NYISO 10/10/2018

1144 Continuous 0659

Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJ - NY	<b>1950 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	150 MW	0 MW
TTC with All Lines In Service	2100 MW	1300 MW

## SCH-NYISO-HQ\_CEDARS\_LIMIT\_0

Mon 09/10/2018 to Fri 10/12/2018 EXTENDED by HQ 09/20/2018

0800 Continuous 1900

Work scheduled by: HQ

	REV (Export)
SCH - HQ_CEDARS	<b>0 MW</b>
Impacts Total Transfer Capability	40 MW
TTC with All Lines In Service	40 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 12, 2018 to Sunday ,April 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>FRASER_-GILBOA_345_GF5-35</b>						FWD
Tue 09/11/2018	to	Wed 10/10/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/09/2018</u>	(Import)
0700	Continuous	0659				CENTRAL EAST - VC <b>2650 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 325 MW
						TTC with All Lines In Service 2975 MW
<b>ROSETON_-ROCKTVRN_345_311</b>						FWD
Mon 09/17/2018	to	Tue 10/09/2018	<u>UPDATED</u>	<u>by CHGE</u>	<u>09/12/2018</u>	(Import)
0800	Continuous	1600				UPNY CONED <b>4400 MW</b>
Work scheduled by: CHGE						Impacts Total Transfer Capability 1300 MW
						TTC with All Lines In Service 5700 MW
<b>MARCY_765_345_AT2</b>						FWD
Wed 09/19/2018	to	Sat 10/27/2018	<u>EXT FORCE</u>	<u>by NYPA</u>	<u>10/11/2018</u>	(Import)
0001	Continuous	1730				MOSES SOUTH <b>1700 MW</b>
Work scheduled by: NYPA				ARR: 19		Impacts Total Transfer Capability 1450 MW
						TTC with All Lines In Service 3150 MW
<b>SCH-IMO-NYISO_LIMIT_800</b>						FWD
Sun 09/23/2018	to	Sun 10/14/2018				(Import)
2300	Continuous	1900				SCH - OH - NY <b>1100 MW</b>
Work scheduled by: NYISO						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 1900 MW
<b>SCH-NYISO-PJM_LIMIT_100</b>						REV
Fri 10/05/2018	to	Sun 10/07/2018	<u>UPDATED</u>	<u>by PJM</u>	<u>10/04/2018</u>	(Export)
1700	Continuous	2000				SCH - PJ - NY <b>400 MW</b>
Work scheduled by: PJM						Impacts Total Transfer Capability 900 MW
						TTC with All Lines In Service 1300 MW
<b>EGRDNCTY_345_138_AT1</b>						FWD
Sat 10/06/2018	to	Sat 11/03/2018	<u>UPDATED</u>	<u>by CE</u>	<u>10/03/2018</u>	(Import)
0130	Continuous	0300				CONED - LIPA <b>1250 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 1500 MW
<b>EGRDNCTY_345_138_AT2</b>						FWD
Sat 10/06/2018	to	Sat 11/03/2018	<u>UPDATED</u>	<u>by CE</u>	<u>10/03/2018</u>	(Import)
0130	Continuous	0300				CONED - LIPA <b>1250 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 12, 2018 to Sunday ,April 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SPRNBK\_-EGRDNCTR\_345\_Y49

Sat 10/06/2018 to Sat 11/03/2018 UPDATED by CE 10/03/2018  
0130 Continuous 0300

Work scheduled by: LI

FWD  
(Import)  
**775 MW**  
CONED - LIPA  
Impacts Total Transfer Capability 725 MW  
TTC with All Lines In Service 1500 MW

## DUNWODIE\_345KV\_3

Sun 10/07/2018 to Tue 10/09/2018 EXTENDED by CE 10/09/2018  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
**3800 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## DUNWODIE\_345KV\_5

Sun 10/07/2018 to Tue 10/09/2018 EXTENDED by CE 10/09/2018  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
**3800 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## CHAT\_DC\_GC2

Tue 10/09/2018 to Fri 11/23/2018 UPDATED by HQ 10/04/2018  
0500 Continuous 2000

Work scheduled by: HQ

FWD  
(Import)  
**2850 MW**  
MOSES SOUTH  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC2

Tue 10/09/2018 to Fri 11/23/2018 UPDATED by HQ 10/04/2018  
0500 Continuous 2000

Work scheduled by: HQ

REV  
(Export)  
**500 MW**  
SCH - HQ - NY  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

## SCH-IMO-NYISO\_LIMIT\_1100

Tue 10/09/2018 to Fri 10/12/2018  
0530 Continuous 1700

Work scheduled by: IESO

FWD  
(Import)  
**1400 MW**  
SCH - OH - NY  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1900 MW

## SCH-NYISO-IMO\_LIMIT\_1100

Tue 10/09/2018 to Fri 10/12/2018  
0530 Continuous 1700

Work scheduled by: IESO

REV  
(Export)  
**1400 MW**  
SCH - OH - NY  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 1750 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 12, 2018 to Sunday ,April 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_6**

Wed 10/10/2018 to Wed 10/10/2018  
0001 Continuous 2359  
Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **400 MW**  
Impacts Total Transfer Capability 260 MW  
TTC with All Lines In Service 660 MW

**DOLSONAV-ROCKTVRN\_345\_DART44**

Wed 10/10/2018 to Thu 10/11/2018  
0700 Continuous 1530  
Work scheduled by: NYPA

UPDATED by NYPA 10/09/2018

FWD  
(Import)  
CENTRAL EAST - VC **2720 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

**EDIC -FRASER\_345\_EF24-40**

Wed 10/10/2018 to Fri 10/12/2018  
0700 Continuous 1730  
Work scheduled by: NYPA

CANCELLED by NYPA 10/09/2018

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**MILLWOOD\_345KV\_18**

Thu 10/11/2018 to Fri 10/12/2018  
0001 Continuous 0200  
Work scheduled by: ConEd

CANCELLED by ConEd 10/10/2018

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 1350 MW  
TTC with All Lines In Service 5700 MW

**SCH-NYISO-NE\_LIMIT\_1100**

Thu 10/11/2018 to Thu 10/11/2018  
0800 Continuous 1430  
Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY **1300 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 1600 MW

**SCH-IMO-NYISO\_LIMIT\_850**

Fri 10/12/2018 to Fri 10/12/2018  
0700 Continuous 1600  
Work scheduled by: PJM

UPDATED by PJM 10/10/2018

FWD  
(Import)  
SCH - OH - NY **1150 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 1900 MW

**SCH-NYISO-PJM\_LIMIT\_100**

Fri 10/12/2018 to Fri 10/12/2018  
0700 Continuous 1600  
Work scheduled by: PJM

UPDATED by PJM 10/10/2018

REV  
(Export)  
SCH - PJ - NY **400 MW**  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 1300 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 12, 2018 to Sunday ,April 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>S.RIPLEY-DUNKIRK__230_68</b>							
Fri 10/12/2018	to	Sat 02/01/2020	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/10/2018</u>		
1601	Continuous	0000				<b>1950 MW</b>	<b>1300 MW</b>
Work scheduled by: PJM						Impacts Total Transfer Capability	150 MW
						TTC with All Lines In Service	2100 MW
<b>MILLWOOD_345KV_18</b>						FWD	
Sat 10/13/2018	to	Sun 10/14/2018				(Import)	
0001	Continuous	0200				<b>4350 MW</b>	
Work scheduled by: ConEd						Impacts Total Transfer Capability	1350 MW
						TTC with All Lines In Service	5700 MW
<b>CHATGUAY-MASSENA__765_7040</b>						FWD	
Sat 10/13/2018	to	Sat 10/27/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/11/2018</u>	(Import)	
0100	Continuous	1730				<b>1550 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1600 MW
						TTC with All Lines In Service	3150 MW
<b>CHATGUAY-MASSENA__765_7040</b>						FWD	REV
Sat 10/13/2018	to	Sat 10/27/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/11/2018</u>	(Import)	(Export)
0100	Continuous	1730				<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1500 MW
						TTC with All Lines In Service	1500 MW
<b>MARCY____765_345_AT1</b>						FWD	
Sat 10/13/2018	to	Sat 10/27/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/11/2018</u>	(Import)	
0100	Continuous	1730				<b>1750 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1400 MW
						TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY____765_MSU1</b>						FWD	
Sat 10/13/2018	to	Sat 10/27/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/11/2018</u>	(Import)	
0100	Continuous	1730				<b>2265 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	710 MW
						TTC with All Lines In Service	2975 MW
<b>MASSENA_-MARCY____765_MSU1</b>						FWD	
Sat 10/13/2018	to	Sat 10/27/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/11/2018</u>	(Import)	
0100	Continuous	1730				<b>500 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 12, 2018 to Sunday ,April 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA_-MARCY_765_MSU1</b>					FWD	REV
Sat 10/13/2018	to	Sat 10/27/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/11/2018</u>	(Import) (Export)
0100	Continuous	1730				
Work scheduled by: NYPA					SCH - HQ - NY	<b>475 MW</b>
					Impacts Total Transfer Capability	1025 MW
					TTC with All Lines In Service	1500 MW
<b>MASSENA_-MARCY_765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>					FWD	
Sat 10/13/2018	to	Sat 10/27/2018				(Import)
0100		1730			MOSES SOUTH	<b>500 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	2650 MW
					TTC with All Lines In Service	3150 MW
<b>MOSES_-MASSENA_230_MMS1 &amp; MOSES_-MASSENA_230_MMS2</b>					FWD	REV
Sat 10/13/2018	to	Sat 10/27/2018				(Import) (Export)
0100		1730			SCH - HQ - NY	<b>850 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	650 MW
					TTC with All Lines In Service	1500 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2 &amp; MOSES_-MASSENA_230_MMS1 &amp; MOSES_-MASSENA_230_MMS2</b>					FWD	
Sat 10/13/2018	to	Sat 10/27/2018				(Import)
0500		1730			MOSES SOUTH	<b>1950 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	1200 MW
					TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC1</b>					FWD	
Sat 10/13/2018	to	Sat 10/27/2018				(Import)
0500	Continuous	2000			MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC1</b>						REV
Sat 10/13/2018	to	Sat 10/27/2018				(Export)
0500	Continuous	2000			SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>					FWD	
Sat 10/13/2018	to	Sat 10/27/2018				(Import)
0500		2000			MOSES SOUTH	<b>2550 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	600 MW
					TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 12, 2018 to Sunday ,April 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Sat 10/13/2018 to Sat 10/27/2018  
0500 2000

Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ - NY	<b>1370 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	130 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

## EFISHKIL-WOOD\_ST\_\_345\_F38

Sun 10/14/2018 to Mon 10/15/2018  
0201 Continuous 0900

Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	<b>4000 MW</b>
Impacts Total Transfer Capability	1700 MW
TTC with All Lines In Service	5700 MW

## PLSNTVLE-DUNWODIE\_345\_W89

Sun 10/14/2018 to Mon 10/15/2018  
0201 Continuous 0900

Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	<b>4000 MW</b>
Impacts Total Transfer Capability	1700 MW
TTC with All Lines In Service	5700 MW

## WOOD\_ST\_-PLSNTVLE\_345\_Y86

Sun 10/14/2018 to Mon 10/15/2018  
0201 Continuous 0900

Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	<b>4000 MW</b>
Impacts Total Transfer Capability	1700 MW
TTC with All Lines In Service	5700 MW

## FROST\_BR-LONG\_MTN\_345\_352

Sun 10/14/2018 to Sun 10/14/2018 **UPDATED by ISONE 10/11/2018**  
0700 Continuous 1800

Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1150 MW</b>	<b>1600 MW</b>
Impacts Total Transfer Capability	250 MW	0 MW
TTC with All Lines In Service	1400 MW	1600 MW

## SCH-NE-NYISO\_LIMIT\_800

Sun 10/14/2018 to Sun 10/14/2018 **UPDATED by ISONE 10/11/2018**  
0700 Continuous 1800

Work scheduled by: ISONE

	FWD (Import)
SCH - NE - NY	<b>1000 MW</b>
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	1400 MW

## FRASER\_-COOPERS\_\_345\_33

Mon 10/15/2018 to Mon 10/15/2018  
0500 Continuous 0700

Work scheduled by: NYSEG

	FWD (Import)
CENTRAL EAST - VC	<b>2395 MW</b>
Impacts Total Transfer Capability	580 MW
TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 12, 2018 to Sunday ,April 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-IMO-NYISO\_LIMIT\_1200

Mon 10/15/2018 to Thu 10/18/2018  
0530 Continuous 1800  
Work scheduled by: IESO

FWD  
(Import)  
SCH - OH - NY **1500 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1900 MW

## SCH-NYISO-IMO\_LIMIT\_1200

Mon 10/15/2018 to Thu 10/18/2018  
0530 Continuous 1800  
Work scheduled by: IESO

REV  
(Export)  
SCH - OH - NY **1500 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1750 MW

## HUDSONTP-W49TH\_ST\_345\_Y56

Mon 10/15/2018 to Tue 10/16/2018  
0600 Continuous 1600  
Work scheduled by: PJM

FWD  
(Import)  
SCH - PJM\_HTP **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

## SCH-IMO-NYISO\_LIMIT\_1000

Mon 10/15/2018 to Wed 10/31/2018 **UPDATED by NYISO 10/11/2018**  
0600 Continuous 2359  
Work scheduled by: NGrid

FWD  
(Import)  
SCH - OH - NY **1300 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1900 MW

## HOMR\_NYW-PIERC\_NY\_345\_48

Mon 10/15/2018 to Tue 10/16/2018 **CANCELLED by PJM 10/12/2018**  
0800 Continuous 2000  
Work scheduled by: PJM

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2100 MW 1300 MW**  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 2100 MW 1300 MW

## PLSNTVLY\_345KV\_RN5 &amp; PLSNTVLY\_345KV\_RN4

Wed 10/17/2018 to Sat 10/20/2018  
0001 0300  
Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1900 MW  
TTC with All Lines In Service 5700 MW

## MARCY\_345KV\_CSC

Wed 10/17/2018 to Thu 10/18/2018 **UPDATED by NYPA 10/11/2018**  
0500 Continuous 1930  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 12, 2018 to Sunday ,April 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>STONYRDG-HILLSIDE_230_72</b>					FWD	
Wed 10/17/2018	to	Thu 10/18/2018			(Import)	
0800	Continuous	1530			DYSINGER EAST	<b>2850 MW</b>
Work scheduled by: NYSEG					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
<b>SCH-IMO-NYISO_LIMIT_900</b>					FWD	
Thu 10/18/2018	to	Fri 10/19/2018			(Import)	
0500	Continuous	2300			SCH - OH - NY	<b>1200 MW</b>
Work scheduled by: NYISO					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	1900 MW
<b>FRASER__-COOPERS__345_33</b>					FWD	
Fri 10/19/2018	to	Fri 10/19/2018			(Import)	
2000	Continuous	2059			CENTRAL EAST - VC	<b>2395 MW</b>
Work scheduled by: NYSEG					Impacts Total Transfer Capability	580 MW
					TTC with All Lines In Service	2975 MW
<b>PLSNTVLY-EFISHKIL_345_F36</b>					FWD	
Sat 10/20/2018	to	Mon 10/22/2018	<b>UPDATED</b>	<b>by CONED 10/09/2018</b>	(Import)	
0001	Continuous	0300			UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1700 MW
					TTC with All Lines In Service	5700 MW
<b>FROST_BR-LONG_MTN_345_352</b>					FWD	REV
Sat 10/20/2018	to	Sat 10/20/2018			(Import)	(Export)
0700	Continuous	1800			SCH - NE - NY	<b>1150 MW 1600 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	250 MW 0 MW
					TTC with All Lines In Service	1400 MW 1600 MW
<b>WOOD_ST_-PLSNTVLE_345_Y87</b>					FWD	
Mon 10/22/2018	to	Mon 10/22/2018	<b>UPDATED</b>	<b>by CE 10/04/2018</b>	(Import)	
0301	Continuous	0330			UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1700 MW
					TTC with All Lines In Service	5700 MW
<b>DUNWODIE_345KV_6</b>					FWD	
Mon 10/22/2018	to	Sat 12/22/2018	<b>UPDATED</b>	<b>by CE 10/04/2018</b>	(Import)	
0301	Continuous	0200			SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 12, 2018 to Sunday ,April 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_8**

FWD

Mon 10/22/2018 to Sat 12/22/2018 UPDATED by CE 10/04/2018

(Import)

0301 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**PLSNTVLE-DUNWODIE\_345\_W90**

FWD

Mon 10/22/2018 to Sat 12/22/2018 UPDATED by CE 10/04/2018

(Import)

0301 Continuous 0200

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**SCRIBA\_-VOLNEY\_345\_21**

FWD

Mon 10/22/2018 to Tue 10/23/2018 UPDATED by NGRID 08/13/2018

(Import)

0730 Continuous 1930

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

**LINDN\_CG-LNDVFT\_345\_V-3022**

FWD

REV

Mon 10/22/2018 to Thu 10/25/2018

(Import) (Export)

0800 Continuous 1500

SCH - PJM\_VFT

**0 MW****0 MW**

Impacts Total Transfer Capability 315 MW 315 MW

TTC with All Lines In Service 315 MW 315 MW

Work scheduled by: PJM

**FROST\_BR-LONG\_MTN\_345\_352**

FWD

REV

Tue 10/23/2018 to Fri 10/26/2018

(Import) (Export)

0700 Continuous 1600

SCH - NE - NY

**1150 MW****1600 MW**

Impacts Total Transfer Capability 250 MW 0 MW

TTC with All Lines In Service 1400 MW 1600 MW

Work scheduled by: ISONE

**SCH-NE-NYISO\_LIMIT\_800**

FWD

Tue 10/23/2018 to Fri 10/26/2018

(Import)

0700 Continuous 1600

SCH - NE - NY

**1000 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

**LEEDS\_-HURLYAVE\_345\_301**

FWD

Wed 10/24/2018 to Fri 11/16/2018 UPDATED by CH 09/18/2018

(Import)

0800 Continuous 1600

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: CHGE

# NYISO TRANSFER LIMITATIONS

Friday ,October 12, 2018 to Sunday ,April 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>DENNISON-NORFOLK__115_4</b>							
Wed 10/24/2018	to	Wed 10/24/2018	<u>UPDATED</u>	<u>by NGRID</u>	<u>10/11/2018</u>		
0830	Daily(No Weekends)	1600				SCH - HQ_CEDARS	<b>150 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	40 MW
						TTC with All Lines In Service	190 MW
							40 MW
<b>KINTIGH_-ROCHESTR_345_SR1-39</b>						FWD	
Mon 10/29/2018	to	Fri 11/02/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/10/2018</u>	(Import)	
0500	Continuous	1700				DYSINGER EAST	<b>1400 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1750 MW
						TTC with All Lines In Service	3150 MW
<b>MOSES_-ADIRNDCK_230_MA1</b>						FWD	
Mon 10/29/2018	to	Fri 11/02/2018				(Import)	
0700	Continuous	1530				MOSES SOUTH	<b>2100 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1050 MW
						TTC with All Lines In Service	3150 MW
<b>SCH-IMO-NYISO_LIMIT_1200</b>						FWD	
Thu 11/01/2018	to	Wed 11/21/2018	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/11/2018</u>	(Import)	
0001	Continuous	1830				SCH - OH - NY	<b>1500 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	250 MW
						TTC with All Lines In Service	1750 MW
<b>PORTER_-ROTTDAM_230_31</b>						FWD	
Fri 11/02/2018	to	Fri 11/02/2018				(Import)	
0600	Daily(No Weekends)	1600				CENTRAL EAST - VC	<b>2805 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	170 MW
						TTC with All Lines In Service	2975 MW
<b>NEPTUNE_-DUFFYAVE_345_NEPTUNE</b>						FWD	
Sat 11/03/2018	to	Sun 11/18/2018				(Import)	
0001	Continuous	1800				SCH - PJM_NEPTUNE	<b>0 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	660 MW
						TTC with All Lines In Service	660 MW
<b>NEWBRDGE-DUFFYAVE_345_501</b>						FWD	
Sat 11/03/2018	to	Sun 11/18/2018				(Import)	
0001	Continuous	1800				SCH - PJM_NEPTUNE	<b>0 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	660 MW
						TTC with All Lines In Service	660 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 12, 2018 to Sunday ,April 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NEWBRDGE\_345\_138\_BK\_1**

Sat 11/03/2018 to Sun 11/18/2018

0001 Continuous 1800

Work scheduled by: LI

FWD

(Import)

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

**NEWBRDGE\_345\_138\_BK\_2**

Sat 11/03/2018 to Sun 11/18/2018

0001 Continuous 1800

Work scheduled by: LI

FWD

(Import)

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

**BROWNFLS-TAYLORVL\_115\_3**

Sat 11/03/2018 to Sat 11/03/2018

0700 Continuous 1630

Work scheduled by: NGrid

**ARR: 38**

FWD

(Import) (Export)

SCH - HQ\_CEDARS

**100 MW****100 MW**

Impacts Total Transfer Capability 99 MW

0 MW

TTC with All Lines In Service 199 MW

100 MW

**BROWNFLS-TAYLORVL\_115\_3 & TAYLORVL-LOWVILLE\_115\_5 & CLIMAX\_\_TAYLORVL\_115\_8**

Sat 11/03/2018 to Sat 11/03/2018

0700 1630

Work scheduled by:

**ARR: 38**

FWD

(Import) (Export)

SCH - HQ\_CEDARS

**120 MW****100 MW**

Impacts Total Transfer Capability 79 MW

0 MW

TTC with All Lines In Service 199 MW

100 MW

**TAYLORVL-LOWVILLE\_115\_5**

Sat 11/03/2018 to Sat 11/03/2018

0700 Continuous 1630

Work scheduled by: NGrid

**ARR: 38**

FWD

(Import) (Export)

SCH - HQ\_CEDARS

**199 MW****100 MW**

Impacts Total Transfer Capability 0 MW

0 MW

TTC with All Lines In Service 199 MW

100 MW

**GOETHALS\_345KV\_5**

Sun 11/04/2018 to Sun 11/04/2018

0001 Continuous 0030

Work scheduled by: ConEd

**UPDATED****by CONED 10/01/2018**

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

**LINDEN\_\_GOETHALS\_230\_A2253**

Sun 11/04/2018 to Sun 11/11/2018

0001 Continuous 0300

Work scheduled by: ConEd

**UPDATED****by CONED 10/01/2018**

SCH - PJ - NY

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 2750 MW

FWD

(Import) (Export)

**2600 MW****1300 MW**

0 MW

0 MW

1300 MW

1300 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LINDEN\_\_ -GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402

Sun 11/04/2018 to Sun 11/11/2018  
0001 0300

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2000 MW	1300 MW
Impacts Total Transfer Capability	750 MW	0 MW
TTC with All Lines In Service	2750 MW	1300 MW

## LINDEN\_\_ -GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_\_ -FARRAGUT\_345\_C3403

Sun 11/04/2018 to Sun 11/11/2018  
0001 0300

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2000 MW	1300 MW
Impacts Total Transfer Capability	750 MW	0 MW
TTC with All Lines In Service	2750 MW	1300 MW

## LINDEN\_\_ -GOETHALS\_230\_A2253 & MARION\_\_ -FARRAGUT\_345\_C3403

Sun 11/04/2018 to Sun 11/11/2018  
0001 0300

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2000 MW	1300 MW
Impacts Total Transfer Capability	750 MW	0 MW
TTC with All Lines In Service	2750 MW	1300 MW

## NIAGARA\_\_ 345\_230\_AT4

Mon 11/05/2018 to Fri 11/09/2018 UPDATED by NYPA 10/05/2018  
0400 Continuous 2300

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1750 MW	1800 MW
Impacts Total Transfer Capability	0 MW	100 MW
TTC with All Lines In Service	1750 MW	1900 MW

## SCH-NYISO-NE\_LIMIT\_1100

Mon 11/05/2018 to Sat 11/24/2018  
0600 Continuous 1900

Work scheduled by: ISONE

		REV
		(Export)
SCH - NE - NY		1300 MW
Impacts Total Transfer Capability		300 MW
TTC with All Lines In Service		1600 MW

## MOSES\_\_ -ADIRNDCK\_230\_MAI

Mon 11/05/2018 to Fri 11/09/2018  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## HOMR\_NYW-PIERC\_NY\_345\_48

Mon 11/05/2018 to Fri 11/09/2018  
0800 Continuous 2000

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2500 MW	1300 MW
Impacts Total Transfer Capability	250 MW	0 MW
TTC with All Lines In Service	2750 MW	1300 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## GOETHALS\_345KV\_5

Sun 11/11/2018 to Sun 11/11/2018 **UPDATED by CONED 10/01/2018**  
0230 Continuous 0300

Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## FROST\_BR-LONG\_MTN\_345\_352

Sun 11/11/2018 to Sun 11/11/2018  
0700 Continuous 1800

Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1300 MW</b>	<b>1600 MW</b>
Impacts Total Transfer Capability	100 MW	0 MW
TTC with All Lines In Service	1400 MW	1600 MW

## SCH-NE-NYISO\_LIMIT\_1000

Sun 11/11/2018 to Sun 11/11/2018  
0700 Continuous 1800

Work scheduled by: ISONE

	FWD (Import)
SCH - NE - NY	<b>1200 MW</b>
Impacts Total Transfer Capability	200 MW
TTC with All Lines In Service	1400 MW

## NIAGARA\_-KINTIGH\_345\_NS1-38

Tue 11/13/2018 to Fri 11/16/2018  
0700 Continuous 1600

Work scheduled by: NYSEG

	FWD (Import)
DYSINGER EAST	<b>1700 MW</b>
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

## SCH-IMO-NYISO\_LIMIT\_1050

Thu 11/15/2018 to Wed 11/21/2018  
0500 Continuous 1830

Work scheduled by: NYPA

	FWD (Import)
SCH - OH - NY	<b>1350 MW</b>
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	1750 MW

## SCH-IMO-NYISO\_LIMIT\_1350

Thu 11/15/2018 to Thu 12/20/2018  
0500 Continuous 2359

Work scheduled by: NYPA

	FWD (Import)
SCH - OH - NY	<b>1650 MW</b>
Impacts Total Transfer Capability	100 MW
TTC with All Lines In Service	1750 MW

## MARCY\_345KV\_CSC

Fri 11/16/2018 to Sat 11/17/2018  
0500 Continuous 1730

Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	<b>2925 MW</b>
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 12, 2018 to Sunday ,April 12, 2020

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MARCY\_\_\_765\_345\_AT2

Fri 11/16/2018 to Sat 11/17/2018  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH 1700 MW  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MAI

Mon 11/19/2018 to Wed 11/21/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2300 MW  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## LONG\_MTN-PLSNTVLY\_345\_398

Mon 11/26/2018 to Thu 12/06/2018  
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 10/09/2018

FWD REV  
(Import) (Export)  
SCH - NE - NY 700 MW 1300 MW  
Impacts Total Transfer Capability 700 MW 300 MW  
TTC with All Lines In Service 1400 MW 1600 MW

## LONG\_MTN-PLSNTVLY\_345\_398

Mon 11/26/2018 to Thu 12/06/2018  
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 10/09/2018

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 100 MW 100 MW  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

## SCH-NYISO-NE\_LIMIT\_400

Mon 11/26/2018 to Thu 12/06/2018  
0001 Continuous 0030

Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY 600 MW  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 1600 MW

## SCRIBA\_\_\_-VOLNEY\_\_\_345\_21

Mon 11/26/2018 to Wed 11/28/2018  
0700 Continuous 1730

Work scheduled by: NGrid

UPDATED by NGRID 08/14/2018

FWD  
(Import)  
OSWEGO EXPORT 5250 MW  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MAI

Mon 11/26/2018 to Fri 11/30/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2300 MW  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHOR_NPX-SHOREHAM_138_CSC				FWD	REV
				(Import)	(Export)
Mon 11/26/2018	to	Fri 12/07/2018		SCH - NPX_CSC	<b>0 MW</b>
0700	Continuous	1600		Impacts Total Transfer Capability	330 MW
Work scheduled by: LI				TTC with All Lines In Service	330 MW
HURLYAVE-ROSETON_345_303				FWD	
				(Import)	
Mon 11/26/2018	to	Fri 12/21/2018		UPNY CONED	<b>4100 MW</b>
0800	Continuous	1600		Impacts Total Transfer Capability	1600 MW
Work scheduled by: CHGE				TTC with All Lines In Service	5700 MW
DUNWODIE-MOTTHAVN_345_72				FWD	
				(Import)	
Sun 12/02/2018	to	Thu 12/06/2018		SPR/DUN-SOUTH	<b>3800 MW</b>
0001	Continuous	0159		Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_7				FWD	
				(Import)	
Sun 12/02/2018	to	Thu 12/06/2018		SPR/DUN-SOUTH	<b>3800 MW</b>
0001	Continuous	0159		Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW
MOSES__-ADIRNDCK_230_MA2				FWD	
				(Import)	
Mon 12/03/2018	to	Fri 12/07/2018		MOSES SOUTH	<b>2300 MW</b>
0700	Continuous	1530		Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW
DUNWODIE-SHORE_RD_345_Y50				FWD	
				(Import)	
Thu 12/06/2018	to	Wed 12/12/2018		CONED - LIPA	<b>800 MW</b>
0201	Continuous	0200		Impacts Total Transfer Capability	700 MW
Work scheduled by: ConEd				TTC with All Lines In Service	1500 MW
DUNWODIE_345KV_4				FWD	
				(Import)	
Thu 12/06/2018	to	Wed 12/12/2018		SPR/DUN-SOUTH	<b>3800 MW</b>
0201	Continuous	0200		Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SHORE\_RD\_345\_138\_BK 1

Thu 12/06/2018 to Wed 12/12/2018  
0201 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
CONED - LIPA **1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

## SHORE\_RD\_345\_138\_BK 2

Thu 12/06/2018 to Wed 12/12/2018  
0201 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
CONED - LIPA **1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 12/10/2018 to Fri 12/14/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## WOOD\_ST\_-PLSNTVLE\_345\_Y87

Sat 12/15/2018 to Sat 01/26/2019  
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 10/04/2018

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1700 MW  
TTC with All Lines In Service 5700 MW

## MARCY\_\_\_765\_345\_AT2

Mon 12/17/2018 to Fri 12/21/2018  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## EFISHKIL-WOOD\_ST\_345\_F39

Thu 12/20/2018 to Thu 12/20/2018  
0200 Continuous 0230

Work scheduled by: ConEd

UPDATED by CE 10/04/2018

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1700 MW  
TTC with All Lines In Service 5700 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MAI

Wed 12/26/2018 to Fri 12/28/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 12, 2018 to Sunday ,April 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
<b>BECK____-NIAGARA_230_PA27</b>						
Sat 12/29/2018	to	Sat 12/29/2018	<u>UPDATED</u>	<u>by NYPA</u> <u>10/10/2018</u>	SCH - OH - NY	<b>1750 MW</b>
0500	Continuous	1700			Impacts Total Transfer Capability	0 MW
Work scheduled by: NYPA					TTC with All Lines In Service	1750 MW
<b>HURLYAVE-ROSETON_345_303</b>					FWD	
Wed 01/02/2019	to	Fri 01/11/2019		<u>08/20/2018</u>	(Import)	
0800	Continuous	1600			UPNY CONED	<b>4100 MW</b>
Work scheduled by: CHGE					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	5700 MW
<b>SCH-NE-NYISO_LIMIT_1100</b>					FWD	
Mon 01/07/2019	to	Thu 01/10/2019			(Import)	
0700	Continuous	1600			SCH - NE - NY	<b>1300 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1400 MW
<b>MOSES____-ADIRNDCK_230_MA1</b>					FWD	
Mon 01/07/2019	to	Fri 01/11/2019			(Import)	
0700	Continuous	1500			MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
<b>MOSES____-ADIRNDCK_230_MA2</b>					FWD	
Mon 01/14/2019	to	Fri 01/18/2019			(Import)	
0700	Continuous	1500			MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
<b>LEEDS____-HURLYAVE_345_301</b>					FWD	
Mon 01/14/2019	to	Fri 01/25/2019		<u>08/20/2018</u>	(Import)	
0800	Continuous	1600			UPNY CONED	<b>4100 MW</b>
Work scheduled by: CHGE					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	5700 MW
<b>EFISHKIL-WOOD_ST_345_F39</b>					FWD	
Sat 01/19/2019	to	Sat 01/19/2019	<u>UPDATED</u>	<u>by CE</u> <u>10/04/2018</u>	(Import)	
0130	Continuous	0200			UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1700 MW
					TTC with All Lines In Service	5700 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 12, 2018 to Sunday ,April 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_6**

FWD

Mon 01/21/2019 to Mon 01/28/2019 UPDATED by CE 10/04/2018

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**DUNWODIE\_345KV\_8**

FWD

Mon 01/21/2019 to Mon 01/28/2019 UPDATED by CE 10/04/2018

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**PLSNTVLE-DUNWODIE\_345\_W90**

FWD

Mon 01/21/2019 to Mon 01/28/2019 UPDATED by CE 10/04/2018

(Import)

0001 Continuous 0200

UPNY CONED **4000 MW**

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**MOSES\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 01/21/2019 to Fri 01/25/2019

(Import)

0700 Continuous 1500

MOSES SOUTH **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**MOSES\_\_-ADIRNDCK\_230\_MA1**

FWD

Mon 01/28/2019 to Fri 02/01/2019

(Import)

0700 Continuous 1500

MOSES SOUTH **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

FWD

Tue 01/29/2019 to Sun 02/03/2019

(Import)

0001 0300

UPNY CONED **3800 MW**

Impacts Total Transfer Capability 1900 MW

TTC with All Lines In Service 5700 MW

Work scheduled by:

**MOSES\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 02/04/2019 to Thu 02/07/2019

(Import)

0700 Continuous 1500

MOSES SOUTH **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**ADIRNDCK-CHASLAKE\_230\_13**

Thu 02/07/2019 to Thu 02/07/2019  
0800 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**MOSES-ADIRNDCK\_230\_MA1**

Fri 02/08/2019 to Fri 02/08/2019  
0800 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**MOSES-ADIRNDCK\_230\_MA2**

Mon 02/11/2019 to Fri 02/15/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**MOSES-ADIRNDCK\_230\_MA2**

Tue 02/19/2019 to Fri 02/22/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Sun 02/24/2019 to Sun 02/24/2019  
0001 2359

Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1900 MW  
TTC with All Lines In Service 5700 MW

**LONG\_MTN-PLSNTVLY\_345\_398**

Sun 02/24/2019 to Sun 05/19/2019 **UPDATED by CE 09/14/2018**  
0001 Continuous 2359

Work scheduled by: ConEd

FWD REV  
(Import) (Export)  
SCH - NE - NY **700 MW 1300 MW**  
Impacts Total Transfer Capability 700 MW 300 MW  
TTC with All Lines In Service 1400 MW 1600 MW

**LONG\_MTN-PLSNTVLY\_345\_398**

Sun 02/24/2019 to Sun 05/19/2019 **UPDATED by CE 09/14/2018**  
0001 Continuous 2359

Work scheduled by: ConEd

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **100 MW 100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 12, 2018 to Sunday ,April 12, 2020

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PLSNTVLY-EFISHKIL\_345\_F37

FWD

Mon 02/25/2019 to Tue 02/26/2019

UPDATEDby CE09/14/2018

(Import)

0001 Continuous 0300

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

## MOSES-ADIRNDCK\_230\_MAl

FWD

Mon 03/04/2019 to Fri 03/08/2019

(Import)

0700 Continuous 1500

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## MOSES-ADIRNDCK\_230\_MAl

FWD

Mon 03/11/2019 to Fri 03/15/2019

(Import)

0700 Continuous 1500

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## LEEDS-345\_LEEDS SVC

FWD

Mon 03/11/2019 to Fri 03/22/2019

(Import)

0800 Continuous 1600

CENTRAL EAST - VC

**2950 MW**

Impacts Total Transfer Capability 25 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

## MARCY-765\_345\_AT1

FWD

Mon 03/18/2019 to Fri 03/22/2019

(Import)

0500 Continuous 1530

MOSES SOUTH

**1750 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

ARR: 19

## PLSNTVLY-EFISHKIL\_345\_F37

FWD

Sat 03/30/2019 to Wed 04/03/2019

(Import)

0001 Continuous 0300

UPDATEDby CE09/14/2018

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

## MARCY-345KV\_CSC

FWD

Mon 04/01/2019 to Sun 04/07/2019

(Import)

0500 Continuous 1730

CENTRAL EAST - VC

**2925 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

VOLNEY__-MARCY____345_19				FWD	
Mon 04/01/2019	to	Wed 04/10/2019		(Import)	
0500	Continuous	1730		CENTRAL EAST - VC	2825 MW
Work scheduled by: NYPA			ARR: 19	Impacts Total Transfer Capability	150 MW
				TTC with All Lines In Service	2975 MW
VOLNEY__-MARCY____345_19				FWD	
Mon 04/01/2019	to	Wed 04/10/2019		(Import)	
0500	Continuous	1730		OSWEGO EXPORT	4900 MW
Work scheduled by: NYPA			ARR: 19	Impacts Total Transfer Capability	350 MW
				TTC with All Lines In Service	5250 MW
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4				FWD	
Sun 04/07/2019	to	Mon 04/08/2019		(Import)	
0001		0030		UPNY CONED	3800 MW
Work scheduled by:				Impacts Total Transfer Capability	1900 MW
				TTC with All Lines In Service	5700 MW
LINDN_CG-LNDVFT____345_V-3022				FWD	REV
Sun 04/07/2019	to	Fri 04/12/2019		(Import)	(Export)
1400	Continuous	1800		SCH - PJM_VFT	0 MW 0 MW
Work scheduled by: PJM				Impacts Total Transfer Capability	315 MW 315 MW
				TTC with All Lines In Service	315 MW 315 MW
MARCY____345KV_CSC				FWD	
Thu 04/11/2019	to	Wed 04/17/2019		(Import)	
0500	Continuous	1730		CENTRAL EAST - VC	2925 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	50 MW
				TTC with All Lines In Service	2975 MW
MARCY__-EDIC____345_UE1-7				FWD	
Thu 04/11/2019	to	Sat 04/20/2019		(Import)	
0500	Continuous	1730		OSWEGO EXPORT	5250 MW
Work scheduled by: NYPA			ARR: 19&16	Impacts Total Transfer Capability	0 MW
				TTC with All Lines In Service	5250 MW
GILBOA__-N.SCTLND_345_GNS-1				FWD	
Fri 04/12/2019	to	Fri 04/12/2019		(Import)	
1330	Continuous	1530		CENTRAL EAST - VC	2520 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	455 MW
				TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 12, 2018 to Sunday ,April 12, 2020

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## EDIC\_\_\_\_-FRASER\_\_\_\_345\_EF24-40

Mon 04/22/2019 to Fri 04/26/2019

0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC 2500 MW

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

## MARCY\_\_\_\_765\_345\_AT2

Mon 04/22/2019 to Fri 04/26/2019

0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

MOSES SOUTH 1700 MW

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

## FRASANNX-COOPERS\_\_\_\_345\_UCC2-41

Mon 04/29/2019 to Fri 05/03/2019

0500 Continuous 1730

Work scheduled by: NYPA

UPDATED

by NYPA

08/22/2018

ARR: 19

FWD

(Import)

CENTRAL EAST - VC 2500 MW

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

## MARCY\_\_\_\_-FRASANNX\_345\_UCC2-41

Mon 04/29/2019 to Fri 05/03/2019

0500 Continuous 1730

Work scheduled by: NYPA

UPDATED

by NYPA

08/22/2018

ARR: 19

FWD

(Import)

CENTRAL EAST - VC 2500 MW

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MAI

Mon 04/29/2019 to Fri 05/03/2019

0700 Continuous 1500

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH 2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## ROSETON\_-ROCKTVRN\_345\_311

Mon 05/06/2019 to Sat 06/01/2019

0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED 4400 MW

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5700 MW

## ADIRNDCK-PORTER\_\_\_\_230\_12

Mon 05/20/2019 to Fri 05/24/2019

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH 2100 MW

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**PANNELL\_-CLAY\_\_\_\_\_345\_1**

Mon 05/20/2019 to Fri 05/24/2019  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

---

**PANNELL\_-CLAY\_\_\_\_\_345\_2**

Mon 06/03/2019 to Fri 06/07/2019  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_Ma1**

Mon 08/12/2019 to Mon 08/12/2019 **UPDATED by NYPA 10/10/2018**  
0700 Continuous 1459

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

---

**MARCY\_\_\_-N.SCTLND\_345\_18**

Wed 09/04/2019 to Wed 09/04/2019  
0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2090 MW**  
Impacts Total Transfer Capability 885 MW  
TTC with All Lines In Service 2975 MW

---

**ADIRNDCK-PORTER\_\_\_230\_12**

Wed 09/04/2019 to Wed 09/04/2019  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

---

**ADIRNDCK-CHASLAKE\_230\_13**

Thu 09/05/2019 to Thu 09/05/2019  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

---

**LEEDS\_\_\_\_\_345KV\_R395**

Mon 09/09/2019 to Mon 09/09/2019  
0700 Continuous 0730

Work scheduled by: NYPA

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1900 MW  
TTC with All Lines In Service 5700 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**GILBOA -LEEDS 345\_GL3**

Mon 09/09/2019 to Fri 09/27/2019

0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC

**2200 MW**

Impacts Total Transfer Capability 775 MW

TTC with All Lines In Service 2975 MW

---

**MOSES -ADIRNDCK 230\_MA2**

Mon 09/16/2019 to Fri 09/20/2019

0700 Continuous 1500

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

---

**LEEDS 345KV\_R395**

Fri 09/27/2019 to Fri 09/27/2019

1700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1900 MW

TTC with All Lines In Service 5700 MW

---

**CLAY -EDIC 345\_1-16**

Mon 09/30/2019 to Fri 10/04/2019

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

OSWEGO EXPORT

**4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

---

**CLAY -EDIC 345\_2-15**

Mon 10/07/2019 to Thu 10/17/2019

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

OSWEGO EXPORT

**4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

---

**HURLYAVE-ROSETON 345\_303**

Mon 10/21/2019 to Sat 11/16/2019

0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 5700 MW

---

**PANNELL -CLAY 345\_2**

Wed 11/06/2019 to Fri 11/22/2019

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 12, 2018 to Sunday ,April 12, 2020

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 5700MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

FWD

Tue 11/12/2019 to Fri 11/15/2019

(Import)

0700 Continuous 1500

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

FWD

Mon 11/18/2019 to Fri 11/22/2019

(Import)

0700 Continuous 1500

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA