

**NYISO TRANSFER LIMITATIONS**

Tuesday ,October 16, 2018 to Thursday ,April 16, 2020

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5700MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**HUDSONP\_-FARRAGUT\_345\_B3402**

Mon 01/15/2018 to Fri 02/15/2019 **EXT FORCE by CE** **10/07/2018**

0001 Continuous 2359

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>1950 MW</b>	<b>1200 MW</b>
Impacts Total Transfer Capability	150 MW	100 MW
TTC with All Lines In Service	2100 MW	1300 MW

**HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403**

Mon 01/15/2018 to Fri 02/15/2019

0001 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>1800 MW</b>	<b>1100 MW</b>
Impacts Total Transfer Capability	300 MW	200 MW
TTC with All Lines In Service	2100 MW	1300 MW

**MARION\_-FARRAGUT\_345\_C3403**

Mon 01/15/2018 to Fri 02/15/2019 **EXT FORCE by CE** **10/07/2018**

0001 Continuous 2359

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>1950 MW</b>	<b>1200 MW</b>
Impacts Total Transfer Capability	150 MW	100 MW
TTC with All Lines In Service	2100 MW	1300 MW

**STLAWRNC-MOSES\_230\_L33P**

Mon 04/30/2018 to Fri 12/31/2021 **EXT FORCE by IESO** **08/21/2018**

0456 Continuous 2359

Work scheduled by: IESO

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1900 MW</b>	<b>1750 MW</b>
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	1900 MW	1750 MW

**S.RIPLEY-DUNKIRK\_230\_68**

Thu 08/09/2018 to Fri 10/12/2018 **UPDATED by NYISO** **10/10/2018**

1144 Continuous 0659

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>1950 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	150 MW	0 MW
TTC with All Lines In Service	2100 MW	1300 MW

**SCH-NYISO-HQ CEDARS\_LIMIT\_0**

Mon 09/10/2018 to Fri 10/12/2018 **EXTENDED by HQ** **09/20/2018**

0800 Continuous 1900

Work scheduled by: HQ

		REV
		(Export)
SCH - HQ_CEDARS		<b>0 MW</b>
Impacts Total Transfer Capability		40 MW
TTC with All Lines In Service		40 MW

**MARCY\_765\_345\_AT2**

Wed 09/19/2018 to Sat 10/27/2018 **EXT FORCE by NYPA** **10/11/2018**

0001 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>1700 MW</b>
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

**ARR: 19**

**NYISO TRANSFER LIMITATIONS**

Tuesday ,October 16, 2018 to Thursday ,April 16, 2020

**CENTRAL EAST** 3100MW  
**CENTRAL EAST - VC** 2975MW  
**TOTAL EAST** 6500MW  
**UPNY CONED** 5700MW  
**SPR/DUN-SOUTH** 4600MW  
**DYSINGER EAST** 3150MW  
**MOSES SOUTH** 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-IMO-NYISO\_LIMIT\_800**

Sun 09/23/2018 to Sun 10/14/2018

2300 Continuous 1900

Work scheduled by: NYISO

FWD

(Import)

SCH - OH - NY

**1100 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 1900 MW

**EGRDNCTY\_345\_138\_AT1**

Sat 10/06/2018 to Sat 11/03/2018

0130 Continuous 0300

Work scheduled by: LI

UPDATEDby CE10/03/2018

FWD

(Import)

CONED - LIPA

**1250 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

**EGRDNCTY\_345\_138\_AT2**

Sat 10/06/2018 to Sat 11/03/2018

0130 Continuous 0300

Work scheduled by: LI

UPDATEDby CE10/03/2018

FWD

(Import)

CONED - LIPA

**1250 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

**SPRNBK\_-EGRDNCTR\_345\_Y49**

Sat 10/06/2018 to Sat 11/03/2018

0130 Continuous 0300

Work scheduled by: LI

UPDATEDby CE10/03/2018

FWD

(Import)

CONED - LIPA

**775 MW**

Impacts Total Transfer Capability 725 MW

TTC with All Lines In Service 1500 MW

**CHAT\_DC\_GC2**

Tue 10/09/2018 to Fri 11/23/2018

0500 Continuous 2000

Work scheduled by: HQ

UPDATEDby HQ10/04/2018

FWD

(Import)

MOSES SOUTH

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC2**

Tue 10/09/2018 to Fri 11/23/2018

0500 Continuous 2000

Work scheduled by: HQ

UPDATEDby HQ10/04/2018

REV

(Export)

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

**SCH-IMO-NYISO\_LIMIT\_1100**

Tue 10/09/2018 to Fri 10/12/2018

0530 Continuous 1700

Work scheduled by: IESO

FWD

(Import)

SCH - OH - NY

**1400 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1900 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,October 16, 2018 to Thursday ,April 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NYISO-IMO\_LIMIT\_1100

Tue 10/09/2018 to Fri 10/12/2018  
0530 Continuous 1700  
Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

REV  
(Export)  
**1400 MW**  
350 MW  
1750 MW

## DOLSONAV-ROCKTVRN\_345\_DART44

Wed 10/10/2018 to Thu 10/11/2018  
0700 Continuous 1530  
Work scheduled by: NYPA

UPDATED by NYPA 10/09/2018

FWD  
(Import)  
CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**2720 MW**  
255 MW  
2975 MW

## SCH-NYISO-NE\_LIMIT\_1100

Thu 10/11/2018 to Thu 10/11/2018  
0800 Continuous 1430  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

REV  
(Export)  
**1300 MW**  
300 MW  
1600 MW

## SCH-IMO-NYISO\_LIMIT\_850

Fri 10/12/2018 to Fri 10/12/2018  
0700 Continuous 1600  
Work scheduled by: PJM

UPDATED by PJM 10/10/2018

FWD  
(Import)  
SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**1150 MW**  
750 MW  
1900 MW

## SCH-NYISO-PJM\_LIMIT\_100

Fri 10/12/2018 to Fri 10/12/2018  
0700 Continuous 1600  
Work scheduled by: PJM

UPDATED by PJM 10/10/2018

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

REV  
(Export)  
**400 MW**  
900 MW  
1300 MW

## S.RIPLEY-DUNKIRK\_230\_68

Fri 10/12/2018 to Sat 02/01/2020  
2001 Continuous 0000  
Work scheduled by: PJM

UPDATED by NYISO 10/10/2018

FWD REV  
(Import) (Export)  
SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**1950 MW** **1300 MW**  
150 MW 0 MW  
2100 MW 1300 MW

## MILLWOOD\_345KV\_18

Sat 10/13/2018 to Sun 10/14/2018  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**4350 MW**  
1350 MW  
5700 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,October 16, 2018 to Thursday ,April 16, 2020

**CENTRAL EAST** 3100MW  
**CENTRAL EAST - VC** 2975MW  
**TOTAL EAST** 6500MW  
**UPNY CONED** 5700MW  
**SPR/DUN-SOUTH** 4600MW  
**DYSINGER EAST** 3150MW  
**MOSES SOUTH** 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CHATGUAY-MASSENA\_\_765\_7040**

Sat 10/13/2018 to Sat 10/27/2018 **UPDATED** **by NYPA** **10/13/2018**  
 0100 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH** **1550 MW**  
 Impacts Total Transfer Capability 1600 MW  
 TTC with All Lines In Service 3150 MW

**CHATGUAY-MASSENA\_\_765\_7040**

Sat 10/13/2018 to Sat 10/27/2018 **UPDATED** **by NYPA** **10/13/2018**  
 0100 Continuous 1730

Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
**SCH - HQ - NY** **0 MW** **0 MW**  
 Impacts Total Transfer Capability 1500 MW 1000 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

**MARCY\_\_765\_345\_AT1**

Sat 10/13/2018 to Sat 10/27/2018 **UPDATED** **by NYPA** **10/13/2018**  
 0100 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
**MOSES SOUTH** **1750 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 3150 MW

**MASSENA\_-MARCY\_\_765\_MSU1**

Sat 10/13/2018 to Sat 10/27/2018 **UPDATED** **by NYPA** **10/13/2018**  
 0100 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
**CENTRAL EAST - VC** **2265 MW**  
 Impacts Total Transfer Capability 710 MW  
 TTC with All Lines In Service 2975 MW

**MASSENA\_-MARCY\_\_765\_MSU1**

Sat 10/13/2018 to Sat 10/27/2018 **UPDATED** **by NYPA** **10/13/2018**  
 0100 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH** **500 MW**  
 Impacts Total Transfer Capability 2650 MW  
 TTC with All Lines In Service 3150 MW

**MASSENA\_-MARCY\_\_765\_MSU1**

Sat 10/13/2018 to Sat 10/27/2018 **UPDATED** **by NYPA** **10/13/2018**  
 0100 Continuous 1730

Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
**SCH - HQ - NY** **475 MW** **1000 MW**  
 Impacts Total Transfer Capability 1025 MW 0 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

**MASSENA\_-MARCY\_\_765\_MSU1 & CHATGUAY-MASSENA\_\_765\_7040**

Sat 10/13/2018 to Sat 10/27/2018  
 0100 1730

Work scheduled by:

FWD  
 (Import)  
**MOSES SOUTH** **500 MW**  
 Impacts Total Transfer Capability 2650 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,October 16, 2018 to Thursday ,April 16, 2020

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 5700MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230\_MMS1 & MOSES -MASSENA 230\_MMS2

Sat 10/13/2018 to Sat 10/27/2018  
 0100 1730

Work scheduled by:

FWD REV  
 (Import) (Export)  
 SCH - HQ - NY 850 MW 0 MW  
 Impacts Total Transfer Capability 650 MW 1000 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

CHAT\_DC\_GC1 & CHAT\_DC\_GC2 & MOSES -MASSENA 230\_MMS1 & MOSES -MASSENA 230\_MMS2

Sat 10/13/2018 to Sat 10/27/2018  
 0500 1730

Work scheduled by:

FWD  
 (Import)  
 MOSES SOUTH 1950 MW  
 Impacts Total Transfer Capability 1200 MW  
 TTC with All Lines In Service 3150 MW

CHAT\_DC\_GC1

Sat 10/13/2018 to Sat 10/27/2018  
 0500 Continuous 2000

Work scheduled by: HQ

FWD  
 (Import)  
 MOSES SOUTH 2850 MW  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

CHAT\_DC\_GC1

Sat 10/13/2018 to Sat 10/27/2018  
 0500 Continuous 2000

Work scheduled by: HQ

REV  
 (Export)  
 SCH - HQ - NY 500 MW  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 1000 MW

CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Sat 10/13/2018 to Sat 10/27/2018  
 0500 2000

Work scheduled by:

FWD  
 (Import)  
 MOSES SOUTH 2550 MW  
 Impacts Total Transfer Capability 600 MW  
 TTC with All Lines In Service 3150 MW

CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Sat 10/13/2018 to Sat 10/27/2018  
 0500 2000

Work scheduled by:

FWD REV  
 (Import) (Export)  
 SCH - HQ - NY 1370 MW 0 MW  
 Impacts Total Transfer Capability 130 MW 1000 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

EFISHKIL-WOOD\_ST 345\_F38

Sun 10/14/2018 to Mon 10/15/2018 **CANCELLED by ConEd 10/15/2018**  
 0201 Continuous 0900

Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED 4000 MW  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,October 16, 2018 to Thursday ,April 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FROST_BR-LONG_MTN_345_352					FWD	REV
					(Import)	(Export)
Sun 10/14/2018	to	Sun 10/14/2018	<u>UPDATED</u>	<u>by ISONE</u> <u>10/11/2018</u>	SCH - NE - NY	<b>1150 MW</b>
0700	Continuous	1800			Impacts Total Transfer Capability	250 MW
Work scheduled by: ISONE					TTC with All Lines In Service	1400 MW
SCH-NE-NYISO_LIMIT_800					FWD	
					(Import)	
Sun 10/14/2018	to	Sun 10/14/2018	<u>UPDATED</u>	<u>by ISONE</u> <u>10/11/2018</u>	SCH - NE - NY	<b>1000 MW</b>
0700	Continuous	1800			Impacts Total Transfer Capability	400 MW
Work scheduled by: ISONE					TTC with All Lines In Service	1400 MW
FRASER__-COOPERS__345_33					FWD	
					(Import)	
Mon 10/15/2018	to	Mon 10/15/2018	<u>CANCELLED</u>	<u>by NYSEG</u> <u>10/15/2018</u>	CENTRAL EAST - VC	<b>2395 MW</b>
0500	Continuous	0700			Impacts Total Transfer Capability	580 MW
Work scheduled by: NYSEG					TTC with All Lines In Service	2975 MW
SCH-IMO-NYISO_LIMIT_1200					FWD	
					(Import)	
Mon 10/15/2018	to	Thu 10/18/2018			SCH - OH - NY	<b>1500 MW</b>
0530	Continuous	1800			Impacts Total Transfer Capability	400 MW
Work scheduled by: IESO					TTC with All Lines In Service	1900 MW
SCH-NYISO-IMO_LIMIT_1200						REV
						(Export)
Mon 10/15/2018	to	Thu 10/18/2018			SCH - OH - NY	<b>1500 MW</b>
0530	Continuous	1800			Impacts Total Transfer Capability	250 MW
Work scheduled by: IESO					TTC with All Lines In Service	1750 MW
HUDSONTP-W49TH_ST_345_Y56					FWD	
					(Import)	
Mon 10/15/2018	to	Tue 10/16/2018			SCH - PJM_HTP	<b>0 MW</b>
0600	Continuous	1600			Impacts Total Transfer Capability	660 MW
Work scheduled by: PJM					TTC with All Lines In Service	660 MW
SCH-IMO-NYISO_LIMIT_1000					FWD	
					(Import)	
Mon 10/15/2018	to	Wed 10/31/2018	<u>UPDATED</u>	<u>by NYISO</u> <u>10/11/2018</u>	SCH - OH - NY	<b>1300 MW</b>
0600	Continuous	2359			Impacts Total Transfer Capability	600 MW
Work scheduled by: NGrid					TTC with All Lines In Service	1900 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,October 16, 2018 to Thursday ,April 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HOMR\_NYW-PIERC\_NY\_345\_48

Mon 10/15/2018 to Tue 10/16/2018 **CANCELLED** by PJM 10/12/2018  
0800 Continuous 2000

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2100 MW	1300 MW
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2100 MW	1300 MW

## MARCY\_345KV\_CSC

Wed 10/17/2018 to Thu 10/18/2018 **UPDATED** by NYPA 10/13/2018  
0500 Continuous 1930

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	2925 MW
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	2975 MW

## STONYRDG-HILLSIDE\_230\_72

Wed 10/17/2018 to Thu 10/18/2018  
0800 Continuous 1530

Work scheduled by: NYSEG

	FWD
	(Import)
DYSINGER EAST	2850 MW
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

## PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Thu 10/18/2018 to Sat 10/20/2018  
0001 0300

Work scheduled by:

	FWD
	(Import)
UPNY CONED	3800 MW
Impacts Total Transfer Capability	1900 MW
TTC with All Lines In Service	5700 MW

## SCH-IMO-NYISO\_LIMIT\_900

Thu 10/18/2018 to Fri 10/19/2018  
0500 Continuous 2300

Work scheduled by: NYISO

	FWD
	(Import)
SCH - OH - NY	1200 MW
Impacts Total Transfer Capability	700 MW
TTC with All Lines In Service	1900 MW

## FRASER\_-COOPERS\_345\_33

Fri 10/19/2018 to Fri 10/19/2018 **CANCELLED** by NYSEG 10/15/2018  
2000 Continuous 2059

Work scheduled by: NYSEG

	FWD
	(Import)
CENTRAL EAST - VC	2395 MW
Impacts Total Transfer Capability	580 MW
TTC with All Lines In Service	2975 MW

## PLSNTVLY-EFISHKIL\_345\_F36

Sat 10/20/2018 to Mon 10/22/2018 **UPDATED** by CONED 10/09/2018  
0301 Continuous 0300

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	4000 MW
Impacts Total Transfer Capability	1700 MW
TTC with All Lines In Service	5700 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,October 16, 2018 to Thursday ,April 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FROST_BR-LONG_MTN_345_352						FWD	REV
Sat 10/20/2018 to Sat 10/20/2018						(Import)	(Export)
0700	Continuous	1800				SCH - NE - NY	1150 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability	250 MW
						TTC with All Lines In Service	1400 MW
WOOD_ST_-PLSNTVLE_345_Y87						FWD	
Mon 10/22/2018 to Mon 10/22/2018						(Import)	
0301	Continuous	0330	<u>UPDATED</u>	<u>by CE</u>	<u>10/04/2018</u>	UPNY CONED	4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	1700 MW
						TTC with All Lines In Service	5700 MW
DUNWODIE_345KV_6						FWD	
Mon 10/22/2018 to Sat 12/22/2018						(Import)	
0301	Continuous	0200	<u>UPDATED</u>	<u>by CE</u>	<u>10/04/2018</u>	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8						FWD	
Mon 10/22/2018 to Sat 12/22/2018						(Import)	
0301	Continuous	0200	<u>UPDATED</u>	<u>by CE</u>	<u>10/04/2018</u>	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
PLSNTVLE-DUNWODIE_345_W90						FWD	
Mon 10/22/2018 to Sat 12/22/2018						(Import)	
0301	Continuous	0200	<u>UPDATED</u>	<u>by CE</u>	<u>10/04/2018</u>	UPNY CONED	4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	1700 MW
						TTC with All Lines In Service	5700 MW
SCRIBA_-VOLNEY_345_21						FWD	
Mon 10/22/2018 to Tue 10/23/2018						(Import)	
0730	Continuous	1930	<u>UPDATED</u>	<u>by NGRID</u>	<u>08/13/2018</u>	OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	5250 MW
LINDN_CG-LNDVFT_345_V-3022						FWD	REV
Mon 10/22/2018 to Thu 10/25/2018						(Import)	(Export)
0800	Continuous	1500				SCH - PJM_VFT	0 MW
Work scheduled by: PJM						Impacts Total Transfer Capability	315 MW
						TTC with All Lines In Service	315 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,October 16, 2018 to Thursday ,April 16, 2020

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## FROST\_BR-LONG\_MTN\_345\_352

Tue 10/23/2018 to Fri 10/26/2018  
0700 Continuous 1600

Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY	1150 MW	1600 MW
Impacts Total Transfer Capability	250 MW	0 MW
TTC with All Lines In Service	1400 MW	1600 MW

## SCH-NE-NYISO\_LIMIT\_800

Tue 10/23/2018 to Fri 10/26/2018  
0700 Continuous 1600

Work scheduled by: ISONE

	FWD (Import)
SCH - NE - NY	1000 MW
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	1400 MW

## LEEDS\_\_-HURLYAVE\_345\_301

Wed 10/24/2018 to Fri 11/16/2018  
0800 Continuous 1600

Work scheduled by: CHGE

UPDATED by CH 09/18/2018

	FWD (Import)
UPNY CONED	4100 MW
Impacts Total Transfer Capability	1600 MW
TTC with All Lines In Service	5700 MW

## DENNISON-NORFOLK\_115\_4

Wed 10/24/2018 to Wed 10/24/2018  
0830 Daily(No Weekends) 1600

Work scheduled by: NGrid

UPDATED by NGRID 10/11/2018

ARR: 38

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	150 MW	40 MW
Impacts Total Transfer Capability	40 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

## DENNISON-ROSEMNTB\_115\_2/22

Thu 10/25/2018 to Thu 10/25/2018  
0900 Daily(No Weekends) 1600

Work scheduled by: NGrid

ARR: 38

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	95 MW	40 MW
Impacts Total Transfer Capability	95 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

## KINTIGH\_-ROCHESTR\_345\_SR1-39

Mon 10/29/2018 to Fri 11/02/2018  
0500 Continuous 1700

Work scheduled by: NYPA

UPDATED by NYPA 10/10/2018

	FWD (Import)
DYSINGER EAST	1400 MW
Impacts Total Transfer Capability	1750 MW
TTC with All Lines In Service	3150 MW

## MOSES\_\_-ADIRNDCK\_230\_MAI

Mon 10/29/2018 to Fri 11/02/2018  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	2100 MW
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,October 16, 2018 to Thursday ,April 16, 2020

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5700MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-IMO-NYISO\_LIMIT\_1200**

FWD

Thu 11/01/2018 to Wed 11/21/2018 **UPDATED by NYISO 10/11/2018**

(Import)

0001 Continuous 1830

SCH - OH - NY

**1500 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1750 MW

Work scheduled by: NGrid

**PORTER\_-ROTTRDAM\_230\_31**

FWD

Fri 11/02/2018 to Fri 11/02/2018

(Import)

0600 Daily(No Weekends) 1600

CENTRAL EAST - VC

**2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

FWD

Sat 11/03/2018 to Sun 11/18/2018

(Import)

0001 Continuous 1800

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

**NEWBRDGE-DUFFYAVE\_345\_501**

FWD

Sat 11/03/2018 to Sun 11/18/2018

(Import)

0001 Continuous 1800

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

**NEWBRDGE\_345\_138\_BK\_1**

FWD

Sat 11/03/2018 to Sun 11/18/2018

(Import)

0001 Continuous 1800

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

**NEWBRDGE\_345\_138\_BK\_2**

FWD

Sat 11/03/2018 to Sun 11/18/2018

(Import)

0001 Continuous 1800

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

**BROWNFLS-TAYLORVL\_115\_3**

FWD

REV

Sat 11/03/2018 to Sat 11/03/2018

(Import) (Export)

0700 Continuous 1630

SCH - HQ\_CEDARS

**100 MW****100 MW**

Impacts Total Transfer Capability 99 MW

0 MW

TTC with All Lines In Service 199 MW

100 MW

Work scheduled by: NGrid

**ARR: 38**

**NYISO TRANSFER LIMITATIONS**

Tuesday ,October 16, 2018 to Thursday ,April 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BROWNFLS-TAYLORVL\_115\_3 & TAYLORVL-LOWVILLE\_115\_5 & CLIMAX\_\_-TAYLORVL\_115\_8**

Sat 11/03/2018 to Sat 11/03/2018  
0700 1630

Work scheduled by:

**ARR: 38**

SCH - HQ\_CEDARS

FWD REV  
(Import) (Export)

**120 MW 100 MW**

Impacts Total Transfer Capability 79 MW 0 MW

TTC with All Lines In Service 199 MW 100 MW

**TAYLORVL-LOWVILLE\_115\_5**

Sat 11/03/2018 to Sat 11/03/2018  
0700 Continuous 1630

Work scheduled by: NGrid

**ARR: 38**

SCH - HQ\_CEDARS

FWD REV  
(Import) (Export)

**199 MW 100 MW**

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 199 MW 100 MW

**GOETHALS\_345KV\_5**

Sun 11/04/2018 to Sun 11/04/2018  
0001 Continuous 0030

Work scheduled by: ConEd

**UPDATED by CONED 10/01/2018**

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

**LINDEN\_\_-GOETHALS\_230\_A2253**

Sun 11/04/2018 to Sun 11/11/2018  
0001 Continuous 0300

Work scheduled by: ConEd

**UPDATED by CONED 10/01/2018**

SCH - PJ - NY

FWD REV  
(Import) (Export)

**2600 MW 1300 MW**

Impacts Total Transfer Capability 150 MW 0 MW

TTC with All Lines In Service 2750 MW 1300 MW

**LINDEN\_\_-GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402**

Sun 11/04/2018 to Sun 11/11/2018  
0001 0300

Work scheduled by:

SCH - PJ - NY

FWD REV  
(Import) (Export)

**2000 MW 1300 MW**

Impacts Total Transfer Capability 750 MW 0 MW

TTC with All Lines In Service 2750 MW 1300 MW

**LINDEN\_\_-GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_\_-FARRAGUT\_345\_C3403**

Sun 11/04/2018 to Sun 11/11/2018  
0001 0300

Work scheduled by:

SCH - PJ - NY

FWD REV  
(Import) (Export)

**2000 MW 1300 MW**

Impacts Total Transfer Capability 750 MW 0 MW

TTC with All Lines In Service 2750 MW 1300 MW

**LINDEN\_\_-GOETHALS\_230\_A2253 & MARION\_\_-FARRAGUT\_345\_C3403**

Sun 11/04/2018 to Sun 11/11/2018  
0001 0300

Work scheduled by:

SCH - PJ - NY

FWD REV  
(Import) (Export)

**2000 MW 1300 MW**

Impacts Total Transfer Capability 750 MW 0 MW

TTC with All Lines In Service 2750 MW 1300 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,October 16, 2018 to Thursday ,April 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_\_345\_230\_AT4

Mon 11/05/2018 to Fri 11/09/2018 UPDATED by NYPA 10/05/2018  
0400 Continuous 2300

Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	<b>1750 MW</b>	<b>1800 MW</b>
Impacts Total Transfer Capability	0 MW	100 MW
TTC with All Lines In Service	1750 MW	1900 MW

## SCH-NYISO-NE\_LIMIT\_1100

Mon 11/05/2018 to Sat 11/24/2018  
0600 Continuous 1900

Work scheduled by: ISONE

	REV (Export)
SCH - NE - NY	<b>1300 MW</b>
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	1600 MW

## MOSES\_\_-ADIRNDCK\_230\_MAL

Mon 11/05/2018 to Fri 11/09/2018  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	<b>2300 MW</b>
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## HOMR\_NYW-PIERC\_NY\_345\_48

Mon 11/05/2018 to Fri 11/09/2018  
0800 Continuous 2000

Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJ - NY	<b>2500 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	250 MW	0 MW
TTC with All Lines In Service	2750 MW	1300 MW

## SCH-HQ-NYISO\_LIMIT\_0

Sat 11/10/2018 to Sun 11/11/2018  
0600 Continuous 1759

Work scheduled by: HQ

	FWD (Import)
SCH - HQ - NY	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW
TTC with All Lines In Service	1500 MW

## GOETHALS\_345KV\_5

Sun 11/11/2018 to Sun 11/11/2018 UPDATED by CONED 10/01/2018  
0230 Continuous 0300

Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

## FROST\_BR-LONG\_MTN\_345\_352

Sun 11/11/2018 to Sun 11/11/2018  
0700 Continuous 1800

Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1300 MW</b>	<b>1600 MW</b>
Impacts Total Transfer Capability	100 MW	0 MW
TTC with All Lines In Service	1400 MW	1600 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NE-NYISO\_LIMIT\_1000

Sun 11/11/2018 to Sun 11/11/2018  
0700 Continuous 1800  
Work scheduled by: ISONE

FWD  
(Import)  
SCH - NE - NY 1200 MW  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1400 MW

## NIAGARA\_KINTIGH\_345\_NS1-38

Tue 11/13/2018 to Fri 11/16/2018  
0700 Continuous 1600  
Work scheduled by: NYSEG

FWD  
(Import)  
DYSINGER EAST 1700 MW  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## SCH-IMO-NYISO\_LIMIT\_1050

Thu 11/15/2018 to Wed 11/21/2018  
0500 Continuous 1830  
Work scheduled by: NYPA

FWD  
(Import)  
SCH - OH - NY 1350 MW  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1750 MW

## SCH-IMO-NYISO\_LIMIT\_1350

Thu 11/15/2018 to Thu 12/20/2018  
0500 Continuous 2359  
Work scheduled by: NYPA

FWD  
(Import)  
SCH - OH - NY 1650 MW  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 1750 MW

## MARCY\_345KV\_CSC

Fri 11/16/2018 to Sat 11/17/2018  
0500 Continuous 1730  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC 2925 MW  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

## MARCY\_765\_345\_AT2

Fri 11/16/2018 to Sat 11/17/2018  
0500 Continuous 1730  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 1700 MW  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

ARR: 19

## DUNWODIE-SHORE\_RD\_345\_Y50

Mon 11/19/2018 to Tue 11/20/2018  
0001 Continuous 0300  
Work scheduled by: ConEd

FWD  
(Import)  
CONED - LIPA 800 MW  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,October 16, 2018 to Thursday ,April 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## DUNWODIE\_345KV\_4

FWD

Mon 11/19/2018 to Tue 11/20/2018

(Import)

0001 Continuous 0300

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## SHORE\_RD\_345\_138\_BK 1

FWD

Mon 11/19/2018 to Tue 11/20/2018

(Import)

0001 Continuous 0300

CONED - LIPA

1350 MW

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: ConEd

## SHORE\_RD\_345\_138\_BK 2

FWD

Mon 11/19/2018 to Tue 11/20/2018

(Import)

0001 Continuous 0300

CONED - LIPA

1350 MW

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: ConEd

## MOSES -ADIRNDCK\_230\_MAL

FWD

Mon 11/19/2018 to Wed 11/21/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## LONG\_MTN-PLSNTVLY\_345\_398

FWD

REV

Mon 11/26/2018 to Thu 12/06/2018

UPDATEDby CONED 10/09/2018

(Import) (Export)

0001 Continuous 0030

SCH - NE - NY

700 MW

1300 MW

Impacts Total Transfer Capability 700 MW

300 MW

TTC with All Lines In Service 1400 MW

1600 MW

Work scheduled by: ConEd

## LONG\_MTN-PLSNTVLY\_345\_398

FWD

REV

Mon 11/26/2018 to Thu 12/06/2018

UPDATEDby CONED 10/09/2018

(Import) (Export)

0001 Continuous 0030

SCH - NPX\_1385

100 MW

100 MW

Impacts Total Transfer Capability 100 MW

100 MW

TTC with All Lines In Service 200 MW

200 MW

Work scheduled by: ConEd

## SCH-NYISO-NE\_LIMIT\_400

REV

Mon 11/26/2018 to Thu 12/06/2018

(Export)

0001 Continuous 0030

SCH - NE - NY

600 MW

Impacts Total Transfer Capability

1000 MW

TTC with All Lines In Service

1600 MW

Work scheduled by: ISONE

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCRIBA__-VOLNEY__345_21</b>				FWD	
Mon 11/26/2018	to	Wed 11/28/2018	<u>UPDATED</u> <u>by NGRID</u> <u>08/14/2018</u>	(Import)	
0700	Continuous	1730		OSWEGO EXPORT	<b>5250 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	0 MW
				TTC with All Lines In Service	5250 MW
<b>MOSES__-ADIRNDCK_230_MA2</b>				FWD	
Mon 11/26/2018	to	Fri 11/30/2018		(Import)	
0700	Continuous	1530		MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>				FWD	REV
Mon 11/26/2018	to	Fri 12/07/2018		(Import)	(Export)
0700	Continuous	1600		SCH - NPX_CSC	<b>0 MW 0 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability	330 MW 330 MW
				TTC with All Lines In Service	330 MW 330 MW
<b>HURLYAVE-ROSETON__345_303</b>				FWD	
Mon 11/26/2018	to	Fri 12/21/2018		(Import)	
0800	Continuous	1600		UPNY CONED	<b>4100 MW</b>
Work scheduled by: CHGE				Impacts Total Transfer Capability	1600 MW
				TTC with All Lines In Service	5700 MW
<b>DUNWODIE-MOTTHAVN_345_72</b>				FWD	
Sun 12/02/2018	to	Thu 12/06/2018		(Import)	
0001	Continuous	0159		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_7</b>				FWD	
Sun 12/02/2018	to	Thu 12/06/2018		(Import)	
0001	Continuous	0159		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
<b>MOSES__-ADIRNDCK_230_MA2</b>				FWD	
Mon 12/03/2018	to	Fri 12/07/2018		(Import)	
0700	Continuous	1530		MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,October 16, 2018 to Thursday ,April 16, 2020

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 5700MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE-SHORE\_RD\_345\_Y50**

FWD

Thu 12/06/2018 to Wed 12/12/2018

(Import)

0201 Continuous 0200

CONED - LIPA

**800 MW**

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: ConEd

**DUNWODIE\_345KV\_4**

FWD

Thu 12/06/2018 to Wed 12/12/2018

(Import)

0201 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**SHORE\_RD\_345\_138\_BK 1**

FWD

Thu 12/06/2018 to Wed 12/12/2018

(Import)

0201 Continuous 0200

CONED - LIPA

**1350 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: ConEd

**SHORE\_RD\_345\_138\_BK 2**

FWD

Thu 12/06/2018 to Wed 12/12/2018

(Import)

0201 Continuous 0200

CONED - LIPA

**1350 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: ConEd

**MOSES\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 12/10/2018 to Fri 12/14/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**WOOD\_ST\_-PLSNTVLE\_345\_Y87**

FWD

Sat 12/15/2018 to Sat 01/26/2019

(Import)

0001 Continuous 0200

**UPDATED****by CE****10/04/2018**

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**MARCY\_\_\_\_765\_345\_AT2**

FWD

Mon 12/17/2018 to Fri 12/21/2018

(Import)

0500 Continuous 1730

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19**

# NYISO TRANSFER LIMITATIONS

Tuesday ,October 16, 2018 to Thursday ,April 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EFISHKIL-WOOD_ST__345_F39</b>					FWD	
Thu 12/20/2018	to	Thu 12/20/2018	<u>UPDATED</u>	<u>by CE</u>	<u>10/04/2018</u>	(Import)
0200	Continuous	0230				
Work scheduled by: ConEd					UPNY CONED	<b>4000 MW</b>
					Impacts Total Transfer Capability	1700 MW
					TTC with All Lines In Service	5700 MW
<b>MOSES__-ADIRNDCK_230_MAl</b>					FWD	
Wed 12/26/2018	to	Fri 12/28/2018				(Import)
0700	Continuous	1530				
Work scheduled by: NYPA					MOSES SOUTH	<b>2300 MW</b>
					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
<b>BECK__-NIAGARA_230_PA27</b>					FWD	REV
Sat 12/29/2018	to	Sat 12/29/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/10/2018</u>	(Import) (Export)
0500	Continuous	1700				
Work scheduled by: NYPA					SCH - OH - NY	<b>1750 MW 1900 MW</b>
					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	1750 MW 1900 MW
<b>HURLYAVE-ROSETON__345_303</b>					FWD	
Wed 01/02/2019	to	Fri 01/11/2019			<u>08/20/2018</u>	(Import)
0800	Continuous	1600				
Work scheduled by: CHGE					UPNY CONED	<b>4100 MW</b>
					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	5700 MW
<b>SCH-NE-NYISO_LIMIT_1100</b>					FWD	
Mon 01/07/2019	to	Thu 01/10/2019				(Import)
0700	Continuous	1600				
Work scheduled by: ISONE					SCH - NE - NY	<b>1300 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1400 MW
<b>MOSES__-ADIRNDCK_230_MAl</b>					FWD	
Mon 01/07/2019	to	Fri 01/11/2019				(Import)
0700	Continuous	1500				
Work scheduled by: NYPA					MOSES SOUTH	<b>2300 MW</b>
					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
<b>MOSES__-ADIRNDCK_230_MA2</b>					FWD	
Mon 01/14/2019	to	Fri 01/18/2019				(Import)
0700	Continuous	1500				
Work scheduled by: NYPA					MOSES SOUTH	<b>2300 MW</b>
					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,October 16, 2018 to Thursday ,April 16, 2020

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5700MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**LEEDS\_\_\_-HURLYAVE\_345\_301**

FWD

Mon 01/14/2019 to Fri 01/25/2019

08/20/2018

(Import)

0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 5700 MW

**EFISHKIL-WOOD\_ST\_345\_F39**

FWD

Sat 01/19/2019 to Sat 01/19/2019

UPDATEDby CE10/04/2018

(Import)

0130 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

**DUNWODIE\_345KV\_6**

FWD

Mon 01/21/2019 to Mon 01/28/2019

UPDATEDby CE10/04/2018

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_8**

FWD

Mon 01/21/2019 to Mon 01/28/2019

UPDATEDby CE10/04/2018

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**PLSNTVLE-DUNWODIE\_345\_W90**

FWD

Mon 01/21/2019 to Mon 01/28/2019

UPDATEDby CE10/04/2018

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 01/21/2019 to Fri 01/25/2019

(Import)

0700 Continuous 1500

Work scheduled by: NYPA

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MAI**

FWD

Mon 01/28/2019 to Fri 02/01/2019

(Import)

0700 Continuous 1500

Work scheduled by: NYPA

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Tue 01/29/2019 to Sun 02/03/2019  
0001 0300

Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1900 MW  
TTC with All Lines In Service 5700 MW

---

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Mon 02/04/2019 to Thu 02/07/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

---

**ADIRNDCK-CHASLAKE\_230\_13**

Thu 02/07/2019 to Thu 02/07/2019  
0800 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

---

**MOSES\_\_-ADIRNDCK\_230\_MA1**

Fri 02/08/2019 to Fri 02/08/2019  
0800 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

---

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Mon 02/11/2019 to Fri 02/15/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

---

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Tue 02/19/2019 to Fri 02/22/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

---

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Sun 02/24/2019 to Sun 02/24/2019  
0001 2359

Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1900 MW  
TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,October 16, 2018 to Thursday ,April 16, 2020

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LONG\_MTN-PLSNTVLY\_345\_398

Sun 02/24/2019 to Sun 05/19/2019 UPDATED by CE 09/14/2018

0001 Continuous 2359

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	<b>700 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	700 MW	300 MW
TTC with All Lines In Service	1400 MW	1600 MW

## LONG\_MTN-PLSNTVLY\_345\_398

Sun 02/24/2019 to Sun 05/19/2019 UPDATED by CE 09/14/2018

0001 Continuous 2359

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

## PLSNTVLY-EFISHKIL\_345\_F37

Mon 02/25/2019 to Tue 02/26/2019 UPDATED by CE 09/14/2018

0001 Continuous 0300

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>4000 MW</b>
Impacts Total Transfer Capability	1700 MW
TTC with All Lines In Service	5700 MW

## MOSES\_\_-ADIRNDCK\_230\_MAI

Mon 03/04/2019 to Fri 03/08/2019

0700 Continuous 1500

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2300 MW</b>
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## MOSES\_\_-ADIRNDCK\_230\_MAI

Mon 03/11/2019 to Fri 03/15/2019

0700 Continuous 1500

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2300 MW</b>
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## LEEDS\_\_345\_LEEDS SVC

Mon 03/11/2019 to Fri 03/22/2019

0800 Continuous 1600

Work scheduled by: NGrid

	FWD
	(Import)
CENTRAL EAST - VC	<b>2950 MW</b>
Impacts Total Transfer Capability	25 MW
TTC with All Lines In Service	2975 MW

## MARCY\_\_765\_345\_AT1

Mon 03/18/2019 to Fri 03/22/2019

0500 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>1750 MW</b>
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	3150 MW

ARR: 19

# NYISO TRANSFER LIMITATIONS

Tuesday ,October 16, 2018 to Thursday ,April 16, 2020

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PLSNTVLY-EFISHKIL\_345\_F37

Sat 03/30/2019 to Wed 04/03/2019  
0001 Continuous 0300

Work scheduled by: ConEd

UPDATED by CE 09/14/2018

UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1700 MW  
TTC with All Lines In Service 5700 MW

FWD  
(Import)

## MARCY\_345KV\_CSC

Mon 04/01/2019 to Sun 04/07/2019  
0500 Continuous 1730

Work scheduled by: NYPA

CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

FWD  
(Import)

## VOLNEY\_-MARCY\_345\_19

Mon 04/01/2019 to Wed 04/10/2019  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC **2825 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 2975 MW

FWD  
(Import)

## VOLNEY\_-MARCY\_345\_19

Mon 04/01/2019 to Wed 04/10/2019  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

OSWEGO EXPORT **4900 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 5250 MW

FWD  
(Import)

## PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Sun 04/07/2019 to Mon 04/08/2019  
0001 0030

Work scheduled by:

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1900 MW  
TTC with All Lines In Service 5700 MW

FWD  
(Import)

## LINDN\_CG-LNDVFT\_345\_V-3022

Sun 04/07/2019 to Fri 04/12/2019  
1400 Continuous 1800

Work scheduled by: PJM

SCH - PJM\_VFT **0 MW** **0 MW**  
Impacts Total Transfer Capability 315 MW 315 MW  
TTC with All Lines In Service 315 MW 315 MW

FWD REV  
(Import) (Export)

## MARCY\_345KV\_CSC

Thu 04/11/2019 to Wed 04/17/2019  
0500 Continuous 1730

Work scheduled by: NYPA

CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

FWD  
(Import)

# NYISO TRANSFER LIMITATIONS

Tuesday ,October 16, 2018 to Thursday ,April 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY\_\_\_-EDIC\_\_\_345\_UE1-7

FWD

Thu 04/11/2019 to Sat 04/20/2019

(Import)

0500 Continuous 1730

OSWEGO EXPORT

5250 MW

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

ARR: 19&16

GILBOA\_\_\_-N.SCTLND\_345\_GNS-1

FWD

Fri 04/12/2019 to Fri 04/12/2019

(Import)

1330 Continuous 1530

CENTRAL EAST - VC

2520 MW

Impacts Total Transfer Capability 455 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

EDIC\_\_\_-FRASER\_\_\_345\_EF24-40

FWD

Mon 04/22/2019 to Fri 04/26/2019

(Import)

0500 Continuous 1730

CENTRAL EAST - VC

2500 MW

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

MARCY\_\_\_765\_345\_AT2

FWD

Mon 04/22/2019 to Fri 04/26/2019

(Import)

0500 Continuous 1730

MOSES SOUTH

1700 MW

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

ARR: 19

FRASANNX-COOPERS\_\_\_345\_UCC2-41

FWD

Mon 04/29/2019 to Fri 05/03/2019

(Import)

0500 Continuous 1730

UPDATED by NYPA 08/22/2018

CENTRAL EAST - VC

2500 MW

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

ARR: 19

MARCY\_\_\_-FRASANNX\_345\_UCC2-41

FWD

Mon 04/29/2019 to Fri 05/03/2019

(Import)

0500 Continuous 1730

UPDATED by NYPA 08/22/2018

CENTRAL EAST - VC

2500 MW

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

ARR: 19

MOSES\_\_\_-ADIRNDCK\_230\_MAI

FWD

Mon 04/29/2019 to Fri 05/03/2019

(Import)

0700 Continuous 1500

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## ROSETON\_-ROCKTVRN\_345\_311

FWD

Mon 05/06/2019 to Sat 06/01/2019

(Import)

0800 Continuous 1600

UPNY CONED

4400 MW

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: CHGE

## ADIRNDCK-PORTER\_230\_12

FWD

Mon 05/20/2019 to Fri 05/24/2019

(Import)

0700 Continuous 1530

MOSES SOUTH

2100 MW

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## PANNELL\_-CLAY\_345\_1

FWD

Mon 05/20/2019 to Fri 05/24/2019

(Import)

0700 Continuous 1530

WEST CENTRAL

1300 MW

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

## PANNELL\_-CLAY\_345\_2

FWD

Mon 06/03/2019 to Fri 06/07/2019

(Import)

0700 Continuous 1530

WEST CENTRAL

1300 MW

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

## LEEDS\_-HURLYAVE\_345\_301

FWD

Mon 08/05/2019 to Fri 08/30/2019

(Import)

0800 Continuous 1600

UPNY CONED

4100 MW

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: CHGE

## MOSES\_-ADIRNDCK\_230\_MA1

FWD

Mon 08/12/2019 to Mon 08/12/2019

(Import)

0700 Continuous 1459

MOSES SOUTH

2100 MW

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## MARCY\_-N.SCTLND\_345\_18

FWD

Wed 09/04/2019 to Wed 09/04/2019

(Import)

0500 Continuous 1730

CENTRAL EAST - VC

2090 MW

Impacts Total Transfer Capability 885 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Wed 09/04/2019 to Wed 09/04/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## ADIRNDCK-PORTER\_\_\_\_230\_12

Wed 09/04/2019 to Wed 09/04/2019  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## ADIRNDCK-CHASLAKE\_230\_13

Thu 09/05/2019 to Thu 09/05/2019  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## NIAGARA\_-ROCHESTR\_345\_NR2

Mon 09/09/2019 to Sat 09/21/2019  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

## LEEDS\_\_\_\_345KV\_R395

Mon 09/09/2019 to Mon 09/09/2019  
0700 Continuous 0730

Work scheduled by: NYPA

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1900 MW  
TTC with All Lines In Service 5700 MW

## GILBOA\_-LEEDS\_\_\_\_345\_GL3

Mon 09/09/2019 to Fri 09/27/2019  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2200 MW**  
Impacts Total Transfer Capability 775 MW  
TTC with All Lines In Service 2975 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 09/16/2019 to Fri 09/20/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## ROCHESTR-PANNELL\_\_345\_RP2

Mon 09/23/2019 to Mon 09/30/2019  
0500 Continuous 1700  
Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## KINTIGH\_-ROCHESTR\_345\_SR1-39

Mon 09/23/2019 to Fri 09/27/2019  
0600 Continuous 1700  
Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

## LEEDS\_\_345KV\_R395

Fri 09/27/2019 to Fri 09/27/2019  
1700 Continuous 1730  
Work scheduled by: NYPA

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1900 MW  
TTC with All Lines In Service 5700 MW

## CLAY\_-EDIC\_\_345\_1-16

Mon 09/30/2019 to Fri 10/04/2019  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

## CLAY\_-EDIC\_\_345\_2-15

Mon 10/07/2019 to Thu 10/17/2019  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

## HURLYAVE-ROSETON\_\_345\_303

Mon 10/21/2019 to Sat 11/16/2019  
0800 Continuous 1600  
Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 5700 MW

## PANNELL\_-CLAY\_\_345\_2

Wed 11/06/2019 to Fri 11/22/2019  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,October 16, 2018 to Thursday ,April 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

FWD

Tue 11/12/2019 to Fri 11/15/2019

(Import)

0700 Continuous 1500

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

FWD

Mon 11/18/2019 to Fri 11/22/2019

(Import)

0700 Continuous 1500

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA