

# NYISO TRANSFER LIMITATIONS

Sunday ,October 21, 2018 to Tuesday ,April 21, 2020

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Fri 02/15/2019 EXT FORCE by CE 10/07/2018

0001 Continuous 2359

Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	1950 MW	1200 MW
Impacts Total Transfer Capability	150 MW	100 MW
TTC with All Lines In Service	2100 MW	1300 MW

## HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Fri 02/15/2019

0001 2359

Work scheduled by:

	FWD (Import)	REV (Export)
SCH - PJ - NY	1800 MW	1100 MW
Impacts Total Transfer Capability	300 MW	200 MW
TTC with All Lines In Service	2100 MW	1300 MW

## MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Fri 02/15/2019 EXT FORCE by CE 10/07/2018

0001 Continuous 2359

Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	1950 MW	1200 MW
Impacts Total Transfer Capability	150 MW	100 MW
TTC with All Lines In Service	2100 MW	1300 MW

## STLAWRNC-MOSES\_\_\_\_230\_L33P

Mon 04/30/2018 to Fri 12/31/2021 EXT FORCE by IESO 08/21/2018

0456 Continuous 2359

Work scheduled by: IESO

	FWD (Import)	REV (Export)
SCH - OH - NY	1900 MW	1750 MW
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	1900 MW	1750 MW

## MARCY\_\_\_\_765\_345\_AT2

Wed 09/19/2018 to Sat 10/27/2018 EXT FORCE by NYPA 10/11/2018

0001 Continuous 1730

Work scheduled by: NYPA

ARR: 19

	FWD (Import)
MOSES SOUTH	1700 MW
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

## EGRDNCTY\_345\_138\_AT1

Sat 10/06/2018 to Sat 11/03/2018 UPDATED by CE 10/03/2018

0130 Continuous 0300

Work scheduled by: LI

	FWD (Import)
CONED - LIPA	1250 MW
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	1500 MW

## EGRDNCTY\_345\_138\_AT2

Sat 10/06/2018 to Sat 11/03/2018 UPDATED by CE 10/03/2018

0130 Continuous 0300

Work scheduled by: LI

	FWD (Import)
CONED - LIPA	1250 MW
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	1500 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 21, 2018 to Tuesday ,April 21, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK_-EGRDNCTR_345_Y49</b>						FWD	
Sat 10/06/2018	to	Sat 11/03/2018	<u>UPDATED</u>	<u>by CE</u>	<u>10/03/2018</u>	(Import)	
0130	Continuous	0300				<b>775 MW</b>	
Work scheduled by: LI						CONED - LIPA	
						Impacts Total Transfer Capability	725 MW
						TTC with All Lines In Service	1500 MW
<b>CHAT_DC_GC2</b>						FWD	
Tue 10/09/2018	to	Fri 11/23/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>10/04/2018</u>	(Import)	
0500	Continuous	2000				<b>2850 MW</b>	
Work scheduled by: HQ						MOSES SOUTH	
						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC2</b>						REV	
Tue 10/09/2018	to	Fri 11/23/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>10/04/2018</u>	(Export)	
0500	Continuous	2000				<b>500 MW</b>	
Work scheduled by: HQ						SCH - HQ - NY	
						Impacts Total Transfer Capability	500 MW
						TTC with All Lines In Service	1000 MW
<b>S.RIPLEY-DUNKIRK_230_68</b>						FWD	REV
Fri 10/12/2018	to	Mon 10/22/2018	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/10/2018</u>	(Import)	(Export)
2001	Continuous	0759				<b>1950 MW</b>	<b>1300 MW</b>
Work scheduled by: PJM						SCH - PJ - NY	
						Impacts Total Transfer Capability	150 MW 0 MW
						TTC with All Lines In Service	2100 MW 1300 MW
<b>CHATGUAY-MASSENA_765_7040</b>						FWD	
Sat 10/13/2018	to	Sat 10/27/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/20/2018</u>	(Import)	
0100	Continuous	1730				<b>1550 MW</b>	
Work scheduled by: NYPA						MOSES SOUTH	
						Impacts Total Transfer Capability	1600 MW
						TTC with All Lines In Service	3150 MW
<b>CHATGUAY-MASSENA_765_7040</b>						FWD	REV
Sat 10/13/2018	to	Sat 10/27/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/20/2018</u>	(Import)	(Export)
0100	Continuous	1730				<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: NYPA						SCH - HQ - NY	
						Impacts Total Transfer Capability	1500 MW 1000 MW
						TTC with All Lines In Service	1500 MW 1000 MW
<b>MARCY_765_345_AT1</b>						FWD	
Sat 10/13/2018	to	Sat 10/27/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/20/2018</u>	(Import)	
0100	Continuous	1730				<b>1750 MW</b>	
Work scheduled by: NYPA						MOSES SOUTH	
						Impacts Total Transfer Capability	1400 MW
						TTC with All Lines In Service	3150 MW
						ARR: 19	

# NYISO TRANSFER LIMITATIONS

Sunday ,October 21, 2018 to Tuesday ,April 21, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA_-MARCY_765_MSU1</b>						FWD	
Sat 10/13/2018	to	Sat 10/27/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/20/2018</u>	(Import)	
0100	Continuous	1730				CENTRAL EAST - VC	<b>2265 MW</b>
						Impacts Total Transfer Capability	710 MW
Work scheduled by: NYPA						TTC with All Lines In Service	2975 MW
<hr/>							
<b>MASSENA_-MARCY_765_MSU1</b>						FWD	
Sat 10/13/2018	to	Sat 10/27/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/20/2018</u>	(Import)	
0100	Continuous	1730				MOSES SOUTH	<b>500 MW</b>
						Impacts Total Transfer Capability	2650 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW
<hr/>							
<b>MASSENA_-MARCY_765_MSU1</b>						FWD	REV
Sat 10/13/2018	to	Sat 10/27/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/20/2018</u>	(Import) (Export)	
0100	Continuous	1730				SCH - HQ - NY	<b>475 MW 1000 MW</b>
						Impacts Total Transfer Capability	1025 MW 0 MW
Work scheduled by: NYPA						TTC with All Lines In Service	1500 MW 1000 MW
<hr/>							
<b>MASSENA_-MARCY_765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>						FWD	
Sat 10/13/2018	to	Sat 10/27/2018				(Import)	
0100		1730				MOSES SOUTH	<b>500 MW</b>
						Impacts Total Transfer Capability	2650 MW
Work scheduled by:						TTC with All Lines In Service	3150 MW
<hr/>							
<b>MOSES_-MASSENA_230_MMS1 &amp; MOSES_-MASSENA_230_MMS2</b>						FWD	REV
Sat 10/13/2018	to	Sat 10/27/2018				(Import) (Export)	
0100		1730				SCH - HQ - NY	<b>850 MW 0 MW</b>
						Impacts Total Transfer Capability	650 MW 1000 MW
Work scheduled by:						TTC with All Lines In Service	1500 MW 1000 MW
<hr/>							
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2 &amp; MOSES_-MASSENA_230_MMS1 &amp; MOSES_-MASSENA_230_MMS2</b>						FWD	
						(Import)	
Sat 10/13/2018	to	Sat 10/27/2018				MOSES SOUTH	<b>1950 MW</b>
0500		1730				Impacts Total Transfer Capability	1200 MW
Work scheduled by:						TTC with All Lines In Service	3150 MW
<hr/>							
<b>CHAT_DC_GC1</b>						FWD	
Sat 10/13/2018	to	Sat 10/27/2018				(Import)	
0500	Continuous	2000				MOSES SOUTH	<b>2850 MW</b>
						Impacts Total Transfer Capability	300 MW
Work scheduled by: HQ						TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 21, 2018 to Tuesday ,April 21, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CHAT\_DC\_GC1

Sat 10/13/2018 to Sat 10/27/2018  
0500 Continuous 2000

Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

REV  
(Export)

## CHAT\_DC\_GC1 &amp; CHAT\_DC\_GC2

Sat 10/13/2018 to Sat 10/27/2018  
0500 2000

Work scheduled by:

MOSES SOUTH  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 3150 MW

FWD  
(Import)

## CHAT\_DC\_GC1 &amp; CHAT\_DC\_GC2

Sat 10/13/2018 to Sat 10/27/2018  
0500 2000

Work scheduled by:

SCH - HQ - NY  
Impacts Total Transfer Capability 130 MW  
TTC with All Lines In Service 1500 MW

FWD  
(Import)

REV  
(Export)

## SCH-IMO-NYISO\_LIMIT\_1200

Mon 10/15/2018 to Thu 10/18/2018  
0530 Continuous 1800

Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1900 MW

FWD  
(Import)

## SCH-NYISO-IMO\_LIMIT\_1200

Mon 10/15/2018 to Thu 10/18/2018  
0530 Continuous 1800

Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1750 MW

REV  
(Export)

## HUDSONTP-W49TH\_ST\_345\_Y56

Mon 10/15/2018 to Tue 10/16/2018  
0600 Continuous 1600

Work scheduled by: PJM

SCH - PJM\_HTP  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

FWD  
(Import)

## SCH-IMO-NYISO\_LIMIT\_1000

Mon 10/15/2018 to Wed 10/31/2018  
0600 Continuous 2359

Work scheduled by: NGrid

SCH - OH - NY  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1900 MW

FWD  
(Import)

UPDATED by NYISO 10/11/2018

# NYISO TRANSFER LIMITATIONS

Sunday ,October 21, 2018 to Tuesday ,April 21, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MARCY\_\_\_\_345KV\_CSC

FWD

Wed 10/17/2018 to Thu 10/18/2018 UPDATED by NYPA 10/20/2018  
0500 Continuous 1930

(Import)

Work scheduled by: NYPA

CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

## STONYRDG-HILLSIDE\_230\_72

FWD

Wed 10/17/2018 to Thu 10/18/2018 CANCELLED by NYSEG 10/17/2018  
0800 Continuous 1530

(Import)

Work scheduled by: NYSEG

DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

## PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

FWD

Thu 10/18/2018 to Sat 10/20/2018  
0001 0300

(Import)

Work scheduled by:

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1900 MW  
TTC with All Lines In Service 5700 MW

## SCH-IMO-NYISO\_LIMIT\_900

FWD

Thu 10/18/2018 to Fri 10/19/2018  
0500 Continuous 2300

(Import)

Work scheduled by: NYISO

SCH - OH - NY **1200 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1900 MW

## PLSNTVLY-EFISHKIL\_345\_F36

FWD

Sat 10/20/2018 to Mon 10/22/2018 UPDATED by CONED 10/19/2018  
0301 Continuous 0300

(Import)

Work scheduled by: ConEd

UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1700 MW  
TTC with All Lines In Service 5700 MW

## FROST\_BR-LONG\_MTN\_345\_352

FWD

REV

Sat 10/20/2018 to Sat 10/20/2018  
0700 Continuous 1800

(Import) (Export)

Work scheduled by: ISONE

SCH - NE - NY **1150 MW 1600 MW**  
Impacts Total Transfer Capability 250 MW 0 MW  
TTC with All Lines In Service 1400 MW 1600 MW

## WOOD\_ST\_-PLSNTVLE\_345\_Y87

FWD

Mon 10/22/2018 to Tue 10/23/2018 UPDATED by CE 10/04/2018  
0301 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1700 MW  
TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 21, 2018 to Tuesday ,April 21, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_6**

FWD

Mon 10/22/2018 to Sat 12/22/2018 UPDATED by CE 10/04/2018

(Import)

0301 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**DUNWODIE\_345KV\_8**

FWD

Mon 10/22/2018 to Sat 12/22/2018 UPDATED by CE 10/04/2018

(Import)

0301 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**PLSNTVLE-DUNWODIE\_345\_W90**

FWD

Mon 10/22/2018 to Sat 12/22/2018 UPDATED by CE 10/04/2018

(Import)

0301 Continuous 0200

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**SCH-IMO-NYISO\_LIMIT\_1500**

FWD

Mon 10/22/2018 to Fri 11/02/2018

(Import)

0500 Continuous 1600

SCH - OH - NY

**1800 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 1900 MW

Work scheduled by: IESO

**SCH-NYISO-IMO\_LIMIT\_1300**

REV

Mon 10/22/2018 to Fri 11/02/2018

(Export)

0500 Continuous 1600

SCH - OH - NY

**1600 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1750 MW

Work scheduled by: IESO

**SCRIBA\_-VOLNEY\_345\_21**

FWD

Mon 10/22/2018 to Tue 10/23/2018 UPDATED by NGRID 08/13/2018

(Import)

0730 Continuous 1930

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

**LINDN\_CG-LNDVFT\_345\_V-3022**

FWD

REV

Mon 10/22/2018 to Thu 10/25/2018

(Import) (Export)

0800 Continuous 1500

SCH - PJM\_VFT

**0 MW****0 MW**

Impacts Total Transfer Capability 315 MW 315 MW

TTC with All Lines In Service 315 MW 315 MW

Work scheduled by: PJM

# NYISO TRANSFER LIMITATIONS

Sunday ,October 21, 2018 to Tuesday ,April 21, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-IMO-NYISO\_LIMIT\_1450**

Mon 10/22/2018 to Fri 10/26/2018  
0800 Continuous 1800  
Work scheduled by: IESO

FWD  
(Import)  
SCH - OH - NY **1750 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1900 MW

**S.RIPLEY-DUNKIRK\_\_230\_68**

Mon 10/22/2018 to Fri 12/14/2018  
0800 Continuous 2000  
Work scheduled by: PJM

FWD REV  
(Import) (Export)  
SCH - PJ - NY **1950 MW 1300 MW**  
Impacts Total Transfer Capability 150 MW 0 MW  
TTC with All Lines In Service 2100 MW 1300 MW

**FROST\_BR-LONG\_MTN\_345\_352**

Tue 10/23/2018 to Fri 10/26/2018  
0700 Continuous 1600  
Work scheduled by: ISONE

FWD REV  
(Import) (Export)  
SCH - NE - NY **1150 MW 1600 MW**  
Impacts Total Transfer Capability 250 MW 0 MW  
TTC with All Lines In Service 1400 MW 1600 MW

**SCH-NE-NYISO\_LIMIT\_800**

Tue 10/23/2018 to Fri 10/26/2018  
0700 Continuous 1600  
Work scheduled by: ISONE

FWD  
(Import)  
SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

**LEEDS\_\_-HURLYAVE\_345\_301**

Wed 10/24/2018 to Fri 11/16/2018 **UPDATED by CH 09/18/2018**  
0800 Continuous 1600  
Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 5700 MW

**DENNISON-NORFOLK\_\_115\_4**

Wed 10/24/2018 to Wed 10/24/2018 **UPDATED by NGRID 10/11/2018**  
0830 Daily(No Weekends) 1600  
Work scheduled by: NGrid **ARR: 38**

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **150 MW 40 MW**  
Impacts Total Transfer Capability 40 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

**DENNISON-ROSEMNTB\_115\_2/22**

Thu 10/25/2018 to Thu 10/25/2018  
0900 Daily(No Weekends) 1600  
Work scheduled by: NGrid **ARR: 38**

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **95 MW 40 MW**  
Impacts Total Transfer Capability 95 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 21, 2018 to Tuesday ,April 21, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## KINTIGH\_-ROCHESTR\_345\_SR1-39

FWD

Mon 10/29/2018 to Fri 11/02/2018 UPDATED by NYPA 10/10/2018

(Import)

0500 Continuous 1700

DYSINGER EAST **1400 MW**

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## MOSES\_-ADIRNDCK\_230\_MAI

FWD

Mon 10/29/2018 to Fri 11/02/2018

(Import)

0700 Continuous 1530

MOSES SOUTH **2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## SCH-IMO-NYISO\_LIMIT\_1200

FWD

Thu 11/01/2018 to Wed 11/21/2018 UPDATED by NYISO 10/11/2018

(Import)

0001 Continuous 1830

SCH - OH - NY **1500 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1750 MW

Work scheduled by: NGrid

## PORTER\_-ROTTDAM\_230\_31

FWD

Fri 11/02/2018 to Fri 11/02/2018

(Import)

0600 Daily(No Weekends) 1600

CENTRAL EAST - VC **2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

## NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

FWD

Sat 11/03/2018 to Sun 11/18/2018

(Import)

0001 Continuous 1800

SCH - PJM\_NEPTUNE **0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

## NEWBRDGE-DUFFYAVE\_345\_501

FWD

Sat 11/03/2018 to Sun 11/18/2018

(Import)

0001 Continuous 1800

SCH - PJM\_NEPTUNE **0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

## NEWBRDGE\_345\_138\_BK\_1

FWD

Sat 11/03/2018 to Sun 11/18/2018

(Import)

0001 Continuous 1800

SCH - PJM\_NEPTUNE **375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

# NYISO TRANSFER LIMITATIONS

Sunday ,October 21, 2018 to Tuesday ,April 21, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NEWBRDGE_345_138_BK_2</b>					FWD		
Sat 11/03/2018	to	Sun 11/18/2018			(Import)		
0001	Continuous	1800			SCH - PJM_NEPTUNE	<b>375 MW</b>	
Work scheduled by: LI					Impacts Total Transfer Capability	285 MW	
					TTC with All Lines In Service	660 MW	
<b>BROWNFLS-TAYLORVL_115_3</b>					FWD	REV	
Sat 11/03/2018	to	Sat 11/03/2018			(Import)	(Export)	
0700	Continuous	1630			SCH - HQ_CEDARS	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	99 MW	0 MW
<b>ARR: 38</b>					TTC with All Lines In Service	199 MW	100 MW
<b>BROWNFLS-TAYLORVL_115_3 &amp; TAYLORVL-LOWVILLE_115_5 &amp; CLIMAX__TAYLORVL_115_8</b>					FWD	REV	
Sat 11/03/2018	to	Sat 11/03/2018			(Import)	(Export)	
0700		1630			SCH - HQ_CEDARS	<b>120 MW</b>	<b>100 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	79 MW	0 MW
<b>ARR: 38</b>					TTC with All Lines In Service	199 MW	100 MW
<b>TAYLORVL-LOWVILLE_115_5</b>					FWD	REV	
Sat 11/03/2018	to	Sat 11/03/2018			(Import)	(Export)	
0700	Continuous	1630			SCH - HQ_CEDARS	<b>199 MW</b>	<b>100 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	0 MW	0 MW
<b>ARR: 38</b>					TTC with All Lines In Service	199 MW	100 MW
<b>GOETHALS_345KV_5</b>							
Sun 11/04/2018	to	Sun 11/04/2018	<b>UPDATED</b>	<b>by CONED 10/01/2018</b>	STATEN ISLAND		
0001	Continuous	0030			Impacts Total Transfer Capability		
Work scheduled by: ConEd					TTC with All Lines In Service		
<b>LINDEN__GOETHALS_230_A2253</b>					FWD	REV	
Sun 11/04/2018	to	Sun 11/11/2018	<b>UPDATED</b>	<b>by CONED 10/01/2018</b>	(Import)	(Export)	
0001	Continuous	0300			SCH - PJ - NY	<b>2600 MW</b>	<b>1300 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	150 MW	0 MW
					TTC with All Lines In Service	2750 MW	1300 MW
<b>LINDEN__GOETHALS_230_A2253 &amp; HUDSONP_-FARRAGUT_345_B3402</b>					FWD	REV	
Sun 11/04/2018	to	Sun 11/11/2018			(Import)	(Export)	
0001		0300			SCH - PJ - NY	<b>2000 MW</b>	<b>1300 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	750 MW	0 MW
					TTC with All Lines In Service	2750 MW	1300 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 21, 2018 to Tuesday ,April 21, 2020

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDEN__ -GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402 & MARION__ -FARRAGUT_345_C3403				FWD	REV
				(Import)	(Export)
Sun 11/04/2018	to	Sun 11/11/2018		SCH - PJ - NY	2000 MW
0001		0300		Impacts Total Transfer Capability	750 MW
Work scheduled by:				TTC with All Lines In Service	2750 MW
LINDEN__ -GOETHALS_230_A2253 & MARION__ -FARRAGUT_345_C3403				FWD	REV
				(Import)	(Export)
Sun 11/04/2018	to	Sun 11/11/2018		SCH - PJ - NY	2000 MW
0001		0300		Impacts Total Transfer Capability	750 MW
Work scheduled by:				TTC with All Lines In Service	2750 MW
NIAGARA_345_230_AT4				FWD	REV
				(Import)	(Export)
Mon 11/05/2018	to	Fri 11/09/2018	<u>UPDATED</u> <u>by NYPA</u> <u>10/05/2018</u>	SCH - OH - NY	1750 MW
0400	Continuous	2300		Impacts Total Transfer Capability	0 MW
Work scheduled by: NYPA				TTC with All Lines In Service	1750 MW
SCH-NYISO-NE_LIMIT_1100					REV
					(Export)
Mon 11/05/2018	to	Sat 11/24/2018		SCH - NE - NY	1300 MW
0600	Continuous	1900		Impacts Total Transfer Capability	300 MW
Work scheduled by: ISONE				TTC with All Lines In Service	1600 MW
MOSES__ -ADIRNDCK_230_MA1				FWD	
				(Import)	
Mon 11/05/2018	to	Fri 11/09/2018		MOSES SOUTH	2300 MW
0700	Continuous	1530		Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW
HOMR_NYW-PIERC_NY_345_48				FWD	REV
				(Import)	(Export)
Mon 11/05/2018	to	Fri 11/09/2018		SCH - PJ - NY	2500 MW
0800	Continuous	2000		Impacts Total Transfer Capability	250 MW
Work scheduled by: PJM				TTC with All Lines In Service	2750 MW
SCH-HQ-NYISO_LIMIT_0				FWD	
				(Import)	
Sat 11/10/2018	to	Sun 11/11/2018		SCH - HQ - NY	0 MW
0600	Continuous	1759		Impacts Total Transfer Capability	1500 MW
Work scheduled by: HQ				TTC with All Lines In Service	1500 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## GOETHALS\_345KV\_5

Sun 11/11/2018 to Sun 11/11/2018 UPDATED by CONED 10/01/2018

0230 Continuous 0300

Work scheduled by: ConEd

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

## FROST\_BR-LONG\_MTN\_345\_352

Sun 11/11/2018 to Sun 11/11/2018

0700 Continuous 1800

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD REV  
(Import) (Export)

**1300 MW 1600 MW**

100 MW 0 MW

1400 MW 1600 MW

## SCH-NE-NYISO\_LIMIT\_1000

Sun 11/11/2018 to Sun 11/11/2018

0700 Continuous 1800

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
(Import)

**1200 MW**

200 MW

1400 MW

## NIAGARA\_-KINTIGH\_345\_NS1-38

Tue 11/13/2018 to Fri 11/16/2018

0700 Continuous 1600

Work scheduled by: NYSEG

DYSINGER EAST

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
(Import)

**1700 MW**

1450 MW

3150 MW

## SCH-IMO-NYISO\_LIMIT\_1050

Thu 11/15/2018 to Wed 11/21/2018

0500 Continuous 1830

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
(Import)

**1350 MW**

400 MW

1750 MW

## SCH-IMO-NYISO\_LIMIT\_1350

Thu 11/15/2018 to Thu 12/20/2018

0500 Continuous 2359

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
(Import)

**1650 MW**

100 MW

1750 MW

## MARCY\_345KV\_CSC

Fri 11/16/2018 to Sat 11/17/2018

0500 Continuous 1730

Work scheduled by: NYPA

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
(Import)

**2925 MW**

50 MW

2975 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 21, 2018 to Tuesday ,April 21, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MARCY\_\_\_\_765\_345\_AT2

Fri 11/16/2018 to Sat 11/17/2018  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## DUNWODIE-SHORE\_RD\_345\_Y50

Mon 11/19/2018 to Tue 11/20/2018  
0001 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
CONED - LIPA **800 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1500 MW

## DUNWODIE\_345KV\_4

Mon 11/19/2018 to Tue 11/20/2018  
0001 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## SHORE\_RD\_345\_138\_BK 1

Mon 11/19/2018 to Tue 11/20/2018  
0001 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
CONED - LIPA **1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

## SHORE\_RD\_345\_138\_BK 2

Mon 11/19/2018 to Tue 11/20/2018  
0001 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
CONED - LIPA **1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MAI

Mon 11/19/2018 to Wed 11/21/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## LONG\_MTN-PLSNTVLY\_345\_398

Mon 11/26/2018 to Thu 12/06/2018  
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 10/19/2018

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	<b>700 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	700 MW	300 MW
TTC with All Lines In Service	1400 MW	1600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 21, 2018 to Tuesday ,April 21, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**LONG\_MTN-PLSNTVLY\_345\_398**

Mon 11/26/2018 to Thu 12/06/2018  
0001 Continuous 0030

UPDATED by CONED 10/19/2018

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

**SCH-NYISO-NE\_LIMIT\_400**

Mon 11/26/2018 to Thu 12/06/2018  
0001 Continuous 0030

Work scheduled by: ISONE

	REV
	(Export)
SCH - NE - NY	<b>600 MW</b>
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	1600 MW

**SCRIBA\_-VOLNEY\_345\_21**

Mon 11/26/2018 to Wed 11/28/2018  
0700 Continuous 1730

UPDATED by NGRID 08/14/2018

Work scheduled by: NGrid

	FWD
	(Import)
OSWEGO EXPORT	<b>5250 MW</b>
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	5250 MW

**MOSES\_-ADIRNDCK\_230\_MA2**

Mon 11/26/2018 to Fri 11/30/2018  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2300 MW</b>
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

**SHOR\_NPX-SHOREHAM\_138\_CSC**

Mon 11/26/2018 to Fri 12/07/2018  
0700 Continuous 1600

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

**HURLYAVE-ROSETON\_345\_303**

Mon 11/26/2018 to Fri 12/21/2018  
0800 Continuous 1600

Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	<b>4100 MW</b>
Impacts Total Transfer Capability	1600 MW
TTC with All Lines In Service	5700 MW

**DUNWODIE-MOTTHAVN\_345\_72**

Sun 12/02/2018 to Thu 12/06/2018  
0001 Continuous 0159

Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	<b>3800 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_7**

Sun 12/02/2018 to Thu 12/06/2018  
0001 Continuous 0159

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**MOSES -ADIRNDCK\_230\_MA2**

Mon 12/03/2018 to Fri 12/07/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**DUNWODIE-SHORE\_RD\_345\_Y50**

Thu 12/06/2018 to Wed 12/12/2018  
0201 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
CONED - LIPA **800 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1500 MW

**DUNWODIE\_345KV\_4**

Thu 12/06/2018 to Wed 12/12/2018  
0201 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**SHORE\_RD\_345\_138\_BK 1**

Thu 12/06/2018 to Wed 12/12/2018  
0201 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
CONED - LIPA **1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

**SHORE\_RD\_345\_138\_BK 2**

Thu 12/06/2018 to Wed 12/12/2018  
0201 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
CONED - LIPA **1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

**MOSES -ADIRNDCK\_230\_MA2**

Mon 12/10/2018 to Fri 12/14/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 21, 2018 to Tuesday ,April 21, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## WOOD\_ST\_-PLSNTVLE\_345\_Y87

FWD

Mon 12/17/2018 to Mon 01/28/2019 **UPDATED by CE 10/04/2018**

(Import)

0001 Continuous 0200

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

## MARCY\_765\_345\_AT2

FWD

Mon 12/17/2018 to Fri 12/21/2018

(Import)

0500 Continuous 1730

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19**

## SPRNBRK\_345KV\_RS3 & SPRNBRK\_345KV\_RS4

FWD

Sun 12/23/2018 to Mon 12/24/2018

(Import)

0001 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by:

## MOSES\_-ADIRNDCK\_230\_MA1

FWD

Wed 12/26/2018 to Fri 12/28/2018

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## BECK\_-NIAGARA\_230\_PA27

FWD

REV

Sat 12/29/2018 to Sat 12/29/2018 **UPDATED by NYPA 10/10/2018**

(Import) (Export)

0500 Continuous 1700

SCH - OH - NY

**1750 MW 1900 MW**

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 1750 MW 1900 MW

Work scheduled by: NYPA

## HURLYAVE-ROSETON\_345\_303

FWD

Wed 01/02/2019 to Fri 01/11/2019

(Import)

0800 Continuous 1600

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: CHGE

## SCH-NE-NYISO\_LIMIT\_1100

FWD

Mon 01/07/2019 to Thu 01/10/2019

(Import)

0700 Continuous 1600

SCH - NE - NY

**1300 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

# NYISO TRANSFER LIMITATIONS

Sunday ,October 21, 2018 to Tuesday ,April 21, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 01/07/2019 to Fri 01/11/2019

0700 Continuous 1500

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 01/14/2019 to Fri 01/18/2019

0700 Continuous 1500

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## LEEDS\_\_\_-HURLYAVE\_345\_301

Mon 01/14/2019 to Fri 01/25/2019

0800 Continuous 1600

Work scheduled by: CHGE

08/20/2018

FWD

(Import)

UPNY CONED **4100 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 5700 MW

## DUNWODIE\_345KV\_6

Mon 01/21/2019 to Mon 01/28/2019

0001 Continuous 0200

Work scheduled by: ConEd

UPDATED

by CE

10/04/2018

FWD

(Import)

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

## DUNWODIE\_345KV\_8

Mon 01/21/2019 to Mon 01/28/2019

0001 Continuous 0200

Work scheduled by: ConEd

UPDATED

by CE

10/04/2018

FWD

(Import)

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

## PLSNTVLE-DUNWODIE\_345\_W90

Mon 01/21/2019 to Mon 01/28/2019

0001 Continuous 0200

Work scheduled by: ConEd

UPDATED

by CE

10/04/2018

FWD

(Import)

UPNY CONED **4000 MW**

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 01/21/2019 to Fri 01/25/2019

0700 Continuous 1500

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 21, 2018 to Tuesday ,April 21, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 01/28/2019 to Fri 02/01/2019

0700 Continuous 1500

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Tue 01/29/2019 to Sun 02/03/2019

0001 0300

Work scheduled by:

FWD

(Import)

UPNY CONED **3800 MW**

Impacts Total Transfer Capability 1900 MW

TTC with All Lines In Service 5700 MW

## PLSNTVLY-EFISHKIL\_345\_F36

Sun 02/03/2019 to Wed 02/06/2019

0301 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 10/19/2018

FWD

(Import)

UPNY CONED **4000 MW**

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 02/04/2019 to Thu 02/07/2019

0700 Continuous 1500

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Wed 02/06/2019 to Wed 02/06/2019

0330 0400

Work scheduled by:

FWD

(Import)

UPNY CONED **3800 MW**

Impacts Total Transfer Capability 1900 MW

TTC with All Lines In Service 5700 MW

## ADIRNDCK-CHASLAKE\_230\_13

Thu 02/07/2019 to Thu 02/07/2019

0800 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA1

Fri 02/08/2019 to Fri 02/08/2019

0800 Continuous 1500

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 02/11/2019 to Fri 02/15/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Tue 02/19/2019 to Fri 02/22/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

---

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Sun 02/24/2019 to Sun 02/24/2019  
0001 2359

Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1900 MW  
TTC with All Lines In Service 5700 MW

---

**LONG\_MTN-PLSNTVLY\_345\_398**

Sun 02/24/2019 to Sun 05/19/2019 UPDATED by CE 09/14/2018  
0001 Continuous 2359

Work scheduled by: ConEd

FWD REV  
(Import) (Export)  
SCH - NE - NY **700 MW 1300 MW**  
Impacts Total Transfer Capability 700 MW 300 MW  
TTC with All Lines In Service 1400 MW 1600 MW

---

**LONG\_MTN-PLSNTVLY\_345\_398**

Sun 02/24/2019 to Sun 05/19/2019 UPDATED by CE 09/14/2018  
0001 Continuous 2359

Work scheduled by: ConEd

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **100 MW 100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

---

**PLSNTVLY-EFISHKIL\_345\_F37**

Mon 02/25/2019 to Tue 02/26/2019 UPDATED by CE 09/14/2018  
0001 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1700 MW  
TTC with All Lines In Service 5700 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MAI**

Mon 03/04/2019 to Fri 03/08/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 21, 2018 to Tuesday ,April 21, 2020

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 03/11/2019 to Fri 03/15/2019

0700 Continuous 1500

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH 2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## LEEDS\_\_\_345\_LEEDS SVC

Mon 03/11/2019 to Fri 03/22/2019

0800 Continuous 1600

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC 2950 MW

Impacts Total Transfer Capability 25 MW

TTC with All Lines In Service 2975 MW

## MARCY\_\_\_765\_345\_AT1

Mon 03/18/2019 to Fri 03/22/2019

0500 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

MOSES SOUTH 1750 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

## PLSNTVLY-EFISHKIL\_345\_F37

Sat 03/30/2019 to Wed 04/03/2019

0001 Continuous 0300

Work scheduled by: ConEd

UPDATED

by CE

09/14/2018

FWD

(Import)

UPNY CONED 4000 MW

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

## MARCY\_\_\_345KV\_CSC

Mon 04/01/2019 to Sun 04/07/2019

0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC 2925 MW

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

## VOLNEY\_\_\_-MARCY\_\_\_345\_19

Mon 04/01/2019 to Wed 04/10/2019

0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

CENTRAL EAST - VC 2825 MW

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 2975 MW

## VOLNEY\_\_\_-MARCY\_\_\_345\_19

Mon 04/01/2019 to Wed 04/10/2019

0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

OSWEGO EXPORT 4900 MW

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 5250 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 21, 2018 to Tuesday ,April 21, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Sun 04/07/2019 to Mon 04/08/2019  
0001 0030

Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1900 MW  
TTC with All Lines In Service 5700 MW

## LINDN\_CG-LNDVFT\_\_\_345\_V-3022

Sun 04/07/2019 to Fri 04/12/2019  
1400 Continuous 1800

Work scheduled by: PJM

FWD REV  
(Import) (Export)  
SCH - PJM\_VFT **0 MW 0 MW**  
Impacts Total Transfer Capability 315 MW 315 MW  
TTC with All Lines In Service 315 MW 315 MW

## MARCY\_\_\_345KV\_CSC

Thu 04/11/2019 to Wed 04/17/2019  
0500 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

## MARCY\_\_\_-EDIC\_\_\_345\_UE1-7

Thu 04/11/2019 to Sat 04/20/2019  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19&16

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

## GILBOA\_\_\_-N.SCTLND\_345\_GNS-1

Fri 04/12/2019 to Fri 04/12/2019  
1330 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2520 MW**  
Impacts Total Transfer Capability 455 MW  
TTC with All Lines In Service 2975 MW

## EDIC\_\_\_-FRASER\_\_\_345\_EF24-40

Mon 04/22/2019 to Fri 04/26/2019  
0500 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

## MARCY\_\_\_765\_345\_AT2

Mon 04/22/2019 to Fri 04/26/2019  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 21, 2018 to Tuesday ,April 21, 2020

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### FRASANX-COOPERS\_\_345\_UCC2-41

FWD

Mon 04/29/2019 to Fri 05/03/2019  
0500 Continuous 1730

UPDATED

by NYPA

08/22/2018

(Import)

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

### MARCY\_\_-FRASANX\_345\_UCC2-41

FWD

Mon 04/29/2019 to Fri 05/03/2019  
0500 Continuous 1730

UPDATED

by NYPA

08/22/2018

(Import)

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

### MOSES\_\_-ADIRNDCK\_230\_Ma1

FWD

Mon 04/29/2019 to Fri 05/03/2019  
0700 Continuous 1500

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### ROSETON\_-ROCKTVRN\_345\_311

FWD

Mon 05/06/2019 to Sat 06/01/2019  
0800 Continuous 1600

(Import)

Work scheduled by: CHGE

UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5700 MW

### ADIRNDCK-PORTER\_\_230\_12

FWD

Mon 05/20/2019 to Fri 05/24/2019  
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

### PANNELL\_-CLAY\_\_345\_1

FWD

Mon 05/20/2019 to Fri 05/24/2019  
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

### PANNELL\_-CLAY\_\_345\_2

FWD

Mon 06/03/2019 to Fri 06/07/2019  
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 21, 2018 to Tuesday ,April 21, 2020

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 06/24/2019 to Fri 06/28/2019

0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 07/08/2019 to Fri 07/12/2019

0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## ADIRNDCK-CHASLAKE\_230\_13

Mon 07/08/2019 to Fri 07/12/2019

0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## LEEDS\_\_\_-HURLYAVE\_345\_301

Mon 08/05/2019 to Fri 08/30/2019

0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 5700 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 08/12/2019 to Mon 08/12/2019

0700 Continuous 1459

Work scheduled by: NYPA

**UPDATED by NYPA 10/10/2018**

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## MARCY\_\_\_-N.SCTLND\_345\_18

Wed 09/04/2019 to Wed 09/04/2019

0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2090 MW**  
Impacts Total Transfer Capability 885 MW  
TTC with All Lines In Service 2975 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Wed 09/04/2019 to Wed 09/04/2019

0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**ADIRNDCK-PORTER\_\_230\_12**

Wed 09/04/2019 to Wed 09/04/2019  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

---

**ADIRNDCK-CHASLAKE\_230\_13**

Thu 09/05/2019 to Thu 09/05/2019  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

---

**NIAGARA\_-ROCHESTR\_345\_NR2**

Mon 09/09/2019 to Sat 09/21/2019  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

---

**LEEDS\_\_345KV\_R395**

Mon 09/09/2019 to Mon 09/09/2019  
0700 Continuous 0730

Work scheduled by: NYPA

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1900 MW  
TTC with All Lines In Service 5700 MW

---

**GILBOA\_-LEEDS\_\_345\_GL3**

Mon 09/09/2019 to Fri 09/27/2019  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2200 MW**  
Impacts Total Transfer Capability 775 MW  
TTC with All Lines In Service 2975 MW

---

**MOSES\_-ADIRNDCK\_230\_MA2**

Mon 09/16/2019 to Fri 09/20/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

---

**ROCHESTR-PANNELL\_\_345\_RP2**

Mon 09/23/2019 to Mon 09/30/2019  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**KINTIGH\_-ROCHESTR\_345\_SR1-39**

FWD

Mon 09/23/2019 to Fri 09/27/2019

(Import)

0600 Continuous 1700

DYSINGER EAST

**1400 MW**

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**LEEDS\_345KV\_R395**

FWD

Fri 09/27/2019 to Fri 09/27/2019

(Import)

1700 Continuous 1730

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1900 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: NYPA

**CLAY\_-EDIC\_345\_1-16**

FWD

Mon 09/30/2019 to Fri 10/04/2019

(Import)

0700 Continuous 1530

OSWEGO EXPORT

**4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**CLAY\_-EDIC\_345\_2-15**

FWD

Mon 10/07/2019 to Thu 10/17/2019

(Import)

0700 Continuous 1530

OSWEGO EXPORT

**4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**HURLYAVE-ROSETON\_345\_303**

FWD

Mon 10/21/2019 to Sat 11/16/2019

(Import)

0800 Continuous 1600

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: CHGE

**PANNELL\_-CLAY\_345\_2**

FWD

Wed 11/06/2019 to Fri 11/22/2019

(Import)

0700 Continuous 1530

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

**MOSES\_-ADIRNDCK\_230\_MA2**

FWD

Tue 11/12/2019 to Fri 11/15/2019

(Import)

0700 Continuous 1500

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Sunday ,October 21, 2018 to Tuesday ,April 21, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 11/18/2019 to Fri 11/22/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 11/25/2019 to Wed 11/27/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 12/02/2019 to Fri 12/06/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Mon 12/09/2019 to Fri 12/13/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 12/16/2019 to Mon 12/16/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Tue 12/17/2019 to Fri 12/20/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW