

**NYISO TRANSFER LIMITATIONS**

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**HUDSONP\_-FARRAGUT\_345\_B3402**Mon 01/15/2018 to Tue 12/31/2019 **EXTENDED** **by CONED** **02/06/2019**

0001 Continuous 2359

Work scheduled by: ConEd

FWD REV  
(Import) (Export)

SCH - PJ - NY **2100 MW 1250 MW**  
Impacts Total Transfer Capability 50 MW 100 MW  
TTC with All Lines In Service 2150 MW 1350 MW

**HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403**

Mon 01/15/2018 to Tue 12/31/2019

0001 2359

Work scheduled by:

FWD REV  
(Import) (Export)

SCH - PJ - NY **2050 MW 1150 MW**  
Impacts Total Transfer Capability 100 MW 200 MW  
TTC with All Lines In Service 2150 MW 1350 MW

**MARION\_-FARRAGUT\_345\_C3403**Mon 01/15/2018 to Tue 12/31/2019 **EXTENDED** **by CONED** **02/06/2019**

0001 Continuous 2359

Work scheduled by: ConEd

FWD REV  
(Import) (Export)

SCH - PJ - NY **2100 MW 1250 MW**  
Impacts Total Transfer Capability 50 MW 100 MW  
TTC with All Lines In Service 2150 MW 1350 MW

**STLAWRNC-MOSES\_230\_L33P**Mon 04/30/2018 to Fri 12/31/2021 **EXT FORCE** **by IESO** **08/21/2018**

0456 Continuous 2359

Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**SCH-NYISO-HQ\_LIMIT\_800**Wed 06/05/2019 to Fri 09/20/2019 **EXTENDED** **by HQ** **09/12/2019**

0001 Continuous 1700

Work scheduled by: HQ

REV  
(Export)

SCH - HQ - NY **800 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1000 MW

**BECK\_-NIAGARA\_345\_PA302**Wed 07/31/2019 to Tue 11/12/2019 **EXTENDED** **by IESO** **08/29/2019**

0800 Continuous 1700

Work scheduled by: IESO

FWD REV  
(Import) (Export)

SCH - OH - NY **900 MW 800 MW**  
Impacts Total Transfer Capability 1000 MW 900 MW  
TTC with All Lines In Service 1900 MW 1700 MW

**NIAGARA\_-PACKARD\_230\_61**Tue 09/03/2019 to Fri 10/18/2019 **UPDATED** **by NYPA** **12/19/2018**

0500 Continuous 1700

Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NYISO-HQ\_CEDARS\_LIMIT\_0

REV

Mon 09/09/2019 to Thu 09/26/2019

(Export)

0400 Continuous 1900

SCH - HQ\_CEDARS

0 MW

Work scheduled by: HQ

Impacts Total Transfer Capability

40 MW

TTC with All Lines In Service

40 MW

## GILBOA -LEEDS 345\_GL3

FWD

Mon 09/09/2019 to Fri 09/27/2019

(Import)

0700 Continuous 1730

UPDATEDby NYPA07/23/2019

CENTRAL EAST - VC

2200 MW

Work scheduled by: NYPA

Impacts Total Transfer Capability

775 MW

TTC with All Lines In Service

2975 MW

## PLSNTVLY\_345KV\_RNS5

FWD

Sat 09/14/2019 to Sat 10/19/2019

(Import)

0001 Continuous 0300

UPDATEDby CE09/17/2019

UPNY CONED

3800 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability

1900 MW

TTC with All Lines In Service

5700 MW

## MOSES -ADIRNDCK\_230\_MA2

FWD

Mon 09/16/2019 to Thu 09/19/2019

(Import)

0700 Continuous 1530

UPDATEDby NYPA09/12/2019

MOSES SOUTH

2100 MW

Work scheduled by: NYPA

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW

## HOMRC\_NY-MAINS\_NY\_345\_47

Fri 09/20/2019 to Sun 09/22/2019

0700 Continuous 1806

SCH - PJ - NY

Work scheduled by: NYSEG

Impacts Total Transfer Capability

TTC with All Lines In Service

## NINEMILE-CLAY 345\_8

FWD

Fri 09/20/2019 to Fri 09/20/2019

(Import)

0800 Daily(No Weekends) 1200

OSWEGO EXPORT

5150 MW

Work scheduled by: NGrid

Impacts Total Transfer Capability

100 MW

TTC with All Lines In Service

5250 MW

## SPRNBK\_-TREMONT\_345\_X28

FWD

Fri 09/20/2019 to Fri 09/20/2019

(Import)

2130 Continuous 2200

SPR/DUN-SOUTH

4200 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

4600 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_\_765\_345\_AT1**

FWD

Sat 09/21/2019 to Sat 09/21/2019

(Import)

0500 Continuous 1730

MOSES SOUTH

**1750 MW**

Work scheduled by: NYPA

**ARR: 19**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

**SPRNBK\_-TREMONT\_\_345\_X28**

FWD

Mon 09/23/2019 to Mon 09/23/2019

(Import)

0001 Continuous 0030

SPR/DUN-SOUTH

**4200 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_6**

FWD

Wed 09/25/2019 to Thu 09/26/2019

(Import)

0001 Continuous 2359

**UPDATED****by CE****09/24/2019**

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_8**

FWD

Wed 09/25/2019 to Thu 09/26/2019

(Import)

0001 Continuous 2359

**UPDATED****by CE****09/24/2019**

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**PLSNTVLE-DUNWODIE\_345\_W90**

FWD

Wed 09/25/2019 to Thu 09/26/2019

(Import)

0001 Continuous 2359

**UPDATED****by CE****09/24/2019**

Work scheduled by: ConEd

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

**WATRCURE-OAKDALE\_\_345\_31**

Thu 09/26/2019 to Thu 09/26/2019

**UPDATED****by NYSEG****09/13/2019**

0800 Continuous 1000

Work scheduled by: NYSEG

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**LEEDS\_\_\_\_345KV\_R395**

FWD

Fri 09/27/2019 to Fri 09/27/2019

(Import)

1700 Continuous 1730

**UPDATED****by NYPA****07/23/2019**

Work scheduled by: NYPA

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1900 MW

TTC with All Lines In Service 5700 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK_-TREMONT_345_X28</b>					FWD	
Sat 09/28/2019	to	Sat 09/28/2019			(Import)	
2230	Continuous	2300			SPR/DUN-SOUTH	<b>4200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	4600 MW
<b>W49TH_ST_345KV_5</b>					FWD	
Sun 09/29/2019	to	Sun 09/29/2019	<u>UPDATED</u>	<u>by CONED</u> <u>09/11/2019</u>	(Import)	
1830	Continuous	1900			SCH - PJM_HTP	<b>375 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	660 MW
<b>W49TH_ST_345KV_7</b>					FWD	
Sun 09/29/2019	to	Sun 09/29/2019	<u>UPDATED</u>	<u>by CONED</u> <u>09/11/2019</u>	(Import)	
1830	Continuous	1900			SCH - PJM_HTP	<b>325 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	335 MW
					TTC with All Lines In Service	660 MW
<b>LINDEN_-GOETHALS_230_A2253</b>					FWD	REV
Mon 09/30/2019	to	Mon 09/30/2019	<u>UPDATED</u>	<u>by PJM</u> <u>08/06/2019</u>	(Import)	(Export)
0001	Continuous	1730			SCH - PJ - NY	<b>2100 MW 1250 MW</b>
Work scheduled by: PJM					Impacts Total Transfer Capability	50 MW 100 MW
					TTC with All Lines In Service	2150 MW 1350 MW
<b>LINDEN_-GOETHALS_230_A2253 &amp; HUDSONP_-FARRAGUT_345_B3402</b>					FWD	REV
Mon 09/30/2019	to	Mon 09/30/2019			(Import)	(Export)
0001		1730			SCH - PJ - NY	<b>2050 MW 1150 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	100 MW 200 MW
					TTC with All Lines In Service	2150 MW 1350 MW
<b>LINDEN_-GOETHALS_230_A2253 &amp; HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>					FWD	REV
Mon 09/30/2019	to	Mon 09/30/2019			(Import)	(Export)
0001		1730			SCH - PJ - NY	<b>2000 MW 1050 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	150 MW 300 MW
					TTC with All Lines In Service	2150 MW 1350 MW
<b>LINDEN_-GOETHALS_230_A2253 &amp; MARION_-FARRAGUT_345_C3403</b>					FWD	REV
Mon 09/30/2019	to	Mon 09/30/2019			(Import)	(Export)
0001		1730			SCH - PJ - NY	<b>2050 MW 1150 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	100 MW 200 MW
					TTC with All Lines In Service	2150 MW 1350 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## EASTVIEW-SPRNBK\_\_345\_W65

Mon 09/30/2019 to Tue 10/01/2019

0100 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

4350 MW

Impacts Total Transfer Capability 1350 MW

TTC with All Lines In Service 5700 MW

## MILLWOOD-EASTVIEW\_345\_W82

Mon 09/30/2019 to Tue 10/01/2019

0100 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

4350 MW

Impacts Total Transfer Capability 1350 MW

TTC with All Lines In Service 5700 MW

## SPRNBK\_\_345KV\_RNS4

Mon 09/30/2019 to Tue 10/01/2019

0100 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

## BERKSHIR-ALPS\_\_\_\_345\_393

Mon 09/30/2019 to Sat 10/05/2019

0600 Continuous 1600

Work scheduled by: ISONE

ARR: 78

FWD

REV

(Import) (Export)

SCH - NE - NY

950 MW 1300 MW

Impacts Total Transfer Capability 450 MW 300 MW

TTC with All Lines In Service 1400 MW 1600 MW

## BERKSHIR-ALPS\_\_\_\_345\_393

Mon 09/30/2019 to Sat 10/05/2019

0600 Continuous 1600

Work scheduled by: ISONE

ARR: 78

FWD

REV

(Import) (Export)

SCH - NPX\_1385

100 MW 100 MW

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

## BERKSHIR-ALPS\_\_\_\_345\_393 &amp; BERKSHIR-NORTHFLD\_345\_312

Mon 09/30/2019 to Sat 10/05/2019

0600 1600

Work scheduled by:

ARR: 78

FWD

REV

(Import) (Export)

SCH - NE - NY

950 MW 1300 MW

Impacts Total Transfer Capability 450 MW 300 MW

TTC with All Lines In Service 1400 MW 1600 MW

## BERKSHIR-NORTHFLD\_345\_312

Mon 09/30/2019 to Sat 10/05/2019

0600 Continuous 1600

Work scheduled by: ISONE

FWD

REV

(Import) (Export)

SCH - NE - NY

900 MW 1500 MW

Impacts Total Transfer Capability 500 MW 100 MW

TTC with All Lines In Service 1400 MW 1600 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Mon 09/30/2019	to	Sat 10/05/2019			(Import)	(Export)
0600	Continuous	1600			SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
<b>SCH-NYISO-NE_LIMIT_500</b>						REV
Mon 09/30/2019	to	Sat 10/05/2019				(Export)
0600	Continuous	1600			SCH - NE - NY	<b>700 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	900 MW
					TTC with All Lines In Service	1600 MW
<b>CLAY____-EDIC____345_1-16</b>					FWD	
Mon 09/30/2019	to	Fri 10/04/2019	<b>UPDATED</b>	<b>by NYPA</b>	(Import)	
0700	Continuous	1530		<b>08/20/2019</b>	OSWEGO EXPORT	<b>4850 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	5250 MW
<b>FIVEMILE-STOLLERD_345_29</b>					FWD	
Mon 09/30/2019	to	Wed 10/02/2019	<b>CANCELLED</b>	<b>by NGrid</b>	(Import)	
0730	Continuous	1230		<b>09/19/2019</b>	SCH - PJ - NY	<b>2100 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2150 MW
<b>LEEDS____-HURLYAVE_345_301</b>					FWD	
Mon 09/30/2019	to	Fri 10/11/2019	<b>UPDATED</b>	<b>by CHGE</b>	(Import)	
0800	Continuous	1600		<b>09/05/2019</b>	UPNY CONED	<b>4100 MW</b>
Work scheduled by: CHGE					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	5700 MW
<b>DUNWODIE_345KV_4</b>					FWD	
Tue 10/01/2019	to	Fri 10/11/2019			(Import)	
0001	Continuous	0300			SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>SPRNBK__345KV_RS3 &amp; SPRNBK__345KV_RS4</b>					FWD	
Tue 10/01/2019	to	Thu 10/10/2019			(Import)	
0201		2230			SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-IMO-NYISO\_LIMIT\_400

Wed 10/02/2019 to Fri 10/04/2019  
0500 Continuous 2100  
Work scheduled by: NYPA

FWD  
(Import)  
SCH - OH - NY **700 MW**  
Impacts Total Transfer Capability 1200 MW  
TTC with All Lines In Service 1900 MW

## FROST\_BR-LONG\_MTN\_345\_352

Wed 10/02/2019 to Thu 10/17/2019  
0700 Continuous 1600  
Work scheduled by: ISONE

FWD  
(Import)  
SCH - NE - NY **1150 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1400 MW

## CHAT\_DC\_GC1

Sat 10/05/2019 to Sat 10/05/2019 CANCELLED by HQ 09/23/2019  
0001 Continuous 0200  
Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC1

Sat 10/05/2019 to Sat 10/05/2019 CANCELLED by HQ 09/23/2019  
0001 Continuous 0200  
Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

## CHAT\_DC\_GC2

Sat 10/05/2019 to Sat 10/05/2019 CANCELLED by HQ 09/23/2019  
0001 Continuous 0200  
Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC2

Sat 10/05/2019 to Sat 10/05/2019 CANCELLED by HQ 09/23/2019  
0001 Continuous 0200  
Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

## SCH-HQ-NYISO\_LIMIT\_1150

Sat 10/05/2019 to Sat 10/05/2019 CANCELLED by HQ 09/23/2019  
0001 Continuous 0200  
Work scheduled by: HQ

FWD  
(Import)  
SCH - HQ - NY **1150 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 1500 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NE-NYISO\_LIMIT\_400

Sat 10/05/2019 to Thu 10/17/2019  
1601 Continuous 1600  
Work scheduled by: ISONE

FWD  
(Import)  
SCH - NE - NY **600 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 1400 MW

## CLAY-EDIC\_345\_2-15

Mon 10/07/2019 to Fri 10/11/2019  
0600 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

## STOLLERD-HISHELDN\_230\_67

Mon 10/07/2019 to Tue 10/08/2019  
0700 Continuous 1400  
Work scheduled by: NYSEG

FWD  
(Import)  
DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

## MARCY-N.SCTLND\_345\_18

Wed 10/09/2019 to Fri 10/11/2019  
0500 Continuous 1730  
Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2090 MW**  
Impacts Total Transfer Capability 885 MW  
TTC with All Lines In Service 2975 MW

## CHAT\_DC\_GC1

Sat 10/12/2019 to Sat 10/12/2019  
0001 Continuous 0200  
Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC1

Sat 10/12/2019 to Sat 10/12/2019  
0001 Continuous 0200  
Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

## CHAT\_DC\_GC1 &amp; CHAT\_DC\_GC2

Sat 10/12/2019 to Sat 10/12/2019  
0001 0200  
Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **2550 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 3150 MW



# NYISO TRANSFER LIMITATIONS

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>				FWD	REV
Sat 10/12/2019	to	Sat 10/12/2019		(Import)	(Export)
0001		0200		SCH - HQ - NY	<b>1370 MW 0 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	130 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
<b>CHAT_DC_GC2</b>				FWD	
Sat 10/12/2019	to	Sat 10/12/2019		(Import)	
0001	Continuous	0200		MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC2</b>					REV
Sat 10/12/2019	to	Sat 10/12/2019			(Export)
0001	Continuous	0200		SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	1000 MW
<b>SCH-HQ-NYISO_LIMIT_1150</b>				FWD	
Sat 10/12/2019	to	Sat 10/12/2019		(Import)	
0001	Continuous	0200		SCH - HQ - NY	<b>1150 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability	350 MW
				TTC with All Lines In Service	1500 MW
<b>LEEDS___-PLSNTVLY_345_92</b>				FWD	
Sat 10/12/2019	to	Tue 10/15/2019	<b>UPDATED by CE 09/17/2019</b>	(Import)	
0001	Continuous	0200		UPNY CONED	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1900 MW
				TTC with All Lines In Service	5700 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2 &amp; MOSES___-MASSENA_230_MMS1 &amp; MOSES___-MASSENA_230_MMS2</b>				FWD	
Sat 10/12/2019	to	Sat 10/12/2019		(Import)	
0100		0200		MOSES SOUTH	<b>1950 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	1200 MW
				TTC with All Lines In Service	3150 MW
<b>CHATGUAY-MASSENA___765_7040</b>				FWD	
Sat 10/12/2019	to	Sat 10/26/2019		(Import)	
0100	Continuous	1900		MOSES SOUTH	<b>1550 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1600 MW
				TTC with All Lines In Service	3150 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**CHATGUAY-MASSENA\_\_765\_7040**

Sat 10/12/2019 to Sat 10/26/2019  
0100 Continuous 1900

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

---

**MARCY\_\_765\_345\_AT1**

Sat 10/12/2019 to Sat 10/26/2019  
0100 Continuous 1900

Work scheduled by: NYPA

**ARR: 19**

	FWD
	(Import)
MOSES SOUTH	<b>1750 MW</b>
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	3150 MW

---

**MARCY\_\_765\_345\_AT2**

Sat 10/12/2019 to Sat 10/26/2019  
0100 Continuous 1900

Work scheduled by: NYPA

**ARR: 19**

	FWD
	(Import)
MOSES SOUTH	<b>1700 MW</b>
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

---

**MASSENA\_-MARCY\_\_765\_MSU1**

Sat 10/12/2019 to Sat 10/26/2019  
0100 Continuous 1900

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2265 MW</b>
Impacts Total Transfer Capability	710 MW
TTC with All Lines In Service	2975 MW

---

**MASSENA\_-MARCY\_\_765\_MSU1**

Sat 10/12/2019 to Sat 10/26/2019  
0100 Continuous 1900

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>500 MW</b>
Impacts Total Transfer Capability	2650 MW
TTC with All Lines In Service	3150 MW

---

**MASSENA\_-MARCY\_\_765\_MSU1**

Sat 10/12/2019 to Sat 10/26/2019  
0100 Continuous 1900

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>475 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

---

**MASSENA\_-MARCY\_\_765\_MSU1**

Sat 10/12/2019 to Sat 10/26/2019  
0100 Continuous 1900

Work scheduled by: NYPA

	FWD
	(Import)
SCH - HQ_CEDARS	<b>90 MW</b>
Impacts Total Transfer Capability	100 MW
TTC with All Lines In Service	190 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA\_-MARCY\_765\_MSU1 & CHATGUAY-MASSENA\_765\_7040

Sat 10/12/2019 to Sat 10/26/2019  
0100 1900

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

MOSES\_-MASSENA\_230\_MMS1 & MOSES\_-MASSENA\_230\_MMS2

Sat 10/12/2019 to Sat 10/26/2019  
0100 1900

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY **850 MW 0 MW**  
Impacts Total Transfer Capability 650 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

MOSES\_-MASSENA\_230\_MMS1 & MOSES\_-MASSENA\_230\_MMS2

Sat 10/12/2019 to Sat 10/26/2019  
0100 1900

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS **90 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 190 MW

STLAWRNC-MOSES\_230\_L33P & MASSENA\_-MARCY\_765\_MSU1

Sat 10/12/2019 to Sat 10/26/2019  
0100 1900

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS **90 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 190 MW

STLAWRNC-MOSES\_230\_L33P & MOSES\_-MASSENA\_230\_MMS1 & MOSES\_-MASSENA\_230\_MMS2

Sat 10/12/2019 to Sat 10/26/2019  
0100 1900

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS **90 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 190 MW

CHAT\_DC\_GC1

Sat 10/12/2019 to Sun 10/13/2019  
2000 Continuous 2300

Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

CHAT\_DC\_GC1

Sat 10/12/2019 to Sun 10/13/2019  
2000 Continuous 2300

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Sat 10/12/2019 to Sun 10/13/2019  
2000 2300

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **2550 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 3150 MW

### CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Sat 10/12/2019 to Sun 10/13/2019  
2000 2300

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY **1370 MW 0 MW**  
Impacts Total Transfer Capability 130 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

### CHAT\_DC\_GC1 & CHAT\_DC\_GC2 & MOSES -MASSENA\_230\_MMS1 & MOSES - MASSENA\_230\_MMS2

Sat 10/12/2019 to Sun 10/13/2019  
2000 2300

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **1950 MW**  
Impacts Total Transfer Capability 1200 MW  
TTC with All Lines In Service 3150 MW

### CHAT\_DC\_GC2

Sat 10/12/2019 to Sun 10/13/2019  
2000 Continuous 2300

Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

### CHAT\_DC\_GC2

Sat 10/12/2019 to Sun 10/13/2019  
2000 Continuous 2300

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

### SCH-HQ-NYISO\_LIMIT\_1150

Sat 10/12/2019 to Sun 10/13/2019  
2000 Continuous 2300

Work scheduled by: HQ

FWD  
(Import)  
SCH - HQ - NY **1150 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 1500 MW

### E13THSTA-FARRAGUT\_345\_45

Sun 10/13/2019 to Mon 10/14/2019  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SHORE_RD_345_138_BK 1</b>					FWD	
Mon 10/14/2019	to	Mon 10/14/2019	<u>UPDATED</u>	<u>by LI</u>	<u>08/28/2019</u>	(Import)
0001	Continuous	2359				
Work scheduled by: LI					CONED - LIPA	<b>1350 MW</b>
					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	1500 MW
<b>PLSNTVLY-WOOD_ST__345_F30</b>					FWD	
Mon 10/14/2019	to	Thu 10/17/2019	<u>UPDATED</u>	<u>by CE</u>	<u>09/17/2019</u>	(Import)
0001	Continuous	0300				
Work scheduled by: ConEd					UPNY CONED	<b>4000 MW</b>
					Impacts Total Transfer Capability	1700 MW
					TTC with All Lines In Service	5700 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>					FWD	REV
Mon 10/14/2019	to	Fri 10/18/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>08/09/2019</u>	(Import) (Export)
0600	Continuous	1600				
Work scheduled by: LI					SCH - NPX_CSC	<b>0 MW 0 MW</b>
					Impacts Total Transfer Capability	330 MW 330 MW
					TTC with All Lines In Service	330 MW 330 MW
<b>FIVEMILE-STOLLERD_345_29</b>					FWD	
Mon 10/14/2019	to	Fri 10/18/2019				(Import)
0700	Continuous	1400				
Work scheduled by: NYSEG					SCH - PJ - NY	<b>2100 MW</b>
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2150 MW
<b>LEEDS__-HURLYAVE_345_301</b>					FWD	
Tue 10/15/2019	to	Fri 10/18/2019	<u>UPDATED</u>	<u>by CHGE</u>	<u>09/05/2019</u>	(Import)
0800	Continuous	1600				
Work scheduled by: CHGE					UPNY CONED	<b>4100 MW</b>
					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	5700 MW
<b>NEPTUNE_-DUFFYAVE_345_NEPTUNE</b>					FWD	
Thu 10/17/2019	to	Wed 10/23/2019				(Import)
0001	Continuous	2359				
Work scheduled by: LI					SCH - PJM_NEPTUNE	<b>0 MW</b>
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
<b>NEWBRDGE-DUFFYAVE_345_501</b>					FWD	
Thu 10/17/2019	to	Wed 10/23/2019				(Import)
0001	Continuous	2359				
Work scheduled by: LI					SCH - PJM_NEPTUNE	<b>0 MW</b>
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NEWBRDGE\_345\_138\_BK\_1

Thu 10/17/2019 to Wed 10/23/2019  
0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

## NEWBRDGE\_345\_138\_BK\_2

Thu 10/17/2019 to Wed 10/23/2019  
0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

## PLSNTVLY\_345KV\_RN5 &amp; PLSNTVLY\_345KV\_RN4

Thu 10/17/2019 to Thu 10/17/2019  
0900 1559

Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1900 MW  
TTC with All Lines In Service 5700 MW

## DUNWODIE\_345KV\_7

Fri 10/18/2019 to Fri 10/18/2019  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## DUNWODIE\_345KV\_8

Fri 10/18/2019 to Fri 10/18/2019  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## DUNWODIE-MOTTHAVN\_345\_72

Fri 10/18/2019 to Sat 10/19/2019  
0001 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## PLSNTVLY\_345KV\_RN5 &amp; PLSNTVLY\_345KV\_RN4

Fri 10/18/2019 to Fri 10/18/2019  
0900 1559

Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1900 MW  
TTC with All Lines In Service 5700 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_7**

FWD

Sat 10/19/2019 to Sat 10/19/2019

(Import)

0230 Continuous 0300

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**DUNWODIE\_345KV\_8**

FWD

Sat 10/19/2019 to Sat 10/19/2019

(Import)

0230 Continuous 0300

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**KINTIGH\_-ROCHESTR\_345\_SRI-39**

FWD

Sat 10/19/2019 to Sun 10/27/2019

(Import)

0700 Continuous 1900

DYSINGER EAST

**1400 MW**

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: RGE

**SHORE\_RD\_345\_138\_BK 1**

FWD

Mon 10/21/2019 to Mon 10/21/2019

(Import)

0001 Continuous 2359

**UPDATED****by LI****08/28/2019**

CONED - LIPA

**1350 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI

**HURLYAVE-ROSETON\_\_345\_303**

FWD

Mon 10/21/2019 to Thu 10/31/2019

(Import)

0800 Continuous 1600

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: CHGE

**GILBOA\_-N.SCTLND\_345\_GNS-1**

FWD

Tue 10/22/2019 to Thu 10/24/2019

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2520 MW**

Impacts Total Transfer Capability 455 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**NIAGARA\_345\_230\_AT4**

REV

Wed 10/23/2019 to Tue 12/17/2019

(Export)

0500 Continuous 1700

**UPDATED****by NYPA****09/10/2019**

SCH - OH - NY

**1400 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 1700 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## EGRDNCTY\_345\_138\_AT1

Thu 10/24/2019 to Sun 11/03/2019  
0001 Continuous 0300

UPDATEDby CE09/12/2019

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

## EGRDNCTY\_345\_138\_AT2

Thu 10/24/2019 to Sun 11/03/2019  
0001 Continuous 0300

UPDATEDby CE09/12/2019

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

## SPRNBK -EGRDNCTR\_345\_Y49

Thu 10/24/2019 to Sun 11/03/2019  
0001 Continuous 0300

UPDATEDby CE09/12/2019

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **775 MW**  
Impacts Total Transfer Capability 725 MW  
TTC with All Lines In Service 1500 MW

## GILBOA -N.SCTLND\_345\_GNS-1

Fri 10/25/2019 to Fri 10/25/2019  
1630 Continuous 1730

UPDATEDby NYPA09/19/2019

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2520 MW**  
Impacts Total Transfer Capability 455 MW  
TTC with All Lines In Service 2975 MW

## SHORE\_RD\_345\_138\_BK 2

Mon 10/28/2019 to Mon 10/28/2019  
0001 Continuous 2359

UPDATEDby LI08/28/2019

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

## NIAGARA -ROCHESTR\_345\_NR2

Mon 10/28/2019 to Wed 11/13/2019  
0500 Continuous 1700

UPDATEDby NYPA08/05/2019

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

## HOPATCON-RAMAPO\_500\_5018

Fri 11/01/2019 to Tue 11/05/2019  
0001 Continuous 2200

Work scheduled by: ConEd

FWD	REV
(Import)	(Export)
SCH - PJ - NY <b>1250 MW</b>	<b>1200 MW</b>
Impacts Total Transfer Capability 1350 MW	350 MW
TTC with All Lines In Service 2600 MW	1550 MW



**NYISO TRANSFER LIMITATIONS**

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>HOPATCON-RAMAPO__500_5018</b>					FWD	
Fri 11/01/2019	to	Tue 11/05/2019			(Import)	
0001	Continuous	2200		UPNY CONED	<b>5000 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	5700 MW
<b>RAMAPO__345_345_PAR3500</b>					FWD	REV
Fri 11/01/2019	to	Tue 11/05/2019			(Import)	(Export)
0001	Continuous	2200		SCH - PJ - NY	<b>2150 MW</b>	<b>1250 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	450 MW 300 MW
					TTC with All Lines In Service	2600 MW 1550 MW
<b>RAMAPO__345_345_PAR4500</b>					FWD	REV
Fri 11/01/2019	to	Tue 11/05/2019			(Import)	(Export)
0001	Continuous	2200		SCH - PJ - NY	<b>2150 MW</b>	<b>1250 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	450 MW 300 MW
					TTC with All Lines In Service	2600 MW 1550 MW
<b>RAMAPO__500_345_BK 1500</b>					FWD	REV
Fri 11/01/2019	to	Tue 11/05/2019			(Import)	(Export)
0001	Continuous	2200		SCH - PJ - NY	<b>1250 MW</b>	<b>1200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1350 MW 350 MW
					TTC with All Lines In Service	2600 MW 1550 MW
<b>RAMAPO__500_345_BK 1500</b>					FWD	
Fri 11/01/2019	to	Tue 11/05/2019			(Import)	
0001	Continuous	2200		UPNY CONED	<b>5000 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	5700 MW
<b>SCH-IMO-NYISO_LIMIT_1750</b>					FWD	
Fri 11/01/2019	to	Thu 04/30/2020	<b>UPDATED</b>	<b>by IESO</b> <b>05/03/2019</b>	(Import)	
0001	Continuous	2359			SCH - OH - NY	<b>2050 MW</b>
Work scheduled by: IESO					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	2250 MW
<b>SCH-NYISO-IMO_LIMIT_1600</b>						REV
Fri 11/01/2019	to	Thu 04/30/2020	<b>UPDATED</b>	<b>by IESO</b> <b>05/03/2019</b>		(Export)
0001	Continuous	2359			SCH - OH - NY	<b>1900 MW</b>
Work scheduled by: IESO					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	2000 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

VOLNEY__-MARCY____345_19					FWD	
Fri 11/01/2019 to Fri 11/01/2019					(Import)	
0730 Daily(No Weekends) 1630					CENTRAL EAST - VC	2825 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	150 MW
ARR: 19					TTC with All Lines In Service	2975 MW
VOLNEY__-MARCY____345_19					FWD	
Fri 11/01/2019 to Fri 11/01/2019					(Import)	
0730 Daily(No Weekends) 1630					OSWEGO EXPORT	4900 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	350 MW
ARR: 19					TTC with All Lines In Service	5250 MW
SHORE_RD_345_138_BK 2					FWD	
Mon 11/04/2019 to Mon 11/04/2019					(Import)	
0001 Continuous 2359					CONED - LIPA	1350 MW
Work scheduled by: LI					Impacts Total Transfer Capability	150 MW
UPDATED by LI 08/28/2019					TTC with All Lines In Service	1500 MW
NRTH1385-NOR HBR__138_601					FWD	REV
Mon 11/04/2019 to Fri 11/15/2019					(Import)	(Export)
0001 Continuous 2359					SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602					FWD	REV
Mon 11/04/2019 to Fri 11/15/2019					(Import)	(Export)
0001 2359					SCH - NPX_1385	0 MW 0 MW
Work scheduled by:					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603					FWD	REV
Mon 11/04/2019 to Fri 11/15/2019					(Import)	(Export)
0001 2359					SCH - NPX_1385	0 MW 0 MW
Work scheduled by:					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_602					FWD	REV
Mon 11/04/2019 to Fri 11/15/2019					(Import)	(Export)
0001 Continuous 2359					SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NRTH1385-NOR HBR\_\_138\_602 & NRTH1385-NOR HBR\_\_138\_603

Mon 11/04/2019 to Fri 11/15/2019  
0001 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

### NRTH1385-NOR HBR\_\_138\_603

Mon 11/04/2019 to Fri 11/15/2019  
0001 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

### NRTH1385-NRTHPORT\_138\_NNC

Mon 11/04/2019 to Fri 11/15/2019  
0001 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Mon 11/04/2019 to Thu 11/07/2019  
0800 Continuous 1500

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJM_VFT	0 MW	0 MW
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

### MARCY\_\_-N.SCTLND\_345\_18

Wed 11/06/2019 to Wed 11/13/2019 UPDATED by NYPA 09/11/2019  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
CENTRAL EAST - VC	2090 MW
Impacts Total Transfer Capability	885 MW
TTC with All Lines In Service	2975 MW

### MARCY\_\_345KV\_CSC

Wed 11/06/2019 to Fri 11/22/2019 UPDATED by NYPA 09/11/2019  
0500 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	2925 MW
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	2975 MW

### MARCY\_\_765\_345\_AT2

Wed 11/06/2019 to Fri 11/22/2019 UPDATED by NYPA 09/11/2019  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
MOSES SOUTH	1700 MW
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HURLYAVE-ROSETON\_\_345\_303

Wed 11/06/2019 to Fri 12/06/2019

0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED

4100 MW

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 5700 MW

## E13THSTA-FARRAGUT\_345\_45

Tue 11/12/2019 to Tue 11/12/2019

0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

## WATRCURE-OAKDALE\_\_345\_31

Tue 11/12/2019 to Tue 11/12/2019

1300 Continuous 1500

Work scheduled by: NYSEG

UPDATEDby NYSEG 09/13/2019

FWD

(Import) (Export)

SCH - PJ - NY

2600 MW 1300 MW

Impacts Total Transfer Capability 0 MW 250 MW

TTC with All Lines In Service 2600 MW 1550 MW

## PLSNTVLY-WOOD\_ST\_\_345\_F31

Thu 11/14/2019 to Thu 11/14/2019

0001 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

4000 MW

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

## PLSNTVLY\_345KV\_RNS4

Thu 11/14/2019 to Thu 11/14/2019

0001 Continuous 2200

Work scheduled by: ConEd

UPDATEDby NYISO 09/18/2019

FWD

(Import)

UPNY CONED

3800 MW

Impacts Total Transfer Capability 1900 MW

TTC with All Lines In Service 5700 MW

## E13THSTA-FARRAGUT\_345\_45

Thu 11/14/2019 to Thu 11/14/2019

0130 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

Sun 11/17/2019 to Mon 11/18/2019

0301 Continuous 0300

Work scheduled by: ConEd

UPDATEDby CONED 09/09/2019

FWD

(Import)

UPNY CONED

4350 MW

Impacts Total Transfer Capability 1350 MW

TTC with All Lines In Service 5700 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EASTVIEW-SPRNBK__345_W79</b>					FWD		
Sun 11/17/2019	to	Mon 11/18/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>09/09/2019</u>	(Import)	
0301	Continuous	0300				UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1350 MW	
					TTC with All Lines In Service	5700 MW	
<b>SPRNBK__345KV_RNS5</b>					FWD		
Mon 11/18/2019	to	Mon 11/18/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>09/09/2019</u>	(Import)	
0301	Continuous	0330				SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW	
					TTC with All Lines In Service	4600 MW	
<b>EASTVIEW-SPRNBK__345_W64</b>					FWD		
Mon 11/18/2019	to	Tue 11/19/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>09/09/2019</u>	(Import)	
0301	Continuous	0200				UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1350 MW	
					TTC with All Lines In Service	5700 MW	
<b>MILLWOOD-EASTVIEW_345_W99</b>					FWD		
Mon 11/18/2019	to	Tue 11/19/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>09/09/2019</u>	(Import)	
0301	Continuous	0200				UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1350 MW	
					TTC with All Lines In Service	5700 MW	
<b>BERKSHIR-ALPS____345_393</b>					FWD	REV	
Mon 11/18/2019	to	Wed 11/27/2019			(Import)	(Export)	
0600	Continuous	1700			SCH - NE - NY	<b>1150 MW</b>	<b>1300 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	250 MW	500 MW
					TTC with All Lines In Service	1400 MW	1800 MW
					<b>ARR: 78</b>		
<b>BERKSHIR-ALPS____345_393</b>					FWD	REV	
Mon 11/18/2019	to	Wed 11/27/2019			(Import)	(Export)	
0600	Continuous	1700			SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	100 MW	100 MW
					TTC with All Lines In Service	200 MW	200 MW
					<b>ARR: 78</b>		
<b>BERKSHIR-ALPS____345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>					FWD	REV	
Mon 11/18/2019	to	Wed 11/27/2019			(Import)	(Export)	
0600		1700			SCH - NE - NY	<b>1150 MW</b>	<b>1300 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	250 MW	500 MW
					TTC with All Lines In Service	1400 MW	1800 MW
					<b>ARR: 78</b>		

# NYISO TRANSFER LIMITATIONS

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### BERKSHIR-NORTHFLD\_345\_312

Mon 11/18/2019 to Wed 11/27/2019  
0600 Continuous 1700  
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY	1400 MW	1500 MW
Impacts Total Transfer Capability	0 MW	300 MW
TTC with All Lines In Service	1400 MW	1800 MW

### BERKSHIR-NORTHFLD\_345\_312

Mon 11/18/2019 to Wed 11/27/2019  
0600 Continuous 1700  
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

### SCH-NE-NYISO\_LIMIT\_800

Mon 11/18/2019 to Wed 11/27/2019  
0600 Continuous 1700  
Work scheduled by: ISONE

	FWD (Import)
SCH - NE - NY	1000 MW
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	1400 MW

### SCH-NYISO-NE\_LIMIT\_500

Mon 11/18/2019 to Wed 11/27/2019  
0600 Continuous 1700  
Work scheduled by: ISONE

	REV (Export)
SCH - NE - NY	700 MW
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	1800 MW

### SPRNBK\_345KV\_RNS5

Tue 11/19/2019 to Tue 11/19/2019 **UPDATED by CONED 09/09/2019**  
0130 Continuous 0200  
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	3200 MW
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

### RAMAPO\_-LADENTWN\_345\_W72

Mon 11/25/2019 to Mon 11/25/2019  
0001 Continuous 2200  
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	4400 MW
Impacts Total Transfer Capability	1300 MW
TTC with All Lines In Service	5700 MW

### MOSES\_-ADIRNDCK\_230\_MA2

Mon 11/25/2019 to Wed 11/27/2019  
0700 Continuous 1500  
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 12/02/2019 to Fri 12/06/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## N.SCTLND-ALPS\_\_\_\_345\_2

Mon 12/02/2019 to Mon 12/02/2019  
0730 Daily(No Weekends) 1630

Work scheduled by: NGrid

FWD REV  
(Import) (Export)  
SCH - NE - NY **900 MW 1700 MW**  
Impacts Total Transfer Capability 500 MW 100 MW  
TTC with All Lines In Service 1400 MW 1800 MW

## N.SCTLND-ALPS\_\_\_\_345\_2

Mon 12/02/2019 to Mon 12/02/2019  
0730 Daily(No Weekends) 1630

Work scheduled by: NGrid

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **100 MW 100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA1

Mon 12/09/2019 to Fri 12/13/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## SHOR\_NPX-SHOREHAM\_138\_CSC

Thu 12/12/2019 to Fri 12/20/2019  
0800 Continuous 1500

Work scheduled by: ISONE

FWD REV  
(Import) (Export)  
SCH - NPX\_CSC **0 MW 0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 12/16/2019 to Mon 12/16/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA1

Tue 12/17/2019 to Fri 12/20/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Thu 01/02/2020 to Sun 03/01/2020  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## LADENTWN-BUCHAN\_S\_345\_Y88

Wed 01/15/2020 to Thu 02/13/2020  
0001 Continuous 2359

Work scheduled by: ORU

11/05/2018

FWD  
(Import)  
UPNY CONED **4800 MW**  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 5700 MW

## MOTTHAVN-RAINEY\_\_\_345\_Q11

Sun 02/23/2020 to Sun 03/01/2020  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## NIAGARA\_-PACKARD\_\_\_230\_62

Fri 02/28/2020 to Fri 02/28/2020  
0500 Continuous 1530

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1100 MW 950 MW**  
Impacts Total Transfer Capability 1150 MW 1050 MW  
TTC with All Lines In Service 2250 MW 2000 MW

## CHATGUAY-MASSENA\_\_\_765\_7040

Mon 03/02/2020 to Fri 03/06/2020  
0500 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 08/08/2019

FWD  
(Import)  
MOSES SOUTH **1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

## CHATGUAY-MASSENA\_\_\_765\_7040

Mon 03/02/2020 to Fri 03/06/2020  
0500 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 08/08/2019

FWD REV  
(Import) (Export)  
SCH - HQ - NY **0 MW 0 MW**  
Impacts Total Transfer Capability 1500 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

## MARCY\_\_\_765\_345\_AT1

Mon 03/02/2020 to Fri 03/06/2020  
0500 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 08/08/2019

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1750 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW



**NYISO TRANSFER LIMITATIONS**

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY\_\_\_\_765\_345\_AT2

FWD

Mon 03/02/2020 to Fri 03/06/2020

(Import)

0500 Continuous 1730

MOSES SOUTH

1700 MW

Work scheduled by: NYPA

ARR: 19

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

MASSENA\_-MARCY\_\_\_\_765\_MSU1

FWD

Mon 03/02/2020 to Fri 03/06/2020

(Import)

0500 Continuous 1730

UPDATEDby NYPA08/08/2019

CENTRAL EAST - VC

2265 MW

Work scheduled by: NYPA

Impacts Total Transfer Capability 710 MW

TTC with All Lines In Service 2975 MW

MASSENA\_-MARCY\_\_\_\_765\_MSU1

FWD

Mon 03/02/2020 to Fri 03/06/2020

(Import)

0500 Continuous 1730

UPDATEDby NYPA08/08/2019

MOSES SOUTH

500 MW

Work scheduled by: NYPA

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

MASSENA\_-MARCY\_\_\_\_765\_MSU1

FWD

REV

Mon 03/02/2020 to Fri 03/06/2020

(Import) (Export)

0500 Continuous 1730

UPDATEDby NYPA08/08/2019

SCH - HQ - NY

475 MW 1000 MW

Work scheduled by: NYPA

Impacts Total Transfer Capability 1025 MW 0 MW

TTC with All Lines In Service 1500 MW 1000 MW

MASSENA\_-MARCY\_\_\_\_765\_MSU1

FWD

Mon 03/02/2020 to Fri 03/06/2020

(Import)

0500 Continuous 1730

UPDATEDby NYPA08/08/2019

SCH - HQ\_CEDARS

90 MW

Work scheduled by: NYPA

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

MASSENA\_-MARCY\_\_\_\_765\_MSU1 &amp; CHATGUAY-MASSENA\_765\_7040

FWD

Mon 03/02/2020 to Fri 03/06/2020

(Import)

0500 1730

MOSES SOUTH

500 MW

Work scheduled by:

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

MOSES\_-MASSENA\_230\_MMS1 &amp; MOSES\_-MASSENA\_230\_MMS2

FWD

REV

Mon 03/02/2020 to Fri 03/06/2020

(Import) (Export)

0500 1730

SCH - HQ - NY

850 MW 0 MW

Work scheduled by:

Impacts Total Transfer Capability 650 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5700MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES\_\_\_-MASSENA\_\_\_230\_MMS1 & MOSES\_\_\_-MASSENA\_\_\_230\_MMS2

FWD

Mon 03/02/2020 to Fri 03/06/2020

(Import)

0500

1730

SCH - HQ\_CEDARS

**90 MW**

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

Work scheduled by:

STLAWRNC-MOSES\_\_\_230\_L33P & MASSENA\_\_\_-MARCY\_\_\_765\_MSU1

FWD

Mon 03/02/2020 to Fri 03/06/2020

(Import)

0500

1730

SCH - HQ\_CEDARS

**90 MW**

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

Work scheduled by:

STLAWRNC-MOSES\_\_\_230\_L33P & MOSES\_\_\_-MASSENA\_\_\_230\_MMS1 & MOSES\_\_\_-  
 MASSENA\_\_\_230\_MMS2

FWD

(Import)

Mon 03/02/2020 to Fri 03/06/2020

0500

1730

SCH - HQ\_CEDARS

**90 MW**

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

Work scheduled by:

EASTVIEW-SPRNBRK\_\_\_345\_W78

FWD

(Import)

Fri 03/06/2020 to Sat 03/07/2020

0001

Continuous

0200

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1350 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

MILLWOOD-EASTVIEW\_\_\_345\_W85

FWD

(Import)

Fri 03/06/2020 to Sat 03/07/2020

0001

Continuous

0200

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1350 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

SPRNBRK\_\_\_345KV\_RNS3

FWD

(Import)

Fri 03/06/2020 to Sat 03/07/2020

0001

Continuous

0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

MOSES\_\_\_-ADIRNDCK\_\_\_230\_MA1

FWD

(Import)

Sat 03/07/2020 to Fri 05/29/2020

0700

Continuous

1300

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

VOLNEY__-MARCY__345_19					FWD
Tue 03/10/2020	to	Tue 03/10/2020	<u>UPDATED</u>	<u>by NYPA</u> <u>09/24/2019</u>	(Import)
0700	Continuous	1530			CENTRAL EAST - VC <b>2825 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 150 MW
ARR: 19					TTC with All Lines In Service 2975 MW
VOLNEY__-MARCY__345_19					FWD
Tue 03/10/2020	to	Tue 03/10/2020	<u>UPDATED</u>	<u>by NYPA</u> <u>09/24/2019</u>	(Import)
0700	Continuous	1530			OSWEGO EXPORT <b>4900 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 350 MW
ARR: 19					TTC with All Lines In Service 5250 MW
FRASANNX-COOPERS__345_UCC2-41					FWD
Wed 03/11/2020	to	Thu 03/12/2020			(Import)
0700	Continuous	1530			CENTRAL EAST - VC <b>2500 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 475 MW
ARR: 19					TTC with All Lines In Service 2975 MW
MARCY__-FRASANNX_345_UCC2-41					FWD
Wed 03/11/2020	to	Thu 03/12/2020			(Import)
0700	Continuous	1530			CENTRAL EAST - VC <b>2500 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 475 MW
ARR: 19					TTC with All Lines In Service 2975 MW
ROCHESTR-PANNELL__345_RP2					FWD
Sat 03/14/2020	to	Mon 03/23/2020			(Import)
0500	Continuous	1700			DYSINGER EAST <b>2300 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW
					TTC with All Lines In Service 3150 MW
MARCY__345KV_CSC					FWD
Mon 03/16/2020	to	Fri 03/27/2020			(Import)
0500	Continuous	1730			CENTRAL EAST - VC <b>2925 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 50 MW
					TTC with All Lines In Service 2975 MW
ROSETON_-EFISHKIL_345_RFK305					FWD
Mon 03/16/2020	to	Fri 04/03/2020			(Import)
0700	Continuous	1530			UPNY CONED <b>4800 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 900 MW
					TTC with All Lines In Service 5700 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5700MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_-KINTIGH\_345\_NS1-38**

FWD

Fri 03/27/2020 to Fri 03/27/2020

(Import)

0600 Continuous 1530

DYSINGER EAST **1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**MARCY\_-EDIC\_345\_UE1-7**

FWD

Tue 03/31/2020 to Tue 03/31/2020

(Import)

0700 Continuous 1530

**UPDATED by NYPA 09/24/2019**OSWEGO EXPORT **5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19&16****MARCY\_-N.SCTLND\_345\_18**

FWD

Tue 04/07/2020 to Wed 04/08/2020

(Import)

0700 Continuous 1530

**UPDATED by NYPA 09/24/2019**CENTRAL EAST - VC **2090 MW**

Impacts Total Transfer Capability 885 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 19****FRASER\_-GILBOA\_345\_GF5-35**

FWD

Mon 04/13/2020 to Wed 04/22/2020

(Import)

0700 Continuous 1730

CENTRAL EAST - VC **2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**NIAGARA\_-ROCHESTR\_345\_NR2**

FWD

Mon 04/20/2020 to Fri 05/01/2020

(Import)

0500 Continuous 1700

DYSINGER EAST **1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**DOLSONAV-ROCKTVRN\_345\_DART44**

FWD

Mon 04/27/2020 to Sun 05/10/2020

(Import)

0700 Continuous 1730

**UPDATED by NYPA 03/21/2019**CENTRAL EAST - VC **2720 MW**

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**LEEDS\_-HURLYAVE\_345\_301**

FWD

Mon 04/27/2020 to Fri 05/29/2020

(Import)

0800 Continuous 1600

UPNY CONED **4100 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: CHGE

**NYISO TRANSFER LIMITATIONS**

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-IMO-NYISO\_LIMIT\_1600**

FWD

Fri 05/01/2020 to Sat 10/31/2020 **UPDATED by IESO 05/03/2019**

(Import)

0001 Continuous 2359

Work scheduled by: IESO

SCH - OH - NY

**1900 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 1900 MW

**PANNELL -CLAY\_345\_2**

FWD

Mon 05/04/2020 to Fri 05/08/2020

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

**PANNELL -CLAY\_345\_1**

FWD

Mon 05/11/2020 to Fri 05/15/2020

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

**COOPERS -DOLSONAV\_345\_CCDA42**

FWD

Mon 05/11/2020 to Fri 05/29/2020 **UPDATED by NYPA 03/21/2019**

(Import)

0700 Continuous 1730

Work scheduled by: NYPA

CENTRAL EAST - VC

**2720 MW**

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

**NIAGARA -ROCHESTR\_345\_NR2**

FWD

Mon 05/18/2020 to Fri 05/22/2020

(Import)

0500 Continuous 1530

Work scheduled by: NYPA

DYSINGER EAST

**1400 MW**

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

**MOSES -ADIRNDCK\_230\_MA2**

FWD

Mon 06/01/2020 to Fri 07/31/2020

(Import)

0700 Continuous 1730

Work scheduled by: NYPA

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

**NIAGARA\_345\_230\_AT4**

REV

Mon 06/29/2020 to Tue 06/30/2020

(Export)

0500 Continuous 1530

Work scheduled by: NYPA

SCH - OH - NY

**1400 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 1700 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA__765_7040						FWD				
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)				
0500	Continuous	1730				MOSES SOUTH	1550 MW			
Work scheduled by: NYPA						Impacts Total Transfer Capability	1600 MW			
						TTC with All Lines In Service	3150 MW			
CHATGUAY-MASSENA__765_7040						FWD	REV			
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	(Export)			
0500	Continuous	1730				SCH - HQ - NY	0 MW	0 MW		
Work scheduled by: NYPA						Impacts Total Transfer Capability	1500 MW			
						TTC with All Lines In Service	1500 MW			
MARCY__765_345_AT1						FWD				
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)				
0500	Continuous	1730				MOSES SOUTH	1750 MW			
Work scheduled by: NYPA						Impacts Total Transfer Capability	1400 MW			
						TTC with All Lines In Service	3150 MW			
MASSENA_-MARCY__765_MSU1						FWD				
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)				
0500	Continuous	1730				CENTRAL EAST - VC	2265 MW			
Work scheduled by: NYPA						Impacts Total Transfer Capability	710 MW			
						TTC with All Lines In Service	2975 MW			
MASSENA_-MARCY__765_MSU1						FWD				
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)				
0500	Continuous	1730				MOSES SOUTH	500 MW			
Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW			
						TTC with All Lines In Service	3150 MW			
MASSENA_-MARCY__765_MSU1						FWD	REV			
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	(Export)			
0500	Continuous	1730				SCH - HQ - NY	475 MW	1000 MW		
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW			
						TTC with All Lines In Service	1500 MW			
MASSENA_-MARCY__765_MSU1						FWD				
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)				
0500	Continuous	1730				SCH - HQ_CEDARS	90 MW			
Work scheduled by: NYPA						Impacts Total Transfer Capability	100 MW			
						TTC with All Lines In Service	190 MW			

**NYISO TRANSFER LIMITATIONS**

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA\_-MARCY\_765\_MSU1 & CHATGUAY-MASSENA\_765\_7040

Sat 08/01/2020 to Sun 08/02/2020  
0500 1730

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH 500 MW  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

MOSES\_-MASSENA\_230\_MMS1 & MOSES\_-MASSENA\_230\_MMS2

Sat 08/01/2020 to Sun 08/02/2020  
0500 1730

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY 850 MW 0 MW  
Impacts Total Transfer Capability 650 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

MOSES\_-MASSENA\_230\_MMS1 & MOSES\_-MASSENA\_230\_MMS2

Sat 08/01/2020 to Sun 08/02/2020  
0500 1730

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS 90 MW  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 190 MW

STLAWRNC-MOSES\_230\_L33P & MASSENA\_-MARCY\_765\_MSU1

Sat 08/01/2020 to Sun 08/02/2020  
0500 1730

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS 90 MW  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 190 MW

STLAWRNC-MOSES\_230\_L33P & MOSES\_-MASSENA\_230\_MMS1 & MOSES\_-MASSENA\_230\_MMS2

Sat 08/01/2020 to Sun 08/02/2020  
0500 1730

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS 90 MW  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 190 MW

MOSES\_-ADIRNDCK\_230\_MA2

Mon 08/03/2020 to Sun 09/13/2020  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2100 MW  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

FRASANX-COOPERS\_345\_UCC2-41

Mon 09/07/2020 to Fri 10/23/2020  
0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 03/01/2019

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC 2500 MW  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_-FRASANNX\_345\_UCC2-41**

FWD

Mon 09/07/2020 to Fri 10/23/2020  
0700 Continuous 1730

UPDATEDby NYPA03/01/2019

(Import)

Work scheduled by: NYPA

**ARR: 19**

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

**MARCY\_\_\_765\_345\_AT1**

FWD

Mon 09/14/2020 to Mon 09/14/2020  
0500 Continuous 1730

(Import)

Work scheduled by: NYPA

**ARR: 19**

MOSES SOUTH

**1750 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

**NIAGARA\_-KINTIGH\_345\_NS1-38**

FWD

Mon 09/14/2020 to Thu 09/17/2020  
0500 Continuous 1530

(Import)

Work scheduled by: NYPA

DYSINGER EAST

**1400 MW**

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Tue 09/15/2020 to Sat 11/14/2020  
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

**DUNWODIE\_345KV\_3**

FWD

Thu 10/01/2020 to Thu 10/01/2020  
0001 Continuous 0030

(Import)

Work scheduled by: ConEd

UPDATEDby CONED09/05/2019

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_5**

FWD

Thu 10/01/2020 to Thu 10/01/2020  
0001 Continuous 0030

(Import)

Work scheduled by: ConEd

UPDATEDby CONED09/05/2019

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**DUNWODIE-MOTTHAVN\_345\_71**

FWD

Thu 10/01/2020 to Thu 11/05/2020  
0001 Continuous 0300

(Import)

Work scheduled by: ConEd

UPDATEDby CONED09/05/2019

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW



**NYISO TRANSFER LIMITATIONS**

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**ROSETON\_-ROCKTVRN\_345\_311**

FWD

Mon 10/12/2020 to Fri 11/13/2020

(Import)

0800 Continuous 1600

UPNY CONED

**4400 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: CHGE

**SCH-IMO-NYISO\_LIMIT\_1750**

FWD

Sun 11/01/2020 to Fri 04/30/2021

(Import)

0001 Continuous 2359

UPDATEDby IESO05/03/2019

SCH - OH - NY

**2050 MW**

Impacts Total Transfer Capability 200 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: IESO

**SCH-NYISO-IMO\_LIMIT\_1600**

REV

Sun 11/01/2020 to Fri 04/30/2021

(Export)

0001 Continuous 2359

UPDATEDby IESO05/03/2019

SCH - OH - NY

**1900 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 2000 MW

Work scheduled by: IESO

**DUNWODIE\_345KV\_3**

FWD

Thu 11/05/2020 to Thu 11/05/2020

(Import)

0230 Continuous 0300

UPDATEDby CONED09/05/2019

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**DUNWODIE\_345KV\_5**

FWD

Thu 11/05/2020 to Thu 11/05/2020

(Import)

0230 Continuous 0300

UPDATEDby CONED09/05/2019

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**PLSNTVLE-DUNWODIE\_345\_W89**

FWD

Mon 11/16/2020 to Mon 11/16/2020

(Import)

0001 Continuous 0030

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**PLSNTVLE-DUNWODIE\_345\_W89**

FWD

Thu 11/26/2020 to Thu 11/26/2020

(Import)

0230 Continuous 0300

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**NYISO TRANSFER LIMITATIONS**

Tuesday ,September24, 2019 to Thursday ,March 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES\_\_\_-ADIRNDCK\_230\_MA1

FWD

Tue 12/01/2020 to Mon 05/31/2021

(Import)

0700 Continuous 1300

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

MOTTHAVN-RAINEY\_\_\_345\_Q11

FWD

Mon 03/01/2021 to Tue 04/06/2021

(Import)

0001 Continuous 0700

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd