

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**HUDSONP\_-FARRAGUT\_345\_B3402**

Mon 01/15/2018 to Fri 05/01/2020 **EXTENDED** **by CONED** **10/08/2019**  
 0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403**

Mon 01/15/2018 to Fri 05/01/2020  
 0001 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2550 MW</b>	<b>1600 MW</b>
Impacts Total Transfer Capability	350 MW	250 MW
TTC with All Lines In Service	2900 MW	1850 MW

**MARION\_-FARRAGUT\_345\_C3403**

Mon 01/15/2018 to Fri 05/01/2020 **EXTENDED** **by CONED** **10/08/2019**  
 0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**STLAWRNC-MOSES\_230\_L33P**

Mon 04/30/2018 to Fri 12/31/2021 **EXT FORCE** **by IESO** **08/21/2018**  
 0456 Continuous 2359

Work scheduled by: IESO

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**CHAT\_DC\_GC2**

Sun 10/13/2019 to Mon 11/18/2019 **UPDATED** **by HQ** **10/28/2019**  
 2301 Continuous 1640

Work scheduled by: HQ

	FWD
	(Import)
MOSES SOUTH	<b>2850 MW</b>
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

**CHAT\_DC\_GC2**

Sun 10/13/2019 to Mon 11/18/2019 **UPDATED** **by HQ** **10/28/2019**  
 2301 Continuous 1640

Work scheduled by: HQ

	REV
	(Export)
SCH - HQ - NY	<b>500 MW</b>
Impacts Total Transfer Capability	500 MW
TTC with All Lines In Service	1000 MW

**NIAGARA\_345\_230\_AT4**

Wed 10/23/2019 to Tue 12/17/2019 **UPDATED** **by NYPA** **09/10/2019**  
 0500 Continuous 1700

Work scheduled by: NYPA

	REV
	(Export)
SCH - OH - NY	<b>1750 MW</b>
Impacts Total Transfer Capability	150 MW
TTC with All Lines In Service	1900 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-IMO-NYISO_LIMIT_1750</b>						FWD
Fri 11/01/2019	to	Thu 04/30/2020	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				<b>2050 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability 0 MW
						TTC with All Lines In Service 2050 MW
<b>SCH-NYISO-IMO_LIMIT_1600</b>						REV
Fri 11/01/2019	to	Thu 04/30/2020	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Export)
0001	Continuous	2359				<b>1900 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability 0 MW
						TTC with All Lines In Service 1900 MW
<b>SCH-NYISO-NE_LIMIT_1500</b>						REV
Fri 11/01/2019	to	Thu 04/30/2020				(Export)
0001	Continuous	2359				<b>1700 MW</b>
Work scheduled by: NYISO						Impacts Total Transfer Capability 0 MW
						TTC with All Lines In Service 1700 MW
<b>SCH-HQ-NYISO_LIMIT_1150</b>						FWD
Wed 11/06/2019	to	Mon 11/18/2019	<u>UPDATED</u>	<u>by HQ</u>	<u>10/28/2019</u>	(Import)
0500	Continuous	1651				<b>1150 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability 350 MW
						TTC with All Lines In Service 1500 MW
<b>MARCY___345KV_CSC</b>						FWD
Wed 11/06/2019	to	Fri 11/22/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/11/2019</u>	(Import)
0500	Continuous	1730				<b>2925 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 50 MW
						TTC with All Lines In Service 2975 MW
<b>MARCY___765_345_AT2</b>						FWD
Wed 11/06/2019	to	Fri 11/22/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/11/2019</u>	(Import)
0500	Continuous	1730				<b>1700 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 1450 MW
						TTC with All Lines In Service 3150 MW
<b>HURLYAVE-ROSETON__345_303</b>						FWD
Wed 11/06/2019	to	Fri 12/06/2019	<u>UPDATED</u>	<u>by CH</u>	<u>10/21/2019</u>	(Import)
0800	Continuous	1600				<b>4100 MW</b>
Work scheduled by: CHGE						Impacts Total Transfer Capability 1600 MW
						TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>KINTIGH_-ROCHESTR_345_SR1-39</b>						FWD
Thu 11/07/2019	to	Thu 11/14/2019	<u>UPDATED</u>	<u>by RGE</u>	<u>11/13/2019</u>	(Import)
0700	Continuous	1900				DYSINGER EAST <b>1700 MW</b>
Work scheduled by: RGE						Impacts Total Transfer Capability 1450 MW
						TTC with All Lines In Service 3150 MW
<b>SCH-IMO-NYISO_LIMIT_1400</b>						FWD
Tue 11/12/2019	to	Fri 11/29/2019	<u>UPDATED</u>	<u>by IESO</u>	<u>11/11/2019</u>	(Import)
0501	Continuous	2359				SCH - OH - NY <b>1700 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability 350 MW
						TTC with All Lines In Service 2050 MW
<b>SCH-NYISO-IMO_LIMIT_1400</b>						REV
Tue 11/12/2019	to	Fri 11/29/2019	<u>UPDATED</u>	<u>by IESO</u>	<u>11/11/2019</u>	(Export)
0501	Continuous	2359				SCH - OH - NY <b>1700 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability 200 MW
						TTC with All Lines In Service 1900 MW
<b>PLSNTVLY-WOOD_ST_345_F31</b>						FWD
Thu 11/14/2019	to	Thu 11/14/2019	<u>UPDATED</u>	<u>by NYISO</u>	<u>09/18/2019</u>	(Import)
0001	Continuous	2200				UPNY CONED <b>4000 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 1700 MW
						TTC with All Lines In Service 5700 MW
<b>PLSNTVLY_345KV_RNS4</b>						FWD
Thu 11/14/2019	to	Thu 11/14/2019	<u>UPDATED</u>	<u>by NYISO</u>	<u>09/18/2019</u>	(Import)
0001	Continuous	2200				UPNY CONED <b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 1900 MW
						TTC with All Lines In Service 5700 MW
<b>PLSNTVLY-WOOD_ST_345_F30</b>						FWD
Fri 11/15/2019	to	Fri 11/15/2019	<u>CANCELLED</u>	<u>by ConEd</u>	<u>11/15/2019</u>	(Import)
0001	Continuous	0030				UPNY CONED <b>4000 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 1700 MW
						TTC with All Lines In Service 5700 MW
<b>PLSNTVLY_345KV_RNS5</b>						FWD
Fri 11/15/2019	to	Fri 11/15/2019	<u>CANCELLED</u>	<u>by ConEd</u>	<u>11/15/2019</u>	(Import)
0001	Continuous	0030				UPNY CONED <b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 1900 MW
						TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD\_345KV\_18

Fri 11/15/2019 to Sat 11/16/2019  
 0001 Continuous 0200  
 Work scheduled by: ConEd

**CANCELLED** by **ConEd** 11/15/2019

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1350 MW  
 TTC with All Lines In Service 5700 MW

PLSNTVLY-WOOD\_ST\_\_345\_F30

Sat 11/16/2019 to Sat 11/16/2019  
 0130 Continuous 0200  
 Work scheduled by: ConEd

**CANCELLED** by **ConEd** 11/15/2019

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

PLSNTVLY\_345KV\_RNS5

Sat 11/16/2019 to Sat 11/16/2019  
 0130 Continuous 0200  
 Work scheduled by: ConEd

**CANCELLED** by **ConEd** 11/15/2019

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 1900 MW  
 TTC with All Lines In Service 5700 MW

LADENTWN-BUCHAN\_S\_345\_Y88

Sat 11/16/2019 to Sun 11/17/2019  
 0201 Continuous 0300  
 Work scheduled by: ORU

**UPDATED** by **ORU** 11/13/2019

FWD  
 (Import)  
 UPNY CONED **4800 MW**  
 Impacts Total Transfer Capability 900 MW  
 TTC with All Lines In Service 5700 MW

NIAGARA\_-ROCHESTR\_345\_NR2

Sat 11/16/2019 to Tue 11/19/2019  
 0700 Continuous 1900  
 Work scheduled by: RGE

**CANCELLED** by **RGE** 11/14/2019

FWD  
 (Import)  
 DYSINGER EAST **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

SCH-NE-NYISO\_LIMIT\_500

Sun 11/17/2019 to Sun 11/17/2019  
 1100 Continuous 1600  
 Work scheduled by: ISONE

FWD  
 (Import)  
 SCH - NE - NY **700 MW**  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 1400 MW

SCH-NYISO-NE\_LIMIT\_1200

Sun 11/17/2019 to Sun 11/17/2019  
 1100 Continuous 1600  
 Work scheduled by: ISONE

REV  
 (Export)  
 SCH - NE - NY **1400 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 1700 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

OSWEGO\_COMPLEX\_AVR\_O/S

Mon 11/18/2019 to Mon 11/25/2019  
 0221 Continuous 1200  
 Work scheduled by: Gen

FWD  
 (Import)  
 CENTRAL EAST - VC **2870 MW**  
 Impacts Total Transfer Capability 105 MW  
 TTC with All Lines In Service 2975 MW

W49TH\_ST\_345KV\_6

Mon 11/18/2019 to Mon 11/18/2019  
 0230 Continuous 0259  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **370 MW**  
 Impacts Total Transfer Capability 290 MW  
 TTC with All Lines In Service 660 MW

W49TH\_ST\_345KV\_6

Mon 11/18/2019 to Mon 11/18/2019 **CANCELLED by ConEd 11/15/2019**  
 0230 Continuous 0259  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **370 MW**  
 Impacts Total Transfer Capability 290 MW  
 TTC with All Lines In Service 660 MW

E13THSTA-FARRAGUT\_345\_46

Mon 11/18/2019 to Thu 11/21/2019  
 0230 Continuous 0259  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

E13THSTA-FARRAGUT\_345\_46

Mon 11/18/2019 to Thu 11/21/2019 **CANCELLED by ConEd 11/15/2019**  
 0230 Continuous 0259  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

W49TH\_ST-E13THSTA\_345\_M55

Mon 11/18/2019 to Thu 11/21/2019 **CANCELLED by ConEd 11/15/2019**  
 0230 Continuous 0259  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

W49TH\_ST-E13THSTA\_345\_M55

Mon 11/18/2019 to Thu 11/21/2019  
 0230 Continuous 0259  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BERKSHIR-ALPS_____345_393</b>			FWD	REV
Mon 11/18/2019	to	Wed 11/27/2019	(Import)	(Export)
0600	Continuous	1700	<b>SCH - NE - NY</b>	<b>1150 MW 1700 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	250 MW 0 MW
			TTC with All Lines In Service	1400 MW 1700 MW
<b>ARR: 78</b>				
<b>BERKSHIR-ALPS_____345_393</b>			FWD	REV
Mon 11/18/2019	to	Wed 11/27/2019	(Import)	(Export)
0600	Continuous	1700	<b>SCH - NPX_1385</b>	<b>100 MW 100 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>ARR: 78</b>				
<b>BERKSHIR-ALPS_____345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>			FWD	REV
Mon 11/18/2019	to	Wed 11/27/2019	(Import)	(Export)
0600		1700	<b>SCH - NE - NY</b>	<b>1150 MW 1700 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	250 MW 0 MW
			TTC with All Lines In Service	1400 MW 1700 MW
<b>ARR: 78</b>				
<b>BERKSHIR-NORTHFLD_345_312</b>			FWD	
Mon 11/18/2019	to	Wed 11/27/2019	(Import)	
0600	Continuous	1700	<b>SCH - NE - NY</b>	<b>1400 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	0 MW
			TTC with All Lines In Service	1400 MW
<b>BERKSHIR-NORTHFLD_345_312</b>			FWD	REV
Mon 11/18/2019	to	Wed 11/27/2019	(Import)	(Export)
0600	Continuous	1700	<b>SCH - NPX_1385</b>	<b>100 MW 100 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>SCH-NE-NYISO_LIMIT_700</b>			FWD	
Mon 11/18/2019	to	Wed 11/27/2019	(Import)	
0600	Continuous	1700	<b>SCH - NE - NY</b>	<b>900 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_500</b>				REV
Mon 11/18/2019	to	Wed 11/27/2019		(Export)
0600	Continuous	1700	<b>SCH - NE - NY</b>	<b>700 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	1000 MW
			TTC with All Lines In Service	1700 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_6**

Thu 11/21/2019 to Thu 11/21/2019  
 0230 Continuous 0259  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **370 MW**  
 Impacts Total Transfer Capability 290 MW  
 TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_6**

Thu 11/21/2019 to Thu 11/21/2019 **CANCELLED by ConEd 11/15/2019**  
 0230 Continuous 0259  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **370 MW**  
 Impacts Total Transfer Capability 290 MW  
 TTC with All Lines In Service 660 MW

**RAMAPO\_\_-LADENTWN\_345\_W72**

Mon 11/25/2019 to Tue 11/26/2019 **EXTENDED by CONED 11/10/2019**  
 0001 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4400 MW**  
 Impacts Total Transfer Capability 1300 MW  
 TTC with All Lines In Service 5700 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Mon 11/25/2019 to Wed 11/27/2019 **CANCELLED by NYPA 11/18/2019**  
 0700 Continuous 1500  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**VOLNEY\_\_-MARCY\_\_345\_19**

Mon 11/25/2019 to Mon 11/25/2019  
 0730 Daily(No Weekends) 1630  
 Work scheduled by: NGrid **ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2825 MW**  
 Impacts Total Transfer Capability 150 MW  
 TTC with All Lines In Service 2975 MW

**VOLNEY\_\_-MARCY\_\_345\_19**

Mon 11/25/2019 to Mon 11/25/2019  
 0730 Daily(No Weekends) 1630  
 Work scheduled by: NGrid **ARR: 19**

FWD  
 (Import)  
 OSWEGO EXPORT **4900 MW**  
 Impacts Total Transfer Capability 350 MW  
 TTC with All Lines In Service 5250 MW

**CHAT\_DC\_GC1**

Sat 11/30/2019 to Sat 11/30/2019  
 0001 Continuous 0200  
 Work scheduled by: HQ

FWD  
 (Import)  
 MOSES SOUTH **2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC1</b>				REV
Sat 11/30/2019	to	Sat 11/30/2019		(Export)
0001	Continuous	0200	SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	1000 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>				FWD
Sat 11/30/2019	to	Sat 11/30/2019		(Import)
0001		0200	MOSES SOUTH	<b>2550 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	600 MW
			TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>				FWD      REV
Sat 11/30/2019	to	Sat 11/30/2019		(Import) (Export)
0001		0200	SCH - HQ - NY	<b>1370 MW   0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	130 MW   1000 MW
			TTC with All Lines In Service	1500 MW   1000 MW
<b>CHAT_DC_GC2</b>				FWD
Sat 11/30/2019	to	Sat 11/30/2019		(Import)
0001	Continuous	0200	MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability	300 MW
			TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC2</b>				REV
Sat 11/30/2019	to	Sat 11/30/2019		(Export)
0001	Continuous	0200	SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	1000 MW
<b>SCH-HQ-NYISO_LIMIT_1150</b>				FWD
Sat 11/30/2019	to	Sat 11/30/2019		(Import)
0001	Continuous	0200	SCH - HQ - NY	<b>1150 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability	350 MW
			TTC with All Lines In Service	1500 MW
<b>SPRNBK_-TREMONT__345_X28</b>				FWD
Mon 12/02/2019	to	Mon 12/02/2019		(Import)
0001	Continuous	1800	<b>UPDATED    by CONED    11/04/2019</b>	<b>4200 MW</b>
Work scheduled by: ConEd			SPR/DUN-SOUTH	<b>4200 MW</b>
			Impacts Total Transfer Capability	400 MW
			TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
<b>SHOR_NPX-SHOREHAM_138_CSC</b>					
Mon 12/02/2019	to	Mon 12/02/2019	<u>UPDATED</u> <u>by ISONE</u> <u>10/04/2019</u>		
0700	Continuous	2300		SCH - NPX_CSC	<b>0 MW</b> <b>0 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability	330 MW 330 MW
				TTC with All Lines In Service	330 MW 330 MW
<b>MOSES -ADIRNDCK_230_MA2</b>					
Mon 12/02/2019	to	Fri 12/06/2019			
0700	Continuous	1500		MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
<b>N. SCTLND-ALPS 345_2</b>					
Mon 12/02/2019	to	Mon 12/02/2019			
0730	Daily(No Weekends)	1630		SCH - NE - NY	<b>900 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	1400 MW
<b>N. SCTLND-ALPS 345_2</b>					
Mon 12/02/2019	to	Mon 12/02/2019			
0730	Daily(No Weekends)	1630		SCH - NPX_1385	<b>100 MW</b> <b>100 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
<b>FRASER 345_FRASER SVC</b>					
Mon 12/02/2019	to	Fri 12/13/2019			
0800	Continuous	1500		CENTRAL EAST - VC	<b>2935 MW</b>
Work scheduled by: NYSEG				Impacts Total Transfer Capability	40 MW
				TTC with All Lines In Service	2975 MW
<b>LEEDS 345KV_R94301</b>					
Tue 12/03/2019	to	Fri 12/13/2019	<u>UPDATED</u> <u>by NGRID</u> <u>10/04/2019</u>		
0800	Continuous	1500		UPNY CONED	<b>3800 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	1900 MW
				TTC with All Lines In Service	5700 MW
<b>EFISHKIL-WOOD_ST_345_F39</b>					
Thu 12/05/2019	to	Thu 12/05/2019			
0001	Continuous	0030		UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1700 MW
				TTC with All Lines In Service	5700 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**WOOD\_ST\_-PLSNTVLE\_345\_Y87**

Thu 12/05/2019 to Sat 12/07/2019  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

**NIAGARA -PACKARD\_230\_62**

Fri 12/06/2019 to Fri 12/06/2019  
 0800 Daily(No Weekends) 1530  
 Work scheduled by: NGrid

FWD REV  
 (Import) (Export)  
 SCH - OH - NY **900 MW 1850 MW**  
 Impacts Total Transfer Capability 1150 MW 50 MW  
 TTC with All Lines In Service 2050 MW 1900 MW

**EFISHKIL-WOOD\_ST\_345\_F39**

Fri 12/06/2019 to Sat 12/07/2019  
 2330 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

**CHAT\_DC\_GC1**

Sat 12/07/2019 to Sat 12/07/2019  
 0001 Continuous 0200  
 Work scheduled by: HQ

FWD  
 (Import)  
 MOSES SOUTH **2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC1**

Sat 12/07/2019 to Sat 12/07/2019  
 0001 Continuous 0200  
 Work scheduled by: HQ

REV  
 (Export)  
 SCH - HQ - NY **500 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 1000 MW

**CHAT\_DC\_GC1 & CHAT\_DC\_GC2**

Sat 12/07/2019 to Sat 12/07/2019  
 0001 0200  
 Work scheduled by:

FWD  
 (Import)  
 MOSES SOUTH **2550 MW**  
 Impacts Total Transfer Capability 600 MW  
 TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC1 & CHAT\_DC\_GC2**

Sat 12/07/2019 to Sat 12/07/2019  
 0001 0200  
 Work scheduled by:

FWD REV  
 (Import) (Export)  
 SCH - HQ - NY **1370 MW 0 MW**  
 Impacts Total Transfer Capability 130 MW 1000 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event Name	Start Date	End Date	Time	Work Scheduled by	Direction	Zone	Impact	TTC
CHAT_DC_GC2	Sat 12/07/2019	Sat 12/07/2019	0001 - 0200	HQ	FWD (Import)	MOSES SOUTH	2850 MW	3150 MW
						Impacts Total Transfer Capability	300 MW	
						TTC with All Lines In Service		3150 MW
CHAT_DC_GC2	Sat 12/07/2019	Sat 12/07/2019	0001 - 0200	HQ	REV (Export)	SCH - HQ - NY	500 MW	1000 MW
						Impacts Total Transfer Capability	500 MW	
						TTC with All Lines In Service		1000 MW
SCH-HQ-NYISO_LIMIT_1150	Sat 12/07/2019	Sat 12/07/2019	0001 - 0200	HQ	FWD (Import)	SCH - HQ - NY	1150 MW	1500 MW
						Impacts Total Transfer Capability	350 MW	
						TTC with All Lines In Service		1500 MW
MOSES -ADIRNDCK_230_MA1	Mon 12/09/2019	Fri 12/13/2019	0700 - 1500	NYPA	FWD (Import)	MOSES SOUTH	2300 MW	3150 MW
						Impacts Total Transfer Capability	850 MW	
						TTC with All Lines In Service		3150 MW
ROSETON -ROCKTVRN_345_311	Mon 12/09/2019	Thu 12/12/2019	0800 - 1600	CHGE	FWD (Import)	UPNY CONED	4400 MW	5700 MW
						Impacts Total Transfer Capability	1300 MW	
						TTC with All Lines In Service		5700 MW
SHOR_NPX-SHOREHAM_138_CSC	Thu 12/12/2019	Fri 12/20/2019	0700 - 1500	ISONE	FWD (Import) / REV (Export)	SCH - NPX_CSC	0 MW	330 MW / 330 MW
						Impacts Total Transfer Capability	330 MW	330 MW
						TTC with All Lines In Service	330 MW	330 MW
WATRCURE-OAKDALE_345_31	Sun 12/15/2019	Sat 12/21/2019	0800 - 1700	NYSEG	FWD (Import)	SCH - PJ - NY	2750 MW	2900 MW
						Impacts Total Transfer Capability	150 MW	
						TTC with All Lines In Service		2900 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>NRTH1385-NOR HBR__138_601</b>							
Mon 12/16/2019	to	Mon 12/23/2019	<u>UPDATED</u>	<u>by LIPA</u>	<u>10/25/2019</u>		
0001	Continuous	2359				SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_601 &amp; NRTH1385-NOR HBR__138_602</b>							
Mon 12/16/2019	to	Mon 12/23/2019				SCH - NPX_1385	<b>0 MW</b>
0001		2359				Impacts Total Transfer Capability	200 MW
Work scheduled by:						TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_601 &amp; NRTH1385-NOR HBR__138_603</b>							
Mon 12/16/2019	to	Mon 12/23/2019				SCH - NPX_1385	<b>0 MW</b>
0001		2359				Impacts Total Transfer Capability	200 MW
Work scheduled by:						TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_602</b>							
Mon 12/16/2019	to	Mon 12/23/2019	<u>UPDATED</u>	<u>by LIPA</u>	<u>10/25/2019</u>		
0001	Continuous	2359				SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_602 &amp; NRTH1385-NOR HBR__138_603</b>							
Mon 12/16/2019	to	Mon 12/23/2019				SCH - NPX_1385	<b>0 MW</b>
0001		2359				Impacts Total Transfer Capability	200 MW
Work scheduled by:						TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_603</b>							
Mon 12/16/2019	to	Mon 12/23/2019	<u>UPDATED</u>	<u>by LIPA</u>	<u>10/25/2019</u>		
0001	Continuous	2359				SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
<b>NRTH1385-NRTHPORT_138_NNC</b>							
Mon 12/16/2019	to	Mon 12/23/2019	<u>UPDATED</u>	<u>by LIPA</u>	<u>10/25/2019</u>		
0001	Continuous	2359				SCH - NPX_1385	<b>0 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	200 MW
						TTC with All Lines In Service	200 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 12/16/2019 to Mon 12/16/2019  
 0700 Continuous 1500  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**EDIC\_\_\_-FRASER\_\_\_345\_EF24-40**

Mon 12/16/2019 to Tue 12/17/2019  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
**CENTRAL EAST - VC 2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

**S.RIPLEY-DUNKIRK\_\_230\_68**

Mon 12/16/2019 to Fri 12/20/2019 **UPDATED by PJM 11/13/2019**  
 0900 Continuous 1500  
 Work scheduled by: PJM

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Tue 12/17/2019 to Fri 12/20/2019  
 0700 Continuous 1500  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**EASTVIEW-SPRNBK\_\_345\_W65**

Wed 12/18/2019 to Wed 12/18/2019  
 0201 Continuous 0230  
 Work scheduled by: ConEd

FWD  
 (Import)  
**UPNY CONED 4350 MW**  
 Impacts Total Transfer Capability 1350 MW  
 TTC with All Lines In Service 5700 MW

**SPRNBK\_\_345KV\_RNS4**

Wed 12/18/2019 to Wed 12/18/2019  
 0201 Continuous 0230  
 Work scheduled by: ConEd

FWD  
 (Import)  
**SPR/DUN-SOUTH 3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**MILLWOOD-EASTVIEW\_345\_W82**

Wed 12/18/2019 to Wed 12/18/2019  
 0201 Continuous 1800  
 Work scheduled by: ConEd

FWD  
 (Import)  
**UPNY CONED 4350 MW**  
 Impacts Total Transfer Capability 1350 MW  
 TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
<p><b>EASTVIEW-SPRNBK__345_W65</b></p> <p>Wed 12/18/2019      to      Wed 12/18/2019</p> <p style="padding-left: 40px;">1730                  Continuous                  1800</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED                  <b>4350 MW</b></p> <p>Impacts Total Transfer Capability 1350 MW</p> <p>TTC with All Lines In Service    5700 MW</p>		
<hr/>			
<p><b>SPRNBK__345KV_RNS4</b></p> <p>Wed 12/18/2019      to      Wed 12/18/2019</p> <p style="padding-left: 40px;">1730                  Continuous                  1800</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH              <b>3200 MW</b></p> <p>Impacts Total Transfer Capability 1400 MW</p> <p>TTC with All Lines In Service    4600 MW</p>		
<hr/>			
<p><b>EFISHKIL-WOOD_ST__345_F38</b></p> <p>Fri 12/20/2019      to      Sat 12/21/2019</p> <p style="padding-left: 40px;">0001                  Continuous                  0030</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED                  <b>4000 MW</b></p> <p>Impacts Total Transfer Capability 1700 MW</p> <p>TTC with All Lines In Service    5700 MW</p>		
<hr/>			
<p><b>PLSNTVLE-DUNWODIE_345_W89</b></p> <p>Fri 12/20/2019      to      Sat 12/21/2019</p> <p style="padding-left: 40px;">0001                  Continuous                  0030</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED                  <b>4000 MW</b></p> <p>Impacts Total Transfer Capability 1700 MW</p> <p>TTC with All Lines In Service    5700 MW</p>		
<hr/>			
<p><b>WOOD_ST_-PLSNTVLE_345_Y86</b></p> <p>Fri 12/20/2019      to      Sat 12/21/2019</p> <p style="padding-left: 40px;">0001                  Continuous                  0030</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED                  <b>4000 MW</b></p> <p>Impacts Total Transfer Capability 1700 MW</p> <p>TTC with All Lines In Service    5700 MW</p>		
<hr/>			
<p><b>SCH-NE-NYISO_LIMIT_500</b></p> <p>Fri 12/20/2019      to      Fri 12/20/2019      <b><u>UPDATED</u></b>      <b><u>by ISONE</u></b>      <b><u>10/11/2019</u></b></p> <p style="padding-left: 40px;">0600                  Continuous                  1600</p> <p>Work scheduled by: ISONE</p>	<p style="text-align: right;">FWD (Import)</p> <p>SCH - NE - NY                  <b>700 MW</b></p> <p>Impacts Total Transfer Capability 700 MW</p> <p>TTC with All Lines In Service    1400 MW</p>		
<hr/>			
<p><b>SCH-NYISO-NE_LIMIT_1200</b></p> <p>Fri 12/20/2019      to      Fri 12/20/2019      <b><u>UPDATED</u></b>      <b><u>by ISONE</u></b>      <b><u>10/11/2019</u></b></p> <p style="padding-left: 40px;">0600                  Continuous                  1600</p> <p>Work scheduled by: ISONE</p>	<p style="text-align: right;">REV (Export)</p> <p>SCH - NE - NY                  <b>1400 MW</b></p> <p>Impacts Total Transfer Capability 300 MW</p> <p>TTC with All Lines In Service    1700 MW</p>		

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDEN\_\_-GOETHALS\_230\_A2253

Fri 12/27/2019 to Fri 12/27/2019  
 0001 Continuous 2230  
 Work scheduled by: ConEd

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

LINDEN\_\_-GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402

Fri 12/27/2019 to Fri 12/27/2019  
 0001 2230  
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2550 MW</b>	<b>1600 MW</b>
Impacts Total Transfer Capability	350 MW	250 MW
TTC with All Lines In Service	2900 MW	1850 MW

LINDEN\_\_-GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_\_-FARRAGUT\_345\_C3403

Fri 12/27/2019 to Fri 12/27/2019  
 0001 2230  
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2550 MW</b>	<b>1600 MW</b>
Impacts Total Transfer Capability	350 MW	250 MW
TTC with All Lines In Service	2900 MW	1850 MW

LINDEN\_\_-GOETHALS\_230\_A2253 & MARION\_\_-FARRAGUT\_345\_C3403

Fri 12/27/2019 to Fri 12/27/2019  
 0001 2230  
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2550 MW</b>	<b>1600 MW</b>
Impacts Total Transfer Capability	350 MW	250 MW
TTC with All Lines In Service	2900 MW	1850 MW

PLSNTVLY-WOOD\_ST\_345\_F30

Thu 01/02/2020 to Mon 01/13/2020  
 0001 Continuous 2200  
 Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>4000 MW</b>
Impacts Total Transfer Capability	1700 MW
TTC with All Lines In Service	5700 MW

PLSNTVLY\_345KV\_RNS5

Thu 01/02/2020 to Mon 01/13/2020  
 0001 Continuous 2200  
 Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>3800 MW</b>
Impacts Total Transfer Capability	1900 MW
TTC with All Lines In Service	5700 MW

BECK\_\_-NIAGARA\_345\_PA301

Mon 01/13/2020 to Fri 01/17/2020  
 0500 Continuous 1530  
 Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1100 MW</b>	<b>950 MW</b>
Impacts Total Transfer Capability	950 MW	950 MW
TTC with All Lines In Service	2050 MW	1900 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MOTTHAVN-RAINEY</b> ___ 345_Q11					FWD	
Sun 02/23/2020	to	Sun 03/01/2020			(Import)	
0001	Continuous	0200		SPR/DUN-SOUTH	<b>3800 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>NIAGARA -PACKARD</b> ___ 230_62					FWD	REV
Fri 02/28/2020	to	Fri 02/28/2020			(Import)	(Export)
0500	Continuous	1530		SCH - OH - NY	<b>900 MW</b>	<b>1850 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1150 MW 50 MW
					TTC with All Lines In Service	2050 MW 1900 MW
<b>CHATGUAY-MASSENA</b> ___ 765_7040					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<b>UPDATED</b>	<b>by NYPA</b>	<b>08/08/2019</b>	
0500	Continuous	1730			MOSES SOUTH	<b>1550 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	3150 MW
<b>CHATGUAY-MASSENA</b> ___ 765_7040					FWD	REV
Mon 03/02/2020	to	Fri 03/06/2020	<b>UPDATED</b>	<b>by NYPA</b>	<b>08/08/2019</b>	
0500	Continuous	1730			SCH - HQ - NY	<b>0 MW</b> <b>0 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1500 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW
<b>MARCY</b> ___ 765_345_AT1					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<b>UPDATED</b>	<b>by NYPA</b>	<b>08/08/2019</b>	
0500	Continuous	1730			MOSES SOUTH	<b>1750 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	3150 MW
<b>MARCY</b> ___ 765_345_AT2					FWD	
Mon 03/02/2020	to	Fri 03/06/2020			(Import)	
0500	Continuous	1730			MOSES SOUTH	<b>1700 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
<b>MASSENA -MARC</b> ___ 765_MSU1					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<b>UPDATED</b>	<b>by NYPA</b>	<b>08/08/2019</b>	
0500	Continuous	1730			CENTRAL EAST - VC	<b>2265 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	710 MW
					TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA -MARCY 765_MSU1</b>					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				MOSES SOUTH <b>500 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	2650 MW
					TTC with All Lines In Service	3150 MW
<b>MASSENA -MARCY 765_MSU1</b>					FWD	REV
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import) (Export)
0500	Continuous	1730				SCH - HQ - NY <b>475 MW 1000 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1025 MW 0 MW
					TTC with All Lines In Service	1500 MW 1000 MW
<b>MASSENA -MARCY 765_MSU1</b>					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				SCH - HQ_CEDARS <b>90 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	109 MW
					TTC with All Lines In Service	199 MW
<b>MASSENA -MARCY 765_MSU1 &amp; CHATGUAY-MASSENA 765_7040</b>					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500		1730				MOSES SOUTH <b>500 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	2650 MW
					TTC with All Lines In Service	3150 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>					FWD	REV
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import) (Export)
0500		1730				SCH - HQ - NY <b>850 MW 0 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	650 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500		1730				SCH - HQ_CEDARS <b>90 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	109 MW
					TTC with All Lines In Service	199 MW
<b>STLAWRNC-MOSES 230_L33P &amp; MASSENA -MARCY 765_MSU1</b>					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500		1730				SCH - HQ_CEDARS <b>90 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	109 MW
					TTC with All Lines In Service	199 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES\_\_230\_L33P & MOSES\_\_-MASSENA\_\_230\_MMS1 & MOSES\_\_-  
MASSENA\_\_230\_MMS2

FWD  
(Import)

Mon 03/02/2020 to Fri 03/06/2020  
0500 1730

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability 109 MW  
TTC with All Lines In Service 199 MW

Work scheduled by:

SHOR\_NPX-SHOREHAM\_138\_CSC

FWD REV  
(Import) (Export)

Mon 03/02/2020 to Tue 03/03/2020  
0600 Continuous 1300

SCH - NPX\_CSC  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

Work scheduled by: LI

ROSETON\_-EFISHKIL\_345\_RFK305

FWD  
(Import)

Mon 03/02/2020 to Fri 03/20/2020  
0700 Continuous 1730

UPNY CONED  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 5700 MW

Work scheduled by: NYPA

EASTVIEW-SPRNBRK\_\_345\_W78

FWD  
(Import)

Fri 03/06/2020 to Sat 03/07/2020  
0001 Continuous 0200

UPNY CONED  
Impacts Total Transfer Capability 1350 MW  
TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

MILLWOOD-EASTVIEW\_345\_W85

FWD  
(Import)

Fri 03/06/2020 to Sat 03/07/2020  
0001 Continuous 0200

UPNY CONED  
Impacts Total Transfer Capability 1350 MW  
TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

SPRNBRK\_\_345KV\_RNS3

FWD  
(Import)

Fri 03/06/2020 to Sat 03/07/2020  
0001 Continuous 0200

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

MOSES\_\_-ADIRNDCK\_230\_MA1

FWD  
(Import)

Sat 03/07/2020 to Fri 05/29/2020  
0700 Continuous 1300

MOSES SOUTH  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>VOLNEY -MARCY 345_19</b>				FWD
Tue 03/10/2020	to	Tue 03/10/2020	<b>UPDATED</b>	(Import)
0700	Continuous	1530	<b>by NYPA</b>	<b>2825 MW</b>
Work scheduled by: NYPA			<b>ARR: 19</b>	CENTRAL EAST - VC
				Impacts Total Transfer Capability 150 MW
				TTC with All Lines In Service 2975 MW
<b>VOLNEY -MARCY 345_19</b>				FWD
Tue 03/10/2020	to	Tue 03/10/2020	<b>UPDATED</b>	(Import)
0700	Continuous	1530	<b>by NYPA</b>	<b>4900 MW</b>
Work scheduled by: NYPA			<b>ARR: 19</b>	OSWEGO EXPORT
				Impacts Total Transfer Capability 350 MW
				TTC with All Lines In Service 5250 MW
<b>ROCHESTR-PANNELL 345_RP2</b>				FWD
Sat 03/14/2020	to	Mon 03/23/2020		(Import)
0500	Continuous	1700		<b>2300 MW</b>
Work scheduled by: NYPA				DYSINGER EAST
				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
<b>MARCY 345KV_CSC</b>				FWD
Mon 03/16/2020	to	Fri 03/27/2020		(Import)
0500	Continuous	1730		<b>2925 MW</b>
Work scheduled by: NYPA				CENTRAL EAST - VC
				Impacts Total Transfer Capability 50 MW
				TTC with All Lines In Service 2975 MW
<b>EASTVIEW-SPRNBK 345_W64</b>				FWD
Sat 03/21/2020	to	Sat 03/21/2020		(Import)
0001	Continuous	0030		<b>4350 MW</b>
Work scheduled by: ConEd				UPNY CONED
				Impacts Total Transfer Capability 1350 MW
				TTC with All Lines In Service 5700 MW
<b>SPRNBK 345KV_RNS5</b>				FWD
Sat 03/21/2020	to	Sat 03/21/2020		(Import)
0001	Continuous	0030		<b>3200 MW</b>
Work scheduled by: ConEd				SPR/DUN-SOUTH
				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
<b>MILLWOOD-EASTVIEW 345_W99</b>				FWD
Sat 03/21/2020	to	Sun 03/22/2020		(Import)
0001	Continuous	0200		<b>4350 MW</b>
Work scheduled by: ConEd				UPNY CONED
				Impacts Total Transfer Capability 1350 MW
				TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EASTVIEW-SPRNBK__345_W64</b>				FWD	
Sun 03/22/2020	to	Sun 03/22/2020		(Import)	
0130	Continuous	0200	UPNY CONED	<b>4350 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1350 MW	
			TTC with All Lines In Service	5700 MW	
<b>SPRNBK__345KV_RNS5</b>				FWD	
Sun 03/22/2020	to	Sun 03/22/2020		(Import)	
0130	Continuous	0200	SPR/DUN-SOUTH	<b>3200 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW	
			TTC with All Lines In Service	4600 MW	
<b>NIAGARA_-KINTIGH__345_NS1-38</b>				FWD	
Fri 03/27/2020	to	Fri 03/27/2020		(Import)	
0600	Continuous	1530	DYSINGER EAST	<b>1700 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW	
			TTC with All Lines In Service	3150 MW	
<b>BECK____-PACKARD__230_BP76</b>				FWD	REV
Fri 03/27/2020	to	Fri 03/27/2020		(Import)	(Export)
0800	Daily(No Weekends)	1600	SCH - OH - NY	<b>1650 MW</b>	<b>1400 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	400 MW	500 MW
			TTC with All Lines In Service	2050 MW	1900 MW
<b>MARCY____-EDIC____345_UE1-7</b>				FWD	
Tue 03/31/2020	to	Tue 03/31/2020	<b>UPDATED</b>	(Import)	
0700	Continuous	1530	<b>by NYPA 09/24/2019</b>	OSWEGO EXPORT	<b>5250 MW</b>
Work scheduled by: NYPA			<b>ARR: 19&amp;16</b>	Impacts Total Transfer Capability	0 MW
				TTC with All Lines In Service	5250 MW
<b>FRASANNX-COOPERS__345_UCC2-41</b>				FWD	
Wed 04/01/2020	to	Thu 04/02/2020	<b>UPDATED</b>	(Import)	
0700	Continuous	1530	<b>by NYPA 11/12/2019</b>	CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYPA			<b>ARR: 19</b>	Impacts Total Transfer Capability	475 MW
				TTC with All Lines In Service	2975 MW
<b>MARCY____-FRASANNX_345_UCC2-41</b>				FWD	
Wed 04/01/2020	to	Thu 04/02/2020	<b>UPDATED</b>	(Import)	
0700	Continuous	1530	<b>by NYPA 11/12/2019</b>	CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYPA			<b>ARR: 19</b>	Impacts Total Transfer Capability	475 MW
				TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>				
<b>SPRNBRK_-W49TH_ST_345_M51</b>				FWD
Mon 04/06/2020	to	Wed 04/08/2020		(Import)
0001	Continuous	0200	SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW
			TTC with All Lines In Service	4600 MW
<hr/>				
<b>SPRNBRK_345KV_RNS5</b>				FWD
Mon 04/06/2020	to	Wed 04/08/2020		(Import)
0001	Continuous	0200	SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW
			TTC with All Lines In Service	4600 MW
<hr/>				
<b>MARCY_-N.SCTLND_345_18</b>				FWD
Tue 04/07/2020	to	Wed 04/08/2020	<b>UPDATED by NYPA 09/24/2019</b>	(Import)
0700	Continuous	1530	CENTRAL EAST - VC	<b>2090 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	885 MW
			TTC with All Lines In Service	2975 MW
<hr/>				
<b>LINDN_CG-LNDVFT_345_V-3022</b>				FWD      REV
Sun 04/12/2020	to	Fri 04/17/2020		(Import) (Export)
1400	Continuous	1800	SCH - PJM_VFT	<b>0 MW      0 MW</b>
Work scheduled by: PJM			Impacts Total Transfer Capability	315 MW      315 MW
			TTC with All Lines In Service	315 MW      315 MW
<hr/>				
<b>PLSNTVLY-EFISHKIL_345_F36</b>				FWD
Mon 04/13/2020	to	Tue 04/14/2020		(Import)
0001	Continuous	0200	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	1700 MW
			TTC with All Lines In Service	5700 MW
<hr/>				
<b>SAND_BAR-PLATSBRG_115_PV20</b>				
Mon 04/13/2020	to	Tue 04/14/2020		
0600	Daily	1800	SCH - NE - NY	
Work scheduled by: ISONE			Impacts Total Transfer Capability	
			TTC with All Lines In Service	
<hr/>				
<b>FRASER_-GILBOA_345_GF5-35</b>				FWD
Mon 04/13/2020	to	Wed 04/22/2020		(Import)
0700	Continuous	1730	CENTRAL EAST - VC	<b>2650 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	325 MW
			TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**NIAGARA\_-ROCHESTR\_345\_NR2**

Wed 04/15/2020 to Fri 05/01/2020  
 0500 Continuous 1700  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

-----  
**ROCHESTR-PANNELL\_345\_RP1**

Mon 04/20/2020 to Fri 04/24/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**DOLSONAV-ROCKTVRN\_345\_DART44**

Mon 04/27/2020 to Sun 05/10/2020 **UPDATED by NYPA 03/21/2019**  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2720 MW**  
 Impacts Total Transfer Capability 255 MW  
 TTC with All Lines In Service 2975 MW

-----  
**LEEDS\_-HURLYAVE\_345\_301**

Mon 04/27/2020 to Fri 05/29/2020  
 0800 Continuous 1600  
 Work scheduled by: CHGE

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 1600 MW  
 TTC with All Lines In Service 5700 MW

-----  
**SCH-IMO-NYISO\_LIMIT\_1600**

Fri 05/01/2020 to Sat 10/31/2020 **UPDATED by IESO 05/03/2019**  
 0001 Continuous 2359  
 Work scheduled by: IESO

FWD  
 (Import)  
 SCH - OH - NY **1900 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 1900 MW

-----  
**PANNELL\_-CLAY\_345\_2**

Mon 05/04/2020 to Fri 05/08/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

-----  
**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Mon 05/04/2020 to Mon 05/18/2020  
 0800 Continuous 1700  
 Work scheduled by: PJM

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE\_345\_501

Mon 05/04/2020 to Mon 05/18/2020  
0800 Continuous 1700

Work scheduled by: PJM

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

NEWBRDGE\_345\_138\_BK\_1

Mon 05/04/2020 to Mon 05/18/2020  
0800 Continuous 1700

Work scheduled by: PJM

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

NEWBRDGE\_345\_138\_BK\_2

Mon 05/04/2020 to Mon 05/18/2020  
0800 Continuous 1700

Work scheduled by: PJM

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

PANNELL -CLAY\_345\_1

Mon 05/11/2020 to Fri 05/15/2020  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

COOPERS -DOLSONAV\_345\_CCDA42

Mon 05/11/2020 to Fri 05/29/2020 **UPDATED by NYPA 03/21/2019**  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2720 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

KINTIGH -ROCHESTR\_345\_SR1-39

Mon 05/18/2020 to Fri 05/22/2020  
0500 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

MOSES -ADIRNDCK\_230\_MA2

Mon 06/01/2020 to Fri 07/31/2020  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA\_\_345\_230\_AT4

Mon 06/29/2020 to Tue 06/30/2020  
 0500 Continuous 1530  
 Work scheduled by: NYPA

SCH - OH - NY  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 1700 MW

REV  
 (Export)

SCH-IMO-NYISO\_NIAG\_CB\_3008\_W/BB

Mon 07/27/2020 to Fri 08/07/2020  
 0500 Continuous 1530  
 Work scheduled by: NYPA

SCH - OH - NY  
 Impacts Total Transfer Capability 0 MW 250 MW  
 TTC with All Lines In Service 1900 MW 1700 MW

FWD REV  
 (Import) (Export)

CHATGUAY-MASSENA\_\_765\_7040

Sat 08/01/2020 to Sun 08/02/2020 **UPDATED by NYPA 08/08/2019**  
 0500 Continuous 1730  
 Work scheduled by: NYPA

MOSES SOUTH  
 Impacts Total Transfer Capability 1600 MW  
 TTC with All Lines In Service 3150 MW

FWD  
 (Import)

CHATGUAY-MASSENA\_\_765\_7040

Sat 08/01/2020 to Sun 08/02/2020 **UPDATED by NYPA 08/08/2019**  
 0500 Continuous 1730  
 Work scheduled by: NYPA

SCH - HQ - NY  
 Impacts Total Transfer Capability 1500 MW 1000 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

FWD REV  
 (Import) (Export)

MARCY\_\_765\_345\_AT1

Sat 08/01/2020 to Sun 08/02/2020 **UPDATED by NYPA 08/08/2019**  
 0500 Continuous 1730  
 Work scheduled by: NYPA **ARR: 19**

MOSES SOUTH  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 3150 MW

FWD  
 (Import)

MASSENA\_-MARCY\_\_765\_MSU1

Sat 08/01/2020 to Sun 08/02/2020 **UPDATED by NYPA 08/08/2019**  
 0500 Continuous 1730  
 Work scheduled by: NYPA

CENTRAL EAST - VC  
 Impacts Total Transfer Capability 710 MW  
 TTC with All Lines In Service 2975 MW

FWD  
 (Import)

MASSENA\_-MARCY\_\_765\_MSU1

Sat 08/01/2020 to Sun 08/02/2020 **UPDATED by NYPA 08/08/2019**  
 0500 Continuous 1730  
 Work scheduled by: NYPA

MOSES SOUTH  
 Impacts Total Transfer Capability 2650 MW  
 TTC with All Lines In Service 3150 MW

FWD  
 (Import)

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Zone	Start	End	Status	Authority	Effective Date	Schedule	Impact	FWD	REV
MASSENA -MARCY 765_MSU1	Sat 08/01/2020	Sun 08/02/2020	UPDATED	NYPA	08/08/2019	0500 Continuous 1730	SCH - HQ - NY Impacts Total Transfer Capability TTC with All Lines In Service	(Import) 475 MW 1500 MW	(Export) 1000 MW 1000 MW
MASSENA -MARCY 765_MSU1	Sat 08/01/2020	Sun 08/02/2020	UPDATED	NYPA	08/08/2019	0500 Continuous 1730	SCH - HQ_CEDARS Impacts Total Transfer Capability TTC with All Lines In Service	(Import) 90 MW 190 MW	
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040	Sat 08/01/2020	Sun 08/02/2020				0500 1730	MOSES SOUTH Impacts Total Transfer Capability TTC with All Lines In Service	(Import) 500 MW 3150 MW	
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	Sat 08/01/2020	Sun 08/02/2020				0500 1730	SCH - HQ - NY Impacts Total Transfer Capability TTC with All Lines In Service	(Import) 850 MW 1500 MW	(Export) 0 MW 1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	Sat 08/01/2020	Sun 08/02/2020				0500 1730	SCH - HQ_CEDARS Impacts Total Transfer Capability TTC with All Lines In Service	(Import) 90 MW 190 MW	
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1	Sat 08/01/2020	Sun 08/02/2020				0500 1730	SCH - HQ_CEDARS Impacts Total Transfer Capability TTC with All Lines In Service	(Import) 90 MW 190 MW	
STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	Sat 08/01/2020	Sun 08/02/2020				0500 1730	SCH - HQ_CEDARS Impacts Total Transfer Capability TTC with All Lines In Service	(Import) 90 MW 190 MW	

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES -ADIRNDCK\_230\_MA2**

Mon 08/03/2020 to Sun 09/13/2020  
0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**FRASANX-COOPERS\_345\_UCC2-41**

Mon 09/07/2020 to Fri 10/23/2020  
0700 Continuous 1730

Work scheduled by: NYPA

**UPDATED by NYPA 03/01/2019**

**ARR: 19**

FWD

(Import)

CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**MARCY -FRASANX\_345\_UCC2-41**

Mon 09/07/2020 to Fri 10/23/2020  
0700 Continuous 1730

Work scheduled by: NYPA

**UPDATED by NYPA 03/01/2019**

**ARR: 19**

FWD

(Import)

CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**MARCY\_765\_345\_AT1**

Mon 09/14/2020 to Mon 09/14/2020  
0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD

(Import)

MOSES SOUTH **1750 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

**NIAGARA -KINTIGH\_345\_NS1-38**

Mon 09/14/2020 to Thu 09/17/2020  
0500 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

**MOSES -ADIRNDCK\_230\_MA2**

Tue 09/15/2020 to Sat 11/14/2020  
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**NIAGARA -ROCHESTR\_345\_NR2**

Fri 09/18/2020 to Sat 11/14/2020  
0500 Continuous 2330

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p><b>CLAY -EDIC 345_1-16</b></p> <p>Mon 09/21/2020 to Fri 09/25/2020</p> <p style="padding-left: 40px;">0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>OSWEGO EXPORT <b>4850 MW</b></p> <p>Impacts Total Transfer Capability 400 MW</p> <p>TTC with All Lines In Service 5250 MW</p>
<p><b>ROSETON -ROCKTVRN 345_311</b></p> <p>Mon 09/21/2020 to Fri 10/23/2020 <b>UPDATED by CHGE 10/09/2019</b></p> <p style="padding-left: 40px;">0800 Continuous 1600</p> <p>Work scheduled by: CHGE</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED <b>4400 MW</b></p> <p>Impacts Total Transfer Capability 1300 MW</p> <p>TTC with All Lines In Service 5700 MW</p>
<p><b>DUNWODIE 345KV_3</b></p> <p>Fri 09/25/2020 to Fri 09/25/2020 <b>UPDATED by CONED 09/05/2019</b></p> <p style="padding-left: 40px;">0001 Continuous 0030</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH <b>3800 MW</b></p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>
<p><b>DUNWODIE 345KV_5</b></p> <p>Fri 09/25/2020 to Fri 09/25/2020 <b>UPDATED by CONED 09/05/2019</b></p> <p style="padding-left: 40px;">0001 Continuous 0030</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH <b>3800 MW</b></p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>
<p><b>DUNWODIE-MOTTHAVN 345_71</b></p> <p>Fri 09/25/2020 to Fri 10/30/2020 <b>UPDATED by CONED 09/05/2019</b></p> <p style="padding-left: 40px;">0001 Continuous 0300</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH <b>3800 MW</b></p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>
<p><b>CLAY -EDIC 345_2-15</b></p> <p>Mon 09/28/2020 to Fri 10/02/2020</p> <p style="padding-left: 40px;">0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>OSWEGO EXPORT <b>4850 MW</b></p> <p>Impacts Total Transfer Capability 400 MW</p> <p>TTC with All Lines In Service 5250 MW</p>
<p><b>SAND_BAR-PLATSBRG 115_PV20</b></p> <p>Sat 10/17/2020 to Sat 11/14/2020</p> <p style="padding-left: 40px;">0600 Continuous 1800</p> <p>Work scheduled by: ISONE</p>	<p>SCH - NE - NY</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>HURLYAVE-ROSETON__345_303</b>					FWD		
Mon 10/26/2020	to	Fri 12/04/2020	<u>UPDATED</u>	<u>by CHGE</u>	<u>10/09/2019</u>	(Import)	
0800	Continuous	1600				UPNY CONED <b>4100 MW</b>	
Work scheduled by: CHGE					Impacts Total Transfer Capability	1600 MW	
					TTC with All Lines In Service	5700 MW	
<b>DUNWODIE_345KV_3</b>					FWD		
Fri 10/30/2020	to	Fri 10/30/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>09/05/2019</u>	(Import)	
0230	Continuous	0300				SPR/DUN-SOUTH <b>3800 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW	
					TTC with All Lines In Service	4600 MW	
<b>DUNWODIE_345KV_5</b>					FWD		
Fri 10/30/2020	to	Fri 10/30/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>09/05/2019</u>	(Import)	
0230	Continuous	0300				SPR/DUN-SOUTH <b>3800 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW	
					TTC with All Lines In Service	4600 MW	
<b>SCH-IMO-NYISO_LIMIT_1750</b>					FWD		
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)	
0001	Continuous	2359				SCH - OH - NY <b>2050 MW</b>	
Work scheduled by: IESO					Impacts Total Transfer Capability	0 MW	
					TTC with All Lines In Service	2050 MW	
<b>SCH-NYISO-IMO_LIMIT_1600</b>					REV		
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Export)	
0001	Continuous	2359				SCH - OH - NY <b>1900 MW</b>	
Work scheduled by: IESO					Impacts Total Transfer Capability	0 MW	
					TTC with All Lines In Service	1900 MW	
<b>CHATGUAY-MASSENA__765_7040</b>					FWD		
Sun 11/15/2020	to	Mon 11/30/2020				(Import)	
0100	Continuous	1900				MOSES SOUTH <b>1550 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	1600 MW	
					TTC with All Lines In Service	3150 MW	
<b>CHATGUAY-MASSENA__765_7040</b>					FWD	REV	
Sun 11/15/2020	to	Mon 11/30/2020				(Import)	(Export)
0100	Continuous	1900				SCH - HQ - NY <b>0 MW</b>	<b>0 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1500 MW	1000 MW
					TTC with All Lines In Service	1500 MW	1000 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY___765_345_AT1</b>		FWD
Sun 11/15/2020	to Mon 11/30/2020	(Import)
0100	Continuous 1900	MOSES SOUTH <b>1750 MW</b>
Work scheduled by: NYPA	<b>ARR: 19</b>	Impacts Total Transfer Capability 1400 MW
		TTC with All Lines In Service 3150 MW
<b>MARCY___765_345_AT2</b>		FWD
Sun 11/15/2020	to Mon 11/30/2020	(Import)
0100	Continuous 1900	MOSES SOUTH <b>1700 MW</b>
Work scheduled by: NYPA	<b>ARR: 19</b>	Impacts Total Transfer Capability 1450 MW
		TTC with All Lines In Service 3150 MW
<b>MASSENA_-MARCY___765_MSU1</b>		FWD
Sun 11/15/2020	to Mon 11/30/2020	(Import)
0100	Continuous 1900	CENTRAL EAST - VC <b>2265 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability 710 MW
		TTC with All Lines In Service 2975 MW
<b>MASSENA_-MARCY___765_MSU1</b>		FWD
Sun 11/15/2020	to Mon 11/30/2020	(Import)
0100	Continuous 1900	MOSES SOUTH <b>500 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability 2650 MW
		TTC with All Lines In Service 3150 MW
<b>MASSENA_-MARCY___765_MSU1</b>		FWD
Sun 11/15/2020	to Mon 11/30/2020	(Import) (Export)
0100	Continuous 1900	SCH - HQ - NY <b>475 MW 1000 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability 1025 MW 0 MW
		TTC with All Lines In Service 1500 MW 1000 MW
<b>MASSENA_-MARCY___765_MSU1</b>		FWD
Sun 11/15/2020	to Mon 11/30/2020	(Import)
0100	Continuous 1900	SCH - HQ_CEDARS <b>90 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability 109 MW
		TTC with All Lines In Service 199 MW
<b>MASSENA_-MARCY___765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>		FWD
Sun 11/15/2020	to Mon 11/30/2020	(Import)
0100	Continuous 1900	MOSES SOUTH <b>500 MW</b>
Work scheduled by:		Impacts Total Transfer Capability 2650 MW
		TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230\_MMS1 & MOSES -MASSENA 230\_MMS2

Sun 11/15/2020 to Mon 11/30/2020  
0100 1900

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	850 MW	0 MW
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

MOSES -MASSENA 230\_MMS1 & MOSES -MASSENA 230\_MMS2

Sun 11/15/2020 to Mon 11/30/2020  
0100 1900

Work scheduled by:

	FWD	
	(Import)	
SCH - HQ_CEDARS	90 MW	
Impacts Total Transfer Capability	109 MW	
TTC with All Lines In Service	199 MW	

STLAWRNC-MOSES 230\_L33P & MASSENA -MARCY 765\_MSU1

Sun 11/15/2020 to Mon 11/30/2020  
0100 1900

Work scheduled by:

	FWD	
	(Import)	
SCH - HQ_CEDARS	90 MW	
Impacts Total Transfer Capability	109 MW	
TTC with All Lines In Service	199 MW	

STLAWRNC-MOSES 230\_L33P & MOSES -MASSENA 230\_MMS1 & MOSES -MASSENA 230\_MMS2

Sun 11/15/2020 to Mon 11/30/2020  
0100 1900

Work scheduled by:

	FWD	
	(Import)	
SCH - HQ_CEDARS	90 MW	
Impacts Total Transfer Capability	109 MW	
TTC with All Lines In Service	199 MW	

PLSNTVLE-DUNWODIE\_345\_W89

Mon 11/16/2020 to Mon 11/16/2020  
0001 Continuous 0030

Work scheduled by: ConEd

	FWD	
	(Import)	
UPNY CONED	4000 MW	
Impacts Total Transfer Capability	1700 MW	
TTC with All Lines In Service	5700 MW	

PLSNTVLE-DUNWODIE\_345\_W89

Thu 11/26/2020 to Thu 11/26/2020  
0230 Continuous 0300

Work scheduled by: ConEd

	FWD	
	(Import)	
UPNY CONED	4000 MW	
Impacts Total Transfer Capability	1700 MW	
TTC with All Lines In Service	5700 MW	

MOSES -ADIRNDCK 230\_MA1

Tue 12/01/2020 to Mon 05/31/2021  
0700 Continuous 1300

Work scheduled by: NYPA

	FWD	
	(Import)	
MOSES SOUTH	2300 MW	
Impacts Total Transfer Capability	850 MW	
TTC with All Lines In Service	3150 MW	

# NYISO TRANSFER LIMITATIONS

Tuesday ,November 19, 2019 to Thursday ,May 20, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND\_BAR-PLATSBURG\_115\_PV20

Mon 12/07/2020 to Fri 12/11/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

SAND\_BAR-PLATSBURG\_115\_PV20

Mon 12/14/2020 to Fri 12/18/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

MOTTHAVN-RAINEY\_345\_Q11

Mon 03/01/2021 to Tue 04/06/2021  
 0001 Continuous 0700  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

CLAY\_-EDIC\_345\_2-15

Mon 03/29/2021 to Fri 04/16/2021  
 0800 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 OSWEGO EXPORT **4850 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 5250 MW

SCH-IMO-NYISO\_LIMIT\_1600

Sat 05/01/2021 to Sun 10/31/2021 **UPDATED by IESO 05/03/2019**  
 0001 Continuous 2359  
 Work scheduled by: IESO

FWD  
 (Import)  
 SCH - OH - NY **1900 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 1900 MW

PANNELL\_-CLAY\_345\_2

Mon 05/03/2021 to Fri 05/28/2021  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW