

NYISO TRANSFER LIMITATIONS

Saturday ,November 02, 2019 to Monday ,May 03, 2021

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5700MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Fri 05/01/2020 EXTENDED by CONED 10/08/2019

0001 Continuous 2359

Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|-----------------------------------|-----------------|-----------------|
| SCH - PJ - NY | 2600 MW | 1300 MW |
| Impacts Total Transfer Capability | 300 MW | 550 MW |
| TTC with All Lines In Service | 2900 MW | 1850 MW |

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Fri 05/01/2020

0001 2359

Work scheduled by:

| | FWD (Import) | REV (Export) |
|-----------------------------------|-----------------|-----------------|
| SCH - PJ - NY | 2000 MW | 1300 MW |
| Impacts Total Transfer Capability | 900 MW | 550 MW |
| TTC with All Lines In Service | 2900 MW | 1850 MW |

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Fri 05/01/2020 EXTENDED by CONED 10/08/2019

0001 Continuous 2359

Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|-----------------------------------|-----------------|-----------------|
| SCH - PJ - NY | 2600 MW | 1300 MW |
| Impacts Total Transfer Capability | 300 MW | 550 MW |
| TTC with All Lines In Service | 2900 MW | 1850 MW |

STLAWRNC-MOSES_230_L33P

Mon 04/30/2018 to Fri 12/31/2021 EXT FORCE by IESO 08/21/2018

0456 Continuous 2359

Work scheduled by: IESO

| | FWD (Import) | REV (Export) |
|-----------------------------------|-----------------|-----------------|
| SCH - OH - NY | 2050 MW | 1900 MW |
| Impacts Total Transfer Capability | 0 MW | 0 MW |
| TTC with All Lines In Service | 2050 MW | 1900 MW |

BECK_-NIAGARA_345_PA302

Wed 07/31/2019 to Tue 11/12/2019 UPDATED by IESO 10/31/2019

0800 Continuous 1700

Work scheduled by: IESO

| | FWD (Import) | REV (Export) |
|-----------------------------------|-----------------|-----------------|
| SCH - OH - NY | 1100 MW | 950 MW |
| Impacts Total Transfer Capability | 950 MW | 950 MW |
| TTC with All Lines In Service | 2050 MW | 1900 MW |

SCH-HQ-NYISO_LIMIT_1100

Mon 10/07/2019 to Mon 10/28/2019 UPDATED by HQ 10/28/2019

0400 Continuous 0959

Work scheduled by: HQ

| | FWD (Import) |
|-----------------------------------|-----------------|
| SCH - HQ - NY | 1100 MW |
| Impacts Total Transfer Capability | 400 MW |
| TTC with All Lines In Service | 1500 MW |

CHAT_DC_GC2

Sun 10/13/2019 to Fri 11/22/2019 UPDATED by HQ 10/28/2019

2301 Continuous 2300

Work scheduled by: HQ

| | FWD (Import) |
|-----------------------------------|-----------------|
| MOSES SOUTH | 2850 MW |
| Impacts Total Transfer Capability | 300 MW |
| TTC with All Lines In Service | 3150 MW |

NYISO TRANSFER LIMITATIONS

Saturday ,November 02, 2019 to Monday ,May 03, 2021

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5700MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC2

| | | | | | | | |
|-----------------------|------------|----------------|----------------|--------------|-------------------|-----------------------------------|----------|
| Sun 10/13/2019 | to | Fri 11/22/2019 | <u>UPDATED</u> | <u>by HQ</u> | <u>10/28/2019</u> | SCH - HQ - NY | REV |
| 2301 | Continuous | 2300 | | | | Impacts Total Transfer Capability | (Export) |
| Work scheduled by: HQ | | | | | | TTC with All Lines In Service | 500 MW |
| | | | | | | | 500 MW |
| | | | | | | | 1000 MW |

SCH-IMO-NYISO_LIMIT_400

| | | | | | | | |
|-------------------------|------------|----------------|----------------|-----------------|-------------------|-----------------------------------|----------|
| Wed 10/23/2019 | to | Mon 11/04/2019 | <u>UPDATED</u> | <u>by NYISO</u> | <u>10/31/2019</u> | SCH - OH - NY | FWD |
| 0500 | Continuous | 1859 | | | | Impacts Total Transfer Capability | (Import) |
| Work scheduled by: NYPA | | | | | | TTC with All Lines In Service | 700 MW |
| | | | | | | | 1350 MW |
| | | | | | | | 2050 MW |

SCH-NYISO-IMO_LIMIT_400

| | | | | | | | |
|-------------------------|------------|----------------|----------------|-----------------|-------------------|-----------------------------------|----------|
| Wed 10/23/2019 | to | Mon 11/04/2019 | <u>UPDATED</u> | <u>by NYISO</u> | <u>10/31/2019</u> | SCH - OH - NY | REV |
| 0500 | Continuous | 1859 | | | | Impacts Total Transfer Capability | (Export) |
| Work scheduled by: NYPA | | | | | | TTC with All Lines In Service | 700 MW |
| | | | | | | | 1200 MW |
| | | | | | | | 1900 MW |

NIAGARA_345_230_AT4

| | | | | | | | | |
|-------------------------|------------|----------------|----------------|----------------|-------------------|-----------------------------------|----------|----------|
| Wed 10/23/2019 | to | Tue 12/17/2019 | <u>UPDATED</u> | <u>by NYPA</u> | <u>09/10/2019</u> | SCH - OH - NY | FWD | REV |
| 0500 | Continuous | 1700 | | | | Impacts Total Transfer Capability | (Import) | (Export) |
| Work scheduled by: NYPA | | | | | | TTC with All Lines In Service | 2050 MW | 1800 MW |
| | | | | | | | 0 MW | 100 MW |
| | | | | | | | 2050 MW | 1900 MW |

HURLYAVE-ROSETON_345_303

| | | | | | | | |
|-------------------------|------------|----------------|----------------|--------------|-------------------|-----------------------------------|----------|
| Wed 10/23/2019 | to | Thu 10/31/2019 | <u>UPDATED</u> | <u>by CH</u> | <u>10/21/2019</u> | UPNY CONED | FWD |
| 0800 | Continuous | 1600 | | | | Impacts Total Transfer Capability | (Import) |
| Work scheduled by: CHGE | | | | | | TTC with All Lines In Service | 4100 MW |
| | | | | | | | 1600 MW |
| | | | | | | | 5700 MW |

EGRDNCTY_345_138_AT1

| | | | | | | | |
|-----------------------|------------|----------------|----------------|--------------|-------------------|-----------------------------------|----------|
| Thu 10/24/2019 | to | Sun 11/03/2019 | <u>UPDATED</u> | <u>by LI</u> | <u>10/24/2019</u> | CONED - LIPA | FWD |
| 0001 | Continuous | 0300 | | | | Impacts Total Transfer Capability | (Import) |
| Work scheduled by: LI | | | | | | TTC with All Lines In Service | 1250 MW |
| | | | | | | | 250 MW |
| | | | | | | | 1500 MW |

EGRDNCTY_345_138_AT2

| | | | | | | | |
|-----------------------|------------|----------------|----------------|--------------|-------------------|-----------------------------------|----------|
| Thu 10/24/2019 | to | Sun 11/03/2019 | <u>UPDATED</u> | <u>by LI</u> | <u>10/24/2019</u> | CONED - LIPA | FWD |
| 0001 | Continuous | 0300 | | | | Impacts Total Transfer Capability | (Import) |
| Work scheduled by: LI | | | | | | TTC with All Lines In Service | 1250 MW |
| | | | | | | | 250 MW |
| | | | | | | | 1500 MW |

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5700MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-EGRDNCTR_345_Y49

Thu 10/24/2019 to Sun 11/03/2019
0001 Continuous 0300

UPDATED by LI 10/24/2019

Work scheduled by: LI

FWD
(Import)
775 MW
CONED - LIPA
Impacts Total Transfer Capability 725 MW
TTC with All Lines In Service 1500 MW

LONG_MTN-CRICKVLY_345_398

Mon 10/28/2019 to Mon 10/28/2019
0200 Continuous 2000

Work scheduled by: ConEd

FWD REV
(Import) (Export)
500 MW 1250 MW
SCH - NE - NY
Impacts Total Transfer Capability 900 MW 350 MW
TTC with All Lines In Service 1400 MW 1600 MW

LONG_MTN-CRICKVLY_345_398

Mon 10/28/2019 to Mon 10/28/2019
0200 Continuous 2000

Work scheduled by: ConEd

FWD REV
(Import) (Export)
100 MW 100 MW
SCH - NPX_1385
Impacts Total Transfer Capability 100 MW 100 MW
TTC with All Lines In Service 200 MW 200 MW

SCH-NE-NYISO_LIMIT_200

Mon 10/28/2019 to Mon 10/28/2019
0200 Continuous 2000

Work scheduled by: ConEd

FWD
(Import)
400 MW
SCH - NE - NY
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 1400 MW

SCH-NYISO-NE_LIMIT_300

Mon 10/28/2019 to Mon 10/28/2019
0200 Continuous 2000

Work scheduled by: ConEd

REV
(Export)
500 MW
SCH - NE - NY
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 1600 MW

GOETHALS_345KV_5

Tue 10/29/2019 to Thu 10/31/2019
0001 Continuous 0100

UPDATED by CE 10/29/2019

Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

DENNISON-ROSEMNTA_115_1/11

Tue 10/29/2019 to Thu 10/31/2019
0700 Continuous 2015

UPDATED by NGRID 10/28/2019

Work scheduled by: NGrid

FWD REV
(Import) (Export)
95 MW 40 MW
SCH - HQ_CEDARS
Impacts Total Transfer Capability 95 MW 0 MW
TTC with All Lines In Service 190 MW 40 MW

NYISO TRANSFER LIMITATIONS

Saturday ,November 02, 2019 to Monday ,May 03, 2021

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5700MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | FWD | REV |
|-----------------------------------|------------|----------------|----------------|----------------|-------------------|-----------------------------------|----------------|
| | | | | | | (Import) | (Export) |
| HOPATCON-RAMAPO___500_5018 | | | | | | | |
| Fri 11/01/2019 | to | Tue 11/05/2019 | <u>UPDATED</u> | <u>by CE</u> | <u>10/30/2019</u> | | |
| 0001 | Continuous | 2200 | | | | SCH - PJ - NY | 1250 MW |
| Work scheduled by: ConEd | | | | | | Impacts Total Transfer Capability | 650 MW |
| | | | | | | TTC with All Lines In Service | 2900 MW |
| HOPATCON-RAMAPO___500_5018 | | | | | | FWD | |
| | | | | | | (Import) | |
| Fri 11/01/2019 | to | Tue 11/05/2019 | <u>UPDATED</u> | <u>by CE</u> | <u>10/30/2019</u> | | |
| 0001 | Continuous | 2200 | | | | UPNY CONED | 5000 MW |
| Work scheduled by: ConEd | | | | | | Impacts Total Transfer Capability | 700 MW |
| | | | | | | TTC with All Lines In Service | 5700 MW |
| RAMAPO___345_345_PAR3500 | | | | | | FWD | REV |
| | | | | | | (Import) | (Export) |
| Fri 11/01/2019 | to | Tue 11/05/2019 | <u>UPDATED</u> | <u>by CE</u> | <u>10/30/2019</u> | | |
| 0001 | Continuous | 2200 | | | | SCH - PJ - NY | 2150 MW |
| Work scheduled by: ConEd | | | | | | Impacts Total Transfer Capability | 600 MW |
| | | | | | | TTC with All Lines In Service | 2900 MW |
| RAMAPO___345_345_PAR4500 | | | | | | FWD | REV |
| | | | | | | (Import) | (Export) |
| Fri 11/01/2019 | to | Tue 11/05/2019 | <u>UPDATED</u> | <u>by CE</u> | <u>10/30/2019</u> | | |
| 0001 | Continuous | 2200 | | | | SCH - PJ - NY | 2150 MW |
| Work scheduled by: ConEd | | | | | | Impacts Total Transfer Capability | 600 MW |
| | | | | | | TTC with All Lines In Service | 2900 MW |
| RAMAPO___500_345_BK 1500 | | | | | | FWD | REV |
| | | | | | | (Import) | (Export) |
| Fri 11/01/2019 | to | Tue 11/05/2019 | <u>UPDATED</u> | <u>by CE</u> | <u>10/30/2019</u> | | |
| 0001 | Continuous | 2200 | | | | SCH - PJ - NY | 1250 MW |
| Work scheduled by: ConEd | | | | | | Impacts Total Transfer Capability | 650 MW |
| | | | | | | TTC with All Lines In Service | 2900 MW |
| RAMAPO___500_345_BK 1500 | | | | | | FWD | |
| | | | | | | (Import) | |
| Fri 11/01/2019 | to | Tue 11/05/2019 | <u>UPDATED</u> | <u>by CE</u> | <u>10/30/2019</u> | | |
| 0001 | Continuous | 2200 | | | | UPNY CONED | 5000 MW |
| Work scheduled by: ConEd | | | | | | Impacts Total Transfer Capability | 700 MW |
| | | | | | | TTC with All Lines In Service | 5700 MW |
| SCH-IMO-NYISO_LIMIT_1750 | | | | | | FWD | |
| | | | | | | (Import) | |
| Fri 11/01/2019 | to | Thu 04/30/2020 | <u>UPDATED</u> | <u>by IESO</u> | <u>05/03/2019</u> | | |
| 0001 | Continuous | 2359 | | | | SCH - OH - NY | 2050 MW |
| Work scheduled by: IESO | | | | | | Impacts Total Transfer Capability | 0 MW |
| | | | | | | TTC with All Lines In Service | 2050 MW |

NYISO TRANSFER LIMITATIONS

Saturday ,November 02, 2019 to Monday ,May 03, 2021

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5700MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-IMO_LIMIT_1600

Fri 11/01/2019 to Thu 04/30/2020
0001 Continuous 2359

UPDATED by IESO 05/03/2019

Work scheduled by: IESO

SCH - OH - NY
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 1900 MW

REV
(Export)

SCH-NYISO-NE_LIMIT_1500

Fri 11/01/2019 to Thu 04/30/2020
0001 Continuous 2359

Work scheduled by: NYISO

SCH - NE - NY
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 1700 MW

REV
(Export)

VOLNEY_-MARCY_345_19

Fri 11/01/2019 to Fri 11/01/2019
0730 Daily(No Weekends) 1630

Work scheduled by: NGrid

ARR: 19

FWD
(Import)
CENTRAL EAST - VC
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 2975 MW

VOLNEY_-MARCY_345_19

Fri 11/01/2019 to Fri 11/01/2019
0730 Daily(No Weekends) 1630

Work scheduled by: NGrid

ARR: 19

FWD
(Import)
OSWEGO EXPORT
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 5250 MW

SHORE_RD_345_138_BK 1

Mon 11/04/2019 to Mon 11/04/2019
0001 Continuous 2359

Work scheduled by: ConEd

FWD
(Import)
CONED - LIPA
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 1500 MW

SCH-IMO-NYISO_LIMIT_300

Mon 11/04/2019 to Fri 11/08/2019
0500 Continuous 1859

Work scheduled by: IESO

FWD
(Import)
SCH - OH - NY
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 2050 MW

LINDN_CG-LNDVFT_345_V-3022

Mon 11/04/2019 to Thu 11/07/2019
0800 Continuous 1500

Work scheduled by: PJM

FWD REV
(Import) (Export)
SCH - PJM_VFT
Impacts Total Transfer Capability 315 MW 315 MW
TTC with All Lines In Service 315 MW 315 MW

NYISO TRANSFER LIMITATIONS

Saturday ,November 02, 2019 to Monday ,May 03, 2021

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5700MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | |
|-----------------------------------|--------------------|------|----------------|----------------|-----------------------------------|----------------|
| WATRCURE_345_230_BK 1 | | | | | FWD | REV |
| Tue 11/05/2019 to Tue 11/05/2019 | | | | | (Import) | (Export) |
| 0800 | Continuous | 1530 | | | SCH - PJ - NY | 2600 MW |
| Work scheduled by: NYSEG | | | | | Impacts Total Transfer Capability | 300 MW |
| | | | | | TTC with All Lines In Service | 2900 MW |
| LADENTWN-BUCHAN_S_345_Y88 | | | | | FWD | |
| Wed 11/06/2019 to Wed 11/06/2019 | | | | | (Import) | |
| 0001 | Continuous | 2359 | | | UPNY CONED | 4800 MW |
| Work scheduled by: ORU | | | | | Impacts Total Transfer Capability | 900 MW |
| | | | | | TTC with All Lines In Service | 5700 MW |
| MARCY___-N.SCTLND_345_18 | | | | | FWD | |
| Wed 11/06/2019 to Wed 11/13/2019 | | | | | (Import) | |
| 0500 | Continuous | 1730 | UPDATED | by NYPA | CENTRAL EAST - VC | 2090 MW |
| Work scheduled by: NYPA | | | | | Impacts Total Transfer Capability | 885 MW |
| | | | | | TTC with All Lines In Service | 2975 MW |
| MARCY___345KV_CSC | | | | | FWD | |
| Wed 11/06/2019 to Fri 11/22/2019 | | | | | (Import) | |
| 0500 | Continuous | 1730 | UPDATED | by NYPA | CENTRAL EAST - VC | 2925 MW |
| Work scheduled by: NYPA | | | | | Impacts Total Transfer Capability | 50 MW |
| | | | | | TTC with All Lines In Service | 2975 MW |
| MARCY___765_345_AT2 | | | | | FWD | |
| Wed 11/06/2019 to Fri 11/22/2019 | | | | | (Import) | |
| 0500 | Continuous | 1730 | UPDATED | by NYPA | MOSES SOUTH | 1700 MW |
| Work scheduled by: NYPA | | | | | Impacts Total Transfer Capability | 1450 MW |
| | | | | | TTC with All Lines In Service | 3150 MW |
| ALCOA_R8105_TIE_B | | | | | FWD | |
| Wed 11/06/2019 to Wed 11/06/2019 | | | | | (Import) | |
| 0700 | Daily(No Weekends) | 1630 | | | MOSES SOUTH | 3100 MW |
| Work scheduled by: NGrid | | | | | Impacts Total Transfer Capability | 50 MW |
| | | | | | TTC with All Lines In Service | 3150 MW |
| HURLYAVE-ROSETON___345_303 | | | | | FWD | |
| Wed 11/06/2019 to Fri 12/06/2019 | | | | | (Import) | |
| 0800 | Continuous | 1600 | UPDATED | by CH | UPNY CONED | 4100 MW |
| Work scheduled by: CHGE | | | | | Impacts Total Transfer Capability | 1600 MW |
| | | | | | TTC with All Lines In Service | 5700 MW |

NYISO TRANSFER LIMITATIONS

Saturday ,November 02, 2019 to Monday ,May 03, 2021

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5700MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N.SCTLND-LEEDS____345_94

Wed 11/06/2019 to Thu 11/07/2019
0830 Continuous 1430

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

KINTIGH_-ROCHESTR_345_SR1-39

Thu 11/07/2019 to Wed 11/13/2019
0700 Continuous 1900

Work scheduled by: RGE

UPDATED by RGE 11/01/2019

FWD
(Import)
DYSINGER EAST **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

PLSNTVLE-DUNWODIE_345_W89

Fri 11/08/2019 to Sat 11/09/2019
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

PLSNTVLY_345KV_RNS5

Mon 11/11/2019 to Mon 11/11/2019
0001 Continuous 0030

Work scheduled by: ConEd

CANCELLED by ConEd 10/29/2019

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 5700 MW

PLSNTVLY-WOOD_ST__345_F30

Mon 11/11/2019 to Tue 11/12/2019
0001 Continuous 0200

Work scheduled by: ConEd

CANCELLED by ConEd 10/29/2019

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

E13THSTA-FARRAGUT_345_45

Tue 11/12/2019 to Tue 11/12/2019
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 10/23/2019

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

PLSNTVLY_345KV_RNS5

Tue 11/12/2019 to Tue 11/12/2019
0130 Continuous 0200

Work scheduled by: ConEd

CANCELLED by ConEd 10/29/2019

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Saturday ,November 02, 2019 to Monday ,May 03, 2021

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5700MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-WOOD_ST__345_F31

FWD

Thu 11/14/2019 to Thu 11/14/2019 UPDATED by NYISO 09/18/2019

(Import)

0001 Continuous 2200

UPNY CONED **4000 MW**

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

PLSNTVLY_345KV_RNS4

FWD

Thu 11/14/2019 to Thu 11/14/2019 UPDATED by NYISO 09/18/2019

(Import)

0001 Continuous 2200

UPNY CONED **3800 MW**

Impacts Total Transfer Capability 1900 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

E13THSTA-FARRAGUT_345_45

FWD

Thu 11/14/2019 to Thu 11/14/2019 UPDATED by CONED 10/23/2019

(Import)

0130 Continuous 0200

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

W49TH_ST-E13THSTA_345_M54

FWD

Thu 11/14/2019 to Thu 11/14/2019

(Import)

0201 Continuous 0500

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

BUCHAN_N-EASTVIEW_345_W93

FWD

Sun 11/17/2019 to Mon 11/18/2019 UPDATED by CONED 09/09/2019

(Import)

0301 Continuous 0300

UPNY CONED **4350 MW**

Impacts Total Transfer Capability 1350 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

EASTVIEW-SPRNBK__345_W79

FWD

Sun 11/17/2019 to Mon 11/18/2019 UPDATED by CONED 09/09/2019

(Import)

0301 Continuous 0300

UPNY CONED **4350 MW**

Impacts Total Transfer Capability 1350 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

SCH-NE-NYISO_LIMIT_500

FWD

Sun 11/17/2019 to Sun 11/17/2019

(Import)

1100 Continuous 1600

SCH - NE - NY **700 MW**

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5700MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_1200

Sun 11/17/2019 to Sun 11/17/2019

1100 Continuous 1600

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

1400 MW

300 MW

1700 MW

W49TH_ST_345KV_6

Mon 11/18/2019 to Mon 11/18/2019

0230 Continuous 0259

Work scheduled by: ConEd

UPDATEDby CONED 11/01/2019

SCH - PJM_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

350 MW

310 MW

660 MW

E13THSTA-FARRAGUT_345_46

Mon 11/18/2019 to Thu 11/21/2019

0230 Continuous 0259

Work scheduled by: ConEd

UPDATEDby CONED 11/01/2019

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

3800 MW

800 MW

4600 MW

W49TH_ST-E13THSTA_345_M55

Mon 11/18/2019 to Thu 11/21/2019

0230 Continuous 0259

Work scheduled by: ConEd

UPDATEDby CONED 11/01/2019

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

3800 MW

800 MW

4600 MW

SPRNBK__345KV_RNS5

Mon 11/18/2019 to Mon 11/18/2019

0301 Continuous 0330

Work scheduled by: ConEd

UPDATEDby CONED 09/09/2019

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

3200 MW

1400 MW

4600 MW

EASTVIEW-SPRNBK__345_W64

Mon 11/18/2019 to Tue 11/19/2019

0301 Continuous 0200

Work scheduled by: ConEd

UPDATEDby CONED 09/09/2019

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

4350 MW

1350 MW

5700 MW

MILLWOOD-EASTVIEW_345_W99

Mon 11/18/2019 to Tue 11/19/2019

0301 Continuous 0200

Work scheduled by: ConEd

UPDATEDby CONED 09/09/2019

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

4350 MW

1350 MW

5700 MW

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5700MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | |
|--|------------|----------------|----------------|-----------------------------------|------------------------|
| BERKSHIR-ALPS_____345_393 | | | | FWD | REV |
| Mon 11/18/2019 | to | Wed 11/27/2019 | | (Import) | (Export) |
| 0600 | Continuous | 1700 | | SCH - NE - NY | 1150 MW 1300 MW |
| Work scheduled by: ISONE | | | ARR: 78 | Impacts Total Transfer Capability | 250 MW 400 MW |
| | | | | TTC with All Lines In Service | 1400 MW 1700 MW |
| BERKSHIR-ALPS_____345_393 | | | | FWD | REV |
| Mon 11/18/2019 | to | Wed 11/27/2019 | | (Import) | (Export) |
| 0600 | Continuous | 1700 | | SCH - NPX_1385 | 100 MW 100 MW |
| Work scheduled by: ISONE | | | ARR: 78 | Impacts Total Transfer Capability | 100 MW 100 MW |
| | | | | TTC with All Lines In Service | 200 MW 200 MW |
| BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312 | | | | FWD | REV |
| Mon 11/18/2019 | to | Wed 11/27/2019 | | (Import) | (Export) |
| 0600 | | 1700 | | SCH - NE - NY | 1150 MW 1300 MW |
| Work scheduled by: | | | ARR: 78 | Impacts Total Transfer Capability | 250 MW 400 MW |
| | | | | TTC with All Lines In Service | 1400 MW 1700 MW |
| BERKSHIR-NORTHFLD_345_312 | | | | FWD | REV |
| Mon 11/18/2019 | to | Wed 11/27/2019 | | (Import) | (Export) |
| 0600 | Continuous | 1700 | | SCH - NE - NY | 1400 MW 1500 MW |
| Work scheduled by: ISONE | | | | Impacts Total Transfer Capability | 0 MW 200 MW |
| | | | | TTC with All Lines In Service | 1400 MW 1700 MW |
| BERKSHIR-NORTHFLD_345_312 | | | | FWD | REV |
| Mon 11/18/2019 | to | Wed 11/27/2019 | | (Import) | (Export) |
| 0600 | Continuous | 1700 | | SCH - NPX_1385 | 100 MW 100 MW |
| Work scheduled by: ISONE | | | | Impacts Total Transfer Capability | 100 MW 100 MW |
| | | | | TTC with All Lines In Service | 200 MW 200 MW |
| SCH-NE-NYISO_LIMIT_800 | | | | FWD | |
| Mon 11/18/2019 | to | Wed 11/27/2019 | | (Import) | |
| 0600 | Continuous | 1700 | | SCH - NE - NY | 1000 MW |
| Work scheduled by: ISONE | | | | Impacts Total Transfer Capability | 400 MW |
| | | | | TTC with All Lines In Service | 1400 MW |
| SCH-NYISO-NE_LIMIT_500 | | | | | REV |
| Mon 11/18/2019 | to | Wed 11/27/2019 | | | (Export) |
| 0600 | Continuous | 1700 | | SCH - NE - NY | 700 MW |
| Work scheduled by: ISONE | | | | Impacts Total Transfer Capability | 1000 MW |
| | | | | TTC with All Lines In Service | 1700 MW |

NYISO TRANSFER LIMITATIONS

Saturday ,November 02, 2019 to Monday ,May 03, 2021

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5700MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | |
|----------------------------------|------------|----------------|----------------|-----------------|-----------------------------------|------------------------|
| SPRNBK__345KV_RNS5 | | | | | FWD | |
| Tue 11/19/2019 | to | Tue 11/19/2019 | <u>UPDATED</u> | <u>by CONED</u> | <u>09/09/2019</u> | (Import) |
| 0130 | Continuous | 0200 | | | | |
| Work scheduled by: ConEd | | | | | SPR/DUN-SOUTH | 3200 MW |
| | | | | | Impacts Total Transfer Capability | 1400 MW |
| | | | | | TTC with All Lines In Service | 4600 MW |
| WATRCURE-OAKDALE__345_31 | | | | | FWD | REV |
| Tue 11/19/2019 | to | Tue 11/19/2019 | <u>UPDATED</u> | <u>by NYSEG</u> | <u>09/13/2019</u> | (Import) (Export) |
| 1300 | Continuous | 1500 | | | | |
| Work scheduled by: NYSEG | | | | | SCH - PJ - NY | 2600 MW 1300 MW |
| | | | | | Impacts Total Transfer Capability | 300 MW 550 MW |
| | | | | | TTC with All Lines In Service | 2900 MW 1850 MW |
| W49TH_ST_345KV_6 | | | | | FWD | |
| Thu 11/21/2019 | to | Thu 11/21/2019 | <u>UPDATED</u> | <u>by CONED</u> | <u>11/01/2019</u> | (Import) |
| 0230 | Continuous | 0259 | | | | |
| Work scheduled by: ConEd | | | | | SCH - PJM_HTP | 350 MW |
| | | | | | Impacts Total Transfer Capability | 310 MW |
| | | | | | TTC with All Lines In Service | 660 MW |
| EASTVIEW-SPRNBK__345_W64 | | | | | FWD | |
| Sat 11/23/2019 | to | Sat 11/23/2019 | | | | (Import) |
| 0130 | Continuous | 0200 | | | | |
| Work scheduled by: ConEd | | | | | UPNY CONED | 4350 MW |
| | | | | | Impacts Total Transfer Capability | 1350 MW |
| | | | | | TTC with All Lines In Service | 5700 MW |
| MILLWOOD-EASTVIEW_345_W99 | | | | | FWD | |
| Sat 11/23/2019 | to | Sat 11/23/2019 | | | | (Import) |
| 0130 | Continuous | 0200 | | | | |
| Work scheduled by: ConEd | | | | | UPNY CONED | 4350 MW |
| | | | | | Impacts Total Transfer Capability | 1350 MW |
| | | | | | TTC with All Lines In Service | 5700 MW |
| SPRNBK__345KV_RNS5 | | | | | FWD | |
| Sat 11/23/2019 | to | Sat 11/23/2019 | | | | (Import) |
| 0130 | Continuous | 0200 | | | | |
| Work scheduled by: ConEd | | | | | SPR/DUN-SOUTH | 3200 MW |
| | | | | | Impacts Total Transfer Capability | 1400 MW |
| | | | | | TTC with All Lines In Service | 4600 MW |
| RAMAPO__-LADENTWN_345_W72 | | | | | FWD | |
| Mon 11/25/2019 | to | Mon 11/25/2019 | | | | (Import) |
| 0001 | Continuous | 2200 | | | | |
| Work scheduled by: ConEd | | | | | UPNY CONED | 4400 MW |
| | | | | | Impacts Total Transfer Capability | 1300 MW |
| | | | | | TTC with All Lines In Service | 5700 MW |

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5700MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

FWD

Mon 11/25/2019 to Wed 11/27/2019

(Import)

0700 Continuous 1500

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

CHAT_DC_GC1

FWD

Sat 11/30/2019 to Sat 11/30/2019

(Import)

0001 Continuous 0200

MOSES SOUTH

2850 MW

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

CHAT_DC_GC1

REV

Sat 11/30/2019 to Sat 11/30/2019

(Export)

0001 Continuous 0200

SCH - HQ - NY

500 MW

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

Work scheduled by: HQ

CHAT_DC_GC1 & CHAT_DC_GC2

FWD

Sat 11/30/2019 to Sat 11/30/2019

(Import)

0001 0200

MOSES SOUTH

2550 MW

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 3150 MW

Work scheduled by:

CHAT_DC_GC1 & CHAT_DC_GC2

FWD

REV

Sat 11/30/2019 to Sat 11/30/2019

(Import) (Export)

0001 0200

SCH - HQ - NY

1370 MW 0 MW

Impacts Total Transfer Capability 130 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by:

CHAT_DC_GC2

FWD

Sat 11/30/2019 to Sat 11/30/2019

(Import)

0001 Continuous 0200

MOSES SOUTH

2850 MW

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

CHAT_DC_GC2

REV

Sat 11/30/2019 to Sat 11/30/2019

(Export)

0001 Continuous 0200

SCH - HQ - NY

500 MW

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

Work scheduled by: HQ

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5700MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ-NYISO_LIMIT_1150

Sat 11/30/2019 to Sat 11/30/2019
0001 Continuous 0200

Work scheduled by: HQ

FWD
(Import)
SCH - HQ - NY **1150 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 1500 MW

SPRNBK_-TREMONT_345_X28

Mon 12/02/2019 to Mon 12/02/2019
0001 Continuous 1700

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **4200 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 4600 MW

SHOR_NPX-SHOREHAM_138_CSC

Mon 12/02/2019 to Mon 12/02/2019
0700 Continuous 2300

Work scheduled by: LI

UPDATED by ISONE 10/04/2019

FWD REV
(Import) (Export)
SCH - NPX_CSC **0 MW 0 MW**
Impacts Total Transfer Capability 330 MW 330 MW
TTC with All Lines In Service 330 MW 330 MW

MOSES_-ADIRNDCK_230_MA2

Mon 12/02/2019 to Fri 12/06/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

N.SCTLND-ALPS_345_2

Mon 12/02/2019 to Mon 12/02/2019
0730 Daily(No Weekends) 1630

Work scheduled by: NGrid

FWD REV
(Import) (Export)
SCH - NE - NY **900 MW 1700 MW**
Impacts Total Transfer Capability 500 MW 0 MW
TTC with All Lines In Service 1400 MW 1700 MW

N.SCTLND-ALPS_345_2

Mon 12/02/2019 to Mon 12/02/2019
0730 Daily(No Weekends) 1630

Work scheduled by: NGrid

FWD REV
(Import) (Export)
SCH - NPX_1385 **100 MW 100 MW**
Impacts Total Transfer Capability 100 MW 100 MW
TTC with All Lines In Service 200 MW 200 MW

FRASER_345_FRASER SVC

Mon 12/02/2019 to Fri 12/13/2019
0800 Continuous 1500

Work scheduled by: NYSEG

FWD
(Import)
CENTRAL EAST - VC **2935 MW**
Impacts Total Transfer Capability 40 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Saturday ,November 02, 2019 to Monday ,May 03, 2021

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5700MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

S.RIPLEY-DUNKIRK__230_68

Mon 12/02/2019 to Fri 12/06/2019
0900 Continuous 1500

Work scheduled by: PJM

| | FWD | REV |
|-----------------------------------|----------------|----------------|
| | (Import) | (Export) |
| SCH - PJ - NY | 2600 MW | 1300 MW |
| Impacts Total Transfer Capability | 300 MW | 550 MW |
| TTC with All Lines In Service | 2900 MW | 1850 MW |

LEEDS__345KV_R94301

Tue 12/03/2019 to Fri 12/13/2019
0800 Continuous 1500

Work scheduled by: NGrid

UPDATED by NGRID 10/04/2019

| | FWD |
|-----------------------------------|----------------|
| | (Import) |
| UPNY CONED | 3800 MW |
| Impacts Total Transfer Capability | 1900 MW |
| TTC with All Lines In Service | 5700 MW |

MOSES__-ADIRNDCK_230_Ma1

Mon 12/09/2019 to Fri 12/13/2019
0700 Continuous 1500

Work scheduled by: NYPA

| | FWD |
|-----------------------------------|----------------|
| | (Import) |
| MOSES SOUTH | 2300 MW |
| Impacts Total Transfer Capability | 850 MW |
| TTC with All Lines In Service | 3150 MW |

ROSETON_-ROCKTVRN_345_311

Mon 12/09/2019 to Thu 12/12/2019
0800 Continuous 1600

Work scheduled by: CHGE

| | FWD |
|-----------------------------------|----------------|
| | (Import) |
| UPNY CONED | 4400 MW |
| Impacts Total Transfer Capability | 1300 MW |
| TTC with All Lines In Service | 5700 MW |

SHOR_NPX-SHOREHAM_138_CSC

Thu 12/12/2019 to Fri 12/20/2019
0700 Continuous 1500

Work scheduled by: ISONE

| | FWD | REV |
|-----------------------------------|-------------|-------------|
| | (Import) | (Export) |
| SCH - NPX_CSC | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 330 MW | 330 MW |
| TTC with All Lines In Service | 330 MW | 330 MW |

NRTH1385-NOR HBR__138_601

Mon 12/16/2019 to Mon 12/23/2019
0001 Continuous 2359

Work scheduled by: LI

UPDATED by LIPA 10/25/2019

| | FWD | REV |
|-----------------------------------|---------------|---------------|
| | (Import) | (Export) |
| SCH - NPX_1385 | 100 MW | 100 MW |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602

Mon 12/16/2019 to Mon 12/23/2019
0001 Continuous 2359

Work scheduled by:

| | FWD | REV |
|-----------------------------------|-------------|-------------|
| | (Import) | (Export) |
| SCH - NPX_1385 | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 200 MW | 200 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

NYISO TRANSFER LIMITATIONS

Saturday ,November 02, 2019 to Monday ,May 03, 2021

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5700MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603

Mon 12/16/2019 to Mon 12/23/2019
0001 2359

Work scheduled by:

| | | |
|-----------------------------------|----------|----------|
| | FWD | REV |
| | (Import) | (Export) |
| SCH - NPX_1385 | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 200 MW | 200 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

NRTH1385-NOR HBR__138_602

Mon 12/16/2019 to Mon 12/23/2019 UPDATED by LIPA 10/25/2019
0001 Continuous 2359

Work scheduled by: LI

| | | |
|-----------------------------------|----------|----------|
| | FWD | REV |
| | (Import) | (Export) |
| SCH - NPX_1385 | 100 MW | 100 MW |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603

Mon 12/16/2019 to Mon 12/23/2019
0001 2359

Work scheduled by:

| | | |
|-----------------------------------|----------|----------|
| | FWD | REV |
| | (Import) | (Export) |
| SCH - NPX_1385 | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 200 MW | 200 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

NRTH1385-NOR HBR__138_603

Mon 12/16/2019 to Mon 12/23/2019 UPDATED by LIPA 10/25/2019
0001 Continuous 2359

Work scheduled by: LI

| | | |
|-----------------------------------|----------|----------|
| | FWD | REV |
| | (Import) | (Export) |
| SCH - NPX_1385 | 100 MW | 100 MW |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

NRTH1385-NRTHPORT_138_NNC

Mon 12/16/2019 to Mon 12/23/2019 UPDATED by LIPA 10/25/2019
0001 Continuous 2359

Work scheduled by: LI

| | | |
|-----------------------------------|----------|----------|
| | FWD | REV |
| | (Import) | (Export) |
| SCH - NPX_1385 | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 200 MW | 200 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

MOSES__-ADIRNDCK_230_MA2

Mon 12/16/2019 to Mon 12/16/2019
0700 Continuous 1500

Work scheduled by: NYPA

| | |
|-----------------------------------|----------|
| | FWD |
| | (Import) |
| MOSES SOUTH | 2300 MW |
| Impacts Total Transfer Capability | 850 MW |
| TTC with All Lines In Service | 3150 MW |

EDIC__-FRASER__345_EF24-40

Mon 12/16/2019 to Tue 12/17/2019
0700 Continuous 1730

Work scheduled by: NYPA

| | |
|-----------------------------------|----------|
| | FWD |
| | (Import) |
| CENTRAL EAST - VC | 2500 MW |
| Impacts Total Transfer Capability | 475 MW |
| TTC with All Lines In Service | 2975 MW |

NYISO TRANSFER LIMITATIONS

Saturday ,November 02, 2019 to Monday ,May 03, 2021

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5700MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

Tue 12/17/2019 to Fri 12/20/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

EASTVIEW-SPRNBK__345_W65

Wed 12/18/2019 to Wed 12/18/2019
0201 Continuous 0230

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

SPRNBK__345KV_RNS4

Wed 12/18/2019 to Wed 12/18/2019
0201 Continuous 0230

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W82

Wed 12/18/2019 to Wed 12/18/2019
0201 Continuous 1800

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

EASTVIEW-SPRNBK__345_W65

Wed 12/18/2019 to Wed 12/18/2019
1730 Continuous 1800

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

SPRNBK__345KV_RNS4

Wed 12/18/2019 to Wed 12/18/2019
1730 Continuous 1800

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

EFISHKIL-WOOD_ST__345_F38

Fri 12/20/2019 to Sat 12/21/2019
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Saturday ,November 02, 2019 to Monday ,May 03, 2021

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5700MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLE-DUNWODIE_345_W89

Fri 12/20/2019 to Sat 12/21/2019

0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

4000 MW

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

WOOD_ST_-PLSNTVLE_345_Y86

Fri 12/20/2019 to Sat 12/21/2019

0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

4000 MW

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

SCH-NE-NYISO_LIMIT_500

Fri 12/20/2019 to Fri 12/20/2019

0600 Continuous 1600

Work scheduled by: ISONE

UPDATEDby ISONE 10/11/2019

FWD

(Import)

SCH - NE - NY

700 MW

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 1400 MW

SCH-NYISO-NE_LIMIT_1200

Fri 12/20/2019 to Fri 12/20/2019

0600 Continuous 1600

Work scheduled by: ISONE

UPDATEDby ISONE 10/11/2019

REV

(Export)

SCH - NE - NY

1400 MW

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 1700 MW

MOSES_-ADIRNDCK_230_MA2

Thu 01/02/2020 to Sun 03/01/2020

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

BECK_-NIAGARA_345_PA301

Mon 01/13/2020 to Fri 01/17/2020

0500 Continuous 1530

Work scheduled by: NYPA

FWD

REV

(Import) (Export)

SCH - OH - NY

1100 MW 950 MW

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2050 MW 1900 MW

LADENTWN-BUCHAN_S_345_Y88

Wed 01/15/2020 to Thu 02/13/2020

0001 Continuous 2359

Work scheduled by: ORU

CANCELLEDby NYISO 10/31/2019

FWD

(Import)

UPNY CONED

4800 MW

Impacts Total Transfer Capability 900 MW

TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Saturday ,November 02, 2019 to Monday ,May 03, 2021

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5700MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOTTHAVN-RAINEY___345_Q11

Sun 02/23/2020 to Sun 03/01/2020

0001 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

NIAGARA_-PACKARD__230_62

Fri 02/28/2020 to Fri 02/28/2020

0500 Continuous 1530

Work scheduled by: NYPA

FWD

REV

(Import) (Export)

SCH - OH - NY

1100 MW 950 MW

Impacts Total Transfer Capability 950 MW 950 MW

TTC with All Lines In Service 2050 MW 1900 MW

CHATGUAY-MASSENA__765_7040

Mon 03/02/2020 to Fri 03/06/2020

0500 Continuous 1730

Work scheduled by: NYPA

UPDATEDby NYPA08/08/2019

FWD

(Import)

MOSES SOUTH

1550 MW

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA__765_7040

Mon 03/02/2020 to Fri 03/06/2020

0500 Continuous 1730

Work scheduled by: NYPA

UPDATEDby NYPA08/08/2019

FWD

REV

(Import) (Export)

SCH - HQ - NY

0 MW 0 MW

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

MARCY___765_345_AT1

Mon 03/02/2020 to Fri 03/06/2020

0500 Continuous 1730

Work scheduled by: NYPA

UPDATEDby NYPA08/08/2019

FWD

(Import)

MOSES SOUTH

1750 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

ARR: 19

MARCY___765_345_AT2

Mon 03/02/2020 to Fri 03/06/2020

0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

1700 MW

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

ARR: 19

MASSENA_-MARCY___765_MSU1

Mon 03/02/2020 to Fri 03/06/2020

0500 Continuous 1730

Work scheduled by: NYPA

UPDATEDby NYPA08/08/2019

FWD

(Import)

CENTRAL EAST - VC

2265 MW

Impacts Total Transfer Capability 710 MW

TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Saturday ,November 02, 2019 to Monday ,May 03, 2021

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5700MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | | | | | |
|---|------------|----------------|----------------|----------------|-------------------|-----------------------------------|----------|---------|--|--|
| MASSENA_-MARCY____765_MSU1 | | | | | | FWD | | | | |
| Mon 03/02/2020 | to | Fri 03/06/2020 | <u>UPDATED</u> | <u>by NYPA</u> | <u>08/08/2019</u> | (Import) | | | | |
| 0500 | Continuous | 1730 | | | | MOSES SOUTH | 500 MW | | | |
| Work scheduled by: NYPA | | | | | | Impacts Total Transfer Capability | 2650 MW | | | |
| | | | | | | TTC with All Lines In Service | 3150 MW | | | |
| MASSENA_-MARCY____765_MSU1 | | | | | | FWD | REV | | | |
| Mon 03/02/2020 | to | Fri 03/06/2020 | <u>UPDATED</u> | <u>by NYPA</u> | <u>08/08/2019</u> | (Import) | (Export) | | | |
| 0500 | Continuous | 1730 | | | | SCH - HQ - NY | 475 MW | 1000 MW | | |
| Work scheduled by: NYPA | | | | | | Impacts Total Transfer Capability | 1025 MW | | | |
| | | | | | | TTC with All Lines In Service | 1500 MW | | | |
| MASSENA_-MARCY____765_MSU1 | | | | | | FWD | | | | |
| Mon 03/02/2020 | to | Fri 03/06/2020 | <u>UPDATED</u> | <u>by NYPA</u> | <u>08/08/2019</u> | (Import) | | | | |
| 0500 | Continuous | 1730 | | | | SCH - HQ_CEDARS | 90 MW | | | |
| Work scheduled by: NYPA | | | | | | Impacts Total Transfer Capability | 109 MW | | | |
| | | | | | | TTC with All Lines In Service | 199 MW | | | |
| MASSENA_-MARCY____765_MSU1 & CHATGUAY-MASSENA____765_7040 | | | | | | FWD | | | | |
| Mon 03/02/2020 | to | Fri 03/06/2020 | | | | (Import) | | | | |
| 0500 | | 1730 | | | | MOSES SOUTH | 500 MW | | | |
| Work scheduled by: | | | | | | Impacts Total Transfer Capability | 2650 MW | | | |
| | | | | | | TTC with All Lines In Service | 3150 MW | | | |
| MOSES____-MASSENA____230_MMS1 & MOSES____-MASSENA____230_MMS2 | | | | | | FWD | REV | | | |
| Mon 03/02/2020 | to | Fri 03/06/2020 | | | | (Import) | (Export) | | | |
| 0500 | | 1730 | | | | SCH - HQ - NY | 850 MW | 0 MW | | |
| Work scheduled by: | | | | | | Impacts Total Transfer Capability | 650 MW | | | |
| | | | | | | TTC with All Lines In Service | 1500 MW | | | |
| MOSES____-MASSENA____230_MMS1 & MOSES____-MASSENA____230_MMS2 | | | | | | FWD | | | | |
| Mon 03/02/2020 | to | Fri 03/06/2020 | | | | (Import) | | | | |
| 0500 | | 1730 | | | | SCH - HQ_CEDARS | 90 MW | | | |
| Work scheduled by: | | | | | | Impacts Total Transfer Capability | 109 MW | | | |
| | | | | | | TTC with All Lines In Service | 199 MW | | | |
| STLAWRNC-MOSES____230_L33P & MASSENA_-MARCY____765_MSU1 | | | | | | FWD | | | | |
| Mon 03/02/2020 | to | Fri 03/06/2020 | | | | (Import) | | | | |
| 0500 | | 1730 | | | | SCH - HQ_CEDARS | 90 MW | | | |
| Work scheduled by: | | | | | | Impacts Total Transfer Capability | 109 MW | | | |
| | | | | | | TTC with All Lines In Service | 199 MW | | | |

NYISO TRANSFER LIMITATIONS

Saturday ,November 02, 2019 to Monday ,May 03, 2021

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5700MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES___230_L33P & MOSES___-MASSENA_230_MMS1 & MOSES___-
MASSENA_230_MMS2

Mon 03/02/2020 to Fri 03/06/2020
0500 1730

Work scheduled by:

SCH - HQ_CEDARS 90 MW
Impacts Total Transfer Capability 109 MW
TTC with All Lines In Service 199 MW

EASTVIEW-SPRNBRK___345_W78

Fri 03/06/2020 to Sat 03/07/2020
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED 4350 MW
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

MILLWOOD-EASTVIEW_345_W85

Fri 03/06/2020 to Sat 03/07/2020
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED 4350 MW
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

SPRNBRK___345KV_RNS3

Fri 03/06/2020 to Sat 03/07/2020
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH 3800 MW
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

MOSES___-ADIRNDCK_230_MA1

Sat 03/07/2020 to Fri 05/29/2020
0700 Continuous 1300

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2300 MW
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

VOLNEY___-MARCY___345_19

Tue 03/10/2020 to Tue 03/10/2020
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 09/24/2019

ARR: 19

FWD
(Import)
CENTRAL EAST - VC 2825 MW
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 2975 MW

VOLNEY___-MARCY___345_19

Tue 03/10/2020 to Tue 03/10/2020
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 09/24/2019

ARR: 19

FWD
(Import)
OSWEGO EXPORT 4900 MW
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Saturday ,November 02, 2019 to Monday ,May 03, 2021

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5700MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASANNX-COOPERS__345_UCC2-41

Wed 03/11/2020 to Thu 03/12/2020
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY__-FRASANNX_345_UCC2-41

Wed 03/11/2020 to Thu 03/12/2020
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

ROCHESTR-PANNELL__345_RP2

Sat 03/14/2020 to Mon 03/23/2020
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MARCY__345KV_CSC

Mon 03/16/2020 to Fri 03/27/2020
0500 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

ROSETON_-EFISHKIL_345_RFK305

Mon 03/16/2020 to Fri 04/03/2020
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
UPNY CONED **4800 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 5700 MW

NIAGARA_-KINTIGH__345_NS1-38

Fri 03/27/2020 to Fri 03/27/2020
0600 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

BECK__-PACKARD__230_BP76

Fri 03/27/2020 to Fri 03/27/2020
0800 Daily(No Weekends) 1600

Work scheduled by: NGrid

| | |
|-----------------------------------|------------------------|
| FWD | REV |
| (Import) | (Export) |
| SCH - OH - NY | 1700 MW 1500 MW |
| Impacts Total Transfer Capability | 350 MW 400 MW |
| TTC with All Lines In Service | 2050 MW 1900 MW |

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5700MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | |
|------------------------------------|------------|----------------|----------------|----------------|-----------------------------------|-------------------|
| MARCY__-EDIC__345_UE1-7 | | | | | FWD | |
| Tue 03/31/2020 | to | Tue 03/31/2020 | <u>UPDATED</u> | <u>by NYPA</u> | <u>09/24/2019</u> | (Import) |
| 0700 | Continuous | 1530 | | | | |
| Work scheduled by: NYPA | | | | | OSWEGO EXPORT | 5250 MW |
| | | | | | Impacts Total Transfer Capability | 0 MW |
| | | | | | TTC with All Lines In Service | 5250 MW |
| SPRNBRK_-W49TH_ST_345_M51 | | | | | FWD | |
| Mon 04/06/2020 | to | Wed 04/08/2020 | | | | (Import) |
| 0001 | Continuous | 0200 | | | | |
| Work scheduled by: ConEd | | | | | SPR/DUN-SOUTH | 3200 MW |
| | | | | | Impacts Total Transfer Capability | 1400 MW |
| | | | | | TTC with All Lines In Service | 4600 MW |
| SPRNBRK__345KV_RNS5 | | | | | FWD | |
| Mon 04/06/2020 | to | Wed 04/08/2020 | | | | (Import) |
| 0001 | Continuous | 0200 | | | | |
| Work scheduled by: ConEd | | | | | SPR/DUN-SOUTH | 3200 MW |
| | | | | | Impacts Total Transfer Capability | 1400 MW |
| | | | | | TTC with All Lines In Service | 4600 MW |
| MARCY__-N.SCTLND_345_18 | | | | | FWD | |
| Tue 04/07/2020 | to | Wed 04/08/2020 | <u>UPDATED</u> | <u>by NYPA</u> | <u>09/24/2019</u> | (Import) |
| 0700 | Continuous | 1530 | | | | |
| Work scheduled by: NYPA | | | | | CENTRAL EAST - VC | 2090 MW |
| | | | | | Impacts Total Transfer Capability | 885 MW |
| | | | | | TTC with All Lines In Service | 2975 MW |
| LINDN_CG-LNDVFT__345_V-3022 | | | | | FWD REV | |
| Sun 04/12/2020 | to | Fri 04/17/2020 | | | | (Import) (Export) |
| 1400 | Continuous | 1800 | | | | |
| Work scheduled by: PJM | | | | | SCH - PJM_VFT | 0 MW 0 MW |
| | | | | | Impacts Total Transfer Capability | 315 MW 315 MW |
| | | | | | TTC with All Lines In Service | 315 MW 315 MW |
| PLSNTVLY-EFISHKIL_345_F36 | | | | | FWD | |
| Mon 04/13/2020 | to | Tue 04/14/2020 | | | | (Import) |
| 0001 | Continuous | 0200 | | | | |
| Work scheduled by: ConEd | | | | | UPNY CONED | 4000 MW |
| | | | | | Impacts Total Transfer Capability | 1700 MW |
| | | | | | TTC with All Lines In Service | 5700 MW |
| FRASER_-GILBOA__345_GF5-35 | | | | | FWD | |
| Mon 04/13/2020 | to | Wed 04/22/2020 | | | | (Import) |
| 0700 | Continuous | 1730 | | | | |
| Work scheduled by: NYPA | | | | | CENTRAL EAST - VC | 2650 MW |
| | | | | | Impacts Total Transfer Capability | 325 MW |
| | | | | | TTC with All Lines In Service | 2975 MW |

NYISO TRANSFER LIMITATIONS

Saturday ,November 02, 2019 to Monday ,May 03, 2021

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5700MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-ROCHESTR_345_NR2

FWD

Mon 04/20/2020 to Fri 05/01/2020

(Import)

0500 Continuous 1700

DYSINGER EAST **1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

ROCHESTR-PANNELL_345_RP1

FWD

Mon 04/20/2020 to Fri 04/24/2020

(Import)

0700 Continuous 1530

DYSINGER EAST **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

DOLSONAV-ROCKTVRN_345_DART44

FWD

Mon 04/27/2020 to Sun 05/10/2020

(Import)

0700 Continuous 1730

UPDATED by NYPA 03/21/2019CENTRAL EAST - VC **2720 MW**

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

LEEDS_-HURLYAVE_345_301

FWD

Mon 04/27/2020 to Fri 05/29/2020

(Import)

0800 Continuous 1600

UPNY CONED **4100 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: CHGE

SCH-IMO-NYISO_LIMIT_1600

FWD

Fri 05/01/2020 to Sat 10/31/2020

(Import)

0001 Continuous 2359

UPDATED by IESO 05/03/2019SCH - OH - NY **1900 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 1900 MW

Work scheduled by: IESO

PANNELL_-CLAY_345_2

FWD

Mon 05/04/2020 to Fri 05/08/2020

(Import)

0700 Continuous 1530

WEST CENTRAL **1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

NEPTUNE_-DUFFYAVE_345_NEPTUNE

FWD

Mon 05/04/2020 to Mon 05/18/2020

(Import)

0800 Continuous 1700

SCH - PJM_NEPTUNE **0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: PJM

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5700MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501

FWD

Mon 05/04/2020 to Mon 05/18/2020

(Import)

0800 Continuous 1700

Work scheduled by: PJM

SCH - PJM_NEPTUNE

0 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

FWD

Mon 05/04/2020 to Mon 05/18/2020

(Import)

0800 Continuous 1700

Work scheduled by: PJM

SCH - PJM_NEPTUNE

375 MW

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

FWD

Mon 05/04/2020 to Mon 05/18/2020

(Import)

0800 Continuous 1700

Work scheduled by: PJM

SCH - PJM_NEPTUNE

375 MW

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

PANNELL_-CLAY_345_1

FWD

Mon 05/11/2020 to Fri 05/15/2020

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL

1300 MW

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

COOPERS_-DOLSONAV_345_CCDA42

FWD

Mon 05/11/2020 to Fri 05/29/2020

(Import)

0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 03/21/2019

CENTRAL EAST - VC

2720 MW

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

KINTIGH_-ROCHESTR_345_SR1-39

FWD

Mon 05/18/2020 to Fri 05/22/2020

(Import)

0500 Continuous 1530

Work scheduled by: NYPA

DYSINGER EAST

1400 MW

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

NIAGARA_-ROCHESTR_345_NR2

FWD

Mon 05/18/2020 to Fri 05/22/2020

(Import)

0500 Continuous 1530

Work scheduled by: NYPA

CANCELLED by NYPA 10/29/2019

DYSINGER EAST

1400 MW

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,November 02, 2019 to Monday ,May 03, 2021

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5700MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

FWD

Mon 06/01/2020 to Fri 07/31/2020

(Import)

0700 Continuous 1730

MOSES SOUTH

2100 MW

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

NIAGARA_345_230_AT4

REV

Mon 06/29/2020 to Tue 06/30/2020

(Export)

0500 Continuous 1530

SCH - OH - NY

1400 MW

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 1700 MW

Work scheduled by: NYPA

SCH-IMO-NYISO_NIAG_CB_3008_W/BB

FWD

REV

Mon 07/27/2020 to Fri 08/07/2020

(Import) (Export)

0500 Continuous 1530

SCH - OH - NY

1900 MW 1450 MW

Impacts Total Transfer Capability 0 MW 250 MW

TTC with All Lines In Service 1900 MW 1700 MW

Work scheduled by: NYPA

CHATGUAY-MASSENA_765_7040

FWD

Sat 08/01/2020 to Sun 08/02/2020

(Import)

0500 Continuous 1730

UPDATEDby NYPA08/08/2019

MOSES SOUTH

1550 MW

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

CHATGUAY-MASSENA_765_7040

FWD

REV

Sat 08/01/2020 to Sun 08/02/2020

(Import) (Export)

0500 Continuous 1730

UPDATEDby NYPA08/08/2019

SCH - HQ - NY

0 MW

0 MW

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by: NYPA

MARCY___765_345_AT1

FWD

Sat 08/01/2020 to Sun 08/02/2020

(Import)

0500 Continuous 1730

UPDATEDby NYPA08/08/2019

MOSES SOUTH

1750 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

ARR: 19

MASSENA_-MARCY___765_MSU1

FWD

Sat 08/01/2020 to Sun 08/02/2020

(Import)

0500 Continuous 1730

UPDATEDby NYPA08/08/2019

CENTRAL EAST - VC

2265 MW

Impacts Total Transfer Capability 710 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

NYISO TRANSFER LIMITATIONS

Saturday ,November 02, 2019 to Monday ,May 03, 2021

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5700MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | | | | | |
|--|------------|----------------|----------------|----------------|-------------------|-----------------------------------|-----------------|----------------|--|--|
| MASSENA_-MARCY____765_MSU1 | | | | | | FWD | | | | |
| Sat 08/01/2020 | to | Sun 08/02/2020 | <u>UPDATED</u> | <u>by NYPA</u> | <u>08/08/2019</u> | (Import) | | | | |
| 0500 | Continuous | 1730 | | | | MOSES SOUTH | 500 MW | | | |
| Work scheduled by: NYPA | | | | | | Impacts Total Transfer Capability | 2650 MW | | | |
| | | | | | | TTC with All Lines In Service | 3150 MW | | | |
| MASSENA_-MARCY____765_MSU1 | | | | | | FWD | REV | | | |
| Sat 08/01/2020 | to | Sun 08/02/2020 | <u>UPDATED</u> | <u>by NYPA</u> | <u>08/08/2019</u> | (Import) | (Export) | | | |
| 0500 | Continuous | 1730 | | | | SCH - HQ - NY | 475 MW | 1000 MW | | |
| Work scheduled by: NYPA | | | | | | Impacts Total Transfer Capability | 1025 MW 0 MW | | | |
| | | | | | | TTC with All Lines In Service | 1500 MW 1000 MW | | | |
| MASSENA_-MARCY____765_MSU1 | | | | | | FWD | | | | |
| Sat 08/01/2020 | to | Sun 08/02/2020 | <u>UPDATED</u> | <u>by NYPA</u> | <u>08/08/2019</u> | (Import) | | | | |
| 0500 | Continuous | 1730 | | | | SCH - HQ_CEDARS | 90 MW | | | |
| Work scheduled by: NYPA | | | | | | Impacts Total Transfer Capability | 100 MW | | | |
| | | | | | | TTC with All Lines In Service | 190 MW | | | |
| MASSENA_-MARCY____765_MSU1 & CHATGUAY-MASSENA____765_7040 | | | | | | FWD | | | | |
| Sat 08/01/2020 | to | Sun 08/02/2020 | | | | (Import) | | | | |
| 0500 | | 1730 | | | | MOSES SOUTH | 500 MW | | | |
| Work scheduled by: | | | | | | Impacts Total Transfer Capability | 2650 MW | | | |
| | | | | | | TTC with All Lines In Service | 3150 MW | | | |
| MOSES____-MASSENA____230_MMS1 & MOSES____-MASSENA____230_MMS2 | | | | | | FWD | REV | | | |
| Sat 08/01/2020 | to | Sun 08/02/2020 | | | | (Import) | (Export) | | | |
| 0500 | | 1730 | | | | SCH - HQ - NY | 850 MW | 0 MW | | |
| Work scheduled by: | | | | | | Impacts Total Transfer Capability | 650 MW 1000 MW | | | |
| | | | | | | TTC with All Lines In Service | 1500 MW 1000 MW | | | |
| MOSES____-MASSENA____230_MMS1 & MOSES____-MASSENA____230_MMS2 | | | | | | FWD | | | | |
| Sat 08/01/2020 | to | Sun 08/02/2020 | | | | (Import) | | | | |
| 0500 | | 1730 | | | | SCH - HQ_CEDARS | 90 MW | | | |
| Work scheduled by: | | | | | | Impacts Total Transfer Capability | 100 MW | | | |
| | | | | | | TTC with All Lines In Service | 190 MW | | | |
| STLAWRNC-MOSES____230_L33P & MASSENA_-MARCY____765_MSU1 | | | | | | FWD | | | | |
| Sat 08/01/2020 | to | Sun 08/02/2020 | | | | (Import) | | | | |
| 0500 | | 1730 | | | | SCH - HQ_CEDARS | 90 MW | | | |
| Work scheduled by: | | | | | | Impacts Total Transfer Capability | 100 MW | | | |
| | | | | | | TTC with All Lines In Service | 190 MW | | | |

NYISO TRANSFER LIMITATIONS

Saturday ,November 02, 2019 to Monday ,May 03, 2021

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5700MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES___230_L33P & MOSES___-MASSENA_230_MMS1 & MOSES___-
MASSENA_230_MMS2

Sat 08/01/2020 to Sun 08/02/2020
0500 1730

Work scheduled by:

SCH - HQ_CEDARS **90 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 190 MW

MOSES___-ADIRNDCK_230_MA2

Mon 08/03/2020 to Sun 09/13/2020
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

FRASANNX-COOPERS___345_UCC2-41

Mon 09/07/2020 to Fri 10/23/2020
0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 03/01/2019
ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY___-FRASANNX_345_UCC2-41

Mon 09/07/2020 to Fri 10/23/2020
0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 03/01/2019
ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY___765_345_AT1

Mon 09/14/2020 to Mon 09/14/2020
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1750 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH___345_NS1-38

Mon 09/14/2020 to Thu 09/17/2020
0500 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Tue 09/15/2020 to Sat 11/14/2020
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,November 02, 2019 to Monday ,May 03, 2021

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5700MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-ROCHESTR_345_NR2

FWD

Fri 09/18/2020 to Sat 11/14/2020
0500 Continuous 2330

Work scheduled by: NYPA

(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

CLAY_-EDIC_345_1-16

FWD

Mon 09/21/2020 to Fri 09/25/2020
0700 Continuous 1530

Work scheduled by: NYPA

(Import)
OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

ROSETON_-ROCKTVRN_345_311

FWD

Mon 09/21/2020 to Fri 10/23/2020 UPDATED by CHGE 10/09/2019
0800 Continuous 1600

Work scheduled by: CHGE

(Import)
UPNY CONED **4400 MW**
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5700 MW

DUNWODIE_345KV_3

FWD

Fri 09/25/2020 to Fri 09/25/2020 UPDATED by CONED 09/05/2019
0001 Continuous 0030

Work scheduled by: ConEd

(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

FWD

Fri 09/25/2020 to Fri 09/25/2020 UPDATED by CONED 09/05/2019
0001 Continuous 0030

Work scheduled by: ConEd

(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE-MOTTHAVN_345_71

FWD

Fri 09/25/2020 to Fri 10/30/2020 UPDATED by CONED 09/05/2019
0001 Continuous 0300

Work scheduled by: ConEd

(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

CLAY_-EDIC_345_2-15

FWD

Mon 09/28/2020 to Fri 10/02/2020
0700 Continuous 1530

Work scheduled by: NYPA

(Import)
OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Saturday ,November 02, 2019 to Monday ,May 03, 2021

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5700MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HURLYAVE-ROSETON__345_303

Mon 10/26/2020 to Fri 12/04/2020
0800 Continuous 1600

UPDATED by CHGE 10/09/2019

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 5700 MW

DUNWODIE_345KV_3

Fri 10/30/2020 to Fri 10/30/2020
0230 Continuous 0300

UPDATED by CONED 09/05/2019

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

Fri 10/30/2020 to Fri 10/30/2020
0230 Continuous 0300

UPDATED by CONED 09/05/2019

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

SCH-IMO-NYISO_LIMIT_1750

Sun 11/01/2020 to Fri 04/30/2021
0001 Continuous 2359

UPDATED by IESO 05/03/2019

Work scheduled by: IESO

FWD
(Import)
SCH - OH - NY **2050 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 2050 MW

SCH-NYISO-IMO_LIMIT_1600

Sun 11/01/2020 to Fri 04/30/2021
0001 Continuous 2359

UPDATED by IESO 05/03/2019

Work scheduled by: IESO

REV
(Export)
SCH - OH - NY **1900 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 1900 MW

CHATGUAY-MASSENA__765_7040

Sun 11/15/2020 to Mon 11/30/2020
0100 Continuous 1900

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **1550 MW**
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA__765_7040

Sun 11/15/2020 to Mon 11/30/2020
0100 Continuous 1900

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - HQ - NY **0 MW 0 MW**
Impacts Total Transfer Capability 1500 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Saturday ,November 02, 2019 to Monday ,May 03, 2021

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5700MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY____765_345_AT1

FWD

Sun 11/15/2020 to Mon 11/30/2020

(Import)

0100 Continuous 1900

MOSES SOUTH

1750 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

ARR: 19**MARCY____765_345_AT2**

FWD

Sun 11/15/2020 to Mon 11/30/2020

(Import)

0100 Continuous 1900

MOSES SOUTH

1700 MW

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

ARR: 19**MASSENA_-MARCY____765_MSU1**

FWD

Sun 11/15/2020 to Mon 11/30/2020

(Import)

0100 Continuous 1900

CENTRAL EAST - VC

2265 MW

Impacts Total Transfer Capability 710 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

MASSENA_-MARCY____765_MSU1

FWD

Sun 11/15/2020 to Mon 11/30/2020

(Import)

0100 Continuous 1900

MOSES SOUTH

500 MW

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

MASSENA_-MARCY____765_MSU1

FWD

REV

Sun 11/15/2020 to Mon 11/30/2020

(Import) (Export)

0100 Continuous 1900

SCH - HQ - NY

475 MW 1000 MW

Impacts Total Transfer Capability 1025 MW 0 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by: NYPA

MASSENA_-MARCY____765_MSU1

FWD

Sun 11/15/2020 to Mon 11/30/2020

(Import)

0100 Continuous 1900

SCH - HQ_CEDARS

90 MW

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

Work scheduled by: NYPA

MASSENA_-MARCY____765_MSU1 & CHATGUAY-MASSENA_765_7040

FWD

Sun 11/15/2020 to Mon 11/30/2020

(Import)

0100 Continuous 1900

MOSES SOUTH

500 MW

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

Work scheduled by:

NYISO TRANSFER LIMITATIONS

Saturday ,November 02, 2019 to Monday ,May 03, 2021

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5700MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Sun 11/15/2020 to Mon 11/30/2020
 0100 1900

Work scheduled by:

FWD REV
 (Import) (Export)
 SCH - HQ - NY **850 MW 0 MW**
 Impacts Total Transfer Capability 650 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Sun 11/15/2020 to Mon 11/30/2020
 0100 1900

Work scheduled by:

FWD
 (Import)
 SCH - HQ_CEDARS **90 MW**
 Impacts Total Transfer Capability 109 MW
 TTC with All Lines In Service 199 MW

STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1

Sun 11/15/2020 to Mon 11/30/2020
 0100 1900

Work scheduled by:

FWD
 (Import)
 SCH - HQ_CEDARS **90 MW**
 Impacts Total Transfer Capability 109 MW
 TTC with All Lines In Service 199 MW

STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -
 MASSENA 230_MMS2

Sun 11/15/2020 to Mon 11/30/2020
 0100 1900

Work scheduled by:

FWD
 (Import)
 SCH - HQ_CEDARS **90 MW**
 Impacts Total Transfer Capability 109 MW
 TTC with All Lines In Service 199 MW

PLSNTVLE-DUNWODIE_345_W89

Mon 11/16/2020 to Mon 11/16/2020
 0001 Continuous 0030

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

PLSNTVLE-DUNWODIE_345_W89

Thu 11/26/2020 to Thu 11/26/2020
 0230 Continuous 0300

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

MOSES -ADIRNDCK 230_MAI

Tue 12/01/2020 to Mon 05/31/2021
 0700 Continuous 1300

Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5700MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOTTHAVN-RAINEY___345_Q11

FWD

Mon 03/01/2021 to Tue 04/06/2021

(Import)

0001 Continuous 0700

SPR/DUN-SOUTH

3800 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

CLAY___-EDIC___345_2-15

FWD

Mon 03/29/2021 to Fri 04/16/2021

(Import)

0800 Continuous 1730

OSWEGO EXPORT

4850 MW

Work scheduled by: NYPA

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

SCH-IMO-NYISO_LIMIT_1600

FWD

Sat 05/01/2021 to Sun 10/31/2021

(Import)

0001 Continuous 2359

UPDATEDby IESO05/03/2021

Work scheduled by: IESO

SCH - OH - NY

1900 MW

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 1900 MW

PANNELL_-CLAY___345_2

FWD

Mon 05/03/2021 to Fri 05/28/2021

(Import)

0700 Continuous 1730

WEST CENTRAL

1300 MW

Work scheduled by: NYPA

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW