

# NYISO TRANSFER LIMITATIONS

Wednesday, December 18, 2019 to Friday , June 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HUDSONP\_-FARRAGUT\_345\_B3402

 Mon 01/15/2018 to Fri 05/01/2020 EXTENDED by CONED 10/08/2019

0001 Continuous 2359

Work scheduled by: ConEd

 SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

## HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Fri 05/01/2020

0001 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2550 MW</b>	<b>1600 MW</b>
Impacts Total Transfer Capability	350 MW	250 MW
TTC with All Lines In Service	2900 MW	1850 MW

## MARION\_-FARRAGUT\_345\_C3403

 Mon 01/15/2018 to Fri 05/01/2020 EXTENDED by CONED 10/08/2019

0001 Continuous 2359

Work scheduled by: ConEd

 SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

## STLAWRNC-MOSES\_230\_L33P

 Mon 04/30/2018 to Fri 12/31/2021 EXT FORCE by IESO 08/21/2018

0456 Continuous 2359

Work scheduled by: IESO

 SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

## NIAGARA\_345\_230\_AT4

 Wed 10/23/2019 to Mon 12/16/2019 UPDATED by NYPA 09/10/2019

0500 Continuous 1422

Work scheduled by: NYPA

	REV
	(Export)
SCH - OH - NY	<b>1750 MW</b>
Impacts Total Transfer Capability	150 MW
TTC with All Lines In Service	1900 MW

## SCH-IMO-NYISO\_LIMIT\_1750

 Fri 11/01/2019 to Thu 04/30/2020 UPDATED by IESO 05/03/2019

0001 Continuous 2359

Work scheduled by: IESO

	FWD
	(Import)
SCH - OH - NY	<b>2050 MW</b>
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	2050 MW

## SCH-NYISO-IMO\_LIMIT\_1600

 Fri 11/01/2019 to Thu 04/30/2020 UPDATED by IESO 05/03/2019

0001 Continuous 2359

Work scheduled by: IESO

	REV
	(Export)
SCH - OH - NY	<b>1900 MW</b>
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	1900 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 18, 2019 to Friday, June 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NYISO-NE_LIMIT_1500</b>						REV
Fri 11/01/2019	to	Thu 04/30/2020				(Export)
0001	Continuous	2359			SCH - NE - NY	<b>1700 MW</b>
Work scheduled by: NYISO						Impacts Total Transfer Capability 0 MW
						TTC with All Lines In Service 1700 MW
<b>SCH-IMO-NYISO_LIMIT_1400</b>						FWD
Tue 11/12/2019	to	Mon 12/16/2019	<b><u>EXTENDED</u></b>	<b><u>by IESO</u></b>	<b><u>11/27/2019</u></b>	(Import)
0501	Continuous	1427			SCH - OH - NY	<b>1700 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability 350 MW
						TTC with All Lines In Service 2050 MW
<b>SCH-NYISO-IMO_LIMIT_1400</b>						REV
Tue 11/12/2019	to	Mon 12/16/2019	<b><u>EXTENDED</u></b>	<b><u>by IESO</u></b>	<b><u>11/27/2019</u></b>	(Export)
0501	Continuous	1428			SCH - OH - NY	<b>1700 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability 200 MW
						TTC with All Lines In Service 1900 MW
<b>OSWEGO_COMPLEX_AVR_O/S</b>						FWD
Mon 11/18/2019	to	Tue 12/31/2019	<b><u>EXT FORCE</u></b>	<b><u>by GEN</u></b>	<b><u>12/13/2019</u></b>	(Import)
0221	Continuous	2359			CENTRAL EAST - VC	<b>2870 MW</b>
Work scheduled by: Gen						Impacts Total Transfer Capability 105 MW
						TTC with All Lines In Service 2975 MW
<b>DUNWODIE_345KV_6</b>						FWD
Tue 12/03/2019	to	Tue 12/31/2019	<b><u>FORCED</u></b>	<b><u>by CONED</u></b>	<b><u>12/03/2019</u></b>	(Import)
0048	Continuous	2359			SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<b>DUNWODIE_345KV_8</b>						FWD
Tue 12/03/2019	to	Tue 12/31/2019	<b><u>FORCED</u></b>	<b><u>by CONED</u></b>	<b><u>12/03/2019</u></b>	(Import)
0048	Continuous	2359			SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<b>PLSNTVLE-DUNWODIE_345_W90</b>						FWD
Tue 12/03/2019	to	Tue 12/31/2019	<b><u>FORCED</u></b>	<b><u>by CONED</u></b>	<b><u>12/03/2019</u></b>	(Import)
0107	Continuous	2359			UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 1700 MW
						TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 18, 2019 to Friday, June 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NE-NYISO_LIMIT_500</b>					FWD	
Tue 12/03/2019	to	Sun 12/22/2019	<u>EXTENDED</u>	<u>by ISONE</u>	<u>12/18/2019</u>	(Import)
0700	Continuous	1600				<b>700 MW</b>
Work scheduled by: ISONE					SCH - NE - NY	Impacts Total Transfer Capability
					TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_1200</b>					REV	
Tue 12/03/2019	to	Sun 12/22/2019	<u>EXTENDED</u>	<u>by ISONE</u>	<u>12/18/2019</u>	(Export)
0700	Continuous	1600				<b>1400 MW</b>
Work scheduled by: ISONE					SCH - NE - NY	Impacts Total Transfer Capability
					TTC with All Lines In Service	1700 MW
<b>W49TH_ST_345KV_7</b>					FWD	
Mon 12/09/2019	to	Sat 12/14/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>12/11/2019</u>	(Import)
0001	Continuous	0200				<b>315 MW</b>
Work scheduled by: ConEd					SCH - PJM_HTP	Impacts Total Transfer Capability
					TTC with All Lines In Service	660 MW
<b>MOSES__-ADIRNDCK_230_MA1</b>					FWD	
Mon 12/09/2019	to	Fri 12/13/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>12/03/2019</u>	(Import)
0700	Continuous	1530				<b>2300 MW</b>
Work scheduled by: NYPA					MOSES SOUTH	Impacts Total Transfer Capability
					TTC with All Lines In Service	3150 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>					FWD REV	
Thu 12/12/2019	to	Fri 12/20/2019				(Import) (Export)
0700	Continuous	1500				<b>0 MW 0 MW</b>
Work scheduled by: ISONE					SCH - NPX_CSC	Impacts Total Transfer Capability
					TTC with All Lines In Service	330 MW 330 MW
<b>SCH-IMO-NYISO_LIMIT_950</b>					FWD	
Thu 12/12/2019	to	Fri 12/13/2019				(Import)
2001	Continuous	1900				<b>1250 MW</b>
Work scheduled by: NYPA					SCH - OH - NY	Impacts Total Transfer Capability
					TTC with All Lines In Service	2050 MW
<b>PIERCBRK-FIVEMILE_345_37</b>					FWD	
Fri 12/13/2019	to	Fri 12/13/2019	<u>UPDATED</u>	<u>by NGRID</u>	<u>12/05/2019</u>	(Import)
0800	Daily(No Weekends)	1530				<b>2400 MW</b>
Work scheduled by: NGrid					SCH - PJ - NY	Impacts Total Transfer Capability
					TTC with All Lines In Service	2900 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, December 18, 2019 to Friday, June 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-IMO-NYISO\_LIMIT\_300**

FWD

Sat 12/14/2019 to Sun 12/15/2019 **UPDATED by IESO 12/10/2019**

(Import)

0500 Continuous 1900

Work scheduled by: NYPA

SCH - OH - NY

**600 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 2050 MW

**DUNWODIE-MOTTHAVN\_345\_72**

FWD

Sat 12/14/2019 to Mon 12/16/2019

(Import)

1256 Continuous 2359

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**WATRCURE-OAKDALE\_345\_31**

FWD

Sun 12/15/2019 to Sat 12/21/2019 **UPDATED by NYSEG 12/11/2019**

(Import)

0800 Continuous 1700

Work scheduled by: NYSEG

SCH - PJ - NY

**2750 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 2900 MW

**CHAT\_DC\_GC2**

FWD

Mon 12/16/2019 to Mon 12/16/2019 **CANCELLED by HQ 12/16/2019**

(Import)

0001 Continuous 0200

Work scheduled by: HQ

MOSES SOUTH

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC2**

REV

Mon 12/16/2019 to Mon 12/16/2019 **CANCELLED by HQ 12/16/2019**

(Export)

0001 Continuous 0200

Work scheduled by: HQ

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

**EDIC -FRASER\_345\_EF24-40**

FWD

Mon 12/16/2019 to Tue 12/17/2019

(Import)

0700 Continuous 1730

Work scheduled by: NYPA

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

**S.RIPLEY-DUNKIRK\_230\_68**Mon 12/16/2019 to Fri 12/20/2019 **UPDATED by PJM 11/13/2019**

0900 Continuous 1500

Work scheduled by: PJM

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Wednesday, December 18, 2019 to Friday, June 18, 2021

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Tue 12/17/2019 to Tue 12/17/2019  
0400 Continuous 0600  
Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

### NEWBRIDGE-DUFFYAVE\_345\_501

Tue 12/17/2019 to Tue 12/17/2019  
0400 Continuous 0600  
Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

### PIERCEBRK-FIVEMILE\_345\_37

Tue 12/17/2019 to Thu 12/19/2019  
0730 Continuous 1630  
Work scheduled by: NGrid

FWD  
(Import)  
SCH - PJ - NY **2400 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 2900 MW

### W49TH\_ST-E13THSTA\_345\_M54

Thu 12/19/2019 to Fri 12/20/2019 **UPDATED by CE 12/18/2019**  
0001 Continuous 0100  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### LINDEN\_-GOETHALS\_230\_A2253

Sat 12/28/2019 to Sun 12/29/2019 **CANCELLED by ConEd 12/13/2019**  
0001 Continuous 0300  
Work scheduled by: ConEd

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### WATRCURE-OAKDALE\_345\_31

Mon 01/06/2020 to Mon 01/06/2020  
0800 Continuous 0830  
Work scheduled by: NYSEG

FWD  
(Import)  
SCH - PJ - NY **2750 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 2900 MW

### S.RIPLEY-DUNKIRK\_230\_68

Mon 01/06/2020 to Fri 01/10/2020  
0800 Continuous 1600  
Work scheduled by: NGrid

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Wednesday, December 18, 2019 to Friday, June 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>FROST_BR-LONG_MTN_345_352</b>					FWD	
Tue 01/07/2020	to	Fri 01/10/2020	<u>UPDATED</u>	<u>by ISONE</u> <u>12/16/2019</u>	(Import)	
0700	Continuous	1600			SCH - NE - NY	<b>1300 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1400 MW
<b>SCH-NE-NYISO_LIMIT_800</b>					FWD	
Tue 01/07/2020	to	Fri 01/10/2020	<u>UPDATED</u>	<u>by ISONE</u> <u>12/16/2019</u>	(Import)	
0700	Continuous	1600			SCH - NE - NY	<b>1000 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	1400 MW
<b>OSWEGO__-VOLNEY__345_12</b>					FWD	
Wed 01/08/2020	to	Wed 01/08/2020			(Import)	
0830	Daily(No Weekends)	1130			OSWEGO EXPORT	<b>5250 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	5250 MW
<b>BECK____-NIAGARA__345_PA301</b>					FWD	REV
Mon 01/13/2020	to	Fri 01/17/2020			(Import)	(Export)
0500	Continuous	1530			SCH - OH - NY	<b>1100 MW 950 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	950 MW 950 MW
					TTC with All Lines In Service	2050 MW 1900 MW
<b>FRASER__345_FRASER SVC</b>					FWD	
Mon 01/13/2020	to	Mon 01/27/2020	<u>UPDATED</u>	<u>by NYSEG</u> <u>12/18/2019</u>	(Import)	
0800	Continuous	1500			CENTRAL EAST - VC	<b>2935 MW</b>
Work scheduled by: NYSEG					Impacts Total Transfer Capability	40 MW
					TTC with All Lines In Service	2975 MW
<b>FROST_BR-LONG_MTN_345_352</b>					FWD	
Mon 01/20/2020	to	Thu 01/23/2020	<u>UPDATED</u>	<u>by ISONE</u> <u>12/16/2019</u>	(Import)	
0700	Continuous	1600			SCH - NE - NY	<b>1300 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1400 MW
<b>SCH-NE-NYISO_LIMIT_800</b>					FWD	
Mon 01/20/2020	to	Thu 01/23/2020	<u>UPDATED</u>	<u>by ISONE</u> <u>12/16/2019</u>	(Import)	
0700	Continuous	1600			SCH - NE - NY	<b>1000 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	1400 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 18, 2019 to Friday, June 18, 2021

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBRK__TREMONT__345_X28</b>				FWD	
Mon 02/17/2020	to	Mon 02/17/2020	<u>UPDATED</u> <u>by CONED</u> <u>12/05/2019</u>	(Import)	
0001	Continuous	1800		SPR/DUN-SOUTH	<b>4200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	4600 MW
<b>WATRCURE-OAKDALE__345_31</b>				FWD	
Mon 02/17/2020	to	Mon 02/17/2020		(Import)	
1500	Continuous	1530		SCH - PJ - NY	<b>2750 MW</b>
Work scheduled by: NYSEG				Impacts Total Transfer Capability	150 MW
				TTC with All Lines In Service	2900 MW
<b>SPRNBRK__345KV_RNS5</b>				FWD	
Mon 02/24/2020	to	Mon 02/24/2020		(Import)	
0001	Continuous	0030		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<b>SPRNBRK__W49TH_ST_345_M51</b>				FWD	
Mon 02/24/2020	to	Sun 03/01/2020		(Import)	
0001	Continuous	0200		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<b>SPRNBRK__345KV_RNS5</b>				FWD	
Wed 02/26/2020	to	Wed 02/26/2020		(Import)	
2130	Continuous	2200		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<b>SPRNBRK__345KV_RNS5</b>				FWD	
Thu 02/27/2020	to	Sun 03/01/2020		(Import)	
2301	Continuous	0200		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<b>NIAGARA__PACKARD__230_62</b>				FWD	REV
Fri 02/28/2020	to	Fri 02/28/2020		(Import)	(Export)
0500	Continuous	1530		SCH - OH - NY	<b>900 MW 1850 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1150 MW 50 MW
				TTC with All Lines In Service	2050 MW 1900 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, December 18, 2019 to Friday, June 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_4**

Sun 03/01/2020 to Sun 03/08/2020

0001 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**CHATGUAY-MASSENA\_765\_7040**

Mon 03/02/2020 to Fri 03/06/2020

0500 Continuous 1730

Work scheduled by: NYPA

UPDATEDby NYPA08/08/2019

FWD

(Import)

MOSES SOUTH

**1550 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

**CHATGUAY-MASSENA\_765\_7040**

Mon 03/02/2020 to Fri 03/06/2020

0500 Continuous 1730

Work scheduled by: NYPA

UPDATEDby NYPA08/08/2019

FWD

(Import) (Export)

SCH - HQ - NY

**0 MW****0 MW**

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

**MARCY\_765\_345\_AT1**

Mon 03/02/2020 to Fri 03/06/2020

0500 Continuous 1730

Work scheduled by: NYPA

UPDATEDby NYPA08/08/2019

FWD

(Import)

MOSES SOUTH

**1750 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

**ARR: 19****MARCY\_765\_345\_AT2**

Mon 03/02/2020 to Fri 03/06/2020

0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

**ARR: 19****MASSENA\_-MARCY\_765\_MSU1**

Mon 03/02/2020 to Fri 03/06/2020

0500 Continuous 1730

Work scheduled by: NYPA

UPDATEDby NYPA08/08/2019

FWD

(Import)

CENTRAL EAST - VC

**2265 MW**

Impacts Total Transfer Capability 710 MW

TTC with All Lines In Service 2975 MW

**MASSENA\_-MARCY\_765\_MSU1**

Mon 03/02/2020 to Fri 03/06/2020

0500 Continuous 1730

Work scheduled by: NYPA

UPDATEDby NYPA08/08/2019

FWD

(Import)

MOSES SOUTH

**500 MW**

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW



# NYISO TRANSFER LIMITATIONS

Wednesday, December 18, 2019 to Friday, June 18, 2021

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY_765_MSU1						FWD	REV
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	(Export)
0500	Continuous	1730				475 MW	1000 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW 0 MW
						TTC with All Lines In Service	1500 MW 1000 MW
MASSENA_-MARCY_765_MSU1						FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	
0500	Continuous	1730				90 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	109 MW
						TTC with All Lines In Service	199 MW
MASSENA_-MARCY_765_MSU1 & CHATGUAY-MASSENA_765_7040						FWD	
Mon 03/02/2020	to	Fri 03/06/2020				(Import)	
0500		1730				500 MW	
Work scheduled by:						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2						FWD	REV
Mon 03/02/2020	to	Fri 03/06/2020				(Import)	(Export)
0500		1730				850 MW	0 MW
Work scheduled by:						Impacts Total Transfer Capability	650 MW 1000 MW
						TTC with All Lines In Service	1500 MW 1000 MW
MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2						FWD	
Mon 03/02/2020	to	Fri 03/06/2020				(Import)	
0500		1730				90 MW	
Work scheduled by:						Impacts Total Transfer Capability	109 MW
						TTC with All Lines In Service	199 MW
STLAWRNC-MOSES_230_L33P & MASSENA_-MARCY_765_MSU1						FWD	
Mon 03/02/2020	to	Fri 03/06/2020				(Import)	
0500		1730				90 MW	
Work scheduled by:						Impacts Total Transfer Capability	109 MW
						TTC with All Lines In Service	199 MW
STLAWRNC-MOSES_230_L33P & MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2						FWD	
Mon 03/02/2020	to	Fri 03/06/2020				(Import)	
0500		1730				90 MW	
Work scheduled by:						Impacts Total Transfer Capability	109 MW
						TTC with All Lines In Service	199 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 18, 2019 to Friday, June 18, 2021

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHOR_NPX-SHOREHAM_138_CSC				FWD	REV
				(Import)	(Export)
Mon 03/02/2020	to	Tue 03/03/2020		SCH - NPX_CSC	<b>0 MW</b>
0600	Continuous	1300		Impacts Total Transfer Capability	330 MW
Work scheduled by: LI				TTC with All Lines In Service	330 MW
ROSETON_EFISHKIL_345_RFK305				FWD	
				(Import)	
Mon 03/02/2020	to	Fri 03/20/2020		UPNY CONED	<b>4800 MW</b>
0700	Continuous	1730		Impacts Total Transfer Capability	900 MW
Work scheduled by: NYPA				TTC with All Lines In Service	5700 MW
EASTVIEW-SPRNBK_345_W78				FWD	
				(Import)	
Fri 03/06/2020	to	Sat 03/07/2020		UPNY CONED	<b>4350 MW</b>
0001	Continuous	0200		Impacts Total Transfer Capability	1350 MW
Work scheduled by: ConEd				TTC with All Lines In Service	5700 MW
MILLWOOD-EASTVIEW_345_W85				FWD	
				(Import)	
Fri 03/06/2020	to	Sat 03/07/2020		UPNY CONED	<b>4350 MW</b>
0001	Continuous	0200		Impacts Total Transfer Capability	1350 MW
Work scheduled by: ConEd				TTC with All Lines In Service	5700 MW
SPRNBK_345KV_RNS3				FWD	
				(Import)	
Fri 03/06/2020	to	Sat 03/07/2020		SPR/DUN-SOUTH	<b>3800 MW</b>
0001	Continuous	0200		Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW
MOSES_-ADIRNDCK_230_MA1				FWD	
				(Import)	
Sat 03/07/2020	to	Fri 05/29/2020		MOSES SOUTH	<b>2300 MW</b>
0700	Continuous	1300		Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW
VOLNEY_-MARCY_345_19				FWD	
				(Import)	
Tue 03/10/2020	to	Tue 03/10/2020	<b>UPDATED by NYPA 09/24/2019</b>	CENTRAL EAST - VC	<b>2825 MW</b>
0700	Continuous	1530		Impacts Total Transfer Capability	150 MW
Work scheduled by: NYPA				TTC with All Lines In Service	2975 MW
				<b>ARR: 19</b>	

**NYISO TRANSFER LIMITATIONS**

Wednesday, December 18, 2019 to Friday , June 18, 2021

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5700MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**VOLNEY\_\_ -MARCY\_\_ 345\_19**

FWD

Tue 03/10/2020 to Tue 03/10/2020  
 0700 Continuous 1530

UPDATEDby NYPA09/24/2019

(Import)

Work scheduled by: NYPA

**ARR: 19**

OSWEGO EXPORT

**4900 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 5250 MW

**ROCHESTR-PANNELL\_\_ 345\_RP2**

FWD

Sat 03/14/2020 to Mon 03/23/2020  
 0500 Continuous 1700

(Import)

Work scheduled by: NYPA

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

**MARCY\_\_ 345KV\_CSC**

FWD

Mon 03/16/2020 to Fri 03/27/2020  
 0500 Continuous 1730

(Import)

Work scheduled by: NYPA

CENTRAL EAST - VC

**2925 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

**EASTVIEW-SPRNBK\_\_ 345\_W64**

FWD

Sat 03/21/2020 to Sat 03/21/2020  
 0001 Continuous 0030

UPDATEDby CONED12/05/2019

(Import)

Work scheduled by: ConEd

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1350 MW

TTC with All Lines In Service 5700 MW

**SPRNBK\_\_ 345KV\_RNS5**

FWD

Sat 03/21/2020 to Sat 03/21/2020  
 0001 Continuous 0030

UPDATEDby CONED12/05/2019

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

**MILLWOOD-EASTVIEW\_345\_W99**

FWD

Sat 03/21/2020 to Sun 03/22/2020  
 0001 Continuous 0200

UPDATEDby CONED12/05/2019

(Import)

Work scheduled by: ConEd

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1350 MW

TTC with All Lines In Service 5700 MW

**EASTVIEW-SPRNBK\_\_ 345\_W64**

FWD

Sun 03/22/2020 to Sun 03/22/2020  
 0130 Continuous 0200

UPDATEDby CONED12/05/2019

(Import)

Work scheduled by: ConEd

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1350 MW

TTC with All Lines In Service 5700 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, December 18, 2019 to Friday, June 18, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK__345KV_RNS5</b>						FWD
Sun 03/22/2020	to	Sun 03/22/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>12/05/2019</u>	(Import)
0130	Continuous	0200				
Work scheduled by: ConEd						
<b>DUNWODIE-MOTTHAVN_345_72</b>						FWD
Sun 03/22/2020	to	Wed 03/25/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/18/2019</u>	(Import)
0201	Continuous	0200				
Work scheduled by: ConEd						
<b>DUNWODIE_345KV_8</b>						FWD
Sun 03/22/2020	to	Wed 03/25/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/18/2019</u>	(Import)
0201	Continuous	0200				
Work scheduled by: ConEd						
<b>DUNWODIE_345KV_5</b>						FWD
Sun 03/22/2020	to	Fri 05/08/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/18/2019</u>	(Import)
0201	Continuous	0300				
Work scheduled by: ConEd						
<b>DUNWODIE_345KV_7</b>						FWD
Sun 03/22/2020	to	Fri 05/08/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/18/2019</u>	(Import)
0201	Continuous	0300				
Work scheduled by: ConEd						
<b>SPRNBK_-DUNWODIE_345_W75</b>						FWD
Sun 03/22/2020	to	Fri 05/08/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/18/2019</u>	(Import)
0201	Continuous	0300				
Work scheduled by: ConEd						
<b>SPRNBK__345KV_RNS3</b>						FWD
Sun 03/22/2020	to	Fri 05/08/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/18/2019</u>	(Import)
0201	Continuous	0300				
Work scheduled by: ConEd						

SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 18, 2019 to Friday , June 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## DUNWODIE-MOTTHAVN\_345\_71

FWD

 Wed 03/25/2020 to Sat 03/28/2020 UPDATED by CE 12/18/2019

(Import)

0201 Continuous 0200

Work scheduled by: ConEd

 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

## DUNWODIE\_345KV\_3

FWD

 Wed 03/25/2020 to Sat 03/28/2020 UPDATED by CE 12/18/2019

(Import)

0201 Continuous 0200

Work scheduled by: ConEd

 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

## NIAGARA\_-KINTIGH\_345\_NS1-38

FWD

Fri 03/27/2020 to Fri 03/27/2020

(Import)

0600 Continuous 1530

Work scheduled by: NYPA

 DYSINGER EAST **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

## BECK\_-PACKARD\_230\_BP76

FWD

REV

Fri 03/27/2020 to Fri 03/27/2020

(Import) (Export)

0800 Daily(No Weekends) 1600

Work scheduled by: NGrid

 SCH - OH - NY **1650 MW 1400 MW**  
 Impacts Total Transfer Capability 400 MW 500 MW  
 TTC with All Lines In Service 2050 MW 1900 MW

## MILLWOOD-EASTVIEW\_345\_W85

FWD

 Sat 03/28/2020 to Sat 03/28/2020 UPDATED by CE 12/18/2019

(Import)

0201 Continuous 0231

Work scheduled by: ConEd

 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1350 MW  
 TTC with All Lines In Service 5700 MW

## EASTVIEW-SPRNBK\_345\_W78

FWD

 Sat 03/28/2020 to Tue 03/31/2020 UPDATED by CE 12/18/2019

(Import)

0201 Continuous 0200

Work scheduled by: ConEd

 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1350 MW  
 TTC with All Lines In Service 5700 MW

## MILLWOOD-EASTVIEW\_345\_W85

FWD

 Tue 03/31/2020 to Tue 03/31/2020 UPDATED by CE 12/18/2019

(Import)

0130 Continuous 0200

Work scheduled by: ConEd

 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1350 MW  
 TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 18, 2019 to Friday, June 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SPRNBK\_\_345KV\_RS3 & SPRNBK\_\_345KV\_RS4**

 Tue 03/31/2020 to Sat 04/04/2020  
 0201 0200

Work scheduled by:

 FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**MARCY\_\_-EDIC\_\_345\_UE1-7**

 Tue 03/31/2020 to Tue 03/31/2020  
 0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 09/24/2019

ARR: 19&amp;16

 FWD  
 (Import)  
 OSWEGO EXPORT **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

**RAMAPO\_\_-LADENTWN\_345\_W72**

 Wed 04/01/2020 to Thu 04/02/2020  
 0001 Continuous 1830

Work scheduled by: ConEd

 FWD  
 (Import)  
 UPNY CONED **4400 MW**  
 Impacts Total Transfer Capability 1300 MW  
 TTC with All Lines In Service 5700 MW

**FRASANNX-COOPERS\_\_345\_UCC2-41**

 Wed 04/01/2020 to Thu 04/02/2020  
 0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 11/12/2019

ARR: 19

 FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

**MARCY\_\_-FRASANNX\_345\_UCC2-41**

 Wed 04/01/2020 to Thu 04/02/2020  
 0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 11/12/2019

ARR: 19

 FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

**LINDN\_CG-LNDVFT\_\_345\_V-3022**

 Sun 04/05/2020 to Sat 04/11/2020  
 1400 Continuous 1400

Work scheduled by: PJM

 FWD REV  
 (Import) (Export)  
 SCH - PJM\_VFT **0 MW 0 MW**  
 Impacts Total Transfer Capability 315 MW 315 MW  
 TTC with All Lines In Service 315 MW 315 MW

**MARCY\_\_-N.SCTLND\_345\_18**

 Tue 04/07/2020 to Wed 04/08/2020  
 0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 09/24/2019

ARR: 19

 FWD  
 (Import)  
 CENTRAL EAST - VC **2090 MW**  
 Impacts Total Transfer Capability 885 MW  
 TTC with All Lines In Service 2975 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, December 18, 2019 to Friday, June 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLY-EFISHKIL\_345\_F36**

FWD

Mon 04/13/2020 to Tue 04/14/2020

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 04/13/2020 to Tue 04/14/2020

0600 Daily 1800

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**FRASER\_-GILBOA\_345\_GF5-35**

FWD

Mon 04/13/2020 to Wed 04/22/2020

(Import)

0700 Continuous 1730

Work scheduled by: NYPA

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

**NIAGARA\_-ROCHESTR\_345\_NR2**

FWD

Wed 04/15/2020 to Fri 05/01/2020

(Import)

0500 Continuous 1700

Work scheduled by: NYPA

DYSINGER EAST

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

**ROCHESTR-PANNELL\_345\_RP1**

FWD

Mon 04/20/2020 to Fri 04/24/2020

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

**DOLSONAV-ROCKTVRN\_345\_DART44**

FWD

Mon 04/27/2020 to Sun 05/10/2020

(Import)

0700 Continuous 1730

Work scheduled by: NYPA

UPDATEDby NYPA03/21/2019

CENTRAL EAST - VC

**2720 MW**

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

**HURLYAVE-ROSETON\_345\_303**

FWD

Mon 04/27/2020 to Fri 05/29/2020

(Import)

0800 Continuous 1600

Work scheduled by: CHGE

UPDATEDby CHGE10/09/2019

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 18, 2019 to Friday, June 18, 2021

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-IMO-NYISO\_LIMIT\_1600

Fri 05/01/2020 to Sat 10/31/2020 UPDATED by IESO 05/03/2019

0001 Continuous 2359

Work scheduled by: IESO

FWD  
(Import)  
SCH - OH - NY **1900 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 1900 MW

### PANNELL -CLAY\_345\_2

Mon 05/04/2020 to Fri 05/08/2020

0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

### NEPTUNE -DUFFYAVE\_345\_NEPTUNE

Mon 05/04/2020 to Mon 05/18/2020

0800 Continuous 1700

Work scheduled by: PJM

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

### NEWBRIDGE-DUFFYAVE\_345\_501

Mon 05/04/2020 to Mon 05/18/2020

0800 Continuous 1700

Work scheduled by: PJM

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

### NEWBRIDGE\_345\_138\_BK\_1

Mon 05/04/2020 to Mon 05/18/2020

0800 Continuous 1700

Work scheduled by: PJM

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

### NEWBRIDGE\_345\_138\_BK\_2

Mon 05/04/2020 to Mon 05/18/2020

0800 Continuous 1700

Work scheduled by: PJM

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

### PANNELL -CLAY\_345\_1

Mon 05/11/2020 to Fri 05/15/2020

0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW



# NYISO TRANSFER LIMITATIONS

Wednesday, December 18, 2019 to Friday , June 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## COOPERS\_-DOLSONAV\_345\_CCDA42

FWD

Mon 05/11/2020 to Fri 05/29/2020

UPDATEDby NYPA03/21/2019

(Import)

0700 Continuous 1730

Work scheduled by: NYPA

CENTRAL EAST - VC

**2720 MW**

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

## KINTIGH\_-ROCHESTR\_345\_SRI-39

FWD

Mon 05/18/2020 to Fri 05/22/2020

(Import)

0500 Continuous 1530

Work scheduled by: NYPA

DYSINGER EAST

**1400 MW**

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

## MOSES\_-ADIRNDCK\_230\_MA2

FWD

Mon 06/01/2020 to Fri 07/31/2020

(Import)

0700 Continuous 1730

Work scheduled by: NYPA

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

## NIAGARA\_345\_230\_AT4

REV

Mon 06/29/2020 to Tue 06/30/2020

(Export)

0500 Continuous 1530

Work scheduled by: NYPA

SCH - OH - NY

**1400 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 1700 MW

## SCH-IMO-NYISO\_NIAG\_CB\_3008\_W/BB

FWD

REV

Mon 07/27/2020 to Fri 08/07/2020

(Import) (Export)

0500 Continuous 1530

Work scheduled by: NYPA

SCH - OH - NY

**1900 MW 1450 MW**

Impacts Total Transfer Capability 0 MW 250 MW

TTC with All Lines In Service 1900 MW 1700 MW

## CHATGUAY-MASSENA\_765\_7040

FWD

Sat 08/01/2020 to Sun 08/02/2020

(Import)

0500 Continuous 1730

Work scheduled by: NYPA

MOSES SOUTH

**1550 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

## CHATGUAY-MASSENA\_765\_7040

FWD

REV

Sat 08/01/2020 to Sun 08/02/2020

(Import) (Export)

0500 Continuous 1730

Work scheduled by: NYPA

SCH - HQ - NY

**0 MW 0 MW**

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, December 18, 2019 to Friday, June 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY____765_345_AT1</b>						FWD		
Sat 08/01/2020	to	Sun 08/02/2020	<b><u>UPDATED</u></b>	<b><u>by NYPA</u></b>	<b><u>08/08/2019</u></b>	(Import)		
0500	Continuous	1730				MOSES SOUTH	<b>1750 MW</b>	
Work scheduled by: NYPA		Impacts Total Transfer Capability				1400 MW		
		TTC with All Lines In Service				3150 MW		
<b>MASSENA_-MARCY____765_MSU1</b>						FWD		
Sat 08/01/2020	to	Sun 08/02/2020	<b><u>UPDATED</u></b>	<b><u>by NYPA</u></b>	<b><u>08/08/2019</u></b>	(Import)		
0500	Continuous	1730				CENTRAL EAST - VC	<b>2265 MW</b>	
Work scheduled by: NYPA		Impacts Total Transfer Capability				710 MW		
		TTC with All Lines In Service				2975 MW		
<b>MASSENA_-MARCY____765_MSU1</b>						FWD		
Sat 08/01/2020	to	Sun 08/02/2020	<b><u>UPDATED</u></b>	<b><u>by NYPA</u></b>	<b><u>08/08/2019</u></b>	(Import)		
0500	Continuous	1730				MOSES SOUTH	<b>500 MW</b>	
Work scheduled by: NYPA		Impacts Total Transfer Capability				2650 MW		
		TTC with All Lines In Service				3150 MW		
<b>MASSENA_-MARCY____765_MSU1</b>						FWD	REV	
Sat 08/01/2020	to	Sun 08/02/2020	<b><u>UPDATED</u></b>	<b><u>by NYPA</u></b>	<b><u>08/08/2019</u></b>	(Import)	(Export)	
0500	Continuous	1730				SCH - HQ - NY	<b>475 MW</b>	<b>1000 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability				1025 MW	0 MW	
		TTC with All Lines In Service				1500 MW	1000 MW	
<b>MASSENA_-MARCY____765_MSU1</b>						FWD		
Sat 08/01/2020	to	Sun 08/02/2020	<b><u>UPDATED</u></b>	<b><u>by NYPA</u></b>	<b><u>08/08/2019</u></b>	(Import)		
0500	Continuous	1730				SCH - HQ_CEDARS	<b>90 MW</b>	
Work scheduled by: NYPA		Impacts Total Transfer Capability				100 MW		
		TTC with All Lines In Service				190 MW		
<b>MASSENA_-MARCY____765_MSU1 &amp; CHATGUAY-MASSENA__765_7040</b>						FWD		
Sat 08/01/2020	to	Sun 08/02/2020				(Import)		
0500		1730				MOSES SOUTH	<b>500 MW</b>	
Work scheduled by:		Impacts Total Transfer Capability				2650 MW		
		TTC with All Lines In Service				3150 MW		
<b>MOSES____-MASSENA__230_MMS1 &amp; MOSES____-MASSENA__230_MMS2</b>						FWD	REV	
Sat 08/01/2020	to	Sun 08/02/2020				(Import)	(Export)	
0500		1730				SCH - HQ - NY	<b>850 MW</b>	<b>0 MW</b>
Work scheduled by:		Impacts Total Transfer Capability				650 MW	1000 MW	
		TTC with All Lines In Service				1500 MW	1000 MW	

# NYISO TRANSFER LIMITATIONS

Wednesday, December 18, 2019 to Friday, June 18, 2021

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230\_MMS1 & MOSES -MASSENA 230\_MMS2

Sat 08/01/2020 to Sun 08/02/2020  
0500 1730

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS 90 MW  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 190 MW

STLAWRNC-MOSES 230\_L33P & MASSENA-MARCY 765\_MSU1

Sat 08/01/2020 to Sun 08/02/2020  
0500 1730

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS 90 MW  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 190 MW

STLAWRNC-MOSES 230\_L33P & MOSES -MASSENA 230\_MMS1 & MOSES -  
MASSENA 230\_MMS2

Sat 08/01/2020 to Sun 08/02/2020  
0500 1730

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS 90 MW  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 190 MW

MOSES -ADIRNDCK 230\_MA2

Mon 08/03/2020 to Sun 09/13/2020  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2100 MW  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

FRASANRX-COOPERS 345\_UCC2-41

Mon 09/07/2020 to Fri 10/23/2020 UPDATED by NYPA 03/01/2019  
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC 2500 MW  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

MARCY -FRASANRX 345\_UCC2-41

Mon 09/07/2020 to Fri 10/23/2020 UPDATED by NYPA 03/01/2019  
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC 2500 MW  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

MARCY 765\_345\_AT1

Mon 09/14/2020 to Mon 09/14/2020  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH 1750 MW  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 18, 2019 to Friday, June 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_-KINTIGH\_345\_NS1-38

Mon 09/14/2020 to Thu 09/17/2020  
0500 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

## MOSES\_-ADIRNDCK\_230\_MA2

Tue 09/15/2020 to Sat 11/14/2020  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## NIAGARA\_-ROCHESTR\_345\_NR2

Fri 09/18/2020 to Sat 11/14/2020  
0500 Continuous 2330

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

## CLAY\_-EDIC\_345\_1-16

Mon 09/21/2020 to Fri 09/25/2020  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

## ROSETON\_-ROCKTVRN\_345\_311

Mon 09/21/2020 to Fri 10/23/2020 **UPDATED by CHGE 10/09/2019**  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5700 MW

## DUNWODIE\_345KV\_3

Fri 09/25/2020 to Fri 09/25/2020 **UPDATED by CONED 09/05/2019**  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## DUNWODIE\_345KV\_5

Fri 09/25/2020 to Fri 09/25/2020 **UPDATED by CONED 09/05/2019**  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 18, 2019 to Friday, June 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## DUNWODIE-MOTTHAVN\_345\_71

Fri 09/25/2020 to Fri 10/30/2020 UPDATED by CONED 09/05/2019  
0001 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## CLAY-EDIC\_345\_2-15

Mon 09/28/2020 to Fri 10/02/2020  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

## MOTTHAVN-RAINEY\_345\_Q11

Thu 10/01/2020 to Thu 11/05/2020 UPDATED by CONED 12/17/2019  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## SAND\_BAR-PLATSBURG\_115\_PV20

Sat 10/17/2020 to Sat 11/14/2020  
0600 Continuous 1800

Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## LEEDS-HURLYAVE\_345\_301

Mon 10/26/2020 to Fri 12/04/2020  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 5700 MW

## DUNWODIE\_345KV\_3

Fri 10/30/2020 to Fri 10/30/2020 UPDATED by CONED 09/05/2019  
0230 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## DUNWODIE\_345KV\_5

Fri 10/30/2020 to Fri 10/30/2020 UPDATED by CONED 09/05/2019  
0230 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 18, 2019 to Friday , June 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-IMO-NYISO\_LIMIT\_1750

 Sun 11/01/2020 to Fri 04/30/2021 **UPDATED by IESO 05/03/2019**

0001 Continuous 2359

Work scheduled by: IESO

FWD

(Import)

SCH - OH - NY

**2050 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 2050 MW

## SCH-NYISO-IMO\_LIMIT\_1600

 Sun 11/01/2020 to Fri 04/30/2021 **UPDATED by IESO 05/03/2019**

0001 Continuous 2359

Work scheduled by: IESO

REV

(Export)

SCH - OH - NY

**1900 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 1900 MW

## CHATGUAY-MASSENA\_765\_7040

Sun 11/15/2020 to Mon 11/30/2020

0100 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

**1550 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

## CHATGUAY-MASSENA\_765\_7040

Sun 11/15/2020 to Mon 11/30/2020

0100 Continuous 1900

Work scheduled by: NYPA

FWD

REV

(Import) (Export)

SCH - HQ - NY

**0 MW****0 MW**

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

## MARCY\_765\_345\_AT1

Sun 11/15/2020 to Mon 11/30/2020

0100 Continuous 1900

Work scheduled by: NYPA

**ARR: 19**

FWD

(Import)

MOSES SOUTH

**1750 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

## MARCY\_765\_345\_AT2

Sun 11/15/2020 to Mon 11/30/2020

0100 Continuous 1900

Work scheduled by: NYPA

**ARR: 19**

FWD

(Import)

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

## MASSENA\_-MARCY\_765\_MSU1

Sun 11/15/2020 to Mon 11/30/2020

0100 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC

**2265 MW**

Impacts Total Transfer Capability 710 MW

TTC with All Lines In Service 2975 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, December 18, 2019 to Friday, June 18, 2021

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5700MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MASSENA\_-MARCY\_765\_MSU1**

Sun 11/15/2020 to Mon 11/30/2020

0100 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

**500 MW**

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

**MASSENA\_-MARCY\_765\_MSU1**

Sun 11/15/2020 to Mon 11/30/2020

0100 Continuous 1900

Work scheduled by: NYPA

FWD

(Import) (Export)

SCH - HQ - NY

**475 MW 1000 MW**

Impacts Total Transfer Capability 1025 MW 0 MW

TTC with All Lines In Service 1500 MW 1000 MW

**MASSENA\_-MARCY\_765\_MSU1**

Sun 11/15/2020 to Mon 11/30/2020

0100 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

SCH - HQ\_CEDARS

**90 MW**

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

**MASSENA\_-MARCY\_765\_MSU1 & CHATGUAY-MASSENA\_765\_7040**

Sun 11/15/2020 to Mon 11/30/2020

0100 1900

Work scheduled by:

FWD

(Import)

MOSES SOUTH

**500 MW**

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

**MOSES\_-MASSENA\_230\_MMS1 & MOSES\_-MASSENA\_230\_MMS2**

Sun 11/15/2020 to Mon 11/30/2020

0100 1900

Work scheduled by:

FWD

(Import) (Export)

SCH - HQ - NY

**850 MW 0 MW**

Impacts Total Transfer Capability 650 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

**MOSES\_-MASSENA\_230\_MMS1 & MOSES\_-MASSENA\_230\_MMS2**

Sun 11/15/2020 to Mon 11/30/2020

0100 1900

Work scheduled by:

FWD

(Import)

SCH - HQ\_CEDARS

**90 MW**

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

**STLAWRNC-MOSES\_230\_L33P & MASSENA\_-MARCY\_765\_MSU1**

Sun 11/15/2020 to Mon 11/30/2020

0100 1900

Work scheduled by:

FWD

(Import)

SCH - HQ\_CEDARS

**90 MW**

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 18, 2019 to Friday, June 18, 2021

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES\_\_\_230\_L33P & MOSES\_\_\_-MASSENA\_230\_MMS1 & MOSES\_\_\_-  
MASSENA\_230\_MMS2

FWD

(Import)

Sun 11/15/2020 to Mon 11/30/2020  
0100 1900

SCH - HQ\_CEDARS

90 MW

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

Work scheduled by:

PLSNTVLE-DUNWODIE\_345\_W89

FWD

(Import)

Mon 11/16/2020 to Mon 11/16/2020  
0001 Continuous 0030

UPNY CONED

4000 MW

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

PLSNTVLE-DUNWODIE\_345\_W89

FWD

(Import)

Thu 11/26/2020 to Thu 11/26/2020  
0230 Continuous 0300

UPNY CONED

4000 MW

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

MOSES\_\_\_-ADIRNDCK\_230\_MA1

FWD

(Import)

Tue 12/01/2020 to Mon 05/31/2021  
0700 Continuous 1300

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

SAND\_BAR-PLATSBRG\_115\_PV20

Mon 12/07/2020 to Fri 12/11/2020  
0700 Continuous 1530

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYPA

SAND\_BAR-PLATSBRG\_115\_PV20

Mon 12/14/2020 to Fri 12/18/2020  
0700 Continuous 1530

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYPA

DUNWODIE\_345KV\_3

FWD

(Import)

Mon 03/01/2021 to Mon 03/01/2021  
0001 Continuous 0030

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd



# NYISO TRANSFER LIMITATIONS

Wednesday, December 18, 2019 to Friday , June 18, 2021

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_5

Mon 03/01/2021 to Mon 03/01/2021  
0001 Continuous 0030  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### DUNWODIE-MOTTHAVN\_345\_71

Mon 03/01/2021 to Mon 04/05/2021  
0001 Continuous 0300  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### MOTTHAVN-RAINEY\_\_\_345\_Q11

Mon 03/01/2021 to Tue 04/06/2021  
0001 Continuous 0700  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### CLAY\_\_\_\_-EDIC\_\_\_\_345\_2-15

Mon 03/29/2021 to Fri 04/16/2021  
0800 Continuous 1730  
Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

### DUNWODIE\_345KV\_3

Mon 04/05/2021 to Mon 04/05/2021  
0230 Continuous 0300  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### DUNWODIE\_345KV\_5

Mon 04/05/2021 to Mon 04/05/2021  
0230 Continuous 0300  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### SCH-IMO-NYISO\_LIMIT\_1600

Sat 05/01/2021 to Sun 10/31/2021 **UPDATED by IESO 05/03/2019**  
0001 Continuous 2359  
Work scheduled by: IESO

FWD  
(Import)  
SCH - OH - NY **1900 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 1900 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, December 18, 2019 to Friday , June 18, 2021

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 5700MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL\_-CLAY\_\_\_\_\_345\_2

FWD

Mon 05/03/2021 to Fri 05/28/2021

(Import)

0700 Continuous 1730

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

MOSES\_-ADIRNDCK\_230\_MA2

FWD

Tue 06/01/2021 to Sun 11/14/2021

(Import)

0700 Continuous 1300

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA