

# NYISO TRANSFER LIMITATIONS

Monday ,January 13, 2020 to Wednesday,July 14, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Fri 05/01/2020 EXTENDED by CONED 10/08/2019

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Fri 05/01/2020

0001 2359

Work scheduled by:

	FWD (Import)	REV (Export)
SCH - PJ - NY	<b>2550 MW</b>	<b>1600 MW</b>
Impacts Total Transfer Capability	350 MW	250 MW
TTC with All Lines In Service	2900 MW	1850 MW

## MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Fri 05/01/2020 EXTENDED by CONED 10/08/2019

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## STLAWRNC-MOSES\_230\_L33P

Mon 04/30/2018 to Fri 12/31/2021 EXT FORCE by IESO 08/21/2018

0456 Continuous 2359

Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## SCH-IMO-NYISO\_LIMIT\_1750

Fri 11/01/2019 to Thu 04/30/2020 UPDATED by IESO 05/03/2019

0001 Continuous 2359

Work scheduled by: IESO

	FWD (Import)
SCH - OH - NY	<b>2050 MW</b>
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	2050 MW

## SCH-NYISO-IMO\_LIMIT\_1600

Fri 11/01/2019 to Thu 04/30/2020 UPDATED by IESO 05/03/2019

0001 Continuous 2359

Work scheduled by: IESO

	REV (Export)
SCH - OH - NY	<b>1900 MW</b>
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	1900 MW

## SCH-NYISO-NE\_LIMIT\_1500

Fri 11/01/2019 to Thu 04/30/2020

0001 Continuous 2359

Work scheduled by: NYISO

	REV (Export)
SCH - NE - NY	<b>1700 MW</b>
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	1700 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,January 13, 2020 to Wednesday,July 14, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**OSWEGO\_COMPLEX\_AVR\_O/S**

FWD

Mon 11/18/2019 to Mon 03/09/2020 **EXT FORCE** **by GEN** **12/26/2019**

(Import)

0221 Continuous 0001

CENTRAL EAST - VC **2870 MW**

Impacts Total Transfer Capability 105 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: Gen

**DUNWODIE\_345KV\_6**

FWD

Tue 12/03/2019 to Thu 02/06/2020 **EXT FORCE** **by CONED** **12/27/2019**

(Import)

0048 Continuous 2359

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**DUNWODIE\_345KV\_8**

FWD

Tue 12/03/2019 to Thu 02/06/2020 **EXT FORCE** **by CONED** **12/27/2019**

(Import)

0048 Continuous 2359

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**PLSNTVLE-DUNWODIE\_345\_W90**

FWD

Tue 12/03/2019 to Thu 02/06/2020 **EXT FORCE** **by CONED** **12/27/2019**

(Import)

0107 Continuous 2359

UPNY CONED **4000 MW**

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**CHAT\_DC\_GC2**

FWD

Thu 12/26/2019 to Thu 01/30/2020 **EXTENDED** **by HQ** **01/13/2020**

(Import)

1827 Continuous 2359

MOSES SOUTH **2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

**CHAT\_DC\_GC2**

REV

Thu 12/26/2019 to Thu 01/30/2020 **EXTENDED** **by HQ** **01/13/2020**

(Export)

1827 Continuous 2359

SCH - HQ - NY **500 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

Work scheduled by: HQ

**SCH-HQ-NYISO\_LIMIT\_1200**

FWD

Fri 01/03/2020 to Thu 01/30/2020 **EXTENDED** **by HQ** **01/13/2020**

(Import)

1430 Continuous 2359

SCH - HQ - NY **1200 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: HQ

**NYISO TRANSFER LIMITATIONS**

Monday ,January 13, 2020 to Wednesday, July 14, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PIERCBRK-FIVEMILE\_345\_37**

FWD

Mon 01/06/2020 to Fri 01/10/2020

(Import)

0800 Continuous 1600

SCH - PJ - NY

**2400 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 2900 MW

Work scheduled by: NGrid

**S.RIPLEY-DUNKIRK\_230\_68**

Mon 01/06/2020 to Fri 01/10/2020

0800 Continuous 1600

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NGrid

**FROST\_BR-LONG MTN\_345\_352**

FWD

Tue 01/07/2020 to Fri 01/10/2020

(Import)

0700 Continuous 1600

**UPDATED by ISONE 01/08/2020**

SCH - NE - NY

**1300 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

**SCH-NE-NYISO\_LIMIT\_300**

FWD

Tue 01/07/2020 to Fri 01/10/2020

(Import)

0900 Continuous 1600

**UPDATED by ISONE 01/08/2020**

SCH - NE - NY

**500 MW**

Impacts Total Transfer Capability 900 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

**FROST\_BR-LONG MTN\_345\_352 & NRTH1385-NOR HBR\_138\_601**

FWD

REV

Wed 01/08/2020 to Wed 01/08/2020

(Import) (Export)

0800 1600

SCH - NPX\_1385

**0 MW****0 MW**

Impacts Total Transfer Capability 200 MW 200 MW

TTC with All Lines In Service 200 MW 200 MW

Work scheduled by:

**FROST\_BR-LONG MTN\_345\_352 & NRTH1385-NOR HBR\_138\_602**

FWD

REV

Wed 01/08/2020 to Wed 01/08/2020

(Import) (Export)

0800 1600

SCH - NPX\_1385

**0 MW****0 MW**

Impacts Total Transfer Capability 200 MW 200 MW

TTC with All Lines In Service 200 MW 200 MW

Work scheduled by:

**FROST\_BR-LONG MTN\_345\_352 & NRTH1385-NOR HBR\_138\_603**

FWD

REV

Wed 01/08/2020 to Wed 01/08/2020

(Import) (Export)

0800 1600

SCH - NPX\_1385

**0 MW****0 MW**

Impacts Total Transfer Capability 200 MW 200 MW

TTC with All Lines In Service 200 MW 200 MW

Work scheduled by:

**NYISO TRANSFER LIMITATIONS**

Monday ,January 13, 2020 to Wednesday, July 14, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_601			FWD	REV
Wed 01/08/2020	to	Wed 01/08/2020	(Import)	(Export)
0800	Continuous	1600	SCH - NPX_1385	<b>100 MW</b> <b>100 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602			FWD	REV
Wed 01/08/2020	to	Wed 01/08/2020	(Import)	(Export)
0800		1600	SCH - NPX_1385	<b>0 MW</b> <b>0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603			FWD	REV
Wed 01/08/2020	to	Wed 01/08/2020	(Import)	(Export)
0800		1600	SCH - NPX_1385	<b>0 MW</b> <b>0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_602			FWD	REV
Wed 01/08/2020	to	Wed 01/08/2020	(Import)	(Export)
0800	Continuous	1600	SCH - NPX_1385	<b>100 MW</b> <b>100 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603			FWD	REV
Wed 01/08/2020	to	Wed 01/08/2020	(Import)	(Export)
0800		1600	SCH - NPX_1385	<b>0 MW</b> <b>0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_603			FWD	REV
Wed 01/08/2020	to	Wed 01/08/2020	(Import)	(Export)
0800	Continuous	1600	SCH - NPX_1385	<b>100 MW</b> <b>100 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NRTHPORT_138_NNC			FWD	REV
Wed 01/08/2020	to	Wed 01/08/2020	(Import)	(Export)
0800	Continuous	1600	SCH - NPX_1385	<b>0 MW</b> <b>0 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Monday ,January 13, 2020 to Wednesday,July 14, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

OSWEGO__ -VOLNEY__ 345_12					FWD	
Wed 01/08/2020	to	Wed 01/08/2020			(Import)	
0830	Daily(No Weekends)	1130			OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	5250 MW
W49TH_ST_345KV_5					FWD	
Thu 01/09/2020	to	Thu 01/09/2020	<u>CANCELLED</u>	<u>by ConEd</u> <u>01/09/2020</u>	(Import)	
0001	Continuous	0030			SCH - PJM_HTP	350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	310 MW
					TTC with All Lines In Service	660 MW
W49TH_ST_345KV_7					FWD	
Thu 01/09/2020	to	Thu 01/09/2020	<u>CANCELLED</u>	<u>by ConEd</u> <u>01/09/2020</u>	(Import)	
0001	Continuous	0030			SCH - PJM_HTP	350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	310 MW
					TTC with All Lines In Service	660 MW
W49TH_ST_345KV_5					FWD	
Sun 01/12/2020	to	Sun 01/12/2020	<u>CANCELLED</u>	<u>by ConEd</u> <u>01/09/2020</u>	(Import)	
0130	Continuous	0159			SCH - PJM_HTP	350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	310 MW
					TTC with All Lines In Service	660 MW
W49TH_ST_345KV_7					FWD	
Sun 01/12/2020	to	Sun 01/12/2020	<u>CANCELLED</u>	<u>by ConEd</u> <u>01/09/2020</u>	(Import)	
0130	Continuous	0159			SCH - PJM_HTP	350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	310 MW
					TTC with All Lines In Service	660 MW
FRASER__ 345_FRASER SVC					FWD	
Mon 01/13/2020	to	Mon 01/27/2020	<u>UPDATED</u>	<u>by NYSEG</u> <u>12/18/2019</u>	(Import)	
0800	Continuous	1500			CENTRAL EAST - VC	2935 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability	40 MW
					TTC with All Lines In Service	2975 MW
BECK__ -NIAGARA__ 345_PA301					FWD	REV
Tue 01/14/2020	to	Fri 01/17/2020	<u>UPDATED</u>	<u>by NYPA</u> <u>01/13/2020</u>	(Import)	(Export)
0500	Continuous	1530			SCH - OH - NY	1100 MW 950 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	950 MW 950 MW
					TTC with All Lines In Service	2050 MW 1900 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,January 13, 2020 to Wednesday, July 14, 2021

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5700MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SAND\_BAR-PLATSBURG\_115\_PV20**

Tue 01/14/2020 to Tue 01/14/2020  
 0700 Continuous 1830

Work scheduled by: NYPA

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**FROST\_BR-LONG MTN\_345\_352**

Mon 01/20/2020 to Thu 01/23/2020  
 0100 Continuous 1600

Work scheduled by: ISONE

UPDATEDby ISONE 01/08/2020

SCH - NE - NY

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 1400 MW

FWD

(Import)

**1300 MW****SCH-NE-NYISO\_LIMIT\_800**

Mon 01/20/2020 to Thu 01/23/2020  
 0100 Continuous 1600

Work scheduled by: ISONE

UPDATEDby ISONE 01/08/2020

SCH - NE - NY

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 1400 MW

FWD

(Import)

**1000 MW****SCH-NE-NYISO\_LIMIT\_500**

Wed 01/22/2020 to Wed 01/29/2020  
 0500 Continuous 1300

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 1400 MW

FWD

(Import)

**700 MW****SCH-NYISO-NE\_LIMIT\_1200**

Wed 01/22/2020 to Wed 01/29/2020  
 0500 Continuous 1300

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

**1400 MW**

300 MW

1700 MW

**RAMAPO\_\_-BUCHAN\_N\_345\_Y94**

Mon 02/03/2020 to Tue 02/04/2020  
 0001 Continuous 0230

Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability 900 MW

TTC with All Lines In Service 5700 MW

FWD

(Import)

**4800 MW****PLSNTVLY\_345KV\_RNS4**

Mon 02/03/2020 to Tue 02/04/2020  
 0001 Continuous 2200

Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability 1900 MW

TTC with All Lines In Service 5700 MW

FWD

(Import)

**3800 MW**

**NYISO TRANSFER LIMITATIONS**

Monday ,January 13, 2020 to Wednesday, July 14, 2021

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5700MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Mon 02/03/2020 to Fri 02/07/2020

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**EFISHKIL-WOOD\_ST\_\_345\_F39**

FWD

Mon 02/10/2020 to Mon 02/10/2020

(Import)

0001 Continuous 0030

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**WOOD\_ST\_-PLSNTVLE\_345\_Y87**

FWD

Mon 02/10/2020 to Wed 02/12/2020

(Import)

0001 Continuous 0030

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Mon 02/10/2020 to Fri 02/14/2020

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**HURLYAVE-ROSETON\_\_345\_303**

FWD

Tue 02/11/2020 to Thu 02/13/2020

(Import)

0700 Continuous 1600

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: CHGE

**EFISHKIL-WOOD\_ST\_\_345\_F39**

FWD

Wed 02/12/2020 to Wed 02/12/2020

(Import)

0001 Continuous 0030

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**EFISHKIL-WOOD\_ST\_\_345\_F38**

FWD

Fri 02/14/2020 to Sat 02/15/2020

(Import)

0001 Continuous 0030

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**NYISO TRANSFER LIMITATIONS**

Monday ,January 13, 2020 to Wednesday, July 14, 2021

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5700MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**WOOD\_ST\_-PLSNTVLE\_345\_Y86**

FWD

Fri 02/14/2020 to Sat 02/15/2020

(Import)

0001 Continuous 0030

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**SPRNBRK\_-TREMONT\_345\_X28**

FWD

Mon 02/17/2020 to Mon 02/17/2020

(Import)

0001 Continuous 1800

UPDATEDby CONED 12/05/2019

SPR/DUN-SOUTH

**4200 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**WATRCURE-OAKDALE\_345\_31**

FWD

Mon 02/17/2020 to Mon 02/17/2020

(Import)

1500 Continuous 1530

UPDATEDby NYSEG 12/20/2019

SCH - PJ - NY

**2750 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 2900 MW

Work scheduled by: NYSEG

**PLSNTVLY-WOOD\_ST\_345\_F30**

FWD

Tue 02/18/2020 to Sat 02/29/2020

(Import)

0001 Continuous 2200

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**PLSNTVLY\_345KV\_RNS5**

FWD

Tue 02/18/2020 to Sat 02/29/2020

(Import)

0001 Continuous 2200

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1900 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**MOSES\_-ADIRNDCK\_230\_MA1**

FWD

Tue 02/18/2020 to Fri 02/21/2020

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**SPRNBRK\_345KV\_RNS5**

FWD

Mon 02/24/2020 to Mon 02/24/2020

(Import)

0001 Continuous 0030

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Monday ,January 13, 2020 to Wednesday, July 14, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBRK_-W49TH_ST_345_M51</b>				FWD	
Mon 02/24/2020	to	Sun 03/01/2020		(Import)	
0001	Continuous	0200		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<b>SPRNBRK_345KV_RNS5</b>				FWD	
Wed 02/26/2020	to	Wed 02/26/2020		(Import)	
2130	Continuous	2200		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<b>SPRNBRK_345KV_RNS5</b>				FWD	
Thu 02/27/2020	to	Sun 03/01/2020		(Import)	
2301	Continuous	0200		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<b>NIAGARA_-PACKARD_230_62</b>				FWD	REV
Fri 02/28/2020	to	Fri 02/28/2020		(Import)	(Export)
0500	Continuous	1530		SCH - OH - NY	<b>900 MW 1850 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1150 MW 50 MW
				TTC with All Lines In Service	2050 MW 1900 MW
<b>DUNWODIE_345KV_4</b>				FWD	
Sun 03/01/2020	to	Sun 03/08/2020		(Import)	
0001	Continuous	2200		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
<b>CHATGUAY-MASSENA_765_7040</b>				FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<b>UPDATED by NYPA 08/08/2019</b>	(Import)	
0500	Continuous	1730		MOSES SOUTH	<b>1550 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1600 MW
				TTC with All Lines In Service	3150 MW
<b>CHATGUAY-MASSENA_765_7040</b>				FWD	REV
Mon 03/02/2020	to	Fri 03/06/2020	<b>UPDATED by NYPA 08/08/2019</b>	(Import)	(Export)
0500	Continuous	1730		SCH - HQ - NY	<b>0 MW 0 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1500 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,January 13, 2020 to Wednesday, July 14, 2021

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5700MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_\_765\_345\_AT1**

FWD

Mon 03/02/2020 to Fri 03/06/2020

**UPDATED****by NYPA****08/08/2019**

(Import)

0500 Continuous 1730

MOSES SOUTH

**1750 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19****MARCY\_\_\_\_765\_345\_AT2**

FWD

Mon 03/02/2020 to Fri 03/06/2020

(Import)

0500 Continuous 1730

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19****MASSENA\_-MARCY\_\_\_\_765\_MSU1**

FWD

Mon 03/02/2020 to Fri 03/06/2020

**UPDATED****by NYPA****08/08/2019**

(Import)

0500 Continuous 1730

CENTRAL EAST - VC

**2265 MW**

Impacts Total Transfer Capability 710 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**MASSENA\_-MARCY\_\_\_\_765\_MSU1**

FWD

Mon 03/02/2020 to Fri 03/06/2020

**UPDATED****by NYPA****08/08/2019**

(Import)

0500 Continuous 1730

MOSES SOUTH

**500 MW**

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**MASSENA\_-MARCY\_\_\_\_765\_MSU1**

FWD

REV

Mon 03/02/2020 to Fri 03/06/2020

**UPDATED****by NYPA****08/08/2019**

(Import) (Export)

0500 Continuous 1730

SCH - HQ - NY

**475 MW****1000 MW**

Impacts Total Transfer Capability 1025 MW

0 MW

TTC with All Lines In Service 1500 MW

1000 MW

Work scheduled by: NYPA

**MASSENA\_-MARCY\_\_\_\_765\_MSU1**

FWD

Mon 03/02/2020 to Fri 03/06/2020

**UPDATED****by NYPA****08/08/2019**

(Import)

0500 Continuous 1730

SCH - HQ\_CEDARS

**90 MW**

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

Work scheduled by: NYPA

**MASSENA\_-MARCY\_\_\_\_765\_MSU1 & CHATGUAY-MASSENA\_765\_7040**

FWD

Mon 03/02/2020 to Fri 03/06/2020

(Import)

0500 1730

MOSES SOUTH

**500 MW**

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

Work scheduled by:

# NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday ,January 13, 2020 to Wednesday, July 14, 2021

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230\_MMS1 & MOSES -MASSENA 230\_MMS2

Mon 03/02/2020 to Fri 03/06/2020  
0500 1730

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY 850 MW 0 MW  
Impacts Total Transfer Capability 650 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

MOSES -MASSENA 230\_MMS1 & MOSES -MASSENA 230\_MMS2

Mon 03/02/2020 to Fri 03/06/2020  
0500 1730

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS 90 MW  
Impacts Total Transfer Capability 109 MW  
TTC with All Lines In Service 199 MW

STLAWRNC-MOSES 230\_L33P & MASSENA -MARCY 765\_MSU1

Mon 03/02/2020 to Fri 03/06/2020  
0500 1730

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS 90 MW  
Impacts Total Transfer Capability 109 MW  
TTC with All Lines In Service 199 MW

STLAWRNC-MOSES 230\_L33P & MOSES -MASSENA 230\_MMS1 & MOSES -MASSENA 230\_MMS2

Mon 03/02/2020 to Fri 03/06/2020  
0500 1730

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS 90 MW  
Impacts Total Transfer Capability 109 MW  
TTC with All Lines In Service 199 MW

SHOR\_NPX-SHOREHAM 138\_CSC

Mon 03/02/2020 to Tue 03/03/2020  
0600 Continuous 1300

Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_CSC 0 MW 0 MW  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

ROSETON -EFISHKIL 345\_RFK305

Mon 03/02/2020 to Fri 03/20/2020  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
UPNY CONED 4800 MW  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 5700 MW

EASTVIEW-SPRNBRK 345\_W78

Fri 03/06/2020 to Sat 03/07/2020  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED 4350 MW  
Impacts Total Transfer Capability 1350 MW  
TTC with All Lines In Service 5700 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,January 13, 2020 to Wednesday,July 14, 2021

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5700MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MILLWOOD-EASTVIEW\_345\_W85**

FWD

Fri 03/06/2020 to Sat 03/07/2020

(Import)

0001 Continuous 0200

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1350 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**SPRNBRK\_345KV\_RNS3**

FWD

Fri 03/06/2020 to Sat 03/07/2020

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**MOSES\_-ADIRNDCK\_230\_MA1**

FWD

Sat 03/07/2020 to Fri 05/29/2020

(Import)

0700 Continuous 1300

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**W49TH\_ST\_345KV\_5**

FWD

Mon 03/09/2020 to Mon 03/09/2020

(Import)

0001 Continuous 0030

SCH - PJM\_HTP

**350 MW**

Impacts Total Transfer Capability 310 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**SPRNBRK\_-W49TH\_ST\_345\_M52**

FWD

Mon 03/09/2020 to Wed 03/11/2020

(Import)

0001 Continuous 2200

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**SPRNBRK\_345KV\_RNS4**

FWD

Mon 03/09/2020 to Wed 03/11/2020

(Import)

0001 Continuous 2200

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**SCH-NE-NYISO\_LIMIT\_500**

FWD

Mon 03/09/2020 to Fri 04/03/2020

(Import)

0700 Continuous 1600

SCH - NE - NY

**700 MW**

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

**NYISO TRANSFER LIMITATIONS**

Monday ,January 13, 2020 to Wednesday, July 14, 2021

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5700MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-NYISO-NE\_LIMIT\_1200**

REV

Mon 03/09/2020 to Fri 04/03/2020

(Export)

0700 Continuous 1600

SCH - NE - NY

**1400 MW**

Impacts Total Transfer Capability

300 MW

TTC with All Lines In Service

1700 MW

Work scheduled by: ISONE

**VOLNEY -MARCY 345\_19**

FWD

Tue 03/10/2020 to Tue 03/10/2020

UPDATEDby NYPA09/24/2019

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2825 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 19****VOLNEY -MARCY 345\_19**

FWD

Tue 03/10/2020 to Tue 03/10/2020

UPDATEDby NYPA09/24/2019

(Import)

0700 Continuous 1530

OSWEGO EXPORT

**4900 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19****W49TH\_ST\_345KV\_5**

FWD

Wed 03/11/2020 to Wed 03/11/2020

(Import)

2130 Continuous 2200

SCH - PJM\_HTP

**350 MW**

Impacts Total Transfer Capability 310 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**ROCHESTR-PANNELL 345\_RP2**

FWD

Sat 03/14/2020 to Mon 03/23/2020

(Import)

0500 Continuous 1700

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**MARCY 345KV\_CSC**

FWD

Mon 03/16/2020 to Fri 03/27/2020

(Import)

0500 Continuous 1730

CENTRAL EAST - VC

**2925 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**CHASLAKE-PORTER 230\_11**

FWD

Wed 03/18/2020 to Wed 03/18/2020

(Import)

0630 Daily(No Weekends) 1330

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NGrid

**NYISO TRANSFER LIMITATIONS**

Monday ,January 13, 2020 to Wednesday, July 14, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-NYISO-NE\_LIMIT\_900**

REV

Wed 03/18/2020 to Tue 03/31/2020

(Export)

0700 Continuous 2359

SCH - NE - NY

**1100 MW**

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

1700 MW

Work scheduled by: ISONE

**BUCHAN\_N-EASTVIEW\_345\_W93**

FWD

Thu 03/19/2020 to Thu 03/19/2020

(Import)

0200 Continuous 0230

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1350 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**EASTVIEW-SPRNBK\_\_345\_W79**

FWD

Thu 03/19/2020 to Fri 03/20/2020

(Import)

0200 Continuous 0200

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1350 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**BUCHAN\_N-EASTVIEW\_345\_W93**

FWD

Fri 03/20/2020 to Fri 03/20/2020

(Import)

0130 Continuous 0200

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1350 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**EASTVIEW-SPRNBK\_\_345\_W64**

FWD

Sat 03/21/2020 to Sat 03/21/2020

(Import)

0001 Continuous 0030

**UPDATED****by CONED 12/05/2019**

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1350 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**SPRNBK\_\_345KV\_RNS5**

FWD

Sat 03/21/2020 to Sat 03/21/2020

(Import)

0001 Continuous 0030

**UPDATED****by CONED 12/05/2019**

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**MILLWOOD-EASTVIEW\_345\_W99**

FWD

Sat 03/21/2020 to Sun 03/22/2020

(Import)

0001 Continuous 0200

**UPDATED****by CONED 12/05/2019**

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1350 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**NYISO TRANSFER LIMITATIONS**

Monday ,January 13, 2020 to Wednesday,July 14, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EASTVIEW-SPRNBK\_\_345\_W64**

FWD

Sun 03/22/2020 to Sun 03/22/2020 **UPDATED** **by CONED** **12/05/2019**  
 0130 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1350 MW  
 TTC with All Lines In Service 5700 MW

**SPRNBK\_\_345KV\_RNS5**

FWD

Sun 03/22/2020 to Sun 03/22/2020 **UPDATED** **by CONED** **12/05/2019**  
 0130 Continuous 0200

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**MILLWOOD-EASTVIEW\_345\_W85**

FWD

Sun 03/22/2020 to Sun 03/22/2020 **UPDATED** **by CE** **12/20/2019**  
 0201 Continuous 0231

(Import)

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1350 MW  
 TTC with All Lines In Service 5700 MW

**DUNWODIE-MOTTHAVN\_345\_72**

FWD

Sun 03/22/2020 to Tue 03/24/2020 **UPDATED** **by CE** **12/20/2019**  
 0201 Continuous 0200

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_8**

FWD

Sun 03/22/2020 to Tue 03/24/2020 **UPDATED** **by CE** **12/20/2019**  
 0201 Continuous 0200

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**EASTVIEW-SPRNBK\_\_345\_W78**

FWD

Sun 03/22/2020 to Tue 03/24/2020 **UPDATED** **by CE** **12/20/2019**  
 0201 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1350 MW  
 TTC with All Lines In Service 5700 MW

**DUNWODIE\_345KV\_5**

FWD

Sun 03/22/2020 to Mon 05/11/2020 **UPDATED** **by CE** **12/20/2019**  
 0201 Continuous 0300

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,January 13, 2020 to Wednesday,July 14, 2021

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5700MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_7**

FWD

Sun 03/22/2020 to Mon 05/11/2020 UPDATED by CE 12/20/2019

(Import)

0201 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**SPRNBRK\_-DUNWODIE\_345\_W75**

FWD

Sun 03/22/2020 to Mon 05/11/2020 UPDATED by CE 12/20/2019

(Import)

0201 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**SPRNBRK\_\_345KV\_RNS3**

FWD

Sun 03/22/2020 to Mon 05/11/2020 UPDATED by CE 12/20/2019

(Import)

0201 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**RAMAPO\_-BUCHAN\_N\_345\_Y94**

FWD

Tue 03/24/2020 to Tue 03/24/2020

(Import)

0001 Continuous 0030

Work scheduled by: ConEd

UPNY CONED **4800 MW**  
 Impacts Total Transfer Capability 900 MW  
 TTC with All Lines In Service 5700 MW

**MILLWOOD-EASTVIEW\_345\_W85**

FWD

Tue 03/24/2020 to Tue 03/24/2020 UPDATED by CE 12/20/2019

(Import)

0130 Continuous 0200

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1350 MW  
 TTC with All Lines In Service 5700 MW

**DUNWODIE-MOTTHAVN\_345\_71**

FWD

Tue 03/24/2020 to Thu 03/26/2020 UPDATED by CE 12/20/2019

(Import)

0201 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_3**

FWD

Tue 03/24/2020 to Thu 03/26/2020 UPDATED by CE 12/20/2019

(Import)

0201 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,January 13, 2020 to Wednesday, July 14, 2021

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5700MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**RAMAPO\_\_-BUCHAN\_N\_345\_Y94**

FWD

Tue 03/24/2020 to Tue 03/24/2020

(Import)

0630 Continuous 0700

UPNY CONED

**4800 MW**

Impacts Total Transfer Capability 900 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**SPRNBK\_\_345KV\_RS3 & SPRNBK\_\_345KV\_RS4**

FWD

Thu 03/26/2020 to Sun 03/29/2020

(Import)

0201 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by:

**NIAGARA\_-KINTIGH\_\_345\_NS1-38**

FWD

Fri 03/27/2020 to Fri 03/27/2020

(Import)

0600 Continuous 1530

DYSINGER EAST

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**BECK\_\_\_\_-PACKARD\_\_230\_BP76**

FWD

REV

Fri 03/27/2020 to Fri 03/27/2020

(Import) (Export)

0800 Daily(No Weekends) 1600

SCH - OH - NY

**1650 MW 1400 MW**

Impacts Total Transfer Capability 400 MW 500 MW

TTC with All Lines In Service 2050 MW 1900 MW

Work scheduled by: NGrid

**MARCY\_\_-EDIC\_\_\_\_345\_UE1-7**

FWD

Tue 03/31/2020 to Tue 03/31/2020

(Import)

0700 Continuous 1530

**UPDATED by NYPA 09/24/2019**

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19&16****RAMAPO\_\_-LADENTWN\_345\_W72**

FWD

Wed 04/01/2020 to Thu 04/02/2020

(Import)

0001 Continuous 1830

UPNY CONED

**4400 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**SCH-NYISO-NE\_LIMIT\_700**

REV

Wed 04/01/2020 to Fri 04/03/2020

(Export)

0001 Continuous 1600

SCH - NE - NY

**900 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 1700 MW

Work scheduled by: ISONE

# NYISO TRANSFER LIMITATIONS

Monday ,January 13, 2020 to Wednesday, July 14, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>FRASANNX-COOPERS__345_UCC2-41</b>					FWD	
Wed 04/01/2020	to	Thu 04/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/12/2019</u>	(Import)
0700	Continuous	1530				
Work scheduled by: NYPA					ARR: 19	
					CENTRAL EAST - VC	2500 MW
					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW
<b>MARCY__-FRASANNX_345_UCC2-41</b>					FWD	
Wed 04/01/2020	to	Thu 04/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/12/2019</u>	(Import)
0700	Continuous	1530				
Work scheduled by: NYPA					ARR: 19	
					CENTRAL EAST - VC	2500 MW
					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW
<b>LINDN_CG-LNDVFT__345_V-3022</b>					FWD	REV
Sun 04/05/2020	to	Sat 04/11/2020			(Import)	(Export)
1400	Continuous	1400				
Work scheduled by: PJM					SCH - PJM_VFT	0 MW 0 MW
					Impacts Total Transfer Capability	315 MW 315 MW
					TTC with All Lines In Service	315 MW 315 MW
<b>MARCY__-N.SCTLND_345_18</b>					FWD	
Tue 04/07/2020	to	Wed 04/08/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/24/2019</u>	(Import)
0700	Continuous	1530				
Work scheduled by: NYPA					ARR: 19	
					CENTRAL EAST - VC	2090 MW
					Impacts Total Transfer Capability	885 MW
					TTC with All Lines In Service	2975 MW
<b>PLSNTVLY-EFISHKIL_345_F36</b>					FWD	
Mon 04/13/2020	to	Tue 04/14/2020			(Import)	
0001	Continuous	0200				
Work scheduled by: ConEd					UPNY CONED	4000 MW
					Impacts Total Transfer Capability	1700 MW
					TTC with All Lines In Service	5700 MW
<b>SAND_BAR-PLATSBRG_115_PV20</b>						
Mon 04/13/2020	to	Tue 04/14/2020			SCH - NE - NY	
0600	Daily	1800			Impacts Total Transfer Capability	
Work scheduled by: ISONE					TTC with All Lines In Service	
<b>FRASER__-GILBOA__345_GF5-35</b>					FWD	
Mon 04/13/2020	to	Wed 04/22/2020			(Import)	
0700	Continuous	1730				
Work scheduled by: NYPA					CENTRAL EAST - VC	2650 MW
					Impacts Total Transfer Capability	325 MW
					TTC with All Lines In Service	2975 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,January 13, 2020 to Wednesday, July 14, 2021

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5700MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_-ROCHESTR\_345\_NR2**

FWD

Wed 04/15/2020 to Fri 05/01/2020

(Import)

0500 Continuous 1700

DYSINGER EAST **1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ROCHESTR-PANNELL\_345\_RP1**

FWD

Mon 04/20/2020 to Fri 04/24/2020

(Import)

0700 Continuous 1530

DYSINGER EAST **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**DOLSONAV-ROCKTVRN\_345\_DART44**

FWD

Mon 04/27/2020 to Sun 05/10/2020

(Import)

0700 Continuous 1730

**UPDATED by NYPA 03/21/2019**CENTRAL EAST - VC **2720 MW**

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**HURLYAVE-ROSETON\_345\_303**

FWD

Mon 04/27/2020 to Fri 05/29/2020

(Import)

0800 Continuous 1600

**UPDATED by CHGE 10/09/2019**UPNY CONED **4100 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: CHGE

**DUNWODIE-MOTTHAVN\_345\_72**

FWD

Tue 04/28/2020 to Sat 05/02/2020

(Import)

0200 Continuous 0200

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**MILLWOOD-EASTVIEW\_345\_W85**

FWD

Wed 04/29/2020 to Wed 04/29/2020

(Import)

0201 Continuous 0230

UPNY CONED **4350 MW**

Impacts Total Transfer Capability 1350 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**EASTVIEW-SPRNBK\_345\_W78**

FWD

Wed 04/29/2020 to Sun 05/03/2020

(Import)

0201 Continuous 0200

UPNY CONED **4350 MW**

Impacts Total Transfer Capability 1350 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**NYISO TRANSFER LIMITATIONS**

Monday ,January 13, 2020 to Wednesday, July 14, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-IMO-NYISO\_LIMIT\_1600**

FWD

Fri 05/01/2020 to Sat 10/31/2020 **UPDATED by IESO 05/03/2019**

(Import)

0001 Continuous 2359

Work scheduled by: IESO

SCH - OH - NY

**1900 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 1900 MW

**DUNWODIE-MOTTHAVN\_345\_71**

FWD

Sat 05/02/2020 to Wed 05/06/2020

(Import)

0201 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_3**

FWD

Sat 05/02/2020 to Wed 05/06/2020

(Import)

0201 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**MILLWOOD-EASTVIEW\_345\_W85**

FWD

Sun 05/03/2020 to Sun 05/03/2020

(Import)

0130 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1350 MW

TTC with All Lines In Service 5700 MW

**PANNELL\_-CLAY\_\_\_\_345\_2**

FWD

Mon 05/04/2020 to Fri 05/08/2020

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

FWD

Mon 05/04/2020 to Mon 05/18/2020

(Import)

0800 Continuous 1700

Work scheduled by: PJM

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

**NEWBRIDGE-DUFFYAVE\_345\_501**

FWD

Mon 05/04/2020 to Mon 05/18/2020

(Import)

0800 Continuous 1700

Work scheduled by: PJM

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,January 13, 2020 to Wednesday,July 14, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NEWBRIDGE\_345\_138\_BK\_1**

FWD

Mon 05/04/2020 to Mon 05/18/2020

(Import)

0800 Continuous 1700

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

Work scheduled by: PJM

**NEWBRIDGE\_345\_138\_BK\_2**

FWD

Mon 05/04/2020 to Mon 05/18/2020

(Import)

0800 Continuous 1700

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

Work scheduled by: PJM

**SPRNBRK\_\_345KV\_RS3 & SPRNBRK\_\_345KV\_RS4**

FWD

Wed 05/06/2020 to Mon 05/11/2020

(Import)

0201 0200

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by:

**PANNELL\_-CLAY\_\_\_\_345\_1**

FWD

Mon 05/11/2020 to Fri 05/15/2020

(Import)

0700 Continuous 1530

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

**COOPERS\_-DOLSONAV\_345\_CCDA42**

FWD

Mon 05/11/2020 to Fri 05/29/2020

(Import)

0700 Continuous 1730

**UPDATED by NYPA 03/21/2019**

CENTRAL EAST - VC

**2720 MW**

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**KINTIGH\_-ROCHESTR\_345\_SR1-39**

FWD

Mon 05/18/2020 to Fri 05/22/2020

(Import)

0500 Continuous 1530

DYSINGER EAST

**1400 MW**

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**SCH-NE-NYISO\_LIMIT\_700**

FWD

Mon 05/18/2020 to Mon 05/18/2020

(Import)

0700 Continuous 1059

SCH - NE - NY

**900 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

# NYISO TRANSFER LIMITATIONS

Monday ,January 13, 2020 to Wednesday,July 14, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NYISO-NE\_LIMIT\_500

Mon 05/18/2020 to Mon 05/18/2020  
0700 Continuous 1059  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 1600 MW

REV  
(Export)

## BERKSHIR-ALPS\_\_\_\_\_345\_393 &amp; BERKSHIR-NORTHFLD\_345\_312

Mon 05/18/2020 to Mon 05/18/2020  
0700 1100  
Work scheduled by:

ARR: 78

FWD REV  
(Import) (Export)  
SCH - NE - NY 950 MW 1300 MW  
Impacts Total Transfer Capability 450 MW 300 MW  
TTC with All Lines In Service 1400 MW 1600 MW

## BERKSHIR-NORTHFLD\_345\_312

Mon 05/18/2020 to Mon 05/18/2020  
0700 Continuous 1100  
Work scheduled by: ISONE

FWD REV  
(Import) (Export)  
SCH - NE - NY 900 MW 1500 MW  
Impacts Total Transfer Capability 500 MW 100 MW  
TTC with All Lines In Service 1400 MW 1600 MW

## BERKSHIR-NORTHFLD\_345\_312

Mon 05/18/2020 to Mon 05/18/2020  
0700 Continuous 1100  
Work scheduled by: ISONE

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 100 MW 100 MW  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

## BERKSHIR-ALPS\_\_\_\_\_345\_393

Mon 05/18/2020 to Sat 05/30/2020  
0700 Continuous 1700  
Work scheduled by: ISONE

ARR: 78

FWD REV  
(Import) (Export)  
SCH - NE - NY 950 MW 1300 MW  
Impacts Total Transfer Capability 450 MW 300 MW  
TTC with All Lines In Service 1400 MW 1600 MW

## BERKSHIR-ALPS\_\_\_\_\_345\_393

Mon 05/18/2020 to Sat 05/30/2020  
0700 Continuous 1700  
Work scheduled by: ISONE

ARR: 78

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 100 MW 100 MW  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

## SCH-NE-NYISO\_LIMIT\_500

Mon 05/18/2020 to Mon 05/25/2020  
1100 Continuous 2359  
Work scheduled by: ISONE

FWD  
(Import)  
SCH - NE - NY 700 MW  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1400 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,January 13, 2020 to Wednesday,July 14, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NYISO-NE_LIMIT_600</b>						REV
Mon 05/18/2020	to	Sat 05/30/2020				(Export)
1100	Continuous	1459		SCH - NE - NY		<b>800 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability		800 MW
				TTC with All Lines In Service		1600 MW
<b>SCH-NE-NYISO_LIMIT_600</b>						FWD
Tue 05/26/2020	to	Sat 05/30/2020				(Import)
0001	Continuous	1459		SCH - NE - NY		<b>800 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability	600 MW	
				TTC with All Lines In Service	1400 MW	
<b>BERKSHIR-ALPS_____345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>						FWD REV
Sat 05/30/2020	to	Sat 05/30/2020				(Import) (Export)
1500		1700		SCH - NE - NY	<b>950 MW</b>	<b>1300 MW</b>
Work scheduled by: <b>ARR: 78</b>				Impacts Total Transfer Capability	450 MW	300 MW
				TTC with All Lines In Service	1400 MW	1600 MW
<b>BERKSHIR-NORTHFLD_345_312</b>						FWD REV
Sat 05/30/2020	to	Sat 05/30/2020				(Import) (Export)
1500	Continuous	1700		SCH - NE - NY	<b>900 MW</b>	<b>1500 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability	500 MW	100 MW
				TTC with All Lines In Service	1400 MW	1600 MW
<b>BERKSHIR-NORTHFLD_345_312</b>						FWD REV
Sat 05/30/2020	to	Sat 05/30/2020				(Import) (Export)
1500	Continuous	1700		SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability	100 MW	100 MW
				TTC with All Lines In Service	200 MW	200 MW
<b>SCH-NE-NYISO_LIMIT_500</b>						FWD
Sat 05/30/2020	to	Sat 05/30/2020				(Import)
1500	Continuous	1700		SCH - NE - NY	<b>700 MW</b>	
Work scheduled by: ISONE				Impacts Total Transfer Capability	700 MW	
				TTC with All Lines In Service	1400 MW	
<b>SCH-NYISO-NE_LIMIT_500</b>						REV
Sat 05/30/2020	to	Sat 05/30/2020				(Export)
1500	Continuous	1700		SCH - NE - NY		<b>700 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability		900 MW
				TTC with All Lines In Service		1600 MW

# NYISO TRANSFER LIMITATIONS

Monday ,January 13, 2020 to Wednesday, July 14, 2021

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5700MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 06/01/2020 to Tue 06/02/2020

0501 Continuous 1600

Work scheduled by: LI

SCH - NPX\_CSC

FWD REV  
(Import) (Export)

0 MW 0 MW

Impacts Total Transfer Capability 330 MW 330 MW

TTC with All Lines In Service 330 MW 330 MW

## MOSES-ADIRNDCK\_230\_MA2

Mon 06/01/2020 to Fri 07/31/2020

0700 Continuous 1730

Work scheduled by: NYPA

MOSES SOUTH

FWD  
(Import)

2100 MW

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

## NIAGARA\_345\_230\_AT4

Mon 06/29/2020 to Tue 06/30/2020

0500 Continuous 1530

Work scheduled by: NYPA

SCH - OH - NY

REV  
(Export)

1400 MW

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 1700 MW

## SCH-IMO-NYISO\_NIAG\_CB\_3008\_W/BB

Mon 07/27/2020 to Fri 08/07/2020

0500 Continuous 1530

Work scheduled by: NYPA

SCH - OH - NY

FWD REV  
(Import) (Export)

1900 MW 1450 MW

Impacts Total Transfer Capability 0 MW 250 MW

TTC with All Lines In Service 1900 MW 1700 MW

## CHATGUAY-MASSENA\_765\_7040

Sat 08/01/2020 to Sun 08/02/2020

0500 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 08/08/2019

MOSES SOUTH

FWD  
(Import)

1550 MW

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

## CHATGUAY-MASSENA\_765\_7040

Sat 08/01/2020 to Sun 08/02/2020

0500 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 08/08/2019

SCH - HQ - NY

FWD REV  
(Import) (Export)

0 MW 0 MW

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

## MARCY\_765\_345\_AT1

Sat 08/01/2020 to Sun 08/02/2020

0500 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 08/08/2019

MOSES SOUTH

FWD  
(Import)

1750 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

ARR: 19

**NYISO TRANSFER LIMITATIONS**

Monday ,January 13, 2020 to Wednesday, July 14, 2021

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5700MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA_-MARCY_____765_MSU1</b>						FWD	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	
0500	Continuous	1730				CENTRAL EAST - VC	<b>2265 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	710 MW
						TTC with All Lines In Service	2975 MW
<b>MASSENA_-MARCY_____765_MSU1</b>						FWD	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	
0500	Continuous	1730				MOSES SOUTH	<b>500 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY_____765_MSU1</b>						FWD	REV
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import) (Export)	
0500	Continuous	1730				SCH - HQ - NY	<b>475 MW 1000 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW 0 MW
						TTC with All Lines In Service	1500 MW 1000 MW
<b>MASSENA_-MARCY_____765_MSU1</b>						FWD	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	
0500	Continuous	1730				SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	190 MW
<b>MASSENA_-MARCY_____765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>						FWD	
Sat 08/01/2020	to	Sun 08/02/2020				(Import)	
0500		1730				MOSES SOUTH	<b>500 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
<b>MOSES____-MASSENA_230_MMS1 &amp; MOSES____-MASSENA_230_MMS2</b>						FWD	REV
Sat 08/01/2020	to	Sun 08/02/2020				(Import) (Export)	
0500		1730				SCH - HQ - NY	<b>850 MW 0 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	650 MW 1000 MW
						TTC with All Lines In Service	1500 MW 1000 MW
<b>MOSES____-MASSENA_230_MMS1 &amp; MOSES____-MASSENA_230_MMS2</b>						FWD	
Sat 08/01/2020	to	Sun 08/02/2020				(Import)	
0500		1730				SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	190 MW

# NYISO TRANSFER LIMITATIONS

Monday ,January 13, 2020 to Wednesday, July 14, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES\_\_\_230\_L33P &amp; MASSENA\_-MARCY\_\_\_765\_MSU1

Sat 08/01/2020 to Sun 08/02/2020  
0500 1730

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS **90 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 190 MW

STLAWRNC-MOSES\_\_\_230\_L33P &amp; MOSES\_\_\_-MASSENA\_230\_MMS1 &amp; MOSES\_\_\_-MASSENA\_230\_MMS2

Sat 08/01/2020 to Sun 08/02/2020  
0500 1730

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS **90 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 190 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 08/03/2020 to Sun 09/13/2020  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

FRASANNX-COOPERS\_\_\_345\_UCC2-41

Mon 09/07/2020 to Fri 10/23/2020  
0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 03/01/2019

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

MARCY\_\_\_-FRASANNX\_345\_UCC2-41

Mon 09/07/2020 to Fri 10/23/2020  
0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 03/01/2019

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

MARCY\_\_\_765\_345\_AT1

Mon 09/14/2020 to Mon 09/14/2020  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1750 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

NIAGARA\_-KINTIGH\_\_\_345\_NS1-38

Mon 09/14/2020 to Thu 09/17/2020  
0500 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,January 13, 2020 to Wednesday, July 14, 2021

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5700MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Tue 09/15/2020 to Sat 11/14/2020

(Import)

0700 Continuous 1530

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**NIAGARA\_-ROCHESTR\_345\_NR2**

FWD

Fri 09/18/2020 to Sat 11/14/2020

(Import)

0500 Continuous 2330

DYSINGER EAST

**1400 MW**

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**CLAY\_\_\_-EDIC\_\_\_345\_1-16**

FWD

Mon 09/21/2020 to Fri 09/25/2020

(Import)

0700 Continuous 1530

OSWEGO EXPORT

**4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ROSETON\_-ROCKTVRN\_345\_311**

FWD

Mon 09/21/2020 to Fri 10/23/2020

(Import)

0800 Continuous 1600

UPDATEDby CHGE10/09/2019

UPNY CONED

**4400 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: CHGE

**DUNWODIE\_345KV\_3**

FWD

Fri 09/25/2020 to Fri 09/25/2020

(Import)

0001 Continuous 0030

UPDATEDby CONED09/05/2019

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**DUNWODIE\_345KV\_5**

FWD

Fri 09/25/2020 to Fri 09/25/2020

(Import)

0001 Continuous 0030

UPDATEDby CONED09/05/2019

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**DUNWODIE-MOTTHAVN\_345\_71**

FWD

Fri 09/25/2020 to Fri 10/30/2020

(Import)

0001 Continuous 0300

UPDATEDby CONED09/05/2019

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Monday ,January 13, 2020 to Wednesday,July 14, 2021

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 5700MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CLAY\_\_\_\_-EDIC\_\_\_\_345\_2-15

Mon 09/28/2020 to Fri 10/02/2020

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

OSWEGO EXPORT

4850 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

## MOTTHAVN-RAINEY\_\_\_\_345\_Q11

Thu 10/01/2020 to Thu 11/05/2020

0001 Continuous 0200

Work scheduled by: ConEd

UPDATEDby CONED 12/17/2019

FWD

(Import)

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

## SAND\_BAR-PLATSBURG\_115\_PV20

Sat 10/17/2020 to Sat 11/14/2020

0600 Continuous 1800

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## LEEDS\_\_\_\_-HURLYAVE\_345\_301

Mon 10/26/2020 to Fri 12/04/2020

0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED

4100 MW

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 5700 MW

## DUNWODIE\_345KV\_3

Fri 10/30/2020 to Fri 10/30/2020

0230 Continuous 0300

Work scheduled by: ConEd

UPDATEDby CONED 09/05/2019

FWD

(Import)

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

## DUNWODIE\_345KV\_5

Fri 10/30/2020 to Fri 10/30/2020

0230 Continuous 0300

Work scheduled by: ConEd

UPDATEDby CONED 09/05/2019

FWD

(Import)

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

## SCH-IMO-NYISO\_LIMIT\_1750

Sun 11/01/2020 to Fri 04/30/2021

0001 Continuous 2359

Work scheduled by: IESO

UPDATEDby IESO 05/03/2019

FWD

(Import)

SCH - OH - NY

2050 MW

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 2050 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,January 13, 2020 to Wednesday, July 14, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-NYISO-IMO\_LIMIT\_1600**

REV

Sun 11/01/2020 to Fri 04/30/2021

UPDATEDby IESO05/03/2019

(Export)

0001 Continuous 2359

Work scheduled by: IESO

SCH - OH - NY

**1900 MW**

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

1900 MW

**CHATGUAY-MASSENA\_\_765\_7040**

FWD

Sun 11/15/2020 to Mon 11/30/2020

(Import)

0100 Continuous 1900

Work scheduled by: NYPA

MOSES SOUTH

**1550 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

**CHATGUAY-MASSENA\_\_765\_7040**

FWD

REV

Sun 11/15/2020 to Mon 11/30/2020

(Import) (Export)

0100 Continuous 1900

Work scheduled by: NYPA

SCH - HQ - NY

**0 MW****0 MW**

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

**MARCY\_\_765\_345\_AT1**

FWD

Sun 11/15/2020 to Mon 11/30/2020

(Import)

0100 Continuous 1900

Work scheduled by: NYPA

MOSES SOUTH

**1750 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

**ARR: 19****MARCY\_\_765\_345\_AT2**

FWD

Sun 11/15/2020 to Mon 11/30/2020

(Import)

0100 Continuous 1900

Work scheduled by: NYPA

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

**ARR: 19****MASSENA\_-MARCY\_\_765\_MSU1**

FWD

Sun 11/15/2020 to Mon 11/30/2020

(Import)

0100 Continuous 1900

Work scheduled by: NYPA

CENTRAL EAST - VC

**2265 MW**

Impacts Total Transfer Capability 710 MW

TTC with All Lines In Service 2975 MW

**MASSENA\_-MARCY\_\_765\_MSU1**

FWD

Sun 11/15/2020 to Mon 11/30/2020

(Import)

0100 Continuous 1900

Work scheduled by: NYPA

MOSES SOUTH

**500 MW**

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,January 13, 2020 to Wednesday,July 14, 2021

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5700MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA_-MARCY_765_MSU1</b>	FWD	REV
Sun 11/15/2020 to Mon 11/30/2020	(Import)	(Export)
0100 Continuous 1900	SCH - HQ - NY	<b>475 MW 1000 MW</b>
Work scheduled by: NYPA	Impacts Total Transfer Capability	1025 MW 0 MW
	TTC with All Lines In Service	1500 MW 1000 MW
<b>MASSENA_-MARCY_765_MSU1</b>	FWD	
Sun 11/15/2020 to Mon 11/30/2020	(Import)	
0100 Continuous 1900	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by: NYPA	Impacts Total Transfer Capability	109 MW
	TTC with All Lines In Service	199 MW
<b>MASSENA_-MARCY_765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>	FWD	
Sun 11/15/2020 to Mon 11/30/2020	(Import)	
0100 1900	MOSES SOUTH	<b>500 MW</b>
Work scheduled by:	Impacts Total Transfer Capability	2650 MW
	TTC with All Lines In Service	3150 MW
<b>MOSES_-MASSENA_230_MMS1 &amp; MOSES_-MASSENA_230_MMS2</b>	FWD	REV
Sun 11/15/2020 to Mon 11/30/2020	(Import)	(Export)
0100 1900	SCH - HQ - NY	<b>850 MW 0 MW</b>
Work scheduled by:	Impacts Total Transfer Capability	650 MW 1000 MW
	TTC with All Lines In Service	1500 MW 1000 MW
<b>MOSES_-MASSENA_230_MMS1 &amp; MOSES_-MASSENA_230_MMS2</b>	FWD	
Sun 11/15/2020 to Mon 11/30/2020	(Import)	
0100 1900	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:	Impacts Total Transfer Capability	109 MW
	TTC with All Lines In Service	199 MW
<b>STLAWRNC-MOSES_230_L33P &amp; MASSENA_-MARCY_765_MSU1</b>	FWD	
Sun 11/15/2020 to Mon 11/30/2020	(Import)	
0100 1900	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:	Impacts Total Transfer Capability	109 MW
	TTC with All Lines In Service	199 MW
<b>STLAWRNC-MOSES_230_L33P &amp; MOSES_-MASSENA_230_MMS1 &amp; MOSES_-MASSENA_230_MMS2</b>	FWD	
Sun 11/15/2020 to Mon 11/30/2020	(Import)	
0100 1900	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:	Impacts Total Transfer Capability	109 MW
	TTC with All Lines In Service	199 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,January 13, 2020 to Wednesday,July 14, 2021

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5700MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLE-DUNWODIE\_345\_W89**

FWD

Mon 11/16/2020 to Mon 11/16/2020

(Import)

0001 Continuous 0030

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**PLSNTVLE-DUNWODIE\_345\_W89**

FWD

Thu 11/26/2020 to Thu 11/26/2020

(Import)

0230 Continuous 0300

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1700 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**MOSES\_\_-ADIRNDCK\_230\_MAl**

FWD

Tue 12/01/2020 to Mon 05/31/2021

(Import)

0700 Continuous 1300

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 12/07/2020 to Fri 12/11/2020

0700 Continuous 1530

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYPA

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 12/14/2020 to Fri 12/18/2020

0700 Continuous 1530

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYPA

**HOPATCON-RAMAPO\_\_500\_5018**

FWD

REV

Mon 02/01/2021 to Wed 02/03/2021

(Import) (Export)

0001 Continuous 2200

SCH - PJ - NY

**1250 MW 1200 MW**

Impacts Total Transfer Capability 1650 MW 650 MW

TTC with All Lines In Service 2900 MW 1850 MW

Work scheduled by: ConEd

**HOPATCON-RAMAPO\_\_500\_5018**

FWD

Mon 02/01/2021 to Wed 02/03/2021

(Import)

0001 Continuous 2200

UPNY CONED

**5000 MW**

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

**NYISO TRANSFER LIMITATIONS**

Monday ,January 13, 2020 to Wednesday, July 14, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>RAMAPO___345_345_PAR3500</b>			FWD	REV
Mon 02/01/2021	to	Wed 02/03/2021	(Import)	(Export)
0001	Continuous	2200	SCH - PJ - NY	<b>2150 MW 1250 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	750 MW 600 MW
			TTC with All Lines In Service	2900 MW 1850 MW
<b>RAMAPO___345_345_PAR4500</b>			FWD	REV
Mon 02/01/2021	to	Wed 02/03/2021	(Import)	(Export)
0001	Continuous	2200	SCH - PJ - NY	<b>2150 MW 1250 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	750 MW 600 MW
			TTC with All Lines In Service	2900 MW 1850 MW
<b>RAMAPO___500_345_BK 1500</b>			FWD	REV
Mon 02/01/2021	to	Wed 02/03/2021	(Import)	(Export)
0001	Continuous	2200	SCH - PJ - NY	<b>1250 MW 1200 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	1650 MW 650 MW
			TTC with All Lines In Service	2900 MW 1850 MW
<b>RAMAPO___500_345_BK 1500</b>			FWD	
Mon 02/01/2021	to	Wed 02/03/2021	(Import)	
0001	Continuous	2200	UPNY CONED	<b>5000 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	700 MW
			TTC with All Lines In Service	5700 MW
<b>DUNWODIE_345KV_3</b>			FWD	
Mon 03/01/2021	to	Mon 03/01/2021	(Import)	
0001	Continuous	0030	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_5</b>			FWD	
Mon 03/01/2021	to	Mon 03/01/2021	(Import)	
0001	Continuous	0030	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
<b>DUNWODIE-MOTTHAVN_345_71</b>			FWD	
Mon 03/01/2021	to	Mon 04/05/2021	(Import)	
0001	Continuous	0300	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,January 13, 2020 to Wednesday, July 14, 2021

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5700MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOTTHAVN-RAINEY\_\_\_345\_Q11**

FWD

Mon 03/01/2021 to Tue 04/06/2021

(Import)

0001 Continuous 0700

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**CLAY\_\_\_-EDIC\_\_\_345\_2-15**

FWD

Mon 03/29/2021 to Fri 04/16/2021

(Import)

0800 Continuous 1730

OSWEGO EXPORT

**4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**DUNWODIE\_345KV\_3**

FWD

Mon 04/05/2021 to Mon 04/05/2021

(Import)

0230 Continuous 0300

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**DUNWODIE\_345KV\_5**

FWD

Mon 04/05/2021 to Mon 04/05/2021

(Import)

0230 Continuous 0300

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**SCH-IMO-NYISO\_LIMIT\_1600**

FWD

Sat 05/01/2021 to Sun 10/31/2021

(Import)

0001 Continuous 2359

**UPDATED by IESO 05/03/2019**

SCH - OH - NY

**1900 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 1900 MW

Work scheduled by: IESO

**PANNELL\_-CLAY\_\_\_345\_2**

FWD

Mon 05/03/2021 to Fri 05/28/2021

(Import)

0700 Continuous 1730

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Tue 06/01/2021 to Sun 11/14/2021

(Import)

0700 Continuous 1300

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA