

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Fri 05/01/2020 **EXTENDED** by **CONED** **10/08/2019**
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Fri 05/01/2020
 0001 2359
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1600 MW
Impacts Total Transfer Capability	350 MW	250 MW
TTC with All Lines In Service	2900 MW	1850 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Fri 05/01/2020 **EXTENDED** by **CONED** **10/08/2019**
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

STLAWRNC-MOSES_230_L33P

Mon 04/30/2018 to Fri 12/31/2021 **EXT FORCE** by **IESO** **08/21/2018**
 0456 Continuous 2359
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

SCH-IMO-NYISO_LIMIT_1750

Fri 11/01/2019 to Thu 04/30/2020 **UPDATED** by **IESO** **05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

	FWD
	(Import)
SCH - OH - NY	2050 MW
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	2050 MW

SCH-NYISO-IMO_LIMIT_1600

Fri 11/01/2019 to Thu 04/30/2020 **UPDATED** by **IESO** **05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

	REV
	(Export)
SCH - OH - NY	1900 MW
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	1900 MW

SCH-NYISO-NE_LIMIT_1500

Fri 11/01/2019 to Thu 04/30/2020
 0001 Continuous 2359
 Work scheduled by: NYISO

	REV
	(Export)
SCH - NE - NY	1700 MW
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	1700 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

OSWEGO_COMPLEX_AVR_O/S					FWD	
Mon 11/18/2019	to	Mon 03/09/2020	<u>EXT FORCE</u>	<u>by GEN</u>	<u>12/26/2019</u>	(Import)
0221	Continuous	0001				CENTRAL EAST - VC 2870 MW
Work scheduled by: Gen					Impacts Total Transfer Capability	105 MW
					TTC with All Lines In Service	2975 MW
DUNWODIE_345KV_6					FWD	
Tue 12/03/2019	to	Thu 02/06/2020	<u>EXT FORCE</u>	<u>by CONED</u>	<u>12/27/2019</u>	(Import)
0048	Continuous	2359				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8					FWD	
Tue 12/03/2019	to	Thu 02/06/2020	<u>EXT FORCE</u>	<u>by CONED</u>	<u>12/27/2019</u>	(Import)
0048	Continuous	2359				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
PLSNTVLE-DUNWODIE_345_W90					FWD	
Tue 12/03/2019	to	Thu 02/06/2020	<u>EXT FORCE</u>	<u>by CONED</u>	<u>12/27/2019</u>	(Import)
0107	Continuous	2359				UPNY CONED 4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1700 MW
					TTC with All Lines In Service	5700 MW
CHAT_DC_GC2					FWD	
Thu 12/26/2019	to	Thu 01/30/2020	<u>EXTENDED</u>	<u>by HQ</u>	<u>01/13/2020</u>	(Import)
1827	Continuous	2359				MOSES SOUTH 2850 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
CHAT_DC_GC2					REV	
Thu 12/26/2019	to	Thu 01/30/2020	<u>EXTENDED</u>	<u>by HQ</u>	<u>01/13/2020</u>	(Export)
1827	Continuous	2359				SCH - HQ - NY 500 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
SCH-HQ-NYISO_LIMIT_1200					FWD	
Fri 01/03/2020	to	Thu 01/30/2020	<u>EXTENDED</u>	<u>by HQ</u>	<u>01/13/2020</u>	(Import)
1430	Continuous	2359				SCH - HQ - NY 1200 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PIERCBRK-FIVEMILE_345_37					FWD	
Mon 01/06/2020	to	Fri 01/10/2020			(Import)	
0800	Continuous	1600		SCH - PJ - NY	2400 MW	
Work scheduled by: NGrid					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	2900 MW
<hr/>						
S.RIPLEY-DUNKIRK_230_68						
Mon 01/06/2020	to	Fri 01/10/2020				
0800	Continuous	1600		SCH - PJ - NY		
Work scheduled by: NGrid					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<hr/>						
FROST_BR-LONG_MTN_345_352					FWD	
Tue 01/07/2020	to	Fri 01/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>01/14/2020</u>	(Import)
0700	Continuous	1600				
Work scheduled by: ISONE					SCH - NE - NY	1300 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1400 MW
<hr/>						
SCH-NE-NYISO_LIMIT_300					FWD	
Tue 01/07/2020	to	Fri 01/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>01/14/2020</u>	(Import)
0900	Continuous	1600				
Work scheduled by: ISONE					SCH - NE - NY	500 MW
					Impacts Total Transfer Capability	900 MW
					TTC with All Lines In Service	1400 MW
<hr/>						
FRASER_345_FRASER SVC					FWD	
Mon 01/13/2020	to	Mon 01/27/2020	<u>UPDATED</u>	<u>by NYSEG</u>	<u>12/18/2019</u>	(Import)
0800	Continuous	1500				
Work scheduled by: NYSEG					CENTRAL EAST - VC	2935 MW
					Impacts Total Transfer Capability	40 MW
					TTC with All Lines In Service	2975 MW
<hr/>						
SAND_BAR-PLATSBRG_115_PV20						
Tue 01/14/2020	to	Tue 01/14/2020				
0700	Continuous	1830		SCH - NE - NY		
Work scheduled by: NYPA					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<hr/>						
BECK_-NIAGARA_345_PA301					FWD	REV
Wed 01/15/2020	to	Fri 01/17/2020	<u>EXTENDED</u>	<u>by NYPA</u>	<u>01/14/2020</u>	(Import) (Export)
0500	Continuous	2100				
Work scheduled by: NYPA					SCH - OH - NY	1100 MW 950 MW
					Impacts Total Transfer Capability	950 MW 950 MW
					TTC with All Lines In Service	2050 MW 1900 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FROST_BR-LONG_MTN_345_352				FWD
Mon 01/20/2020	to	Thu 01/23/2020	UPDATED	(Import)
0100	Continuous	1600	by ISONE 01/14/2020	1300 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability 100 MW
				TTC with All Lines In Service 1400 MW
SCH-NE-NYISO_LIMIT_300				FWD
Mon 01/20/2020	to	Thu 01/23/2020	UPDATED	(Import)
0100	Continuous	1600	by ISONE 01/14/2020	500 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability 900 MW
				TTC with All Lines In Service 1400 MW
SCH-NE-NYISO_LIMIT_500				FWD
Wed 01/22/2020	to	Wed 01/29/2020		(Import)
0500	Continuous	1300		700 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability 700 MW
				TTC with All Lines In Service 1400 MW
SCH-NYISO-NE_LIMIT_1200				REV
Wed 01/22/2020	to	Wed 01/29/2020		(Export)
0500	Continuous	1300		1400 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability 300 MW
				TTC with All Lines In Service 1700 MW
RAMAPO__-BUCHAN_N_345_Y94				FWD
Mon 02/03/2020	to	Tue 02/04/2020		(Import)
0001	Continuous	0230		4800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 900 MW
				TTC with All Lines In Service 5700 MW
PLSNTVLY_345KV_RNS4				FWD
Mon 02/03/2020	to	Tue 02/04/2020		(Import)
0001	Continuous	2200		3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1900 MW
				TTC with All Lines In Service 5700 MW
MOSES__-ADIRNDCK_230_MAL				FWD
Mon 02/03/2020	to	Fri 02/07/2020		(Import)
0700	Continuous	1530		2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EFISHKIL-WOOD_ST__345_F39				FWD
Mon 02/10/2020	to	Mon 02/10/2020		(Import)
0001	Continuous	0030	UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1700 MW
				TTC with All Lines In Service 5700 MW
WOOD_ST_-PLSNTVLE_345_Y87				FWD
Mon 02/10/2020	to	Wed 02/12/2020		(Import)
0001	Continuous	0030	UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1700 MW
				TTC with All Lines In Service 5700 MW
MOSES__-ADIRNDCK_230_MA1				FWD
Mon 02/10/2020	to	Fri 02/14/2020		(Import)
0700	Continuous	1530	MOSES SOUTH	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
HURLYAVE-ROSETON__345_303				FWD
Tue 02/11/2020	to	Thu 02/13/2020		(Import)
0700	Continuous	1600	UPNY CONED	4100 MW
Work scheduled by: CHGE				Impacts Total Transfer Capability 1600 MW
				TTC with All Lines In Service 5700 MW
EFISHKIL-WOOD_ST__345_F39				FWD
Wed 02/12/2020	to	Wed 02/12/2020		(Import)
0001	Continuous	0030	UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1700 MW
				TTC with All Lines In Service 5700 MW
EFISHKIL-WOOD_ST__345_F38				FWD
Fri 02/14/2020	to	Sat 02/15/2020	UPDATED by CONED 01/15/2020	(Import)
0001	Continuous	0030	UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1700 MW
				TTC with All Lines In Service 5700 MW
WOOD_ST_-PLSNTVLE_345_Y86				FWD
Fri 02/14/2020	to	Sat 02/15/2020	UPDATED by CONED 01/15/2020	(Import)
0001	Continuous	0030	UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1700 MW
				TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-TREMONT__345_X28					FWD
Mon 02/17/2020	to	Mon 02/17/2020	UPDATED	by CONED	12/05/2019
0001	Continuous	1800			
Work scheduled by: ConEd					(Import)
					SPR/DUN-SOUTH 4200 MW
					Impacts Total Transfer Capability 400 MW
					TTC with All Lines In Service 4600 MW
WATRCURE-OAKDALE__345_31					FWD
Mon 02/17/2020	to	Mon 02/17/2020	UPDATED	by NYSEG	12/20/2019
1500	Continuous	1530			
Work scheduled by: NYSEG					(Import)
					SCH - PJ - NY 2750 MW
					Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service 2900 MW
PLSNTVLY-WOOD_ST__345_F30					FWD
Tue 02/18/2020	to	Sat 02/29/2020	CANCELLED	by ConEd	01/15/2020
0001	Continuous	2200			
Work scheduled by: ConEd					(Import)
					UPNY CONED 4000 MW
					Impacts Total Transfer Capability 1700 MW
					TTC with All Lines In Service 5700 MW
PLSNTVLY_345KV_RNS5					FWD
Tue 02/18/2020	to	Sat 02/29/2020	CANCELLED	by ConEd	01/15/2020
0001	Continuous	2200			
Work scheduled by: ConEd					(Import)
					UPNY CONED 3800 MW
					Impacts Total Transfer Capability 1900 MW
					TTC with All Lines In Service 5700 MW
MOSES__-ADIRNDCK_230_MAI					FWD
Tue 02/18/2020	to	Fri 02/21/2020			
0700	Continuous	1530			
Work scheduled by: NYPA					(Import)
					MOSES SOUTH 2300 MW
					Impacts Total Transfer Capability 850 MW
					TTC with All Lines In Service 3150 MW
SPRNBK__345KV_RNS5					FWD
Mon 02/24/2020	to	Mon 02/24/2020			
0001	Continuous	0030			
Work scheduled by: ConEd					(Import)
					SPR/DUN-SOUTH 3200 MW
					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
SPRNBK_-W49TH_ST_345_M51					FWD
Mon 02/24/2020	to	Sun 03/01/2020			
0001	Continuous	0200			
Work scheduled by: ConEd					(Import)
					SPR/DUN-SOUTH 3200 MW
					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK__345KV_RNS5					FWD
Wed 02/26/2020	to	Wed 02/26/2020			(Import)
2130	Continuous	2200		SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
SPRNBRK__345KV_RNS5					FWD
Thu 02/27/2020	to	Sun 03/01/2020			(Import)
2301	Continuous	0200		SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
NIAGARA_-PACKARD__230_62					FWD REV
Fri 02/28/2020	to	Fri 02/28/2020			(Import) (Export)
0500	Continuous	1530		SCH - OH - NY	900 MW 1850 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1150 MW 50 MW
					TTC with All Lines In Service 2050 MW 1900 MW
DUNWODIE_345KV_4					FWD
Sun 03/01/2020	to	Sun 03/08/2020			(Import)
0001	Continuous	2200		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
CHATGUAY-MASSENA__765_7040					FWD
Mon 03/02/2020	to	Fri 03/06/2020	UPDATED	by NYPA	08/08/2019
0500	Continuous	1730			(Import)
Work scheduled by: NYPA					MOSES SOUTH 1550 MW
					Impacts Total Transfer Capability 1600 MW
					TTC with All Lines In Service 3150 MW
CHATGUAY-MASSENA__765_7040					FWD REV
Mon 03/02/2020	to	Fri 03/06/2020	UPDATED	by NYPA	08/08/2019
0500	Continuous	1730			(Import) (Export)
Work scheduled by: NYPA					SCH - HQ - NY 0 MW 0 MW
					Impacts Total Transfer Capability 1500 MW 1000 MW
					TTC with All Lines In Service 1500 MW 1000 MW
MARCY____765_345_AT1					FWD
Mon 03/02/2020	to	Fri 03/06/2020	UPDATED	by NYPA	08/08/2019
0500	Continuous	1730			(Import)
Work scheduled by: NYPA					MOSES SOUTH 1750 MW
					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 3150 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2					FWD
Mon 03/02/2020	to	Fri 03/06/2020			(Import)
0500	Continuous	1730			MOSES SOUTH 1700 MW
Work scheduled by: NYPA			ARR: 19		Impacts Total Transfer Capability 1450 MW
					TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1					FWD
Mon 03/02/2020	to	Fri 03/06/2020	UPDATED	by NYPA	08/08/2019
0500	Continuous	1730			(Import)
Work scheduled by: NYPA					CENTRAL EAST - VC 2265 MW
					Impacts Total Transfer Capability 710 MW
					TTC with All Lines In Service 2975 MW
MASSENA_-MARCY___765_MSU1					FWD
Mon 03/02/2020	to	Fri 03/06/2020	UPDATED	by NYPA	08/08/2019
0500	Continuous	1730			(Import)
Work scheduled by: NYPA					MOSES SOUTH 500 MW
					Impacts Total Transfer Capability 2650 MW
					TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1					FWD
Mon 03/02/2020	to	Fri 03/06/2020	UPDATED	by NYPA	08/08/2019
0500	Continuous	1730			(Import) (Export)
Work scheduled by: NYPA					SCH - HQ - NY 475 MW 1000 MW
					Impacts Total Transfer Capability 1025 MW 0 MW
					TTC with All Lines In Service 1500 MW 1000 MW
MASSENA_-MARCY___765_MSU1					FWD
Mon 03/02/2020	to	Fri 03/06/2020	UPDATED	by NYPA	08/08/2019
0500	Continuous	1730			(Import)
Work scheduled by: NYPA					SCH - HQ_CEDARS 90 MW
					Impacts Total Transfer Capability 109 MW
					TTC with All Lines In Service 199 MW
MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040					FWD
Mon 03/02/2020	to	Fri 03/06/2020			(Import)
0500		1730			MOSES SOUTH 500 MW
Work scheduled by:					Impacts Total Transfer Capability 2650 MW
					TTC with All Lines In Service 3150 MW
MOSES___-MASSENA_230_MMS1 & MOSES___-MASSENA_230_MMS2					FWD
Mon 03/02/2020	to	Fri 03/06/2020			(Import) (Export)
0500		1730			SCH - HQ - NY 850 MW 0 MW
Work scheduled by:					Impacts Total Transfer Capability 650 MW 1000 MW
					TTC with All Lines In Service 1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2		FWD	
Mon 03/02/2020	to Fri 03/06/2020	(Import)	
0500	1730	SCH - HQ_CEDARS	90 MW
Work scheduled by:		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1		FWD	
Mon 03/02/2020	to Fri 03/06/2020	(Import)	
0500	1730	SCH - HQ_CEDARS	90 MW
Work scheduled by:		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW
STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2		FWD	
Mon 03/02/2020	to Fri 03/06/2020	(Import)	
0500	1730	SCH - HQ_CEDARS	90 MW
Work scheduled by:		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW
SHOR_NPX-SHOREHAM 138_CSC		FWD	REV
Mon 03/02/2020	to Tue 03/03/2020	(Import)	(Export)
0600	Continuous 1300	SCH - NPX_CSC	0 MW 0 MW
Work scheduled by: LI		Impacts Total Transfer Capability	330 MW 330 MW
		TTC with All Lines In Service	330 MW 330 MW
ROSETON -EFISHKIL 345_RFK305		FWD	
Mon 03/02/2020	to Fri 03/20/2020	(Import)	
0700	Continuous 1730	UPNY CONED	4800 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	900 MW
		TTC with All Lines In Service	5700 MW
EASTVIEW-SPRNBK 345_W78		FWD	
Fri 03/06/2020	to Sat 03/07/2020	(Import)	
0001	Continuous 0200	UPNY CONED	4350 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	1350 MW
		TTC with All Lines In Service	5700 MW
MILLWOOD-EASTVIEW 345_W85		FWD	
Fri 03/06/2020	to Sat 03/07/2020	(Import)	
0001	Continuous 0200	UPNY CONED	4350 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	1350 MW
		TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			FWD
SPRNBK__345KV_RNS3			(Import)
Fri 03/06/2020	to	Sat 03/07/2020	
0001	Continuous	0200	SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 4600 MW
<hr/>			FWD
MOSES__-ADIRNDCK_230_MAI			(Import)
Sat 03/07/2020	to	Fri 05/29/2020	
0700	Continuous	1300	MOSES SOUTH 2300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 850 MW
			TTC with All Lines In Service 3150 MW
<hr/>			FWD
W49TH_ST_345KV_5			(Import)
Mon 03/09/2020	to	Mon 03/09/2020	
0001	Continuous	0030	SCH - PJM_HTP 350 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 310 MW
			TTC with All Lines In Service 660 MW
<hr/>			FWD
SPRNBK_-W49TH_ST_345_M52			(Import)
Mon 03/09/2020	to	Wed 03/11/2020	
0001	Continuous	2200	SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
<hr/>			FWD
SPRNBK__345KV_RNS4			(Import)
Mon 03/09/2020	to	Wed 03/11/2020	
0001	Continuous	2200	SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
<hr/>			FWD
SCH-NE-NYISO_LIMIT_500			(Import)
Mon 03/09/2020	to	Fri 04/03/2020	
0700	Continuous	1600	SCH - NE - NY 700 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability 700 MW
			TTC with All Lines In Service 1400 MW
<hr/>			REV
SCH-NYISO-NE_LIMIT_1200			(Export)
Mon 03/09/2020	to	Fri 04/03/2020	
0700	Continuous	1600	SCH - NE - NY 1400 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability 300 MW
			TTC with All Lines In Service 1700 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
VOLNEY -MARCY 345_19			FWD
Tue 03/10/2020	to Tue 03/10/2020	UPDATED by NYPA 09/24/2019	(Import)
0700	Continuous	1530	CENTRAL EAST - VC 2825 MW
Work scheduled by: NYPA		ARR: 19	Impacts Total Transfer Capability 150 MW
			TTC with All Lines In Service 2975 MW
<hr/>			
VOLNEY -MARCY 345_19			FWD
Tue 03/10/2020	to Tue 03/10/2020	UPDATED by NYPA 09/24/2019	(Import)
0700	Continuous	1530	OSWEGO EXPORT 4900 MW
Work scheduled by: NYPA		ARR: 19	Impacts Total Transfer Capability 350 MW
			TTC with All Lines In Service 5250 MW
<hr/>			
W49TH_ST_345KV_5			FWD
Wed 03/11/2020	to Wed 03/11/2020		(Import)
2130	Continuous	2200	SCH - PJM_HTP 350 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 310 MW
			TTC with All Lines In Service 660 MW
<hr/>			
ROCHESTR-PANNELL 345_RP2			FWD
Sat 03/14/2020	to Mon 03/23/2020		(Import)
0500	Continuous	1700	DYSINGER EAST 2300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 850 MW
			TTC with All Lines In Service 3150 MW
<hr/>			
MARCY 345KV_CSC			FWD
Mon 03/16/2020	to Fri 03/27/2020		(Import)
0500	Continuous	1730	CENTRAL EAST - VC 2925 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 50 MW
			TTC with All Lines In Service 2975 MW
<hr/>			
CHASLAKE-PORTER 230_11			FWD
Wed 03/18/2020	to Wed 03/18/2020		(Import)
0630	Daily(No Weekends)	1330	MOSES SOUTH 2300 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability 850 MW
			TTC with All Lines In Service 3150 MW
<hr/>			
SCH-NYISO-NE_LIMIT_900			REV
Wed 03/18/2020	to Tue 03/31/2020		(Export)
0700	Continuous	2359	SCH - NE - NY 1100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability 600 MW
			TTC with All Lines In Service 1700 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_N-EASTVIEW_345_W93					FWD
Thu 03/19/2020	to	Thu 03/19/2020			(Import)
0200	Continuous	0230		UPNY CONED	4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1350 MW
					TTC with All Lines In Service 5700 MW
EASTVIEW-SPRNBK__345_W79					FWD
Thu 03/19/2020	to	Fri 03/20/2020			(Import)
0200	Continuous	0200		UPNY CONED	4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1350 MW
					TTC with All Lines In Service 5700 MW
BUCHAN_N-EASTVIEW_345_W93					FWD
Fri 03/20/2020	to	Fri 03/20/2020			(Import)
0130	Continuous	0200		UPNY CONED	4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1350 MW
					TTC with All Lines In Service 5700 MW
EASTVIEW-SPRNBK__345_W64					FWD
Sat 03/21/2020	to	Sat 03/21/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>12/05/2019</u>
0001	Continuous	0030			(Import)
Work scheduled by: ConEd					UPNY CONED 4350 MW
					Impacts Total Transfer Capability 1350 MW
					TTC with All Lines In Service 5700 MW
SPRNBK__345KV_RNS5					FWD
Sat 03/21/2020	to	Sat 03/21/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>12/05/2019</u>
0001	Continuous	0030			(Import)
Work scheduled by: ConEd					SPR/DUN-SOUTH 3200 MW
					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
MILLWOOD-EASTVIEW_345_W99					FWD
Sat 03/21/2020	to	Sun 03/22/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>12/05/2019</u>
0001	Continuous	0200			(Import)
Work scheduled by: ConEd					UPNY CONED 4350 MW
					Impacts Total Transfer Capability 1350 MW
					TTC with All Lines In Service 5700 MW
EASTVIEW-SPRNBK__345_W64					FWD
Sun 03/22/2020	to	Sun 03/22/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>12/05/2019</u>
0130	Continuous	0200			(Import)
Work scheduled by: ConEd					UPNY CONED 4350 MW
					Impacts Total Transfer Capability 1350 MW
					TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						
SPRNBK__345KV_RNS5					FWD	
Sun 03/22/2020	to	Sun 03/22/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>12/05/2019</u>	(Import)
0130	Continuous	0200				3200 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 4600 MW
<hr/>						
MILLWOOD-EASTVIEW_345_W85					FWD	
Sun 03/22/2020	to	Sun 03/22/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	(Import)
0201	Continuous	0231				4350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1350 MW
						TTC with All Lines In Service 5700 MW
<hr/>						
DUNWODIE-MOTTHAVN_345_72					FWD	
Sun 03/22/2020	to	Tue 03/24/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	(Import)
0201	Continuous	0200				3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<hr/>						
DUNWODIE_345KV_8					FWD	
Sun 03/22/2020	to	Tue 03/24/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	(Import)
0201	Continuous	0200				3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<hr/>						
EASTVIEW-SPRNBK__345_W78					FWD	
Sun 03/22/2020	to	Tue 03/24/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	(Import)
0201	Continuous	0200				4350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1350 MW
						TTC with All Lines In Service 5700 MW
<hr/>						
DUNWODIE_345KV_5					FWD	
Sun 03/22/2020	to	Mon 05/11/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	(Import)
0201	Continuous	0300				3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<hr/>						
DUNWODIE_345KV_7					FWD	
Sun 03/22/2020	to	Mon 05/11/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	(Import)
0201	Continuous	0300				3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-DUNWODIE_345_W75					FWD	
Sun 03/22/2020	to	Mon 05/11/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	(Import)
0201	Continuous	0300				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
SPRNBK_345KV_RNS3					FWD	
Sun 03/22/2020	to	Mon 05/11/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	(Import)
0201	Continuous	0300				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
RAMAPO_-BUCHAN_N_345_Y94					FWD	
Tue 03/24/2020	to	Tue 03/24/2020				(Import)
0001	Continuous	0030				4800 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	900 MW
					TTC with All Lines In Service	5700 MW
MILLWOOD-EASTVIEW_345_W85					FWD	
Tue 03/24/2020	to	Tue 03/24/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	(Import)
0130	Continuous	0200				4350 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW
DUNWODIE-MOTTHAVN_345_71					FWD	
Tue 03/24/2020	to	Thu 03/26/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	(Import)
0201	Continuous	0200				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_3					FWD	
Tue 03/24/2020	to	Thu 03/26/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	(Import)
0201	Continuous	0200				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
RAMAPO_-BUCHAN_N_345_Y94					FWD	
Tue 03/24/2020	to	Tue 03/24/2020				(Import)
0630	Continuous	0700				4800 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	900 MW
					TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4
 Thu 03/26/2020 to Sun 03/29/2020
 0201 0200

Work scheduled by:

FWD
 (Import)
SPR/DUN-SOUTH 3800 MW
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NIAGARA_-KINTIGH__345_NS1-38
 Fri 03/27/2020 to Fri 03/27/2020
 0600 Continuous 1530

Work scheduled by: NYPA

FWD
 (Import)
DYSINGER EAST 1700 MW
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

BECK__-PACKARD__230_BP76
 Fri 03/27/2020 to Fri 03/27/2020
 0800 Daily(No Weekends) 1600

Work scheduled by: NGrid

FWD REV
 (Import) (Export)
SCH - OH - NY 1650 MW 1400 MW
 Impacts Total Transfer Capability 400 MW 500 MW
 TTC with All Lines In Service 2050 MW 1900 MW

MARCY__-EDIC__345_UE1-7
 Tue 03/31/2020 to Tue 03/31/2020
 0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 09/24/2019

ARR: 19&16

FWD
 (Import)
OSWEGO EXPORT 5250 MW
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

RAMAPO__-LADENTWN_345_W72
 Wed 04/01/2020 to Thu 04/02/2020
 0001 Continuous 1830

Work scheduled by: ConEd

FWD
 (Import)
UPNY CONED 4400 MW
 Impacts Total Transfer Capability 1300 MW
 TTC with All Lines In Service 5700 MW

SCH-NYISO-NE_LIMIT_700
 Wed 04/01/2020 to Fri 04/03/2020
 0001 Continuous 1600

Work scheduled by: ISONE

REV
 (Export)
SCH - NE - NY 900 MW
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 1700 MW

FRASANNX-COOPERS__345_UCC2-41
 Wed 04/01/2020 to Thu 04/02/2020
 0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 11/12/2019

ARR: 19

FWD
 (Import)
CENTRAL EAST - VC 2500 MW
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY -FRASANNX_345_UCC2-41					FWD	
Wed 04/01/2020	to	Thu 04/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/12/2019</u>	(Import)
0700	Continuous	1530				CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA					ARR: 19	Impacts Total Transfer Capability 475 MW
						TTC with All Lines In Service 2975 MW
LINDN_CG-LNDVFT_345_V-3022					FWD	
Sun 04/05/2020	to	Sat 04/11/2020				(Import) (Export)
1400	Continuous	1400				SCH - PJM_VFT 0 MW 0 MW
Work scheduled by: PJM						Impacts Total Transfer Capability 315 MW 315 MW
						TTC with All Lines In Service 315 MW 315 MW
MARCY -N.SCTLND_345_18					FWD	
Tue 04/07/2020	to	Wed 04/08/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/24/2019</u>	(Import)
0700	Continuous	1530				CENTRAL EAST - VC 2090 MW
Work scheduled by: NYPA					ARR: 19	Impacts Total Transfer Capability 885 MW
						TTC with All Lines In Service 2975 MW
PLSNTVLY-EFISHKIL_345_F36					FWD	
Mon 04/13/2020	to	Tue 04/14/2020				(Import)
0001	Continuous	0200				UPNY CONED 4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1700 MW
						TTC with All Lines In Service 5700 MW
SAND_BAR-PLATSBRG_115_PV20					FWD	
Mon 04/13/2020	to	Tue 04/14/2020				(Import)
0600	Daily	1800				SCH - NE - NY
Work scheduled by: ISONE						Impacts Total Transfer Capability
						TTC with All Lines In Service
FRASER -GILBOA_345_GF5-35					FWD	
Mon 04/13/2020	to	Wed 04/22/2020				(Import)
0700	Continuous	1730				CENTRAL EAST - VC 2650 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 325 MW
						TTC with All Lines In Service 2975 MW
NIAGARA -ROCHESTR_345_NR2					FWD	
Wed 04/15/2020	to	Fri 05/01/2020				(Import)
0500	Continuous	1700				DYSINGER EAST 1700 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1450 MW
						TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCHESTR-PANNELL__345_RP1

Mon 04/20/2020 to Fri 04/24/2020
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

DOLSONAV-ROCKTVRN_345_DART44

Mon 04/27/2020 to Sun 05/10/2020
0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 03/21/2019

FWD
(Import)
CENTRAL EAST - VC **2720 MW**
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 2975 MW

HURLYAVE-ROSETON__345_303

Mon 04/27/2020 to Fri 05/29/2020
0800 Continuous 1600

Work scheduled by: CHGE

UPDATED by CHGE 10/09/2019

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 5700 MW

DUNWODIE-MOTTHAVN_345_72

Tue 04/28/2020 to Sat 05/02/2020
0200 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W85

Wed 04/29/2020 to Wed 04/29/2020
0201 Continuous 0230

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

EASTVIEW-SPRNBRK__345_W78

Wed 04/29/2020 to Sun 05/03/2020
0201 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

SCH-IMO-NYISO_LIMIT_1600

Fri 05/01/2020 to Sat 10/31/2020
0001 Continuous 2359

Work scheduled by: IESO

UPDATED by IESO 05/03/2019

FWD
(Import)
SCH - OH - NY **1900 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 1900 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE-MOTTHAVN_345_71

Sat 05/02/2020 to Wed 05/06/2020
 0201 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_3

Sat 05/02/2020 to Wed 05/06/2020
 0201 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W85

Sun 05/03/2020 to Sun 05/03/2020
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

PANNELL -CLAY_345_2

Mon 05/04/2020 to Fri 05/08/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

NEPTUNE -DUFFYAVE_345_NEPTUNE

Mon 05/04/2020 to Mon 05/18/2020
 0800 Continuous 1700
 Work scheduled by: PJM

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 05/04/2020 to Mon 05/18/2020
 0800 Continuous 1700
 Work scheduled by: PJM

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Mon 05/04/2020 to Mon 05/18/2020
 0800 Continuous 1700
 Work scheduled by: PJM

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE_345_138_BK_2				FWD
Mon 05/04/2020	to	Mon 05/18/2020		(Import)
0800	Continuous	1700	SCH - PJM_NEPTUNE	375 MW
Work scheduled by: PJM				Impacts Total Transfer Capability 285 MW
				TTC with All Lines In Service 660 MW
SPRNBK_345KV_RS3 & SPRNBK_345KV_RS4				FWD
Wed 05/06/2020	to	Mon 05/11/2020		(Import)
0201		0200	SPR/DUN-SOUTH	3200 MW
Work scheduled by:				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
PANNELL_-CLAY_345_1				FWD
Mon 05/11/2020	to	Fri 05/15/2020		(Import)
0700	Continuous	1530	WEST CENTRAL	1300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 950 MW
				TTC with All Lines In Service 2250 MW
COOPERS_-DOLSONAV_345_CCDA42				FWD
Mon 05/11/2020	to	Fri 05/29/2020	UPDATED by NYPA 03/21/2019	(Import)
0700	Continuous	1730	CENTRAL EAST - VC	2720 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 255 MW
				TTC with All Lines In Service 2975 MW
KINTIGH_-ROCHESTR_345_SRL-39				FWD
Mon 05/18/2020	to	Fri 05/22/2020		(Import)
0500	Continuous	1530	DYSINGER EAST	1400 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1750 MW
				TTC with All Lines In Service 3150 MW
SCH-NE-NYISO_LIMIT_700				FWD
Mon 05/18/2020	to	Mon 05/18/2020		(Import)
0700	Continuous	1059	SCH - NE - NY	900 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability 500 MW
				TTC with All Lines In Service 1400 MW
SCH-NYISO-NE_LIMIT_500				REV
Mon 05/18/2020	to	Mon 05/18/2020		(Export)
0700	Continuous	1059	SCH - NE - NY	700 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability 900 MW
				TTC with All Lines In Service 1600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS _____ 345_393 & BERKSHIR-NORTHFLD_345_312			FWD	REV
Mon 05/18/2020	to	Mon 05/18/2020	(Import)	(Export)
0700		1100	SCH - NE - NY	950 MW 1300 MW
Work scheduled by:			Impacts Total Transfer Capability	450 MW 300 MW
ARR: 78			TTC with All Lines In Service	1400 MW 1600 MW
<hr/>				
BERKSHIR-NORTHFLD_345_312			FWD	REV
Mon 05/18/2020	to	Mon 05/18/2020	(Import)	(Export)
0700	Continuous	1100	SCH - NE - NY	900 MW 1500 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	500 MW 100 MW
			TTC with All Lines In Service	1400 MW 1600 MW
<hr/>				
BERKSHIR-NORTHFLD_345_312			FWD	REV
Mon 05/18/2020	to	Mon 05/18/2020	(Import)	(Export)
0700	Continuous	1100	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
<hr/>				
BERKSHIR-ALPS _____ 345_393			FWD	REV
Mon 05/18/2020	to	Sat 05/30/2020	(Import)	(Export)
0700	Continuous	1700	SCH - NE - NY	950 MW 1300 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	450 MW 300 MW
ARR: 78			TTC with All Lines In Service	1400 MW 1600 MW
<hr/>				
BERKSHIR-ALPS _____ 345_393			FWD	REV
Mon 05/18/2020	to	Sat 05/30/2020	(Import)	(Export)
0700	Continuous	1700	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
<hr/>				
SCH-NE-NYISO_LIMIT_600			FWD	
Mon 05/18/2020	to	Tue 05/26/2020	(Import)	
1100	Continuous	0559	SCH - NE - NY	800 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	600 MW
			TTC with All Lines In Service	1400 MW
<hr/>				
SCH-NYISO-NE_LIMIT_600				REV
Mon 05/18/2020	to	Sat 05/30/2020		(Export)
1100	Continuous	1459	SCH - NE - NY	800 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	1600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCHEDULE			FWD	REV
SCH-NE-NYISO_LIMIT_500				
Tue 05/26/2020	to	Sat 05/30/2020	(Import)	
0600	Continuous	1700	SCH - NE - NY	700 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	700 MW
			TTC with All Lines In Service	1400 MW
BERKSHIR-ALPS_345_393 & BERKSHIR-NORTHFLD_345_312				
Sat 05/30/2020	to	Sat 05/30/2020	(Import) (Export)	
1500		1700	SCH - NE - NY	950 MW 1300 MW
Work scheduled by: ARR: 78			Impacts Total Transfer Capability	450 MW 300 MW
			TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-NORTHFLD_345_312				
Sat 05/30/2020	to	Sat 05/30/2020	(Import) (Export)	
1500	Continuous	1700	SCH - NE - NY	900 MW 1500 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	500 MW 100 MW
			TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-NORTHFLD_345_312				
Sat 05/30/2020	to	Sat 05/30/2020	(Import) (Export)	
1500	Continuous	1700	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
SCH-NYISO-NE_LIMIT_500				
Sat 05/30/2020	to	Sat 05/30/2020	(Export)	
1500	Continuous	1700	SCH - NE - NY	700 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	900 MW
			TTC with All Lines In Service	1600 MW
SHOR_NPX-SHOREHAM_138_CSC				
Mon 06/01/2020	to	Tue 06/02/2020	(Import) (Export)	
0501	Continuous	1600	SCH - NPX_CSC	0 MW 0 MW
Work scheduled by: LI			Impacts Total Transfer Capability	330 MW 330 MW
			TTC with All Lines In Service	330 MW 330 MW
MOSES-ADIRNDCK_230_MA2				
Mon 06/01/2020	to	Fri 07/31/2020	(Import)	
0700	Continuous	1730	MOSES SOUTH	2100 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW
			TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA__345_230_AT4

Mon 06/29/2020 to Tue 06/30/2020
 0500 Continuous 1530
 Work scheduled by: NYPA

REV
 (Export)
 SCH - OH - NY **1400 MW**
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 1700 MW

SCH-IMO-NYISO_NIAG_CB_3008_W/BB

Mon 07/27/2020 to Fri 08/07/2020
 0500 Continuous 1530
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - OH - NY **1900 MW 1450 MW**
 Impacts Total Transfer Capability 0 MW 250 MW
 TTC with All Lines In Service 1900 MW 1700 MW

CHATGUAY-MASSENA__765_7040

Sat 08/01/2020 to Sun 08/02/2020 **UPDATED by NYPA 08/08/2019**
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **1550 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA__765_7040

Sat 08/01/2020 to Sun 08/02/2020 **UPDATED by NYPA 08/08/2019**
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - HQ - NY **0 MW 0 MW**
 Impacts Total Transfer Capability 1500 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

MARCY__765_345_AT1

Sat 08/01/2020 to Sun 08/02/2020 **UPDATED by NYPA 08/08/2019**
 0500 Continuous 1730
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 MOSES SOUTH **1750 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 3150 MW

MASSENA_-MARCY__765_MSU1

Sat 08/01/2020 to Sun 08/02/2020 **UPDATED by NYPA 08/08/2019**
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2265 MW**
 Impacts Total Transfer Capability 710 MW
 TTC with All Lines In Service 2975 MW

MASSENA_-MARCY__765_MSU1

Sat 08/01/2020 to Sun 08/02/2020 **UPDATED by NYPA 08/08/2019**
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **500 MW**
 Impacts Total Transfer Capability 2650 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1		FWD		REV
Sat 08/01/2020 to Sun 08/02/2020	UPDATED by NYPA 08/08/2019			(Import) (Export)
0500 Continuous 1730				
Work scheduled by: NYPA		SCH - HQ - NY		475 MW 1000 MW
		Impacts Total Transfer Capability		1025 MW 0 MW
		TTC with All Lines In Service		1500 MW 1000 MW
<hr/>				
MASSENA -MARCY 765_MSU1				FWD
Sat 08/01/2020 to Sun 08/02/2020	UPDATED by NYPA 08/08/2019			(Import)
0500 Continuous 1730				
Work scheduled by: NYPA		SCH - HQ_CEDARS		90 MW
		Impacts Total Transfer Capability		100 MW
		TTC with All Lines In Service		190 MW
<hr/>				
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040				FWD
Sat 08/01/2020 to Sun 08/02/2020				(Import)
0500 1730				
Work scheduled by:		MOSES SOUTH		500 MW
		Impacts Total Transfer Capability		2650 MW
		TTC with All Lines In Service		3150 MW
<hr/>				
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2				FWD
Sat 08/01/2020 to Sun 08/02/2020				(Import) (Export)
0500 1730				
Work scheduled by:		SCH - HQ - NY		850 MW 0 MW
		Impacts Total Transfer Capability		650 MW 1000 MW
		TTC with All Lines In Service		1500 MW 1000 MW
<hr/>				
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2				FWD
Sat 08/01/2020 to Sun 08/02/2020				(Import)
0500 1730				
Work scheduled by:		SCH - HQ_CEDARS		90 MW
		Impacts Total Transfer Capability		100 MW
		TTC with All Lines In Service		190 MW
<hr/>				
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1				FWD
Sat 08/01/2020 to Sun 08/02/2020				(Import)
0500 1730				
Work scheduled by:		SCH - HQ_CEDARS		90 MW
		Impacts Total Transfer Capability		100 MW
		TTC with All Lines In Service		190 MW
<hr/>				
STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2				FWD
Sat 08/01/2020 to Sun 08/02/2020				(Import)
0500 1730				
Work scheduled by:		SCH - HQ_CEDARS		90 MW
		Impacts Total Transfer Capability		100 MW
		TTC with All Lines In Service		190 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA2

Mon 08/03/2020 to Sun 09/13/2020
0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

FRASANNX-COOPERS_345_UCC2-41

Mon 09/07/2020 to Fri 10/23/2020
0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 03/01/2019

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY -FRASANNX_345_UCC2-41

Mon 09/07/2020 to Fri 10/23/2020
0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 03/01/2019

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY_765_345_AT1

Mon 09/14/2020 to Mon 09/14/2020
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

MOSES SOUTH **1750 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 3150 MW

NIAGARA -KINTIGH_345_NS1-38

Mon 09/14/2020 to Thu 09/17/2020
0500 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

MOSES -ADIRNDCK_230_MA2

Tue 09/15/2020 to Sat 11/14/2020
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

NIAGARA -ROCHESTR_345_NR2

Fri 09/18/2020 to Sat 11/14/2020
0500 Continuous 2330

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>CLAY -EDIC 345_1-16</p> <p>Mon 09/21/2020 to Fri 09/25/2020</p> <p style="padding-left: 40px;">0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>OSWEGO EXPORT 4850 MW</p> <p>Impacts Total Transfer Capability 400 MW</p> <p>TTC with All Lines In Service 5250 MW</p>
<p>ROSETON -ROCKTVRN 345_311</p> <p>Mon 09/21/2020 to Fri 10/23/2020 UPDATED by CHGE 10/09/2019</p> <p style="padding-left: 40px;">0800 Continuous 1600</p> <p>Work scheduled by: CHGE</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED 4400 MW</p> <p>Impacts Total Transfer Capability 1300 MW</p> <p>TTC with All Lines In Service 5700 MW</p>
<p>DUNWODIE 345KV_3</p> <p>Fri 09/25/2020 to Fri 09/25/2020 UPDATED by CONED 09/05/2019</p> <p style="padding-left: 40px;">0001 Continuous 0030</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH 3800 MW</p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>
<p>DUNWODIE 345KV_5</p> <p>Fri 09/25/2020 to Fri 09/25/2020 UPDATED by CONED 09/05/2019</p> <p style="padding-left: 40px;">0001 Continuous 0030</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH 3800 MW</p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>
<p>DUNWODIE-MOTTHAVN 345_71</p> <p>Fri 09/25/2020 to Fri 10/30/2020 UPDATED by CONED 09/05/2019</p> <p style="padding-left: 40px;">0001 Continuous 0300</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH 3800 MW</p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>
<p>CLAY -EDIC 345_2-15</p> <p>Mon 09/28/2020 to Fri 10/02/2020</p> <p style="padding-left: 40px;">0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>OSWEGO EXPORT 4850 MW</p> <p>Impacts Total Transfer Capability 400 MW</p> <p>TTC with All Lines In Service 5250 MW</p>
<p>MOTTHAVN-RAINEY 345_Q11</p> <p>Thu 10/01/2020 to Thu 11/05/2020 UPDATED by CONED 12/17/2019</p> <p style="padding-left: 40px;">0001 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH 3800 MW</p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND_BAR-PLATSBURG_115_PV20

Sat 10/17/2020 to Sat 11/14/2020
 0600 Continuous 1800
 Work scheduled by: ISONE

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

LEEDS__-HURLYAVE_345_301

Mon 10/26/2020 to Fri 12/04/2020
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 5700 MW

DUNWODIE_345KV_3

Fri 10/30/2020 to Fri 10/30/2020 **UPDATED by CONED 09/05/2019**
 0230 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

Fri 10/30/2020 to Fri 10/30/2020 **UPDATED by CONED 09/05/2019**
 0230 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

SCH-IMO-NYISO_LIMIT_1750

Sun 11/01/2020 to Fri 04/30/2021 **UPDATED by IESO 05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

FWD
 (Import)
 SCH - OH - NY **2050 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 2050 MW

SCH-NYISO-IMO_LIMIT_1600

Sun 11/01/2020 to Fri 04/30/2021 **UPDATED by IESO 05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

REV
 (Export)
 SCH - OH - NY **1900 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 1900 MW

CHATGUAY-MASSENA__765_7040

Sun 11/15/2020 to Mon 11/30/2020
 0100 Continuous 1900
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **1550 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA__765_7040				FWD	REV
Sun 11/15/2020	to	Mon 11/30/2020		(Import)	(Export)
0100	Continuous	1900		0 MW	0 MW
Work scheduled by: NYPA				SCH - HQ - NY	
				Impacts Total Transfer Capability	1500 MW
				TTC with All Lines In Service	1500 MW
MARCY__765_345_AT1				FWD	
Sun 11/15/2020	to	Mon 11/30/2020		(Import)	
0100	Continuous	1900		1750 MW	
Work scheduled by: NYPA				MOSES SOUTH	
				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	3150 MW
				ARR: 19	
MARCY__765_345_AT2				FWD	
Sun 11/15/2020	to	Mon 11/30/2020		(Import)	
0100	Continuous	1900		1700 MW	
Work scheduled by: NYPA				MOSES SOUTH	
				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
				ARR: 19	
MASSENA_-MARCY__765_MSU1				FWD	
Sun 11/15/2020	to	Mon 11/30/2020		(Import)	
0100	Continuous	1900		2265 MW	
Work scheduled by: NYPA				CENTRAL EAST - VC	
				Impacts Total Transfer Capability	710 MW
				TTC with All Lines In Service	2975 MW
MASSENA_-MARCY__765_MSU1				FWD	
Sun 11/15/2020	to	Mon 11/30/2020		(Import)	
0100	Continuous	1900		500 MW	
Work scheduled by: NYPA				MOSES SOUTH	
				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW
MASSENA_-MARCY__765_MSU1				FWD	REV
Sun 11/15/2020	to	Mon 11/30/2020		(Import)	(Export)
0100	Continuous	1900		475 MW	1000 MW
Work scheduled by: NYPA				SCH - HQ - NY	
				Impacts Total Transfer Capability	1025 MW
				TTC with All Lines In Service	1500 MW
MASSENA_-MARCY__765_MSU1				FWD	
Sun 11/15/2020	to	Mon 11/30/2020		(Import)	
0100	Continuous	1900		90 MW	
Work scheduled by: NYPA				SCH - HQ_CEDARS	
				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040		FWD	
Sun 11/15/2020	to Mon 11/30/2020	(Import)	
0100	1900	MOSES SOUTH	500 MW
Work scheduled by:		Impacts Total Transfer Capability	2650 MW
		TTC with All Lines In Service	3150 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2		FWD	REV
Sun 11/15/2020	to Mon 11/30/2020	(Import)	(Export)
0100	1900	SCH - HQ - NY	850 MW 0 MW
Work scheduled by:		Impacts Total Transfer Capability	650 MW 1000 MW
		TTC with All Lines In Service	1500 MW 1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2		FWD	
Sun 11/15/2020	to Mon 11/30/2020	(Import)	
0100	1900	SCH - HQ_CEDARS	90 MW
Work scheduled by:		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1		FWD	
Sun 11/15/2020	to Mon 11/30/2020	(Import)	
0100	1900	SCH - HQ_CEDARS	90 MW
Work scheduled by:		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW
STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2		FWD	
Sun 11/15/2020	to Mon 11/30/2020	(Import)	
0100	1900	SCH - HQ_CEDARS	90 MW
Work scheduled by:		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW
PLSNTVLE-DUNWODIE_345_W89		FWD	
Mon 11/16/2020	to Mon 11/16/2020	(Import)	
0001	Continuous 0030	UPNY CONED	4000 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	1700 MW
		TTC with All Lines In Service	5700 MW
PLSNTVLE-DUNWODIE_345_W89		FWD	
Thu 11/26/2020	to Thu 11/26/2020	(Import)	
0230	Continuous 0300	UPNY CONED	4000 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	1700 MW
		TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES ___ -ADIRNDCK_230_MA1		FWD	
Tue 12/01/2020	to Mon 05/31/2021	(Import)	
0700	Continuous 1300	MOSES SOUTH	2300 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	850 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
SAND_BAR-PLATSBURG_115_PV20			
Mon 12/07/2020	to Fri 12/11/2020	SCH - NE - NY	
0700	Continuous 1530	Impacts Total Transfer Capability	
Work scheduled by: NYPA		TTC with All Lines In Service	
<hr/>			
SAND_BAR-PLATSBURG_115_PV20			
Mon 12/14/2020	to Fri 12/18/2020	SCH - NE - NY	
0700	Continuous 1530	Impacts Total Transfer Capability	
Work scheduled by: NYPA		TTC with All Lines In Service	
<hr/>			
HOPATCON-RAMAPO___500_5018		FWD	REV
Mon 02/01/2021	to Wed 02/03/2021	(Import)	(Export)
0001	Continuous 2200	SCH - PJ - NY	1250 MW 1200 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	1650 MW 650 MW
		TTC with All Lines In Service	2900 MW 1850 MW
<hr/>			
HOPATCON-RAMAPO___500_5018		FWD	
Mon 02/01/2021	to Wed 02/03/2021	(Import)	
0001	Continuous 2200	UPNY CONED	5000 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	700 MW
		TTC with All Lines In Service	5700 MW
<hr/>			
RAMAPO___345_345_PAR3500		FWD	REV
Mon 02/01/2021	to Wed 02/03/2021	(Import)	(Export)
0001	Continuous 2200	SCH - PJ - NY	2150 MW 1250 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	750 MW 600 MW
		TTC with All Lines In Service	2900 MW 1850 MW
<hr/>			
RAMAPO___345_345_PAR4500		FWD	REV
Mon 02/01/2021	to Wed 02/03/2021	(Import)	(Export)
0001	Continuous 2200	SCH - PJ - NY	2150 MW 1250 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	750 MW 600 MW
		TTC with All Lines In Service	2900 MW 1850 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday, July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

	FWD	REV
	(Import)	(Export)
RAMAPO___500_345_BK 1500		
Mon 02/01/2021 to Wed 02/03/2021		
0001 Continuous 2200		
Work scheduled by: ConEd		
	SCH - PJ - NY	1250 MW
	Impacts Total Transfer Capability	1650 MW
	TTC with All Lines In Service	2900 MW
		1850 MW
RAMAPO___500_345_BK 1500		
Mon 02/01/2021 to Wed 02/03/2021		
0001 Continuous 2200		
Work scheduled by: ConEd		
	UPNY CONED	5000 MW
	Impacts Total Transfer Capability	700 MW
	TTC with All Lines In Service	5700 MW
DUNWODIE_345KV_3		
Mon 03/01/2021 to Mon 03/01/2021		
0001 Continuous 0030		
Work scheduled by: ConEd		
	SPR/DUN-SOUTH	3800 MW
	Impacts Total Transfer Capability	800 MW
	TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_5		
Mon 03/01/2021 to Mon 03/01/2021		
0001 Continuous 0030		
Work scheduled by: ConEd		
	SPR/DUN-SOUTH	3800 MW
	Impacts Total Transfer Capability	800 MW
	TTC with All Lines In Service	4600 MW
DUNWODIE-MOTTHAVN_345_71		
Mon 03/01/2021 to Mon 04/05/2021		
0001 Continuous 0300		
Work scheduled by: ConEd		
	SPR/DUN-SOUTH	3800 MW
	Impacts Total Transfer Capability	800 MW
	TTC with All Lines In Service	4600 MW
MOTTHAVN-RAINEY___345_Q11		
Mon 03/01/2021 to Tue 04/06/2021		
0001 Continuous 0700		
Work scheduled by: ConEd		
	SPR/DUN-SOUTH	3800 MW
	Impacts Total Transfer Capability	800 MW
	TTC with All Lines In Service	4600 MW
CLAY___-EDIC___345_2-15		
Mon 03/29/2021 to Fri 04/16/2021		
0800 Continuous 1730		
Work scheduled by: NYPA		
	OSWEGO EXPORT	4850 MW
	Impacts Total Transfer Capability	400 MW
	TTC with All Lines In Service	5250 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 15, 2020 to Friday ,July 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_3

Mon 04/05/2021 to Mon 04/05/2021
 0230 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

Mon 04/05/2021 to Mon 04/05/2021
 0230 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

SCH-IMO-NYISO_LIMIT_1600

Sat 05/01/2021 to Sun 10/31/2021 **UPDATED by IESO 05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

FWD
 (Import)
 SCH - OH - NY **1900 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 1900 MW

PANNELL_-CLAY_345_2

Mon 05/03/2021 to Fri 05/28/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

MOSES_-ADIRNDCK_230_MA2

Tue 06/01/2021 to Sun 11/14/2021
 0700 Continuous 1300
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW