

# NYISO TRANSFER LIMITATIONS

Monday ,September28, 2020 to Wednesday, March 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE\_345KV\_9\_BYPASS & DUNWODIE\_345KV\_10\_BYPASS & SPRNBRK\_\_345KV\_R5S3\_BYPASS  
& SPRNBRK\_\_345KV\_R4S3\_BYPASS

FWD

(Import)

Sun 02/01/2015 to Sat 02/01/2025  
0000 0000

SPR/DUN-SOUTH

4350 MW

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 4600 MW

Work scheduled by:

DUNWODIE\_345KV\_9\_BYPASS & DUNWODIE\_345KV\_10\_BYPASS & SPRNBRK\_\_345KV\_R5S3\_BYPASS  
& SPRNBRK\_\_345KV\_R4S3\_BYPASS

Sun 02/01/2015 to Sat 02/01/2025  
0000 0000

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by:

HUDSONP\_-FARRAGUT\_345\_B3402

FWD

REV

Mon 01/15/2018 to Sun 02/28/2021 EXT FORCE by CONED 08/28/2020  
0001 Continuous 2359

(Import) (Export)

SCH - PJ - NY

2050 MW 1150 MW

Impacts Total Transfer Capability 150 MW 100 MW

TTC with All Lines In Service 2200 MW 1250 MW

Work scheduled by: ConEd

HUDSONP\_-FARRAGUT\_345\_B3402 &amp; MARION\_-FARRAGUT\_345\_C3403

FWD

REV

Mon 01/15/2018 to Sun 02/28/2021  
0001 2359

(Import) (Export)

SCH - PJ - NY

2000 MW 1000 MW

Impacts Total Transfer Capability 200 MW 250 MW

TTC with All Lines In Service 2200 MW 1250 MW

Work scheduled by:

MARION\_-FARRAGUT\_345\_C3403

FWD

REV

Mon 01/15/2018 to Sun 02/28/2021 EXT FORCE by CONED 08/28/2020  
0001 Continuous 2359

(Import) (Export)

SCH - PJ - NY

2050 MW 1150 MW

Impacts Total Transfer Capability 150 MW 100 MW

TTC with All Lines In Service 2200 MW 1250 MW

Work scheduled by: ConEd

STLAWRNC-MOSES\_\_230\_L33P

Mon 04/30/2018 to Thu 03/31/2022 EXT FORCE by IESO 09/04/2020  
0456 Continuous 2359

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: IESO

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-IMO-NYISO\_LIMIT\_1600**

Fri 05/01/2020 to Sat 10/31/2020 **UPDATED by IESO 05/03/2019**

0001 Continuous 2359

Work scheduled by: IESO

FWD  
(Import)  
**1900 MW**  
SCH - OH - NY  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 1950 MW

**SHOR\_NPX-SHOREHAM\_138\_CSC**

Wed 07/08/2020 to Mon 10/19/2020 **EXT FORCE by ISONE 09/18/2020**

1247 Continuous 0659

Work scheduled by: LI

FWD REV  
(Import) (Export)  
**0 MW 0 MW**  
SCH - NPX\_CSC  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

**SPRNBK\_-W49TH\_ST\_345\_M52**

Sun 08/16/2020 to Tue 10/13/2020 **EXTENDED by CONED 09/25/2020**

1149 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
**3200 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

**BECK\_-NIAGARA\_230\_PA27**

Mon 08/31/2020 to Mon 11/30/2020

0700 Continuous 0700

Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**SCH-IMO-NYISO\_LIMIT\_1450**

Mon 08/31/2020 to Mon 11/30/2020

0700 Continuous 0700

Work scheduled by: IESO

FWD  
(Import)  
**1750 MW**  
SCH - OH - NY  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1950 MW

**HOMRC\_NY-MAINS\_NY\_345\_47**

Tue 09/01/2020 to Fri 10/09/2020

0700 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**NEWBRDGE\_345\_138\_BK\_1**

Wed 09/02/2020 to Thu 12/31/2020 **EXT FORCE by LI 09/03/2020**

1807 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
**375 MW**  
SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,September28, 2020 to Wednesday, March 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-NYISO-HQ\_CEDARS\_LIMIT\_0**Tue 09/08/2020 to Fri 09/25/2020 **EXTENDED** **by HQ** **09/24/2020**

0500 Continuous 1700

Work scheduled by: HQ

REV  
(Export)  
**0 MW**  
SCH - HQ\_CEDARS  
Impacts Total Transfer Capability 40 MW  
TTC with All Lines In Service 40 MW

**MOSES\_-ADIRNDCK\_230\_MA2**Wed 09/09/2020 to Sat 11/14/2020 **UPDATED** **by NYPA** **09/04/2020**

0700 Continuous 1300

Work scheduled by: NYPA

FWD  
(Import)  
**2100 MW**  
MOSES SOUTH  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**FITZPTRK-EDIC\_345\_FE-1**Mon 09/14/2020 to Mon 09/28/2020 **UPDATED** **by NYISO** **09/23/2020**

0001 Continuous 1400

Work scheduled by: NYPA

FWD  
(Import)  
**2825 MW**  
CENTRAL EAST - VC  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 2975 MW

**FITZPTRK-EDIC\_345\_FE-1**Mon 09/14/2020 to Mon 09/28/2020 **UPDATED** **by NYISO** **09/23/2020**

0001 Continuous 1400

Work scheduled by: NYPA

FWD  
(Import)  
**4800 MW**  
OSWEGO EXPORT  
Impacts Total Transfer Capability 450 MW  
TTC with All Lines In Service 5250 MW

**SCH-IMO-NYISO\_LIMIT\_1350**Fri 09/18/2020 to Sat 10/31/2020 **UPDATED** **by NYPA** **09/16/2020**

0500 Continuous 2359

Work scheduled by: NYPA

FWD  
(Import)  
**1650 MW**  
SCH - OH - NY  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 1950 MW

**NIAGARA\_-ROCHESTR\_345\_NR2**Fri 09/18/2020 to Sat 11/14/2020 **UPDATED** **by NYPA** **09/16/2020**

0500 Continuous 2330

Work scheduled by: NYPA

FWD  
(Import)  
**1400 MW**  
DYSINGER EAST  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

**NIAGARA\_345KV\_3108**Fri 09/18/2020 to Sat 11/14/2020 **UPDATED** **by NYPA** **09/16/2020**

0500 Continuous 2330

Work scheduled by: NYPA

REV  
(Export)  
**1500 MW**  
SCH - OH - NY  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1700 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BUCHAN_S-MILLWOOD_345_W98</b>					FWD	
Sun 09/20/2020	to	Fri 09/25/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>09/22/2020</u>	(Import)
0001	Continuous	2230				
Work scheduled by: ConEd					UPNY CONED	<b>6135 MW</b>
					Impacts Total Transfer Capability	85 MW
					TTC with All Lines In Service	6220 MW
<b>CLAY_-EDIC_345_1-16</b>					FWD	
Mon 09/21/2020	to	Fri 09/25/2020				(Import)
0700	Continuous	1530				
Work scheduled by: NYPA					OSWEGO EXPORT	<b>4850 MW</b>
					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	5250 MW
<b>DOLSONAV-ROCKTVRN_345_DART44</b>					FWD	
Mon 09/21/2020	to	Fri 09/25/2020	<u>UPDATED</u>	<u>by CHGE</u>	<u>09/21/2020</u>	(Import)
0700	Continuous	1600				
Work scheduled by: CHGE					CENTRAL EAST - VC	<b>2720 MW</b>
					Impacts Total Transfer Capability	255 MW
					TTC with All Lines In Service	2975 MW
<b>FRASANX-COOPERS_345_UCC2-41</b>					FWD	
Mon 09/21/2020	to	Wed 09/30/2020	<u>EXTENDED</u>	<u>by NYPA</u>	<u>07/21/2020</u>	(Import)
0700	Continuous	1730				
Work scheduled by: NYPA					CENTRAL EAST - VC	<b>2500 MW</b>
					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW
<b>MARCY_-FRASANX_345_UCC2-41</b>					FWD	
Mon 09/21/2020	to	Wed 09/30/2020	<u>EXTENDED</u>	<u>by NYPA</u>	<u>07/21/2020</u>	(Import)
0700	Continuous	1730				
Work scheduled by: NYPA					CENTRAL EAST - VC	<b>2500 MW</b>
					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW
<b>BRANCHBG-HOPATCON_500_5060</b>					FWD	
Tue 09/22/2020	to	Wed 09/23/2020	<u>UPDATED</u>	<u>by PJM</u>	<u>04/20/2020</u>	(Import)
0200	Continuous	2300				
Work scheduled by: PJM					UPNY CONED	<b>6025 MW</b>
					Impacts Total Transfer Capability	195 MW
					TTC with All Lines In Service	6220 MW
<b>LINDEN_-GOETHALS_230_A2253</b>					FWD	REV
Tue 09/22/2020	to	Wed 09/23/2020	<u>UPDATED</u>	<u>by CE</u>	<u>06/24/2020</u>	(Import) (Export)
0200	Continuous	2359				
Work scheduled by: PJM					SCH - PJ - NY	<b>2050 MW 1150 MW</b>
					Impacts Total Transfer Capability	150 MW 100 MW
					TTC with All Lines In Service	2200 MW 1250 MW

# NYISO TRANSFER LIMITATIONS

Monday ,September28, 2020 to Wednesday, March 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LINDEN\_\_ -GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402

Tue 09/22/2020 to Wed 09/23/2020  
0200 2359

Work scheduled by:

	FWD (Import)	REV (Export)
SCH - PJ - NY	<b>2000 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

## LINDEN\_\_ -GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_\_ -FARRAGUT\_345\_C3403

Tue 09/22/2020 to Wed 09/23/2020  
0200 2359

Work scheduled by:

	FWD (Import)	REV (Export)
SCH - PJ - NY	<b>2000 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

## LINDEN\_\_ -GOETHALS\_230\_A2253 & MARION\_\_ -FARRAGUT\_345\_C3403

Tue 09/22/2020 to Wed 09/23/2020  
0200 2359

Work scheduled by:

	FWD (Import)	REV (Export)
SCH - PJ - NY	<b>2000 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

## ADIRNDCK-CHASLAKE\_230\_13

Wed 09/23/2020 to Wed 09/23/2020 EXTENDED by NGRID 09/21/2020  
0700 Continuous 1730

Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	<b>2100 MW</b>
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

## LINDEN\_\_ -GOETHALS\_230\_A2253

Thu 09/24/2020 to Sun 09/27/2020 UPDATED by CONED 09/25/2020  
0001 Continuous 1700

Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJ - NY	<b>2050 MW</b>	<b>1150 MW</b>
Impacts Total Transfer Capability	150 MW	100 MW
TTC with All Lines In Service	2200 MW	1250 MW

## LINDEN\_\_ -GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402

Thu 09/24/2020 to Sun 09/27/2020  
0001 1700

Work scheduled by:

	FWD (Import)	REV (Export)
SCH - PJ - NY	<b>2000 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

# NYISO TRANSFER LIMITATIONS

Monday ,September28, 2020 to Wednesday, March 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDEN\_\_-GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_\_-  
FARRAGUT\_345\_C3403

Thu 09/24/2020 to Sun 09/27/2020  
0001 1700

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2000 MW	1000 MW
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

LINDEN\_\_-GOETHALS\_230\_A2253 & MARION\_\_-FARRAGUT\_345\_C3403

Thu 09/24/2020 to Sun 09/27/2020  
0001 1700

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2000 MW	1000 MW
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

NIAGARA\_\_345KV\_3302

Thu 09/24/2020 to Thu 09/24/2020  
0500 Continuous 1700

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1000 MW	1600 MW
Impacts Total Transfer Capability	950 MW	100 MW
TTC with All Lines In Service	1950 MW	1700 MW

SCH-IMO-NYISO\_LIMIT\_600

Thu 09/24/2020 to Thu 09/24/2020  
0500 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
SCH - OH - NY	900 MW
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	1950 MW

W49TH\_ST\_345KV\_6

Thu 09/24/2020 to Thu 09/24/2020 **CANCELLED** **by ConEd** **09/23/2020**  
0700 Continuous 0730

Work scheduled by: ConEd

	FWD
	(Import)
SCH - PJM_HTP	300 MW
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

W49TH\_ST\_345KV\_8

Thu 09/24/2020 to Thu 09/24/2020 **CANCELLED** **by ConEd** **09/23/2020**  
0700 Continuous 0730

Work scheduled by: ConEd

	FWD
	(Import)
SCH - PJM_HTP	450 MW
Impacts Total Transfer Capability	210 MW
TTC with All Lines In Service	660 MW

W49TH\_ST\_345KV\_6

Thu 09/24/2020 to Thu 09/24/2020 **CANCELLED** **by ConEd** **09/23/2020**  
1830 Continuous 1900

Work scheduled by: ConEd

	FWD
	(Import)
SCH - PJM_HTP	300 MW
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_8**

Thu 09/24/2020 to Thu 09/24/2020 **CANCELLED** by ConEd 09/23/2020  
 1830 Continuous 1900  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **450 MW**  
 Impacts Total Transfer Capability 210 MW  
 TTC with All Lines In Service 660 MW

**MILLWOOD\_345KV\_18**

Fri 09/25/2020 to Fri 09/25/2020 **UPDATED** by CONED 09/22/2020  
 0001 Continuous 2230  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1870 MW  
 TTC with All Lines In Service 6220 MW

**SCH-HQ-NYISO\_LIMIT\_1150**

Sat 09/26/2020 to Sun 09/27/2020  
 2000 Continuous 0459  
 Work scheduled by: HQ

FWD  
 (Import)  
 SCH - HQ - NY **1150 MW**  
 Impacts Total Transfer Capability 350 MW  
 TTC with All Lines In Service 1500 MW

**SCH-NYISO-HQ\_LIMIT\_0**

Sat 09/26/2020 to Sun 09/27/2020  
 2000 Continuous 0459  
 Work scheduled by: HQ

REV  
 (Export)  
 SCH - HQ - NY **0 MW**  
 Impacts Total Transfer Capability 1000 MW  
 TTC with All Lines In Service 1000 MW

**CHAT\_DC\_GC1 & CHAT\_DC\_GC2**

Sat 09/26/2020 to Sun 09/27/2020  
 2000 0500  
 Work scheduled by:

FWD  
 (Import)  
 MOSES SOUTH **2550 MW**  
 Impacts Total Transfer Capability 600 MW  
 TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC1 & CHAT\_DC\_GC2**

Sat 09/26/2020 to Sun 09/27/2020  
 2000 0500  
 Work scheduled by:

FWD REV  
 (Import) (Export)  
 SCH - HQ - NY **1370 MW 0 MW**  
 Impacts Total Transfer Capability 130 MW 1000 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

**CHAT\_DC\_GC2**

Sat 09/26/2020 to Sun 09/27/2020  
 2000 Continuous 0500  
 Work scheduled by: HQ

FWD  
 (Import)  
 MOSES SOUTH **2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Monday ,September28, 2020 to Wednesday, March 30, 2022

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHAT\_DC\_GC2

Sat 09/26/2020 to Sun 09/27/2020  
2000 Continuous 0500

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

### CHAT\_DC\_GC1

Sat 09/26/2020 to Tue 10/20/2020  
2000 Continuous 2300

Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

### CHAT\_DC\_GC1

Sat 09/26/2020 to Tue 10/20/2020  
2000 Continuous 2300

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

### W49TH\_ST\_345KV\_5

Sun 09/27/2020 to Mon 09/28/2020  
0001 Continuous 0300

Work scheduled by: ConEd

**CANCELLED by ConEd 09/27/2020**

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

### W49TH\_ST\_345KV\_7

Sun 09/27/2020 to Mon 09/28/2020  
0001 Continuous 0300

Work scheduled by: ConEd

**CANCELLED by ConEd 09/27/2020**

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

### SCH-HQ-NYISO\_LIMIT\_1400

Sun 09/27/2020 to Wed 09/30/2020  
0500 Continuous 1730

Work scheduled by: HQ

FWD  
(Import)  
SCH - HQ - NY **1400 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 1500 MW

### SCH-NYISO-HQ\_LIMIT\_500

Sun 09/27/2020 to Tue 10/20/2020  
0500 Continuous 0500

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW



CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## GOETHALS\_345KV\_5

Sun 09/27/2020 to Sun 09/27/2020 **UPDATED** **by CONED** **09/25/2020**

1630 Continuous 1700

Work scheduled by: PJM

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

## CRICKVLY-PLSNTVLY\_345\_F83

Mon 09/28/2020 to Sun 10/04/2020

0001 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

SCH - NE - NY

**350 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 1400 MW

## CRICKVLY-PLSNTVLY\_345\_F83

Mon 09/28/2020 to Sun 10/04/2020

0001 Continuous 2200

Work scheduled by: ConEd

FWD

(Import) (Export)

SCH - NPX\_1385

**100 MW 100 MW**

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

## NRTH1385-NOR HBR\_138\_601

Mon 09/28/2020 to Sat 10/17/2020

0500 Continuous 2359

Work scheduled by: LI

**CANCELLED** **by LI** **09/25/2020**

FWD

(Import) (Export)

SCH - NPX\_1385

**100 MW 100 MW**

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

## NRTH1385-NOR HBR\_138\_602

Mon 09/28/2020 to Sat 10/17/2020

0500 Continuous 2359

Work scheduled by: LI

**CANCELLED** **by LI** **09/25/2020**

FWD

(Import) (Export)

SCH - NPX\_1385

**100 MW 100 MW**

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

## NRTH1385-NOR HBR\_138\_603

Mon 09/28/2020 to Sat 10/17/2020

0500 Continuous 2359

Work scheduled by: LI

**CANCELLED** **by LI** **09/25/2020**

FWD

(Import) (Export)

SCH - NPX\_1385

**100 MW 100 MW**

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

## NRTH1385-NRTHPORT\_138\_NNC

Mon 09/28/2020 to Sat 10/17/2020

0500 Continuous 2359

Work scheduled by: LI

**CANCELLED** **by LI** **09/25/2020**

FWD

(Import) (Export)

SCH - NPX\_1385

**0 MW 0 MW**

Impacts Total Transfer Capability 200 MW 200 MW

TTC with All Lines In Service 200 MW 200 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,September28, 2020 to Wednesday, March 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**STONYRDG-HILLSIDE\_230\_72**

Mon 09/28/2020 to Mon 09/28/2020  
0600 Continuous 0630

Work scheduled by: NYSEG

FWD  
(Import)  
DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

**CLAY -EDIC 345\_2-15**

Mon 09/28/2020 to Fri 10/02/2020  
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYISO 09/23/2020

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

**ROSETON -ROCKTVRN\_345\_311**

Mon 09/28/2020 to Fri 10/02/2020  
0800 Continuous 1600

Work scheduled by: CHGE

UPDATED by CHGE 08/27/2020

FWD  
(Import)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 1820 MW  
TTC with All Lines In Service 6220 MW

**DENNISON-ROSEMNTB\_115\_2/22**

Mon 09/28/2020 to Fri 10/02/2020  
0800 Continuous 1630

Work scheduled by: NGrid

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **95 MW 40 MW**  
Impacts Total Transfer Capability 95 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

**SCH-NYISO-HQ\_CEDARS\_LIMIT\_0**

Mon 09/28/2020 to Thu 10/01/2020  
1500 Continuous 2359

Work scheduled by: HQ

UPDATED by HQ 09/28/2020

REV  
(Export)  
SCH - HQ\_CEDARS **0 MW**  
Impacts Total Transfer Capability 40 MW  
TTC with All Lines In Service 40 MW

**W49TH\_ST\_345KV\_6**

Mon 09/28/2020 to Mon 09/28/2020  
2330 Continuous 2359

Work scheduled by: ConEd

EXTENDED by CONED 09/27/2020

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_8**

Mon 09/28/2020 to Mon 09/28/2020  
2330 Continuous 2359

Work scheduled by: ConEd

EXTENDED by CONED 09/27/2020

FWD  
(Import)  
SCH - PJM\_HTP **450 MW**  
Impacts Total Transfer Capability 210 MW  
TTC with All Lines In Service 660 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**SPRNBRK\_\_345KV\_RNS4**

FWD

 Tue 09/29/2020 to Tue 10/13/2020 **EXTENDED** **by CONED** **09/25/2020**

(Import)

0001 Continuous 0300

Work scheduled by: ConEd

 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

---

**W49TH\_ST\_345KV\_5**

FWD

 Tue 09/29/2020 to Tue 10/13/2020 **EXTENDED** **by CONED** **09/25/2020**

(Import)

0201 Continuous 0300

Work scheduled by: ConEd

 SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

---

**SCRIBA\_\_VOLNEY\_\_345\_21**

FWD

 Tue 09/29/2020 to Wed 09/30/2020 **UPDATED** **by NGRID** **08/01/2020**

(Import)

0800 Continuous 1630

Work scheduled by: NGrid

 OSWEGO EXPORT **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

---

**SCH-NPX\_1385-NYISO\_LIMIT\_50**

FWD

Wed 09/30/2020 to Sun 10/04/2020

(Import)

0001 Continuous 2200

Work scheduled by: ConEd

 SCH - NPX\_1385 **50 MW**  
 Impacts Total Transfer Capability 150 MW  
 TTC with All Lines In Service 200 MW

---

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

FWD

Wed 09/30/2020 to Wed 09/30/2020

(Import)

0800 Continuous 1200

Work scheduled by: LI

 SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

---

**NEWBRDGE-DUFFYAVE\_345\_501**

FWD

Wed 09/30/2020 to Wed 09/30/2020

(Import)

0800 Continuous 1200

Work scheduled by: LI

 SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

---

**NEWBRDGE\_345\_138\_BK\_2**

FWD

Wed 09/30/2020 to Wed 09/30/2020

(Import)

0800 Continuous 1200

Work scheduled by: LI

 SCH - PJM\_NEPTUNE **375 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 660 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,September28, 2020 to Wednesday, March 30, 2022

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_5**

FWD

Thu 10/01/2020 to Thu 10/01/2020 **CANCELLED by NYISO 09/23/2020**

(Import)

0001 Continuous 1800

SCH - PJM\_HTP

**300 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

**EDIC -FRASER 345 EF24-40**

FWD

Thu 10/01/2020 to Fri 10/02/2020

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

**2500 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

**FITZPTRK-EDIC 345 FE-1**

FWD

Sat 10/03/2020 to Sat 10/03/2020 **UPDATED by NYPA 09/28/2020**

(Import)

0900 Continuous 1100

CENTRAL EAST - VC

**2825 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 2975 MW

**FITZPTRK-EDIC 345 FE-1**

FWD

Sat 10/03/2020 to Sat 10/03/2020 **UPDATED by NYPA 09/28/2020**

(Import)

0900 Continuous 1100

OSWEGO EXPORT

**4800 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 450 MW

TTC with All Lines In Service 5250 MW

**STONYRDG-HILLSIDE\_230\_72**

FWD

Sun 10/04/2020 to Sun 10/04/2020

(Import)

1500 Continuous 1530

DYSINGER EAST

**2850 MW**

Work scheduled by: NYSEG

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

**PANNELL -CLAY 345\_1**

FWD

Mon 10/05/2020 to Fri 10/09/2020 **UPDATED by NYPA 05/07/2020**

(Import)

0700 Continuous 1530

WEST CENTRAL

**1300 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

**BRANCHBG-HOPATCON\_500\_5060**

FWD

Wed 10/07/2020 to Wed 10/07/2020

(Import)

0200 Continuous 1500

UPNY CONED

**6025 MW**

Work scheduled by: PJM

Impacts Total Transfer Capability 195 MW

TTC with All Lines In Service 6220 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**LEEDS\_\_\_\_345KV\_R395**

FWD

Thu 10/08/2020 to Thu 10/08/2020

(Import)

0700 Daily(No Weekends) 1630

Work scheduled by: NGrid

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

**HOMR\_NYW-PIERC\_NY\_345\_48**

Mon 10/12/2020 to Fri 10/30/2020

UPDATEDby PJM08/06/2020

0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**DUNWODIE-MOTTHAVN\_345\_71**

FWD

Tue 10/13/2020 to Wed 10/14/2020

UPDATEDby CONED09/28/2020

0301 Continuous 0100

Work scheduled by: ConEd

(Import)

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_5**

FWD

Tue 10/13/2020 to Wed 10/14/2020

UPDATEDby CONED09/28/2020

0301 Continuous 0100

Work scheduled by: ConEd

(Import)

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_3**

FWD

Tue 10/13/2020 to Wed 11/18/2020

UPDATEDby CONED09/28/2020

0301 Continuous 0100

Work scheduled by: ConEd

(Import)

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_4**

FWD

Tue 10/13/2020 to Wed 11/18/2020

UPDATEDby CONED09/28/2020

0301 Continuous 0100

Work scheduled by: ConEd

(Import)

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**PLSNTVLE-DUNWODIE\_345\_W89**

FWD

Tue 10/13/2020 to Wed 11/18/2020

UPDATEDby CONED09/28/2020

0301 Continuous 0100

Work scheduled by: ConEd

(Import)

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**HURLYAVE-ROSETON\_\_345\_303**

FWD

Tue 10/13/2020 to Fri 10/16/2020

UPDATEDby CHGE09/10/2020

(Import)

0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 2120 MW

TTC with All Lines In Service 6220 MW

**W49TH\_ST\_345KV\_6**

FWD

Fri 10/16/2020 to Fri 10/16/2020

(Import)

0331 Continuous 0400

Work scheduled by: ConEd

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

**E13THSTA-FARRAGUT\_345\_46**

FWD

Fri 10/16/2020 to Fri 10/16/2020

(Import)

0331 Continuous 0600

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**W49TH\_ST-E13THSTA\_345\_M55**

FWD

Fri 10/16/2020 to Fri 10/16/2020

(Import)

0331 Continuous 0600

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**W49TH\_ST\_345KV\_6**

FWD

Fri 10/16/2020 to Fri 10/16/2020

(Import)

0530 Continuous 0600

Work scheduled by: ConEd

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

**SAND\_BAR-PLATSBRG\_115\_PV20**

Sat 10/17/2020 to Sat 11/14/2020

0600 Continuous 1800

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**MILLWOOD\_345KV\_18**

FWD

Mon 10/19/2020 to Mon 10/19/2020

(Import)

0001 Continuous 0030

Work scheduled by: ConEd

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-NE-NYISO\_LIMIT\_600**

FWD

Mon 10/19/2020 to Sat 10/31/2020 UPDATED by ISONE 06/05/2020

(Import)

0630 Continuous 2359

Work scheduled by: NGrid

SCH - NE - NY

**800 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 1400 MW

**SCH-NYISO-NE\_LIMIT\_800**

REV

Mon 10/19/2020 to Sat 10/31/2020 UPDATED by ISONE 06/05/2020

(Export)

0630 Continuous 2359

Work scheduled by: NGrid

SCH - NE - NY

**1000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 1600 MW

**BERKSHIR-ALPS\_\_\_\_\_345\_393**

FWD

REV

Mon 10/19/2020 to Tue 11/10/2020 UPDATED by ISONE 06/05/2020

(Import) (Export)

0630 Continuous 1630

Work scheduled by: NGrid

**ARR: 78**

SCH - NE - NY

**950 MW****1300 MW**

Impacts Total Transfer Capability 450 MW 300 MW

TTC with All Lines In Service 1400 MW 1600 MW

**BERKSHIR-ALPS\_\_\_\_\_345\_393**

FWD

REV

Mon 10/19/2020 to Tue 11/10/2020 UPDATED by ISONE 06/05/2020

(Import) (Export)

0630 Continuous 1630

Work scheduled by: NGrid

**ARR: 78**

SCH - NPX\_1385

**100 MW****100 MW**

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

**BERKSHIR-ALPS\_\_\_\_\_345\_393 & BERKSHIR-NORTHFLD\_345\_312**

FWD

REV

Mon 10/19/2020 to Tue 11/10/2020

(Import) (Export)

0630 1630

Work scheduled by:

**ARR: 78**

SCH - NE - NY

**950 MW****1300 MW**

Impacts Total Transfer Capability 450 MW 300 MW

TTC with All Lines In Service 1400 MW 1600 MW

**BERKSHIR-NORTHFLD\_345\_312**

FWD

REV

Mon 10/19/2020 to Tue 11/10/2020 UPDATED by ISONE 06/05/2020

(Import) (Export)

0630 Continuous 1630

Work scheduled by: NGrid

SCH - NE - NY

**900 MW****1500 MW**

Impacts Total Transfer Capability 500 MW 100 MW

TTC with All Lines In Service 1400 MW 1600 MW

**BERKSHIR-NORTHFLD\_345\_312**

FWD

REV

Mon 10/19/2020 to Tue 11/10/2020 UPDATED by ISONE 06/05/2020

(Import) (Export)

0630 Continuous 1630

Work scheduled by: NGrid

SCH - NPX\_1385

**100 MW****100 MW**

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHOR_NPX-SHOREHAM_138_CSC						FWD	REV
						(Import)	(Export)
Mon 10/19/2020	to	Fri 10/23/2020	<u>UPDATED</u>	<u>by LI</u>	<u>03/02/2020</u>		
0700	Continuous	1500				SCH - NPX_CSC	<b>0 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	330 MW
						TTC with All Lines In Service	330 MW
PANNELL -CLAY_345_2						FWD	
Mon 10/19/2020	to	Fri 10/23/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/07/2020</u>	(Import)	
0700	Continuous	1530				WEST CENTRAL	<b>1300 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	950 MW
						TTC with All Lines In Service	2250 MW
COOPERS -DOLSONAV_345_CCDA42						FWD	
Mon 10/19/2020	to	Fri 11/06/2020				(Import)	
0700	Continuous	1730				CENTRAL EAST - VC	<b>2720 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	255 MW
						TTC with All Lines In Service	2975 MW
MILLWOOD_345KV_18						FWD	
Fri 10/23/2020	to	Fri 10/23/2020				(Import)	
2130	Continuous	2200				UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	1870 MW
						TTC with All Lines In Service	6220 MW
HUDSONTP-W49TH_ST_345_Y56						FWD	
Sat 10/24/2020	to	Fri 10/30/2020				(Import)	
0001	Continuous	0300				SCH - PJM_HTP	<b>0 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	660 MW
						TTC with All Lines In Service	660 MW
W49TH_ST_345KV_7						FWD	
Sat 10/24/2020	to	Fri 10/30/2020				(Import)	
0001	Continuous	0300				SCH - PJM_HTP	<b>300 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	360 MW
						TTC with All Lines In Service	660 MW
W49TH_ST_345KV_8						FWD	
Sat 10/24/2020	to	Fri 10/30/2020				(Import)	
0001	Continuous	0300				SCH - PJM_HTP	<b>450 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	210 MW
						TTC with All Lines In Service	660 MW



CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK_-TREMONT_345_X28</b>					FWD
Mon 10/26/2020	to	Mon 10/26/2020	<u>UPDATED</u>	<u>by CONED</u> <u>08/31/2020</u>	(Import)
0001	Continuous	0030			
Work scheduled by: ConEd					
					SPR/DUN-SOUTH <b>4200 MW</b>
					Impacts Total Transfer Capability 400 MW
					TTC with All Lines In Service 4600 MW
<b>LEEDS_345_LEEDS SVC</b>					FWD
Mon 10/26/2020	to	Fri 10/30/2020			(Import)
0800	Continuous	1600			
Work scheduled by: NGrid					
					CENTRAL EAST - VC <b>2950 MW</b>
					Impacts Total Transfer Capability 25 MW
					TTC with All Lines In Service 2975 MW
<b>LEEDS_-HURLYAVE_345_301</b>					FWD
Mon 10/26/2020	to	Fri 12/04/2020			(Import)
0800	Continuous	1600			
Work scheduled by: CHGE					
					UPNY CONED <b>4100 MW</b>
					Impacts Total Transfer Capability 2120 MW
					TTC with All Lines In Service 6220 MW
<b>SCH-NE-NYISO_LIMIT_800</b>					FWD
Sun 11/01/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u> <u>06/05/2020</u>	(Import)
0001	Continuous	1630			
Work scheduled by: NGrid					
					SCH - NE - NY <b>1000 MW</b>
					Impacts Total Transfer Capability 400 MW
					TTC with All Lines In Service 1400 MW
<b>SCH-NYISO-NE_LIMIT_700</b>					REV
Sun 11/01/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u> <u>06/05/2020</u>	(Export)
0001	Continuous	1630			
Work scheduled by: NGrid					
					SCH - NE - NY <b>900 MW</b>
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 1700 MW
<b>SCH-IMO-NYISO_LIMIT_1750</b>					FWD
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u> <u>05/03/2019</u>	(Import)
0001	Continuous	2359			
Work scheduled by: IESO					
					SCH - OH - NY <b>2050 MW</b>
					Impacts Total Transfer Capability 0 MW
					TTC with All Lines In Service 2050 MW
<b>SCH-NYISO-IMO_LIMIT_1600</b>					REV
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u> <u>05/03/2019</u>	(Export)
0001	Continuous	2359			
Work scheduled by: IESO					
					SCH - OH - NY <b>1900 MW</b>
					Impacts Total Transfer Capability 0 MW
					TTC with All Lines In Service 1900 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EGRDNCTY\_345\_138\_AT1**

Sun 11/01/2020 to Fri 11/13/2020  
0800 Continuous 2159

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

**EGRDNCTY\_345\_138\_AT2**

Sun 11/01/2020 to Fri 11/13/2020  
0800 Continuous 2159

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

**SPRNBK -EGRDNCTR\_345\_Y49**

Sun 11/01/2020 to Fri 11/13/2020  
0800 Continuous 2159

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **775 MW**  
Impacts Total Transfer Capability 725 MW  
TTC with All Lines In Service 1500 MW

**S.RIPLEY-DUNKIRK\_\_230\_68**

Mon 11/02/2020 to Fri 11/06/2020  
0700 Daily(No Weekends) 1800

Work scheduled by: NGrid

**CANCELLED by NGrid 09/28/2020**

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**S.RIPLEY-DUNKIRK\_\_230\_68**

Mon 11/02/2020 to Fri 11/20/2020  
0700 Continuous 1800

Work scheduled by: NGrid

**UPDATED by NGRID 09/28/2020**

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**SPRNBK -TREMONT\_\_345\_X28**

Fri 11/06/2020 to Sat 11/07/2020  
0001 Continuous 0059

Work scheduled by: ConEd

**UPDATED by CONED 08/31/2020**

FWD  
(Import)  
SPR/DUN-SOUTH **4200 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

**NIAGARA\_\_345KV\_3102**

Fri 11/06/2020 to Fri 11/06/2020  
0500 Continuous 2100

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **2000 MW 1700 MW**  
Impacts Total Transfer Capability 50 MW 200 MW  
TTC with All Lines In Service 2050 MW 1900 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_\_345\_230\_AT4

Fri 11/06/2020 to Fri 11/06/2020  
0500 Continuous 2100

Work scheduled by: NYPA

REV  
(Export)  
SCH - OH - NY 1750 MW  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1900 MW

## SPRNBK\_-TREMONT\_\_345\_X28

Mon 11/09/2020 to Mon 11/09/2020  
0030 Continuous 0059

Work scheduled by: ConEd

UPDATED by CONED 08/31/2020

FWD  
(Import)  
SPR/DUN-SOUTH 4200 MW  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

## S.RIPLEY-DUNKIRK\_\_230\_68

Mon 11/09/2020 to Fri 11/13/2020  
0700 Daily(No Weekends) 1800

Work scheduled by: NGrid

CANCELLED by NGrid 09/28/2020

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## ROSETON\_-ROCKTVRN\_345\_311

Mon 11/09/2020 to Fri 11/20/2020  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED 4400 MW  
Impacts Total Transfer Capability 1820 MW  
TTC with All Lines In Service 6220 MW

## SPRNBK\_-TREMONT\_\_345\_X28

Sat 11/14/2020 to Sun 11/15/2020  
0101 Continuous 0300

Work scheduled by: ConEd

UPDATED by CE 09/18/2020

FWD  
(Import)  
SPR/DUN-SOUTH 4200 MW  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

## CHATGUAY-MASSENA\_\_765\_7040

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 1550 MW  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

## CHATGUAY-MASSENA\_\_765\_7040

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - HQ - NY 0 MW 0 MW  
Impacts Total Transfer Capability 1500 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**MARCY\_\_\_\_765\_345\_AT1**

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1750 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

---

**MARCY\_\_\_\_765\_345\_AT2**

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

---

**MASSENA\_-MARCY\_\_\_\_765\_MSU1**

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2265 MW**  
Impacts Total Transfer Capability 710 MW  
TTC with All Lines In Service 2975 MW

---

**MASSENA\_-MARCY\_\_\_\_765\_MSU1**

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

---

**MASSENA\_-MARCY\_\_\_\_765\_MSU1**

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - HQ - NY **475 MW 1000 MW**  
Impacts Total Transfer Capability 1025 MW 0 MW  
TTC with All Lines In Service 1500 MW 1000 MW

---

**MASSENA\_-MARCY\_\_\_\_765\_MSU1**

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900

Work scheduled by: NYPA

FWD  
(Import)  
SCH - HQ\_CEDARS **90 MW**  
Impacts Total Transfer Capability 109 MW  
TTC with All Lines In Service 199 MW

---

**MASSENA\_-MARCY\_\_\_\_765\_MSU1 & CHATGUAY-MASSENA\_765\_7040**

Sun 11/15/2020 to Mon 11/30/2020  
0100 1900

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,September28, 2020 to Wednesday, March 30, 2022

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230\_MMS1 & MOSES -MASSENA 230\_MMS2

Sun 11/15/2020 to Mon 11/30/2020  
0100 1900

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY 850 MW 0 MW  
Impacts Total Transfer Capability 650 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

MOSES -MASSENA 230\_MMS1 & MOSES -MASSENA 230\_MMS2

Sun 11/15/2020 to Mon 11/30/2020  
0100 1900

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS 90 MW  
Impacts Total Transfer Capability 109 MW  
TTC with All Lines In Service 199 MW

STLAWRNC-MOSES 230\_L33P & MASSENA -MARCY 765\_MSU1

Sun 11/15/2020 to Mon 11/30/2020  
0100 1900

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS 90 MW  
Impacts Total Transfer Capability 109 MW  
TTC with All Lines In Service 199 MW

STLAWRNC-MOSES 230\_L33P & MOSES -MASSENA 230\_MMS1 & MOSES -  
MASSENA 230\_MMS2

Sun 11/15/2020 to Mon 11/30/2020  
0100 1900

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS 90 MW  
Impacts Total Transfer Capability 109 MW  
TTC with All Lines In Service 199 MW

DUNWODIE-MOTTHAVN\_345\_71

Mon 11/16/2020 to Wed 11/18/2020 UPDATED by CONED 09/28/2020  
0001 Continuous 0100

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH 3800 MW  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

DUNWODIE\_345KV\_5

Mon 11/16/2020 to Wed 11/18/2020 UPDATED by CONED 09/28/2020  
0001 Continuous 0100

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH 3800 MW  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

S.RIPLEY-DUNKIRK 230\_68

Mon 11/16/2020 to Mon 11/16/2020 CANCELLED by NGrid 09/28/2020  
0700 Daily(No Weekends) 1800

Work scheduled by: NGrid

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_6**

FWD

Wed 11/18/2020 to Wed 11/18/2020 UPDATED by CONED 09/28/2020

(Import)

0101 Continuous 0130

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**DUNWODIE\_345KV\_8**

FWD

Wed 11/18/2020 to Wed 11/18/2020 UPDATED by CONED 09/28/2020

(Import)

0101 Continuous 0130

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**PLSNTVLE-DUNWODIE\_345\_W90**

FWD

Wed 11/18/2020 to Wed 11/18/2020 UPDATED by CONED 09/28/2020

(Import)

0101 Continuous 0130

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

**WOOD\_ST\_-PLSNTVLE\_345\_Y87**

FWD

Wed 11/18/2020 to Wed 11/18/2020 UPDATED by CONED 09/28/2020

(Import)

0101 Continuous 0130

UPNY CONED

**5905 MW**

Impacts Total Transfer Capability 315 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

**DUNWODIE\_345KV\_6**

FWD

Wed 11/18/2020 to Wed 11/18/2020 UPDATED by CONED 09/28/2020

(Import)

1730 Continuous 1800

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**DUNWODIE\_345KV\_8**

FWD

Wed 11/18/2020 to Wed 11/18/2020 UPDATED by CONED 09/28/2020

(Import)

1730 Continuous 1800

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**PLSNTVLE-DUNWODIE\_345\_W90**

FWD

Wed 11/18/2020 to Wed 11/18/2020 UPDATED by CONED 09/28/2020

(Import)

1730 Continuous 1800

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## WOOD\_ST\_-PLSNTVLE\_345\_Y87

FWD

Wed 11/18/2020 to Wed 11/18/2020 UPDATED by CONED 09/28/2020

(Import)

1730 Continuous 1800

Work scheduled by: ConEd

UPNY CONED

5905 MW

Impacts Total Transfer Capability 315 MW

TTC with All Lines In Service 6220 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

FWD

Thu 11/19/2020 to Thu 11/19/2020 UPDATED by CONED 09/18/2020

(Import)

0301 Continuous 0330

Work scheduled by: ConEd

UPNY CONED

4350 MW

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

## EASTVIEW-SPRNBK\_345\_W79

FWD

Thu 11/19/2020 to Fri 11/20/2020 UPDATED by CONED 09/18/2020

(Import)

0301 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

4350 MW

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

## W49TH\_ST\_345KV\_6

FWD

Fri 11/20/2020 to Wed 11/25/2020 UPDATED by CE 08/06/2020

(Import)

0001 Continuous 2300

Work scheduled by: ConEd

SCH - PJM\_HTP

300 MW

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

## W49TH\_ST\_345KV\_8

FWD

Fri 11/20/2020 to Wed 11/25/2020 UPDATED by CE 08/06/2020

(Import)

0001 Continuous 2300

Work scheduled by: ConEd

SCH - PJM\_HTP

300 MW

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

FWD

Fri 11/20/2020 to Fri 11/20/2020 UPDATED by CONED 09/18/2020

(Import)

0130 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

4350 MW

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

## MOTTHAVN-RAINEY\_345\_Q12

FWD

Mon 11/23/2020 to Sat 11/28/2020 UPDATED by CONED 09/01/2020

(Import)

0201 Continuous 0159

Work scheduled by: ConEd

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,September28, 2020 to Wednesday, March 30, 2022

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 6220MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLY-WOOD\_ST\_\_345\_F30**

FWD

Mon 11/30/2020 to Mon 11/30/2020 **CANCELLED** **by ConEd** **09/24/2020**

(Import)

0001 Continuous 0030

UPNY CONED

**4000 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

**PLSNTVLY\_345KV\_RNS5**

FWD

Mon 11/30/2020 to Mon 11/30/2020 **CANCELLED** **by ConEd** **09/24/2020**

(Import)

0001 Continuous 0030

UPNY CONED

**3800 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

**MILLWOOD\_345KV\_18**

FWD

Mon 11/30/2020 to Tue 12/01/2020 **CANCELLED** **by ConEd** **09/24/2020**

(Import)

0001 Continuous 0200

UPNY CONED

**4350 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

**DOLSONAV-ROCKTVRN\_345\_DART44**

FWD

Mon 11/30/2020 to Mon 12/14/2020 **UPDATED** **by NYPA** **08/27/2020**

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

**2720 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

FWD

Mon 11/30/2020 to Fri 12/11/2020 **by LI** **09/14/2020**

(Import)

0800 Continuous 1600

SCH - PJM\_NEPTUNE

**0 MW**

Work scheduled by: PJM

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

**NEWBRDGE-DUFFYAVE\_345\_501**

FWD

Mon 11/30/2020 to Fri 12/11/2020 **by LI** **09/14/2020**

(Import)

0800 Continuous 1600

SCH - PJM\_NEPTUNE

**0 MW**

Work scheduled by: PJM

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

**PLSNTVLY-WOOD\_ST\_\_345\_F30**

FWD

Tue 12/01/2020 to Tue 12/01/2020 **CANCELLED** **by ConEd** **09/24/2020**

(Import)

0130 Continuous 0200

UPNY CONED

**4000 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW



# NYISO TRANSFER LIMITATIONS

Monday ,September28, 2020 to Wednesday, March 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PLSNTVLY\_345KV\_RNS5

FWD

Tue 12/01/2020 to Tue 12/01/2020 CANCELLED by ConEd 09/24/2020  
0130 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 2420 MW  
TTC with All Lines In Service 6220 MW

## MARCY\_345KV\_CSC

FWD

Tue 12/01/2020 to Fri 12/11/2020  
0700 Continuous 1730

(Import)

Work scheduled by: NYPA

CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

## MOSES\_-ADIRNDCK\_230\_MAl

FWD

Tue 12/01/2020 to Sat 02/27/2021 UPDATED by NYPA 07/27/2020  
0700 Continuous 1730

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## W49TH\_ST\_345KV\_6

FWD

Tue 12/01/2020 to Tue 12/01/2020 UPDATED by CE 08/06/2020  
2230 Continuous 2300

(Import)

Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

## W49TH\_ST\_345KV\_8

FWD

Tue 12/01/2020 to Tue 12/01/2020 UPDATED by CE 08/06/2020  
2230 Continuous 2300

(Import)

Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

## KINTIGH\_-ROCHESTR\_345\_SR1-39

FWD

Thu 12/03/2020 to Tue 12/15/2020 UPDATED by NYISO 06/24/2020  
0800 Continuous 1900

(Import)

Work scheduled by: RGE

DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## NIAGARA\_-KINTIGH\_345\_NS1-38

FWD

Thu 12/03/2020 to Tue 12/15/2020 UPDATED by NYISO 06/24/2020  
0800 Continuous 1900

(Import)

Work scheduled by: RGE

DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## BECK\_\_\_\_-PACKARD\_\_230\_BP76

Fri 12/04/2020 to Fri 12/04/2020  
0730 Daily(No Weekends) 1530  
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
SCH - OH - NY	1650 MW	1400 MW
Impacts Total Transfer Capability	400 MW	500 MW
TTC with All Lines In Service	2050 MW	1900 MW

## SAND\_BAR-PLATSBURG\_115\_PV20

Mon 12/07/2020 to Fri 12/11/2020  
0700 Continuous 1530  
Work scheduled by: NYPA

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

## LONG\_MTN-CRICKVLY\_345\_398

Tue 12/08/2020 to Thu 12/10/2020  
0700 Continuous 1600  
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY	700 MW	1300 MW
Impacts Total Transfer Capability	700 MW	400 MW
TTC with All Lines In Service	1400 MW	1700 MW

## LONG\_MTN-CRICKVLY\_345\_398

Tue 12/08/2020 to Thu 12/10/2020  
0700 Continuous 1600  
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

## SCH-NE-NYISO\_LIMIT\_400

Tue 12/08/2020 to Thu 12/10/2020  
0700 Continuous 1600  
Work scheduled by: ISONE

	FWD (Import)
SCH - NE - NY	600 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	1400 MW

## SCH-NYISO-NE\_LIMIT\_1000

Tue 12/08/2020 to Thu 12/10/2020  
0700 Continuous 1600  
Work scheduled by: ISONE

	REV (Export)
SCH - NE - NY	1200 MW
Impacts Total Transfer Capability	500 MW
TTC with All Lines In Service	1700 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

Sat 12/12/2020 to Tue 12/15/2020 **UPDATED by CE 09/17/2020**  
0001 Continuous 0259  
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	4350 MW
Impacts Total Transfer Capability	1870 MW
TTC with All Lines In Service	6220 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## EASTVIEW-SPRNBK\_\_345\_W79

Sat 12/12/2020 to Tue 12/15/2020  
0001 Continuous 0259

Work scheduled by: ConEd

UPDATED by CE 09/17/2020

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 1870 MW  
TTC with All Lines In Service 6220 MW

## MARCY\_\_-EDIC\_\_345\_UE1-7

Mon 12/14/2020 to Mon 12/14/2020  
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19&16

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

## SAND\_BAR-PLATSBURG\_115\_PV20

Mon 12/14/2020 to Fri 12/18/2020  
0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## LADENTWN-BUCHAN\_S\_345\_Y88

Tue 12/15/2020 to Sat 01/30/2021  
0301 Continuous 0300

Work scheduled by: ConEd

UPDATED by CE 09/17/2020

FWD  
(Import)  
UPNY CONED **5930 MW**  
Impacts Total Transfer Capability 290 MW  
TTC with All Lines In Service 6220 MW

## FRASANNX-COOPERS\_\_345\_UCC2-41

Tue 12/15/2020 to Wed 12/16/2020  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

## MARCY\_\_-FRASANNX\_345\_UCC2-41

Tue 12/15/2020 to Wed 12/16/2020  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

## STONYRDLG-HILLSIDE\_230\_72

Wed 12/16/2020 to Mon 12/21/2020  
0800 Continuous 0300

Work scheduled by: NYSEG

FWD  
(Import)  
DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-TREMONT__345_X28						FWD		
Sat 12/19/2020	to	Tue 12/22/2020	<u>UPDATED</u>	<u>by CE</u>	<u>09/27/2020</u>	(Import)		
0301	Continuous	0300					4200 MW	
Work scheduled by: ConEd						SPR/DUN-SOUTH	400 MW	
						Impacts Total Transfer Capability	4600 MW	
						TTC with All Lines In Service		
SPRNBK_-TREMONT__345_X28						FWD		
Thu 12/24/2020	to	Thu 12/24/2020	<u>UPDATED</u>	<u>by CE</u>	<u>09/27/2020</u>	(Import)		
2130	Continuous	2200					4200 MW	
Work scheduled by: ConEd						SPR/DUN-SOUTH	400 MW	
						Impacts Total Transfer Capability	4600 MW	
						TTC with All Lines In Service		
HOPATCON-RAMAPO__500_5018						FWD	REV	
Mon 02/01/2021	to	Sat 02/06/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/25/2020</u>	(Import)	(Export)	
0001	Continuous	0200					1250 MW	1200 MW
Work scheduled by: ConEd						SCH - PJ - NY	650 MW	
						Impacts Total Transfer Capability	1850 MW	
						TTC with All Lines In Service		
HOPATCON-RAMAPO__500_5018						FWD		
Mon 02/01/2021	to	Sat 02/06/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/25/2020</u>	(Import)		
0001	Continuous	0200					6025 MW	
Work scheduled by: ConEd						UPNY CONED		
						Impacts Total Transfer Capability	195 MW	
						TTC with All Lines In Service	6220 MW	
RAMAPO__345_345_PAR3500						FWD	REV	
Mon 02/01/2021	to	Sat 02/06/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/25/2020</u>	(Import)	(Export)	
0001	Continuous	0200					2150 MW	1250 MW
Work scheduled by: ConEd						SCH - PJ - NY	600 MW	
						Impacts Total Transfer Capability	1850 MW	
						TTC with All Lines In Service		
RAMAPO__345_345_PAR4500						FWD	REV	
Mon 02/01/2021	to	Sat 02/06/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/25/2020</u>	(Import)		
0001	Continuous	0200					2150 MW	1250 MW
Work scheduled by: ConEd						SCH - PJ - NY	600 MW	
						Impacts Total Transfer Capability	1850 MW	
						TTC with All Lines In Service		
RAMAPO__500_345_BK 1500						FWD	REV	
Mon 02/01/2021	to	Sat 02/06/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/25/2020</u>	(Import)		
0001	Continuous	0200					1250 MW	1200 MW
Work scheduled by: ConEd						SCH - PJ - NY	650 MW	
						Impacts Total Transfer Capability	1850 MW	
						TTC with All Lines In Service		

# NYISO TRANSFER LIMITATIONS

Monday ,September 28, 2020 to Wednesday, March 30, 2022

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### RAMAPO\_\_\_500\_345\_BK 1500

FWD

Mon 02/01/2021 to Sat 02/06/2021 UPDATED by CONED 09/25/2020

(Import)

0001 Continuous 0200

UPNY CONED

**6025 MW**

Impacts Total Transfer Capability 195 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

### PORTER\_-ROTTDAM 230\_31

FWD

Mon 02/01/2021 to Sat 02/27/2021

(Import)

0600 Continuous 1830

CENTRAL EAST - VC

**2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

### PLSNTVLY-WOOD\_ST\_345\_F30

FWD

Sun 02/14/2021 to Tue 02/16/2021 UPDATED by CONED 09/28/2020

(Import)

2000 Continuous 0200

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

### PLSNTVLY\_345KV\_RNS5

FWD

Sun 02/14/2021 to Tue 02/16/2021 UPDATED by CONED 09/28/2020

(Import)

2000 Continuous 0200

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

### EFISHKIL-WOOD\_ST\_345\_F39

FWD

Thu 02/18/2021 to Sat 02/20/2021 UPDATED by CE 04/01/2020

(Import)

2100 Continuous 0200

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

### WOOD\_ST\_-PLSNTVLE 345\_Y87

FWD

Thu 02/18/2021 to Sat 02/20/2021 UPDATED by CE 04/01/2020

(Import)

2100 Continuous 0200

UPNY CONED

**5905 MW**

Impacts Total Transfer Capability 315 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

### CHATGUAY-MASSENA\_765\_7040

FWD

Sun 02/28/2021 to Mon 03/01/2021

(Import)

0500 Continuous 1730

MOSES SOUTH

**1550 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHATGUAY-MASSENA__765_7040</b>			FWD	REV
Sun 02/28/2021	to	Mon 03/01/2021	(Import)	(Export)
0500	Continuous	1730	SCH - HQ - NY	<b>0 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1500 MW
			TTC with All Lines In Service	1500 MW
<b>MASSENA_-MARCY____765_MSU1</b>			FWD	
Sun 02/28/2021	to	Mon 03/01/2021	(Import)	
0500	Continuous	1730	CENTRAL EAST - VC	<b>2265 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	710 MW
			TTC with All Lines In Service	2975 MW
<b>MASSENA_-MARCY____765_MSU1</b>			FWD	
Sun 02/28/2021	to	Mon 03/01/2021	(Import)	
0500	Continuous	1730	MOSES SOUTH	<b>500 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY____765_MSU1</b>			FWD	REV
Sun 02/28/2021	to	Mon 03/01/2021	(Import)	(Export)
0500	Continuous	1730	SCH - HQ - NY	<b>475 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1025 MW
			TTC with All Lines In Service	1500 MW
<b>MASSENA_-MARCY____765_MSU1</b>			FWD	
Sun 02/28/2021	to	Mon 03/01/2021	(Import)	
0500	Continuous	1730	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
<b>MASSENA_-MARCY____765_MSU1 &amp; CHATGUAY-MASSENA__765_7040</b>			FWD	
Sun 02/28/2021	to	Mon 03/01/2021	(Import)	
0500		1730	MOSES SOUTH	<b>500 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
<b>STLAWRNC-MOSES____230_L33P &amp; MASSENA_-MARCY____765_MSU1</b>			FWD	
Sun 02/28/2021	to	Mon 03/01/2021	(Import)	
0500		1730	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_3**

FWD

Mon 03/01/2021 to Mon 03/01/2021

(Import)

0001 Continuous 0030

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

Work scheduled by: ConEd

TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_5**

FWD

Mon 03/01/2021 to Mon 03/01/2021

(Import)

0001 Continuous 0030

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

Work scheduled by: ConEd

TTC with All Lines In Service 4600 MW

**EASTVIEW-SPRNBK\_345\_W64**

FWD

Mon 03/01/2021 to Mon 03/01/2021

(Import)

0001 Continuous 0030

**UPDATED by CONED 01/23/2020**

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1870 MW

Work scheduled by: ConEd

TTC with All Lines In Service 6220 MW

**SPRNBK\_345KV\_RNS5**

FWD

Mon 03/01/2021 to Mon 03/01/2021

(Import)

0001 Continuous 0030

**UPDATED by CONED 01/23/2020**

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

Work scheduled by: ConEd

TTC with All Lines In Service 4600 MW

**MILLWOOD-EASTVIEW\_345\_W99**

FWD

Mon 03/01/2021 to Mon 03/22/2021

(Import)

0001 Continuous 0200

**UPDATED by CONED 01/23/2020**

UPNY CONED

**5985 MW**

Impacts Total Transfer Capability 235 MW

Work scheduled by: ConEd

TTC with All Lines In Service 6220 MW

**DUNWODIE-MOTTHAVN\_345\_71**

FWD

Mon 03/01/2021 to Mon 04/05/2021

(Import)

0001 Continuous 0300

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

Work scheduled by: ConEd

TTC with All Lines In Service 4600 MW

**MOTTHAVN-RAINEY\_345\_Q11**

FWD

Mon 03/01/2021 to Tue 04/06/2021

(Import)

0001 Continuous 0700

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

Work scheduled by: ConEd

TTC with All Lines In Service 4600 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## EDIC\_\_\_\_-N.SCTLND\_345\_14

Tue 03/02/2021 to Mon 05/31/2021

0600 Continuous 1830

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC **2240 MW**

Impacts Total Transfer Capability 735 MW

TTC with All Lines In Service 2975 MW

## PORTER\_\_\_\_-ROTTDAM\_230\_31

Tue 03/02/2021 to Mon 05/31/2021

0600 Continuous 1830

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC **2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA1

Tue 03/02/2021 to Mon 05/31/2021

0700 Continuous 1300

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## NIAGARA\_\_\_\_-ROBNSNRD\_230\_64

Fri 03/12/2021 to Fri 03/12/2021

0500 Continuous 1700

Work scheduled by: NYPA

REV

(Export)

SCH - OH - NY **1900 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 1900 MW

## MARCY\_\_\_\_345KV\_CSC

Sat 03/13/2021 to Sat 03/13/2021

0700 Continuous 1730

Work scheduled by: NYPA

UPDATED

by NYPA

07/29/2020

FWD

(Import)

CENTRAL EAST - VC **2925 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

## EASTVIEW-SPRNBK\_\_\_\_345\_W64

Mon 03/22/2021 to Mon 03/22/2021

0130 Continuous 0200

Work scheduled by: ConEd

UPDATED

by CONED

01/23/2020

FWD

(Import)

UPNY CONED **4350 MW**

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

## SPRNBK\_\_\_\_345KV\_RNS5

Mon 03/22/2021 to Mon 03/22/2021

0130 Continuous 0200

Work scheduled by: ConEd

UPDATED

by CONED

01/23/2020

FWD

(Import)

SPR/DUN-SOUTH **3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW



CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CLAY\_\_\_\_-EDIC\_\_\_\_345\_2-15

Mon 03/29/2021 to Fri 04/16/2021

0800 Continuous 1730

Work scheduled by: NYPA

09/12/2020

OSWEGO EXPORT

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

FWD

(Import)

**4850 MW**

## W49TH\_ST\_345KV\_5

Wed 03/31/2021 to Wed 05/05/2021

0400 Continuous 0300

Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

FWD

(Import)

**300 MW**

## ROCHESTR-PANNELL\_\_345\_RP2

Wed 03/31/2021 to Mon 04/12/2021

0500 Continuous 1700

Work scheduled by: NYPA

DYSINGER EAST

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

FWD

(Import)

**2300 MW**

## LINDN\_CG-LNDVFT\_\_345\_V-3022

Sun 04/04/2021 to Sat 04/10/2021

1400 Continuous 1400

Work scheduled by: PJM

SCH - PJM\_VFT

Impacts Total Transfer Capability 315 MW 315 MW

TTC with All Lines In Service 315 MW 315 MW

FWD

(Import) (Export)

**0 MW 0 MW**

## DUNWODIE\_345KV\_3

Mon 04/05/2021 to Mon 04/05/2021

0230 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

FWD

(Import)

**3800 MW**

## DUNWODIE\_345KV\_5

Mon 04/05/2021 to Mon 04/05/2021

0230 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

FWD

(Import)

**3800 MW**

## SPRNBK\_-TREMONT\_\_345\_X28

Mon 04/19/2021 to Tue 04/20/2021

0001 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

FWD

(Import)

**4200 MW**

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLY-WOOD\_ST\_\_345\_F31**

FWD

Tue 04/27/2021 to Wed 04/28/2021

(Import)

0001 Continuous 0159

UPNY CONED

**4000 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

**PLSNTVLY\_345KV\_RNS4**

FWD

Tue 04/27/2021 to Wed 04/28/2021

(Import)

0001 Continuous 0159

UPNY CONED

**3800 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

**SPRNBRK\_\_345KV\_RNS4**

FWD

Sat 05/01/2021 to Sat 05/01/2021

(Import)

0001 Continuous 0030

SPR/DUN-SOUTH

**3200 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

**SPRNBRK\_-W49TH\_ST\_345\_M52**

FWD

Sat 05/01/2021 to Tue 05/04/2021

(Import)

0001 Continuous 0300

SPR/DUN-SOUTH

**3200 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

**W49TH\_ST\_345KV\_7**

FWD

Sat 05/01/2021 to Tue 05/04/2021

(Import)

0001 Continuous 0300

SCH - PJM\_HTP

**300 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

**SCH-IMO-NYISO\_LIMIT\_1600**

FWD

Sat 05/01/2021 to Sun 10/31/2021

(Import)

0001 Continuous 2359

**UPDATED by IESO 05/03/2019**

SCH - OH - NY

**1900 MW**

Work scheduled by: IESO

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 1950 MW

**CLAY\_-EDIC\_345\_2-15**

FWD

Mon 05/03/2021 to Fri 05/07/2021

(Import)

0700 Continuous 1530

OSWEGO EXPORT

**4850 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PANNELL\_-CLAY\_\_\_\_\_345\_2

Mon 05/03/2021 to Sun 05/30/2021  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

## HURLYAVE-ROSETON\_\_\_345\_303

Mon 05/03/2021 to Fri 05/21/2021  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 2120 MW  
TTC with All Lines In Service 6220 MW

## SPRNBK\_\_345KV\_RNS4

Tue 05/04/2021 to Tue 05/04/2021  
0230 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

## NIAGARA\_\_345KV\_3102

Thu 05/06/2021 to Fri 05/07/2021  
0500 Continuous 1700

Work scheduled by: NYPA

FWD	REV
(Import)	(Export)
SCH - OH - NY	<b>1700 MW 1400 MW</b>
Impacts Total Transfer Capability	250 MW 300 MW
TTC with All Lines In Service	1950 MW 1700 MW

## NIAGARA\_\_345KV\_3302

Mon 05/10/2021 to Wed 05/12/2021  
0500 Continuous 1700

Work scheduled by: NYPA

FWD	REV
(Import)	(Export)
SCH - OH - NY	<b>1000 MW 1600 MW</b>
Impacts Total Transfer Capability	950 MW 100 MW
TTC with All Lines In Service	1950 MW 1700 MW

## CLAY\_\_\_\_\_EDIC\_\_\_\_\_345\_1-16

Mon 05/10/2021 to Fri 05/14/2021  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

## NIAGARA\_\_345KV\_3108

Thu 05/13/2021 to Fri 05/14/2021  
0500 Continuous 1700

Work scheduled by: NYPA

	REV
	(Export)
SCH - OH - NY	<b>1500 MW</b>
Impacts Total Transfer Capability	200 MW
TTC with All Lines In Service	1700 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## VOLNEY\_\_-MARCY\_\_\_\_345\_19

Tue 06/01/2021 to Wed 06/02/2021  
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2825 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 2975 MW

## VOLNEY\_\_-MARCY\_\_\_\_345\_19

Tue 06/01/2021 to Wed 06/02/2021  
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
OSWEGO EXPORT **4900 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 5250 MW

## FRASER\_\_-GILBOA\_\_\_\_345\_GF5-35

Tue 06/01/2021 to Mon 06/07/2021  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

## MOSES\_\_-ADIRNDCK\_230\_MA2

Tue 06/01/2021 to Sun 11/14/2021  
0700 Continuous 1300

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## PORTER\_\_-ROTTRDAM\_230\_30

Thu 06/03/2021 to Wed 09/15/2021  
0600 Continuous 0559

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2805 MW**  
Impacts Total Transfer Capability 170 MW  
TTC with All Lines In Service 2975 MW

## MARCY\_\_-EDIC\_\_\_\_345\_UE1-7

Thu 06/03/2021 to Fri 06/04/2021  
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19&amp;16

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

## MARCY\_\_\_\_345KV\_CSC

Sat 06/05/2021 to Sat 06/05/2021  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,September28, 2020 to Wednesday, March 30, 2022

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 6220MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA2 & MARCY\_\_\_345KV\_3102 & MARCY\_\_\_345KV\_3202 & MARCY\_\_\_345KV\_3302**

FWD

(Import)

Sat 06/05/2021 to Sat 06/05/2021  
 0700 1730

MOSES SOUTH

**1800 MW**

Impacts Total Transfer Capability 1350 MW

TTC with All Lines In Service 3150 MW

Work scheduled by:

**SAND\_BAR-PLATSBURG\_115\_PV20**

Tue 08/03/2021 to Tue 08/03/2021  
 0700 Continuous 1830

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYPA

**FRASANNX-COOPERS\_\_\_345\_UCC2-41**

FWD

(Import)

Tue 09/07/2021 to Wed 09/15/2021  
 0700 Continuous 1730

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 19****MARCY\_\_\_-FRASANNX\_345\_UCC2-41**

FWD

(Import)

Tue 09/07/2021 to Wed 09/15/2021  
 0700 Continuous 1730

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 19****NIAGARA\_-KINTIGH\_\_\_345\_NS1-38**

FWD

(Import)

Mon 09/13/2021 to Fri 09/17/2021  
 0500 Continuous 1700

DYSINGER EAST

**1400 MW**

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**PORTER\_\_\_-ROTTRDAM\_230\_30**

FWD

(Import)

Wed 09/15/2021 to Tue 11/30/2021  
 0600 Continuous 1830

CENTRAL EAST - VC

**2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**EDIC\_\_\_-N.SCTLND\_345\_14**

FWD

(Import)

Thu 09/16/2021 to Sun 11/14/2021  
 0600 Continuous 1830

CENTRAL EAST - VC

**2240 MW**

Impacts Total Transfer Capability 735 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HURLYAVE-ROSETON\_\_345\_303

FWD

Thu 09/16/2021 to Sun 10/17/2021

UPDATEDby CHGE09/22/2020

(Import)

0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 2120 MW

TTC with All Lines In Service 6220 MW

## PANNELL\_-CLAY\_\_\_\_345\_1

FWD

Mon 09/20/2021 to Fri 09/24/2021

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

## PANNELL\_-CLAY\_\_\_\_345\_2

FWD

Mon 09/27/2021 to Fri 10/01/2021

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

## W49TH\_ST\_345KV\_6

FWD

Tue 09/28/2021 to Tue 09/28/2021

(Import)

0100 Continuous 0130

Work scheduled by: ConEd

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

## E13THSTA-FARRAGUT\_345\_46

FWD

Tue 09/28/2021 to Tue 10/26/2021

(Import)

0100 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

## W49TH\_ST-E13THSTA\_345\_M55

FWD

Tue 09/28/2021 to Tue 10/26/2021

(Import)

0100 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

## LEEDS\_\_\_\_-HURLYAVE\_345\_301

FWD

Mon 10/18/2021 to Fri 11/19/2021

(Import)

0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 2120 MW

TTC with All Lines In Service 6220 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,September28, 2020 to Wednesday, March 30, 2022

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 6220MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_6**

FWD

Tue 10/26/2021 to Tue 10/26/2021

(Import)

0230 Continuous 0300

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

Work scheduled by: ConEd

TTC with All Lines In Service 660 MW

**SCH-IMO-NYISO\_LIMIT\_1750**

FWD

Mon 11/01/2021 to Fri 12/31/2021

(Import)

0001 Continuous 2359

UPDATEDby IESO05/03/2019

SCH - OH - NY

**2050 MW**

Impacts Total Transfer Capability 0 MW

Work scheduled by: IESO

TTC with All Lines In Service 2050 MW

**SCH-NYISO-IMO\_LIMIT\_1600**

REV

Mon 11/01/2021 to Fri 12/31/2021

(Export)

0001 Continuous 2359

UPDATEDby IESO05/03/2019

SCH - OH - NY

**1900 MW**

Impacts Total Transfer Capability 0 MW

Work scheduled by: IESO

TTC with All Lines In Service

1900 MW

**MOSES\_\_-ADIRNDCK\_230\_Ma1**

FWD

Wed 12/01/2021 to Tue 05/31/2022

(Import)

0700 Continuous 1300

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

Work scheduled by: NYPA

TTC with All Lines In Service 3150 MW