

# NYISO TRANSFER LIMITATIONS

Monday ,September14, 2020 to Wednesday, March 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE\_345KV\_9\_BYPASS & DUNWODIE\_345KV\_10\_BYPASS & SPRNBRK\_\_345KV\_R5S3\_BYPASS  
& SPRNBRK\_\_345KV\_R4S3\_BYPASS

FWD  
(Import)

Sun 02/01/2015 to Sat 02/01/2025  
0000 0000

SPR/DUN-SOUTH **4350 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 4600 MW

Work scheduled by:

DUNWODIE\_345KV\_9\_BYPASS & DUNWODIE\_345KV\_10\_BYPASS & SPRNBRK\_\_345KV\_R5S3\_BYPASS  
& SPRNBRK\_\_345KV\_R4S3\_BYPASS

Sun 02/01/2015 to Sat 02/01/2025  
0000 0000

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

Work scheduled by:

HUDSONP\_-FARRAGUT\_345\_B3402

FWD REV  
(Import) (Export)

Mon 01/15/2018 to Sun 02/28/2021 EXT FORCE by CONED 08/28/2020  
0001 Continuous 2359

SCH - PJ - NY **2050 MW 1150 MW**  
Impacts Total Transfer Capability 150 MW 100 MW  
TTC with All Lines In Service 2200 MW 1250 MW

Work scheduled by: ConEd

HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

FWD REV  
(Import) (Export)

Mon 01/15/2018 to Sun 02/28/2021  
0001 2359

SCH - PJ - NY **2000 MW 1000 MW**  
Impacts Total Transfer Capability 200 MW 250 MW  
TTC with All Lines In Service 2200 MW 1250 MW

Work scheduled by:

MARION\_-FARRAGUT\_345\_C3403

FWD REV  
(Import) (Export)

Mon 01/15/2018 to Sun 02/28/2021 EXT FORCE by CONED 08/28/2020  
0001 Continuous 2359

SCH - PJ - NY **2050 MW 1150 MW**  
Impacts Total Transfer Capability 150 MW 100 MW  
TTC with All Lines In Service 2200 MW 1250 MW

Work scheduled by: ConEd

STLAWRNC-MOSES\_\_\_\_230\_L33P

Mon 04/30/2018 to Thu 03/31/2022 EXT FORCE by IESO 09/04/2020  
0456 Continuous 2359

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

Work scheduled by: IESO

# NYISO TRANSFER LIMITATIONS

Monday ,September14, 2020 to Wednesday, March 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-IMO-NYISO\_LIMIT\_1600

Fri 05/01/2020 to Sat 10/31/2020 UPDATED by IESO 05/03/2019

0001 Continuous 2359

Work scheduled by: IESO

FWD  
(Import)  
**1900 MW**  
SCH - OH - NY  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 1950 MW

## SHOR\_NPX-SHOREHAM\_138\_CSC

Wed 07/08/2020 to Fri 09/25/2020 EXT FORCE by ISONE 07/20/2020

1247 Continuous 2359

Work scheduled by: LI

FWD REV  
(Import) (Export)  
**0 MW 0 MW**  
SCH - NPX\_CSC  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

## MOSES\_\_-ADIRNDCK\_230\_MA2

Thu 08/13/2020 to Wed 09/09/2020 UPDATED by NYPA 09/04/2020

0500 Continuous 0659

Work scheduled by: NYPA

FWD  
(Import)  
**2100 MW**  
MOSES SOUTH  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## SPRNBK\_-W49TH\_ST\_345\_M52

Sun 08/16/2020 to Thu 10/08/2020 EXT FORCE by CONED 08/26/2020

1149 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
**3200 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

## BECK\_\_-NIAGARA\_230\_PA27

Mon 08/31/2020 to Mon 11/30/2020

0700 Continuous 0700

Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## SCH-IMO-NYISO\_LIMIT\_1450

Mon 08/31/2020 to Mon 11/30/2020

0700 Continuous 0700

Work scheduled by: IESO

FWD  
(Import)  
**1750 MW**  
SCH - OH - NY  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1950 MW

## HOMRC\_NY-MAINS\_NY\_345\_47

Tue 09/01/2020 to Fri 10/09/2020

0700 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Monday ,September14, 2020 to Wednesday, March 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE_345_138_BK_1						FWD
Wed 09/02/2020	to	Wed 09/30/2020	<u>EXT FORCE</u>	<u>by LI</u>	<u>09/03/2020</u>	(Import)
1807	Continuous	2359				SCH - PJM_NEPTUNE 375 MW
Work scheduled by: LI						Impacts Total Transfer Capability 285 MW
						TTC with All Lines In Service 660 MW
SCH-NYISO-HQ_CEDARS_LIMIT_0						REV
Tue 09/08/2020	to	Thu 09/24/2020	<u>UPDATED</u>	<u>by HQ</u>	<u>09/06/2020</u>	(Export)
0500	Continuous	1700				SCH - HQ_CEDARS 0 MW
Work scheduled by: HQ						Impacts Total Transfer Capability 40 MW
						TTC with All Lines In Service 40 MW
MOSES__-ADIRNDCK_230_MA2						FWD
Wed 09/09/2020	to	Sat 11/14/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/04/2020</u>	(Import)
0700	Continuous	1300				MOSES SOUTH 2100 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1050 MW
						TTC with All Lines In Service 3150 MW
MARCY__-N.SCTLND_345_18						FWD
Wed 09/09/2020	to	Wed 09/09/2020				(Import)
0800	Daily(No Weekends)	1500				CENTRAL EAST - VC 2090 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 885 MW
						TTC with All Lines In Service 2975 MW
MEYER__-CANANDGA_230_60						FWD
Thu 09/10/2020	to	Thu 09/10/2020				(Import)
0730	Continuous	1630				DYSINGER EAST 2850 MW
Work scheduled by: NYSEG						Impacts Total Transfer Capability 300 MW
						TTC with All Lines In Service 3150 MW
SPRNBRK__345KV_RNS4						FWD
Fri 09/11/2020	to	Sun 09/13/2020				(Import)
0038	Continuous	2359				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 4600 MW
SPRNBRK__345KV_RNS4						FWD
Sat 09/12/2020	to	Sun 09/13/2020	<u>CANCELLED</u>	<u>by NYISO</u>	<u>09/11/2020</u>	(Import)
0001	Continuous	2359				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 4600 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,September14, 2020 to Wednesday, March 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>FITZPTRK-EDIC_____345_FE-1</b>					FWD		
Mon 09/14/2020	to	Mon 09/28/2020	<u>UPDATED</u>	<u>by NGRID</u>	<u>09/11/2020</u>	(Import)	
0001	Continuous	1100				CENTRAL EAST - VC	<b>2825 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	150 MW
						TTC with All Lines In Service	2975 MW
<b>FITZPTRK-EDIC_____345_FE-1</b>					FWD		
Mon 09/14/2020	to	Mon 09/28/2020	<u>UPDATED</u>	<u>by NGRID</u>	<u>09/11/2020</u>	(Import)	
0001	Continuous	1100				OSWEGO EXPORT	<b>4800 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	450 MW
						TTC with All Lines In Service	5250 MW
<b>NIAGARA__345KV_3302</b>					FWD		
Mon 09/14/2020	to	Mon 09/14/2020	<u>UPDATED</u>	<u>by NYSEG</u>	<u>09/11/2020</u>	(Import)	(Export)
0500	Continuous	0600				SCH - OH - NY	<b>1000 MW 1600 MW</b>
Work scheduled by: NYSEG						Impacts Total Transfer Capability	950 MW 100 MW
						TTC with All Lines In Service	1950 MW 1700 MW
<b>KINTIGH_-ROCHESTR_345_SR1-39</b>					FWD		
Mon 09/14/2020	to	Thu 09/17/2020	<u>UPDATED</u>	<u>by NYSEG</u>	<u>09/11/2020</u>	(Import)	
0500	Continuous	1530				DYSINGER EAST	<b>1400 MW</b>
Work scheduled by: NYSEG						Impacts Total Transfer Capability	1750 MW
						TTC with All Lines In Service	3150 MW
<b>NIAGARA_-KINTIGH__345_NS1-38</b>					FWD		
Mon 09/14/2020	to	Thu 09/17/2020	<u>UPDATED</u>	<u>by NYSEG</u>	<u>09/11/2020</u>	(Import)	
0500	Continuous	1530				DYSINGER EAST	<b>1400 MW</b>
Work scheduled by: NYSEG						Impacts Total Transfer Capability	1750 MW
						TTC with All Lines In Service	3150 MW
<b>LINDN_CG-LNDVFT_____345_V-3022</b>					FWD		
Mon 09/14/2020	to	Wed 09/16/2020	<u>UPDATED</u>	<u>by NYISO</u>	<u>09/10/2020</u>	(Import)	(Export)
0800	Continuous	2000				SCH - PJM_VFT	<b>0 MW 0 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	315 MW 315 MW
						TTC with All Lines In Service	315 MW 315 MW
<b>WOOD_ST_-PLSNTVLE_345_Y87</b>					FWD		
Mon 09/14/2020	to	Wed 09/16/2020	<u>UPDATED</u>	<u>by CE</u>	<u>09/04/2020</u>	(Import)	
2000	Continuous	0200				UPNY CONED	<b>5905 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	315 MW
						TTC with All Lines In Service	6220 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EFISHKIL-WOOD\_ST\_\_345\_F39**

FWD

Mon 09/14/2020 to Wed 09/16/2020 UPDATED by CE 09/04/2020

(Import)

2000 Continuous 2200

UPNY CONED **4000 MW**

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

**ADIRNDCK-CHASLAKE\_230\_13**

FWD

Tue 09/15/2020 to Tue 09/15/2020 UPDATED by NGRID 08/06/2020

(Import)

0700 Continuous 1530

MOSES SOUTH **2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**WOOD\_ST\_-PLSNTVLE\_345\_Y87**

FWD

Wed 09/16/2020 to Wed 09/16/2020 UPDATED by CE 09/04/2020

(Import)

2130 Continuous 2200

UPNY CONED **5905 MW**

Impacts Total Transfer Capability 315 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

FWD

Thu 09/17/2020 to Thu 09/17/2020

(Import)

0700 Continuous 1700

SCH - PJM\_NEPTUNE **0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

**NEWBRDGE-DUFFYAVE\_345\_501**

FWD

Thu 09/17/2020 to Thu 09/17/2020

(Import)

0700 Continuous 1700

SCH - PJM\_NEPTUNE **0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

**NEWBRDGE\_345\_138\_BK\_2**

FWD

Thu 09/17/2020 to Thu 09/17/2020

(Import)

0700 Continuous 1700

SCH - PJM\_NEPTUNE **375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

**S.RIPLEY-DUNKIRK\_\_230\_68**

Thu 09/17/2020 to Fri 09/18/2020

0900 Continuous 1500

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: PJM

# NYISO TRANSFER LIMITATIONS

Monday ,September14, 2020 to Wednesday, March 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_\_345KV\_3302**

Thu 09/17/2020 to Thu 09/17/2020 UPDATED by NYSEG 09/11/2020  
1430 Continuous 1530

Work scheduled by: NYSEG

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1000 MW</b>	<b>1600 MW</b>
Impacts Total Transfer Capability	950 MW	100 MW
TTC with All Lines In Service	1950 MW	1700 MW

**NIAGARA\_-ROCHESTR\_345\_NR2**

Fri 09/18/2020 to Sat 11/14/2020 UPDATED by NYPA 08/27/2020  
0500 Continuous 2330

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>1400 MW</b>
Impacts Total Transfer Capability	1750 MW
TTC with All Lines In Service	3150 MW

**NIAGARA\_\_345KV\_3108**

Fri 09/18/2020 to Sat 11/14/2020 UPDATED by NYPA 08/27/2020  
0500 Continuous 2330

Work scheduled by: NYPA

	REV
	(Export)
SCH - OH - NY	<b>1500 MW</b>
Impacts Total Transfer Capability	200 MW
TTC with All Lines In Service	1700 MW

**MILLWOOD\_345KV\_18**

Sun 09/20/2020 to Sun 09/20/2020 UPDATED by CONED 08/25/2020  
0001 Continuous 0030

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>4350 MW</b>
Impacts Total Transfer Capability	1870 MW
TTC with All Lines In Service	6220 MW

**BUCHAN\_S-MILLWOOD\_345\_W98**

Sun 09/20/2020 to Fri 09/25/2020 UPDATED by CONED 08/25/2020  
0001 Continuous 2230

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>6135 MW</b>
Impacts Total Transfer Capability	85 MW
TTC with All Lines In Service	6220 MW

**NIAGARA\_\_345KV\_3102**

Sun 09/20/2020 to Sun 09/20/2020  
0500 Continuous 2100

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1700 MW</b>	<b>1400 MW</b>
Impacts Total Transfer Capability	250 MW	300 MW
TTC with All Lines In Service	1950 MW	1700 MW

**NIAGARA\_\_345\_230\_AT4**

Sun 09/20/2020 to Sun 09/20/2020  
0500 Continuous 2100

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1900 MW</b>	<b>1400 MW</b>
Impacts Total Transfer Capability	50 MW	300 MW
TTC with All Lines In Service	1950 MW	1700 MW

# NYISO TRANSFER LIMITATIONS

Monday ,September14, 2020 to Wednesday, March 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CLAY\_\_\_\_-EDIC\_\_\_\_345\_1-16

Mon 09/21/2020 to Fri 09/25/2020  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

## DOLSONAV-ROCKTVRN\_345\_DART44

Mon 09/21/2020 to Fri 09/25/2020  
0700 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
CENTRAL EAST - VC **2720 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

## FRASANNX-COOPERS\_\_345\_UCC2-41

Mon 09/21/2020 to Wed 09/30/2020  
0700 Continuous 1730

Work scheduled by: NYPA

EXTENDED by NYPA 07/21/2020

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

## MARCY\_\_\_\_-FRASANNX\_345\_UCC2-41

Mon 09/21/2020 to Wed 09/30/2020  
0700 Continuous 1730

Work scheduled by: NYPA

EXTENDED by NYPA 07/21/2020

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

## GOETHALS\_345KV\_5

Tue 09/22/2020 to Tue 09/22/2020  
0200 Continuous 0230

Work scheduled by: PJM

UPDATED by CE 06/24/2020

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## BRANCHBG-HOPATCON\_500\_5060

Tue 09/22/2020 to Wed 09/23/2020  
0200 Continuous 2300

Work scheduled by: PJM

UPDATED by PJM 04/20/2020

FWD  
(Import)  
UPNY CONED **6025 MW**  
Impacts Total Transfer Capability 195 MW  
TTC with All Lines In Service 6220 MW

## LINDEN\_\_\_\_-GOETHALS\_230\_A2253

Tue 09/22/2020 to Wed 09/23/2020  
0200 Continuous 2359

Work scheduled by: PJM

UPDATED by CE 06/24/2020

FWD	REV
(Import)	(Export)
SCH - PJ - NY <b>2050 MW</b>	<b>1150 MW</b>
Impacts Total Transfer Capability 150 MW	100 MW
TTC with All Lines In Service 2200 MW	1250 MW

# NYISO TRANSFER LIMITATIONS

Monday ,September14, 2020 to Wednesday, March 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LINDEN\_\_ -GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402

Tue 09/22/2020 to Wed 09/23/2020  
0200 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2000 MW	1000 MW
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

## LINDEN\_\_ -GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_\_ - FARRAGUT\_345\_C3403

Tue 09/22/2020 to Wed 09/23/2020  
0200 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2000 MW	1000 MW
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

## LINDEN\_\_ -GOETHALS\_230\_A2253 & MARION\_\_ -FARRAGUT\_345\_C3403

Tue 09/22/2020 to Wed 09/23/2020  
0200 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2000 MW	1000 MW
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

## ADIRNDCK-CHASLAKE\_230\_13

Wed 09/23/2020 to Wed 09/23/2020 UPDATED by NGRID 08/06/2020  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2100 MW
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

## LINDEN\_\_ -GOETHALS\_230\_A2253

Thu 09/24/2020 to Sat 09/26/2020 UPDATED by PJM 07/06/2020  
0001 Continuous 0300

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2050 MW	1150 MW
Impacts Total Transfer Capability	150 MW	100 MW
TTC with All Lines In Service	2200 MW	1250 MW

## LINDEN\_\_ -GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402

Thu 09/24/2020 to Sat 09/26/2020  
0001 0300

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2000 MW	1000 MW
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW



# NYISO TRANSFER LIMITATIONS

Monday ,September14, 2020 to Wednesday, March 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDEN\_\_-GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_\_-  
FARRAGUT\_345\_C3403

Thu 09/24/2020 to Sat 09/26/2020  
0001 0300

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2000 MW	1000 MW
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

LINDEN\_\_-GOETHALS\_230\_A2253 & MARION\_\_-FARRAGUT\_345\_C3403

Thu 09/24/2020 to Sat 09/26/2020  
0001 0300

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2000 MW	1000 MW
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

MILLWOOD\_345KV\_18

Fri 09/25/2020 to Fri 09/25/2020 UPDATED by CONED 08/25/2020  
0001 Continuous 2230

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	4350 MW
Impacts Total Transfer Capability	1870 MW
TTC with All Lines In Service	6220 MW

W49TH\_ST\_345KV\_5

Fri 09/25/2020 to Sat 09/26/2020 UPDATED by CONED 09/10/2020  
0001 Continuous 0300

Work scheduled by: ConEd

	FWD
	(Import)
SCH - PJM_HTP	300 MW
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

W49TH\_ST\_345KV\_7

Fri 09/25/2020 to Sat 09/26/2020 UPDATED by CONED 09/10/2020  
0001 Continuous 0300

Work scheduled by: ConEd

	FWD
	(Import)
SCH - PJM_HTP	300 MW
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

GOETHALS\_345KV\_5

Sat 09/26/2020 to Sat 09/26/2020 UPDATED by PJM 07/06/2020  
0230 Continuous 0300

Work scheduled by: PJM

	FWD
	(Import)
STATEN ISLAND	
Impacts Total Transfer Capability	
TTC with All Lines In Service	

CRICKVLY-PLSNTVLY\_345\_F83

Mon 09/28/2020 to Sun 10/04/2020  
0001 Continuous 2200

Work scheduled by: ConEd

	FWD
	(Import)
SCH - NE - NY	350 MW
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	1400 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CRICKVLY-PLSNTVLY_345_F83</b>					FWD	REV
Mon 09/28/2020	to	Sun 10/04/2020			(Import)	(Export)
0001	Continuous	2200			SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
<b>W49TH_ST_345KV_5</b>					FWD	
Mon 09/28/2020	to	Mon 09/28/2020	<u>UPDATED</u>	<u>by CONED</u> <u>09/10/2020</u>	(Import)	
0230	Continuous	0300			SCH - PJM_HTP	<b>300 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
<b>W49TH_ST_345KV_7</b>					FWD	
Mon 09/28/2020	to	Mon 09/28/2020	<u>UPDATED</u>	<u>by CONED</u> <u>09/10/2020</u>	(Import)	
0230	Continuous	0300			SCH - PJM_HTP	<b>300 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
<b>NRTH1385-NOR HBR__138_601 &amp; CRICKVLY-PLSNTVLY_345_F83</b>					FWD	REV
Mon 09/28/2020	to	Sun 10/04/2020			(Import)	(Export)
0500		2200			SCH - NPX_1385	<b>0 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_602 &amp; CRICKVLY-PLSNTVLY_345_F83</b>					FWD	REV
Mon 09/28/2020	to	Sun 10/04/2020			(Import)	(Export)
0500		2200			SCH - NPX_1385	<b>0 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_603 &amp; CRICKVLY-PLSNTVLY_345_F83</b>					FWD	REV
Mon 09/28/2020	to	Sun 10/04/2020			(Import)	(Export)
0500		2200			SCH - NPX_1385	<b>0 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_601</b>					FWD	REV
Mon 09/28/2020	to	Sat 10/17/2020	<u>UPDATED</u>	<u>by LIPA</u> <u>07/10/2020</u>	(Import)	(Export)
0500	Continuous	2359			SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_602

Mon 09/28/2020 to Sat 10/17/2020  
0500 2359

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 0 MW 0 MW  
Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_603

Mon 09/28/2020 to Sat 10/17/2020  
0500 2359

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 0 MW 0 MW  
Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NOR HBR\_\_138\_602

Mon 09/28/2020 to Sat 10/17/2020 UPDATED by LIPA 07/10/2020  
0500 Continuous 2359

Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 100 MW 100 MW  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NOR HBR\_\_138\_602 & NRTH1385-NOR HBR\_\_138\_603

Mon 09/28/2020 to Sat 10/17/2020  
0500 2359

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 0 MW 0 MW  
Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NOR HBR\_\_138\_603

Mon 09/28/2020 to Sat 10/17/2020 UPDATED by LIPA 07/10/2020  
0500 Continuous 2359

Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 100 MW 100 MW  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NRTHPORT\_138\_NNC

Mon 09/28/2020 to Sat 10/17/2020 UPDATED by LIPA 07/10/2020  
0500 Continuous 2359

Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 0 MW 0 MW  
Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 200 MW 200 MW

STONYRDG-HILLSIDE\_230\_72

Mon 09/28/2020 to Mon 09/28/2020  
0600 Continuous 0630

Work scheduled by: NYSEG

FWD  
(Import)  
DYSINGER EAST 2850 MW  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY -EDIC 345\_2-15

Mon 09/28/2020 to Fri 10/02/2020  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT 4850 MW  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

ROSETON -ROCKTVRN 345\_311

Mon 09/28/2020 to Fri 10/02/2020  
0800 Continuous 1600

Work scheduled by: CHGE

UPDATED by CHGE 08/27/2020

FWD  
(Import)  
UPNY CONED 4400 MW  
Impacts Total Transfer Capability 1820 MW  
TTC with All Lines In Service 6220 MW

DENNISON-ROSEMNTB 115\_2/22

Mon 09/28/2020 to Fri 10/02/2020  
0800 Continuous 1630

Work scheduled by: NGrid

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS 95 MW 40 MW  
Impacts Total Transfer Capability 95 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

SCRIBA -VOLNEY 345\_21

Tue 09/29/2020 to Wed 09/30/2020  
0800 Continuous 1630

Work scheduled by: NGrid

UPDATED by NGRID 08/01/2020

FWD  
(Import)  
OSWEGO EXPORT 5250 MW  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

W49TH\_ST 345KV\_5

Thu 10/01/2020 to Thu 10/01/2020  
0001 Continuous 1800

Work scheduled by: ConEd

UPDATED by CE 09/02/2020

FWD  
(Import)  
SCH - PJM\_HTP 300 MW  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

EDIC -FRASER 345\_EF24-40

Thu 10/01/2020 to Fri 10/02/2020  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC 2500 MW  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

FITZPTRK-EDIC 345\_FE-1

Thu 10/01/2020 to Thu 10/01/2020  
1400 Continuous 1600

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC 2825 MW  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 2975 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## FITZPTRK-EDIC\_\_\_\_\_345\_FE-1

Thu 10/01/2020 to Thu 10/01/2020  
1400 Continuous 1600

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4800 MW**  
Impacts Total Transfer Capability 450 MW  
TTC with All Lines In Service 5250 MW

## STONYRDG-HILLSIDE\_230\_72

Sun 10/04/2020 to Sun 10/04/2020  
1500 Continuous 1530

Work scheduled by: NYSEG

FWD  
(Import)  
DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

## PANNELL\_-CLAY\_\_\_\_\_345\_1

Mon 10/05/2020 to Fri 10/09/2020  
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 05/07/2020

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

## DUNWODIE-MOTTHAVN\_345\_71

Wed 10/07/2020 to Thu 10/08/2020  
0001 Continuous 0100

Work scheduled by: ConEd

UPDATED by CONED 07/22/2020

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## DUNWODIE\_345KV\_5

Wed 10/07/2020 to Thu 10/08/2020  
0001 Continuous 0100

Work scheduled by: ConEd

UPDATED by CONED 07/22/2020

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## DUNWODIE\_345KV\_3

Wed 10/07/2020 to Thu 11/12/2020  
0001 Continuous 0100

Work scheduled by: ConEd

UPDATED by CONED 07/22/2020

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## DUNWODIE\_345KV\_4

Wed 10/07/2020 to Thu 11/12/2020  
0001 Continuous 0100

Work scheduled by: ConEd

UPDATED by CONED 07/22/2020

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,September14, 2020 to Wednesday, March 16, 2022

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLE-DUNWODIE\_345\_W89**

FWD

Wed 10/07/2020 to Thu 11/12/2020 UPDATED by CONED 07/22/2020

(Import)

0001 Continuous 0100

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

**BRANCHBG-HOPATCON\_500\_5060**

FWD

Wed 10/07/2020 to Wed 10/07/2020

(Import)

0200 Continuous 1500

UPNY CONED

**6025 MW**

Impacts Total Transfer Capability 195 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: PJM

**HOMR\_NYW-PIERC\_NY\_345\_48**Mon 10/12/2020 to Fri 10/30/2020 UPDATED by PJM 08/06/2020

0800 Continuous 1600

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: PJM

**HURLYAVE-ROSETON\_345\_303**

FWD

Tue 10/13/2020 to Fri 10/16/2020 UPDATED by CHGE 09/10/2020

(Import)

0800 Continuous 1600

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 2120 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: CHGE

**SAND\_BAR-PLATSBURG\_115\_PV20**

Sat 10/17/2020 to Sat 11/14/2020

0600 Continuous 1800

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: ISONE

**MILLWOOD\_345KV\_18**

FWD

Mon 10/19/2020 to Mon 10/19/2020

(Import)

0001 Continuous 0030

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

**SCH-NE-NYISO\_LIMIT\_600**

FWD

Mon 10/19/2020 to Sat 10/31/2020 UPDATED by ISONE 06/05/2020

(Import)

0630 Continuous 2359

SCH - NE - NY

**800 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: NGrid

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NYISO-NE_LIMIT_800</b>							REV	
Mon 10/19/2020	to	Sat 10/31/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>		(Export)	
0630	Continuous	2359				SCH - NE - NY	<b>1000 MW</b>	
Work scheduled by: NGrid						Impacts Total Transfer Capability	600 MW	
						TTC with All Lines In Service	1600 MW	
<b>BERKSHIR-ALPS_____345_393</b>							FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>		(Import)	(Export)
0630	Continuous	1630				SCH - NE - NY	<b>950 MW</b>	<b>1300 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	450 MW	300 MW
						TTC with All Lines In Service	1400 MW	1600 MW
<b>BERKSHIR-ALPS_____345_393</b>							FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>		(Import)	(Export)
0630	Continuous	1630				SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW	100 MW
						TTC with All Lines In Service	200 MW	200 MW
<b>BERKSHIR-ALPS_____345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>							FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020					(Import)	(Export)
0630		1630				SCH - NE - NY	<b>950 MW</b>	<b>1300 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	450 MW	300 MW
						TTC with All Lines In Service	1400 MW	1600 MW
<b>BERKSHIR-NORTHFLD_345_312</b>							FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>		(Import)	(Export)
0630	Continuous	1630				SCH - NE - NY	<b>900 MW</b>	<b>1500 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	500 MW	100 MW
						TTC with All Lines In Service	1400 MW	1600 MW
<b>BERKSHIR-NORTHFLD_345_312</b>							FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>		(Import)	(Export)
0630	Continuous	1630				SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW	100 MW
						TTC with All Lines In Service	200 MW	200 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>							FWD	REV
Mon 10/19/2020	to	Fri 10/23/2020	<u>UPDATED</u>	<u>by LI</u>	<u>03/02/2020</u>		(Import)	(Export)
0700	Continuous	1500				SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	330 MW	330 MW
						TTC with All Lines In Service	330 MW	330 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,September14, 2020 to Wednesday, March 16, 2022

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 6220MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PANNELL\_-CLAY\_\_\_\_\_345\_2**

FWD

Mon 10/19/2020 to Fri 10/23/2020

UPDATEDby NYPA05/07/2020

(Import)

0700 Continuous 1530

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

**COOPERS\_-DOLSONAV\_345\_CCD42**

FWD

Mon 10/19/2020 to Fri 11/06/2020

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

**2720 MW**

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**MILLWOOD\_345KV\_18**

FWD

Fri 10/23/2020 to Fri 10/23/2020

(Import)

2130 Continuous 2200

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

**HUDSONTP-W49TH\_ST\_345\_Y56**

FWD

Sat 10/24/2020 to Fri 10/30/2020

(Import)

0001 Continuous 0300

SCH - PJM\_HTP

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**W49TH\_ST\_345KV\_7**

FWD

Sat 10/24/2020 to Fri 10/30/2020

(Import)

0001 Continuous 0300

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**W49TH\_ST\_345KV\_8**

FWD

Sat 10/24/2020 to Fri 10/30/2020

(Import)

0001 Continuous 0300

SCH - PJM\_HTP

**450 MW**

Impacts Total Transfer Capability 210 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**SPRNBK\_-TREMONT\_\_\_345\_X28**

FWD

Mon 10/26/2020 to Mon 10/26/2020

UPDATEDby CONED08/31/2020

(Import)

0001 Continuous 0030

SPR/DUN-SOUTH

**4200 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd



**NYISO TRANSFER LIMITATIONS**

Monday ,September14, 2020 to Wednesday, March 16, 2022

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**LEEDS\_\_\_\_345\_LEEDS SVC**

FWD

Mon 10/26/2020 to Fri 10/30/2020

(Import)

0800 Continuous 1600

CENTRAL EAST - VC

**2950 MW**

Impacts Total Transfer Capability 25 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**LEEDS\_\_\_\_-HURLYAVE\_345\_301**

FWD

Mon 10/26/2020 to Fri 12/04/2020

(Import)

0800 Continuous 1600

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 2120 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: CHGE

**SCH-NE-NYISO\_LIMIT\_800**

FWD

Sun 11/01/2020 to Tue 11/10/2020

(Import)

0001 Continuous 1630

UPDATEDby ISONE 06/05/2020

SCH - NE - NY

**1000 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: NGrid

**SCH-NYISO-NE\_LIMIT\_700**

REV

Sun 11/01/2020 to Tue 11/10/2020

(Export)

0001 Continuous 1630

UPDATEDby ISONE 06/05/2020

SCH - NE - NY

**900 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 1700 MW

Work scheduled by: NGrid

**SCH-IMO-NYISO\_LIMIT\_1750**

FWD

Sun 11/01/2020 to Fri 04/30/2021

(Import)

0001 Continuous 2359

UPDATEDby IESO 05/03/2019

SCH - OH - NY

**2050 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 2050 MW

Work scheduled by: IESO

**SCH-NYISO-IMO\_LIMIT\_1600**

REV

Sun 11/01/2020 to Fri 04/30/2021

(Export)

0001 Continuous 2359

UPDATEDby IESO 05/03/2019

SCH - OH - NY

**1900 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 1900 MW

Work scheduled by: IESO

**SPRNBK\_-TREMONT\_\_345\_X28**

FWD

Fri 11/06/2020 to Sat 11/07/2020

(Import)

0001 Continuous 0059

UPDATEDby CONED 08/31/2020

SPR/DUN-SOUTH

**4200 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Monday ,September14, 2020 to Wednesday, March 16, 2022

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NIAGARA\_\_345KV\_3102

Fri 11/06/2020 to Fri 11/06/2020  
0500 Continuous 2100  
Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	2000 MW	1700 MW
Impacts Total Transfer Capability	50 MW	200 MW
TTC with All Lines In Service	2050 MW	1900 MW

### NIAGARA\_345\_230\_AT4

Fri 11/06/2020 to Fri 11/06/2020  
0500 Continuous 2100  
Work scheduled by: NYPA

		REV
		(Export)
SCH - OH - NY		1750 MW
Impacts Total Transfer Capability		150 MW
TTC with All Lines In Service		1900 MW

### SPRNBK\_-TREMONT\_\_345\_X28

Mon 11/09/2020 to Mon 11/09/2020 UPDATED by CONED 08/31/2020  
0030 Continuous 0059  
Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	4200 MW
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	4600 MW

### ROSETON\_-ROCKTVRN\_345\_311

Mon 11/09/2020 to Fri 11/20/2020  
0800 Continuous 1600  
Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	4400 MW
Impacts Total Transfer Capability	1820 MW
TTC with All Lines In Service	6220 MW

### DUNWODIE-MOTTHAVN\_345\_71

Tue 11/10/2020 to Thu 11/12/2020 UPDATED by CONED 07/22/2020  
0001 Continuous 0100  
Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	3800 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

### DUNWODIE\_345KV\_5

Tue 11/10/2020 to Thu 11/12/2020 UPDATED by CONED 07/22/2020  
0001 Continuous 0100  
Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	3800 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

### SPRNBK\_-TREMONT\_\_345\_X28

Fri 11/13/2020 to Sat 11/14/2020  
0001 Continuous 0300  
Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	4200 MW
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	4600 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,September14, 2020 to Wednesday, March 16, 2022

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 6220MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BUCHAN\_N-EASTVIEW\_345\_W93**

Sat 11/14/2020 to Sat 11/14/2020  
0301 Continuous 0330

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 1870 MW  
TTC with All Lines In Service 6220 MW

**EASTVIEW-SPRNBK\_345\_W79**

Sat 11/14/2020 to Sun 11/15/2020  
0301 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 1870 MW  
TTC with All Lines In Service 6220 MW

**CHATGUAY-MASSENA\_765\_7040**

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

**CHATGUAY-MASSENA\_765\_7040**

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - HQ - NY **0 MW 0 MW**  
Impacts Total Transfer Capability 1500 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

**MARCY\_765\_345\_AT1**

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1750 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

**MARCY\_765\_345\_AT2**

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**MASSENA\_-MARCY\_765\_MSU1**

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2265 MW**  
Impacts Total Transfer Capability 710 MW  
TTC with All Lines In Service 2975 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,September14, 2020 to Wednesday, March 16, 2022

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 6220MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MASSENA\_-MARC\_ 765\_MSU1**

Sun 11/15/2020 to Mon 11/30/2020

0100 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

**500 MW**

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

**MASSENA\_-MARC\_ 765\_MSU1**

Sun 11/15/2020 to Mon 11/30/2020

0100 Continuous 1900

Work scheduled by: NYPA

FWD

(Import) (Export)

SCH - HQ - NY

**475 MW 1000 MW**

Impacts Total Transfer Capability 1025 MW 0 MW

TTC with All Lines In Service 1500 MW 1000 MW

**MASSENA\_-MARC\_ 765\_MSU1**

Sun 11/15/2020 to Mon 11/30/2020

0100 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

SCH - HQ\_CEDARS

**90 MW**

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

**MASSENA\_-MARC\_ 765\_MSU1 & CHATGUAY-MASSENA\_ 765\_7040**

Sun 11/15/2020 to Mon 11/30/2020

0100 1900

Work scheduled by:

FWD

(Import)

MOSES SOUTH

**500 MW**

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

**MOSES\_-MASSENA\_ 230\_MMS1 & MOSES\_-MASSENA\_ 230\_MMS2**

Sun 11/15/2020 to Mon 11/30/2020

0100 1900

Work scheduled by:

FWD

(Import) (Export)

SCH - HQ - NY

**850 MW 0 MW**

Impacts Total Transfer Capability 650 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

**MOSES\_-MASSENA\_ 230\_MMS1 & MOSES\_-MASSENA\_ 230\_MMS2**

Sun 11/15/2020 to Mon 11/30/2020

0100 1900

Work scheduled by:

FWD

(Import)

SCH - HQ\_CEDARS

**90 MW**

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

**STLAWRNC-MOSES\_ 230\_L33P & MASSENA\_-MARC\_ 765\_MSU1**

Sun 11/15/2020 to Mon 11/30/2020

0100 1900

Work scheduled by:

FWD

(Import)

SCH - HQ\_CEDARS

**90 MW**

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,September14, 2020 to Wednesday, March 16, 2022

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 6220MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES\_\_\_\_230\_L33P & MOSES\_\_\_\_-MASSENA\_230\_MMS1 & MOSES\_\_\_\_-  
 MASSENA\_230\_MMS2

Sun 11/15/2020 to Mon 11/30/2020  
 0100 1900

Work scheduled by:

SCH - HQ\_CEDARS

FWD

(Import)

**90 MW**

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

BUCHAN\_N-EASTVIEW\_345\_W93

Sun 11/15/2020 to Sun 11/15/2020  
 0130 Continuous 0300

Work scheduled by: ConEd

UPNY CONED

FWD

(Import)

**4350 MW**

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

PLSNTVLY-WOOD\_ST\_\_345\_F30

Mon 11/16/2020 to Mon 11/16/2020  
 0001 Continuous 0030

Work scheduled by: ConEd

UPNY CONED

FWD

(Import)

**4000 MW**

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

PLSNTVLY\_345KV\_RNS5

Mon 11/16/2020 to Mon 11/16/2020  
 0001 Continuous 0030

Work scheduled by: ConEd

UPNY CONED

FWD

(Import)

**3800 MW**

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

MILLWOOD\_345KV\_18

Mon 11/16/2020 to Tue 11/17/2020  
 0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

FWD

(Import)

**4350 MW**

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

PLSNTVLY-WOOD\_ST\_\_345\_F30

Tue 11/17/2020 to Tue 11/17/2020  
 0130 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

FWD

(Import)

**4000 MW**

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

PLSNTVLY\_345KV\_RNS5

Tue 11/17/2020 to Tue 11/17/2020  
 0130 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

FWD

(Import)

**3800 MW**

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_6**

FWD

Fri 11/20/2020 to Wed 11/25/2020 UPDATED by CE 08/06/2020

(Import)

0001 Continuous 2300

Work scheduled by: ConEd

SCH - PJM\_HTP 300 MW  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_8**

FWD

Fri 11/20/2020 to Wed 11/25/2020 UPDATED by CE 08/06/2020

(Import)

0001 Continuous 2300

Work scheduled by: ConEd

SCH - PJM\_HTP 300 MW  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**MOTTHAVN-RAINEY\_\_\_345\_Q12**

FWD

Mon 11/23/2020 to Sat 11/28/2020 UPDATED by CONED 09/01/2020

(Import)

0201 Continuous 0159

Work scheduled by: ConEd

SPR/DUN-SOUTH 3800 MW  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DOLSONAV-ROCKTVRN\_345\_DART44**

FWD

Mon 11/30/2020 to Mon 12/14/2020 UPDATED by NYPA 08/27/2020

(Import)

0700 Continuous 1730

Work scheduled by: NYPA

CENTRAL EAST - VC 2720 MW  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

FWD

Mon 11/30/2020 to Fri 12/11/2020 by LI 09/14/2020

(Import)

0800 Continuous 1600

Work scheduled by: PJM

SCH - PJM\_NEPTUNE 0 MW  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

**NEWBRDGE-DUFFYAVE\_345\_501**

FWD

Mon 11/30/2020 to Fri 12/11/2020 by LI 09/14/2020

(Import)

0800 Continuous 1600

Work scheduled by: PJM

SCH - PJM\_NEPTUNE 0 MW  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

**MARCY\_\_\_345KV\_CSC**

FWD

Tue 12/01/2020 to Fri 12/11/2020

(Import)

0700 Continuous 1730

Work scheduled by: NYPA

CENTRAL EAST - VC 2925 MW  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,September14, 2020 to Wednesday, March 16, 2022

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 6220MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_Ma1**

FWD

Tue 12/01/2020 to Sat 02/27/2021

UPDATEDby NYPA07/27/2020

(Import)

0700 Continuous 1730

Work scheduled by: NYPA

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

**W49TH\_ST\_345KV\_6**

FWD

Tue 12/01/2020 to Tue 12/01/2020

UPDATEDby CE08/06/2020

(Import)

2230 Continuous 2300

Work scheduled by: ConEd

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_8**

FWD

Tue 12/01/2020 to Tue 12/01/2020

UPDATEDby CE08/06/2020

(Import)

2230 Continuous 2300

Work scheduled by: ConEd

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

**KINTIGH\_-ROCHESTR\_345\_SR1-39**

FWD

Thu 12/03/2020 to Tue 12/15/2020

UPDATEDby NYISO06/24/2020

(Import)

0800 Continuous 1900

Work scheduled by: RGE

DYSINGER EAST

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

**NIAGARA\_-KINTIGH\_345\_NS1-38**

FWD

Thu 12/03/2020 to Tue 12/15/2020

UPDATEDby NYISO06/24/2020

(Import)

0800 Continuous 1900

Work scheduled by: RGE

DYSINGER EAST

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

**BECK\_\_\_-PACKARD\_230\_BP76**

FWD

REV

Fri 12/04/2020 to Fri 12/04/2020

(Import) (Export)

0730 Daily(No Weekends) 1530

Work scheduled by: NGrid

SCH - OH - NY

**1650 MW 1400 MW**

Impacts Total Transfer Capability 400 MW 500 MW

TTC with All Lines In Service 2050 MW 1900 MW

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 12/07/2020 to Fri 12/11/2020

0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**LONG\_MTN-CRICKVLY\_345\_398**

Tue 12/08/2020 to Thu 12/10/2020  
0700 Continuous 1600

Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>700 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	700 MW	400 MW
TTC with All Lines In Service	1400 MW	1700 MW

**LONG\_MTN-CRICKVLY\_345\_398**

Tue 12/08/2020 to Thu 12/10/2020  
0700 Continuous 1600

Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

**SCH-NE-NYISO\_LIMIT\_400**

Tue 12/08/2020 to Thu 12/10/2020  
0700 Continuous 1600

Work scheduled by: ISONE

	FWD (Import)
SCH - NE - NY	<b>600 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	1400 MW

**SCH-NYISO-NE\_LIMIT\_1000**

Tue 12/08/2020 to Thu 12/10/2020  
0700 Continuous 1600

Work scheduled by: ISONE

	REV (Export)
SCH - NE - NY	<b>1200 MW</b>
Impacts Total Transfer Capability	500 MW
TTC with All Lines In Service	1700 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

Fri 12/11/2020 to Mon 12/14/2020  
0001 Continuous 0300

Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	<b>4350 MW</b>
Impacts Total Transfer Capability	1870 MW
TTC with All Lines In Service	6220 MW

**EASTVIEW-SPRNBRK\_345\_W79**

Fri 12/11/2020 to Mon 12/14/2020  
0001 Continuous 0300

Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	<b>4350 MW</b>
Impacts Total Transfer Capability	1870 MW
TTC with All Lines In Service	6220 MW

**SPRNBRK\_-TREMONT\_345\_X28**

Mon 12/14/2020 to Thu 12/17/2020  
0301 Continuous 0300

Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	<b>4200 MW</b>
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	4600 MW



**NYISO TRANSFER LIMITATIONS**

Monday ,September14, 2020 to Wednesday, March 16, 2022

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 6220MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_-EDIC\_\_345\_UE1-7**

FWD

Mon 12/14/2020 to Mon 12/14/2020

(Import)

0700 Continuous 1730

OSWEGO EXPORT

**5250 MW**

Work scheduled by: NYPA

**ARR: 19&16**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 12/14/2020 to Fri 12/18/2020

0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**LADENTWN-BUCHAN\_S\_345\_Y88**

FWD

Tue 12/15/2020 to Sat 01/30/2021

(Import)

0001 Continuous 0300

Work scheduled by: ConEd

UPNY CONED

**5930 MW**

Impacts Total Transfer Capability 290 MW

TTC with All Lines In Service 6220 MW

**FRASANNX-COOPERS\_\_345\_UCC2-41**

FWD

Tue 12/15/2020 to Wed 12/16/2020

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

**MARCY\_\_-FRASANNX\_345\_UCC2-41**

FWD

Tue 12/15/2020 to Wed 12/16/2020

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

**STONYRDG-HILLSIDE\_230\_72**

FWD

Wed 12/16/2020 to Mon 12/21/2020

(Import)

0800 Continuous 0300

Work scheduled by: NYSEG

DYSINGER EAST

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

**SPRNBK\_-TREMONT\_\_345\_X28**

FWD

Sat 12/19/2020 to Sat 12/19/2020

(Import)

2130 Continuous 2200

Work scheduled by: ConEd

SPR/DUN-SOUTH

**4200 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOPATCON-RAMAPO___500_5018				FWD	REV
Mon 02/01/2021	to	Sat 02/06/2021		(Import)	(Export)
0001	Continuous	0200	SCH - PJ - NY	1250 MW	1200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1650 MW 650 MW
				TTC with All Lines In Service	2900 MW 1850 MW
HOPATCON-RAMAPO___500_5018				FWD	
Mon 02/01/2021	to	Sat 02/06/2021		(Import)	
0001	Continuous	0200	UPNY CONED	6025 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	195 MW
				TTC with All Lines In Service	6220 MW
RAMAPO___345_345_PAR3500				FWD	REV
Mon 02/01/2021	to	Sat 02/06/2021		(Import)	(Export)
0001	Continuous	0200	SCH - PJ - NY	2150 MW	1250 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	750 MW 600 MW
				TTC with All Lines In Service	2900 MW 1850 MW
RAMAPO___345_345_PAR4500				FWD	REV
Mon 02/01/2021	to	Sat 02/06/2021		(Import)	(Export)
0001	Continuous	0200	SCH - PJ - NY	2150 MW	1250 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	750 MW 600 MW
				TTC with All Lines In Service	2900 MW 1850 MW
RAMAPO___500_345_BK 1500				FWD	REV
Mon 02/01/2021	to	Sat 02/06/2021		(Import)	(Export)
0001	Continuous	0200	SCH - PJ - NY	1250 MW	1200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1650 MW 650 MW
				TTC with All Lines In Service	2900 MW 1850 MW
RAMAPO___500_345_BK 1500				FWD	
Mon 02/01/2021	to	Sat 02/06/2021		(Import)	
0001	Continuous	0200	UPNY CONED	6025 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	195 MW
				TTC with All Lines In Service	6220 MW
PORTER___-ROTTRDAM_230_31				FWD	
Mon 02/01/2021	to	Sat 02/27/2021		(Import)	
0600	Continuous	1830	CENTRAL EAST - VC	2805 MW	
Work scheduled by: NGrid				Impacts Total Transfer Capability	170 MW
				TTC with All Lines In Service	2975 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PLSNTVLY-WOOD\_ST\_\_345\_F30

Mon 02/15/2021 to Tue 02/16/2021

0001 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

4000 MW

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

## PLSNTVLY\_345KV\_RNS5

Mon 02/15/2021 to Tue 02/16/2021

0001 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

3800 MW

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

## EFISHKIL-WOOD\_ST\_\_345\_F39

Thu 02/18/2021 to Sat 02/20/2021

2100 Continuous 0200

Work scheduled by: ConEd

UPDATEDby CE04/01/2020

FWD

(Import)

UPNY CONED

4000 MW

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

## WOOD\_ST\_-PLSNTVLE\_345\_Y87

Thu 02/18/2021 to Sat 02/20/2021

2100 Continuous 0200

Work scheduled by: ConEd

UPDATEDby CE04/01/2020

FWD

(Import)

UPNY CONED

5905 MW

Impacts Total Transfer Capability 315 MW

TTC with All Lines In Service 6220 MW

## CHATGUAY-MASSENA\_\_765\_7040

Sun 02/28/2021 to Mon 03/01/2021

0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

1550 MW

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

## CHATGUAY-MASSENA\_\_765\_7040

Sun 02/28/2021 to Mon 03/01/2021

0500 Continuous 1730

Work scheduled by: NYPA

FWD

REV

(Import) (Export)

SCH - HQ - NY

0 MW

0 MW

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

## MASSENA\_-MARCY\_\_765\_MSU1

Sun 02/28/2021 to Mon 03/01/2021

0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC

2265 MW

Impacts Total Transfer Capability 710 MW

TTC with All Lines In Service 2975 MW

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 6220MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MASSENA\_-MARC\_765\_MSU1**

Sun 02/28/2021 to Mon 03/01/2021

0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

**500 MW**

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

**MASSENA\_-MARC\_765\_MSU1**

Sun 02/28/2021 to Mon 03/01/2021

0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import) (Export)

SCH - HQ - NY

**475 MW 1000 MW**

Impacts Total Transfer Capability 1025 MW 0 MW

TTC with All Lines In Service 1500 MW 1000 MW

**MASSENA\_-MARC\_765\_MSU1**

Sun 02/28/2021 to Mon 03/01/2021

0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

SCH - HQ\_CEDARS

**90 MW**

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

**MASSENA\_-MARC\_765\_MSU1 & CHATGUAY-MASSENA\_765\_7040**

Sun 02/28/2021 to Mon 03/01/2021

0500 1730

Work scheduled by:

FWD

(Import)

MOSES SOUTH

**500 MW**

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

**STLAWRNC-MOSES\_230\_L33P & MASSENA\_-MARC\_765\_MSU1**

Sun 02/28/2021 to Mon 03/01/2021

0500 1730

Work scheduled by:

FWD

(Import)

SCH - HQ\_CEDARS

**90 MW**

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

**DUNWODIE\_345KV\_3**

Mon 03/01/2021 to Mon 03/01/2021

0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_5**

Mon 03/01/2021 to Mon 03/01/2021

0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EASTVIEW-SPRNBK\_\_345\_W64**

FWD

Mon 03/01/2021 to Mon 03/01/2021 UPDATED by CONED 01/23/2020

(Import)

0001 Continuous 0030

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

**SPRNBK\_\_345KV\_RNS5**

FWD

Mon 03/01/2021 to Mon 03/01/2021 UPDATED by CONED 01/23/2020

(Import)

0001 Continuous 0030

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**MILLWOOD-EASTVIEW\_345\_W99**

FWD

Mon 03/01/2021 to Mon 03/22/2021 UPDATED by CONED 01/23/2020

(Import)

0001 Continuous 0200

UPNY CONED

**5985 MW**

Impacts Total Transfer Capability 235 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

**DUNWODIE-MOTTHAVN\_345\_71**

FWD

Mon 03/01/2021 to Mon 04/05/2021

(Import)

0001 Continuous 0300

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**MOTTHAVN-RAINEY\_\_345\_Q11**

FWD

Mon 03/01/2021 to Tue 04/06/2021

(Import)

0001 Continuous 0700

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**EDIC\_\_-N.SCTLND\_345\_14**

FWD

Tue 03/02/2021 to Mon 05/31/2021

(Import)

0600 Continuous 1830

CENTRAL EAST - VC

**2240 MW**

Impacts Total Transfer Capability 735 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**PORTER\_\_-ROTTRDAM\_230\_31**

FWD

Tue 03/02/2021 to Mon 05/31/2021

(Import)

0600 Continuous 1830

CENTRAL EAST - VC

**2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Tue 03/02/2021 to Mon 05/31/2021

(Import)

0700 Continuous 1300

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**NIAGARA\_-ROBNSNRD\_230\_64**

REV

Fri 03/12/2021 to Fri 03/12/2021

(Export)

0500 Continuous 1700

SCH - OH - NY

**1900 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 1900 MW

Work scheduled by: NYPA

**MARCY\_\_\_345KV\_CSC**

FWD

Sat 03/13/2021 to Sat 03/13/2021

(Import)

0700 Continuous 1730

**UPDATED****by NYPA****07/29/2020**

CENTRAL EAST - VC

**2925 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**EASTVIEW-SPRNBK\_\_345\_W64**

FWD

Mon 03/22/2021 to Mon 03/22/2021

(Import)

0130 Continuous 0200

**UPDATED****by CONED****01/23/2020**

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

**SPRNBK\_\_345KV\_RNS5**

FWD

Mon 03/22/2021 to Mon 03/22/2021

(Import)

0130 Continuous 0200

**UPDATED****by CONED****01/23/2020**

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**CLAY\_\_\_-EDIC\_\_\_345\_2-15**

FWD

Mon 03/29/2021 to Fri 04/16/2021

(Import)

0800 Continuous 1730

**09/12/2020**

OSWEGO EXPORT

**4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**W49TH\_ST\_345KV\_5**

FWD

Wed 03/31/2021 to Wed 05/05/2021

(Import)

0400 Continuous 0300

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 6220MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**ROCHESTR-PANNELL\_\_345\_RP2**

FWD

Wed 03/31/2021 to Mon 04/12/2021

(Import)

0500 Continuous 1700

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**DUNWODIE\_345KV\_3**

FWD

Mon 04/05/2021 to Mon 04/05/2021

(Import)

0230 Continuous 0300

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**DUNWODIE\_345KV\_5**

FWD

Mon 04/05/2021 to Mon 04/05/2021

(Import)

0230 Continuous 0300

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**SPRNBK\_-TREMONT\_\_345\_X28**

FWD

Mon 04/19/2021 to Tue 04/20/2021

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**4200 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**PLSNTVLY-WOOD\_ST\_\_345\_F31**

FWD

Tue 04/27/2021 to Wed 04/28/2021

(Import)

0001 Continuous 0159

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

**PLSNTVLY\_345KV\_RNS4**

FWD

Tue 04/27/2021 to Wed 04/28/2021

(Import)

0001 Continuous 0159

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

**SPRNBK\_\_345KV\_RNS4**

FWD

Sat 05/01/2021 to Sat 05/01/2021

(Import)

0001 Continuous 0030

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SPRNBK\_-W49TH\_ST\_345\_M52

Sat 05/01/2021 to Tue 05/04/2021  
0001 Continuous 0300  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH 3200 MW  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

## W49TH\_ST\_345KV\_7

Sat 05/01/2021 to Tue 05/04/2021  
0001 Continuous 0300  
Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP 300 MW  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

## SCH-IMO-NYISO\_LIMIT\_1600

Sat 05/01/2021 to Sun 10/31/2021 UPDATED by IESO 05/03/2019  
0001 Continuous 2359  
Work scheduled by: IESO

FWD  
(Import)  
SCH - OH - NY 1900 MW  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 1950 MW

## CLAY\_-EDIC\_345\_2-15

Mon 05/03/2021 to Fri 05/07/2021  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT 4850 MW  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

## PANNELL\_-CLAY\_345\_2

Mon 05/03/2021 to Sun 05/30/2021  
0700 Continuous 1730  
Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL 1300 MW  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

## SPRNBK\_345KV\_RNS4

Tue 05/04/2021 to Tue 05/04/2021  
0230 Continuous 0300  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH 3200 MW  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

## NIAGARA\_345KV\_3102

Thu 05/06/2021 to Fri 05/07/2021  
0500 Continuous 1700  
Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1700 MW	1400 MW
Impacts Total Transfer Capability	250 MW	300 MW
TTC with All Lines In Service	1950 MW	1700 MW



CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_\_345KV\_3302

Mon 05/10/2021 to Wed 05/12/2021  
0500 Continuous 1700

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1000 MW	1600 MW
Impacts Total Transfer Capability	950 MW	100 MW
TTC with All Lines In Service	1950 MW	1700 MW

## CLAY\_\_-EDIC\_\_345\_1-16

Mon 05/10/2021 to Fri 05/14/2021  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
OSWEGO EXPORT	4850 MW
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	5250 MW

## NIAGARA\_\_345KV\_3108

Thu 05/13/2021 to Fri 05/14/2021  
0500 Continuous 1700

Work scheduled by: NYPA

	REV
	(Export)
SCH - OH - NY	1500 MW
Impacts Total Transfer Capability	200 MW
TTC with All Lines In Service	1700 MW

## VOLNEY\_\_-MARCY\_\_345\_19

Tue 06/01/2021 to Wed 06/02/2021  
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
CENTRAL EAST - VC	2825 MW
Impacts Total Transfer Capability	150 MW
TTC with All Lines In Service	2975 MW

## VOLNEY\_\_-MARCY\_\_345\_19

Tue 06/01/2021 to Wed 06/02/2021  
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
OSWEGO EXPORT	4900 MW
Impacts Total Transfer Capability	350 MW
TTC with All Lines In Service	5250 MW

## FRASER\_\_-GILBOA\_\_345\_GF5-35

Tue 06/01/2021 to Mon 06/07/2021  
0700 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	2650 MW
Impacts Total Transfer Capability	325 MW
TTC with All Lines In Service	2975 MW

## MOSES\_\_-ADIRNDCK\_230\_MA2

Tue 06/01/2021 to Sun 11/14/2021  
0700 Continuous 1300

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2100 MW
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY\_\_\_-EDIC\_\_\_345\_UE1-7

FWD

Thu 06/03/2021 to Fri 06/04/2021

(Import)

0700 Continuous 1730

OSWEGO EXPORT

5250 MW

Impacts Total Transfer Capability 0 MW

Work scheduled by: NYPA

ARR: 19&16

TTC with All Lines In Service 5250 MW

MARCY\_\_\_345KV\_CSC

FWD

Sat 06/05/2021 to Sat 06/05/2021

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

2925 MW

Impacts Total Transfer Capability 50 MW

Work scheduled by: NYPA

TTC with All Lines In Service 2975 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA2 & MARCY\_\_\_345KV\_3102 & MARCY\_\_\_345KV\_3202 &  
MARCY\_\_\_345KV\_3302

FWD

(Import)

Sat 06/05/2021 to Sat 06/05/2021

MOSES SOUTH

1800 MW

0700 1730

Impacts Total Transfer Capability 1350 MW

TTC with All Lines In Service 3150 MW

Work scheduled by:

SAND\_BAR-PLATSBURG\_115\_PV20

Tue 08/03/2021 to Tue 08/03/2021

SCH - NE - NY

0700 Continuous 1830

Impacts Total Transfer Capability

Work scheduled by: NYPA

TTC with All Lines In Service

NIAGARA\_\_\_-KINTIGH\_\_\_345\_NS1-38

FWD

(Import)

Mon 09/13/2021 to Fri 09/17/2021

DYSINGER EAST

1400 MW

0500 Continuous 1700

Impacts Total Transfer Capability 1750 MW

Work scheduled by: NYPA

TTC with All Lines In Service 3150 MW

PORTER\_\_\_-ROTTDAM\_230\_30

FWD

(Import)

Wed 09/15/2021 to Tue 11/30/2021

CENTRAL EAST - VC

2805 MW

0600 Continuous 1830

Impacts Total Transfer Capability 170 MW

Work scheduled by: NGrid

TTC with All Lines In Service 2975 MW

EDIC\_\_\_-N.SCTLND\_345\_14

FWD

(Import)

Thu 09/16/2021 to Sun 11/14/2021

CENTRAL EAST - VC

2240 MW

0600 Continuous 1830

Impacts Total Transfer Capability 735 MW

Work scheduled by: NGrid

TTC with All Lines In Service 2975 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PANNELL\_-CLAY\_\_\_\_\_345\_1**

Mon 09/20/2021 to Fri 09/24/2021  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**PANNELL\_-CLAY\_\_\_\_\_345\_2**

Mon 09/27/2021 to Fri 10/01/2021  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**W49TH\_ST\_345KV\_6**

Tue 09/28/2021 to Tue 09/28/2021  
0100 Continuous 0130

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**E13THSTA-FARRAGUT\_345\_46**

Tue 09/28/2021 to Tue 10/26/2021  
0100 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**W49TH\_ST-E13THSTA\_345\_M55**

Tue 09/28/2021 to Tue 10/26/2021  
0100 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**W49TH\_ST\_345KV\_6**

Tue 10/26/2021 to Tue 10/26/2021  
0230 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**SCH-IMO-NYISO\_LIMIT\_1750**

Mon 11/01/2021 to Fri 12/31/2021  
0001 Continuous 2359

Work scheduled by: IESO

UPDATED by IESO 05/03/2019

FWD  
(Import)  
SCH - OH - NY **2050 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 2050 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,September14, 2020 to Wednesday, March 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-NYISO-IMO\_LIMIT\_1600**

REV

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019

(Export)

0001 Continuous 2359

SCH - OH - NY

**1900 MW**

Impacts Total Transfer Capability

0 MW

Work scheduled by: IESO

TTC with All Lines In Service

1900 MW

**MOSES-ADIRNDCK\_230\_MAI**

FWD

Wed 12/01/2021 to Tue 05/31/2022

(Import)

0700 Continuous 1300

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

Work scheduled by: NYPA

TTC with All Lines In Service

3150 MW