

# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE\_345KV\_9\_BYPASS & DUNWODIE\_345KV\_10\_BYPASS & SPRNBRK\_\_345KV\_R5S3\_BYPASS  
& SPRNBRK\_\_345KV\_R4S3\_BYPASS

FWD  
(Import)

Sun 02/01/2015 to Sat 02/01/2025  
0000 0000

SPR/DUN-SOUTH **4350 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 4600 MW

Work scheduled by:

DUNWODIE\_345KV\_9\_BYPASS & DUNWODIE\_345KV\_10\_BYPASS & SPRNBRK\_\_345KV\_R5S3\_BYPASS  
& SPRNBRK\_\_345KV\_R4S3\_BYPASS

Sun 02/01/2015 to Sat 02/01/2025  
0000 0000

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

Work scheduled by:

HUDSONP\_-FARRAGUT\_345\_B3402

FWD REV  
(Import) (Export)

Mon 01/15/2018 to Sun 02/28/2021 EXT FORCE by CONED 08/28/2020  
0001 Continuous 2359

SCH - PJ - NY **2050 MW 1150 MW**  
Impacts Total Transfer Capability 150 MW 100 MW  
TTC with All Lines In Service 2200 MW 1250 MW

Work scheduled by: ConEd

HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

FWD REV  
(Import) (Export)

Mon 01/15/2018 to Sun 02/28/2021  
0001 2359

SCH - PJ - NY **2000 MW 1000 MW**  
Impacts Total Transfer Capability 200 MW 250 MW  
TTC with All Lines In Service 2200 MW 1250 MW

Work scheduled by:

MARION\_-FARRAGUT\_345\_C3403

FWD REV  
(Import) (Export)

Mon 01/15/2018 to Sun 02/28/2021 EXT FORCE by CONED 08/28/2020  
0001 Continuous 2359

SCH - PJ - NY **2050 MW 1150 MW**  
Impacts Total Transfer Capability 150 MW 100 MW  
TTC with All Lines In Service 2200 MW 1250 MW

Work scheduled by: ConEd

STLAWRNC-MOSES\_\_\_\_230\_L33P

Mon 04/30/2018 to Mon 10/31/2022 EXT FORCE by IESO 10/01/2020  
0456 Continuous 1600

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

Work scheduled by: IESO

# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-IMO-NYISO\_LIMIT\_1600

Fri 05/01/2020 to Sat 10/31/2020 UPDATED by IESO 05/03/2019

0001 Continuous 2359

Work scheduled by: IESO

FWD  
(Import)  
**1900 MW**  
SCH - OH - NY  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 1950 MW

## SHOR\_NPX-SHOREHAM\_138\_CSC

Wed 07/08/2020 to Sat 10/24/2020 EXT FORCE by LIPA 10/22/2020

1247 Continuous 2359

Work scheduled by: LI

FWD REV  
(Import) (Export)  
**0 MW 0 MW**  
SCH - NPX\_CSC  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

## BECK\_\_\_\_-NIAGARA\_230\_PA27

Mon 08/31/2020 to Mon 11/30/2020

0700 Continuous 0700

Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## SCH-IMO-NYISO\_LIMIT\_1450

Mon 08/31/2020 to Mon 11/30/2020

0700 Continuous 0700

Work scheduled by: IESO

FWD  
(Import)  
**1750 MW**  
SCH - OH - NY  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1950 MW

## NEWBRDGE\_345\_138\_BK\_1

Wed 09/02/2020 to Thu 12/31/2020 EXT FORCE by LI 09/03/2020

1807 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
**375 MW**  
SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Wed 09/09/2020 to Sat 11/14/2020 UPDATED by NYPA 09/04/2020

0700 Continuous 1300

Work scheduled by: NYPA

FWD  
(Import)  
**2100 MW**  
MOSES SOUTH  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## SCH-IMO-NYISO\_LIMIT\_1350

Fri 09/18/2020 to Sat 10/31/2020 UPDATED by NYPA 10/20/2020

0500 Continuous 2359

Work scheduled by: NYPA

FWD  
(Import)  
**1650 MW**  
SCH - OH - NY  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 1950 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_-ROCHESTR\_345\_NR2

Fri 09/18/2020 to Fri 12/31/2021  
0500 Continuous 2359

UPDATED by NYPA 10/20/2020

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC1

Sat 09/26/2020 to Tue 10/20/2020  
2000 Continuous 2300

UPDATED by HQ 09/30/2020

Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC1

Sat 09/26/2020 to Tue 10/20/2020  
2000 Continuous 2300

UPDATED by HQ 09/30/2020

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

## SCH-NYISO-HQ\_LIMIT\_500

Sun 09/27/2020 to Tue 10/20/2020  
0500 Continuous 2300

UPDATED by HQ 09/30/2020

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

## SPRNBK\_-EGRDNCTR\_345\_Y49

Thu 10/01/2020 to Mon 11/30/2020  
0404 Continuous 2359

UPDATED by LI 10/11/2020

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **775 MW**  
Impacts Total Transfer Capability 725 MW  
TTC with All Lines In Service 1500 MW

## EGRDNCTY\_345\_138\_AT2

Sat 10/10/2020 to Mon 11/30/2020  
1815 Continuous 2359

UPDATED by LI 10/11/2020

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

## EGRDNCTY\_345\_138\_AT1

Sat 10/10/2020 to Mon 11/30/2020  
1856 Continuous 2359

UPDATED by LI 10/11/2020

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HOMR\_NYW-PIERC\_NY\_345\_48

Mon 10/12/2020 to Fri 10/30/2020 UPDATED by PJM 10/09/2020

0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## MILLWOOD\_345KV\_18

Mon 10/19/2020 to Mon 10/19/2020 UPDATED by CONED 10/18/2020

0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 1870 MW  
TTC with All Lines In Service 6220 MW

## DUNWODIE-MOTTHAVN\_345\_71

Mon 10/19/2020 to Tue 10/20/2020 UPDATED by CONED 10/15/2020

0001 Continuous 0159

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## DUNWODIE\_345KV\_5

Mon 10/19/2020 to Tue 10/20/2020 UPDATED by CONED 10/15/2020

0001 Continuous 0159

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## DUNWODIE\_345KV\_3

Mon 10/19/2020 to Tue 11/24/2020 UPDATED by CONED 10/15/2020

0001 Continuous 0159

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## DUNWODIE\_345KV\_4

Mon 10/19/2020 to Tue 11/24/2020 UPDATED by CONED 10/15/2020

0001 Continuous 0159

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## PLSNTVLE-DUNWODIE\_345\_W89

Mon 10/19/2020 to Tue 11/24/2020 UPDATED by CONED 10/15/2020

0001 Continuous 0159

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 2220 MW  
TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SAND\_BAR-PLATSBURG\_115\_PV20

Mon 10/19/2020 to Fri 11/13/2020 UPDATED by ISONE 10/08/2020

0600 Continuous 1800

Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## BERKSHIR-ALPS\_\_\_\_\_345\_393

Mon 10/19/2020 to Tue 11/10/2020 UPDATED by ISONE 10/16/2020

0630 Continuous 1600

Work scheduled by: NGrid

ARR: 78

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	<b>950 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	450 MW	300 MW
TTC with All Lines In Service	1400 MW	1600 MW

## BERKSHIR-ALPS\_\_\_\_\_345\_393

Mon 10/19/2020 to Tue 11/10/2020 UPDATED by ISONE 10/16/2020

0630 Continuous 1600

Work scheduled by: NGrid

ARR: 78

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

## BERKSHIR-ALPS\_\_\_\_\_345\_393 & BERKSHIR-NORTHFLD\_345\_312

Mon 10/19/2020 to Tue 11/10/2020

0630 1600

Work scheduled by:

ARR: 78

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	<b>950 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	450 MW	300 MW
TTC with All Lines In Service	1400 MW	1600 MW

## BERKSHIR-NORTHFLD\_345\_312

Mon 10/19/2020 to Tue 11/10/2020 UPDATED by ISONE 10/16/2020

0630 Continuous 1600

Work scheduled by: NGrid

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	<b>900 MW</b>	<b>1500 MW</b>
Impacts Total Transfer Capability	500 MW	100 MW
TTC with All Lines In Service	1400 MW	1600 MW

## BERKSHIR-NORTHFLD\_345\_312

Mon 10/19/2020 to Tue 11/10/2020 UPDATED by ISONE 10/16/2020

0630 Continuous 1600

Work scheduled by: NGrid

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

## SCH-NE-NYISO\_LIMIT\_700

Mon 10/19/2020 to Tue 11/10/2020 UPDATED by ISONE 10/16/2020

0630 Continuous 1600

Work scheduled by: NGrid

	FWD
	(Import)
SCH - NE - NY	<b>900 MW</b>
Impacts Total Transfer Capability	500 MW
TTC with All Lines In Service	1400 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-NYISO-NE\_LIMIT\_800**

REV

Mon 10/19/2020 to Tue 11/10/2020 **UPDATED** **by ISONE** **10/16/2020**

(Export)

0630 Continuous 1600

Work scheduled by: NGrid

SCH - NE - NY

**1000 MW**

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

1600 MW

**PANNELL -CLAY\_345\_2**

FWD

Mon 10/19/2020 to Fri 10/23/2020 **UPDATED** **by NYPA** **05/07/2020**

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability

950 MW

TTC with All Lines In Service

2250 MW

**COOPERS -DOLSONAV\_345\_CCDA42**

FWD

Mon 10/19/2020 to Fri 11/06/2020

(Import)

0700 Continuous 1730

Work scheduled by: NYPA

CENTRAL EAST - VC

**2720 MW**

Impacts Total Transfer Capability

255 MW

TTC with All Lines In Service

2975 MW

**W49TH\_ST\_345KV\_6**

FWD

Tue 10/20/2020 to Tue 10/20/2020 **EXTENDED** **by CONED** **10/15/2020**

(Import)

0331 Continuous 0400

Work scheduled by: ConEd

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

**E13THSTA-FARRAGUT\_345\_46**

FWD

Tue 10/20/2020 to Fri 10/23/2020 **EXTENDED** **by CONED** **10/15/2020**

(Import)

0331 Continuous 2300

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

**W49TH\_ST-E13THSTA\_345\_M55**

FWD

Tue 10/20/2020 to Fri 10/23/2020 **EXTENDED** **by CONED** **10/15/2020**

(Import)

0331 Continuous 2300

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

**CHAT\_DC\_GC2**

FWD

Wed 10/21/2020 to Sat 11/14/2020

(Import)

0500 Continuous 2300

Work scheduled by: HQ

MOSES SOUTH

**2850 MW**

Impacts Total Transfer Capability

300 MW

TTC with All Lines In Service

3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CHAT\_DC\_GC2**

REV

Wed 10/21/2020 to Sat 11/14/2020

(Export)

0500 Continuous 2300

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1000 MW

Work scheduled by: HQ

**SCH-NYISO-HQ\_LIMIT\_500**

REV

Wed 10/21/2020 to Sat 11/14/2020

(Export)

0500 Continuous 2300

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1000 MW

Work scheduled by: HQ

**MILLWOOD\_345KV\_18**

FWD

Fri 10/23/2020 to Fri 10/23/2020

(Import)

2130 Continuous 2200

**UPDATED by CONED 10/18/2020**

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

**PIERCBRK-FIVEMILE\_345\_37**

Mon 10/26/2020 to Fri 10/30/2020

0700 Continuous 1530

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NGrid

**LEEDS\_\_\_\_345\_LEEDS SVC**

FWD

Mon 10/26/2020 to Fri 10/30/2020

(Import)

0800 Continuous 1600

CENTRAL EAST - VC

**2950 MW**

Impacts Total Transfer Capability 25 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**LEEDS\_\_\_\_345KV\_R94301**

FWD

Mon 10/26/2020 to Wed 11/25/2020

(Import)

0800 Continuous 1600

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: NGrid

**LEEDS\_\_\_\_-HURLYAVE\_345\_301**

FWD

Mon 10/26/2020 to Fri 12/04/2020

(Import)

0800 Continuous 1600

**UPDATED by CHGE 10/21/2020**

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 2120 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: CHGE

# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SPRNBK\_-TREMONT\_\_345\_X28

FWD

Mon 10/26/2020 to Mon 10/26/2020 UPDATED by CONED 10/24/2020

(Import)

1201 Continuous 1230

Work scheduled by: ConEd

SPR/DUN-SOUTH

4200 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

## HUDSONTP-W49TH\_ST\_345\_Y56

FWD

Tue 10/27/2020 to Wed 10/28/2020 CANCELLED by ConEd 10/23/2020

(Import)

0001 Continuous 2200

Work scheduled by: ConEd

SCH - PJM\_HTP

0 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

## W49TH\_ST\_345KV\_7

FWD

Tue 10/27/2020 to Wed 10/28/2020 CANCELLED by ConEd 10/23/2020

(Import)

0001 Continuous 2200

Work scheduled by: ConEd

SCH - PJM\_HTP

300 MW

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

## W49TH\_ST\_345KV\_8

FWD

Tue 10/27/2020 to Wed 10/28/2020 CANCELLED by ConEd 10/23/2020

(Import)

0001 Continuous 2200

Work scheduled by: ConEd

SCH - PJM\_HTP

450 MW

Impacts Total Transfer Capability 210 MW

TTC with All Lines In Service 660 MW

## SCRIBA\_-VOLNEY\_\_345\_21

FWD

Wed 10/28/2020 to Wed 10/28/2020

(Import)

0800 Daily(No Weekends) 1630

Work scheduled by: NGrid

OSWEGO EXPORT

5250 MW

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

## W49TH\_ST\_345KV\_5

FWD

Fri 10/30/2020 to Sat 10/31/2020 UPDATED by CONED 10/11/2020

(Import)

0301 Continuous 0300

Work scheduled by: ConEd

SCH - PJM\_HTP

300 MW

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

## W49TH\_ST\_345KV\_7

FWD

Fri 10/30/2020 to Sat 10/31/2020 UPDATED by CONED 10/11/2020

(Import)

0301 Continuous 0300

Work scheduled by: ConEd

SCH - PJM\_HTP

300 MW

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW



# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SPRNBK\_\_345KV\_RS3 & SPRNBK\_\_345KV\_RS4

Sat 10/31/2020 to Sat 10/31/2020  
0001 0030

Work scheduled by:

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

## BRANCHBG-HOPATCON\_500\_5060

Sat 10/31/2020 to Sat 10/31/2020  
0200 Continuous 1500

Work scheduled by: PJM

UPDATED by PJM 10/24/2020

FWD  
(Import)  
UPNY CONED **6025 MW**  
Impacts Total Transfer Capability 195 MW  
TTC with All Lines In Service 6220 MW

## SCH-IMO-NYISO\_LIMIT\_1750

Sun 11/01/2020 to Fri 04/30/2021  
0001 Continuous 2359

Work scheduled by: IESO

UPDATED by IESO 05/03/2019

FWD  
(Import)  
SCH - OH - NY **2050 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 2300 MW

## SCH-NYISO-IMO\_LIMIT\_1600

Sun 11/01/2020 to Fri 04/30/2021  
0001 Continuous 2359

Work scheduled by: IESO

UPDATED by IESO 05/03/2019

REV  
(Export)  
SCH - OH - NY **1900 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 2000 MW

## SPRNBK\_\_345KV\_RS3 & SPRNBK\_\_345KV\_RS4

Sun 11/01/2020 to Sun 11/01/2020  
0130 0200

Work scheduled by:

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## PIERCBK-FIVEMILE\_345\_37

Mon 11/02/2020 to Fri 11/06/2020  
0700 Continuous 1400

Work scheduled by: NYSEG

UPDATED by NGRID 10/19/2020

FWD  
(Import)  
SCH - PJ - NY **2400 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 2800 MW

## S.RIPLEY-DUNKIRK\_\_230\_68

Mon 11/02/2020 to Fri 11/20/2020  
0700 Continuous 1800

Work scheduled by: NGrid

by PJM 10/20/2020

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-TREMONT_345_X28					FWD
Fri 11/06/2020	to	Sat 11/07/2020	<u>UPDATED</u>	<u>by CONED</u> <u>10/24/2020</u>	(Import)
0001	Continuous	0059			SPR/DUN-SOUTH <b>4200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 400 MW
					TTC with All Lines In Service 4600 MW
NIAGARA_345_230_AT4					REV
Fri 11/06/2020	to	Fri 11/06/2020			(Export)
0500	Continuous	2100			SCH - OH - NY <b>1750 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 250 MW
					TTC with All Lines In Service 2000 MW
SPRNBK_-TREMONT_345_X28					FWD
Mon 11/09/2020	to	Mon 11/09/2020	<u>UPDATED</u>	<u>by CONED</u> <u>10/24/2020</u>	(Import)
0030	Continuous	0059			SPR/DUN-SOUTH <b>4200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 400 MW
					TTC with All Lines In Service 4600 MW
ROSETON_-ROCKTVRN_345_311					FWD
Mon 11/09/2020	to	Fri 11/20/2020			(Import)
0800	Continuous	1600			UPNY CONED <b>4400 MW</b>
Work scheduled by: CHGE					Impacts Total Transfer Capability 1820 MW
					TTC with All Lines In Service 6220 MW
DUNWODIE-MOTTHAVN_345_71					FWD
Thu 11/12/2020	to	Thu 11/12/2020	<u>UPDATED</u>	<u>by CONED</u> <u>10/15/2020</u>	(Import)
0001	Continuous	0030			SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_5					FWD
Thu 11/12/2020	to	Fri 11/13/2020	<u>UPDATED</u>	<u>by CONED</u> <u>10/15/2020</u>	(Import)
0001	Continuous	0100			SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
DUNWODIE-MOTTHAVN_345_71					FWD
Fri 11/13/2020	to	Fri 11/13/2020	<u>UPDATED</u>	<u>by CONED</u> <u>10/15/2020</u>	(Import)
0030	Continuous	0100			SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CHATGUAY-MASSENA\_\_765\_7040

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 1550 MW  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

## CHATGUAY-MASSENA\_\_765\_7040

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900  
Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - HQ - NY 0 MW 0 MW  
Impacts Total Transfer Capability 1500 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

## MARCY\_\_765\_345\_AT1

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900  
Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH 1750 MW  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

## MARCY\_\_765\_345\_AT2

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900  
Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH 1700 MW  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## MASSENA\_-MARCY\_\_765\_MSU1

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC 2265 MW  
Impacts Total Transfer Capability 710 MW  
TTC with All Lines In Service 2975 MW

## MASSENA\_-MARCY\_\_765\_MSU1

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 500 MW  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

## MASSENA\_-MARCY\_\_765\_MSU1

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900  
Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - HQ - NY 475 MW 1000 MW  
Impacts Total Transfer Capability 1025 MW 0 MW  
TTC with All Lines In Service 1500 MW 1000 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY___765_MSU1				FWD	
Sun 11/15/2020	to	Mon 11/30/2020		(Import)	
0100	Continuous	1900	SCH - HQ_CEDARS	90 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA___765_7040				FWD	
Sun 11/15/2020	to	Mon 11/30/2020		(Import)	
0100		1900	MOSES SOUTH	500 MW	
Work scheduled by:				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW
MOSES___-MASSENA___230_MMS1 & MOSES___-MASSENA___230_MMS2				FWD	REV
Sun 11/15/2020	to	Mon 11/30/2020		(Import)	(Export)
0100		1900	SCH - HQ - NY	850 MW	0 MW
Work scheduled by:				Impacts Total Transfer Capability	650 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
MOSES___-MASSENA___230_MMS1 & MOSES___-MASSENA___230_MMS2				FWD	
Sun 11/15/2020	to	Mon 11/30/2020		(Import)	
0100		1900	SCH - HQ_CEDARS	90 MW	
Work scheduled by:				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
STLAWRNC-MOSES___230_L33P & MASSENA_-MARCY___765_MSU1				FWD	
Sun 11/15/2020	to	Mon 11/30/2020		(Import)	
0100		1900	SCH - HQ_CEDARS	90 MW	
Work scheduled by:				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
STLAWRNC-MOSES___230_L33P & MOSES___-MASSENA___230_MMS1 & MOSES___-MASSENA___230_MMS2				FWD	
Sun 11/15/2020	to	Mon 11/30/2020		(Import)	
0100		1900	SCH - HQ_CEDARS	90 MW	
Work scheduled by:				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
W49TH_ST_345KV_5				FWD	
Tue 11/17/2020	to	Tue 11/17/2020		(Import)	
0001	Continuous	0030	SCH - PJM_HTP	300 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	360 MW
				TTC with All Lines In Service	660 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_7**

Tue 11/17/2020 to Tue 11/17/2020  
0001 Continuous 0030  
Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP 300 MW  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_5**

Thu 11/19/2020 to Thu 11/19/2020  
1830 Continuous 1900  
Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP 300 MW  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_7**

Thu 11/19/2020 to Thu 11/19/2020  
1830 Continuous 1900  
Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP 300 MW  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_6**

Fri 11/20/2020 to Wed 11/25/2020 **UPDATED** **by CE** **08/06/2020**  
0001 Continuous 2300  
Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP 300 MW  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_8**

Fri 11/20/2020 to Wed 11/25/2020 **UPDATED** **by CE** **08/06/2020**  
0001 Continuous 2300  
Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP 300 MW  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**SPRNBK\_-TREMONT\_345\_X28**

Tue 11/24/2020 to Wed 11/25/2020  
0101 Continuous 0300  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH 4200 MW  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

**SPRNBK\_-TREMONT\_345\_X28**

Tue 11/24/2020 to Wed 11/25/2020 **CANCELLED** **by ConEd** **10/21/2020**  
0101 Continuous 0300  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH 4200 MW  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BUCHAN\_N-EASTVIEW\_345\_W93**

FWD

Wed 11/25/2020 to Wed 11/25/2020

by CONED 10/16/2020

(Import)

0301 Continuous 0330

Work scheduled by: ConEd

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

**EASTVIEW-SPRNBK\_345\_W79**

FWD

Wed 11/25/2020 to Thu 11/26/2020

by CONED 10/16/2020

(Import)

0301 Continuous 0300

Work scheduled by: ConEd

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

**MOTHAVN-RAINEY\_345\_Q12**

FWD

Wed 11/25/2020 to Thu 12/03/2020

UPDATEDby CONED 10/16/2020

(Import)

0301 Continuous 0159

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

FWD

Thu 11/26/2020 to Thu 11/26/2020

by CONED 10/16/2020

(Import)

0130 Continuous 0300

Work scheduled by: ConEd

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

**DOLSONAV-ROCKTVRN\_345\_DART44**

FWD

Mon 11/30/2020 to Mon 12/14/2020

UPDATEDby NYPA 08/27/2020

(Import)

0700 Continuous 1730

Work scheduled by: NYPA

CENTRAL EAST - VC

**2720 MW**

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

FWD

Mon 11/30/2020 to Fri 12/11/2020

by LI09/14/2020

(Import)

0800 Continuous 1600

Work scheduled by: PJM

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

**NEWBRDGE-DUFFYAVE\_345\_501**

FWD

Mon 11/30/2020 to Fri 12/11/2020

by LI09/14/2020

(Import)

0800 Continuous 1600

Work scheduled by: PJM

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_\_345KV\_CSC**

FWD

Tue 12/01/2020 to Fri 12/11/2020  
0700 Continuous 1730

(Import)

Work scheduled by: NYPA

CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

**MOSES\_\_\_\_-ADIRNDCK\_230\_MAI**

FWD

Tue 12/01/2020 to Sat 02/27/2021  
0700 Continuous 1730

(Import)

Work scheduled by: NYPA

UPDATED by NYPA 07/27/2020

MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**LAFAYTTE-CLRKSCRN\_345\_4-46**

FWD

Tue 12/01/2020 to Tue 12/01/2020  
0730 Daily(No Weekends) 1230

(Import)

Work scheduled by: NGrid

UPDATED by NGRID 10/05/2020

CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

**W49TH\_ST\_345KV\_6**

FWD

Tue 12/01/2020 to Tue 12/01/2020  
2230 Continuous 2300

(Import)

Work scheduled by: ConEd

UPDATED by CE 08/06/2020

SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_8**

FWD

Tue 12/01/2020 to Tue 12/01/2020  
2230 Continuous 2300

(Import)

Work scheduled by: ConEd

UPDATED by CE 08/06/2020

SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**MOTTHAVN-RAINEY\_\_\_\_345\_Q11**

FWD

Thu 12/03/2020 to Tue 12/08/2020  
0201 Continuous 0200

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**NIAGARA\_-KINTIGH\_\_345\_NS1-38**

FWD

Thu 12/03/2020 to Tue 12/15/2020  
0800 Continuous 1900

(Import)

Work scheduled by: RGE

UPDATED by NYISO 06/24/2020

DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**KINTIGH\_-ROCHESTR\_345\_SR1-39**

FWD

Thu 12/03/2020 to Fri 12/31/2021 UPDATED by NYISO 06/24/2020

(Import)

0800 Continuous 2359

DYSINGER EAST **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

Work scheduled by: RGE

**KINTIGH\_-ROCHESTR\_345\_SR1-39 & NIAGARA\_-ROCHESTR\_345\_NR2**

FWD

Thu 12/03/2020 to Fri 12/31/2021

(Import)

0800 2359

DYSINGER EAST **1300 MW**  
 Impacts Total Transfer Capability 1850 MW  
 TTC with All Lines In Service 3150 MW

Work scheduled by:

**BECK\_-PACKARD\_230\_BP76**

FWD

REV

Fri 12/04/2020 to Fri 12/04/2020

(Import) (Export)

0730 Daily(No Weekends) 1530

SCH - OH - NY **1750 MW 1400 MW**  
 Impacts Total Transfer Capability 550 MW 600 MW  
 TTC with All Lines In Service 2300 MW 2000 MW

Work scheduled by: NGrid

**LEEDS\_345KV\_R94301**

FWD

Fri 12/04/2020 to Fri 12/04/2020 UPDATED by CHGE 10/21/2020

(Import)

1500 Continuous 1600

UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 2420 MW  
 TTC with All Lines In Service 6220 MW

Work scheduled by: CHGE

**OSWEGO\_COMPLEX\_AVR\_O/S**

FWD

Sun 12/06/2020 to Sun 12/06/2020

(Import)

0900 Continuous 0930

CENTRAL EAST - VC **2870 MW**  
 Impacts Total Transfer Capability 105 MW  
 TTC with All Lines In Service 2975 MW

Work scheduled by: Gen

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 12/07/2020 to Fri 12/11/2020

SCH - NE - NY

0700 Continuous 1530

Impacts Total Transfer Capability  
 TTC with All Lines In Service

Work scheduled by: NYPA

**LONG\_MTN-CRICKVLY\_345\_398**

FWD

REV

Tue 12/08/2020 to Thu 12/10/2020

(Import) (Export)

0700 Continuous 1600

SCH - NE - NY **700 MW 1300 MW**  
 Impacts Total Transfer Capability 700 MW 400 MW  
 TTC with All Lines In Service 1400 MW 1700 MW

Work scheduled by: ISONE



# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LONG\_MTN-CRICKVLY\_345\_398

Tue 12/08/2020 to Thu 12/10/2020  
0700 Continuous 1600  
Work scheduled by: ISONE

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 100 MW 100 MW  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

## SCH-NE-NYISO\_LIMIT\_400

Tue 12/08/2020 to Thu 12/10/2020  
0700 Continuous 1600  
Work scheduled by: ISONE

FWD  
(Import)  
SCH - NE - NY 600 MW  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 1400 MW

## SCH-NYISO-NE\_LIMIT\_1000

Tue 12/08/2020 to Thu 12/10/2020  
0700 Continuous 1600  
Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY 1200 MW  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1700 MW

## MARCY-EDIC\_345\_UE1-7

Mon 12/14/2020 to Mon 12/14/2020  
0700 Continuous 1730  
Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT 5250 MW  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

ARR: 19&16

## SAND\_BAR-PLATSBURG\_115\_PV20

Mon 12/14/2020 to Fri 12/18/2020  
0700 Continuous 1530  
Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## FRASANNX-COOPERS\_345\_UCC2-41

Tue 12/15/2020 to Wed 12/16/2020  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC 2500 MW  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

ARR: 19

## MARCY-FRASANNX\_345\_UCC2-41

Tue 12/15/2020 to Wed 12/16/2020  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC 2500 MW  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

ARR: 19

# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**STONYRDG-HILLSIDE\_230\_72**

FWD

Wed 12/16/2020 to Mon 12/21/2020

(Import)

0800 Continuous 0300

DYSINGER EAST

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYSEG

**N.SCTLND-LEEDS\_345\_93**

FWD

Thu 12/17/2020 to Fri 12/18/2020

(Import)

0800 Continuous 1500

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**BUCHAN\_N-EASTVIEW\_345\_W93**

FWD

Tue 12/22/2020 to Tue 12/22/2020

(Import)

0001 Continuous 0030

UPDATEDby CE10/16/2020

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

**EASTVIEW-SPRNBK\_345\_W79**

FWD

Tue 12/22/2020 to Fri 12/25/2020

(Import)

0001 Continuous 0259

UPDATEDby CE10/16/2020

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

**BUCHAN\_N-EASTVIEW\_345\_W93**

FWD

Fri 12/25/2020 to Fri 12/25/2020

(Import)

0230 Continuous 0259

UPDATEDby CE10/16/2020

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

**SPRNBK\_-TREMONT\_345\_X28**

FWD

Sat 12/26/2020 to Tue 12/29/2020

(Import)

0301 Continuous 0300

UPDATEDby CE10/16/2020

SPR/DUN-SOUTH

**4200 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**LADENTWN-BUCHAN\_S\_345\_Y88**

FWD

Mon 12/28/2020 to Fri 02/12/2021

(Import)

0300 Continuous 0300

UPDATEDby CE10/16/2020

UPNY CONED

**5930 MW**

Impacts Total Transfer Capability 290 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-TREMONT__345_X28					FWD		
Wed 12/30/2020	to	Wed 12/30/2020	<u>UPDATED</u>	<u>by CE</u>	<u>10/16/2020</u>	(Import)	
2130	Continuous	2200					SPR/DUN-SOUTH <b>4200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 400 MW		
					TTC with All Lines In Service 4600 MW		
PORTER_-ROTTRDAM_230_31					FWD		
Mon 02/01/2021	to	Sat 02/27/2021				(Import)	
0600	Continuous	1830					CENTRAL EAST - VC <b>2805 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 170 MW		
					TTC with All Lines In Service 2975 MW		
PLSNTVLY-WOOD_ST__345_F30					FWD		
Sun 02/14/2021	to	Tue 02/16/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/28/2020</u>	(Import)	
2000	Continuous	0200					UPNY CONED <b>4000 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 2220 MW		
					TTC with All Lines In Service 6220 MW		
PLSNTVLY_345KV_RNS5					FWD		
Sun 02/14/2021	to	Tue 02/16/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/28/2020</u>	(Import)	
2000	Continuous	0200					UPNY CONED <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 2420 MW		
					TTC with All Lines In Service 6220 MW		
BERKSHIR-ALPS____345_393					FWD REV		
Wed 02/17/2021	to	Fri 02/19/2021				(Import) (Export)	
0730	Continuous	1600					SCH - NE - NY <b>1100 MW 1700 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 300 MW 0 MW		
					TTC with All Lines In Service 1400 MW 1700 MW		
BERKSHIR-ALPS____345_393					FWD REV		
Wed 02/17/2021	to	Fri 02/19/2021				(Import) (Export)	
0730	Continuous	1600					SCH - NPX_1385 <b>100 MW 100 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 100 MW 100 MW		
					TTC with All Lines In Service 200 MW 200 MW		
EFISHKIL-WOOD_ST__345_F39					FWD		
Thu 02/18/2021	to	Sat 02/20/2021	<u>UPDATED</u>	<u>by CE</u>	<u>04/01/2020</u>	(Import)	
2100	Continuous	0200					UPNY CONED <b>4000 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 2220 MW		
					TTC with All Lines In Service 6220 MW		

# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### WOOD\_ST\_-PLSNTVLE\_345\_Y87

FWD

Thu 02/18/2021 to Sat 02/20/2021

UPDATED

by CE

04/01/2020

(Import)

2100 Continuous 0200

UPNY CONED

**5905 MW**

Impacts Total Transfer Capability 315 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

### CHATGUAY-MASSENA\_765\_7040

FWD

Sun 02/28/2021 to Mon 03/01/2021

(Import)

0500 Continuous 1730

MOSES SOUTH

**1550 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

### CHATGUAY-MASSENA\_765\_7040

FWD

REV

Sun 02/28/2021 to Mon 03/01/2021

(Import) (Export)

0500 Continuous 1730

SCH - HQ - NY

**0 MW**

**0 MW**

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by: NYPA

### MASSENA\_-MARCY\_765\_MSU1

FWD

Sun 02/28/2021 to Mon 03/01/2021

(Import)

0500 Continuous 1730

CENTRAL EAST - VC

**2265 MW**

Impacts Total Transfer Capability 710 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

### MASSENA\_-MARCY\_765\_MSU1

FWD

Sun 02/28/2021 to Mon 03/01/2021

(Import)

0500 Continuous 1730

MOSES SOUTH

**500 MW**

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

### MASSENA\_-MARCY\_765\_MSU1

FWD

REV

Sun 02/28/2021 to Mon 03/01/2021

(Import) (Export)

0500 Continuous 1730

SCH - HQ - NY

**475 MW**

**1000 MW**

Impacts Total Transfer Capability 1025 MW 0 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by: NYPA

### MASSENA\_-MARCY\_765\_MSU1

FWD

Sun 02/28/2021 to Mon 03/01/2021

(Import)

0500 Continuous 1730

SCH - HQ\_CEDARS

**90 MW**

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA\_-MARCY\_\_\_765\_MSU1 & CHATGUAY-MASSENA\_\_\_765\_7040

Sun 02/28/2021 to Mon 03/01/2021  
0500 1730

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

STLAWRNC-MOSES\_\_\_230\_L33P & MASSENA\_-MARCY\_\_\_765\_MSU1

Sun 02/28/2021 to Mon 03/01/2021  
0500 1730

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS **90 MW**  
Impacts Total Transfer Capability 109 MW  
TTC with All Lines In Service 199 MW

DUNWODIE\_345KV\_3

Mon 03/01/2021 to Mon 03/01/2021  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

DUNWODIE\_345KV\_5

Mon 03/01/2021 to Mon 03/01/2021  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBK\_\_\_345\_W64

Mon 03/01/2021 to Mon 03/01/2021  
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 01/23/2020

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 1870 MW  
TTC with All Lines In Service 6220 MW

SPRNBK\_\_\_345KV\_RNS5

Mon 03/01/2021 to Mon 03/01/2021  
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 01/23/2020

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW\_345\_W99

Mon 03/01/2021 to Mon 03/22/2021  
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 01/23/2020

FWD  
(Import)  
UPNY CONED **5985 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 6220MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE-MOTTHAVN\_345\_71**

FWD

Mon 03/01/2021 to Mon 04/05/2021

(Import)

0001 Continuous 0300

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

Work scheduled by: ConEd

TTC with All Lines In Service 4600 MW

**MOTTHAVN-RAINEY\_345\_Q11**

FWD

Mon 03/01/2021 to Tue 04/06/2021

(Import)

0001 Continuous 0700

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

Work scheduled by: ConEd

TTC with All Lines In Service 4600 MW

**EDIC-N.SCTLND\_345\_14**

FWD

Tue 03/02/2021 to Mon 05/31/2021

(Import)

0600 Continuous 1830

CENTRAL EAST - VC

**2240 MW**

Impacts Total Transfer Capability 735 MW

Work scheduled by: NGrid

TTC with All Lines In Service 2975 MW

**PORTER-ROTTDAM\_230\_31**

FWD

Tue 03/02/2021 to Mon 05/31/2021

(Import)

0600 Continuous 1830

CENTRAL EAST - VC

**2805 MW**

Impacts Total Transfer Capability 170 MW

Work scheduled by: NGrid

TTC with All Lines In Service 2975 MW

**MOSES-ADIRNDCK\_230\_MAI**

FWD

Tue 03/02/2021 to Mon 05/31/2021

(Import)

0700 Continuous 1300

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

Work scheduled by: NYPA

TTC with All Lines In Service 3150 MW

**NIAGARA-ROBNSNRD\_230\_64**

REV

Fri 03/12/2021 to Fri 03/12/2021

(Export)

0500 Continuous 1700

SCH - OH - NY

**1900 MW**

Impacts Total Transfer Capability 100 MW

Work scheduled by: NYPA

TTC with All Lines In Service 2000 MW

**MARCY\_345KV\_CSC**

FWD

Sat 03/13/2021 to Sat 03/13/2021

(Import)

0700 Continuous 1730

**UPDATED****by NYPA****07/29/2020**

CENTRAL EAST - VC

**2925 MW**

Impacts Total Transfer Capability 50 MW

Work scheduled by: NYPA

TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EASTVIEW-SPRNBK\_\_345\_W64**

FWD

Mon 03/22/2021 to Mon 03/22/2021 UPDATED by CONED 01/23/2020

(Import)

0130 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

**SPRNBK\_\_345KV\_RNS5**

FWD

Mon 03/22/2021 to Mon 03/22/2021 UPDATED by CONED 01/23/2020

(Import)

0130 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

**W49TH\_ST\_345KV\_5**

FWD

Fri 03/26/2021 to Wed 05/05/2021 UPDATED by CONED 10/06/2020

(Import)

0001 Continuous 0300

Work scheduled by: ConEd

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

**CLAY\_\_-EDIC\_\_345\_2-15**

FWD

Mon 03/29/2021 to Fri 04/16/2021 09/12/2020

(Import)

0800 Continuous 1730

Work scheduled by: NYPA

OSWEGO EXPORT

**4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

**ROCHESTR-PANNELL\_\_345\_RP2**

FWD

Wed 03/31/2021 to Mon 04/12/2021

(Import)

0500 Continuous 1700

Work scheduled by: NYPA

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

**LINDN\_CG-LNDVFT\_\_345\_V-3022**

FWD

REV

Sun 04/04/2021 to Sat 04/10/2021

(Import) (Export)

1400 Continuous 1400

Work scheduled by: PJM

SCH - PJM\_VFT

**0 MW****0 MW**

Impacts Total Transfer Capability 315 MW 315 MW

TTC with All Lines In Service 315 MW 315 MW

**DUNWODIE\_345KV\_3**

FWD

Mon 04/05/2021 to Mon 04/05/2021

(Import)

0230 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_5**

FWD

Mon 04/05/2021 to Mon 04/05/2021  
0230 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**PLSNTVLY-WOOD\_ST\_345\_F31**

FWD

Tue 04/27/2021 to Wed 04/28/2021  
0001 Continuous 0159

Work scheduled by: ConEd

(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 2220 MW  
TTC with All Lines In Service 6220 MW

**PLSNTVLY\_345KV\_RNS4**

FWD

Tue 04/27/2021 to Wed 04/28/2021  
0001 Continuous 0159

Work scheduled by: ConEd

(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 2420 MW  
TTC with All Lines In Service 6220 MW

**SPRNBRK\_345KV\_RNS4**

FWD

Sat 05/01/2021 to Sat 05/01/2021 **UPDATED by CONED 10/06/2020**  
0001 Continuous 0030

Work scheduled by: ConEd

(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

**SPRNBRK\_-W49TH\_ST\_345\_M52**

FWD

Sat 05/01/2021 to Tue 05/04/2021 **UPDATED by CONED 10/06/2020**  
0001 Continuous 0300

Work scheduled by: ConEd

(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

**W49TH\_ST\_345KV\_7**

FWD

Sat 05/01/2021 to Tue 05/04/2021 **UPDATED by CONED 10/06/2020**  
0001 Continuous 0300

Work scheduled by: ConEd

(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**SCH-IMO-NYISO\_LIMIT\_1600**

FWD

Sat 05/01/2021 to Sun 10/31/2021 **UPDATED by IESO 05/03/2019**  
0001 Continuous 2359

Work scheduled by: IESO

(Import)  
SCH - OH - NY **1900 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 1950 MW



# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY -EDIC 345\_2-15

Mon 05/03/2021 to Fri 05/07/2021  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT 4850 MW  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

PANNELL -CLAY 345\_2

Mon 05/03/2021 to Sun 05/30/2021  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL 1300 MW  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

HURLYAVE-ROSETON 345\_303

Mon 05/03/2021 to Fri 05/21/2021  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED 4100 MW  
Impacts Total Transfer Capability 2120 MW  
TTC with All Lines In Service 6220 MW

SPRNBK 345KV\_RNS4

Tue 05/04/2021 to Tue 05/04/2021  
0230 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 10/06/2020

FWD  
(Import)  
SPR/DUN-SOUTH 3200 MW  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

CLAY -EDIC 345\_1-16

Mon 05/10/2021 to Fri 05/14/2021  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT 4850 MW  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

VOLNEY -MARC 345\_19

Tue 06/01/2021 to Wed 06/02/2021  
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC 2825 MW  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 2975 MW

VOLNEY -MARC 345\_19

Tue 06/01/2021 to Wed 06/02/2021  
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
OSWEGO EXPORT 4900 MW  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 5250 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## FRASER\_\_-GILBOA\_\_345\_GF5-35

Tue 06/01/2021 to Mon 06/07/2021  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC 2650 MW  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

## MOSES\_\_-ADIRNDCK\_230\_MA2

Tue 06/01/2021 to Sun 11/14/2021  
0700 Continuous 1300

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2100 MW  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## PORTER\_\_-ROTTRDAM\_230\_30

Thu 06/03/2021 to Wed 09/15/2021  
0600 Continuous 0559

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC 2805 MW  
Impacts Total Transfer Capability 170 MW  
TTC with All Lines In Service 2975 MW

## MARCY\_\_-EDIC\_\_345\_UE1-7

Thu 06/03/2021 to Fri 06/04/2021  
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19&16

FWD  
(Import)  
OSWEGO EXPORT 5250 MW  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

## MARCY\_\_345KV\_CSC

Sat 06/05/2021 to Sat 06/05/2021  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC 2925 MW  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

## SAND\_BAR-PLATSBRG\_115\_PV20

Tue 08/03/2021 to Tue 08/03/2021  
0700 Continuous 1830

Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## FRASANNX-COOPERS\_\_345\_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021  
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC 2500 MW  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_\_-FRASANNX\_345\_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021  
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

### NIAGARA\_-KINTIGH\_345\_NS1-38

Mon 09/13/2021 to Fri 09/17/2021  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

### PORTER\_-ROTTRDAM\_230\_30

Wed 09/15/2021 to Tue 11/30/2021  
0600 Continuous 1830

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2805 MW**  
Impacts Total Transfer Capability 170 MW  
TTC with All Lines In Service 2975 MW

### EDIC\_\_\_-N.SCTLND\_345\_14

Thu 09/16/2021 to Sun 11/14/2021  
0600 Continuous 1830

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2240 MW**  
Impacts Total Transfer Capability 735 MW  
TTC with All Lines In Service 2975 MW

### HURLYAVE-ROSETON\_345\_303

Thu 09/16/2021 to Sun 10/17/2021  
0800 Continuous 1600

Work scheduled by: CHGE

UPDATED by CHGE 09/22/2020

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 2120 MW  
TTC with All Lines In Service 6220 MW

### PANNELL\_-CLAY\_\_\_\_\_345\_1

Mon 09/20/2021 to Fri 09/24/2021  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

### PANNELL\_-CLAY\_\_\_\_\_345\_2

Mon 09/27/2021 to Fri 10/01/2021  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_6**

Tue 09/28/2021 to Tue 09/28/2021  
0100 Continuous 0130

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**E13THSTA-FARRAGUT\_345\_46**

Tue 09/28/2021 to Tue 10/26/2021  
0100 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**W49TH\_ST-E13THSTA\_345\_M55**

Tue 09/28/2021 to Tue 10/26/2021  
0100 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**LEEDS\_\_-HURLYAVE\_345\_301**

Mon 10/18/2021 to Fri 11/19/2021  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 2120 MW  
TTC with All Lines In Service 6220 MW

**W49TH\_ST\_345KV\_6**

Tue 10/26/2021 to Tue 10/26/2021  
0230 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**SCH-IMO-NYISO\_LIMIT\_1750**

Mon 11/01/2021 to Fri 12/31/2021 **UPDATED by IESO 05/03/2019**  
0001 Continuous 2359

Work scheduled by: IESO

FWD  
(Import)  
SCH - OH - NY **2050 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 2300 MW

**SCH-NYISO-IMO\_LIMIT\_1600**

Mon 11/01/2021 to Fri 12/31/2021 **UPDATED by IESO 05/03/2019**  
0001 Continuous 2359

Work scheduled by: IESO

REV  
(Export)  
SCH - OH - NY **1900 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 2000 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,October 24, 2020 to Monday ,April 25, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES\_\_\_\_-ADIRNDCK\_230\_MA1

FWD

Wed 12/01/2021 to Tue 05/31/2022

( Import )

0700 Continuous 1300

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA