

NYISO TRANSFER LIMITATIONS

Saturday ,December 26, 2020 to Monday ,June 27, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Sun 02/28/2021 EXT FORCE by CONED 08/28/2020

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Sun 02/28/2021

0001 2359

Work scheduled by:

FWD REV
(Import) (Export)

SCH - PJ - NY

Impacts Total Transfer Capability 250 MW 50 MW

TTC with All Lines In Service 2800 MW 1950 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Sun 02/28/2021 EXT FORCE by CONED 08/28/2020

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

STLAWRNC-MOSES_230_L33P

Mon 04/30/2018 to Mon 10/31/2022 EXT FORCE by IESO 10/01/2020

0456 Continuous 1600

Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

NEWBRDGE_345_138_BK_1

Wed 09/02/2020 to Sun 03/21/2021 EXT FORCE by LI 09/03/2020

1807 Continuous 2359

Work scheduled by: LI

FWD
(Import)

SCH - PJM_NEPTUNE

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

SPRNBRK_-EGRDNCTR_345_Y49

Thu 10/01/2020 to Fri 02/19/2021 EXT FORCE by LI 12/16/2020

0404 Continuous 2359

Work scheduled by: LI

FWD
(Import)

CONED - LIPA

Impacts Total Transfer Capability 725 MW

TTC with All Lines In Service 1500 MW

EGRDNCTY_345_138_AT2

Sat 10/10/2020 to Fri 02/19/2021 EXT FORCE by LI 12/16/2020

1815 Continuous 2359

Work scheduled by: LI

FWD
(Import)

CONED - LIPA

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

NYISO TRANSFER LIMITATIONS

Saturday ,December 26, 2020 to Monday ,June 27, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EGRDNCTY_345_138_AT1

FWD

Sat 10/10/2020 to Fri 02/19/2021 EXT FORCE by LI 12/16/2020

(Import)

1856 Continuous 2359

CONED - LIPA

1250 MW

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI

SCH-IMO-NYISO_LIMIT_1750

FWD

Sun 11/01/2020 to Fri 04/30/2021 UPDATED by IESO 05/03/2019

(Import)

0001 Continuous 2359

SCH - OH - NY

2050 MW

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 2300 MW

Work scheduled by: IESO

SCH-NYISO-IMO_LIMIT_1600

REV

Sun 11/01/2020 to Fri 04/30/2021 UPDATED by IESO 05/03/2019

(Export)

0001 Continuous 2359

SCH - OH - NY

1900 MW

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 2000 MW

Work scheduled by: IESO

SHOR_NPX-SHOREHAM_138_CSC

FWD

REV

Sun 11/08/2020 to Fri 01/15/2021 EXT FORCE by ISONE 12/23/2020

(Import) (Export)

1341 Continuous 2359

SCH - NPX_CSC

0 MW**0 MW**

Impacts Total Transfer Capability 330 MW

TTC with All Lines In Service 330 MW

Work scheduled by: LI

PLSNTVLE-DUNWODIE_345_W89

FWD

Mon 11/30/2020 to Mon 01/18/2021 EXT FORCE by CONED 12/23/2020

(Import)

1840 Continuous 0259

UPNY CONED

4000 MW

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

MOSES -ADIRNDCK_230_MA1

FWD

Thu 12/03/2020 to Wed 12/23/2020 UPDATED by NYPA 11/30/2020

(Import)

0700 Continuous 1400

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

SHORE_RD_345_138_BK_2

FWD

Sat 12/19/2020 to Fri 03/05/2021 EXTENDED by LIPA 12/23/2020

(Import)

1452 Continuous 2359

CONED - LIPA

1350 MW

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI

NYISO TRANSFER LIMITATIONS

Saturday ,December 26, 2020 to Monday ,June 27, 2022

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONTP-W49TH_ST_345_Y56

Sun 12/20/2020 to Sun 12/27/2020
0001 Continuous 0300

UPDATED by CE 12/17/2020

Work scheduled by: ConEd

FWD
(Import)
0 MW
SCH - PJM_HTP
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7

Sun 12/20/2020 to Sun 12/27/2020
0001 Continuous 0300

UPDATED by CE 12/17/2020

Work scheduled by: ConEd

FWD
(Import)
300 MW
SCH - PJM_HTP
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Sun 12/20/2020 to Sun 12/27/2020
0001 Continuous 0300

UPDATED by CE 12/17/2020

Work scheduled by: ConEd

FWD
(Import)
300 MW
SCH - PJM_HTP
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

STONYRDG-HILLSIDE_230_72

Mon 12/21/2020 to Mon 12/21/2020
0700 Continuous 1800

EXTENDED by NYSEG 12/18/2020

Work scheduled by: NYSEG

FWD
(Import)
2850 MW
DYSINGER EAST
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

HOMRC_NY-MAINS_NY_345_47

Wed 12/23/2020 to Wed 12/23/2020
0700 Continuous 1530

Work scheduled by: NYSEG

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

MOTTHAVN-RAINEY_345_Q12

Sat 12/26/2020 to Thu 12/31/2020
0301 Continuous 0200

CANCELLED by ConEd 12/21/2020

Work scheduled by: ConEd

FWD
(Import)
3800 MW
SPR/DUN-SOUTH
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NRTH1385-NOR HBR_138_601

Tue 12/29/2020 to Tue 12/29/2020
0800 Continuous 1600

Work scheduled by: LI

| | |
|--|---------------|
| FWD | REV |
| (Import) | (Export) |
| 100 MW | 100 MW |
| SCH - NPX_1385 | |
| Impacts Total Transfer Capability 100 MW | 100 MW |
| TTC with All Lines In Service 200 MW | 200 MW |

NYISO TRANSFER LIMITATIONS

Saturday ,December 26, 2020 to Monday ,June 27, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602

Tue 12/29/2020 to Tue 12/29/2020
0800 1600

Work scheduled by:

| | | |
|-----------------------------------|-------------|-------------|
| | FWD | REV |
| | (Import) | (Export) |
| SCH - NPX_1385 | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 200 MW | 200 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603

Tue 12/29/2020 to Tue 12/29/2020
0800 1600

Work scheduled by:

| | | |
|-----------------------------------|-------------|-------------|
| | FWD | REV |
| | (Import) | (Export) |
| SCH - NPX_1385 | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 200 MW | 200 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

NRTH1385-NOR HBR__138_602

Tue 12/29/2020 to Tue 12/29/2020
0800 Continuous 1600

Work scheduled by: LI

| | | |
|-----------------------------------|---------------|---------------|
| | FWD | REV |
| | (Import) | (Export) |
| SCH - NPX_1385 | 100 MW | 100 MW |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603

Tue 12/29/2020 to Tue 12/29/2020
0800 1600

Work scheduled by:

| | | |
|-----------------------------------|-------------|-------------|
| | FWD | REV |
| | (Import) | (Export) |
| SCH - NPX_1385 | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 200 MW | 200 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

NRTH1385-NOR HBR__138_603

Tue 12/29/2020 to Tue 12/29/2020
0800 Continuous 1600

Work scheduled by: LI

| | | |
|-----------------------------------|---------------|---------------|
| | FWD | REV |
| | (Import) | (Export) |
| SCH - NPX_1385 | 100 MW | 100 MW |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

NRTH1385-NRTHPORT_138_NNC

Tue 12/29/2020 to Tue 12/29/2020
0800 Continuous 1600

Work scheduled by: LI

| | | |
|-----------------------------------|-------------|-------------|
| | FWD | REV |
| | (Import) | (Export) |
| SCH - NPX_1385 | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 200 MW | 200 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

OSWEGO__VOLNEY__345_12

Tue 12/29/2020 to Tue 12/29/2020
0800 Daily 1630

Work scheduled by: NGrid

| | |
|-----------------------------------|----------------|
| | FWD |
| | (Import) |
| OSWEGO EXPORT | 5250 MW |
| Impacts Total Transfer Capability | 0 MW |
| TTC with All Lines In Service | 5250 MW |

NYISO TRANSFER LIMITATIONS

Saturday ,December 26, 2020 to Monday ,June 27, 2022

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 6220MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4

Sun 01/03/2021 to Sun 01/03/2021
0001 0030

Work scheduled by:

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4

Mon 01/04/2021 to Mon 01/04/2021
0130 0200

Work scheduled by:

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

MOSES__-ADIRNDCK_230_MA1

Mon 01/04/2021 to Sat 02/27/2021
0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 11/30/2020

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

SHORE_RD_345_138_BK 2

Wed 01/06/2021 to Wed 01/13/2021
0001 Continuous 2359

Work scheduled by: LI

CANCELLED by LI 12/23/2020

FWD
(Import)
CONED - LIPA **1350 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 1500 MW

PLSNTVLY-WOOD_ST__345_F30

Sat 01/09/2021 to Mon 01/11/2021
0001 Continuous 0200

Work scheduled by: ConEd

CANCELLED by NYISO 12/23/2020

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 2220 MW
TTC with All Lines In Service 6220 MW

PLSNTVLY_345KV_RNS5

Sat 01/09/2021 to Mon 01/11/2021
0001 Continuous 0200

Work scheduled by: ConEd

CANCELLED by NYISO 12/23/2020

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 2420 MW
TTC with All Lines In Service 6220 MW

LADENTWN-BUCHAN_S_345_Y88

Mon 01/18/2021 to Fri 03/05/2021
0300 Continuous 0300

Work scheduled by: ConEd

UPDATED by CE 11/10/2020

FWD
(Import)
UPNY CONED **5930 MW**
Impacts Total Transfer Capability 290 MW
TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Saturday ,December 26, 2020 to Monday ,June 27, 2022

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 6220MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-TREMONT_345_X28

Sat 01/23/2021 to Sun 01/24/2021
0301 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **4200 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 4600 MW

MOTTHAVN-RAINEY_345_Q12

Mon 01/25/2021 to Sat 02/13/2021
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 12/22/2020

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

W49TH_ST_345KV_8

Sat 01/30/2021 to Thu 03/11/2021
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

PORTER_-ROTTDAM_230_31

Mon 02/01/2021 to Sat 02/27/2021
0600 Continuous 1830

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2805 MW**
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

RAMAPO_345_345_PAR3500

Mon 02/08/2021 to Mon 02/15/2021
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 12/09/2020

| | FWD | REV |
|-----------------------------------|----------------|----------------|
| (Import) (Export) | | |
| SCH - PJ - NY | 2350 MW | 1250 MW |
| Impacts Total Transfer Capability | 450 MW | 700 MW |
| TTC with All Lines In Service | 2800 MW | 1950 MW |

RAMAPO_345_345_PAR4500

Mon 02/08/2021 to Mon 02/15/2021
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 12/09/2020

| | FWD | REV |
|-----------------------------------|----------------|----------------|
| (Import) (Export) | | |
| SCH - PJ - NY | 2350 MW | 1250 MW |
| Impacts Total Transfer Capability | 450 MW | 700 MW |
| TTC with All Lines In Service | 2800 MW | 1950 MW |

RAMAPO_500_345_BK_1500

Mon 02/08/2021 to Mon 02/15/2021
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 12/09/2020

| | FWD | REV |
|-----------------------------------|----------------|----------------|
| (Import) (Export) | | |
| SCH - PJ - NY | 1450 MW | 1200 MW |
| Impacts Total Transfer Capability | 1350 MW | 750 MW |
| TTC with All Lines In Service | 2800 MW | 1950 MW |

NYISO TRANSFER LIMITATIONS

Saturday ,December 26, 2020 to Monday ,June 27, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | | | |
|----------------------------|------------|----------------|----------------|-----------------|-------------------|-----------------------------------|----------|----------|
| RAMAPO___500_345_BK 1500 | | | | | | FWD | | |
| Mon 02/08/2021 | to | Mon 02/15/2021 | <u>UPDATED</u> | <u>by CONED</u> | <u>12/09/2020</u> | (Import) | | |
| 0001 | Continuous | 0200 | | | | | 6025 MW | |
| Work scheduled by: ConEd | | | | | | UPNY CONED | | |
| | | | | | | Impacts Total Transfer Capability | 195 MW | |
| | | | | | | TTC with All Lines In Service | 6220 MW | |
| HOPATCON-RAMAPO___500_5018 | | | | | | FWD | REV | |
| Mon 02/08/2021 | to | Mon 02/15/2021 | <u>UPDATED</u> | <u>by CONED</u> | <u>12/09/2020</u> | (Import) | (Export) | |
| 0001 | Continuous | 1900 | | | | | 1450 MW | 1200 MW |
| Work scheduled by: ConEd | | | | | | Impacts Total Transfer Capability | 1350 MW | |
| | | | | | | TTC with All Lines In Service | 2800 MW | |
| HOPATCON-RAMAPO___500_5018 | | | | | | FWD | | |
| Mon 02/08/2021 | to | Mon 02/15/2021 | <u>UPDATED</u> | <u>by CONED</u> | <u>12/09/2020</u> | (Import) | | |
| 0001 | Continuous | 1900 | | | | | 6025 MW | |
| Work scheduled by: ConEd | | | | | | UPNY CONED | | |
| | | | | | | Impacts Total Transfer Capability | 195 MW | |
| | | | | | | TTC with All Lines In Service | 6220 MW | |
| E13THSTA-FARRAGUT_345_46 | | | | | | FWD | | |
| Tue 02/16/2021 | to | Wed 02/17/2021 | <u>UPDATED</u> | <u>by CONED</u> | <u>12/21/2020</u> | (Import) | | |
| 0001 | Continuous | 2100 | | | | | 3800 MW | |
| Work scheduled by: ConEd | | | | | | SPR/DUN-SOUTH | | |
| | | | | | | Impacts Total Transfer Capability | 800 MW | |
| | | | | | | TTC with All Lines In Service | 4600 MW | |
| W49TH_ST_345KV_6 | | | | | | FWD | | |
| Wed 02/17/2021 | to | Wed 02/17/2021 | | | | | (Import) | |
| 0001 | Continuous | 0030 | | | | | 300 MW | |
| Work scheduled by: ConEd | | | | | | SCH - PJM_HTP | | |
| | | | | | | Impacts Total Transfer Capability | 360 MW | |
| | | | | | | TTC with All Lines In Service | 660 MW | |
| BERKSHIR-ALPS___345_393 | | | | | | FWD | REV | |
| Wed 02/17/2021 | to | Fri 02/19/2021 | | | | | (Import) | (Export) |
| 0730 | Continuous | 1600 | | | | | 1100 MW | 1700 MW |
| Work scheduled by: NGrid | | | | | | Impacts Total Transfer Capability | 300 MW | |
| | | | | | | TTC with All Lines In Service | 1400 MW | |
| BERKSHIR-ALPS___345_393 | | | | | | FWD | REV | |
| Wed 02/17/2021 | to | Fri 02/19/2021 | | | | | (Import) | (Export) |
| 0730 | Continuous | 1600 | | | | | 100 MW | 100 MW |
| Work scheduled by: NGrid | | | | | | Impacts Total Transfer Capability | 100 MW | |
| | | | | | | TTC with All Lines In Service | 200 MW | |

ARR: 78

ARR: 78

NYISO TRANSFER LIMITATIONS

Saturday ,December 26, 2020 to Monday ,June 27, 2022

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND_BAR-PLATSBURG_115_PV20

Mon 02/22/2021 to Fri 02/26/2021
0600 Daily 1800

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

CHATGUAY-MASSENA_765_7040

Sun 02/28/2021 to Mon 03/01/2021
0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

1550 MW

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA_765_7040

Sun 02/28/2021 to Mon 03/01/2021
0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

REV

(Export)

SCH - HQ - NY

0 MW

0 MW

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

MASSENA -MARC_765_MSU1

Sun 02/28/2021 to Mon 03/01/2021
0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC

2265 MW

Impacts Total Transfer Capability 710 MW

TTC with All Lines In Service 2975 MW

MASSENA -MARC_765_MSU1

Sun 02/28/2021 to Mon 03/01/2021
0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

500 MW

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

MASSENA -MARC_765_MSU1

Sun 02/28/2021 to Mon 03/01/2021
0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

REV

(Export)

SCH - HQ - NY

475 MW

1000 MW

Impacts Total Transfer Capability 1025 MW 0 MW

TTC with All Lines In Service 1500 MW 1000 MW

MASSENA -MARC_765_MSU1

Sun 02/28/2021 to Mon 03/01/2021
0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

SCH - HQ_CEDARS

90 MW

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

NYISO TRANSFER LIMITATIONS

Saturday ,December 26, 2020 to Monday ,June 27, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY____765_MSU1 & CHATGUAY-MASSENA____765_7040

Sun 02/28/2021 to Mon 03/01/2021
0500 1730

Work scheduled by:

FWD
(Import)
MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

STLAWRNC-MOSES____230_L33P & MASSENA_-MARCY____765_MSU1

Sun 02/28/2021 to Mon 03/01/2021
0500 1730

Work scheduled by:

FWD
(Import)
SCH - HQ_CEDARS **90 MW**
Impacts Total Transfer Capability 109 MW
TTC with All Lines In Service 199 MW

MOTTHAVN-RAINEY____345_Q11

Mon 03/01/2021 to Tue 04/06/2021
0001 Continuous 0700

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

BERKSHIR-ALPS____345_393

Mon 03/01/2021 to Sat 03/20/2021
0700 Continuous 1600

Work scheduled by: NGrid

UPDATED by NGRID 12/14/2020

ARR: 78

FWD REV
(Import) (Export)
SCH - NE - NY **1100 MW 1700 MW**
Impacts Total Transfer Capability 300 MW 0 MW
TTC with All Lines In Service 1400 MW 1700 MW

BERKSHIR-ALPS____345_393

Mon 03/01/2021 to Sat 03/20/2021
0700 Continuous 1600

Work scheduled by: NGrid

UPDATED by NGRID 12/14/2020

ARR: 78

FWD REV
(Import) (Export)
SCH - NPX_1385 **100 MW 100 MW**
Impacts Total Transfer Capability 100 MW 100 MW
TTC with All Lines In Service 200 MW 200 MW

SCH-NYISO-NE_LIMIT_900

Mon 03/01/2021 to Sat 03/20/2021
0700 Continuous 1600

Work scheduled by: NGrid

UPDATED by NGRID 12/14/2020

REV
(Export)
SCH - NE - NY **1100 MW**
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 1700 MW

EDIC____-N.SCTLND_345_14

Tue 03/02/2021 to Mon 05/31/2021
0600 Continuous 1830

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2240 MW**
Impacts Total Transfer Capability 735 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Saturday ,December 26, 2020 to Monday ,June 27, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PORTER__-ROTTRDAM_230_31

Tue 03/02/2021 to Mon 05/31/2021
0600 Continuous 1830

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2805 MW**
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

MOSES__-ADIRNDCK_230_MAI

Tue 03/02/2021 to Mon 05/31/2021
0700 Continuous 1300

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

HUDSONTP-W49TH_ST_345_Y56

Sat 03/06/2021 to Tue 03/09/2021
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_6

Sat 03/06/2021 to Tue 03/09/2021
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7

Sat 03/06/2021 to Tue 03/09/2021
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

ELBRIDGE-LAFAYTTE_345_17-LE

Tue 03/09/2021 to Tue 03/09/2021
0800 Daily(No Weekends) 1630

Work scheduled by: NGrid

ARR: 75

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

NIAGARA_-ROBNSNRD_230_64

Fri 03/12/2021 to Fri 03/12/2021
0500 Continuous 1700

Work scheduled by: NYPA

REV
(Export)
SCH - OH - NY **1900 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 2000 MW

NYISO TRANSFER LIMITATIONS

Saturday ,December 26, 2020 to Monday ,June 27, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY____345KV_CSC

FWD

Sat 03/13/2021 to Sat 03/13/2021 **UPDATED by NYPA 07/29/2020**
0700 Continuous 1730

(Import)

Work scheduled by: NYPA

CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

W49TH_ST_345KV_6

FWD

Tue 03/16/2021 to Tue 03/16/2021
0230 Continuous 0300

(Import)

Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

FWD

Tue 03/16/2021 to Tue 03/16/2021
0230 Continuous 0300

(Import)

Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_5

FWD

Fri 03/26/2021 to Wed 05/05/2021 **UPDATED by CONED 10/06/2020**
0001 Continuous 0300

(Import)

Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

CLAY____-EDIC____345_2-15

FWD

Mon 03/29/2021 to Fri 04/16/2021 **09/12/2020**
0800 Continuous 1730

(Import)

Work scheduled by: NYPA

OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

BRANCHBG-HOPATCON_500_5060

FWD

Wed 03/31/2021 to Wed 03/31/2021 **UPDATED by PJM 11/30/2020**
0200 Continuous 1500

(Import)

Work scheduled by: PJM

UPNY CONED **6025 MW**
Impacts Total Transfer Capability 195 MW
TTC with All Lines In Service 6220 MW

ROCHESTR-PANNELL__345_RP2

FWD

Wed 03/31/2021 to Mon 04/12/2021
0500 Continuous 1700

(Import)

Work scheduled by: NYPA

DYSINGER EAST **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,December 26, 2020 to Monday ,June 27, 2022

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | |
|------------------------------|------------|----------------|----------------|-----------------------------------|-----------------------------------|---------------|
| SPRNBK__345KV_RNS3 | | | | | FWD | |
| Thu 04/01/2021 | to | Thu 04/01/2021 | <u>UPDATED</u> | <u>by CONED</u> <u>12/16/2020</u> | (Import) | |
| 0001 | Continuous | 0030 | | | | |
| Work scheduled by: ConEd | | | | | SPR/DUN-SOUTH | 3800 MW |
| | | | | | Impacts Total Transfer Capability | 800 MW |
| | | | | | TTC with All Lines In Service | 4600 MW |
| EASTVIEW-SPRNBK__345_W78 | | | | | FWD | |
| Thu 04/01/2021 | to | Thu 04/01/2021 | <u>UPDATED</u> | <u>by CONED</u> <u>12/16/2020</u> | (Import) | |
| 0001 | Continuous | 1830 | | | | |
| Work scheduled by: ConEd | | | | | UPNY CONED | 4350 MW |
| | | | | | Impacts Total Transfer Capability | 1870 MW |
| | | | | | TTC with All Lines In Service | 6220 MW |
| MILLWOOD-EASTVIEW_345_W85 | | | | | FWD | |
| Thu 04/01/2021 | to | Thu 04/01/2021 | <u>UPDATED</u> | <u>by CONED</u> <u>12/16/2020</u> | (Import) | |
| 0001 | Continuous | 1830 | | | | |
| Work scheduled by: ConEd | | | | | UPNY CONED | 5985 MW |
| | | | | | Impacts Total Transfer Capability | 235 MW |
| | | | | | TTC with All Lines In Service | 6220 MW |
| SPRNBK__345KV_RNS3 | | | | | FWD | |
| Thu 04/01/2021 | to | Thu 04/01/2021 | <u>UPDATED</u> | <u>by CONED</u> <u>12/16/2020</u> | (Import) | |
| 1800 | Continuous | 1830 | | | | |
| Work scheduled by: ConEd | | | | | SPR/DUN-SOUTH | 3800 MW |
| | | | | | Impacts Total Transfer Capability | 800 MW |
| | | | | | TTC with All Lines In Service | 4600 MW |
| LINDN_CG-LNDVFT__345_V-3022 | | | | | FWD | REV |
| Sun 04/04/2021 | to | Sat 04/10/2021 | | | (Import) | (Export) |
| 1400 | Continuous | 1400 | | | | |
| Work scheduled by: PJM | | | | | SCH - PJM_VFT | 0 MW 0 MW |
| | | | | | Impacts Total Transfer Capability | 315 MW 315 MW |
| | | | | | TTC with All Lines In Service | 315 MW 315 MW |
| NIAGARA_-STA_255__345_NH2 | | | | | FWD | |
| Fri 04/16/2021 | to | Fri 04/16/2021 | | | (Import) | |
| 0500 | Continuous | 1700 | | | | |
| Work scheduled by: NYPA | | | | | DYSINGER EAST | 2350 MW |
| | | | | | Impacts Total Transfer Capability | 800 MW |
| | | | | | TTC with All Lines In Service | 3150 MW |
| KINTIGH_-STA_255__345_SH1-39 | | | | | FWD | |
| Mon 04/26/2021 | to | Fri 04/30/2021 | | | (Import) | |
| 0700 | Continuous | 1700 | | | | |
| Work scheduled by: NYPA | | | | | DYSINGER EAST | 2350 MW |
| | | | | | Impacts Total Transfer Capability | 800 MW |
| | | | | | TTC with All Lines In Service | 3150 MW |

NYISO TRANSFER LIMITATIONS

Saturday ,December 26, 2020 to Monday ,June 27, 2022

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-KINTIGH__345_NS1-38

FWD

Mon 04/26/2021 to Fri 04/30/2021

(Import)

0700 Continuous 1700

DYSINGER EAST

1700 MW

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

PLSNTVLY-WOOD_ST__345_F31

FWD

Tue 04/27/2021 to Wed 04/28/2021

(Import)

0001 Continuous 0159

UPNY CONED

4000 MW

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

PLSNTVLY_345KV_RNS4

FWD

Tue 04/27/2021 to Wed 04/28/2021

(Import)

0001 Continuous 0159

UPNY CONED

3800 MW

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

SPRNBRK__345KV_RNS4

FWD

Sat 05/01/2021 to Sat 05/01/2021

(Import)

0001 Continuous 0030

UPDATED

by CONED 10/06/2020

SPR/DUN-SOUTH

3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

SPRNBRK_-W49TH_ST_345_M52

FWD

Sat 05/01/2021 to Tue 05/04/2021

(Import)

0001 Continuous 0300

UPDATED

by CONED 10/06/2020

SPR/DUN-SOUTH

3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

W49TH_ST_345KV_7

FWD

Sat 05/01/2021 to Tue 05/04/2021

(Import)

0001 Continuous 0300

UPDATED

by CONED 10/06/2020

SCH - PJM_HTP

300 MW

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

SCH-IMO-NYISO_LIMIT_1600

FWD

Sat 05/01/2021 to Sun 10/31/2021

(Import)

0001 Continuous 2359

UPDATED

by IESO 05/03/2019

SCH - OH - NY

1900 MW

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 1950 MW

Work scheduled by: IESO

NYISO TRANSFER LIMITATIONS

Saturday ,December 26, 2020 to Monday ,June 27, 2022

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | |
|----------------------------------|------------|----------------|------------------------------------|-----------------------------------|------------------|
| CLAY -EDIC 345_2-15 | | | | FWD | |
| Mon 05/03/2021 | to | Fri 05/07/2021 | | (Import) | |
| 0700 | Continuous | 1530 | | OSWEGO EXPORT | 4850 MW |
| Work scheduled by: NYPA | | | | Impacts Total Transfer Capability | 400 MW |
| | | | | TTC with All Lines In Service | 5250 MW |
| PANNELL -CLAY 345_2 | | | | FWD | |
| Mon 05/03/2021 | to | Sun 05/30/2021 | | (Import) | |
| 0700 | Continuous | 1730 | | WEST CENTRAL | 1300 MW |
| Work scheduled by: NYPA | | | | Impacts Total Transfer Capability | 950 MW |
| | | | | TTC with All Lines In Service | 2250 MW |
| HURLYAVE-ROSETON 345_303 | | | | FWD | |
| Mon 05/03/2021 | to | Fri 05/21/2021 | | (Import) | |
| 0800 | Continuous | 1600 | | UPNY CONED | 4100 MW |
| Work scheduled by: CHGE | | | | Impacts Total Transfer Capability | 2120 MW |
| | | | | TTC with All Lines In Service | 6220 MW |
| SHOR_NPX-SHOREHAM_138_CSC | | | | FWD | REV |
| Mon 05/03/2021 | to | Fri 05/07/2021 | | (Import) | (Export) |
| 0900 | Continuous | 1500 | | SCH - NPX_CSC | 0 MW 0 MW |
| Work scheduled by: LI | | | | Impacts Total Transfer Capability | 330 MW 330 MW |
| | | | | TTC with All Lines In Service | 330 MW 330 MW |
| SPRNBK 345KV_RNS4 | | | | FWD | |
| Tue 05/04/2021 | to | Tue 05/04/2021 | UPDATED by CONED 10/06/2020 | (Import) | |
| 0230 | Continuous | 0300 | | SPR/DUN-SOUTH | 3200 MW |
| Work scheduled by: ConEd | | | | Impacts Total Transfer Capability | 1400 MW |
| | | | | TTC with All Lines In Service | 4600 MW |
| CLAY -EDIC 345_1-16 | | | | FWD | |
| Mon 05/10/2021 | to | Fri 05/14/2021 | | (Import) | |
| 0700 | Continuous | 1530 | | OSWEGO EXPORT | 4850 MW |
| Work scheduled by: NYPA | | | | Impacts Total Transfer Capability | 400 MW |
| | | | | TTC with All Lines In Service | 5250 MW |
| NIAGARA -STA_255_345_NH2 | | | | FWD | |
| Mon 05/24/2021 | to | Fri 05/28/2021 | | (Import) | |
| 0500 | Continuous | 1700 | | DYSINGER EAST | 2350 MW |
| Work scheduled by: NYPA | | | | Impacts Total Transfer Capability | 800 MW |
| | | | | TTC with All Lines In Service | 3150 MW |

NYISO TRANSFER LIMITATIONS

Saturday ,December 26, 2020 to Monday ,June 27, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

VOLNEY__-MARCY____345_19

Tue 06/01/2021 to Wed 06/02/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2825 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 2975 MW

VOLNEY__-MARCY____345_19

Tue 06/01/2021 to Wed 06/02/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
OSWEGO EXPORT **4900 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 5250 MW

FRASER__-GILBOA____345_GF5-35

Tue 06/01/2021 to Mon 06/07/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

MOSES__-ADIRNDCK_230_MA2

Tue 06/01/2021 to Sun 11/14/2021
0700 Continuous 1300

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

PORTER__-ROTTRDAM_230_30

Thu 06/03/2021 to Wed 09/15/2021
0600 Continuous 0559

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2805 MW**
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

MARCY__-EDIC____345_UE1-7

Thu 06/03/2021 to Fri 06/04/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19&16

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

MARCY____345KV_CSC

Sat 06/05/2021 to Sat 06/05/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASANNX-COOPERS__345_UCC2-41

Fri 06/25/2021 to Tue 08/10/2021
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY__-FRASANNX_345_UCC2-41

Fri 06/25/2021 to Tue 08/10/2021
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

NIAGARA__345_230_AT4

Mon 07/12/2021 to Fri 07/23/2021
0500 Continuous 1700

Work scheduled by: NYPA

| | |
|-----------------------------------|------------------------|
| FWD | REV |
| (Import) | (Export) |
| SCH - OH - NY | 1900 MW 1400 MW |
| Impacts Total Transfer Capability | 50 MW 300 MW |
| TTC with All Lines In Service | 1950 MW 1700 MW |

SAND_BAR-PLATSBRG_115_PV20

Tue 08/03/2021 to Tue 08/03/2021
0700 Continuous 1830

Work scheduled by: NYPA

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FRASANNX-COOPERS__345_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY__-FRASANNX_345_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

KINTIGH_-STA_255__345_SH1-39

Mon 09/13/2021 to Fri 09/17/2021
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **2350 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,December 26, 2020 to Monday ,June 27, 2022

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 6220MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-KINTIGH_345_NS1-38

FWD

Mon 09/13/2021 to Fri 09/17/2021

(Import)

0500 Continuous 1700

DYSINGER EAST **1400 MW**

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

PORTER_-ROTTDAM_230_30

FWD

Wed 09/15/2021 to Tue 11/30/2021

(Import)

0600 Continuous 1830

CENTRAL EAST - VC **2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

EDIC_-N.SCTLND_345_14

FWD

Thu 09/16/2021 to Sun 11/14/2021

(Import)

0600 Continuous 1830

CENTRAL EAST - VC **2240 MW**

Impacts Total Transfer Capability 735 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

HURLYAVE-ROSETON_345_303

FWD

Thu 09/16/2021 to Sun 10/17/2021

(Import)

0800 Continuous 1600

UPDATED by CHGE 09/22/2020UPNY CONED **4100 MW**

Impacts Total Transfer Capability 2120 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: CHGE

PANNELL_-CLAY_345_1

FWD

Mon 09/20/2021 to Fri 09/24/2021

(Import)

0700 Continuous 1530

WEST CENTRAL **1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

CLAY_-EDIC_345_2-15

FWD

Mon 09/20/2021 to Sat 10/16/2021

(Import)

0700 Continuous 1730

OSWEGO EXPORT **4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

PANNELL_-CLAY_345_2

FWD

Mon 09/27/2021 to Fri 10/01/2021

(Import)

0700 Continuous 1530

WEST CENTRAL **1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

NYISO TRANSFER LIMITATIONS

Saturday ,December 26, 2020 to Monday ,June 27, 2022

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6

Tue 09/28/2021 to Tue 09/28/2021
0100 Continuous 0130

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

E13THSTA-FARRAGUT_345_46

Tue 09/28/2021 to Tue 10/26/2021
0100 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

W49TH_ST-E13THSTA_345_M55

Tue 09/28/2021 to Tue 10/26/2021
0100 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

LEEDS__-HURLYAVE_345_301

Mon 10/18/2021 to Fri 11/19/2021
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 2120 MW
TTC with All Lines In Service 6220 MW

W49TH_ST_345KV_6

Tue 10/26/2021 to Tue 10/26/2021
0230 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

SCH-IMO-NYISO_LIMIT_1750

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019
0001 Continuous 2359

Work scheduled by: IESO

FWD
(Import)
SCH - OH - NY **2050 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 2300 MW

SCH-NYISO-IMO_LIMIT_1600

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019
0001 Continuous 2359

Work scheduled by: IESO

REV
(Export)
SCH - OH - NY **1900 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 2000 MW

NYISO TRANSFER LIMITATIONS

Saturday ,December 26, 2020 to Monday ,June 27, 2022

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER____345_FRASER SVC

Wed 12/01/2021 to Mon 02/28/2022
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2935 MW**
Impacts Total Transfer Capability 40 MW
TTC with All Lines In Service 2975 MW

MOSES____-ADIRNDCK_230_MAI

Wed 12/01/2021 to Tue 05/31/2022
0700 Continuous 1300

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

N.SCTLND-ALPS____345_2

Mon 05/02/2022 to Mon 05/09/2022
0600 Daily 1800

Work scheduled by: NGrid

FWD
(Import)
SCH - NE - NY **750 MW**
Impacts Total Transfer Capability 650 MW
TTC with All Lines In Service 1400 MW

N.SCTLND-ALPS____345_2

Mon 05/02/2022 to Mon 05/09/2022
0600 Daily 1800

Work scheduled by: NGrid

FWD REV
(Import) (Export)
SCH - NPX_1385 **100 MW 100 MW**
Impacts Total Transfer Capability 100 MW 100 MW
TTC with All Lines In Service 200 MW 200 MW

HOMRC_NY-MAINS_NY_345_47

Fri 05/20/2022 to Fri 05/27/2022
0800 Continuous 1600

Work scheduled by: PJM

UPDATED by PJM 11/19/2020

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

HOMR_NYW-PIERC_NY_345_48

Fri 05/20/2022 to Fri 05/27/2022
0800 Continuous 1600

Work scheduled by: PJM

UPDATED by PJM 11/19/2020

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

MOSES____-ADIRNDCK_230_MA2

Wed 06/01/2022 to Mon 11/14/2022
0700 Continuous 1300

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW