

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 22, 2020 to Thursday ,June 23, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Sun 02/28/2021 EXT FORCE by CONED 08/28/2020

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Sun 02/28/2021

0001 2359

Work scheduled by:

FWD REV  
(Import) (Export)

SCH - PJ - NY

**2550 MW 1900 MW**

Impacts Total Transfer Capability 250 MW 50 MW

TTC with All Lines In Service 2800 MW 1950 MW

## MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Sun 02/28/2021 EXT FORCE by CONED 08/28/2020

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## STLAWRNC-MOSES\_230\_L33P

Mon 04/30/2018 to Mon 10/31/2022 EXT FORCE by IESO 10/01/2020

0456 Continuous 1600

Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## NEWBRDGE\_345\_138\_BK\_1

Wed 09/02/2020 to Sun 03/21/2021 EXT FORCE by LI 09/03/2020

1807 Continuous 2359

Work scheduled by: LI

FWD  
(Import)

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

## SPRNBRK\_-EGRDNCTR\_345\_Y49

Thu 10/01/2020 to Fri 02/19/2021 EXT FORCE by LI 12/16/2020

0404 Continuous 2359

Work scheduled by: LI

FWD  
(Import)

CONED - LIPA

**775 MW**

Impacts Total Transfer Capability 725 MW

TTC with All Lines In Service 1500 MW

## EGRDNCTY\_345\_138\_AT2

Sat 10/10/2020 to Fri 02/19/2021 EXT FORCE by LI 12/16/2020

1815 Continuous 2359

Work scheduled by: LI

FWD  
(Import)

CONED - LIPA

**1250 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 22, 2020 to Thursday ,June 23, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## EGRDNCTY\_345\_138\_AT1

FWD

Sat 10/10/2020 to Fri 02/19/2021 EXT FORCE by LI 12/16/2020

(Import)

1856 Continuous 2359

CONED - LIPA

**1250 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI

## SCH-IMO-NYISO\_LIMIT\_1750

FWD

Sun 11/01/2020 to Fri 04/30/2021 UPDATED by IESO 05/03/2019

(Import)

0001 Continuous 2359

SCH - OH - NY

**2050 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 2300 MW

Work scheduled by: IESO

## SCH-NYISO-IMO\_LIMIT\_1600

REV

Sun 11/01/2020 to Fri 04/30/2021 UPDATED by IESO 05/03/2019

(Export)

0001 Continuous 2359

SCH - OH - NY

**1900 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 2000 MW

Work scheduled by: IESO

## STA\_255\_-ROCHESTR\_345\_HR1

FWD

Tue 11/03/2020 to Sun 12/20/2020 UPDATED by NYSEG 12/14/2020

(Import)

1146 Continuous 1600

DYSINGER EAST

**2350 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYISO

## SHOR\_NPX-SHOREHAM\_138\_CSC

FWD

REV

Sun 11/08/2020 to Fri 01/08/2021 EXT FORCE by ISONE 11/25/2020

(Import) (Export)

1341 Continuous 2359

SCH - NPX\_CSC

**0 MW****0 MW**

Impacts Total Transfer Capability 330 MW

330 MW

TTC with All Lines In Service 330 MW

330 MW

Work scheduled by: LI

## PLSNTVLE-DUNWODIE\_345\_W89

FWD

Mon 11/30/2020 to Wed 12/23/2020 EXT FORCE by CONED 12/16/2020

(Import)

1840 Continuous 2359

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

## MOSES\_-ADIRNDCK\_230\_MAI

FWD

Thu 12/03/2020 to Wed 12/23/2020 UPDATED by NYPA 11/30/2020

(Import)

0700 Continuous 1400

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**NYISO TRANSFER LIMITATIONS**

Tuesday ,December 22, 2020 to Thursday ,June 23, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SAND\_BAR-PLATSBURG\_115\_PV20**

Mon 12/14/2020 to Thu 12/17/2020 **UPDATED** **by NYPA** **12/03/2020**  
 0700 Continuous 1300

Work scheduled by: NYPA

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**SCH-HQ\_CEDARS-NYISO\_LIMIT\_80**

Wed 12/16/2020 to Thu 12/17/2020  
 0700 Daily 2300

Work scheduled by: HQ

FWD  
 (Import)  
 SCH - HQ\_CEDARS **80 MW**  
 Impacts Total Transfer Capability 119 MW  
 TTC with All Lines In Service 199 MW

**ROCHESTR-PANNELL\_345\_RP1**

Thu 12/17/2020 to Thu 12/17/2020 **UPDATED** **by RGE** **12/15/2020**  
 0600 Continuous 0900

Work scheduled by: RGE

FWD  
 (Import)  
 DYSINGER EAST **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**HOMRC\_NY-MAINS\_NY\_345\_47**

Fri 12/18/2020 to Fri 12/18/2020 **CANCELLED** **by NYSEG** **12/18/2020**  
 0700 Continuous 1530

Work scheduled by: NYSEG

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**STONYRDG-HILLSIDE\_230\_72**

Fri 12/18/2020 to Fri 12/18/2020 **EXTENDED** **by NYSEG** **12/18/2020**  
 0700 Continuous 1900

Work scheduled by: NYSEG

FWD  
 (Import)  
 DYSINGER EAST **2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

**N.SCTLND-LEEDS\_345\_93**

Fri 12/18/2020 to Fri 12/18/2020 **UPDATED** **by NGRID** **12/17/2020**  
 0800 Continuous 1500

Work scheduled by: NGrid

FWD  
 (Import)  
 CENTRAL EAST - VC **2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

**W49TH\_ST\_345KV\_6**

Sat 12/19/2020 to Sat 12/19/2020 **UPDATED** **by CONED** **12/17/2020**  
 0130 Continuous 0159

Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,December 22, 2020 to Thursday ,June 23, 2022

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 6220MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_8**

FWD

Sat 12/19/2020 to Sat 12/19/2020 **UPDATED** **by CONED** **12/17/2020**  
 0130 Continuous 0159

Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**MAINESBG-WATRCURE\_345\_30**

FWD

Sat 12/19/2020 to Sun 12/20/2020 **CANCELLED** **by NYSEG** **12/20/2020**  
 0800 Daily 1530

Work scheduled by: NYSEG

SCH - PJ - NY **2300 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 2800 MW

**SHORE\_RD\_345\_138\_BK 2**

FWD

Sat 12/19/2020 to Sun 12/27/2020 **EXTENDED** **by LIPA** **12/20/2020**  
 1452 Continuous 2359

Work scheduled by: LI

CONED - LIPA **1350 MW**  
 Impacts Total Transfer Capability 150 MW  
 TTC with All Lines In Service 1500 MW

**HUDSONTP-W49TH\_ST\_345\_Y56**

FWD

Sun 12/20/2020 to Sun 12/27/2020 **UPDATED** **by CE** **12/17/2020**  
 0001 Continuous 0300

Work scheduled by: ConEd

SCH - PJM\_HTP **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_7**

FWD

Sun 12/20/2020 to Sun 12/27/2020 **UPDATED** **by CE** **12/17/2020**  
 0001 Continuous 0300

Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_8**

FWD

Sun 12/20/2020 to Sun 12/27/2020 **UPDATED** **by CE** **12/17/2020**  
 0001 Continuous 0300

Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**HOMRC\_NY-MAINS\_NY\_345\_47**

Sun 12/20/2020 to Sun 12/20/2020 **CANCELLED** **by NYSEG** **12/20/2020**  
 0700 Continuous 1530

Work scheduled by: NYSEG

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**NYISO TRANSFER LIMITATIONS**

Tuesday ,December 22, 2020 to Thursday ,June 23, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**STONYRDG-HILLSIDE\_230\_72**

FWD

Mon 12/21/2020 to Mon 12/21/2020 **EXTENDED** **by NYSEG** **12/18/2020**

(Import)

0700 Continuous 1800

DYSINGER EAST **2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYSEG

**HOMRC\_NY-MAINS\_NY\_345\_47**

Wed 12/23/2020 to Wed 12/23/2020

0700 Continuous 1530

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYSEG

**MOTHAVN-RAINEY\_\_\_345\_Q12**

FWD

Sat 12/26/2020 to Thu 12/31/2020 **CANCELLED** **by ConEd** **12/21/2020**

(Import)

0301 Continuous 0200

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**NRTH1385-NOR HBR\_\_138\_601**

FWD

REV

Tue 12/29/2020 to Tue 12/29/2020

0800 Continuous 1600

(Import) (Export)

SCH - NPX\_1385 **100 MW** **100 MW**

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

Work scheduled by: LI

**NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_602**

FWD

REV

Tue 12/29/2020 to Tue 12/29/2020

0800 1600

(Import) (Export)

SCH - NPX\_1385 **0 MW** **0 MW**

Impacts Total Transfer Capability 200 MW 200 MW

TTC with All Lines In Service 200 MW 200 MW

Work scheduled by:

**NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_603**

FWD

REV

Tue 12/29/2020 to Tue 12/29/2020

0800 1600

(Import) (Export)

SCH - NPX\_1385 **0 MW** **0 MW**

Impacts Total Transfer Capability 200 MW 200 MW

TTC with All Lines In Service 200 MW 200 MW

Work scheduled by:

**NRTH1385-NOR HBR\_\_138\_602**

FWD

REV

Tue 12/29/2020 to Tue 12/29/2020

0800 Continuous 1600

(Import) (Export)

SCH - NPX\_1385 **100 MW** **100 MW**

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

Work scheduled by: LI

**NYISO TRANSFER LIMITATIONS**

Tuesday ,December 22, 2020 to Thursday ,June 23, 2022

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 6220MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR\_\_138\_602 & NRTH1385-NOR HBR\_\_138\_603

Tue 12/29/2020 to Tue 12/29/2020  
 0800 1600

Work scheduled by:

FWD REV  
 (Import) (Export)  
 SCH - NPX\_1385 **0 MW 0 MW**  
 Impacts Total Transfer Capability 200 MW 200 MW  
 TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NOR HBR\_\_138\_603

Tue 12/29/2020 to Tue 12/29/2020  
 0800 Continuous 1600

Work scheduled by: LI

FWD REV  
 (Import) (Export)  
 SCH - NPX\_1385 **100 MW 100 MW**  
 Impacts Total Transfer Capability 100 MW 100 MW  
 TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NRTHPORT\_138\_NNC

Tue 12/29/2020 to Tue 12/29/2020  
 0800 Continuous 1600

Work scheduled by: LI

FWD REV  
 (Import) (Export)  
 SCH - NPX\_1385 **0 MW 0 MW**  
 Impacts Total Transfer Capability 200 MW 200 MW  
 TTC with All Lines In Service 200 MW 200 MW

OSWEGO\_\_-VOLNEY\_\_345\_12

Tue 12/29/2020 to Tue 12/29/2020  
 0800 Daily 1630

Work scheduled by: NGrid

FWD  
 (Import)  
 OSWEGO EXPORT **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

SPRNBK\_\_345KV\_RS3 & SPRNBK\_\_345KV\_RS4

Sun 01/03/2021 to Sun 01/03/2021  
 0001 0030

Work scheduled by:

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

SPRNBK\_\_345KV\_RS3 & SPRNBK\_\_345KV\_RS4

Mon 01/04/2021 to Mon 01/04/2021  
 0130 0200

Work scheduled by:

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

MOSES\_\_-ADIRNDCK\_230\_MAI

Mon 01/04/2021 to Sat 02/27/2021  
 0700 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,December 22, 2020 to Thursday ,June 23, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SHORE_RD_345_138_BK 2</b>					FWD
Wed 01/06/2021	to	Wed 01/13/2021	<u>UPDATED</u>	<u>by CONED</u> <u>11/25/2020</u>	(Import)
0001	Continuous	2359			CONED - LIPA <b>1350 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service 1500 MW
<b>PLSNTVLY-WOOD_ST__345_F30</b>					FWD
Sat 01/09/2021	to	Mon 01/11/2021			(Import)
0001	Continuous	0200			UPNY CONED <b>4000 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 2220 MW
					TTC with All Lines In Service 6220 MW
<b>PLSNTVLY_345KV_RNS5</b>					FWD
Sat 01/09/2021	to	Mon 01/11/2021			(Import)
0001	Continuous	0200			UPNY CONED <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 2420 MW
					TTC with All Lines In Service 6220 MW
<b>LADENTWN-BUCHAN_S_345_Y88</b>					FWD
Mon 01/18/2021	to	Fri 03/05/2021	<u>UPDATED</u>	<u>by CE</u> <u>11/10/2020</u>	(Import)
0300	Continuous	0300			UPNY CONED <b>5930 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 290 MW
					TTC with All Lines In Service 6220 MW
<b>SPRNBK_-TREMONT__345_X28</b>					FWD
Sat 01/23/2021	to	Sun 01/24/2021			(Import)
0301	Continuous	0200			SPR/DUN-SOUTH <b>4200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 400 MW
					TTC with All Lines In Service 4600 MW
<b>MOTTHAVN-RAINEY__345_Q12</b>					FWD
Mon 01/25/2021	to	Sat 02/13/2021	<u>UPDATED</u>	<u>by CONED</u> <u>12/22/2020</u>	(Import)
0001	Continuous	0200			SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>W49TH_ST_345KV_8</b>					FWD
Sat 01/30/2021	to	Thu 03/11/2021			(Import)
0001	Continuous	0200			SCH - PJM_HTP <b>300 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service 660 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,December 22, 2020 to Thursday ,June 23, 2022

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 6220MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PORTER\_\_-ROTTRDAM\_230\_31**

FWD

Mon 02/01/2021 to Sat 02/27/2021

(Import)

0600 Continuous 1830

CENTRAL EAST - VC

**2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**RAMAPO\_\_345\_345\_PAR3500**

FWD

REV

Mon 02/08/2021 to Mon 02/15/2021

**UPDATED****by CONED 12/09/2020**

(Import) (Export)

0001 Continuous 0200

SCH - PJ - NY

**2350 MW 1250 MW**

Impacts Total Transfer Capability 450 MW 700 MW

TTC with All Lines In Service 2800 MW 1950 MW

Work scheduled by: ConEd

**RAMAPO\_\_345\_345\_PAR4500**

FWD

REV

Mon 02/08/2021 to Mon 02/15/2021

**UPDATED****by CONED 12/09/2020**

(Import) (Export)

0001 Continuous 0200

SCH - PJ - NY

**2350 MW 1250 MW**

Impacts Total Transfer Capability 450 MW 700 MW

TTC with All Lines In Service 2800 MW 1950 MW

Work scheduled by: ConEd

**RAMAPO\_\_500\_345\_BK 1500**

FWD

REV

Mon 02/08/2021 to Mon 02/15/2021

**UPDATED****by CONED 12/09/2020**

(Import) (Export)

0001 Continuous 0200

SCH - PJ - NY

**1450 MW 1200 MW**

Impacts Total Transfer Capability 1350 MW 750 MW

TTC with All Lines In Service 2800 MW 1950 MW

Work scheduled by: ConEd

**RAMAPO\_\_500\_345\_BK 1500**

FWD

Mon 02/08/2021 to Mon 02/15/2021

**UPDATED****by CONED 12/09/2020**

(Import)

0001 Continuous 0200

UPNY CONED

**6025 MW**

Impacts Total Transfer Capability 195 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

**HOPATCON-RAMAPO\_\_500\_5018**

FWD

REV

Mon 02/08/2021 to Mon 02/15/2021

**UPDATED****by CONED 12/09/2020**

(Import) (Export)

0001 Continuous 1900

SCH - PJ - NY

**1450 MW 1200 MW**

Impacts Total Transfer Capability 1350 MW 750 MW

TTC with All Lines In Service 2800 MW 1950 MW

Work scheduled by: ConEd

**HOPATCON-RAMAPO\_\_500\_5018**

FWD

Mon 02/08/2021 to Mon 02/15/2021

**UPDATED****by CONED 12/09/2020**

(Import)

0001 Continuous 1900

UPNY CONED

**6025 MW**

Impacts Total Transfer Capability 195 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd



CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**E13THSTA-FARRAGUT\_345\_46**

FWD

Tue 02/16/2021 to Wed 02/17/2021 **UPDATED by CONED 12/21/2020**

(Import)

0001 Continuous 2100

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**W49TH\_ST\_345KV\_6**

FWD

Wed 02/17/2021 to Wed 02/17/2021

(Import)

0001 Continuous 0030

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**BERKSHIR-ALPS\_\_\_\_345\_393**

FWD

REV

Wed 02/17/2021 to Fri 02/19/2021

(Import) (Export)

0730 Continuous 1600

SCH - NE - NY

**1100 MW 1700 MW**

Impacts Total Transfer Capability 300 MW 0 MW

TTC with All Lines In Service 1400 MW 1700 MW

Work scheduled by: NGrid

**ARR: 78****BERKSHIR-ALPS\_\_\_\_345\_393**

FWD

REV

Wed 02/17/2021 to Fri 02/19/2021

(Import) (Export)

0730 Continuous 1600

SCH - NPX\_1385

**100 MW 100 MW**

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

Work scheduled by: NGrid

**ARR: 78****SAND\_BAR-PLATSBURG\_115\_PV20**

Mon 02/22/2021 to Fri 02/26/2021

0600 Daily 1800

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: ISONE

**CHATGUAY-MASSENA\_\_765\_7040**

FWD

Sun 02/28/2021 to Mon 03/01/2021

(Import)

0500 Continuous 1730

MOSES SOUTH

**1550 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**CHATGUAY-MASSENA\_\_765\_7040**

FWD

REV

Sun 02/28/2021 to Mon 03/01/2021

(Import) (Export)

0500 Continuous 1730

SCH - HQ - NY

**0 MW 0 MW**

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by: NYPA

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 6220MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MASSENA\_-MARC\_ 765\_MSU1**

Sun 02/28/2021 to Mon 03/01/2021

0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC

**2265 MW**

Impacts Total Transfer Capability 710 MW

TTC with All Lines In Service 2975 MW

**MASSENA\_-MARC\_ 765\_MSU1**

Sun 02/28/2021 to Mon 03/01/2021

0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

**500 MW**

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

**MASSENA\_-MARC\_ 765\_MSU1**

Sun 02/28/2021 to Mon 03/01/2021

0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import) (Export)

SCH - HQ - NY

**475 MW 1000 MW**

Impacts Total Transfer Capability 1025 MW 0 MW

TTC with All Lines In Service 1500 MW 1000 MW

**MASSENA\_-MARC\_ 765\_MSU1**

Sun 02/28/2021 to Mon 03/01/2021

0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

SCH - HQ\_CEDARS

**90 MW**

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

**MASSENA\_-MARC\_ 765\_MSU1 & CHATGUAY-MASSENA\_ 765\_7040**

Sun 02/28/2021 to Mon 03/01/2021

0500 1730

Work scheduled by:

FWD

(Import)

MOSES SOUTH

**500 MW**

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

**STLAWRNC-MOSES\_ 230\_L33P & MASSENA\_-MARC\_ 765\_MSU1**

Sun 02/28/2021 to Mon 03/01/2021

0500 1730

Work scheduled by:

FWD

(Import)

SCH - HQ\_CEDARS

**90 MW**

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

**MOTTHAVN-RAINEY\_ 345\_Q11**

Mon 03/01/2021 to Tue 04/06/2021

0001 Continuous 0700

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,December 22, 2020 to Thursday ,June 23, 2022

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 6220MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>BERKSHIR-ALPS_____345_393</b>							
Mon 03/01/2021	to	Sat 03/20/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>12/14/2020</u>		
0700	Continuous	1600				<b>1100 MW</b>	<b>1700 MW</b>
Work scheduled by: NGrid							
						<b>ARR: 78</b>	
						SCH - NE - NY	
						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	1400 MW
<b>BERKSHIR-ALPS_____345_393</b>							
Mon 03/01/2021	to	Sat 03/20/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>12/14/2020</u>		
0700	Continuous	1600				<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: NGrid							
						<b>ARR: 78</b>	
						SCH - NPX_1385	
						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
<b>SCH-NYISO-NE_LIMIT_900</b>							
Mon 03/01/2021	to	Sat 03/20/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>12/14/2020</u>		
0700	Continuous	1600					
Work scheduled by: NGrid							
							<b>REV</b>
							(Export)
						SCH - NE - NY	
						Impacts Total Transfer Capability	600 MW
						TTC with All Lines In Service	1700 MW
<b>EDIC____-N.SCTLND_345_14</b>							
Tue 03/02/2021	to	Mon 05/31/2021					
0600	Continuous	1830					
Work scheduled by: NGrid							
							<b>FWD</b>
							(Import)
						CENTRAL EAST - VC	
						Impacts Total Transfer Capability	735 MW
						TTC with All Lines In Service	2975 MW
<b>PORTER__-ROTTRDAM_230_31</b>							
Tue 03/02/2021	to	Mon 05/31/2021					
0600	Continuous	1830					
Work scheduled by: NGrid							
							<b>FWD</b>
							(Import)
						CENTRAL EAST - VC	
						Impacts Total Transfer Capability	170 MW
						TTC with All Lines In Service	2975 MW
<b>MOSES____-ADIRNDCK_230_MAI</b>							
Tue 03/02/2021	to	Mon 05/31/2021					
0700	Continuous	1300					
Work scheduled by: NYPA							
							<b>FWD</b>
							(Import)
						MOSES SOUTH	
						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
<b>HUDSONTP-W49TH_ST_345_Y56</b>							
Sat 03/06/2021	to	Tue 03/09/2021					
0001	Continuous	0200					
Work scheduled by: ConEd							
							<b>FWD</b>
							(Import)
						SCH - PJM_HTP	
						Impacts Total Transfer Capability	660 MW
						TTC with All Lines In Service	660 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 22, 2020 to Thursday ,June 23, 2022

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_6

Sat 03/06/2021 to Tue 03/09/2021  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

### W49TH\_ST\_345KV\_7

Sat 03/06/2021 to Tue 03/09/2021  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

### ELBRIDGE-LAFAYTTE\_345\_17-LE

Tue 03/09/2021 to Tue 03/09/2021  
0800 Daily(No Weekends) 1630  
Work scheduled by: NGrid

ARR: 75

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

### NIAGARA\_-ROBNSNRD\_230\_64

Fri 03/12/2021 to Fri 03/12/2021  
0500 Continuous 1700  
Work scheduled by: NYPA

REV  
(Export)  
SCH - OH - NY **1900 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 2000 MW

### MARCY\_\_\_\_345KV\_CSC

Sat 03/13/2021 to Sat 03/13/2021 **UPDATED by NYPA 07/29/2020**  
0700 Continuous 1730  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

### W49TH\_ST\_345KV\_6

Tue 03/16/2021 to Tue 03/16/2021  
0230 Continuous 0300  
Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

### W49TH\_ST\_345KV\_8

Tue 03/16/2021 to Tue 03/16/2021  
0230 Continuous 0300  
Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 22, 2020 to Thursday ,June 23, 2022

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_5

FWD

Fri 03/26/2021 to Wed 05/05/2021 UPDATED by CONED 10/06/2020

(Import)

0001 Continuous 0300

SCH - PJM\_HTP

300 MW

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

### CLAY -EDIC 345\_2-15

FWD

Mon 03/29/2021 to Fri 04/16/2021 09/12/2020

(Import)

0800 Continuous 1730

OSWEGO EXPORT

4850 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

### BRANCHBG-HOPATCON\_500\_5060

FWD

Wed 03/31/2021 to Wed 03/31/2021 UPDATED by PJM 11/30/2020

(Import)

0200 Continuous 1500

UPNY CONED

6025 MW

Impacts Total Transfer Capability 195 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: PJM

### ROCHESTR-PANNELL 345\_RP2

FWD

Wed 03/31/2021 to Mon 04/12/2021

(Import)

0500 Continuous 1700

DYSINGER EAST

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

### SPRNBK 345KV\_RNS3

FWD

Thu 04/01/2021 to Thu 04/01/2021 UPDATED by CONED 12/16/2020

(Import)

0001 Continuous 0030

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### EASTVIEW-SPRNBK 345\_W78

FWD

Thu 04/01/2021 to Thu 04/01/2021 UPDATED by CONED 12/16/2020

(Import)

0001 Continuous 1830

UPNY CONED

4350 MW

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

### MILLWOOD-EASTVIEW\_345\_W85

FWD

Thu 04/01/2021 to Thu 04/01/2021 UPDATED by CONED 12/16/2020

(Import)

0001 Continuous 1830

UPNY CONED

5985 MW

Impacts Total Transfer Capability 235 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SPRNBK\_\_345KV\_RNS3**

FWD

Thu 04/01/2021 to Thu 04/01/2021 **UPDATED by CONED 12/16/2020**

(Import)

1800 Continuous 1830

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**LINDN\_CG-LNDVFT\_\_345\_V-3022**

FWD

REV

Sun 04/04/2021 to Sat 04/10/2021

(Import) (Export)

1400 Continuous 1400

Work scheduled by: PJM

SCH - PJM\_VFT

**0 MW****0 MW**

Impacts Total Transfer Capability 315 MW 315 MW

TTC with All Lines In Service 315 MW 315 MW

**NIAGARA\_-STA\_255\_\_345\_NH2**

FWD

Fri 04/16/2021 to Fri 04/16/2021

(Import)

0500 Continuous 1700

Work scheduled by: NYPA

DYSINGER EAST

**2350 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 3150 MW

**KINTIGH\_-STA\_255\_\_345\_SH1-39**

FWD

Mon 04/26/2021 to Fri 04/30/2021

(Import)

0700 Continuous 1700

Work scheduled by: NYPA

DYSINGER EAST

**2350 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 3150 MW

**NIAGARA\_-KINTIGH\_\_345\_NS1-38**

FWD

Mon 04/26/2021 to Fri 04/30/2021

(Import)

0700 Continuous 1700

Work scheduled by: NYPA

DYSINGER EAST

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

**PLSNTVLY-WOOD\_ST\_\_345\_F31**

FWD

Tue 04/27/2021 to Wed 04/28/2021

(Import)

0001 Continuous 0159

Work scheduled by: ConEd

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

**PLSNTVLY\_345KV\_RNS4**

FWD

Tue 04/27/2021 to Wed 04/28/2021

(Import)

0001 Continuous 0159

Work scheduled by: ConEd

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,December 22, 2020 to Thursday ,June 23, 2022

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 6220MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SPRNBK\_\_345KV\_RNS4**

FWD

Sat 05/01/2021 to Sat 05/01/2021 UPDATED by CONED 10/06/2020

(Import)

0001 Continuous 0030

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**SPRNBK\_-W49TH\_ST\_345\_M52**

FWD

Sat 05/01/2021 to Tue 05/04/2021 UPDATED by CONED 10/06/2020

(Import)

0001 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**W49TH\_ST\_345KV\_7**

FWD

Sat 05/01/2021 to Tue 05/04/2021 UPDATED by CONED 10/06/2020

(Import)

0001 Continuous 0300

Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**SCH-IMO-NYISO\_LIMIT\_1600**

FWD

Sat 05/01/2021 to Sun 10/31/2021 UPDATED by IESO 05/03/2019

(Import)

0001 Continuous 2359

Work scheduled by: IESO

SCH - OH - NY **1900 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 1950 MW

**CLAY\_\_\_\_-EDIC\_\_\_\_345\_2-15**

FWD

Mon 05/03/2021 to Fri 05/07/2021

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

OSWEGO EXPORT **4850 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 5250 MW

**PANNELL\_-CLAY\_\_\_\_345\_2**

FWD

Mon 05/03/2021 to Sun 05/30/2021

(Import)

0700 Continuous 1730

Work scheduled by: NYPA

WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

**HURLYAVE-ROSETON\_\_345\_303**

FWD

Mon 05/03/2021 to Fri 05/21/2021

(Import)

0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 2120 MW  
 TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 22, 2020 to Thursday ,June 23, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 05/03/2021 to Fri 05/07/2021  
0900 Continuous 1500

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

## SPRNBRK\_345KV\_RNS4

Tue 05/04/2021 to Tue 05/04/2021  
0230 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 10/06/2020

	FWD
	(Import)
SPR/DUN-SOUTH	<b>3200 MW</b>
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

## CLAY\_-EDIC\_345\_1-16

Mon 05/10/2021 to Fri 05/14/2021  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
OSWEGO EXPORT	<b>4850 MW</b>
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	5250 MW

## NIAGARA\_-STA\_255\_345\_NH2

Mon 05/24/2021 to Fri 05/28/2021  
0500 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>2350 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	3150 MW

## VOLNEY\_-MARC\_345\_19

Tue 06/01/2021 to Wed 06/02/2021  
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
CENTRAL EAST - VC	<b>2825 MW</b>
Impacts Total Transfer Capability	150 MW
TTC with All Lines In Service	2975 MW

## VOLNEY\_-MARC\_345\_19

Tue 06/01/2021 to Wed 06/02/2021  
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
OSWEGO EXPORT	<b>4900 MW</b>
Impacts Total Transfer Capability	350 MW
TTC with All Lines In Service	5250 MW

## FRASER\_-GILBOA\_345\_GF5-35

Tue 06/01/2021 to Mon 06/07/2021  
0700 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2650 MW</b>
Impacts Total Transfer Capability	325 MW
TTC with All Lines In Service	2975 MW



CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Tue 06/01/2021 to Sun 11/14/2021

(Import)

0700 Continuous 1300

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**PORTER\_\_\_-ROTTDAM\_230\_30**

FWD

Thu 06/03/2021 to Wed 09/15/2021

(Import)

0600 Continuous 0559

CENTRAL EAST - VC

**2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**MARCY\_\_\_-EDIC\_\_\_345\_UE1-7**

FWD

Thu 06/03/2021 to Fri 06/04/2021

(Import)

0700 Continuous 1730

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19&16****MARCY\_\_\_345KV\_CSC**

FWD

Sat 06/05/2021 to Sat 06/05/2021

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

**2925 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**FRASANNX-COOPERS\_\_\_345\_UCC2-41**

FWD

Fri 06/25/2021 to Tue 08/10/2021

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 19****MARCY\_\_\_-FRASANNX\_345\_UCC2-41**

FWD

Fri 06/25/2021 to Tue 08/10/2021

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 19****NIAGARA\_\_\_345\_230\_AT4**

FWD

REV

Mon 07/12/2021 to Fri 07/23/2021

(Import) (Export)

0500 Continuous 1700

SCH - OH - NY

**1900 MW 1400 MW**

Impacts Total Transfer Capability 50 MW 300 MW

TTC with All Lines In Service 1950 MW 1700 MW

Work scheduled by: NYPA

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SAND\_BAR-PLATSBURG\_115\_PV20

Tue 08/03/2021 to Tue 08/03/2021  
0700 Continuous 1830  
Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## FRASANNX-COOPERS\_\_345\_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021  
0700 Continuous 1730  
Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

## MARCY\_\_-FRASANNX\_345\_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021  
0700 Continuous 1730  
Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

## KINTIGH\_-STA\_255\_\_345\_SH1-39

Mon 09/13/2021 to Fri 09/17/2021  
0500 Continuous 1700  
Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2350 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 3150 MW

## NIAGARA\_-KINTIGH\_\_345\_NS1-38

Mon 09/13/2021 to Fri 09/17/2021  
0500 Continuous 1700  
Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

## PORTER\_\_-ROTTRDAM\_230\_30

Wed 09/15/2021 to Tue 11/30/2021  
0600 Continuous 1830  
Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2805 MW**  
Impacts Total Transfer Capability 170 MW  
TTC with All Lines In Service 2975 MW

## EDIC\_\_-N.SCTLND\_345\_14

Thu 09/16/2021 to Sun 11/14/2021  
0600 Continuous 1830  
Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2240 MW**  
Impacts Total Transfer Capability 735 MW  
TTC with All Lines In Service 2975 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HURLYAVE-ROSETON\_\_345\_303

FWD

Thu 09/16/2021 to Sun 10/17/2021

UPDATEDby CHGE09/22/2020

(Import)

0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 2120 MW

TTC with All Lines In Service 6220 MW

## PANNELL\_-CLAY\_\_\_\_345\_1

FWD

Mon 09/20/2021 to Fri 09/24/2021

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

## CLAY\_\_\_\_-EDIC\_\_\_\_345\_2-15

FWD

Mon 09/20/2021 to Sat 10/16/2021

(Import)

0700 Continuous 1730

Work scheduled by: NYPA

OSWEGO EXPORT

**4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

## PANNELL\_-CLAY\_\_\_\_345\_2

FWD

Mon 09/27/2021 to Fri 10/01/2021

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

## W49TH\_ST\_345KV\_6

FWD

Tue 09/28/2021 to Tue 09/28/2021

(Import)

0100 Continuous 0130

Work scheduled by: ConEd

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

## E13THSTA-FARRAGUT\_345\_46

FWD

Tue 09/28/2021 to Tue 10/26/2021

(Import)

0100 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

## W49TH\_ST-E13THSTA\_345\_M55

FWD

Tue 09/28/2021 to Tue 10/26/2021

(Import)

0100 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 22, 2020 to Thursday ,June 23, 2022

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LEEDS\_\_\_-HURLYAVE\_345\_301

Mon 10/18/2021 to Fri 11/19/2021  
0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 2120 MW  
TTC with All Lines In Service 6220 MW

### W49TH\_ST\_345KV\_6

Tue 10/26/2021 to Tue 10/26/2021  
0230 Continuous 0300

Work scheduled by: ConEd

FWD

(Import)

SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

### SCH-IMO-NYISO\_LIMIT\_1750

Mon 11/01/2021 to Fri 12/31/2021  
0001 Continuous 2359

Work scheduled by: IESO

UPDATED by IESO 05/03/2019

FWD

(Import)

SCH - OH - NY **2050 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 2300 MW

### SCH-NYISO-IMO\_LIMIT\_1600

Mon 11/01/2021 to Fri 12/31/2021  
0001 Continuous 2359

Work scheduled by: IESO

UPDATED by IESO 05/03/2019

REV

(Export)

SCH - OH - NY **1900 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 2000 MW

### FRASER\_\_\_345\_FRASER SVC

Wed 12/01/2021 to Mon 02/28/2022  
0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2935 MW**  
Impacts Total Transfer Capability 40 MW  
TTC with All Lines In Service 2975 MW

### MOSES\_\_\_-ADIRNDCK\_230\_MAI

Wed 12/01/2021 to Tue 05/31/2022  
0700 Continuous 1300

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### N.SCTLND-ALPS\_\_\_\_\_345\_2

Mon 05/02/2022 to Mon 05/09/2022  
0600 Daily 1800

Work scheduled by: NGrid

FWD

(Import)

SCH - NE - NY **750 MW**  
Impacts Total Transfer Capability 650 MW  
TTC with All Lines In Service 1400 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 22, 2020 to Thursday ,June 23, 2022

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### N.SCTLND-ALPS\_\_\_\_\_345\_2

Mon 05/02/2022 to Mon 05/09/2022

0600 Daily 1800

Work scheduled by: NGrid

FWD REV  
(Import) (Export)

SCH - NPX\_1385 100 MW 100 MW  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

### HOMRC\_NY-MAINS\_NY\_345\_47

Fri 05/20/2022 to Fri 05/27/2022

0800 Continuous 1600

Work scheduled by: PJM

UPDATED by PJM 11/19/2020

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### HOMR\_NYW-PIERC\_NY\_345\_48

Fri 05/20/2022 to Fri 05/27/2022

0800 Continuous 1600

Work scheduled by: PJM

UPDATED by PJM 11/19/2020

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Wed 06/01/2022 to Mon 11/14/2022

0700 Continuous 1300

Work scheduled by: NYPA

FWD  
(Import)

MOSES SOUTH 2100 MW  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW