

NYISO TRANSFER LIMITATIONS

Sunday ,December 06, 2020 to Tuesday ,June 07, 2022

CENTRAL EAST 3100MW
 CENTRAL EAST - VC 2975MW
 TOTAL EAST 6500MW
 UPNY CONED 6220MW
 SPR/DUN-SOUTH 4600MW
 DYSINGER EAST 3150MW
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Sun 02/28/2021 EXT FORCE by CONED 08/28/2020

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Sun 02/28/2021

0001 2359

Work scheduled by:

FWD REV

(Import) (Export)

SCH - PJ - NY

2550 MW 1600 MW

Impacts Total Transfer Capability 250 MW 350 MW

TTC with All Lines In Service 2800 MW 1950 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Sun 02/28/2021 EXT FORCE by CONED 08/28/2020

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

STLAWRNC-MOSES_230_L33P

Mon 04/30/2018 to Mon 10/31/2022 EXT FORCE by IESO 10/01/2020

0456 Continuous 1600

Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

BECK_-NIAGARA_230_PA27

Mon 08/31/2020 to Thu 12/03/2020 EXTENDED by IESO 11/25/2020

0700 Continuous 1700

Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

NEWBRDGE_345_138_BK_1

Wed 09/02/2020 to Thu 12/31/2020 EXT FORCE by LI 09/03/2020

1807 Continuous 2359

Work scheduled by: LI

FWD

(Import)

SCH - PJM_NEPTUNE

375 MW

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

SPRNBK_-EGRDNCTR_345_Y49

Thu 10/01/2020 to Sat 12/19/2020 EXTENDED by LI 12/05/2020

0404 Continuous 2100

Work scheduled by: LI

FWD

(Import)

CONED - LIPA

775 MW

Impacts Total Transfer Capability 725 MW

TTC with All Lines In Service 1500 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 06, 2020 to Tuesday ,June 07, 2022

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EGRDNCTY_345_138_AT2

Sat 10/10/2020 to Sat 12/19/2020 EXTENDED by LI 12/05/2020
 1815 Continuous 2100
 Work scheduled by: LI

FWD
 (Import)
 CONED - LIPA **1250 MW**
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 1500 MW

EGRDNCTY_345_138_AT1

Sat 10/10/2020 to Sat 12/19/2020 EXTENDED by LI 12/05/2020
 1856 Continuous 2100
 Work scheduled by: LI

FWD
 (Import)
 CONED - LIPA **1250 MW**
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 1500 MW

KINTIGH_-STA_255_345_SH1-39

Tue 10/20/2020 to Tue 12/15/2020 UPDATED by NYISO 11/04/2020
 1134 Continuous 2359
 Work scheduled by: NYISO

FWD
 (Import)
 DYSINGER EAST **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

LEEDS_-HURLYAVE_345_301

Mon 10/26/2020 to Fri 12/11/2020 EXTENDED by CHGE 11/24/2020
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 2120 MW
 TTC with All Lines In Service 6220 MW

SCH-IMO-NYISO_LIMIT_1750

Sun 11/01/2020 to Fri 04/30/2021 UPDATED by IESO 05/03/2019
 0001 Continuous 2359
 Work scheduled by: IESO

FWD
 (Import)
 SCH - OH - NY **2050 MW**
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 2300 MW

SCH-NYISO-IMO_LIMIT_1600

Sun 11/01/2020 to Fri 04/30/2021 UPDATED by IESO 05/03/2019
 0001 Continuous 2359
 Work scheduled by: IESO

REV
 (Export)
 SCH - OH - NY **1900 MW**
 Impacts Total Transfer Capability 100 MW
 TTC with All Lines In Service 2000 MW

STA_255_-ROCHESTR_345_HR-1

Tue 11/03/2020 to Sun 12/20/2020 UPDATED by NYISO 11/04/2020
 1146 Continuous 2359
 Work scheduled by: NYISO

DYSINGER EAST
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Sunday ,December 06, 2020 to Tuesday ,June 07, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | |
|--------------------------------------|------------|----------------|-------------------------|------------------------|-----------------------------------|-------------------|
| SHOR_NPX-SHOREHAM_138_CSC | | | | | FWD | REV |
| Sun 11/08/2020 | to | Fri 12/18/2020 | <u>EXT FORCE</u> | <u>by ISONE</u> | <u>11/25/2020</u> | (Import) (Export) |
| 1341 | Continuous | 2359 | | | | |
| Work scheduled by: LI | | | | | SCH - NPX_CSC | 0 MW |
| | | | | | Impacts Total Transfer Capability | 330 MW |
| | | | | | TTC with All Lines In Service | 330 MW |
| MARCY_765_345_AT2 | | | | | FWD | |
| Sun 11/15/2020 | to | Wed 12/02/2020 | <u>EXTENDED</u> | <u>by NYPA</u> | <u>11/30/2020</u> | (Import) |
| 0100 | Continuous | 2359 | | | | |
| Work scheduled by: NYPA | | | | | MOSES SOUTH | 1700 MW |
| | | | | | Impacts Total Transfer Capability | 1450 MW |
| | | | | | TTC with All Lines In Service | 3150 MW |
| MOTTHAVN-RAINEY_345_Q12 | | | | | FWD | |
| Mon 11/30/2020 | to | Sat 12/05/2020 | <u>CANCELLED</u> | <u>by ConEd</u> | <u>12/01/2020</u> | (Import) |
| 0301 | Continuous | 0159 | | | | |
| Work scheduled by: ConEd | | | | | SPR/DUN-SOUTH | 3800 MW |
| | | | | | Impacts Total Transfer Capability | 800 MW |
| | | | | | TTC with All Lines In Service | 4600 MW |
| SCH-IMO-NYISO_LIMIT_600 | | | | | FWD | |
| Mon 11/30/2020 | to | Thu 12/03/2020 | | | | (Import) |
| 0700 | Continuous | 1700 | | | | |
| Work scheduled by: IESO | | | | | SCH - OH - NY | 900 MW |
| | | | | | Impacts Total Transfer Capability | 1400 MW |
| | | | | | TTC with All Lines In Service | 2300 MW |
| SCH-NYISO-IMO_LIMIT_900 | | | | | | REV |
| Mon 11/30/2020 | to | Thu 12/03/2020 | | | | (Export) |
| 0700 | Continuous | 1700 | | | | |
| Work scheduled by: IESO | | | | | SCH - OH - NY | 1200 MW |
| | | | | | Impacts Total Transfer Capability | 800 MW |
| | | | | | TTC with All Lines In Service | 2000 MW |
| DOLSONAV-ROCKTVRN_345_DART44 | | | | | FWD | |
| Mon 11/30/2020 | to | Mon 12/14/2020 | <u>UPDATED</u> | <u>by NYPA</u> | <u>11/12/2020</u> | (Import) |
| 0700 | Continuous | 1730 | | | | |
| Work scheduled by: NYPA | | | | | CENTRAL EAST - VC | 2720 MW |
| | | | | | Impacts Total Transfer Capability | 255 MW |
| | | | | | TTC with All Lines In Service | 2975 MW |
| NEPTUNE_-DUFFYAVE_345_NEPTUNE | | | | | FWD | |
| Mon 11/30/2020 | to | Fri 12/04/2020 | <u>UPDATED</u> | <u>by LI</u> | <u>12/05/2020</u> | (Import) |
| 1800 | Continuous | 1749 | | | | |
| Work scheduled by: PJM | | | | | SCH - PJM_NEPTUNE | 0 MW |
| | | | | | Impacts Total Transfer Capability | 660 MW |
| | | | | | TTC with All Lines In Service | 660 MW |

NYISO TRANSFER LIMITATIONS

Sunday ,December 06, 2020 to Tuesday ,June 07, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRIDGE-DUFFYAVE_345_501

FWD

Mon 11/30/2020 to Fri 12/04/2020 UPDATED by LI 12/05/2020

(Import)

1800 Continuous 1749

Work scheduled by: PJM

SCH - PJM_NEPTUNE

0 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

PLSNTVLE-DUNWODIE_345_W89

FWD

Mon 11/30/2020 to Wed 12/09/2020 FORCED by CONED 12/01/2020

(Import)

1840 Continuous 2359

Work scheduled by: ConEd

UPNY CONED

4000 MW

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

MARCY___345KV_CSC

FWD

Tue 12/01/2020 to Fri 12/11/2020 UPDATED by NYPA 12/01/2020

(Import)

0700 Continuous 1730

Work scheduled by: NYPA

CENTRAL EAST - VC

2925 MW

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

LAFAYTTE-CLRKSCRN_345_4-46

FWD

Tue 12/01/2020 to Tue 12/01/2020 UPDATED by NGRID 11/17/2020

(Import)

0730 Daily(No Weekends) 1230

Work scheduled by: NGrid

CENTRAL EAST - VC

2650 MW

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

DUNWODIE_345KV_3

FWD

Tue 12/01/2020 to Wed 12/02/2020 FORCED by CONED 12/01/2020

(Import)

0800 Continuous 0014

Work scheduled by: ConEd

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_4

FWD

Tue 12/01/2020 to Wed 12/02/2020 FORCED by CONED 12/01/2020

(Import)

0800 Continuous 0014

Work scheduled by: ConEd

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

MOSES___-ADIRNDCK_230_MAI

FWD

Thu 12/03/2020 to Wed 12/23/2020 UPDATED by NYPA 11/30/2020

(Import)

0700 Continuous 1400

Work scheduled by: NYPA

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 06, 2020 to Tuesday ,June 07, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-KINTIGH_345_NS1-38

FWD

 Thu 12/03/2020 to Tue 12/15/2020
 0800 Continuous 2359
UPDATEDby NYSEG12/03/2020

Work scheduled by: RGE

 DYSINGER EAST **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

NEWBRIDGE_345_138_BK_2

FWD

 Fri 12/04/2020 to Fri 12/04/2020
 0001 Daily 2359

Work scheduled by: LI

 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

BECK_-PACKARD_230_BP76

FWD

REV

 Fri 12/04/2020 to Fri 12/04/2020
 0730 Daily(No Weekends) 1530
UPDATEDby IESO12/01/2020

Work scheduled by: NGrid

 (Import) (Export)
 SCH - OH - NY **1750 MW 1400 MW**
 Impacts Total Transfer Capability 550 MW 600 MW
 TTC with All Lines In Service 2300 MW 2000 MW

SCH-IMO-NYISO_LIMIT_1150

FWD

 Fri 12/04/2020 to Fri 12/04/2020
 0730 Daily(No Weekends) 1530
UPDATEDby IESO12/01/2020

Work scheduled by: NGrid

 (Import)
 SCH - OH - NY **1450 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 2300 MW

SPRNBK_-W49TH_ST_345_M52

FWD

 Sat 12/05/2020 to Sun 12/06/2020
 0201 Continuous 0200
CANCELLEDby ConEd12/01/2020

Work scheduled by: ConEd

 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

W49TH_ST_345KV_5

FWD

 Sat 12/05/2020 to Sun 12/06/2020
 0201 Continuous 0200
CANCELLEDby ConEd12/01/2020

Work scheduled by: ConEd

 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

CHAT_DC_GC1

FWD

 Sat 12/05/2020 to Sun 12/06/2020
 2200 Continuous 0800

Work scheduled by: HQ

 (Import)
 MOSES SOUTH **2850 MW**
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 06, 2020 to Tuesday ,June 07, 2022

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1

Sat 12/05/2020 to Sun 12/06/2020
2200 Continuous 0800

Work scheduled by: HQ

REV
(Export)
SCH - HQ - NY **500 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1000 MW

OSWEGO_COMPLEX_AVR_O/S

Sun 12/06/2020 to Sun 12/06/2020
0900 Continuous 0930

Work scheduled by: Gen

CANCELLED by Gen 12/06/2020

FWD
(Import)
CENTRAL EAST - VC **2870 MW**
Impacts Total Transfer Capability 105 MW
TTC with All Lines In Service 2975 MW

MOTTHAVN-RAINEY___345_Q12

Tue 12/08/2020 to Mon 12/14/2020
0001 Continuous 0200

Work scheduled by: ConEd

CANCELLED by ConEd 12/05/2020

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

LONG_MTN-CRICKVLY_345_398

Tue 12/08/2020 to Thu 12/10/2020
0700 Continuous 1600

Work scheduled by: ISONE

UPDATED by ISONE 12/03/2020

FWD REV
(Import) (Export)
SCH - NE - NY **700 MW 1300 MW**
Impacts Total Transfer Capability 700 MW 400 MW
TTC with All Lines In Service 1400 MW 1700 MW

LONG_MTN-CRICKVLY_345_398

Tue 12/08/2020 to Thu 12/10/2020
0700 Continuous 1600

Work scheduled by: ISONE

UPDATED by ISONE 12/03/2020

FWD REV
(Import) (Export)
SCH - NPX_1385 **100 MW 100 MW**
Impacts Total Transfer Capability 100 MW 100 MW
TTC with All Lines In Service 200 MW 200 MW

SCH-NYISO-NE_LIMIT_800

Tue 12/08/2020 to Thu 12/10/2020
0700 Continuous 1600

Work scheduled by: ISONE

UPDATED by ISONE 12/03/2020

REV
(Export)
SCH - NE - NY **1000 MW**
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 1700 MW

SAND_BAR-PLATSBRG_115_PV20

Tue 12/08/2020 to Fri 12/11/2020
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 12/03/2020

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Sunday ,December 06, 2020 to Tuesday ,June 07, 2022

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 6220MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONTP-W49TH_ST_345_Y56

FWD

Thu 12/10/2020 to Wed 12/16/2020

UPDATEDby CE12/05/2020

(Import)

0001 Continuous 0300

Work scheduled by: ConEd

SCH - PJM_HTP

0 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7

FWD

Thu 12/10/2020 to Wed 12/16/2020

UPDATEDby CE12/05/2020

(Import)

0001 Continuous 0300

Work scheduled by: ConEd

SCH - PJM_HTP

300 MW

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

FWD

Thu 12/10/2020 to Wed 12/16/2020

UPDATEDby CE12/05/2020

(Import)

0001 Continuous 0300

Work scheduled by: ConEd

SCH - PJM_HTP

300 MW

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

ROCHESTR-PANNELL_345_RP1

FWD

Thu 12/10/2020 to Thu 12/10/2020

EXTENDEDby RGE12/04/2020

(Import)

0800 Continuous 1400

Work scheduled by: RGE

DYSINGER EAST

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

LEEDS_345KV_R94301

FWD

Fri 12/11/2020 to Fri 12/11/2020

EXTENDEDby CHGE11/24/2020

(Import)

1500 Continuous 1600

Work scheduled by: CHGE

UPNY CONED

3800 MW

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

DUNWODIE_345KV_6

FWD

Sat 12/12/2020 to Sat 12/12/2020

CANCELLEDby ConEd12/04/2020

(Import)

0001 Continuous 0030

Work scheduled by: ConEd

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

FWD

Sat 12/12/2020 to Sat 12/12/2020

CANCELLEDby ConEd12/04/2020

(Import)

0001 Continuous 0030

Work scheduled by: ConEd

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 06, 2020 to Tuesday ,June 07, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EFISHKIL-WOOD_ST__345_F38

FWD

Sat 12/12/2020 to Sat 12/12/2020

(Import)

0001 Continuous 0030

UPNY CONED

4000 MW

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

PLSNTVLE-DUNWODIE_345_W90

FWD

Sat 12/12/2020 to Sat 12/12/2020

(Import)

0001 Continuous 0030

CANCELLED by ConEd 12/04/2020

UPNY CONED

4000 MW

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

WOOD_ST_-PLSNTVLE_345_Y86

FWD

Sat 12/12/2020 to Sat 12/12/2020

(Import)

0001 Continuous 0030

UPNY CONED

5935 MW

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

WOOD_ST_-PLSNTVLE_345_Y87

FWD

Sat 12/12/2020 to Sat 12/12/2020

(Import)

0001 Continuous 0030

CANCELLED by ConEd 12/04/2020

UPNY CONED

5905 MW

Impacts Total Transfer Capability 315 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

DUNWODIE_345KV_6

FWD

Sat 12/12/2020 to Sat 12/12/2020

(Import)

1730 Continuous 1800

CANCELLED by ConEd 12/04/2020

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

DUNWODIE_345KV_8

FWD

Sat 12/12/2020 to Sat 12/12/2020

(Import)

1730 Continuous 1800

CANCELLED by ConEd 12/04/2020

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

PLSNTVLE-DUNWODIE_345_W90

FWD

Sat 12/12/2020 to Sat 12/12/2020

(Import)

1730 Continuous 1800

CANCELLED by ConEd 12/04/2020

UPNY CONED

4000 MW

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

NYISO TRANSFER LIMITATIONS

Sunday ,December 06, 2020 to Tuesday ,June 07, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD_ST_-PLSNTVLE_345_Y87

FWD

Sat 12/12/2020 to Sat 12/12/2020 **CANCELLED by ConEd 12/04/2020**

(Import)

1730 Continuous 1800

Work scheduled by: ConEd

UPNY CONED

5905 MW

Impacts Total Transfer Capability 315 MW

TTC with All Lines In Service 6220 MW

CHAT_DC_GC1

FWD

Sat 12/12/2020 to Sun 12/13/2020

(Import)

2000 Continuous 0500

Work scheduled by: HQ

MOSES SOUTH

2850 MW

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

CHAT_DC_GC1

REV

Sat 12/12/2020 to Sun 12/13/2020

(Export)

2000 Continuous 0500

Work scheduled by: HQ

SCH - HQ - NY

500 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1000 MW

CHAT_DC_GC1 & CHAT_DC_GC2

FWD

Sat 12/12/2020 to Sun 12/13/2020

(Import)

2000 0500

Work scheduled by:

MOSES SOUTH

2550 MW

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 3150 MW

CHAT_DC_GC1 & CHAT_DC_GC2

FWD

REV

Sat 12/12/2020 to Sun 12/13/2020

(Import) (Export)

2000 0500

Work scheduled by:

SCH - HQ - NY

1370 MW 0 MW

Impacts Total Transfer Capability 130 MW

1000 MW

TTC with All Lines In Service

1500 MW

1000 MW

CHAT_DC_GC2

FWD

Sat 12/12/2020 to Sun 12/13/2020

(Import)

2000 Continuous 0500

Work scheduled by: HQ

MOSES SOUTH

2850 MW

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

CHAT_DC_GC2

REV

Sat 12/12/2020 to Sun 12/13/2020

(Export)

2000 Continuous 0500

Work scheduled by: HQ

SCH - HQ - NY

500 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1000 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 06, 2020 to Tuesday ,June 07, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ-NYISO_LIMIT_1150

Sat 12/12/2020 to Sun 12/13/2020
2000 Continuous 0500

Work scheduled by: HQ

FWD
(Import)
SCH - HQ - NY **1150 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 1500 MW

EFISHKIL-WOOD_ST_345_F38

Mon 12/14/2020 to Mon 12/14/2020
0230 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 2220 MW
TTC with All Lines In Service 6220 MW

WOOD_ST-PLSNTVLE_345_Y86

Mon 12/14/2020 to Mon 12/14/2020
0230 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **5935 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 6220 MW

ALCOA_PA_115KV_R8105

Mon 12/14/2020 to Wed 12/16/2020
0630 Continuous 1730

Work scheduled by: NGrid

FWD
(Import)
MOSES SOUTH **3100 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 3150 MW

MARCY-EDIC_345_UE1-7

Mon 12/14/2020 to Mon 12/14/2020
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19&16

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

SAND_BAR-PLATSBURG_115_PV20

Mon 12/14/2020 to Fri 12/18/2020 **UPDATED by NYPA 12/03/2020**
0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FRASANNX-COOPERS_345_UCC2-41

Tue 12/15/2020 to Wed 12/16/2020
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 06, 2020 to Tuesday ,June 07, 2022

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-FRASANNX_345_UCC2-41

Tue 12/15/2020 to Wed 12/16/2020
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

STONYRDG-HILLSIDE_230_72

Wed 12/16/2020 to Mon 12/21/2020
0700 Continuous 0300

Work scheduled by: NYSEG

UPDATED by NYSEG 11/04/2020

FWD
(Import)
DYSINGER EAST **2850 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

N.SCTLND-LEEDS___345_93

Thu 12/17/2020 to Fri 12/18/2020
0800 Continuous 1500

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

SPRNBK_-TREMONT__345_X28

Fri 12/18/2020 to Sat 12/19/2020
0101 Continuous 0259

Work scheduled by: ConEd

UPDATED by CONED 11/04/2020

FWD
(Import)
SPR/DUN-SOUTH **4200 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 4600 MW

BUCHAN_N-EASTVIEW_345_W93

Sat 12/19/2020 to Sat 12/19/2020
0301 Continuous 0330

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1870 MW
TTC with All Lines In Service 6220 MW

EASTVIEW-SPRNBK__345_W79

Sat 12/19/2020 to Sun 12/20/2020
0301 Continuous 0259

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1870 MW
TTC with All Lines In Service 6220 MW

BUCHAN_N-EASTVIEW_345_W93

Sun 12/20/2020 to Sun 12/20/2020
0230 Continuous 0259

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1870 MW
TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 06, 2020 to Tuesday ,June 07, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

FWD

 Mon 01/04/2021 to Sat 02/27/2021 UPDATED by NYPA 11/30/2020

(Import)

0700 Continuous 1730

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

SHORE_RD_345_138_BK 2

FWD

 Wed 01/06/2021 to Wed 01/13/2021 UPDATED by CONED 11/25/2020

(Import)

0001 Continuous 2359

CONED - LIPA

1350 MW

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI

BUCHAN_N-EASTVIEW_345_W93

FWD

 Fri 01/15/2021 to Fri 01/15/2021 UPDATED by CE 10/16/2020

(Import)

0001 Continuous 0030

UPNY CONED

4350 MW

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

EASTVIEW-SPRNBK_345_W79

FWD

 Fri 01/15/2021 to Mon 01/18/2021 UPDATED by CE 10/16/2020

(Import)

0001 Continuous 0259

UPNY CONED

4350 MW

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

BUCHAN_N-EASTVIEW_345_W93

FWD

 Mon 01/18/2021 to Mon 01/18/2021 UPDATED by CE 10/16/2020

(Import)

0230 Continuous 0259

UPNY CONED

4350 MW

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

LADENTWN-BUCHAN_S_345_Y88

FWD

 Mon 01/18/2021 to Fri 03/05/2021 UPDATED by CE 11/10/2020

(Import)

0300 Continuous 0300

UPNY CONED

5930 MW

Impacts Total Transfer Capability 290 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

SPRNBK_-TREMONT_345_X28

FWD

 Mon 01/18/2021 to Thu 01/21/2021 UPDATED by CE 11/07/2020

(Import)

0301 Continuous 0259

SPR/DUN-SOUTH

4200 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

NYISO TRANSFER LIMITATIONS

Sunday ,December 06, 2020 to Tuesday ,June 07, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-TREMONT__345_X28

FWD

 Fri 01/22/2021 to Fri 01/22/2021 **UPDATED by CE 11/07/2020**

(Import)

2130 Continuous 2159

SPR/DUN-SOUTH

4200 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

SPRNBK_-TREMONT__345_X28

FWD

Sat 01/23/2021 to Sun 01/24/2021

(Import)

0301 Continuous 0200

SPR/DUN-SOUTH

4200 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

MOTHAVN-RAINEY__345_Q12

FWD

Mon 01/25/2021 to Tue 02/09/2021

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

W49TH_ST_345KV_8

FWD

Sat 01/30/2021 to Thu 03/11/2021

(Import)

0001 Continuous 0200

SCH - PJM_HTP

300 MW

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

PORTER_-ROTTDAM_230_31

FWD

Mon 02/01/2021 to Sat 02/27/2021

(Import)

0600 Continuous 1830

CENTRAL EAST - VC

2805 MW

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

W49TH_ST_345KV_6

FWD

Wed 02/17/2021 to Wed 02/17/2021

(Import)

0001 Continuous 0030

SCH - PJM_HTP

300 MW

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

BERKSHIR-ALPS____345_393

FWD

REV

Wed 02/17/2021 to Fri 02/19/2021

(Import) (Export)

0730 Continuous 1600

SCH - NE - NY

1100 MW 1700 MW

Impacts Total Transfer Capability 300 MW 0 MW

TTC with All Lines In Service 1400 MW 1700 MW

Work scheduled by: NGrid

ARR: 78

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday ,December 06, 2020 to Tuesday ,June 07, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | |
|----------------------------|------------|----------------|-----------------------------------|-----------------|
| BERKSHIR-ALPS____345_393 | | | FWD | REV |
| Wed 02/17/2021 | to | Fri 02/19/2021 | (Import) | (Export) |
| 0730 | Continuous | 1600 | SCH - NPX_1385 | 100 MW 100 MW |
| Work scheduled by: NGrid | | | Impacts Total Transfer Capability | 100 MW 100 MW |
| ARR: 78 | | | TTC with All Lines In Service | 200 MW 200 MW |
| ATHENS__-PLSNTVLY_345_91 | | | FWD | |
| Mon 02/22/2021 | to | Wed 02/24/2021 | (Import) | |
| 0600 | Continuous | 1800 | UPNY CONED | 3800 MW |
| Work scheduled by: NGrid | | | Impacts Total Transfer Capability | 2420 MW |
| | | | TTC with All Lines In Service | 6220 MW |
| SAND_BAR-PLATSBRG_115_PV20 | | | | |
| Mon 02/22/2021 | to | Fri 02/26/2021 | | |
| 0600 | Daily | 1800 | SCH - NE - NY | |
| Work scheduled by: ISONE | | | Impacts Total Transfer Capability | |
| | | | TTC with All Lines In Service | |
| LEEDS__-PLSNTVLY_345_92 | | | FWD | |
| Thu 02/25/2021 | to | Sat 02/27/2021 | (Import) | |
| 0600 | Continuous | 1800 | UPNY CONED | 3800 MW |
| Work scheduled by: NGrid | | | Impacts Total Transfer Capability | 2420 MW |
| | | | TTC with All Lines In Service | 6220 MW |
| CHATGUAY-MASSENA__765_7040 | | | FWD | |
| Sun 02/28/2021 | to | Mon 03/01/2021 | (Import) | |
| 0500 | Continuous | 1730 | MOSES SOUTH | 1550 MW |
| Work scheduled by: NYPA | | | Impacts Total Transfer Capability | 1600 MW |
| | | | TTC with All Lines In Service | 3150 MW |
| CHATGUAY-MASSENA__765_7040 | | | FWD | REV |
| Sun 02/28/2021 | to | Mon 03/01/2021 | (Import) | (Export) |
| 0500 | Continuous | 1730 | SCH - HQ - NY | 0 MW 0 MW |
| Work scheduled by: NYPA | | | Impacts Total Transfer Capability | 1500 MW 1000 MW |
| | | | TTC with All Lines In Service | 1500 MW 1000 MW |
| MASSENA_-MARCY____765_MSU1 | | | FWD | |
| Sun 02/28/2021 | to | Mon 03/01/2021 | (Import) | |
| 0500 | Continuous | 1730 | CENTRAL EAST - VC | 2265 MW |
| Work scheduled by: NYPA | | | Impacts Total Transfer Capability | 710 MW |
| | | | TTC with All Lines In Service | 2975 MW |

NYISO TRANSFER LIMITATIONS

Sunday ,December 06, 2020 to Tuesday ,June 07, 2022

Seasonal Limits

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 6220MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY____765_MSU1

Sun 02/28/2021 to Mon 03/01/2021

0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

500 MW

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

MASSENA_-MARCY____765_MSU1

Sun 02/28/2021 to Mon 03/01/2021

0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import) (Export)

SCH - HQ - NY

475 MW 1000 MW

Impacts Total Transfer Capability 1025 MW 0 MW

TTC with All Lines In Service 1500 MW 1000 MW

MASSENA_-MARCY____765_MSU1

Sun 02/28/2021 to Mon 03/01/2021

0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

SCH - HQ_CEDARS

90 MW

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

MASSENA_-MARCY____765_MSU1 & CHATGUAY-MASSENA____765_7040

Sun 02/28/2021 to Mon 03/01/2021

0500 1730

Work scheduled by:

FWD

(Import)

MOSES SOUTH

500 MW

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

STLAWRNC-MOSES____230_L33P & MASSENA_-MARCY____765_MSU1

Sun 02/28/2021 to Mon 03/01/2021

0500 1730

Work scheduled by:

FWD

(Import)

SCH - HQ_CEDARS

90 MW

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

DUNWODIE_345KV_3

Mon 03/01/2021 to Mon 03/01/2021

0001 Continuous 0030

Work scheduled by: ConEd

CANCELLED by ConEd 12/01/2020

FWD

(Import)

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

Mon 03/01/2021 to Mon 03/01/2021

0001 Continuous 0030

Work scheduled by: ConEd

CANCELLED by ConEd 12/01/2020

FWD

(Import)

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 06, 2020 to Tuesday ,June 07, 2022

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | | | | | |
|----------------------------------|------------|----------------|------------------|-----------------|-------------------|-----------------------------------|-----------------|----------------|--|--|
| EASTVIEW-SPRNBK__345_W64 | | | | | | FWD | | | | |
| Mon 03/01/2021 | to | Mon 03/01/2021 | <u>UPDATED</u> | <u>by CONED</u> | <u>01/23/2020</u> | (Import) | | | | |
| 0001 | Continuous | 0030 | | | | UPNY CONED | 4350 MW | | | |
| Work scheduled by: ConEd | | | | | | Impacts Total Transfer Capability | 1870 MW | | | |
| | | | | | | TTC with All Lines In Service | 6220 MW | | | |
| SPRNBK__345KV_RNS5 | | | | | | FWD | | | | |
| Mon 03/01/2021 | to | Mon 03/01/2021 | <u>UPDATED</u> | <u>by CONED</u> | <u>01/23/2020</u> | (Import) | | | | |
| 0001 | Continuous | 0030 | | | | SPR/DUN-SOUTH | 3200 MW | | | |
| Work scheduled by: ConEd | | | | | | Impacts Total Transfer Capability | 1400 MW | | | |
| | | | | | | TTC with All Lines In Service | 4600 MW | | | |
| MILLWOOD-EASTVIEW_345_W99 | | | | | | FWD | | | | |
| Mon 03/01/2021 | to | Mon 03/22/2021 | <u>UPDATED</u> | <u>by CONED</u> | <u>01/23/2020</u> | (Import) | | | | |
| 0001 | Continuous | 0200 | | | | UPNY CONED | 5985 MW | | | |
| Work scheduled by: ConEd | | | | | | Impacts Total Transfer Capability | 235 MW | | | |
| | | | | | | TTC with All Lines In Service | 6220 MW | | | |
| DUNWODIE-MOTTHAVN_345_71 | | | | | | FWD | | | | |
| Mon 03/01/2021 | to | Mon 04/05/2021 | <u>CANCELLED</u> | <u>by ConEd</u> | <u>12/01/2020</u> | (Import) | | | | |
| 0001 | Continuous | 0300 | | | | SPR/DUN-SOUTH | 3800 MW | | | |
| Work scheduled by: ConEd | | | | | | Impacts Total Transfer Capability | 800 MW | | | |
| | | | | | | TTC with All Lines In Service | 4600 MW | | | |
| MOTTHAVN-RAINEY__345_Q11 | | | | | | FWD | | | | |
| Mon 03/01/2021 | to | Tue 04/06/2021 | | | | (Import) | | | | |
| 0001 | Continuous | 0700 | | | | SPR/DUN-SOUTH | 3800 MW | | | |
| Work scheduled by: ConEd | | | | | | Impacts Total Transfer Capability | 800 MW | | | |
| | | | | | | TTC with All Lines In Service | 4600 MW | | | |
| BERKSHIR-ALPS____345_393 | | | | | | FWD | REV | | | |
| Mon 03/01/2021 | to | Sat 03/20/2021 | <u>UPDATED</u> | <u>by NYISO</u> | <u>11/20/2020</u> | (Import) | (Export) | | | |
| 0700 | Continuous | 1600 | | | | SCH - NE - NY | 1100 MW | 1700 MW | | |
| Work scheduled by: NGrid | | | | | | Impacts Total Transfer Capability | 300 MW 0 MW | | | |
| | | | | | | TTC with All Lines In Service | 1400 MW 1700 MW | | | |
| BERKSHIR-ALPS____345_393 | | | | | | FWD | REV | | | |
| Mon 03/01/2021 | to | Sat 03/20/2021 | <u>UPDATED</u> | <u>by NYISO</u> | <u>11/20/2020</u> | (Import) | (Export) | | | |
| 0700 | Continuous | 1600 | | | | SCH - NPX_1385 | 100 MW | 100 MW | | |
| Work scheduled by: NGrid | | | | | | Impacts Total Transfer Capability | 100 MW 100 MW | | | |
| | | | | | | TTC with All Lines In Service | 200 MW 200 MW | | | |

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_900

REV

Mon 03/01/2021 to Sat 03/20/2021 **UPDATED by NYISO 11/20/2020**

(Export)

0700 Continuous 1600

Work scheduled by: NGrid

SCH - NE - NY

1100 MW

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

1700 MW

EDIC__-N.SCTLND_345_14

FWD

Tue 03/02/2021 to Mon 05/31/2021

(Import)

0600 Continuous 1830

Work scheduled by: NGrid

CENTRAL EAST - VC

2240 MW

Impacts Total Transfer Capability

735 MW

TTC with All Lines In Service

2975 MW

PORTER__-ROTTRDAM_230_31

FWD

Tue 03/02/2021 to Mon 05/31/2021

(Import)

0600 Continuous 1830

Work scheduled by: NGrid

CENTRAL EAST - VC

2805 MW

Impacts Total Transfer Capability

170 MW

TTC with All Lines In Service

2975 MW

MOSES__-ADIRNDCK_230_MA1

FWD

Tue 03/02/2021 to Mon 05/31/2021

(Import)

0700 Continuous 1300

Work scheduled by: NYPA

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability

850 MW

TTC with All Lines In Service

3150 MW

HUDSONTP-W49TH_ST_345_Y56

FWD

Sat 03/06/2021 to Tue 03/09/2021

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

SCH - PJM_HTP

0 MW

Impacts Total Transfer Capability

660 MW

TTC with All Lines In Service

660 MW

W49TH_ST_345KV_6

FWD

Sat 03/06/2021 to Tue 03/09/2021

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

SCH - PJM_HTP

300 MW

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

W49TH_ST_345KV_7

FWD

Sat 03/06/2021 to Tue 03/09/2021

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

SCH - PJM_HTP

300 MW

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 06, 2020 to Tuesday ,June 07, 2022

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 6220MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-ROBNSNRD_230_64

REV

Fri 03/12/2021 to Fri 03/12/2021

(Export)

0500 Continuous 1700

SCH - OH - NY

1900 MW

Work scheduled by: NYPA

Impacts Total Transfer Capability

100 MW

TTC with All Lines In Service

2000 MW

MARCY_345KV_CSC

FWD

Sat 03/13/2021 to Sat 03/13/2021

(Import)

0700 Continuous 1730

UPDATED**by NYPA****07/29/2020**

CENTRAL EAST - VC

2925 MW

Work scheduled by: NYPA

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service

2975 MW

W49TH_ST_345KV_6

FWD

Tue 03/16/2021 to Tue 03/16/2021

(Import)

0230 Continuous 0300

SCH - PJM_HTP

300 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service

660 MW

W49TH_ST_345KV_8

FWD

Tue 03/16/2021 to Tue 03/16/2021

(Import)

0230 Continuous 0300

SCH - PJM_HTP

300 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service

660 MW

EASTVIEW-SPRNBK_345_W64

FWD

Mon 03/22/2021 to Mon 03/22/2021

(Import)

0130 Continuous 0200

UPDATED**by CONED****01/23/2020**

UPNY CONED

4350 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service

6220 MW

SPRNBK_345KV_RNS5

FWD

Mon 03/22/2021 to Mon 03/22/2021

(Import)

0130 Continuous 0200

UPDATED**by CONED****01/23/2020**

SPR/DUN-SOUTH

3200 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service

4600 MW

W49TH_ST_345KV_5

FWD

Fri 03/26/2021 to Wed 05/05/2021

(Import)

0001 Continuous 0300

UPDATED**by CONED****10/06/2020**

SCH - PJM_HTP

300 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service

660 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 06, 2020 to Tuesday ,June 07, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY____-EDIC____345_2-15

 Mon 03/29/2021 to Fri 04/16/2021
 0800 Continuous 1730

09/12/2020

Work scheduled by: NYPA

 FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

BRANCHBG-HOPATCON_500_5060

 Wed 03/31/2021 to Wed 03/31/2021
 0200 Continuous 1500

UPDATED by PJM 11/30/2020

Work scheduled by: PJM

 FWD
 (Import)
 UPNY CONED **6025 MW**
 Impacts Total Transfer Capability 195 MW
 TTC with All Lines In Service 6220 MW

ROCHESTR-PANNELL__345_RP2

 Wed 03/31/2021 to Mon 04/12/2021
 0500 Continuous 1700

Work scheduled by: NYPA

 FWD
 (Import)
 DYSINGER EAST **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

LINDN_CG-LNDVFT__345_V-3022

 Sun 04/04/2021 to Sat 04/10/2021
 1400 Continuous 1400

Work scheduled by: PJM

 FWD REV
 (Import) (Export)
 SCH - PJM_VFT **0 MW 0 MW**
 Impacts Total Transfer Capability 315 MW 315 MW
 TTC with All Lines In Service 315 MW 315 MW

DUNWODIE_345KV_3

 Mon 04/05/2021 to Mon 04/05/2021
 0230 Continuous 0300

CANCELLED by ConEd 12/01/2020

Work scheduled by: ConEd

 FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

 Mon 04/05/2021 to Mon 04/05/2021
 0230 Continuous 0300

CANCELLED by ConEd 12/01/2020

Work scheduled by: ConEd

 FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NIAGARA_-STA_255__345_NH-2

 Fri 04/16/2021 to Fri 04/16/2021
 0500 Continuous 1700

Work scheduled by: NYPA

 FWD
 (Import)
 DYSINGER EAST **2350 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 06, 2020 to Tuesday ,June 07, 2022

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 6220MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

KINTIGH_-STA_255__345_SH1-39

FWD

Mon 04/26/2021 to Fri 04/30/2021

(Import)

0700 Continuous 1700

DYSINGER EAST **1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

NIAGARA_-KINTIGH__345_NS1-38

FWD

Mon 04/26/2021 to Fri 04/30/2021

(Import)

0700 Continuous 1700

DYSINGER EAST **1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

PLSNTVLY-WOOD_ST__345_F31

FWD

Tue 04/27/2021 to Wed 04/28/2021

(Import)

0001 Continuous 0159

UPNY CONED **4000 MW**

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

PLSNTVLY_345KV_RNS4

FWD

Tue 04/27/2021 to Wed 04/28/2021

(Import)

0001 Continuous 0159

UPNY CONED **3800 MW**

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

SPRNBK__345KV_RNS4

FWD

Sat 05/01/2021 to Sat 05/01/2021

(Import)

0001 Continuous 0030

UPDATED by CONED 10/06/2020SPR/DUN-SOUTH **3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

SPRNBK_-W49TH_ST_345_M52

FWD

Sat 05/01/2021 to Tue 05/04/2021

(Import)

0001 Continuous 0300

UPDATED by CONED 10/06/2020SPR/DUN-SOUTH **3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

W49TH_ST_345KV_7

FWD

Sat 05/01/2021 to Tue 05/04/2021

(Import)

0001 Continuous 0300

UPDATED by CONED 10/06/2020SCH - PJM_HTP **300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday ,December 06, 2020 to Tuesday ,June 07, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1600

FWD

Sat 05/01/2021 to Sun 10/31/2021 UPDATED by IESO 05/03/2019

(Import)

0001 Continuous 2359

SCH - OH - NY

1900 MW

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 1950 MW

Work scheduled by: IESO

CLAY-EDIC_345_2-15

FWD

Mon 05/03/2021 to Fri 05/07/2021

(Import)

0700 Continuous 1530

OSWEGO EXPORT

4850 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

PANNELL-CLAY_345_2

FWD

Mon 05/03/2021 to Sun 05/30/2021

(Import)

0700 Continuous 1730

WEST CENTRAL

1300 MW

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

HURLYAVE-ROSETON_345_303

FWD

Mon 05/03/2021 to Fri 05/21/2021

(Import)

0800 Continuous 1600

UPNY CONED

4100 MW

Impacts Total Transfer Capability 2120 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: CHGE

SHOR_NPX-SHOREHAM_138_CSC

FWD

REV

Mon 05/03/2021 to Fri 05/07/2021

(Import) (Export)

0900 Continuous 1500

SCH - NPX_CSC

0 MW

0 MW

Impacts Total Transfer Capability 330 MW 330 MW

TTC with All Lines In Service 330 MW 330 MW

Work scheduled by: LI

SPRNBRK_345KV_RNS4

FWD

Tue 05/04/2021 to Tue 05/04/2021 UPDATED by CONED 10/06/2020

(Import)

0230 Continuous 0300

SPR/DUN-SOUTH

3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

CLAY-EDIC_345_1-16

FWD

Mon 05/10/2021 to Fri 05/14/2021

(Import)

0700 Continuous 1530

OSWEGO EXPORT

4850 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

NYISO TRANSFER LIMITATIONS

Sunday ,December 06, 2020 to Tuesday ,June 07, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA__-STA_255__345_NH-2

Mon 05/24/2021 to Fri 05/28/2021

0500 Continuous 1700

Work scheduled by: NYPA

DYSINGER EAST

Impacts Total Transfer Capability

TTC with All Lines In Service

VOLNEY__-MARCY__345_19

Tue 06/01/2021 to Wed 06/02/2021

0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

CENTRAL EAST - VC

2825 MW

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 2975 MW

VOLNEY__-MARCY__345_19

Tue 06/01/2021 to Wed 06/02/2021

0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

OSWEGO EXPORT

4900 MW

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 5250 MW

FRASER__-GILBOA__345_GF5-35

Tue 06/01/2021 to Mon 06/07/2021

0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC

2650 MW

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

MOSES__-ADIRNDCK_230_MA2

Tue 06/01/2021 to Sun 11/14/2021

0700 Continuous 1300

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

2100 MW

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

PORTER__-ROTTRDAM_230_30

Thu 06/03/2021 to Wed 09/15/2021

0600 Continuous 0559

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC

2805 MW

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

MARCY__-EDIC__345_UE1-7

Thu 06/03/2021 to Fri 06/04/2021

0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19&16

FWD

(Import)

OSWEGO EXPORT

5250 MW

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 6220MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___345KV_CSC

FWD

Sat 06/05/2021 to Sat 06/05/2021

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

2925 MW

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

NIAGARA__345_230_AT4

FWD

REV

Mon 07/12/2021 to Fri 07/23/2021

(Import) (Export)

0500 Continuous 1700

SCH - OH - NY

1900 MW 1400 MW

Impacts Total Transfer Capability 50 MW 300 MW

TTC with All Lines In Service 1950 MW 1700 MW

Work scheduled by: NYPA

SAND_BAR-PLATSBURG_115_PV20

Tue 08/03/2021 to Tue 08/03/2021

0700 Continuous 1830

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYPA

FRASANNX-COOPERS__345_UCC2-41

FWD

Tue 09/07/2021 to Wed 09/15/2021

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

2500 MW

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

ARR: 19**MARCY___-FRASANNX_345_UCC2-41**

FWD

Tue 09/07/2021 to Wed 09/15/2021

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

2500 MW

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

ARR: 19**KINTIGH_-STA_255__345_SH1-39**

Mon 09/13/2021 to Fri 09/17/2021

0500 Continuous 1700

DYSINGER EAST

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYPA

NIAGARA_-KINTIGH__345_NS1-38

FWD

Mon 09/13/2021 to Fri 09/17/2021

(Import)

0500 Continuous 1700

DYSINGER EAST

1400 MW

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

NYISO TRANSFER LIMITATIONS

Sunday ,December 06, 2020 to Tuesday ,June 07, 2022

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 6220MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PORTER__-ROTTRDAM_230_30

Wed 09/15/2021 to Tue 11/30/2021
0600 Continuous 1830

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2805 MW**
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

EDIC____-N.SCTLND_345_14

Thu 09/16/2021 to Sun 11/14/2021
0600 Continuous 1830

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2240 MW**
Impacts Total Transfer Capability 735 MW
TTC with All Lines In Service 2975 MW

HURLYAVE-ROSETON__345_303

Thu 09/16/2021 to Sun 10/17/2021
0800 Continuous 1600

Work scheduled by: CHGE

UPDATED by CHGE 09/22/2020

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 2120 MW
TTC with All Lines In Service 6220 MW

PANNELL_-CLAY_____345_1

Mon 09/20/2021 to Fri 09/24/2021
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

PANNELL_-CLAY_____345_2

Mon 09/27/2021 to Fri 10/01/2021
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

W49TH_ST_345KV_6

Tue 09/28/2021 to Tue 09/28/2021
0100 Continuous 0130

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

E13THSTA-FARRAGUT_345_46

Tue 09/28/2021 to Tue 10/26/2021
0100 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday ,December 06, 2020 to Tuesday ,June 07, 2022

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 6220MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST-E13THSTA_345_M55

FWD

Tue 09/28/2021 to Tue 10/26/2021
0100 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH 3800 MW
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

LEEDS -HURLYAVE_345_301

FWD

Mon 10/18/2021 to Fri 11/19/2021
0800 Continuous 1600

Work scheduled by: CHGE

(Import)
UPNY CONED 4100 MW
Impacts Total Transfer Capability 2120 MW
TTC with All Lines In Service 6220 MW

W49TH_ST_345KV_6

FWD

Tue 10/26/2021 to Tue 10/26/2021
0230 Continuous 0300

Work scheduled by: ConEd

(Import)
SCH - PJM_HTP 300 MW
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

SCH-IMO-NYISO_LIMIT_1750

FWD

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019
0001 Continuous 2359

Work scheduled by: IESO

(Import)
SCH - OH - NY 2050 MW
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 2300 MW

SCH-NYISO-IMO_LIMIT_1600

REV

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019
0001 Continuous 2359

Work scheduled by: IESO

(Export)
SCH - OH - NY 1900 MW
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 2000 MW

MOSES -ADIRNDCK_230_MAI

FWD

Wed 12/01/2021 to Tue 05/31/2022
0700 Continuous 1300

Work scheduled by: NYPA

(Import)
MOSES SOUTH 2300 MW
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

N.SCTLND-ALPS_345_2

FWD

Mon 05/02/2022 to Mon 05/09/2022
0600 Daily 1800

Work scheduled by: NGrid

(Import)
SCH - NE - NY 750 MW
Impacts Total Transfer Capability 650 MW
TTC with All Lines In Service 1400 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 06, 2020 to Tuesday ,June 07, 2022

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 6220MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N.SCTLND-ALPS_____345_2

Mon 05/02/2022 to Mon 05/09/2022
0600 Daily 1800

Work scheduled by: NGrid

| | FWD | REV |
|-----------------------------------|----------|----------|
| | (Import) | (Export) |
| SCH - NPX_1385 | 100 MW | 100 MW |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

HOMRC_NY-MAINS_NY_345_47

Fri 05/20/2022 to Fri 05/27/2022
0800 Continuous 1600

Work scheduled by: PJM

UPDATED by PJM 11/19/2020

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

HOMR_NYW-PIERC_NY_345_48

Fri 05/20/2022 to Fri 05/27/2022
0800 Continuous 1600

Work scheduled by: PJM

UPDATED by PJM 11/19/2020

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

MOSES____-ADIRNDCK_230_MA2

Wed 06/01/2022 to Mon 11/14/2022
0700 Continuous 1300

Work scheduled by: NYPA

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| MOSES SOUTH | 2100 MW |
| Impacts Total Transfer Capability | 1050 MW |
| TTC with All Lines In Service | 3150 MW |