

# NYISO TRANSFER LIMITATIONS

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Wed 06/30/2021 EXT FORCE by CONED 08/28/2020

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Wed 06/30/2021

0001 2359

Work scheduled by:

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD	REV
(Import)	(Export)
<b>2550 MW</b>	<b>1900 MW</b>
250 MW	50 MW
2800 MW	1950 MW

### MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Wed 06/30/2021 EXT FORCE by CONED 08/28/2020

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### STLAWRNC-MOSES\_230\_L33P

Mon 04/30/2018 to Mon 10/31/2022 EXT FORCE by IESO 10/01/2020

0456 Continuous 1600

Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### NEWBRDGE\_345\_138\_BK\_1

Wed 09/02/2020 to Tue 02/01/2022 EXT FORCE by LI 01/12/2021

1807 Continuous 2359

Work scheduled by: LI

FWD
(Import)
<b>375 MW</b>
285 MW
660 MW

SCH - PJM\_NEPTUNE

Impacts Total Transfer Capability

TTC with All Lines In Service

### SPRNBRK\_-EGRDNCTR\_345\_Y49

Thu 10/01/2020 to Mon 04/19/2021 EXT FORCE by LI 02/23/2021

0404 Continuous 2359

Work scheduled by: LI

FWD
(Import)
<b>775 MW</b>
725 MW
1500 MW

CONED - LIPA

Impacts Total Transfer Capability

TTC with All Lines In Service

### EGRDNCTY\_345\_138\_AT2

Sat 10/10/2020 to Mon 04/19/2021 EXT FORCE by LI 02/23/2021

1815 Continuous 2359

Work scheduled by: LI

FWD
(Import)
<b>1250 MW</b>
250 MW
1500 MW

CONED - LIPA

Impacts Total Transfer Capability

TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## EGRDNCTY\_345\_138\_AT1

Sat 10/10/2020 to Mon 04/19/2021  
1856 Continuous 2359

EXT FORCE by LI 02/23/2021

Work scheduled by: LI

FWD  
(Import)  
**1250 MW**  
CONED - LIPA  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

## SCH-IMO-NYISO\_LIMIT\_1750

Sun 11/01/2020 to Fri 04/30/2021  
0001 Continuous 2359

UPDATED by IESO 05/03/2019

Work scheduled by: IESO

FWD  
(Import)  
**2050 MW**  
SCH - OH - NY  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 2300 MW

## SCH-NYISO-IMO\_LIMIT\_1600

Sun 11/01/2020 to Fri 04/30/2021  
0001 Continuous 2359

UPDATED by IESO 05/03/2019

Work scheduled by: IESO

REV  
(Export)  
**1900 MW**  
SCH - OH - NY  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 2000 MW

## SAND\_BAR-PLATSBURG\_115\_PV20

Tue 02/23/2021 to Mon 05/17/2021  
1801 Continuous 0559

EXT FORCE by ISONE 02/26/2021

Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## BERKSHIR-ALPS\_\_\_\_\_345\_393

Mon 03/01/2021 to Tue 03/09/2021  
0600 Continuous 1600

UPDATED by NGRID 03/08/2021

Work scheduled by: NGrid

ARR: 78

FWD REV  
(Import) (Export)  
**1100 MW 1700 MW**  
SCH - NE - NY  
Impacts Total Transfer Capability 300 MW 0 MW  
TTC with All Lines In Service 1400 MW 1700 MW

## BERKSHIR-ALPS\_\_\_\_\_345\_393

Mon 03/01/2021 to Tue 03/09/2021  
0600 Continuous 1600

UPDATED by NGRID 03/08/2021

Work scheduled by: NGrid

ARR: 78

FWD REV  
(Import) (Export)  
**100 MW 100 MW**  
SCH - NPX\_1385  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

## BERKSHIR-ALPS\_\_\_\_\_345\_393 &amp; BERKSHIR-NORTHFLD\_345\_312

Mon 03/01/2021 to Tue 03/09/2021  
0600 1600

Work scheduled by:

ARR: 78

FWD REV  
(Import) (Export)  
**1100 MW 1700 MW**  
SCH - NE - NY  
Impacts Total Transfer Capability 300 MW 0 MW  
TTC with All Lines In Service 1400 MW 1700 MW

**NYISO TRANSFER LIMITATIONS**

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BERKSHIR-NORTHFLD_345_312</b>						FWD				
Mon 03/01/2021	to	Tue 03/09/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/08/2021</u>	(Import)				
0600	Continuous	1600				SCH - NE - NY	<b>1300 MW</b>			
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW			
						TTC with All Lines In Service	1400 MW			
<b>BERKSHIR-NORTHFLD_345_312</b>						FWD	REV			
Mon 03/01/2021	to	Tue 03/09/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/08/2021</u>	(Import)	(Export)			
0600	Continuous	1600				SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>		
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW			
						TTC with All Lines In Service	200 MW			
<b>SCH-NE-NYISO_LIMIT_800</b>						FWD				
Mon 03/01/2021	to	Tue 03/09/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/08/2021</u>	(Import)				
2300	Daily	0659				SCH - NE - NY	<b>1000 MW</b>			
Work scheduled by: ISONE						Impacts Total Transfer Capability	400 MW			
						TTC with All Lines In Service	1400 MW			
<b>SCH-NYISO-NE_LIMIT_700</b>							REV			
Mon 03/01/2021	to	Tue 03/09/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/08/2021</u>		(Export)			
2300	Daily	0659				SCH - NE - NY	<b>900 MW</b>			
Work scheduled by: ISONE						Impacts Total Transfer Capability	800 MW			
						TTC with All Lines In Service	1700 MW			
<b>W49TH_ST_345KV_8</b>						FWD				
Tue 03/02/2021	to	Mon 04/26/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>03/11/2021</u>	(Import)				
0201	Continuous	0200				SCH - PJM_HTP	<b>300 MW</b>			
Work scheduled by: ConEd						Impacts Total Transfer Capability	360 MW			
						TTC with All Lines In Service	660 MW			
<b>PORTER__-ROTTRDAM_230_31</b>						FWD				
Tue 03/02/2021	to	Mon 05/31/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/10/2021</u>	(Import)				
0600	Continuous	1730				CENTRAL EAST - VC	<b>2805 MW</b>			
Work scheduled by: NGrid						Impacts Total Transfer Capability	170 MW			
						TTC with All Lines In Service	2975 MW			
<b>MOSES__-ADIRNDCK_230_MAI</b>						FWD				
Tue 03/02/2021	to	Mon 05/10/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/11/2021</u>	(Import)				
0700	Continuous	1159				MOSES SOUTH	<b>2300 MW</b>			
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW			
						TTC with All Lines In Service	3150 MW			

# NYISO TRANSFER LIMITATIONS

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOPATCON-RAMAPO___500_5018						FWD	REV
Fri 03/05/2021 to Sat 03/20/2021						(Import)	(Export)
0001	Continuous	0200	<u>EXTENDED</u>	<u>by CONED</u>	<u>03/12/2021</u>	SCH - PJ - NY	<b>1450 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	1350 MW
						TTC with All Lines In Service	2800 MW
HOPATCON-RAMAPO___500_5018						FWD	
Fri 03/05/2021 to Sat 03/20/2021						(Import)	
0001	Continuous	0200	<u>EXTENDED</u>	<u>by CONED</u>	<u>03/12/2021</u>	UPNY CONED	<b>6025 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	195 MW
						TTC with All Lines In Service	6220 MW
RAMAPO___345_345_PAR3500						FWD	REV
Fri 03/05/2021 to Sat 03/20/2021						(Import)	(Export)
0001	Continuous	0200	<u>EXTENDED</u>	<u>by CONED</u>	<u>03/12/2021</u>	SCH - PJ - NY	<b>2350 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	450 MW
						TTC with All Lines In Service	2800 MW
RAMAPO___345_345_PAR4500						FWD	REV
Fri 03/05/2021 to Sat 03/20/2021						(Import)	(Export)
0001	Continuous	0200	<u>EXTENDED</u>	<u>by CONED</u>	<u>03/12/2021</u>	SCH - PJ - NY	<b>2350 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	450 MW
						TTC with All Lines In Service	2800 MW
RAMAPO___500_345_BK 1500						FWD	REV
Fri 03/05/2021 to Sat 03/20/2021						(Import)	(Export)
0001	Continuous	0200	<u>EXTENDED</u>	<u>by CONED</u>	<u>03/12/2021</u>	SCH - PJ - NY	<b>1450 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	1350 MW
						TTC with All Lines In Service	2800 MW
RAMAPO___500_345_BK 1500						FWD	
Fri 03/05/2021 to Sat 03/20/2021						(Import)	
0001	Continuous	0200	<u>EXTENDED</u>	<u>by CONED</u>	<u>03/12/2021</u>	UPNY CONED	<b>6025 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	195 MW
						TTC with All Lines In Service	6220 MW
LADENTWN-BUCHAN_S_345_Y88						FWD	
Tue 03/09/2021 to Thu 04/08/2021						(Import)	
0001	Continuous	0200	<u>UPDATED</u>	<u>by CE</u>	<u>03/05/2021</u>	UPNY CONED	<b>5930 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	290 MW
						TTC with All Lines In Service	6220 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NE-NYISO\_LIMIT\_900

Tue 03/09/2021 to Tue 03/09/2021 UPDATED by ISONE 03/08/2021  
0700 Daily 1600

Work scheduled by: ISONE

FWD  
(Import)  
SCH - NE - NY **1100 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 1400 MW

## SCH-NYISO-NE\_LIMIT\_800

Tue 03/09/2021 to Tue 03/09/2021 UPDATED by ISONE 03/08/2021  
0700 Daily 1600

Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1700 MW

## OSWEGO\_\_ -ELBRIDGE\_345\_17

Tue 03/09/2021 to Tue 03/09/2021 UPDATED by NGRID 03/10/2021  
0800 Daily(No Weekends) 1000

Work scheduled by: NGrid

ARR: 75

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

## ELBRIDGE-LAFAYTTE\_345\_17-LE

Tue 03/09/2021 to Tue 03/09/2021 UPDATED by NGRID 03/10/2021  
0800 Daily(No Weekends) 1630

Work scheduled by: NGrid

ARR: 75

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

## OSWEGO\_\_ -ELBRIDGE\_345\_17

Tue 03/09/2021 to Tue 03/09/2021 UPDATED by NGRID 03/10/2021  
1430 Daily(No Weekends) 1630

Work scheduled by: NGrid

ARR: 75

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

## STLAWRNC-MOSES\_\_\_\_230\_L33P &amp; STLAWRNC-MOSES\_\_\_\_230\_L34P

Wed 03/10/2021 to Thu 03/11/2021  
1555 2359

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **2700 MW**  
Impacts Total Transfer Capability 450 MW  
TTC with All Lines In Service 3150 MW

## STLAWRNC-MOSES\_\_\_\_230\_L33P &amp; STLAWRNC-MOSES\_\_\_\_230\_L34P

Wed 03/10/2021 to Thu 03/11/2021  
1555 2359

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS **0 MW**  
Impacts Total Transfer Capability 199 MW  
TTC with All Lines In Service 199 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES\_\_\_\_230\_L33P & STLAWRNC-MOSES\_\_\_\_230\_L34P & SAND\_BAR-  
PLATSBURG\_115\_PV20

FWD

(Import)

Wed 03/10/2021 to Thu 03/11/2021  
1555 2359

SCH - HQ\_CEDARS

0 MW

Impacts Total Transfer Capability 199 MW

TTC with All Lines In Service 199 MW

Work scheduled by:

STLAWRNC-MOSES\_\_\_\_230\_L34P

Wed 03/10/2021 to Thu 03/11/2021  
1555 Continuous 2359

FORCEDby NYPA03/10/2021

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYPA

SCH-NE-NYISO\_LIMIT\_900

FWD

(Import)

Thu 03/11/2021 to Fri 03/19/2021  
0700 Daily 2259

UPDATEDby ISONE03/08/2021

SCH - NE - NY

1100 MW

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

SCH-NYISO-NE\_LIMIT\_800

REV

(Export)

Thu 03/11/2021 to Fri 03/19/2021  
0700 Daily 2259

UPDATEDby ISONE03/08/2021

SCH - NE - NY

1000 MW

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 1700 MW

Work scheduled by: ISONE

BERKSHIR-ALPS\_\_\_\_345\_393

FWD

REV

(Import) (Export)

Thu 03/11/2021 to Sat 03/20/2021  
0700 Continuous 1700

UPDATEDby NGRID03/08/2021

SCH - NE - NY

1100 MW

1700 MW

Impacts Total Transfer Capability 300 MW

0 MW

TTC with All Lines In Service 1400 MW

1700 MW

Work scheduled by: NGrid

ARR: 78

BERKSHIR-ALPS\_\_\_\_345\_393

FWD

REV

(Import) (Export)

Thu 03/11/2021 to Sat 03/20/2021  
0700 Continuous 1700

UPDATEDby NGRID03/08/2021

SCH - NPX\_1385

100 MW

100 MW

Impacts Total Transfer Capability 100 MW

100 MW

TTC with All Lines In Service 200 MW

200 MW

Work scheduled by: NGrid

ARR: 78

BERKSHIR-ALPS\_\_\_\_345\_393 &amp; BERKSHIR-NORTHFLD\_345\_312

FWD

REV

(Import) (Export)

Thu 03/11/2021 to Sat 03/20/2021  
0700 1700

SCH - NE - NY

1100 MW

1700 MW

Impacts Total Transfer Capability 300 MW

0 MW

TTC with All Lines In Service 1400 MW

1700 MW

Work scheduled by:

ARR: 78

**NYISO TRANSFER LIMITATIONS**

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BERKSHIR-NORTHFLD_345_312</b>						FWD		
Thu 03/11/2021	to	Sat 03/20/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/08/2021</u>	(Import)		
0700	Continuous	1700				SCH - NE - NY	<b>1300 MW</b>	
Work scheduled by: NGrid		Impacts Total Transfer Capability				100 MW		
		TTC with All Lines In Service				1400 MW		
<b>BERKSHIR-NORTHFLD_345_312</b>						FWD	REV	
Thu 03/11/2021	to	Sat 03/20/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/08/2021</u>	(Import) (Export)		
0700	Continuous	1700				SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: NGrid		Impacts Total Transfer Capability				100 MW	100 MW	
		TTC with All Lines In Service				200 MW	200 MW	
<b>SCH-NE-NYISO_LIMIT_800</b>						FWD		
Thu 03/11/2021	to	Sat 03/20/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/08/2021</u>	(Import)		
2300	Daily	0659				SCH - NE - NY	<b>1000 MW</b>	
Work scheduled by: ISONE		Impacts Total Transfer Capability				400 MW		
		TTC with All Lines In Service				1400 MW		
<b>SCH-NYISO-NE_LIMIT_700</b>							REV	
Thu 03/11/2021	to	Sat 03/20/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/08/2021</u>	(Export)		
2300	Daily	0659				SCH - NE - NY	<b>900 MW</b>	
Work scheduled by: ISONE		Impacts Total Transfer Capability				800 MW		
		TTC with All Lines In Service				1700 MW		
<b>SCH-HQ-NYISO_LIMIT_1400</b>						FWD		
Fri 03/12/2021	to	Fri 03/12/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>03/01/2021</u>	(Import)		
0001	Continuous	0100				SCH - HQ - NY	<b>1400 MW</b>	
Work scheduled by: HQ		Impacts Total Transfer Capability				100 MW		
		TTC with All Lines In Service				1500 MW		
<b>NIAGARA_-ROBNSNRD_230_64</b>							REV	
Fri 03/12/2021	to	Fri 03/12/2021				(Export)		
0500	Continuous	1700				SCH - OH - NY	<b>1900 MW</b>	
Work scheduled by: NYPA		Impacts Total Transfer Capability				100 MW		
		TTC with All Lines In Service				2000 MW		
<b>SCH-HQ-NYISO_LIMIT_1400</b>						FWD		
Mon 03/15/2021	to	Mon 03/15/2021				(Import)		
0001	Continuous	0100				SCH - HQ - NY	<b>1400 MW</b>	
Work scheduled by: HQ		Impacts Total Transfer Capability				100 MW		
		TTC with All Lines In Service				1500 MW		

# NYISO TRANSFER LIMITATIONS

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NYISO-HQ\_CEDARS\_LIMIT\_0

Mon 03/15/2021 to Thu 04/01/2021  
0500 Continuous 2000  
Work scheduled by: HQ

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 100 MW

REV  
(Export)

## SCRIBA -VOLNEY\_345\_20

Mon 03/15/2021 to Fri 03/26/2021  
0730 Continuous 1700  
Work scheduled by: NGrid

OSWEGO EXPORT  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

FWD  
(Import)

## W49TH\_ST\_345KV\_6

Wed 03/17/2021 to Mon 04/12/2021 UPDATED by CONED 03/11/2021  
0001 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

FWD  
(Import)

## LEEDS\_345KV\_R395

Fri 03/19/2021 to Fri 03/19/2021 CANCELLED by NGrid 03/12/2021  
1200 Daily(No Weekends) 1730  
Work scheduled by: NGrid

UPNY CONED  
Impacts Total Transfer Capability 2420 MW  
TTC with All Lines In Service 6220 MW

FWD  
(Import)

## SCH-NE-NYISO\_LIMIT\_900

Sat 03/20/2021 to Sat 03/20/2021 UPDATED by ISONE 03/08/2021  
0700 Daily 1700  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 1400 MW

FWD  
(Import)

## SCH-NYISO-NE\_LIMIT\_800

Sat 03/20/2021 to Sat 03/20/2021 UPDATED by ISONE 03/08/2021  
0700 Daily 1700  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1700 MW

REV  
(Export)

## CHAT\_DC\_GC1

Sat 03/20/2021 to Sun 03/21/2021 UPDATED by HQ 03/10/2021  
2000 Continuous 0500  
Work scheduled by: HQ

MOSES SOUTH  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

FWD  
(Import)



# NYISO TRANSFER LIMITATIONS

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC1</b>						REV
Sat 03/20/2021	to	Sun 03/21/2021	<u>CANCELLED</u>	<u>by HQ</u>	<u>03/10/2021</u>	(Export)
2000	Continuous	0500				
Work scheduled by: HQ					SCH - HQ - NY	<b>500 MW</b>
					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
<b>CHAT_DC_GC1</b>						FWD
Sun 03/21/2021	to	Sun 03/21/2021	<u>CANCELLED</u>	<u>by HQ</u>	<u>03/10/2021</u>	(Import)
0001	Continuous	0200				
Work scheduled by: HQ					MOSES SOUTH	<b>2850 MW</b>
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC1</b>						REV
Sun 03/21/2021	to	Sun 03/21/2021	<u>CANCELLED</u>	<u>by HQ</u>	<u>03/10/2021</u>	(Export)
0001	Continuous	0200				
Work scheduled by: HQ					SCH - HQ - NY	<b>500 MW</b>
					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
<b>CHAT_DC_GC2</b>						FWD
Sun 03/21/2021	to	Sun 03/21/2021	<u>CANCELLED</u>	<u>by HQ</u>	<u>03/10/2021</u>	(Import)
0001	Continuous	0200				
Work scheduled by: HQ					MOSES SOUTH	<b>2850 MW</b>
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC2</b>						REV
Sun 03/21/2021	to	Sun 03/21/2021	<u>CANCELLED</u>	<u>by HQ</u>	<u>03/10/2021</u>	(Export)
0001	Continuous	0200				
Work scheduled by: HQ					SCH - HQ - NY	<b>500 MW</b>
					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
<b>SCH-HQ-NYISO_LIMIT_1150</b>						FWD
Sun 03/21/2021	to	Sun 03/21/2021	<u>CANCELLED</u>	<u>by HQ</u>	<u>03/10/2021</u>	(Import)
0001	Continuous	0200				
Work scheduled by: HQ					SCH - HQ - NY	<b>1150 MW</b>
					Impacts Total Transfer Capability	350 MW
					TTC with All Lines In Service	1500 MW
<b>NINEMILE-CLAY_____345_8</b>						FWD
Mon 03/22/2021	to	Mon 03/22/2021				(Import)
0001	Daily(No Weekends)	0400				
Work scheduled by: NGrid					OSWEGO EXPORT	<b>5150 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	5250 MW

**NYISO TRANSFER LIMITATIONS**

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC\_\_\_\_-N.SCTLND\_345\_14 &amp; PORTER\_\_\_\_-ROTTRDAM\_230\_31

FWD

Mon 03/22/2021 to Mon 05/31/2021

(Import)

0600

1730

CENTRAL EAST - VC

**1500 MW**

Impacts Total Transfer Capability 1475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

EDIC\_\_\_\_-N.SCTLND\_345\_14

FWD

Mon 03/22/2021 to Mon 05/31/2021

(Import)

0600

Continuous

1830

UPDATEDby NGRID 03/10/2021

CENTRAL EAST - VC

**1670 MW**

Impacts Total Transfer Capability 1305 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

NINEMILE-CLAY\_\_\_\_345\_8

FWD

Wed 03/24/2021 to Wed 03/24/2021

(Import)

0001

Daily(No Weekends) 0359

UPDATEDby NGRID 03/03/2021

OSWEGO EXPORT

**5150 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

SPRNBK\_\_345KV\_RNS3

FWD

Fri 03/26/2021 to Fri 03/26/2021

(Import)

0001

Continuous

0030

UPDATEDby CONED 01/26/2021

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

EASTVIEW-SPRNBK\_\_345\_W78

FWD

Fri 03/26/2021 to Tue 03/30/2021

(Import)

0001

Continuous

2200

UPDATEDby CONED 01/26/2021

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

MILLWOOD-EASTVIEW\_345\_W85

FWD

Fri 03/26/2021 to Tue 03/30/2021

(Import)

0001

Continuous

2200

UPDATEDby CONED 01/26/2021

UPNY CONED

**5985 MW**

Impacts Total Transfer Capability 235 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

NINEMILE-CLAY\_\_\_\_345\_8

FWD

Sun 03/28/2021 to Sat 04/03/2021

(Import)

2300

Continuous

0200

UPDATEDby NGRID 03/03/2021

OSWEGO EXPORT

**5150 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

# NYISO TRANSFER LIMITATIONS

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HUDSONTP-W49TH\_ST\_345\_Y56

FWD

Tue 03/30/2021 to Fri 04/02/2021 UPDATED by CONED 03/11/2021  
0001 Continuous 0200

Work scheduled by: ConEd

SCH - PJM\_HTP 0 MW  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

(Import)

### W49TH\_ST\_345KV\_7

FWD

Tue 03/30/2021 to Fri 04/02/2021 UPDATED by CONED 03/11/2021  
0001 Continuous 0200

Work scheduled by: ConEd

SCH - PJM\_HTP 300 MW  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

(Import)

### BRANCHBG-HOPATCON\_500\_5060

FWD

Wed 03/31/2021 to Wed 03/31/2021 UPDATED by PJM 11/30/2020  
0200 Continuous 1500

Work scheduled by: PJM

UPNY CONED 6025 MW  
Impacts Total Transfer Capability 195 MW  
TTC with All Lines In Service 6220 MW

(Import)

### ROCHESTR-PANNELL\_\_345\_RP2

FWD

Wed 03/31/2021 to Mon 04/12/2021  
0500 Continuous 1700

Work scheduled by: NYPA

DYSINGER EAST 2300 MW  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

(Import)

### MILLWOOD-EASTVIEW\_345\_W85

FWD

Thu 04/01/2021 to Thu 04/01/2021  
0001 Continuous 0030

Work scheduled by: ConEd

UPNY CONED 5985 MW  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 6220 MW

(Import)

### SPRNBRK\_\_345KV\_RNS3

FWD

Thu 04/01/2021 to Thu 04/01/2021  
0001 Continuous 0030

Work scheduled by: ConEd

SPR/DUN-SOUTH 3800 MW  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

(Import)

### EASTVIEW-SPRNBRK\_\_345\_W78

FWD

Thu 04/01/2021 to Thu 04/01/2021  
0001 Continuous 2200

Work scheduled by: ConEd

UPNY CONED 4350 MW  
Impacts Total Transfer Capability 1870 MW  
TTC with All Lines In Service 6220 MW

(Import)

# NYISO TRANSFER LIMITATIONS

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE_345KV_3</b>					FWD	
Thu 04/01/2021	to	Thu 04/01/2021	<u>EXT FORCE</u>	<u>by CONED</u>	<u>03/13/2021</u>	(Import)
0130	Continuous	0200				
Work scheduled by: ConEd					SPR/DUN-SOUTH	<b>3800 MW</b>
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_4</b>					FWD	
Thu 04/01/2021	to	Thu 04/01/2021	<u>EXT FORCE</u>	<u>by CONED</u>	<u>03/13/2021</u>	(Import)
0130	Continuous	0200				
Work scheduled by: ConEd					SPR/DUN-SOUTH	<b>3800 MW</b>
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>PLSNTVLE-DUNWODIE_345_W89</b>					FWD	
Thu 04/01/2021	to	Thu 04/01/2021	<u>EXT FORCE</u>	<u>by CONED</u>	<u>03/13/2021</u>	(Import)
0130	Continuous	0200				
Work scheduled by: ConEd					UPNY CONED	<b>4000 MW</b>
					Impacts Total Transfer Capability	2220 MW
					TTC with All Lines In Service	6220 MW
<b>MILLWOOD-EASTVIEW_345_W85</b>					FWD	
Thu 04/01/2021	to	Thu 04/01/2021				(Import)
2130	Continuous	2200				
Work scheduled by: ConEd					UPNY CONED	<b>5985 MW</b>
					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	6220 MW
<b>SPRNBRK__345KV_RNS3</b>					FWD	
Thu 04/01/2021	to	Thu 04/01/2021				(Import)
2130	Continuous	2200				
Work scheduled by: ConEd					SPR/DUN-SOUTH	<b>3800 MW</b>
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>LINDN_CG-LNDVFT__345_V-3022</b>					FWD	REV
Sun 04/04/2021	to	Sat 04/10/2021				(Import) (Export)
1400	Continuous	1400				
Work scheduled by: PJM					SCH - PJM_VFT	<b>0 MW 0 MW</b>
					Impacts Total Transfer Capability	315 MW 315 MW
					TTC with All Lines In Service	315 MW 315 MW
<b>NINEMILE-CLAY__345_8</b>					FWD	
Sun 04/04/2021	to	Sun 04/04/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/04/2021</u>	(Import)
1600	Daily	1700				
Work scheduled by: NGrid					OSWEGO EXPORT	<b>5150 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	5250 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## WATRCURE-OAKDALE\_\_345\_31

Mon 04/05/2021 to Thu 04/08/2021

0800 Daily(No Weekends) 1500

Work scheduled by: NYSEG

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## SPRNBRK\_\_345KV\_RNS3

Mon 04/05/2021 to Mon 04/05/2021

1800 Continuous 1830

Work scheduled by: ConEd

UPDATEDby CONED 01/26/2021

SPR/DUN-SOUTH

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

FWD

(Import)

**3800 MW**

## MILLWOOD\_345KV\_18

Thu 04/08/2021 to Fri 04/16/2021

0201 Continuous 1800

Work scheduled by: ConEd

UPDATEDby CONED 03/05/2021

UPNY CONED

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

FWD

(Import)

**4350 MW**

## SPRNBRK\_-TREMONT\_\_345\_X28

Fri 04/09/2021 to Sat 04/10/2021

0001 Continuous 0300

Work scheduled by: ConEd

by CONED 03/12/2021

SPR/DUN-SOUTH

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

FWD

(Import)

**4200 MW**

## GOETHALS\_345KV\_5

Sat 04/10/2021 to Mon 05/10/2021

0200 Continuous 0300

Work scheduled by: PJM

UPDATEDby CONED 01/26/2021

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

## LINDEN\_-GOETHALS\_230\_A2253

Sat 04/10/2021 to Mon 05/10/2021

0200 Continuous 0300

Work scheduled by: PJM

UPDATEDby CONED 01/26/2021

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## LINDEN\_-GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402

Sat 04/10/2021 to Mon 05/10/2021

0200 Continuous 0300

Work scheduled by:

SCH - PJ - NY

Impacts Total Transfer Capability 250 MW 50 MW

TTC with All Lines In Service 2800 MW 1950 MW

FWD

REV

(Import) (Export)

**2550 MW 1900 MW**

# NYISO TRANSFER LIMITATIONS

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDEN\_\_-GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_\_-  
FARRAGUT\_345\_C3403

Sat 04/10/2021 to Mon 05/10/2021  
0200 0300

Work scheduled by:

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD REV  
(Import) (Export)

2550 MW 1900 MW

250 MW 50 MW

2800 MW 1950 MW

LINDEN\_\_-GOETHALS\_230\_A2253 & MARION\_\_-FARRAGUT\_345\_C3403

Sat 04/10/2021 to Mon 05/10/2021  
0200 0300

Work scheduled by:

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD REV  
(Import) (Export)

2550 MW 1900 MW

250 MW 50 MW

2800 MW 1950 MW

W49TH\_ST-E13THSTA\_345\_M55

Mon 04/12/2021 to Tue 04/13/2021  
0201 Continuous 2200

Work scheduled by: ConEd

UPDATED

by CONED 02/19/2021

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
(Import)

3800 MW

800 MW

4600 MW

W49TH\_ST\_345KV\_6

Mon 04/12/2021 to Tue 04/13/2021  
0201 Continuous 2200

Work scheduled by: ConEd

UPDATED

by CONED 02/19/2021

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
(Import)

300 MW

360 MW

660 MW

S.RIPLEY-DUNKIRK\_\_230\_68

Mon 04/12/2021 to Fri 04/23/2021  
0630 Continuous 1700

Work scheduled by: NGrid

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

LEEDS\_\_345KV\_R94301

Mon 04/12/2021 to Mon 04/12/2021  
0800 Continuous 0830

Work scheduled by: CHGE

UPDATED

by NGRID 02/01/2021

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
(Import)

3800 MW

2420 MW

6220 MW

LEEDS\_\_-HURLYAVE\_345\_301

Mon 04/12/2021 to Fri 04/16/2021  
0800 Continuous 1600

Work scheduled by: CHGE

UPDATED

by NGRID 02/01/2021

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
(Import)

4100 MW

2120 MW

6220 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_6

FWD

Tue 04/13/2021 to Mon 04/26/2021 UPDATED by CONED 03/11/2021

(Import)

2201 Continuous 0200

SCH - PJM\_HTP

300 MW

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

### NIAGARA\_STA\_255\_345\_NH2

FWD

Fri 04/16/2021 to Fri 04/16/2021

(Import)

0500 Continuous 1700

DYSINGER EAST

2350 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

### LEEDS\_345KV\_R94301

FWD

Fri 04/16/2021 to Fri 04/16/2021 UPDATED by NGRID 02/01/2021

(Import)

1530 Continuous 1600

UPNY CONED

3800 MW

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: CHGE

### SPRNBK\_TREMONT\_345\_X28

FWD

Sat 04/17/2021 to Mon 05/03/2021

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

4200 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### PLSNTVLY-WOOD\_ST\_345\_F30

FWD

Mon 04/19/2021 to Tue 04/20/2021 UPDATED by CONED 02/23/2021

(Import)

0001 Continuous 0200

UPNY CONED

4000 MW

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

### PLSNTVLY\_345KV\_RNS5

FWD

Mon 04/19/2021 to Tue 04/20/2021 UPDATED by CONED 02/23/2021

(Import)

0001 Continuous 0200

UPNY CONED

3800 MW

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

### DUNWODIE\_345KV\_6

FWD

Tue 04/20/2021 to Tue 04/20/2021 UPDATED by CONED 02/19/2021

(Import)

0201 Continuous 0230

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**NYISO TRANSFER LIMITATIONS**

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_8**

FWD

Tue 04/20/2021 to Tue 04/20/2021 UPDATED by CONED 02/19/2021  
0201 Continuous 0230

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**WOOD\_ST\_-PLSNTVLE\_345\_Y87**

FWD

Tue 04/20/2021 to Tue 04/20/2021 UPDATED by CONED 02/19/2021  
0201 Continuous 0230

(Import)

Work scheduled by: ConEd

UPNY CONED **5905 MW**  
Impacts Total Transfer Capability 315 MW  
TTC with All Lines In Service 6220 MW

**PLSNTVLE-DUNWODIE\_345\_W90**

FWD

Tue 04/20/2021 to Fri 04/23/2021 UPDATED by CONED 02/19/2021  
0201 Continuous 0159

(Import)

Work scheduled by: ConEd

UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 2220 MW  
TTC with All Lines In Service 6220 MW

**MAINESBG-WATRCURE\_345\_30**

FWD

Tue 04/20/2021 to Wed 04/21/2021  
0800 Continuous 1530

(Import)

Work scheduled by: NYSEG

SCH - PJ - NY **2300 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 2800 MW

**DUNWODIE\_345KV\_6**

FWD

Fri 04/23/2021 to Fri 04/23/2021 UPDATED by CONED 02/19/2021  
0130 Continuous 0159

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_8**

FWD

Fri 04/23/2021 to Fri 04/23/2021 UPDATED by CONED 02/19/2021  
0130 Continuous 0159

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**WOOD\_ST\_-PLSNTVLE\_345\_Y87**

FWD

Fri 04/23/2021 to Fri 04/23/2021 UPDATED by CONED 02/19/2021  
0130 Continuous 0159

(Import)

Work scheduled by: ConEd

UPNY CONED **5905 MW**  
Impacts Total Transfer Capability 315 MW  
TTC with All Lines In Service 6220 MW



# NYISO TRANSFER LIMITATIONS

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### KINTIGH\_-STA\_255\_\_345\_SH1-39

Mon 04/26/2021 to Fri 04/30/2021  
0700 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2350 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 3150 MW

### NIAGARA\_-KINTIGH\_\_345\_NS1-38

Mon 04/26/2021 to Fri 04/30/2021  
0700 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

### HOMRC\_NY-MAINS\_NY\_345\_47

Mon 04/26/2021 to Sat 05/29/2021  
0800 Continuous 1900

Work scheduled by: NYSEG

EXTENDED by NYSEG 03/10/2021

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### FRASER\_-COOPERS\_\_345\_33

Mon 04/26/2021 to Fri 04/30/2021  
0830 Continuous 1500

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2395 MW**  
Impacts Total Transfer Capability 580 MW  
TTC with All Lines In Service 2975 MW

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Fri 04/30/2021 to Mon 05/03/2021  
0001 Continuous 0200

Work scheduled by: ConEd

by CONED 03/12/2021

FWD  
(Import)  
UPNY CONED **5765 MW**  
Impacts Total Transfer Capability 455 MW  
TTC with All Lines In Service 6220 MW

### SCH-IMO-NYISO\_LIMIT\_1600

Sat 05/01/2021 to Sun 10/31/2021  
0001 Continuous 2359

Work scheduled by: IESO

UPDATED by IESO 05/03/2019

FWD  
(Import)  
SCH - OH - NY **1900 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 1950 MW

### NRTH1385-NOR HBR\_\_138\_601

Mon 05/03/2021 to Mon 05/24/2021  
0600 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_602**

Mon 05/03/2021 to Mon 05/24/2021  
0600 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

---

**NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_603**

Mon 05/03/2021 to Mon 05/24/2021  
0600 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

---

**NRTH1385-NOR HBR\_\_138\_602**

Mon 05/03/2021 to Mon 05/24/2021  
0600 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

---

**NRTH1385-NOR HBR\_\_138\_602 & NRTH1385-NOR HBR\_\_138\_603**

Mon 05/03/2021 to Mon 05/24/2021  
0600 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

---

**NRTH1385-NOR HBR\_\_138\_603**

Mon 05/03/2021 to Mon 05/24/2021  
0600 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

---

**NRTH1385-NRTHPORT\_138\_NNC**

Mon 05/03/2021 to Mon 05/24/2021  
0600 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

---

**CLAY\_\_-EDIC\_\_345\_2-15**

Mon 05/03/2021 to Fri 05/07/2021  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
OSWEGO EXPORT	<b>4850 MW</b>
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	5250 MW

**NYISO TRANSFER LIMITATIONS**

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**FIVEMILE-STOLLERD\_345\_29**

Mon 05/03/2021 to Fri 05/14/2021  
0700 Continuous 1400

Work scheduled by: NYSEG

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**PANNELL -CLAY\_345\_2**

Mon 05/03/2021 to Sun 05/30/2021  
0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

**HURLYAVE-ROSETON\_345\_303**

Mon 05/03/2021 to Fri 05/21/2021  
0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 2120 MW

TTC with All Lines In Service 6220 MW

**SHOR\_NPX-SHOREHAM\_138\_CSC**

Mon 05/03/2021 to Fri 05/07/2021  
0900 Continuous 1500

Work scheduled by: LI

FWD

REV

(Import) (Export)

SCH - NPX\_CSC

**0 MW****0 MW**

Impacts Total Transfer Capability 330 MW 330 MW

TTC with All Lines In Service 330 MW 330 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

Fri 05/07/2021 to Mon 05/10/2021  
0001 Continuous 0200

Work scheduled by: ConEd

by CONED 03/12/2021

FWD

(Import)

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

**EASTVIEW-SPRNBRK\_345\_W79**

Fri 05/07/2021 to Mon 05/10/2021  
0001 Continuous 0200

Work scheduled by: ConEd

by CONED 03/12/2021

FWD

(Import)

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

**SPRNBRK\_-TREMONT\_345\_X28**

Mon 05/10/2021 to Thu 05/13/2021  
0201 Continuous 2200

Work scheduled by: ConEd

by CONED 03/12/2021

FWD

(Import)

SPR/DUN-SOUTH

**4200 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CLAY\_\_\_\_-EDIC\_\_\_\_345\_1-16

Mon 05/10/2021 to Fri 05/14/2021  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

### MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 05/10/2021 to Tue 06/01/2021  
1200 Continuous 0659

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

### SPRNBRK\_\_345KV\_RS3 & SPRNBRK\_\_345KV\_RS4

Sat 05/15/2021 to Sat 05/15/2021  
0301 2230

Work scheduled by:

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

### DUNWODIE\_345KV\_5

Mon 05/17/2021 to Tue 05/18/2021 UPDATED by CE 03/10/2021  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### DUNWODIE\_345KV\_7

Mon 05/17/2021 to Tue 05/18/2021 UPDATED by CE 03/10/2021  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### SPRNBRK\_-DUNWODIE\_345\_W75

Mon 05/17/2021 to Tue 05/18/2021 UPDATED by CE 03/10/2021  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### SPRNBRK\_\_345KV\_RNS3

Mon 05/17/2021 to Tue 05/18/2021 UPDATED by CE 03/10/2021  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SAND\_BAR-PLATSBURG\_115\_PV20

Mon 05/17/2021 to Fri 07/02/2021

0600 Continuous 1800

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## E13THSTA-FARRAGUT\_345\_46

Sat 05/22/2021 to Sat 05/22/2021

0001 Continuous 1830

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

## NIAGARA\_-STA\_255\_345\_NH2

Mon 05/24/2021 to Fri 05/28/2021

0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

**2350 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 3150 MW

## VOLNEY\_-MARCY\_345\_19

Tue 06/01/2021 to Wed 06/02/2021

0700 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD

(Import)

CENTRAL EAST - VC

**2825 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 2975 MW

## VOLNEY\_-MARCY\_345\_19

Tue 06/01/2021 to Wed 06/02/2021

0700 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD

(Import)

OSWEGO EXPORT

**4900 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 5250 MW

## FRASER\_-GILBOA\_345\_GF5-35

Tue 06/01/2021 to Mon 06/07/2021

0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

## MOSES\_-ADIRNDICK\_230\_MA2

Tue 06/01/2021 to Sun 11/14/2021

0700 Continuous 1300

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-EDIC___345_UE1-7				FWD	
Thu 06/03/2021	to	Fri 06/04/2021		(Import)	
0700	Continuous	1730		OSWEGO EXPORT	5250 MW
Work scheduled by: NYPA			ARR: 19&16	Impacts Total Transfer Capability	0 MW
				TTC with All Lines In Service	5250 MW
PORTER___-ROTTDAM_230_30				FWD	
Thu 06/03/2021	to	Wed 09/15/2021	<u>UPDATED</u> <u>by NGRID</u> <u>01/19/2021</u>	(Import)	
0700	Continuous	0659		CENTRAL EAST - VC	2805 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	170 MW
				TTC with All Lines In Service	2975 MW
MARCY___345KV_CSC				FWD	
Sat 06/05/2021	to	Sat 06/05/2021		(Import)	
0700	Continuous	1730		CENTRAL EAST - VC	2925 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	50 MW
				TTC with All Lines In Service	2975 MW
ATHENS___-PLSNTVLY_345_91				FWD	
Tue 06/08/2021	to	Wed 06/16/2021		(Import)	
0600	Continuous	2000		UPNY CONED	3800 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	2420 MW
				TTC with All Lines In Service	6220 MW
GILBOA___-N.SCTLND_345_GNS-1				FWD	
Wed 06/09/2021	to	Wed 06/09/2021		(Import)	
0800	Daily	1200		CENTRAL EAST - VC	2520 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	455 MW
				TTC with All Lines In Service	2975 MW
BECK___-NIAGARA_345_PA301				FWD	REV
Wed 06/16/2021	to	Thu 06/17/2021		(Import)	(Export)
0500	Continuous	2330		SCH - OH - NY	900 MW 800 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1050 MW 900 MW
				TTC with All Lines In Service	1950 MW 1700 MW
LEEDS___-PLSNTVLY_345_92				FWD	
Thu 06/17/2021	to	Thu 06/24/2021		(Import)	
0600	Continuous	2000		UPNY CONED	3800 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	2420 MW
				TTC with All Lines In Service	6220 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### BECK\_\_\_\_-NIAGARA\_\_345\_PA301

Fri 06/25/2021 to Fri 06/25/2021  
0500 Continuous 1700  
Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	900 MW	800 MW
Impacts Total Transfer Capability	1050 MW	900 MW
TTC with All Lines In Service	1950 MW	1700 MW

### FRASANNX-COOPERS\_\_345\_UCC2-41

Fri 06/25/2021 to Tue 08/10/2021  
0700 Continuous 1530  
Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
CENTRAL EAST - VC	2500 MW
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

### MARCY\_\_\_\_-FRASANNX\_345\_UCC2-41

Fri 06/25/2021 to Tue 08/10/2021  
0700 Continuous 1530  
Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
CENTRAL EAST - VC	2500 MW
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

### BECK\_\_\_\_-NIAGARA\_\_345\_PA302

Mon 07/12/2021 to Fri 07/16/2021  
0500 Continuous 1700  
Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	900 MW	800 MW
Impacts Total Transfer Capability	1050 MW	900 MW
TTC with All Lines In Service	1950 MW	1700 MW

### NIAGARA\_\_345\_230\_AT4

Mon 07/19/2021 to Fri 07/30/2021 UPDATED by NYPA 02/19/2021  
0500 Continuous 1700  
Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1900 MW	1400 MW
Impacts Total Transfer Capability	50 MW	300 MW
TTC with All Lines In Service	1950 MW	1700 MW

### NIAGARA\_-STA\_255\_\_345\_NH2

Mon 07/26/2021 to Fri 07/30/2021 UPDATED by NYPA 02/19/2021  
0500 Continuous 1900  
Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	2350 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	3150 MW

### SAND\_BAR-PLATSBRG\_115\_PV20

Tue 08/03/2021 to Tue 08/03/2021  
0700 Continuous 1830  
Work scheduled by: NYPA

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## KINTIGH\_-STA\_255\_\_345\_SH1-39

Mon 08/09/2021 to Sun 08/15/2021

0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **2350 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 3150 MW

## NIAGARA\_-KINTIGH\_\_345\_NS1-38

Mon 08/09/2021 to Sun 08/15/2021

0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

## KINTIGH\_-STA\_255\_\_345\_SH1-39

Mon 08/16/2021 to Sun 08/22/2021

0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **2350 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 3150 MW

## NIAGARA\_-KINTIGH\_\_345\_NS1-38

Mon 08/16/2021 to Sun 08/22/2021

0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

## NIAGARA\_-STA\_255\_\_345\_NH2

Wed 09/01/2021 to Tue 09/21/2021

0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **2350 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 3150 MW

## FRASANNX-COOPERS\_\_345\_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021

0700 Continuous 1730

Work scheduled by: NYPA

**UPDATED**

**by NYISO 02/03/2021**

**ARR: 19**

FWD

(Import)

CENTRAL EAST - VC **2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

## MARCY\_-FRASANNX\_345\_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021

0700 Continuous 1730

Work scheduled by: NYPA

**UPDATED**

**by NYISO 02/03/2021**

**ARR: 19**

FWD

(Import)

CENTRAL EAST - VC **2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW



# NYISO TRANSFER LIMITATIONS

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PORTER\_\_-ROTTRDAM\_230\_30

Wed 09/15/2021 to Tue 11/30/2021  
0700 Continuous 1730  
Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2805 MW**  
Impacts Total Transfer Capability 170 MW  
TTC with All Lines In Service 2975 MW

## EDIC\_\_\_\_-N.SCTLND\_345\_14

Thu 09/16/2021 to Sun 11/14/2021  
0700 Continuous 1730  
Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **1670 MW**  
Impacts Total Transfer Capability 1305 MW  
TTC with All Lines In Service 2975 MW

## EDIC\_\_\_\_-N.SCTLND\_345\_14 & PORTER\_\_-ROTTRDAM\_230\_30

Thu 09/16/2021 to Sun 11/14/2021  
0700 1730  
Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **1500 MW**  
Impacts Total Transfer Capability 1475 MW  
TTC with All Lines In Service 2975 MW

## HURLYAVE-ROSETON\_\_345\_303

Thu 09/16/2021 to Sun 10/17/2021 **UPDATED by CHGE 09/22/2020**  
0800 Continuous 1600  
Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 2120 MW  
TTC with All Lines In Service 6220 MW

## HOMRC\_NY-MAINS\_NY\_345\_47

Sat 09/18/2021 to Fri 11/05/2021  
0800 Continuous 1600  
Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## PANNELL\_-CLAY\_\_\_\_345\_1

Mon 09/20/2021 to Fri 09/24/2021  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

## CLAY\_\_\_\_-EDIC\_\_\_\_345\_2-15

Mon 09/20/2021 to Sat 10/16/2021  
0700 Continuous 1730  
Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## KINTIGH\_-STA\_255\_\_345\_SH1-39

FWD

Mon 09/27/2021 to Wed 09/29/2021  
0500 Continuous 0459

UPDATEDby NYPA03/04/2021

(Import)

Work scheduled by: NYPA

DYSINGER EAST **2350 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 3150 MW

## NIAGARA\_-KINTIGH\_\_345\_NS1-38

FWD

Mon 09/27/2021 to Wed 09/29/2021  
0500 Continuous 0459

UPDATEDby NYPA03/04/2021

(Import)

Work scheduled by: NYPA

DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

## PANNELL\_-CLAY\_\_\_\_345\_2

FWD

Mon 09/27/2021 to Fri 10/01/2021  
0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

## W49TH\_ST\_345KV\_6

FWD

Tue 09/28/2021 to Tue 09/28/2021  
0100 Continuous 0130

UPDATEDby CONED01/15/2021

(Import)

Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

## E13THSTA-FARRAGUT\_345\_46

FWD

Tue 09/28/2021 to Tue 10/26/2021  
0100 Continuous 0300

UPDATEDby CONED01/15/2021

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## W49TH\_ST-E13THSTA\_345\_M55

FWD

Tue 09/28/2021 to Tue 10/26/2021  
0100 Continuous 0300

UPDATEDby CONED01/15/2021

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## KINTIGH\_-STA\_255\_\_345\_SH1-39

FWD

Wed 09/29/2021 to Wed 12/01/2021  
0500 Continuous 1900

Work scheduled by: NYPA

DYSINGER EAST **2350 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_-KINTIGH\_\_345\_NS1-38

Wed 09/29/2021 to Wed 12/01/2021  
0500 Continuous 1900

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

## LEEDS\_-HURLYAVE\_345\_301

Mon 10/18/2021 to Fri 11/19/2021  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 2120 MW  
TTC with All Lines In Service 6220 MW

## GOETHALS\_345KV\_5

Thu 10/21/2021 to Sat 11/20/2021 UPDATED by CONED 03/05/2021  
0001 Continuous 0200

Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## W49TH\_ST\_345KV\_6

Tue 10/26/2021 to Tue 10/26/2021 UPDATED by CONED 01/15/2021  
0230 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

## SCH-IMO-NYISO\_LIMIT\_1750

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019  
0001 Continuous 2359

Work scheduled by: IESO

FWD  
(Import)  
SCH - OH - NY **2050 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 2300 MW

## SCH-NYISO-IMO\_LIMIT\_1600

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019  
0001 Continuous 2359

Work scheduled by: IESO

REV  
(Export)  
SCH - OH - NY **1900 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 2000 MW

## LINDN\_CG-LNDVFT\_\_345\_V-3022

Tue 11/02/2021 to Fri 11/05/2021  
0800 Continuous 1500

Work scheduled by: PJM

FWD REV  
(Import) (Export)  
SCH - PJM\_VFT **0 MW 0 MW**  
Impacts Total Transfer Capability 315 MW 315 MW  
TTC with All Lines In Service 315 MW 315 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA\_-MARCY\_\_\_765\_MSU1 & PORTER\_-ROTTDAM\_230\_30

FWD

Mon 11/15/2021 to Tue 11/30/2021

(Import)

0100

1730

CENTRAL EAST - VC

**1500 MW**

Impacts Total Transfer Capability 1475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

CHATGUAY-MASSENA\_\_\_765\_7040

FWD

Mon 11/15/2021 to Tue 11/30/2021

(Import)

0100

Continuous

1859

MOSES SOUTH

**1550 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

CHATGUAY-MASSENA\_\_\_765\_7040

FWD

REV

Mon 11/15/2021 to Tue 11/30/2021

(Import) (Export)

0100

Continuous

1859

SCH - HQ - NY

**0 MW****0 MW**

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by: NYPA

MARCY\_\_\_765\_345\_AT1

FWD

Mon 11/15/2021 to Tue 11/30/2021

(Import)

0100

Continuous

1859

MOSES SOUTH

**1750 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

ARR: 19

MARCY\_\_\_765\_345\_AT2

FWD

Mon 11/15/2021 to Tue 11/30/2021

(Import)

0100

Continuous

1859

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

ARR: 19

MASSENA\_-MARCY\_\_\_765\_MSU1

FWD

Mon 11/15/2021 to Tue 11/30/2021

(Import)

0100

Continuous

1859

CENTRAL EAST - VC

**1670 MW**

Impacts Total Transfer Capability 1305 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

MASSENA\_-MARCY\_\_\_765\_MSU1

FWD

Mon 11/15/2021 to Tue 11/30/2021

(Import)

0100

Continuous

1859

MOSES SOUTH

**500 MW**

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA_-MARCY_765_MSU1</b>			FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	(Export)
0100	Continuous	1859	SCH - HQ - NY	<b>475 MW</b> <b>1000 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1025 MW 0 MW
			TTC with All Lines In Service	1500 MW 1000 MW
<b>MASSENA_-MARCY_765_MSU1</b>			FWD	
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	
0100	Continuous	1859	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
<b>MASSENA_-MARCY_765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>			FWD	
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	
0100		1859	MOSES SOUTH	<b>500 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
<b>MOSES_-MASSENA_230_MMS1 &amp; MOSES_-MASSENA_230_MMS2</b>			FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	(Export)
0100		1859	SCH - HQ - NY	<b>850 MW</b> <b>0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	650 MW 1000 MW
			TTC with All Lines In Service	1500 MW 1000 MW
<b>MOSES_-MASSENA_230_MMS1 &amp; MOSES_-MASSENA_230_MMS2</b>			FWD	
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	
0100		1859	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
<b>STLAWRNC-MOSES_230_L33P &amp; MASSENA_-MARCY_765_MSU1</b>			FWD	
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	
0100		1859	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
<b>STLAWRNC-MOSES_230_L33P &amp; MOSES_-MASSENA_230_MMS1 &amp; MOSES_-MASSENA_230_MMS2</b>			FWD	
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	
0100		1859	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## FRASER\_\_\_345\_FRASER SVC

Wed 12/01/2021 to Mon 02/28/2022  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2935 MW**  
Impacts Total Transfer Capability 40 MW  
TTC with All Lines In Service 2975 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MAI

Wed 12/01/2021 to Tue 05/31/2022  
0700 Continuous 1300

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## MOTHAVN-RAINEY\_\_\_345\_Q12

Thu 12/02/2021 to Wed 12/22/2021  
0201 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## NIAGARA\_-STA\_255\_\_\_345\_NH2

Thu 12/02/2021 to Thu 01/13/2022  
0500 Continuous 1900

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2350 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 3150 MW

## N.SCTLND-ALPS\_\_\_345\_2

Mon 05/02/2022 to Mon 05/09/2022  
0600 Daily 1800

Work scheduled by: NGrid

FWD  
(Import)  
SCH - NE - NY **750 MW**  
Impacts Total Transfer Capability 650 MW  
TTC with All Lines In Service 1400 MW

## N.SCTLND-ALPS\_\_\_345\_2

Mon 05/02/2022 to Mon 05/09/2022  
0600 Daily 1800

Work scheduled by: NGrid

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **100 MW 100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

## HOMRC\_NY-MAINS\_NY\_345\_47

Fri 05/20/2022 to Fri 05/27/2022  
0800 Continuous 1600

Work scheduled by: PJM

UPDATED by PJM 11/19/2020

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**NYISO TRANSFER LIMITATIONS**

Sunday ,March 14, 2021 to Tuesday ,September13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOMR\_NYW-PIERC\_NY\_345\_48

Fri 05/20/2022 to Fri 05/27/2022 UPDATED by PJM 11/19/2020

0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

MOSES-ADIRNDCK\_230\_MA2

Wed 06/01/2022 to Mon 11/14/2022

0700 Continuous 1300

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW