

# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Wed 06/30/2021 EXT FORCE by CONED 08/28/2020

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Wed 06/30/2021

0001 2359

Work scheduled by:

FWD REV  
(Import) (Export)

SCH - PJ - NY

Impacts Total Transfer Capability 250 MW 50 MW

TTC with All Lines In Service 2800 MW 1950 MW

## MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Wed 06/30/2021 EXT FORCE by CONED 08/28/2020

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## STLAWRNC-MOSES\_230\_L33P

Mon 04/30/2018 to Mon 10/31/2022 EXT FORCE by IESO 10/01/2020

0456 Continuous 1600

Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## NEWBRDGE\_345\_138\_BK\_1

Wed 09/02/2020 to Tue 02/01/2022 EXT FORCE by LI 01/12/2021

1807 Continuous 2359

Work scheduled by: LI

FWD  
(Import)

SCH - PJM\_NEPTUNE

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

## SPRNBRK\_-EGRDNCTR\_345\_Y49

Thu 10/01/2020 to Mon 04/19/2021 EXT FORCE by LI 02/23/2021

0404 Continuous 2359

Work scheduled by: LI

FWD  
(Import)

CONED - LIPA

Impacts Total Transfer Capability 725 MW

TTC with All Lines In Service 1500 MW

## EGRDNCTY\_345\_138\_AT2

Sat 10/10/2020 to Mon 04/19/2021 EXT FORCE by LI 02/23/2021

1815 Continuous 2359

Work scheduled by: LI

FWD  
(Import)

CONED - LIPA

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EGRDNCTY\_345\_138\_AT1**

FWD

Sat 10/10/2020 to Mon 04/19/2021

EXT FORCE by LI 02/23/2021

(Import)

1856 Continuous 2359

CONED - LIPA

**1250 MW**

Work scheduled by: LI

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

**SCH-IMO-NYISO\_LIMIT\_1750**

FWD

Sun 11/01/2020 to Fri 04/30/2021

UPDATED by IESO 05/03/2019

(Import)

0001 Continuous 2359

SCH - OH - NY

**2050 MW**

Work scheduled by: IESO

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 2300 MW

**SCH-NYISO-IMO\_LIMIT\_1600**

REV

Sun 11/01/2020 to Fri 04/30/2021

UPDATED by IESO 05/03/2019

(Export)

0001 Continuous 2359

SCH - OH - NY

**1900 MW**

Work scheduled by: IESO

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 2000 MW

**SAND\_BAR-PLATSBURG\_115\_PV20**

Tue 02/23/2021 to Mon 05/17/2021

UPDATED by NYISO 03/16/2021

1801 Continuous 0559

SCH - NE - NY

Work scheduled by: ISONE

Impacts Total Transfer Capability

TTC with All Lines In Service

**W49TH\_ST\_345KV\_8**

FWD

Tue 03/02/2021 to Sun 05/02/2021

EXTENDED by CONED 04/10/2021

(Import)

0201 Continuous 0200

SCH - PJM\_HTP

**300 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

**PORTER\_-ROTTRDAM\_230\_31**

FWD

Tue 03/02/2021 to Mon 05/31/2021

UPDATED by NGRID 03/10/2021

(Import)

0600 Continuous 1730

CENTRAL EAST - VC

**2805 MW**

Work scheduled by: NGrid

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

**MOSES\_-ADIRNDCK\_230\_MAI**

FWD

Tue 03/02/2021 to Mon 05/10/2021

UPDATED by NYPA 02/11/2021

(Import)

0700 Continuous 1159

MOSES SOUTH

**2300 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LADENTWN-BUCHAN\_S\_345\_Y88

FWD

Tue 03/09/2021 to Fri 04/09/2021

EXTENDEDby CE04/02/2021

(Import)

0001 Continuous 0200

UPNY CONED

**5930 MW**

Impacts Total Transfer Capability 290 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

## SCH-NYISO-HQ\_CEDARS\_LIMIT\_0

REV

Mon 03/15/2021 to Thu 04/08/2021

UPDATEDby HQ04/08/2021

(Export)

0500 Continuous 2000

SCH - HQ\_CEDARS

**0 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 100 MW

Work scheduled by: HQ

## W49TH\_ST\_345KV\_6

FWD

Sun 03/21/2021 to Sun 05/02/2021

EXTENDEDby CONED04/10/2021

(Import)

0001 Continuous 0200

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

## EDIC\_\_\_\_-N.SCTLND\_345\_14 & PORTER\_\_\_\_-ROTTDAM\_230\_31

FWD

Mon 03/22/2021 to Mon 05/31/2021

(Import)

0600 1730

CENTRAL EAST - VC

**1500 MW**

Impacts Total Transfer Capability 1475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

## EDIC\_\_\_\_-N.SCTLND\_345\_14

FWD

Mon 03/22/2021 to Mon 05/31/2021

(Import)

0600 Continuous 1830

UPDATEDby NGRID03/10/2021

CENTRAL EAST - VC

**1670 MW**

Impacts Total Transfer Capability 1305 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

## S.RIPLEY-DUNKIRK\_230\_68

Mon 03/29/2021 to Fri 04/09/2021

UPDATEDby NYISO03/30/2021

1129 Continuous 1700

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NGrid

## ROCHESTR-PANNELL\_345\_RP2

FWD

Wed 03/31/2021 to Sat 04/10/2021

(Import)

0500 Continuous 2016

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDN_CG-LNDVFT___345_V-3022				FWD	REV
Sun 04/04/2021	to	Sat 04/10/2021		(Import)	(Export)
1400	Continuous	1400		SCH - PJM_VFT	0 MW
Work scheduled by: PJM				Impacts Total Transfer Capability	315 MW
				TTC with All Lines In Service	315 MW
WATRCURE-OAKDALE___345_31					
Mon 04/05/2021	to	Thu 04/08/2021		SCH - PJ - NY	
0800	Daily(No Weekends)	1500		Impacts Total Transfer Capability	
Work scheduled by: NYSEG				TTC with All Lines In Service	
NINEMILE-CLAY___345_8				FWD	
Tue 04/06/2021	to	Sun 04/11/2021	<u>UPDATED</u> <u>by NGRID</u> <u>04/03/2021</u>	(Import)	
1600	Daily	0500		OSWEGO EXPORT	5150 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	5250 MW
N.SCTLND-LEEDS___345_93				FWD	
Wed 04/07/2021	to	Wed 04/07/2021		(Import)	
0700	Daily(No Weekends)	1600		CENTRAL EAST - VC	2650 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	325 MW
				TTC with All Lines In Service	2975 MW
DUNWODIE_345KV_3				FWD	
Wed 04/07/2021	to	Wed 04/07/2021	<u>EXT FORCE</u> <u>by CONED</u> <u>04/02/2021</u>	(Import)	
2230	Continuous	2300		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_4				FWD	
Wed 04/07/2021	to	Wed 04/07/2021	<u>EXT FORCE</u> <u>by CONED</u> <u>04/02/2021</u>	(Import)	
2230	Continuous	2300		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
PLSNTVLE-DUNWODIE_345_W89				FWD	
Wed 04/07/2021	to	Wed 04/07/2021	<u>EXT FORCE</u> <u>by CONED</u> <u>04/02/2021</u>	(Import)	
2230	Continuous	2300		UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	2220 MW
				TTC with All Lines In Service	6220 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**LEEDS\_\_\_\_345KV\_R94301**

FWD

Thu 04/08/2021 to Thu 04/08/2021

(Import)

0700 Daily(No Weekends) 0800

UPNY CONED

**3800 MW**

Work scheduled by: NGrid

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

**N.SCTLND-LEEDS\_\_\_\_345\_94**

FWD

Thu 04/08/2021 to Thu 04/08/2021

(Import)

0700 Daily(No Weekends) 1600

CENTRAL EAST - VC

**2650 MW**

Work scheduled by: NGrid

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

**MARCY\_\_\_\_345KV\_CSC**

FWD

Thu 04/08/2021 to Thu 04/08/2021

(Import)

0700 Continuous 1830

CENTRAL EAST - VC

**2925 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

**LEEDS\_\_\_\_345KV\_R94301**

FWD

Thu 04/08/2021 to Thu 04/08/2021

(Import)

1500 Daily(No Weekends) 1600

UPNY CONED

**3800 MW**

Work scheduled by: NGrid

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

**MOTTHAVN-RAINEY\_\_\_\_345\_Q11**

FWD

Thu 04/08/2021 to Mon 04/12/2021

(Import)

2309 Continuous 2359

**EXT FORCE by CONED 04/11/2021**

SPR/DUN-SOUTH

**3800 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**CHAT\_DC\_GC1**

FWD

Sat 04/10/2021 to Sat 04/10/2021

(Import)

0600 Continuous 1600

MOSES SOUTH

**2850 MW**

Work scheduled by: HQ

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC1**

REV

Sat 04/10/2021 to Sat 04/10/2021

(Export)

0600 Continuous 1600

SCH - HQ - NY

**500 MW**

Work scheduled by: HQ

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## S.RIPLEY-DUNKIRK\_\_230\_68

Mon 04/12/2021 to Fri 04/23/2021

0630 Continuous 1700

Work scheduled by: NGrid

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## LEEDS\_\_345KV\_R94301

Mon 04/12/2021 to Mon 04/12/2021

0800 Continuous 0830

Work scheduled by: CHGE

UPDATED

by NGRID 02/01/2021

FWD  
(Import)

UPNY CONED **3800 MW**

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

## LEEDS\_\_-HURLYAVE\_345\_301

Mon 04/12/2021 to Fri 04/16/2021

0800 Continuous 1600

Work scheduled by: CHGE

UPDATED

by NGRID 02/01/2021

FWD  
(Import)

UPNY CONED **4100 MW**

Impacts Total Transfer Capability 2120 MW

TTC with All Lines In Service 6220 MW

## NIAGARA\_-STA\_255\_\_345\_NH2

Fri 04/16/2021 to Fri 04/16/2021

0500 Continuous 1700

Work scheduled by: NYPA

CANCELLED

by NYPA 04/08/2021

FWD  
(Import)

DYSINGER EAST **2350 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 3150 MW

## LEEDS\_\_345KV\_R94301

Fri 04/16/2021 to Fri 04/16/2021

1530 Continuous 1600

Work scheduled by: CHGE

UPDATED

by NGRID 02/01/2021

FWD  
(Import)

UPNY CONED **3800 MW**

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

## DUNWODIE\_345KV\_6

Tue 04/20/2021 to Tue 04/20/2021

0201 Continuous 0230

Work scheduled by: ConEd

UPDATED

by CONED 02/19/2021

FWD  
(Import)

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

## DUNWODIE\_345KV\_8

Tue 04/20/2021 to Tue 04/20/2021

0201 Continuous 0230

Work scheduled by: ConEd

UPDATED

by CONED 02/19/2021

FWD  
(Import)

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## WOOD\_ST\_-PLSNTVLE\_345\_Y87

FWD

Tue 04/20/2021 to Tue 04/20/2021 UPDATED by CONED 02/19/2021  
0201 Continuous 0230

(Import)

Work scheduled by: ConEd

UPNY CONED **5905 MW**  
Impacts Total Transfer Capability 315 MW  
TTC with All Lines In Service 6220 MW

## PLSNTVLE-DUNWODIE\_345\_W90

FWD

Tue 04/20/2021 to Fri 04/23/2021 UPDATED by CONED 02/19/2021  
0201 Continuous 0159

(Import)

Work scheduled by: ConEd

UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 2220 MW  
TTC with All Lines In Service 6220 MW

## MAINESBG-WATRCURE\_345\_30

FWD

Tue 04/20/2021 to Wed 04/21/2021  
0800 Continuous 1530

(Import)

Work scheduled by: NYSEG

SCH - PJ - NY **2300 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 2800 MW

## DUNWODIE\_345KV\_6

FWD

Fri 04/23/2021 to Fri 04/23/2021 UPDATED by CONED 02/19/2021  
0130 Continuous 0159

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## DUNWODIE\_345KV\_8

FWD

Fri 04/23/2021 to Fri 04/23/2021 UPDATED by CONED 02/19/2021  
0130 Continuous 0159

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## WOOD\_ST\_-PLSNTVLE\_345\_Y87

FWD

Fri 04/23/2021 to Fri 04/23/2021 UPDATED by CONED 02/19/2021  
0130 Continuous 0159

(Import)

Work scheduled by: ConEd

UPNY CONED **5905 MW**  
Impacts Total Transfer Capability 315 MW  
TTC with All Lines In Service 6220 MW

## PLSNTVLY-WOOD\_ST\_345\_F30

FWD

Fri 04/23/2021 to Fri 04/23/2021 UPDATED by CONED 04/02/2021  
0201 Continuous 0230

(Import)

Work scheduled by: ConEd

UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 2220 MW  
TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS5					FWD	
Fri 04/23/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/02/2021</u>	(Import)
0201	Continuous	0230				
Work scheduled by: ConEd					UPNY CONED	3800 MW
					Impacts Total Transfer Capability	2420 MW
					TTC with All Lines In Service	6220 MW
MILLWOOD-EASTVIEW_345_W82					FWD	
Fri 04/23/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/02/2021</u>	(Import)
0201	Continuous	1800				
Work scheduled by: ConEd					UPNY CONED	5985 MW
					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	6220 MW
MILLWOOD_345KV_18					FWD	
Fri 04/23/2021	to	Sat 04/24/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/02/2021</u>	(Import)
0201	Continuous	2200				
Work scheduled by: ConEd					UPNY CONED	4350 MW
					Impacts Total Transfer Capability	1870 MW
					TTC with All Lines In Service	6220 MW
CHAT_DC_GC1					FWD	
Sat 04/24/2021	to	Sun 04/25/2021				(Import)
2000	Continuous	0500				
Work scheduled by: HQ					MOSES SOUTH	2850 MW
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
CHAT_DC_GC1					REV	
Sat 04/24/2021	to	Sun 04/25/2021				(Export)
2000	Continuous	0500				
Work scheduled by: HQ					SCH - HQ - NY	500 MW
					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
PLSNTVLY-WOOD_ST_345_F30					FWD	
Mon 04/26/2021	to	Tue 04/27/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/02/2021</u>	(Import)
0001	Continuous	0200				
Work scheduled by: ConEd					UPNY CONED	4000 MW
					Impacts Total Transfer Capability	2220 MW
					TTC with All Lines In Service	6220 MW
PLSNTVLY_345KV_RNS5					FWD	
Mon 04/26/2021	to	Tue 04/27/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/02/2021</u>	(Import)
0001	Continuous	0200				
Work scheduled by: ConEd					UPNY CONED	3800 MW
					Impacts Total Transfer Capability	2420 MW
					TTC with All Lines In Service	6220 MW



# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**KINTIGH\_-STA\_255\_\_345\_SH1-39**

FWD

Mon 04/26/2021 to Fri 04/30/2021

(Import)

0700 Continuous 1700

DYSINGER EAST **2350 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**NIAGARA\_-KINTIGH\_\_345\_NS1-38**

FWD

Mon 04/26/2021 to Fri 04/30/2021

(Import)

0700 Continuous 1700

DYSINGER EAST **1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**HOMRC\_NY-MAINS\_NY\_345\_47**

Mon 04/26/2021 to Sat 05/29/2021

**EXTENDED by NYSEG 03/10/2021**

0800 Continuous 1900

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYSEG

**FRASER\_-COOPERS\_\_345\_33**

FWD

Mon 04/26/2021 to Fri 04/30/2021

(Import)

0830 Continuous 1500

CENTRAL EAST - VC **2395 MW**

Impacts Total Transfer Capability 580 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

**ALCOA\_PA\_115KV\_R8105**

FWD

Tue 04/27/2021 to Thu 04/29/2021

(Import)

0630 Continuous 1830

MOSES SOUTH **3100 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NGrid

**MOTTHAVN-RAINEY\_\_345\_Q11**

FWD

Wed 04/28/2021 to Sat 05/08/2021

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**W49TH\_ST\_345KV\_5**

FWD

Fri 04/30/2021 to Fri 04/30/2021

(Import)

0201 Continuous 0231

SCH - PJM\_HTP **300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## W49TH\_ST\_345KV\_7

Fri 04/30/2021 to Fri 04/30/2021  
0201 Continuous 0231

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

Fri 04/30/2021 to Sun 05/09/2021  
0700 Continuous 2359

Work scheduled by: ConEd

UPDATED by CONED 04/07/2021

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 1870 MW  
TTC with All Lines In Service 6220 MW

## SCH-IMO-NYISO\_LIMIT\_1600

Sat 05/01/2021 to Sun 10/31/2021  
0001 Continuous 2359

Work scheduled by: IESO

UPDATED by IESO 05/03/2019

FWD  
(Import)  
SCH - OH - NY **1900 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 1950 MW

## NRTH1385-NOR HBR\_\_138\_601

Mon 05/03/2021 to Mon 05/24/2021  
0600 Continuous 2359

Work scheduled by: LI

FWD	REV
(Import)	(Export)
SCH - NPX_1385 <b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability 100 MW	100 MW
TTC with All Lines In Service 200 MW	200 MW

## NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_602

Mon 05/03/2021 to Mon 05/24/2021  
0600 2359

Work scheduled by:

FWD	REV
(Import)	(Export)
SCH - NPX_1385 <b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability 200 MW	200 MW
TTC with All Lines In Service 200 MW	200 MW

## NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_603

Mon 05/03/2021 to Mon 05/24/2021  
0600 2359

Work scheduled by:

FWD	REV
(Import)	(Export)
SCH - NPX_1385 <b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability 200 MW	200 MW
TTC with All Lines In Service 200 MW	200 MW

## NRTH1385-NOR HBR\_\_138\_602

Mon 05/03/2021 to Mon 05/24/2021  
0600 Continuous 2359

Work scheduled by: LI

FWD	REV
(Import)	(Export)
SCH - NPX_1385 <b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability 100 MW	100 MW
TTC with All Lines In Service 200 MW	200 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NRTH1385-NOR HBR\_\_138\_602 & NRTH1385-NOR HBR\_\_138\_603

Mon 05/03/2021 to Mon 05/24/2021  
0600 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

### NRTH1385-NOR HBR\_\_138\_603

Mon 05/03/2021 to Mon 05/24/2021  
0600 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

### NRTH1385-NRTHPORT\_138\_NNC

Mon 05/03/2021 to Mon 05/24/2021  
0600 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

### CLAY\_\_-EDIC\_\_345\_2-15

Mon 05/03/2021 to Fri 05/07/2021  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
OSWEGO EXPORT	4850 MW
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	5250 MW

### FIVEMILE-STOLLERD\_345\_29

Mon 05/03/2021 to Fri 05/14/2021  
0700 Continuous 1400

Work scheduled by: NYSEG

SCH - PJ - NY	
Impacts Total Transfer Capability	
TTC with All Lines In Service	

### PANNELL\_-CLAY\_\_345\_2

Mon 05/03/2021 to Sun 05/30/2021  
0700 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
WEST CENTRAL	1300 MW
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	2250 MW

### HURLYAVE-ROSETON\_\_345\_303

Mon 05/03/2021 to Fri 05/21/2021  
0800 Continuous 1600

Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	4100 MW
Impacts Total Transfer Capability	2120 MW
TTC with All Lines In Service	6220 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SHOR\_NPX-SHOREHAM\_138\_CSC**

Mon 05/03/2021 to Sat 05/08/2021 **EXTENDED** **by ISONE** **03/15/2021**  
0900 Continuous 1600

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

**ROTTDAM-EASTOVER\_230\_38**

Tue 05/04/2021 to Tue 05/04/2021  
0830 Daily(No Weekends) 1130

Work scheduled by: NGrid

**ARR: 77**

	REV
	(Export)
SCH - NE - NY	<b>1400 MW</b>
Impacts Total Transfer Capability	200 MW
TTC with All Lines In Service	1600 MW

**RAMAPO\_\_-BUCHAN\_N\_345\_Y94**

Fri 05/07/2021 to Sun 05/09/2021 **UPDATED** **by CONED** **04/07/2021**  
0001 Continuous 2359

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>5765 MW</b>
Impacts Total Transfer Capability	455 MW
TTC with All Lines In Service	6220 MW

**W49TH\_ST\_345KV\_5**

Fri 05/07/2021 to Fri 05/07/2021  
0130 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
SCH - PJM_HTP	<b>300 MW</b>
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

**W49TH\_ST\_345KV\_7**

Fri 05/07/2021 to Fri 05/07/2021  
0130 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
SCH - PJM_HTP	<b>300 MW</b>
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

**EASTVIEW-SPRNBK\_\_345\_W79**

Sat 05/08/2021 to Sun 05/09/2021 **UPDATED** **by CONED** **04/07/2021**  
0700 Continuous 2359

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>4350 MW</b>
Impacts Total Transfer Capability	1870 MW
TTC with All Lines In Service	6220 MW

**W49TH\_ST\_345KV\_7**

Mon 05/10/2021 to Mon 05/10/2021  
0001 Continuous 0030

Work scheduled by: ConEd

	FWD
	(Import)
SCH - PJM_HTP	<b>300 MW</b>
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_8**

Mon 05/10/2021 to Mon 05/10/2021  
0001 Continuous 0030  
Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **450 MW**  
Impacts Total Transfer Capability 210 MW  
TTC with All Lines In Service 660 MW

**HUDSONTP-W49TH\_ST\_345\_Y56**

Mon 05/10/2021 to Thu 05/13/2021  
0001 Continuous 2300  
Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

**SPRNBK\_-TREMONT\_345\_X28**

Mon 05/10/2021 to Wed 05/26/2021 UPDATED by CONED 03/18/2021  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **4200 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

**CLAY\_-EDIC\_345\_1-16**

Mon 05/10/2021 to Fri 05/14/2021  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

**MOSES\_-ADIRNDCK\_230\_MA2**

Mon 05/10/2021 to Tue 06/01/2021  
1200 Continuous 0659  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**W49TH\_ST\_345KV\_7**

Thu 05/13/2021 to Thu 05/13/2021  
2230 Continuous 2300  
Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_8**

Thu 05/13/2021 to Thu 05/13/2021  
2230 Continuous 2300  
Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **450 MW**  
Impacts Total Transfer Capability 210 MW  
TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CRICKVLY-PLSNTVLY\_345\_F83

Fri 05/14/2021 to Fri 05/14/2021  
0001 Continuous 2200  
Work scheduled by: ConEd

FWD  
(Import)  
SCH - NE - NY **350 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 1400 MW

### CRICKVLY-PLSNTVLY\_345\_F83

Fri 05/14/2021 to Fri 05/14/2021  
0001 Continuous 2200  
Work scheduled by: ConEd

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **100 MW 100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

### NRTH1385-NOR HBR\_138\_601 & CRICKVLY-PLSNTVLY\_345\_F83

Fri 05/14/2021 to Fri 05/14/2021  
0001 2200  
Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **0 MW 0 MW**  
Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 200 MW 200 MW

### NRTH1385-NOR HBR\_138\_602 & CRICKVLY-PLSNTVLY\_345\_F83

Fri 05/14/2021 to Fri 05/14/2021  
0001 2200  
Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **0 MW 0 MW**  
Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 200 MW 200 MW

### NRTH1385-NOR HBR\_138\_603 & CRICKVLY-PLSNTVLY\_345\_F83

Fri 05/14/2021 to Fri 05/14/2021  
0001 2200  
Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **0 MW 0 MW**  
Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 200 MW 200 MW

### BUCHAN\_N-EASTVIEW\_345\_W93

Fri 05/14/2021 to Sat 05/15/2021  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 1870 MW  
TTC with All Lines In Service 6220 MW

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Fri 05/14/2021 to Sat 05/15/2021  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **5765 MW**  
Impacts Total Transfer Capability 455 MW  
TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4					FWD
Sat 05/15/2021	to	Sat 05/15/2021			(Import)
0301		2230		SPR/DUN-SOUTH	3200 MW
Work scheduled by:					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_5					FWD
Mon 05/17/2021	to	Tue 05/18/2021	<u>UPDATED</u>	<u>by CE</u> <u>03/15/2021</u>	(Import)
0201	Continuous	0200		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_7					FWD
Mon 05/17/2021	to	Tue 05/18/2021	<u>UPDATED</u>	<u>by CE</u> <u>03/15/2021</u>	(Import)
0201	Continuous	0200		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
SPRNBK_-DUNWODIE_345_W75					FWD
Mon 05/17/2021	to	Tue 05/18/2021	<u>UPDATED</u>	<u>by CE</u> <u>03/15/2021</u>	(Import)
0201	Continuous	0200		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
SPRNBK__345KV_RNS3					FWD
Mon 05/17/2021	to	Tue 05/18/2021	<u>UPDATED</u>	<u>by CE</u> <u>03/15/2021</u>	(Import)
0201	Continuous	0200		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
NIAGARA_-STA_255__345_NH2					FWD
Mon 05/17/2021	to	Fri 05/21/2021	<u>UPDATED</u>	<u>by NYPA</u> <u>03/23/2021</u>	(Import)
0500	Continuous	1700		DYSINGER EAST	2350 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 3150 MW
SAND_BAR-PLATSBRG_115_PV20					
Mon 05/17/2021	to	Fri 07/02/2021			SCH - NE - NY
0600	Continuous	1800			Impacts Total Transfer Capability
Work scheduled by: ISONE					TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## GOETHALS\_345KV\_5

Wed 05/19/2021 to Mon 05/24/2021 EXTENDED by CE 04/05/2021

0100 Continuous 0200

Work scheduled by: ConEd

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

## LINDEN\_\_GOETHALS\_230\_A2253

Wed 05/19/2021 to Mon 05/24/2021 EXTENDED by CE 04/05/2021

0100 Continuous 0200

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2050 MW</b>	<b>1150 MW</b>
Impacts Total Transfer Capability	150 MW	100 MW
TTC with All Lines In Service	2200 MW	1250 MW

## LINDEN\_\_GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402

Wed 05/19/2021 to Mon 05/24/2021

0100 0200

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2000 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

## LINDEN\_\_GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_\_-FARRAGUT\_345\_C3403

Wed 05/19/2021 to Mon 05/24/2021

0100 0200

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2000 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

## LINDEN\_\_GOETHALS\_230\_A2253 & MARION\_\_-FARRAGUT\_345\_C3403

Wed 05/19/2021 to Mon 05/24/2021

0100 0200

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2000 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

## BUCHAN\_S-MILLWOOD\_345\_W97

Thu 05/20/2021 to Sat 05/22/2021

0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>6135 MW</b>
Impacts Total Transfer Capability	85 MW
TTC with All Lines In Service	6220 MW

## W49TH\_ST\_345KV\_6

Thu 05/20/2021 to Sat 05/22/2021 UPDATED by CONED 03/30/2021

0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
SCH - PJM_HTP	<b>300 MW</b>
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW



# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST-E13THSTA\_345\_M55**

FWD

Thu 05/20/2021 to Mon 05/24/2021 UPDATED by CONED 03/30/2021

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**E13THSTA-FARRAGUT\_345\_46**

FWD

Sat 05/22/2021 to Mon 05/24/2021 UPDATED by CONED 03/30/2021

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**PLSNTVLY-WOOD\_ST\_345\_F31**

FWD

Mon 05/24/2021 to Tue 05/25/2021

(Import)

0001 Continuous 0159

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

**PLSNTVLY\_345KV\_RNS4**

FWD

Mon 05/24/2021 to Tue 05/25/2021

(Import)

0001 Continuous 0159

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

**W49TH\_ST\_345KV\_6**

FWD

Mon 05/24/2021 to Mon 05/24/2021 UPDATED by CONED 03/30/2021

(Import)

0130 Continuous 0200

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**ROSETON\_-EFISHKIL\_345\_RFK305**

FWD

Wed 05/26/2021 to Thu 05/27/2021

(Import)

0001 Continuous 0200

UPNY CONED

**5990 MW**

Impacts Total Transfer Capability 230 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

**VOLNEY\_-MARCY\_345\_19**

FWD

Tue 06/01/2021 to Wed 06/02/2021

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

**2825 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 19**

# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## VOLNEY\_\_-MARCY\_\_\_\_345\_19

Tue 06/01/2021 to Wed 06/02/2021  
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
OSWEGO EXPORT **4900 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 5250 MW

## FRASER\_\_-GILBOA\_\_\_\_345\_GF5-35

Tue 06/01/2021 to Mon 06/07/2021  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

## MOSES\_\_-ADIRNDCK\_230\_MA2

Tue 06/01/2021 to Sun 11/14/2021  
0700 Continuous 1300

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## MARCY\_\_-EDIC\_\_\_\_345\_UE1-7

Thu 06/03/2021 to Fri 06/04/2021  
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19&amp;16

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

## PORTER\_\_-ROTTRDAM\_230\_30

Thu 06/03/2021 to Wed 09/15/2021  
0700 Continuous 0659

Work scheduled by: NGrid

UPDATED by NGRID 01/19/2021

FWD  
(Import)  
CENTRAL EAST - VC **2805 MW**  
Impacts Total Transfer Capability 170 MW  
TTC with All Lines In Service 2975 MW

## MARCY\_\_\_\_345KV\_CSC

Sat 06/05/2021 to Sat 06/05/2021  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

## ATHENS\_\_-PLSNTVLY\_345\_91

Tue 06/08/2021 to Wed 06/16/2021  
0600 Continuous 2000

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 2420 MW  
TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## GILBOA\_\_-N.SCTLND\_345\_GNS-1

Wed 06/09/2021 to Wed 06/09/2021  
0800 Daily 1200

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2520 MW**  
Impacts Total Transfer Capability 455 MW  
TTC with All Lines In Service 2975 MW

## BECK\_\_\_\_-NIAGARA\_345\_PA301

Wed 06/16/2021 to Thu 06/17/2021  
0500 Continuous 2330

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **900 MW 800 MW**  
Impacts Total Transfer Capability 1050 MW 900 MW  
TTC with All Lines In Service 1950 MW 1700 MW

## LEEDS\_\_-PLSNTVLY\_345\_92

Thu 06/17/2021 to Thu 06/24/2021  
0600 Continuous 2000

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 2420 MW  
TTC with All Lines In Service 6220 MW

## BECK\_\_\_\_-NIAGARA\_345\_PA301

Fri 06/25/2021 to Fri 06/25/2021  
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **900 MW 800 MW**  
Impacts Total Transfer Capability 1050 MW 900 MW  
TTC with All Lines In Service 1950 MW 1700 MW

## FRASANNX-COOPERS\_\_345\_UCC2-41

Fri 06/25/2021 to Tue 08/10/2021  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

## MARCY\_\_-FRASANNX\_345\_UCC2-41

Fri 06/25/2021 to Tue 08/10/2021  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

## BECK\_\_\_\_-NIAGARA\_345\_PA302

Mon 07/12/2021 to Fri 07/16/2021  
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **900 MW 800 MW**  
Impacts Total Transfer Capability 1050 MW 900 MW  
TTC with All Lines In Service 1950 MW 1700 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_\_345\_230\_AT4

Mon 07/19/2021 to Fri 07/30/2021  
0500 Continuous 1700

UPDATED by NYPA 02/19/2021

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1900 MW</b>	<b>1400 MW</b>
Impacts Total Transfer Capability	50 MW	300 MW
TTC with All Lines In Service	1950 MW	1700 MW

## NIAGARA\_-STA\_255\_\_345\_NH2

Mon 07/26/2021 to Fri 07/30/2021  
0500 Continuous 1900

UPDATED by NYPA 02/19/2021

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>2350 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	3150 MW

## SAND\_BAR-PLATSBURG\_115\_PV20

Tue 08/03/2021 to Tue 08/03/2021  
0700 Continuous 1830

Work scheduled by: NYPA

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

## KINTIGH\_-STA\_255\_\_345\_SH1-39

Mon 08/09/2021 to Sun 08/15/2021  
0500 Continuous 1900

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>2350 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	3150 MW

## NIAGARA\_-KINTIGH\_\_345\_NS1-38

Mon 08/09/2021 to Sun 08/15/2021  
0500 Continuous 1900

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>1400 MW</b>
Impacts Total Transfer Capability	1750 MW
TTC with All Lines In Service	3150 MW

## KINTIGH\_-STA\_255\_\_345\_SH1-39

Mon 08/16/2021 to Sun 08/22/2021  
0500 Continuous 1900

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>2350 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	3150 MW

## NIAGARA\_-KINTIGH\_\_345\_NS1-38

Mon 08/16/2021 to Sun 08/22/2021  
0500 Continuous 1900

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>1400 MW</b>
Impacts Total Transfer Capability	1750 MW
TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_\_STA\_255\_\_345\_NH2

FWD

Wed 09/01/2021 to Tue 09/21/2021

(Import)

0500 Continuous 1900

DYSINGER EAST

**2350 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## FRASANNX-COOPERS\_\_345\_UCC2-41

FWD

Tue 09/07/2021 to Wed 09/15/2021

(Import)

0700 Continuous 1730

UPDATEDby NYISO 02/03/2021

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 19**

## MARCY\_\_-FRASANNX\_345\_UCC2-41

FWD

Tue 09/07/2021 to Wed 09/15/2021

(Import)

0700 Continuous 1730

UPDATEDby NYISO 02/03/2021

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 19**

## PORTER\_\_-ROTTRDAM\_230\_30

FWD

Wed 09/15/2021 to Tue 11/30/2021

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

**2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

## EDIC\_\_-N.SCTLND\_345\_14

FWD

Thu 09/16/2021 to Sun 11/14/2021

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

**1670 MW**

Impacts Total Transfer Capability 1305 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

## EDIC\_\_-N.SCTLND\_345\_14 & PORTER\_\_-ROTTRDAM\_230\_30

FWD

Thu 09/16/2021 to Sun 11/14/2021

(Import)

0700 1730

CENTRAL EAST - VC

**1500 MW**

Impacts Total Transfer Capability 1475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

## HURLYAVE-ROSETON\_\_345\_303

FWD

Thu 09/16/2021 to Sun 10/17/2021

(Import)

0800 Continuous 1600

UPDATEDby CHGE 09/22/2020

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 2120 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: CHGE

# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HOMRC\_NY-MAINS\_NY\_345\_47

Sat 09/18/2021 to Fri 11/05/2021  
0800 Continuous 1600  
Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## PANNELL\_-CLAY\_345\_1

Mon 09/20/2021 to Fri 09/24/2021  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

## CLAY\_-EDIC\_345\_2-15

Mon 09/20/2021 to Sat 10/16/2021  
0700 Continuous 1730  
Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

## KINTIGH\_-STA\_255\_345\_SH1-39

Mon 09/27/2021 to Wed 09/29/2021 UPDATED by NYPA 03/04/2021  
0500 Continuous 0459  
Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2350 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 3150 MW

## NIAGARA\_-KINTIGH\_345\_NS1-38

Mon 09/27/2021 to Wed 09/29/2021 UPDATED by NYPA 03/04/2021  
0500 Continuous 0459  
Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

## PANNELL\_-CLAY\_345\_2

Mon 09/27/2021 to Fri 10/01/2021  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

## W49TH\_ST\_345KV\_6

Tue 09/28/2021 to Tue 09/28/2021 UPDATED by CONED 01/15/2021  
0100 Continuous 0130  
Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**E13THSTA-FARRAGUT\_345\_46**

FWD

Tue 09/28/2021 to Tue 10/26/2021 UPDATED by CONED 01/15/2021

(Import)

0100 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**W49TH\_ST-E13THSTA\_345\_M55**

FWD

Tue 09/28/2021 to Tue 10/26/2021 UPDATED by CONED 01/15/2021

(Import)

0100 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**KINTIGH\_-STA\_255\_345\_SH1-39**

FWD

Wed 09/29/2021 to Wed 12/01/2021

(Import)

0500 Continuous 1900

Work scheduled by: NYPA

DYSINGER EAST **2350 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 3150 MW

**NIAGARA\_-KINTIGH\_345\_NS1-38**

FWD

Wed 09/29/2021 to Wed 12/01/2021

(Import)

0500 Continuous 1900

Work scheduled by: NYPA

DYSINGER EAST **1400 MW**  
 Impacts Total Transfer Capability 1750 MW  
 TTC with All Lines In Service 3150 MW

**LEEDS\_-HURLYAVE\_345\_301**

FWD

Mon 10/18/2021 to Fri 11/19/2021

(Import)

0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 2120 MW  
 TTC with All Lines In Service 6220 MW

**GOETHALS\_345KV\_5**Thu 10/21/2021 to Sat 11/20/2021 UPDATED by CONED 03/05/2021

0001 Continuous 0200

Work scheduled by: ConEd

STATEN ISLAND  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**W49TH\_ST\_345KV\_6**

FWD

Tue 10/26/2021 to Tue 10/26/2021 UPDATED by CONED 01/15/2021

(Import)

0230 Continuous 0300

Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-IMO-NYISO\_LIMIT\_1750

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019

0001 Continuous 2359

Work scheduled by: IESO

FWD

(Import)

SCH - OH - NY

**2050 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 2300 MW

## SCH-NYISO-IMO\_LIMIT\_1600

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019

0001 Continuous 2359

Work scheduled by: IESO

REV

(Export)

SCH - OH - NY

**1900 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 2000 MW

## LINDN\_CG-LNDVFT\_\_\_345\_V-3022

Tue 11/02/2021 to Fri 11/05/2021

0800 Continuous 1500

Work scheduled by: PJM

FWD

(Import) (Export)

SCH - PJM\_VFT

**0 MW****0 MW**

Impacts Total Transfer Capability 315 MW

315 MW

TTC with All Lines In Service 315 MW

315 MW

## MASSENA\_-MARCY\_\_\_765\_MSU1 &amp; PORTER\_-ROTTDAM\_230\_30

Mon 11/15/2021 to Tue 11/30/2021

0100 1730

Work scheduled by:

FWD

(Import)

CENTRAL EAST - VC

**1500 MW**

Impacts Total Transfer Capability 1475 MW

TTC with All Lines In Service 2975 MW

## CHATGUAY-MASSENA\_\_\_765\_7040

Mon 11/15/2021 to Tue 11/30/2021

0100 Continuous 1859

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

**1550 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

## CHATGUAY-MASSENA\_\_\_765\_7040

Mon 11/15/2021 to Tue 11/30/2021

0100 Continuous 1859

Work scheduled by: NYPA

FWD

(Import) (Export)

SCH - HQ - NY

**0 MW****0 MW**

Impacts Total Transfer Capability 1500 MW

1000 MW

TTC with All Lines In Service 1500 MW

1000 MW

## MARCY\_\_\_765\_345\_AT1

Mon 11/15/2021 to Tue 11/30/2021

0100 Continuous 1859

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

**1750 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

ARR: 19



# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MARCY\_\_\_\_765\_345\_AT2

FWD

Mon 11/15/2021 to Tue 11/30/2021

(Import)

0100 Continuous 1859

MOSES SOUTH

**1700 MW**

Work scheduled by: NYPA

ARR: 19

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

## MASSENA\_-MARCY\_\_\_\_765\_MSU1

FWD

Mon 11/15/2021 to Tue 11/30/2021

(Import)

0100 Continuous 1859

CENTRAL EAST - VC

**1670 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 1305 MW

TTC with All Lines In Service 2975 MW

## MASSENA\_-MARCY\_\_\_\_765\_MSU1

FWD

Mon 11/15/2021 to Tue 11/30/2021

(Import)

0100 Continuous 1859

MOSES SOUTH

**500 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

## MASSENA\_-MARCY\_\_\_\_765\_MSU1

FWD

REV

Mon 11/15/2021 to Tue 11/30/2021

(Import) (Export)

0100 Continuous 1859

SCH - HQ - NY

**475 MW 1000 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 1025 MW 0 MW

TTC with All Lines In Service 1500 MW 1000 MW

## MASSENA\_-MARCY\_\_\_\_765\_MSU1

FWD

Mon 11/15/2021 to Tue 11/30/2021

(Import)

0100 Continuous 1859

SCH - HQ\_CEDARS

**90 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

## MASSENA\_-MARCY\_\_\_\_765\_MSU1 & CHATGUAY-MASSENA\_765\_7040

FWD

Mon 11/15/2021 to Tue 11/30/2021

(Import)

0100 1859

MOSES SOUTH

**500 MW**

Work scheduled by:

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

## MOSES\_-MASSENA\_230\_MMS1 & MOSES\_-MASSENA\_230\_MMS2

FWD

REV

Mon 11/15/2021 to Tue 11/30/2021

(Import) (Export)

0100 1859

SCH - HQ - NY

**850 MW 0 MW**

Work scheduled by:

Impacts Total Transfer Capability 650 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230\_MMS1 & MOSES -MASSENA 230\_MMS2

FWD

Mon 11/15/2021 to Tue 11/30/2021

(Import)

0100

1859

SCH - HQ\_CEDARS

90 MW

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

Work scheduled by:

STLAWRNC-MOSES 230\_L33P & MASSENA -MARCY 765\_MSU1

FWD

Mon 11/15/2021 to Tue 11/30/2021

(Import)

0100

1859

SCH - HQ\_CEDARS

90 MW

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

Work scheduled by:

STLAWRNC-MOSES 230\_L33P & MOSES -MASSENA 230\_MMS1 & MOSES -  
MASSENA 230\_MMS2

FWD

(Import)

Mon 11/15/2021 to Tue 11/30/2021

0100

1859

SCH - HQ\_CEDARS

90 MW

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

Work scheduled by:

FRASER 345\_FRASER SVC

FWD

Wed 12/01/2021 to Mon 02/28/2022

(Import)

0700

Continuous

1730

CENTRAL EAST - VC

2935 MW

Impacts Total Transfer Capability 40 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

MOSES -ADIRNDCK 230\_MA1

FWD

(Import)

Wed 12/01/2021 to Tue 05/31/2022

0700

Continuous

1300

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

NIAGARA -STA\_255 345\_NH2

FWD

(Import)

Thu 12/02/2021 to Thu 01/13/2022

0500

Continuous

1900

DYSINGER EAST

2350 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

MOTTHAVN-RAINEY 345\_Q12

FWD

(Import)

Sun 12/05/2021 to Sat 12/25/2021

UPDATEDby CONED 03/25/2021

0001

Continuous

0159

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LEEDS\_\_\_-PLSNTVLY\_345\_92

FWD

Thu 02/17/2022 to Mon 02/21/2022 UPDATED by NGRID 03/31/2021

(Import)

0600 Continuous 1900

UPNY CONED

3800 MW

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: NGrid

## GOETHALS\_345KV\_5

Sat 03/05/2022 to Mon 04/04/2022 UPDATED by CONED 03/26/2021

0001 Continuous 0200

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: ConEd

## LINDEN\_\_-GOETHALS\_230\_A2253

Sat 03/05/2022 to Mon 04/04/2022 UPDATED by CONED 03/26/2021

0001 Continuous 0200

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: ConEd

## N.SCTLND-ALPS\_\_\_\_\_345\_2

FWD

Mon 05/02/2022 to Mon 05/09/2022

(Import)

0600 Daily 1800

SCH - NE - NY

750 MW

Impacts Total Transfer Capability 650 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: NGrid

## N.SCTLND-ALPS\_\_\_\_\_345\_2

FWD

REV

Mon 05/02/2022 to Mon 05/09/2022

(Import) (Export)

0600 Daily 1800

SCH - NPX\_1385

100 MW

100 MW

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

Work scheduled by: NGrid

## HOMRC\_NY-MAINS\_NY\_345\_47

Fri 05/20/2022 to Fri 05/27/2022 UPDATED by PJM 11/19/2020

0800 Continuous 1600

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: PJM

## HOMR\_NYW-PIERC\_NY\_345\_48

Fri 05/20/2022 to Fri 05/27/2022 UPDATED by PJM 11/19/2020

0800 Continuous 1600

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: PJM

# NYISO TRANSFER LIMITATIONS

Sunday ,April 11, 2021 to Tuesday ,October 11, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Wed 06/01/2022 to Mon 11/14/2022

0700 Continuous 1300

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

## SPRNBRK\_\_\_345KV\_RNS5

Mon 09/19/2022 to Mon 09/19/2022

0001 Continuous 0030

Work scheduled by: ConEd

UPDATED

by CONED 09/17/2020

FWD

(Import)

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

## SPRNBRK\_-W49TH\_ST\_345\_M51

Mon 09/19/2022 to Wed 09/21/2022

0001 Continuous 2200

Work scheduled by: ConEd

UPDATED

by CONED 09/17/2020

FWD

(Import)

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

## SPRNBRK\_\_\_345KV\_RNS5

Wed 09/21/2022 to Wed 09/21/2022

2130 Continuous 2200

Work scheduled by: ConEd

UPDATED

by CONED 09/17/2020

FWD

(Import)

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

## SPRNBRK\_-W49TH\_ST\_345\_M51

Sat 10/01/2022 to Mon 10/17/2022

0001 Continuous 0300

Work scheduled by: ConEd

UPDATED

by CONED 08/01/2020

FWD

(Import)

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

## SPRNBRK\_\_\_345KV\_RNS5

Sat 10/01/2022 to Mon 10/17/2022

0001 Continuous 0300

Work scheduled by: ConEd

UPDATED

by CONED 08/01/2020

FWD

(Import)

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW