

**NYISO TRANSFER LIMITATIONS**

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**HUDSONP\_-FARRAGUT\_345\_B3402**Mon 01/15/2018 to Wed 06/30/2021 EXT FORCE by CONED 08/28/2020

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403**

Mon 01/15/2018 to Wed 06/30/2021

0001 2359

Work scheduled by:

FWD REV

(Import) (Export)

SCH - PJ - NY

**2550 MW 1900 MW**

Impacts Total Transfer Capability 250 MW 50 MW

TTC with All Lines In Service 2800 MW 1950 MW

**MARION\_-FARRAGUT\_345\_C3403**Mon 01/15/2018 to Wed 06/30/2021 EXT FORCE by CONED 08/28/2020

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**STLAWRNC-MOSES\_230\_L33P**Mon 04/30/2018 to Mon 10/31/2022 EXT FORCE by IESO 10/01/2020

0456 Continuous 1600

Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**NEWBRDGE\_345\_138\_BK\_1**Wed 09/02/2020 to Tue 02/01/2022 EXT FORCE by LI 01/12/2021

1807 Continuous 2359

Work scheduled by: LI

FWD

(Import)

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

**SPRNBRK\_-EGRDNCTR\_345\_Y49**Thu 10/01/2020 to Mon 04/19/2021 EXT FORCE by LI 02/23/2021

0404 Continuous 2359

Work scheduled by: LI

FWD

(Import)

CONED - LIPA

**775 MW**

Impacts Total Transfer Capability 725 MW

TTC with All Lines In Service 1500 MW

**EGRDNCTY\_345\_138\_AT2**Sat 10/10/2020 to Mon 04/19/2021 EXT FORCE by LI 02/23/2021

1815 Continuous 2359

Work scheduled by: LI

FWD

(Import)

CONED - LIPA

**1250 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## EGRDNCTY\_345\_138\_AT1

Sat 10/10/2020 to Mon 04/19/2021  
1856 Continuous 2359

EXT FORCE by LI 02/23/2021

Work scheduled by: LI

FWD  
(Import)  
**1250 MW**  
CONED - LIPA  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

## SCH-IMO-NYISO\_LIMIT\_1750

Sun 11/01/2020 to Fri 04/30/2021  
0001 Continuous 2359

UPDATED by IESO 05/03/2019

Work scheduled by: IESO

FWD  
(Import)  
**2050 MW**  
SCH - OH - NY  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 2300 MW

## SCH-NYISO-IMO\_LIMIT\_1600

Sun 11/01/2020 to Fri 04/30/2021  
0001 Continuous 2359

UPDATED by IESO 05/03/2019

Work scheduled by: IESO

REV  
(Export)  
**1900 MW**  
SCH - OH - NY  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 2000 MW

## SAND\_BAR-PLATSBURG\_115\_PV20

Tue 02/23/2021 to Mon 05/17/2021  
1801 Continuous 0559

UPDATED by NYISO 03/16/2021

Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## W49TH\_ST\_345KV\_8

Tue 03/02/2021 to Fri 04/30/2021  
0201 Continuous 0200

UPDATED by CONED 03/16/2021

Work scheduled by: ConEd

FWD  
(Import)  
**300 MW**  
SCH - PJM\_HTP  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

## PORTER\_-ROTTRDAM\_230\_31

Tue 03/02/2021 to Mon 05/31/2021  
0600 Continuous 1730

UPDATED by NGRID 03/10/2021

Work scheduled by: NGrid

FWD  
(Import)  
**2805 MW**  
CENTRAL EAST - VC  
Impacts Total Transfer Capability 170 MW  
TTC with All Lines In Service 2975 MW

## MOSES\_-ADIRNDCK\_230\_MAI

Tue 03/02/2021 to Mon 05/10/2021  
0700 Continuous 1159

UPDATED by NYPA 02/11/2021

Work scheduled by: NYPA

FWD  
(Import)  
**2300 MW**  
MOSES SOUTH  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**NYISO TRANSFER LIMITATIONS**

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 6220MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**LADENTWN-BUCHAN\_S\_345\_Y88**

FWD

Tue 03/09/2021 to Thu 04/08/2021

UPDATEDby CE03/05/2021

(Import)

0001 Continuous 0200

UPNY CONED

**5930 MW**

Impacts Total Transfer Capability 290 MW

Work scheduled by: ConEd

TTC with All Lines In Service 6220 MW

**SCH-NYISO-HQ\_CEDARS\_LIMIT\_0**

REV

Mon 03/15/2021 to Wed 04/07/2021

EXTENDEDby HQ04/01/2021

(Export)

0500 Continuous 2000

SCH - HQ\_CEDARS

**0 MW**

Impacts Total Transfer Capability 100 MW

Work scheduled by: HQ

TTC with All Lines In Service 100 MW

**W49TH\_ST\_345KV\_6**

FWD

Sun 03/21/2021 to Mon 04/12/2021

UPDATEDby CONED03/16/2021

(Import)

0001 Continuous 0200

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

Work scheduled by: ConEd

TTC with All Lines In Service 660 MW

**EDIC\_\_\_\_-N.SCTLND\_345\_14 & PORTER\_\_\_\_-ROTTRDAM\_230\_31**

FWD

Mon 03/22/2021 to Mon 05/31/2021

(Import)

0600 1730

CENTRAL EAST - VC

**1500 MW**

Impacts Total Transfer Capability 1475 MW

Work scheduled by:

TTC with All Lines In Service 2975 MW

**EDIC\_\_\_\_-N.SCTLND\_345\_14**

FWD

Mon 03/22/2021 to Mon 05/31/2021

(Import)

0600 Continuous 1830

UPDATEDby NGRID03/10/2021

CENTRAL EAST - VC

**1670 MW**

Impacts Total Transfer Capability 1305 MW

Work scheduled by: NGrid

TTC with All Lines In Service 2975 MW

**EASTVIEW-SPRNBK\_\_345\_W78**

FWD

Fri 03/26/2021 to Sun 03/28/2021

(Import)

0001 Continuous 2200

EXTENDEDby CONED03/31/2021

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1870 MW

Work scheduled by: ConEd

TTC with All Lines In Service 6220 MW

**MILLWOOD-EASTVIEW\_345\_W85**

FWD

Fri 03/26/2021 to Sun 03/28/2021

(Import)

0001 Continuous 2200

EXTENDEDby CONED03/31/2021

UPNY CONED

**5985 MW**

Impacts Total Transfer Capability 235 MW

Work scheduled by: ConEd

TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NINEMILE-CLAY</b> _____ <b>345_8</b>					FWD	
Sun 03/28/2021	to	Sat 04/03/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>04/01/2021</u>	(Import)
2300	Continuous	0200				
Work scheduled by: NGrid					OSWEGO EXPORT	<b>5150 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	5250 MW
<b>S.RIPLEY-DUNKIRK</b> _____ <b>230_68</b>						
Mon 03/29/2021	to	Fri 04/09/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>03/30/2021</u>	
1129	Continuous	1700				
Work scheduled by: NGrid					SCH - PJ - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<b>HUDSONTP-W49TH_ST</b> _____ <b>345_Y56</b>					FWD	
Tue 03/30/2021	to	Fri 04/02/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>03/16/2021</u>	(Import)
0001	Continuous	0200				
Work scheduled by: ConEd					SCH - PJM_HTP	<b>0 MW</b>
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
<b>W49TH_ST</b> _____ <b>345KV_7</b>					FWD	
Tue 03/30/2021	to	Fri 04/02/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>03/16/2021</u>	(Import)
0001	Continuous	0200				
Work scheduled by: ConEd					SCH - PJM_HTP	<b>300 MW</b>
					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
<b>BRANCHBG-HOPATCON</b> _____ <b>500_5060</b>					FWD	
Wed 03/31/2021	to	Wed 03/31/2021	<u>UPDATED</u>	<u>by PJM</u>	<u>11/30/2020</u>	(Import)
0200	Continuous	1500				
Work scheduled by: PJM					UPNY CONED	<b>6025 MW</b>
					Impacts Total Transfer Capability	195 MW
					TTC with All Lines In Service	6220 MW
<b>ROCHESTR-PANNELL</b> _____ <b>345_RP2</b>					FWD	
Wed 03/31/2021	to	Mon 04/12/2021				(Import)
0500	Continuous	1700				
Work scheduled by: NYPA					DYSINGER EAST	<b>2300 MW</b>
					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
<b>SHOR_NPX-SHOREHAM</b> _____ <b>138_CSC</b>					FWD REV	
Thu 04/01/2021	to	Thu 04/01/2021	<u>FORCED</u>	<u>by LI</u>	<u>03/31/2021</u>	(Import) (Export)
0001	Daily	2359				
Work scheduled by: LI					SCH - NPX_CSC	<b>0 MW 0 MW</b>
					Impacts Total Transfer Capability	330 MW 330 MW
					TTC with All Lines In Service	330 MW 330 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## DUNWODIE\_345KV\_3

FWD

Fri 04/02/2021 to Fri 04/02/2021 EXT FORCE by CONED 03/13/2021  
0130 Continuous 0200

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## DUNWODIE\_345KV\_4

FWD

Fri 04/02/2021 to Fri 04/02/2021 EXT FORCE by CONED 03/13/2021  
0130 Continuous 0200

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## PLSNTVLE-DUNWODIE\_345\_W89

FWD

Fri 04/02/2021 to Fri 04/02/2021 EXT FORCE by CONED 03/13/2021  
0130 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 2220 MW  
TTC with All Lines In Service 6220 MW

## MILLWOOD-EASTVIEW\_345\_W85

FWD

Sat 04/03/2021 to Sat 04/03/2021 UPDATED by CONED 03/31/2021  
0001 Continuous 0030

(Import)

Work scheduled by: ConEd

UPNY CONED **5985 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 6220 MW

## SPRNBK\_345KV\_RNS3

FWD

Sat 04/03/2021 to Sat 04/03/2021 UPDATED by CONED 03/31/2021  
0001 Continuous 0030

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## EASTVIEW-SPRNBK\_345\_W78

FWD

Sat 04/03/2021 to Sat 04/03/2021 UPDATED by CONED 03/31/2021  
0001 Continuous 2200

(Import)

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 1870 MW  
TTC with All Lines In Service 6220 MW

## MILLWOOD-EASTVIEW\_345\_W85

FWD

Sat 04/03/2021 to Sat 04/03/2021 UPDATED by CONED 03/31/2021  
2130 Continuous 2200

(Import)

Work scheduled by: ConEd

UPNY CONED **5985 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_\_345KV\_RNS3

FWD

Sat 04/03/2021 to Sat 04/03/2021 UPDATED by CONED 03/31/2021  
2130 Continuous 2200

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### LINDN\_CG-LNDVFT\_\_345\_V-3022

FWD

REV

Sun 04/04/2021 to Sat 04/10/2021  
1400 Continuous 1400

(Import) (Export)

Work scheduled by: PJM

SCH - PJM\_VFT **0 MW** **0 MW**  
Impacts Total Transfer Capability 315 MW 315 MW  
TTC with All Lines In Service 315 MW 315 MW

### NINEMILE-CLAY\_\_345\_8

FWD

Sun 04/04/2021 to Sun 04/04/2021 UPDATED by NGRID 03/04/2021  
1600 Daily 1700

(Import)

Work scheduled by: NGrid

OSWEGO EXPORT **5150 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 5250 MW

### WATRCURE-OAKDALE\_\_345\_31

Mon 04/05/2021 to Thu 04/08/2021  
0800 Daily(No Weekends) 1500

Work scheduled by: NYSEG

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### N.SCTLND-LEEDS\_\_345\_93

FWD

Wed 04/07/2021 to Wed 04/07/2021  
0700 Daily(No Weekends) 1600

(Import)

Work scheduled by: NGrid

CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

### LEEDS\_\_345KV\_R94301

FWD

Thu 04/08/2021 to Thu 04/08/2021  
0700 Daily(No Weekends) 0800

(Import)

Work scheduled by: NGrid

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 2420 MW  
TTC with All Lines In Service 6220 MW

### N.SCTLND-LEEDS\_\_345\_94

FWD

Thu 04/08/2021 to Thu 04/08/2021  
0700 Daily(No Weekends) 1600

(Import)

Work scheduled by: NGrid

CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

**NYISO TRANSFER LIMITATIONS**

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 6220MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**LEEDS\_\_\_\_345KV\_R94301**

FWD

Thu 04/08/2021 to Thu 04/08/2021

(Import)

1500 Daily(No Weekends) 1600

Work scheduled by: NGrid

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

**SPRNBK\_-TREMONT\_\_345\_X28**

FWD

Fri 04/09/2021 to Sat 04/10/2021

(Import)

0001 Continuous 0300

Work scheduled by: ConEd

UPDATEDby CONED 03/25/2021

SPR/DUN-SOUTH

**4200 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

**EASTVIEW-SPRNBK\_\_345\_W79**

FWD

Sat 04/10/2021 to Sun 04/11/2021

(Import)

0001 Continuous 0300

Work scheduled by: ConEd

UPDATEDby CONED 03/25/2021

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

**CHAT\_DC\_GC1**

FWD

Sat 04/10/2021 to Sat 04/10/2021

(Import)

0600 Continuous 1600

Work scheduled by: HQ

MOSES SOUTH

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC1**

REV

Sat 04/10/2021 to Sat 04/10/2021

(Export)

0600 Continuous 1600

Work scheduled by: HQ

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

**S.RIPLEY-DUNKIRK\_\_230\_68**

Mon 04/12/2021 to Fri 04/23/2021

0630 Continuous 1700

Work scheduled by: NGrid

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**LEEDS\_\_\_\_345KV\_R94301**

FWD

Mon 04/12/2021 to Mon 04/12/2021

(Import)

0800 Continuous 0830

Work scheduled by: CHGE

UPDATEDby NGRID 02/01/2021

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

**NYISO TRANSFER LIMITATIONS**

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 6220MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**LEEDS\_\_\_-HURLYAVE\_345\_301**

FWD

Mon 04/12/2021 to Fri 04/16/2021 UPDATED by NGRID 02/01/2021

(Import)

0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 2120 MW  
 TTC with All Lines In Service 6220 MW

**W49TH\_ST\_345KV\_6**

FWD

Tue 04/13/2021 to Fri 04/30/2021 UPDATED by CONED 03/16/2021

(Import)

2201 Continuous 0200

Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**PLSNTVLY-WOOD\_ST\_345\_F30**

FWD

Fri 04/16/2021 to Fri 04/16/2021 UPDATED by CONED 03/22/2021

(Import)

0001 Continuous 0030

Work scheduled by: ConEd

UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 2220 MW  
 TTC with All Lines In Service 6220 MW

**PLSNTVLY\_345KV\_RNS5**

FWD

Fri 04/16/2021 to Fri 04/16/2021 UPDATED by CONED 03/22/2021

(Import)

0001 Continuous 0030

Work scheduled by: ConEd

UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 2420 MW  
 TTC with All Lines In Service 6220 MW

**MILLWOOD\_345KV\_18**

FWD

Fri 04/16/2021 to Sat 04/17/2021

(Import)

0001 Continuous 2200

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1870 MW  
 TTC with All Lines In Service 6220 MW

**NIAGARA\_-STA\_255\_345\_NH2**

FWD

Fri 04/16/2021 to Fri 04/16/2021

(Import)

0500 Continuous 1700

Work scheduled by: NYPA

DYSINGER EAST **2350 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 3150 MW

**LEEDS\_\_\_345KV\_R94301**

FWD

Fri 04/16/2021 to Fri 04/16/2021 UPDATED by NGRID 02/01/2021

(Import)

1530 Continuous 1600

Work scheduled by: CHGE

UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 2420 MW  
 TTC with All Lines In Service 6220 MW



# NYISO TRANSFER LIMITATIONS

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PLSNTVLY-WOOD\_ST\_\_345\_F30

FWD

Sat 04/17/2021 to Tue 04/20/2021 UPDATED by CONED 03/22/2021

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

4000 MW

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

## PLSNTVLY\_345KV\_RNS5

FWD

Sat 04/17/2021 to Tue 04/20/2021 UPDATED by CONED 03/22/2021

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

3800 MW

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

## DUNWODIE\_345KV\_6

FWD

Tue 04/20/2021 to Tue 04/20/2021 UPDATED by CONED 02/19/2021

(Import)

0201 Continuous 0230

Work scheduled by: ConEd

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

## DUNWODIE\_345KV\_8

FWD

Tue 04/20/2021 to Tue 04/20/2021 UPDATED by CONED 02/19/2021

(Import)

0201 Continuous 0230

Work scheduled by: ConEd

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

## WOOD\_ST\_-PLSNTVLE\_345\_Y87

FWD

Tue 04/20/2021 to Tue 04/20/2021 UPDATED by CONED 02/19/2021

(Import)

0201 Continuous 0230

Work scheduled by: ConEd

UPNY CONED

5905 MW

Impacts Total Transfer Capability 315 MW

TTC with All Lines In Service 6220 MW

## PLSNTVLE-DUNWODIE\_345\_W90

FWD

Tue 04/20/2021 to Fri 04/23/2021 UPDATED by CONED 02/19/2021

(Import)

0201 Continuous 0159

Work scheduled by: ConEd

UPNY CONED

4000 MW

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

## MAINESBG-WATRCURE\_345\_30

FWD

Tue 04/20/2021 to Wed 04/21/2021

(Import)

0800 Continuous 1530

Work scheduled by: NYSEG

SCH - PJ - NY

2300 MW

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 2800 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_6**

FWD

Fri 04/23/2021 to Fri 04/23/2021 UPDATED by CONED 02/19/2021  
0130 Continuous 0159

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_8**

FWD

Fri 04/23/2021 to Fri 04/23/2021 UPDATED by CONED 02/19/2021  
0130 Continuous 0159

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**WOOD\_ST\_-PLSNTVLE\_345\_Y87**

FWD

Fri 04/23/2021 to Fri 04/23/2021 UPDATED by CONED 02/19/2021  
0130 Continuous 0159

(Import)

Work scheduled by: ConEd

UPNY CONED **5905 MW**  
Impacts Total Transfer Capability 315 MW  
TTC with All Lines In Service 6220 MW

**MILLWOOD-EASTVIEW\_345\_W82**

FWD

Fri 04/23/2021 to Fri 04/23/2021  
0201 Continuous 1800

(Import)

Work scheduled by: ConEd

UPNY CONED **5985 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 6220 MW

**CHAT\_DC\_GC1**

FWD

Sat 04/24/2021 to Sun 04/25/2021  
2000 Continuous 0500

(Import)

Work scheduled by: HQ

MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC1**

REV

Sat 04/24/2021 to Sun 04/25/2021  
2000 Continuous 0500

(Export)

Work scheduled by: HQ

SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

**KINTIGH\_-STA\_255\_\_345\_SH1-39**

FWD

Mon 04/26/2021 to Fri 04/30/2021  
0700 Continuous 1700

(Import)

Work scheduled by: NYPA

DYSINGER EAST **2350 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_-KINTIGH\_\_345\_NS1-38

FWD

Mon 04/26/2021 to Fri 04/30/2021

(Import)

0700 Continuous 1700

DYSINGER EAST **1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## HOMRC\_NY-MAINS\_NY\_345\_47

Mon 04/26/2021 to Sat 05/29/2021

**EXTENDED by NYSEG 03/10/2021**

0800 Continuous 1900

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYSEG

## FRASER\_-COOPERS\_\_345\_33

FWD

Mon 04/26/2021 to Fri 04/30/2021

(Import)

0830 Continuous 1500

CENTRAL EAST - VC **2395 MW**

Impacts Total Transfer Capability 580 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

## EFISHKIL-WOOD\_ST\_\_345\_F38

FWD

Tue 04/27/2021 to Tue 04/27/2021

**CANCELLED by ConEd 04/01/2021**

0001 Continuous 0030

UPNY CONED **4000 MW**

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

## WOOD\_ST\_-PLSNTVLE\_345\_Y86

FWD

Tue 04/27/2021 to Tue 04/27/2021

**CANCELLED by ConEd 04/01/2021**

0001 Continuous 0030

UPNY CONED **5935 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

## ALCOA\_PA\_115KV\_R8105

FWD

Tue 04/27/2021 to Thu 04/29/2021

(Import)

0630 Continuous 1830

MOSES SOUTH **3100 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NGrid

## MOTTHAVN-RAINEY\_\_345\_Q11

FWD

Wed 04/28/2021 to Sat 05/08/2021

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## EFISHKIL-WOOD\_ST\_\_345\_F38

FWD

Wed 04/28/2021 to Wed 04/28/2021 CANCELLED by ConEd 04/01/2021

(Import)

1730 Continuous 1800

UPNY CONED

4000 MW

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

## WOOD\_ST\_-PLSNTVLE\_345\_Y86

FWD

Wed 04/28/2021 to Wed 04/28/2021 CANCELLED by ConEd 04/01/2021

(Import)

1730 Continuous 1800

UPNY CONED

5935 MW

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

## EASTVIEW-SPRNBK\_\_345\_W79

FWD

Fri 04/30/2021 to Fri 04/30/2021 UPDATED by CONED 03/25/2021

(Import)

0001 Continuous 0030

UPNY CONED

4350 MW

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

## BUCHAN\_N-EASTVIEW\_345\_W93

FWD

Fri 04/30/2021 to Mon 05/10/2021 UPDATED by CONED 03/25/2021

(Import)

0001 Continuous 0200

UPNY CONED

4350 MW

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

## W49TH\_ST\_345KV\_5

FWD

Fri 04/30/2021 to Fri 04/30/2021

(Import)

0201 Continuous 0231

SCH - PJM\_HTP

300 MW

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

## W49TH\_ST\_345KV\_7

FWD

Fri 04/30/2021 to Fri 04/30/2021

(Import)

0201 Continuous 0231

SCH - PJM\_HTP

300 MW

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

## SCH-IMO-NYISO\_LIMIT\_1600

FWD

Sat 05/01/2021 to Sun 10/31/2021 UPDATED by IESO 05/03/2019

(Import)

0001 Continuous 2359

SCH - OH - NY

1900 MW

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 1950 MW

Work scheduled by: IESO

**NYISO TRANSFER LIMITATIONS**

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_601			FWD	REV
Mon 05/03/2021	to	Mon 05/24/2021	(Import)	(Export)
0600	Continuous	2359	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602			FWD	REV
Mon 05/03/2021	to	Mon 05/24/2021	(Import)	(Export)
0600		2359	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603			FWD	REV
Mon 05/03/2021	to	Mon 05/24/2021	(Import)	(Export)
0600		2359	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_602			FWD	REV
Mon 05/03/2021	to	Mon 05/24/2021	(Import)	(Export)
0600	Continuous	2359	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603			FWD	REV
Mon 05/03/2021	to	Mon 05/24/2021	(Import)	(Export)
0600		2359	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_603			FWD	REV
Mon 05/03/2021	to	Mon 05/24/2021	(Import)	(Export)
0600	Continuous	2359	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NRTHPORT_138_NNC			FWD	REV
Mon 05/03/2021	to	Mon 05/24/2021	(Import)	(Export)
0600	Continuous	2359	SCH - NPX_1385	0 MW 0 MW
Work scheduled by: LI			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 6220MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CLAY -EDIC 345\_2-15**

Mon 05/03/2021 to Fri 05/07/2021  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
 OSWEGO EXPORT **4850 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 5250 MW

**FIVEMILE-STOLLERD 345\_29**

Mon 05/03/2021 to Fri 05/14/2021  
 0700 Continuous 1400

Work scheduled by: NYSEG

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**PANNELL -CLAY 345\_2**

Mon 05/03/2021 to Sun 05/30/2021  
 0700 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
 WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

**HURLYAVE-ROSETON 345\_303**

Mon 05/03/2021 to Fri 05/21/2021  
 0800 Continuous 1600

Work scheduled by: CHGE

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 2120 MW  
 TTC with All Lines In Service 6220 MW

**SHOR\_NPX-SHOREHAM 138\_CSC**

Mon 05/03/2021 to Sat 05/08/2021  
 0900 Continuous 1600

Work scheduled by: LI

**EXTENDED by ISONE 03/15/2021**

FWD REV  
 (Import) (Export)  
 SCH - NPX\_CSC **0 MW 0 MW**  
 Impacts Total Transfer Capability 330 MW 330 MW  
 TTC with All Lines In Service 330 MW 330 MW

**ROTTRDAM-EASTOVER 230\_38**

Tue 05/04/2021 to Tue 05/04/2021  
 0830 Daily(No Weekends) 1130

Work scheduled by: NGrid

**ARR: 77**

REV  
 (Export)  
 SCH - NE - NY **1400 MW**  
 Impacts Total Transfer Capability 200 MW  
 TTC with All Lines In Service 1600 MW

**EASTVIEW-SPRNBK 345\_W79**

Fri 05/07/2021 to Mon 05/10/2021  
 0001 Continuous 0200

Work scheduled by: ConEd

**UPDATED by CONED 03/25/2021**

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1870 MW  
 TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**RAMAPO\_\_-BUCHAN\_N\_345\_Y94**

FWD

Fri 05/07/2021 to Mon 05/10/2021 UPDATED by CONED 03/25/2021

(Import)

0001 Continuous 0200

UPNY CONED

**5765 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 455 MW

TTC with All Lines In Service 6220 MW

**W49TH\_ST\_345KV\_5**

FWD

Fri 05/07/2021 to Fri 05/07/2021

(Import)

0130 Continuous 0200

SCH - PJM\_HTP

**300 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_7**

FWD

Fri 05/07/2021 to Fri 05/07/2021

(Import)

0130 Continuous 0200

SCH - PJM\_HTP

**300 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_7**

FWD

Mon 05/10/2021 to Mon 05/10/2021

(Import)

0001 Continuous 0030

SCH - PJM\_HTP

**300 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_8**

FWD

Mon 05/10/2021 to Mon 05/10/2021

(Import)

0001 Continuous 0030

SCH - PJM\_HTP

**450 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 210 MW

TTC with All Lines In Service 660 MW

**HUDSONTP-W49TH\_ST\_345\_Y56**

FWD

Mon 05/10/2021 to Thu 05/13/2021

(Import)

0001 Continuous 2300

SCH - PJM\_HTP

**0 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

**SPRNBK\_-TREMONT\_\_345\_X28**

FWD

Mon 05/10/2021 to Wed 05/26/2021 UPDATED by CONED 03/18/2021

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**4200 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CLAY - EDIC 345\_1-16

Mon 05/10/2021 to Fri 05/14/2021  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

## MOSES - ADIRNDCK 230\_MA2

Mon 05/10/2021 to Tue 06/01/2021  
1200 Continuous 0659

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## W49TH\_ST\_345KV\_7

Thu 05/13/2021 to Thu 05/13/2021  
2230 Continuous 2300

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

## W49TH\_ST\_345KV\_8

Thu 05/13/2021 to Thu 05/13/2021  
2230 Continuous 2300

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **450 MW**  
Impacts Total Transfer Capability 210 MW  
TTC with All Lines In Service 660 MW

## CRICKVLY-PLSNTVLY\_345\_F83

Fri 05/14/2021 to Fri 05/14/2021  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
SCH - NE - NY **350 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 1400 MW

## CRICKVLY-PLSNTVLY\_345\_F83

Fri 05/14/2021 to Fri 05/14/2021  
0001 Continuous 2200

Work scheduled by: ConEd

FWD	REV
(Import)	(Export)
SCH - NPX_1385 <b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability 100 MW	100 MW
TTC with All Lines In Service 200 MW	200 MW

## NRTH1385-NOR HBR\_138\_601 & CRICKVLY-PLSNTVLY\_345\_F83

Fri 05/14/2021 to Fri 05/14/2021  
0001 Continuous 2200

Work scheduled by:

FWD	REV
(Import)	(Export)
SCH - NPX_1385 <b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability 200 MW	200 MW
TTC with All Lines In Service 200 MW	200 MW



# NYISO TRANSFER LIMITATIONS

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NRTH1385-NOR HBR\_\_138\_602 & CRICKVLY-PLSNTVLY\_345\_F83

Fri 05/14/2021 to Fri 05/14/2021  
0001 2200

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

### NRTH1385-NOR HBR\_\_138\_603 & CRICKVLY-PLSNTVLY\_345\_F83

Fri 05/14/2021 to Fri 05/14/2021  
0001 2200

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

### BUCHAN\_N-EASTVIEW\_345\_W93

Fri 05/14/2021 to Sat 05/15/2021  
0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	4350 MW
Impacts Total Transfer Capability	1870 MW
TTC with All Lines In Service	6220 MW

### RAMAPO\_\_-BUCHAN\_N\_345\_Y94

Fri 05/14/2021 to Sat 05/15/2021  
0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	5765 MW
Impacts Total Transfer Capability	455 MW
TTC with All Lines In Service	6220 MW

### SPRNBK\_\_345KV\_RS3 & SPRNBK\_\_345KV\_RS4

Sat 05/15/2021 to Sat 05/15/2021  
0301 2230

Work scheduled by:

	FWD
	(Import)
SPR/DUN-SOUTH	3200 MW
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

### DUNWODIE\_345KV\_5

Mon 05/17/2021 to Tue 05/18/2021 UPDATED by CE 03/15/2021  
0201 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	3800 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

### DUNWODIE\_345KV\_7

Mon 05/17/2021 to Tue 05/18/2021 UPDATED by CE 03/15/2021  
0201 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	3800 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_-DUNWODIE\_345\_W75

Mon 05/17/2021 to Tue 05/18/2021  
0201 Continuous 0200

UPDATED by CE 03/15/2021

Work scheduled by: ConEd

FWD  
(Import)  
**3800 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### SPRNBK\_345KV\_RNS3

Mon 05/17/2021 to Tue 05/18/2021  
0201 Continuous 0200

UPDATED by CE 03/15/2021

Work scheduled by: ConEd

FWD  
(Import)  
**3800 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### NIAGARA\_-STA\_255\_345\_NH2

Mon 05/17/2021 to Fri 05/21/2021  
0500 Continuous 1700

UPDATED by NYPA 03/23/2021

Work scheduled by: NYPA

FWD  
(Import)  
**2350 MW**  
DYSINGER EAST  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 3150 MW

### SAND\_BAR-PLATSBRG\_115\_PV20

Mon 05/17/2021 to Fri 07/02/2021  
0600 Continuous 1800

Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### GOETHALS\_345KV\_5

Wed 05/19/2021 to Sat 05/22/2021  
0100 Continuous 0100

Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### LINDEN\_-GOETHALS\_230\_A2253

Wed 05/19/2021 to Sat 05/22/2021  
0100 Continuous 0100

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2050 MW</b>	<b>1150 MW</b>
Impacts Total Transfer Capability	150 MW	100 MW
TTC with All Lines In Service	2200 MW	1250 MW

### LINDEN\_-GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402

Wed 05/19/2021 to Sat 05/22/2021  
0100 0100

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2000 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDEN\_\_-GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_\_-  
FARRAGUT\_345\_C3403

Wed 05/19/2021 to Sat 05/22/2021  
0100 0100

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2000 MW	1000 MW
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

LINDEN\_\_-GOETHALS\_230\_A2253 & MARION\_\_-FARRAGUT\_345\_C3403

Wed 05/19/2021 to Sat 05/22/2021  
0100 0100

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2000 MW	1000 MW
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

BUCHAN\_S-MILLWOOD\_345\_W97

Thu 05/20/2021 to Sat 05/22/2021  
0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	6135 MW
Impacts Total Transfer Capability	85 MW
TTC with All Lines In Service	6220 MW

W49TH\_ST\_345KV\_6

Thu 05/20/2021 to Sat 05/22/2021 UPDATED by CONED 03/30/2021  
0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
SCH - PJM_HTP	300 MW
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

W49TH\_ST-E13THSTA\_345\_M55

Thu 05/20/2021 to Mon 05/24/2021 UPDATED by CONED 03/30/2021  
0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	3800 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

E13THSTA-FARRAGUT\_345\_46

Sat 05/22/2021 to Sat 05/22/2021 CANCELLED by ConEd 03/30/2021  
0001 Continuous 1830

Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	3800 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

E13THSTA-FARRAGUT\_345\_46

Sat 05/22/2021 to Mon 05/24/2021 UPDATED by CONED 03/30/2021  
0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	3800 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PLSNTVLY-WOOD\_ST\_\_345\_F31

FWD

Mon 05/24/2021 to Tue 05/25/2021

(Import)

0001 Continuous 0159

UPNY CONED

4000 MW

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

## PLSNTVLY\_345KV\_RNS4

FWD

Mon 05/24/2021 to Tue 05/25/2021

(Import)

0001 Continuous 0159

UPNY CONED

3800 MW

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

## W49TH\_ST\_345KV\_6

FWD

Mon 05/24/2021 to Mon 05/24/2021

(Import)

0130 Continuous 0200

UPDATED by CONED 03/30/2021

SCH - PJM\_HTP

300 MW

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

## ROSETON\_-EFISHKIL\_345\_RFK305

FWD

Wed 05/26/2021 to Thu 05/27/2021

(Import)

0001 Continuous 0200

UPNY CONED

5990 MW

Impacts Total Transfer Capability 230 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

## VOLNEY\_-MARCY\_\_345\_19

FWD

Tue 06/01/2021 to Wed 06/02/2021

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

2825 MW

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

ARR: 19

## VOLNEY\_-MARCY\_\_345\_19

FWD

Tue 06/01/2021 to Wed 06/02/2021

(Import)

0700 Continuous 1730

OSWEGO EXPORT

4900 MW

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

ARR: 19

## FRASER\_-GILBOA\_\_345\_GF5-35

FWD

Tue 06/01/2021 to Mon 06/07/2021

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

2650 MW

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Tue 06/01/2021 to Sun 11/14/2021  
0700 Continuous 1300

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## MARCY\_\_\_-EDIC\_\_\_345\_UE1-7

Thu 06/03/2021 to Fri 06/04/2021  
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19&16

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

## PORTER\_\_\_-ROTTRDAM\_230\_30

Thu 06/03/2021 to Wed 09/15/2021  
0700 Continuous 0659

Work scheduled by: NGrid

UPDATED by NGRID 01/19/2021

FWD  
(Import)  
CENTRAL EAST - VC **2805 MW**  
Impacts Total Transfer Capability 170 MW  
TTC with All Lines In Service 2975 MW

## MARCY\_\_\_345KV\_CSC

Sat 06/05/2021 to Sat 06/05/2021  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

## ATHENS\_\_\_-PLSNTVLY\_345\_91

Tue 06/08/2021 to Wed 06/16/2021  
0600 Continuous 2000

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 2420 MW  
TTC with All Lines In Service 6220 MW

## GILBOA\_\_\_-N.SCTLND\_345\_GNS-1

Wed 06/09/2021 to Wed 06/09/2021  
0800 Daily 1200

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2520 MW**  
Impacts Total Transfer Capability 455 MW  
TTC with All Lines In Service 2975 MW

## BECK\_\_\_-NIAGARA\_345\_PA301

Wed 06/16/2021 to Thu 06/17/2021  
0500 Continuous 2330

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **900 MW 800 MW**  
Impacts Total Transfer Capability 1050 MW 900 MW  
TTC with All Lines In Service 1950 MW 1700 MW

**NYISO TRANSFER LIMITATIONS**

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**LEEDS\_\_\_-PLSNTVLY\_345\_92**

FWD

Thu 06/17/2021 to Thu 06/24/2021

(Import)

0600 Continuous 2000

UPNY CONED

**3800 MW**

Work scheduled by: NGrid

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

**BECK\_\_\_-NIAGARA\_345\_PA301**

FWD

REV

Fri 06/25/2021 to Fri 06/25/2021

(Import) (Export)

0500 Continuous 1700

SCH - OH - NY

**900 MW 800 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 1050 MW 900 MW

TTC with All Lines In Service 1950 MW 1700 MW

**FRASANNX-COOPERS\_345\_UCC2-41**

FWD

Fri 06/25/2021 to Tue 08/10/2021

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2500 MW**

Work scheduled by: NYPA

**ARR: 19**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

**MARCY\_\_\_-FRASANNX\_345\_UCC2-41**

FWD

Fri 06/25/2021 to Tue 08/10/2021

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2500 MW**

Work scheduled by: NYPA

**ARR: 19**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

**BECK\_\_\_-NIAGARA\_345\_PA302**

FWD

REV

Mon 07/12/2021 to Fri 07/16/2021

(Import) (Export)

0500 Continuous 1700

SCH - OH - NY

**900 MW 800 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 1050 MW 900 MW

TTC with All Lines In Service 1950 MW 1700 MW

**NIAGARA\_345\_230\_AT4**

FWD

REV

Mon 07/19/2021 to Fri 07/30/2021

(Import) (Export)

0500 Continuous 1700

**UPDATED****by NYPA****02/19/2021**

SCH - OH - NY

**1900 MW 1400 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 50 MW 300 MW

TTC with All Lines In Service 1950 MW 1700 MW

**NIAGARA\_-STA\_255\_345\_NH2**

FWD

Mon 07/26/2021 to Fri 07/30/2021

(Import)

0500 Continuous 1900

**UPDATED****by NYPA****02/19/2021**

DYSINGER EAST

**2350 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SAND\_BAR-PLATSBURG\_115\_PV20

Tue 08/03/2021 to Tue 08/03/2021  
0700 Continuous 1830

Work scheduled by: NYPA

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## KINTIGH\_-STA\_255\_\_345\_SH1-39

Mon 08/09/2021 to Sun 08/15/2021  
0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

**2350 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 3150 MW

## NIAGARA\_-KINTIGH\_\_345\_NS1-38

Mon 08/09/2021 to Sun 08/15/2021  
0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

**1400 MW**

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

## KINTIGH\_-STA\_255\_\_345\_SH1-39

Mon 08/16/2021 to Sun 08/22/2021  
0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

**2350 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 3150 MW

## NIAGARA\_-KINTIGH\_\_345\_NS1-38

Mon 08/16/2021 to Sun 08/22/2021  
0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

**1400 MW**

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

## NIAGARA\_-STA\_255\_\_345\_NH2

Wed 09/01/2021 to Tue 09/21/2021  
0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

**2350 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 3150 MW

## FRASANNX-COOPERS\_\_345\_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021  
0700 Continuous 1730

Work scheduled by: NYPA

UPDATED

by NYISO 02/03/2021

**ARR: 19**

FWD

(Import)

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

**NYISO TRANSFER LIMITATIONS**

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 6220MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_-FRASANNX\_345\_UCC2-41**

FWD

Tue 09/07/2021 to Wed 09/15/2021 **UPDATED by NYISO 02/03/2021**

(Import)

0700 Continuous 1730

CENTRAL EAST - VC **2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 19****PORTER\_\_\_-ROTTRDAM\_230\_30**

FWD

Wed 09/15/2021 to Tue 11/30/2021

(Import)

0700 Continuous 1730

CENTRAL EAST - VC **2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**EDIC\_\_\_-N.SCTLND\_345\_14**

FWD

Thu 09/16/2021 to Sun 11/14/2021

(Import)

0700 Continuous 1730

CENTRAL EAST - VC **1670 MW**

Impacts Total Transfer Capability 1305 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**EDIC\_\_\_-N.SCTLND\_345\_14 & PORTER\_\_\_-ROTTRDAM\_230\_30**

FWD

Thu 09/16/2021 to Sun 11/14/2021

(Import)

0700 1730

CENTRAL EAST - VC **1500 MW**

Impacts Total Transfer Capability 1475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

**HURLYAVE-ROSETON\_\_\_345\_303**

FWD

Thu 09/16/2021 to Sun 10/17/2021 **UPDATED by CHGE 09/22/2020**

(Import)

0800 Continuous 1600

UPNY CONED **4100 MW**

Impacts Total Transfer Capability 2120 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: CHGE

**HOMRC\_NY-MAINS\_NY\_345\_47**

Sat 09/18/2021 to Fri 11/05/2021

0800 Continuous 1600

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: PJM

**PANNELL\_\_\_-CLAY\_\_\_345\_1**

FWD

Mon 09/20/2021 to Fri 09/24/2021

(Import)

0700 Continuous 1530

WEST CENTRAL **1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA



# NYISO TRANSFER LIMITATIONS

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**CLAY -EDIC 345\_2-15**

Mon 09/20/2021 to Sat 10/16/2021  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

---

**KINTIGH -STA 255\_345\_SH1-39**

Mon 09/27/2021 to Wed 09/29/2021  
0500 Continuous 0459

Work scheduled by: NYPA

UPDATED by NYPA 03/04/2021

FWD  
(Import)  
DYSINGER EAST **2350 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 3150 MW

---

**NIAGARA -KINTIGH 345\_NS1-38**

Mon 09/27/2021 to Wed 09/29/2021  
0500 Continuous 0459

Work scheduled by: NYPA

UPDATED by NYPA 03/04/2021

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

---

**PANNELL -CLAY 345\_2**

Mon 09/27/2021 to Fri 10/01/2021  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

---

**W49TH\_ST\_345KV\_6**

Tue 09/28/2021 to Tue 09/28/2021  
0100 Continuous 0130

Work scheduled by: ConEd

UPDATED by CONED 01/15/2021

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

---

**E13THSTA-FARRAGUT 345\_46**

Tue 09/28/2021 to Tue 10/26/2021  
0100 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 01/15/2021

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

---

**W49TH\_ST-E13THSTA 345\_M55**

Tue 09/28/2021 to Tue 10/26/2021  
0100 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 01/15/2021

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

---

# NYISO TRANSFER LIMITATIONS

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## KINTIGH\_-STA\_255\_\_345\_SH1-39

Wed 09/29/2021 to Wed 12/01/2021  
0500 Continuous 1900

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2350 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 3150 MW

## NIAGARA\_-KINTIGH\_\_345\_NS1-38

Wed 09/29/2021 to Wed 12/01/2021  
0500 Continuous 1900

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

## LEEDS\_-HURLYAVE\_345\_301

Mon 10/18/2021 to Fri 11/19/2021  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 2120 MW  
TTC with All Lines In Service 6220 MW

## GOETHALS\_345KV\_5

Thu 10/21/2021 to Sat 11/20/2021 **UPDATED by CONED 03/05/2021**  
0001 Continuous 0200

Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## W49TH\_ST\_345KV\_6

Tue 10/26/2021 to Tue 10/26/2021 **UPDATED by CONED 01/15/2021**  
0230 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

## SCH-IMO-NYISO\_LIMIT\_1750

Mon 11/01/2021 to Fri 12/31/2021 **UPDATED by IESO 05/03/2019**  
0001 Continuous 2359

Work scheduled by: IESO

FWD  
(Import)  
SCH - OH - NY **2050 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 2300 MW

## SCH-NYISO-IMO\_LIMIT\_1600

Mon 11/01/2021 to Fri 12/31/2021 **UPDATED by IESO 05/03/2019**  
0001 Continuous 2359

Work scheduled by: IESO

REV  
(Export)  
SCH - OH - NY **1900 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 2000 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LINDN\_CG-LNDVFT\_\_\_345\_V-3022

Tue 11/02/2021 to Fri 11/05/2021  
0800 Continuous 1500  
Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJM_VFT	0 MW	0 MW
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

## MASSENA -MARCY\_\_\_765\_MSU1 & PORTER -ROTTDAM\_230\_30

Mon 11/15/2021 to Tue 11/30/2021  
0100 1730  
Work scheduled by:

	FWD
	(Import)
CENTRAL EAST - VC	1500 MW
Impacts Total Transfer Capability	1475 MW
TTC with All Lines In Service	2975 MW

## CHATGUAY-MASSENA\_\_\_765\_7040

Mon 11/15/2021 to Tue 11/30/2021  
0100 Continuous 1859  
Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	1550 MW
Impacts Total Transfer Capability	1600 MW
TTC with All Lines In Service	3150 MW

## CHATGUAY-MASSENA\_\_\_765\_7040

Mon 11/15/2021 to Tue 11/30/2021  
0100 Continuous 1859  
Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	0 MW	0 MW
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

## MARCY\_\_\_765\_345\_AT1

Mon 11/15/2021 to Tue 11/30/2021  
0100 Continuous 1859  
Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
MOSES SOUTH	1750 MW
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	3150 MW

## MARCY\_\_\_765\_345\_AT2

Mon 11/15/2021 to Tue 11/30/2021  
0100 Continuous 1859  
Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
MOSES SOUTH	1700 MW
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

## MASSENA -MARCY\_\_\_765\_MSU1

Mon 11/15/2021 to Tue 11/30/2021  
0100 Continuous 1859  
Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	1670 MW
Impacts Total Transfer Capability	1305 MW
TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY____765_MSU1			FWD	
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	
0100	Continuous	1859	MOSES SOUTH	500 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
MASSENA_-MARCY____765_MSU1			FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	(Export)
0100	Continuous	1859	SCH - HQ - NY	475 MW 1000 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1025 MW 0 MW
			TTC with All Lines In Service	1500 MW 1000 MW
MASSENA_-MARCY____765_MSU1			FWD	
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	
0100	Continuous	1859	SCH - HQ_CEDARS	90 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
MASSENA_-MARCY____765_MSU1 & CHATGUAY-MASSENA____765_7040			FWD	
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	
0100		1859	MOSES SOUTH	500 MW
Work scheduled by:			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
MOSES____-MASSENA____230_MMS1 & MOSES____-MASSENA____230_MMS2			FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	(Export)
0100		1859	SCH - HQ - NY	850 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	650 MW 1000 MW
			TTC with All Lines In Service	1500 MW 1000 MW
MOSES____-MASSENA____230_MMS1 & MOSES____-MASSENA____230_MMS2			FWD	
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	
0100		1859	SCH - HQ_CEDARS	90 MW
Work scheduled by:			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
STLAWRNC-MOSES____230_L33P & MASSENA_-MARCY____765_MSU1			FWD	
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	
0100		1859	SCH - HQ_CEDARS	90 MW
Work scheduled by:			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES\_\_\_230\_L33P & MOSES\_\_\_-MASSENA\_230\_MMS1 & MOSES\_\_\_-  
MASSENA\_230\_MMS2

Mon 11/15/2021 to Tue 11/30/2021  
0100 1859

Work scheduled by:

SCH - HQ\_CEDARS

FWD

(Import)

90 MW

Impacts Total Transfer Capability 109 MW

TTC with All Lines In Service 199 MW

FRASER\_\_\_345\_FRASER SVC

Wed 12/01/2021 to Mon 02/28/2022  
0700 Continuous 1730

Work scheduled by: NYPA

CENTRAL EAST - VC

FWD

(Import)

2935 MW

Impacts Total Transfer Capability 40 MW

TTC with All Lines In Service 2975 MW

MOSES\_\_\_-ADIRNDCK\_230\_MAI

Wed 12/01/2021 to Tue 05/31/2022  
0700 Continuous 1300

Work scheduled by: NYPA

MOSES SOUTH

FWD

(Import)

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

NIAGARA\_-STA\_255\_\_\_345\_NH2

Thu 12/02/2021 to Thu 01/13/2022  
0500 Continuous 1900

Work scheduled by: NYPA

DYSINGER EAST

FWD

(Import)

2350 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 3150 MW

MOTTHAVN-RAINEY\_\_\_345\_Q12

Sun 12/05/2021 to Sat 12/25/2021 UPDATED by CONED 03/25/2021  
0001 Continuous 0159

Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD

(Import)

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

LEEDS\_\_\_-PLSNTVLY\_345\_92

Thu 02/17/2022 to Mon 02/21/2022 UPDATED by NGRID 03/31/2021  
0600 Continuous 1900

Work scheduled by: NGrid

UPNY CONED

FWD

(Import)

3800 MW

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

GOETHALS\_345KV\_5

Sat 03/05/2022 to Mon 04/04/2022 UPDATED by CONED 03/26/2021  
0001 Continuous 0200

Work scheduled by: ConEd

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LINDEN\_\_ -GOETHALS\_230\_A2253

Sat 03/05/2022 to Mon 04/04/2022 UPDATED by CONED 03/26/2021

0001 Continuous 0200

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## N. SCTLND-ALPS\_\_\_\_\_345\_2

Mon 05/02/2022 to Mon 05/09/2022

0600 Daily 1800

Work scheduled by: NGrid

FWD

(Import)

SCH - NE - NY

**750 MW**

Impacts Total Transfer Capability 650 MW

TTC with All Lines In Service 1400 MW

## N. SCTLND-ALPS\_\_\_\_\_345\_2

Mon 05/02/2022 to Mon 05/09/2022

0600 Daily 1800

Work scheduled by: NGrid

FWD REV

(Import) (Export)

SCH - NPX\_1385

**100 MW 100 MW**

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

## HOMRC\_NY-MAINS\_NY\_345\_47

Fri 05/20/2022 to Fri 05/27/2022 UPDATED by PJM 11/19/2020

0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## HOMR\_NYW-PIERC\_NY\_345\_48

Fri 05/20/2022 to Fri 05/27/2022 UPDATED by PJM 11/19/2020

0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## MOSES\_\_ -ADIRNDCK\_230\_MA2

Wed 06/01/2022 to Mon 11/14/2022

0700 Continuous 1300

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

## SPRNBK\_345KV\_RNS5

Mon 09/19/2022 to Mon 09/19/2022 UPDATED by CONED 09/17/2020

0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

**NYISO TRANSFER LIMITATIONS**

Thursday ,April 01, 2021 to Saturday ,October 01, 2022

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 6220MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SPRNBRK\_-W49TH\_ST\_345\_M51**

FWD

Mon 09/19/2022 to Wed 09/21/2022 UPDATED by CONED 09/17/2020

(Import)

0001 Continuous 2200

SPR/DUN-SOUTH **3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**SPRNBRK\_345KV\_RNS5**

FWD

Wed 09/21/2022 to Wed 09/21/2022 UPDATED by CONED 09/17/2020

(Import)

2130 Continuous 2200

SPR/DUN-SOUTH **3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**SPRNBRK\_-W49TH\_ST\_345\_M51**

FWD

Sat 10/01/2022 to Mon 10/17/2022 UPDATED by CONED 08/01/2020

(Import)

0001 Continuous 0300

SPR/DUN-SOUTH **3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**SPRNBRK\_345KV\_RNS5**

FWD

Sat 10/01/2022 to Mon 10/17/2022 UPDATED by CONED 08/01/2020

(Import)

0001 Continuous 0300

SPR/DUN-SOUTH **3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd