

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Wed 06/30/2021 EXT FORCE by CONED 08/28/2020

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Wed 06/30/2021

0001 2359

Work scheduled by:

FWD REV
(Import) (Export)

SCH - PJ - NY

Impacts Total Transfer Capability 250 MW 50 MW

TTC with All Lines In Service 2800 MW 1950 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Wed 06/30/2021 EXT FORCE by CONED 08/28/2020

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

STLAWRNC-MOSES_230_L33P

Mon 04/30/2018 to Mon 10/31/2022 EXT FORCE by IESO 10/01/2020

0456 Continuous 1600

Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

NEWBRDGE_345_138_BK_1

Wed 09/02/2020 to Tue 02/01/2022 EXT FORCE by LI 01/12/2021

1807 Continuous 2359

Work scheduled by: LI

FWD
(Import)

SCH - PJM_NEPTUNE

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

SCH-IMO-NYISO_LIMIT_1750

Sun 11/01/2020 to Fri 04/30/2021 UPDATED by IESO 05/03/2019

0001 Continuous 2359

Work scheduled by: IESO

FWD
(Import)

SCH - OH - NY

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 2300 MW

SCH-NYISO-IMO_LIMIT_1600

Sun 11/01/2020 to Fri 04/30/2021 UPDATED by IESO 05/03/2019

0001 Continuous 2359

Work scheduled by: IESO

REV
(Export)

SCH - OH - NY

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 2000 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND_BAR-PLATSBURG_115_PV20

Tue 02/23/2021 to Mon 05/17/2021 UPDATED by NYISO 03/16/2021

1801 Continuous 0559

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

W49TH_ST_345KV_8

Tue 03/02/2021 to Sun 05/02/2021 EXTENDED by CONED 04/10/2021

0201 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)

SCH - PJM_HTP

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

PORTER_-ROTTRDAM_230_31

Tue 03/02/2021 to Mon 05/31/2021 UPDATED by NGRID 03/10/2021

0600 Continuous 1730

Work scheduled by: NGrid

FWD
(Import)

CENTRAL EAST - VC

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

MOSES_-ADIRNDCK_230_MA1

Tue 03/02/2021 to Mon 05/10/2021 UPDATED by NYPA 02/11/2021

0700 Continuous 1159

Work scheduled by: NYPA

FWD
(Import)

MOSES SOUTH

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

W49TH_ST_345KV_6

Sun 03/21/2021 to Sun 05/02/2021 EXTENDED by CONED 04/10/2021

0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)

SCH - PJM_HTP

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

EDIC_-N.SCTLND_345_14 & PORTER_-ROTTRDAM_230_31

Mon 03/22/2021 to Mon 05/31/2021

0600 1730

Work scheduled by:

FWD
(Import)

CENTRAL EAST - VC

Impacts Total Transfer Capability 1475 MW

TTC with All Lines In Service 2975 MW

EDIC_-N.SCTLND_345_14

Mon 03/22/2021 to Mon 05/31/2021 UPDATED by NGRID 03/10/2021

0600 Continuous 1830

Work scheduled by: NGrid

FWD
(Import)

CENTRAL EAST - VC

Impacts Total Transfer Capability 1305 MW

TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

S.RIPLEY-DUNKIRK__230_68

Mon 04/12/2021 to Fri 04/23/2021 **UPDATED** by **NGRID** **04/12/2021**

0630 Continuous 1700

Work scheduled by: NGrid

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

SPRNBRK_-W49TH_ST_345_M51

Wed 04/14/2021 to Wed 04/21/2021 **UPDATED** by **CONED** **04/22/2021**

1124 Continuous 2136

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

SCH-NPX_1385-NYISO_LIMIT_150

Mon 04/19/2021 to Thu 04/29/2021 **FORCED** by **ISONE** **04/17/2021**

0001 Continuous 1600

Work scheduled by: ISONE

FWD
(Import)
SCH - NPX_1385 **150 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 200 MW

N.SCTLND-ALPS____345_2

Mon 04/19/2021 to Mon 04/26/2021 **UPDATED** by **NGRID** **04/20/2021**

0841 Continuous 1800

Work scheduled by: NGrid

FWD
(Import)
SCH - NE - NY **900 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1400 MW

N.SCTLND-ALPS____345_2

Mon 04/19/2021 to Mon 04/26/2021 **UPDATED** by **NGRID** **04/20/2021**

0841 Continuous 1800

Work scheduled by: NGrid

| | |
|-----------------------------------|-----------------------------|
| FWD | REV |
| (Import) | (Export) |
| SCH - NPX_1385 | 100 MW 100 MW |
| Impacts Total Transfer Capability | 100 MW 100 MW |
| TTC with All Lines In Service | 200 MW 200 MW |

N.SCTLND-LEEDS____345_93

Mon 04/19/2021 to Mon 04/26/2021 **UPDATED** by **NGRID** **04/20/2021**

0841 Continuous 1800

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

NRTH1385-NOR HBR__138_601

Wed 04/21/2021 to Wed 04/21/2021 **CANCELLED** by **ISONE** **04/21/2021**

0800 Continuous 1600

Work scheduled by: ISONE

| | |
|-----------------------------------|-----------------------------|
| FWD | REV |
| (Import) | (Export) |
| SCH - NPX_1385 | 100 MW 100 MW |
| Impacts Total Transfer Capability | 100 MW 100 MW |
| TTC with All Lines In Service | 200 MW 200 MW |

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | FWD | REV |
|---|------------|----------------|-------------------------|------------------------|-----------------------------------|----------------|
| | | | | | (Import) | (Export) |
| NRTH1385-NOR HBR__138_602 | | | | | | |
| Wed 04/21/2021 | to | Wed 04/21/2021 | <u>CANCELLED</u> | <u>by ISONE</u> | <u>04/21/2021</u> | |
| 0800 | Continuous | 1600 | | | SCH - NPX_1385 | 100 MW |
| Work scheduled by: ISONE | | | | | Impacts Total Transfer Capability | 100 MW |
| | | | | | TTC with All Lines In Service | 200 MW |
| NRTH1385-NOR HBR__138_603 | | | | | | |
| Wed 04/21/2021 | to | Wed 04/21/2021 | <u>CANCELLED</u> | <u>by ISONE</u> | <u>04/21/2021</u> | |
| 0800 | Continuous | 1600 | | | SCH - NPX_1385 | 100 MW |
| Work scheduled by: ISONE | | | | | Impacts Total Transfer Capability | 100 MW |
| | | | | | TTC with All Lines In Service | 200 MW |
| NRTH1385-NRTHPORT_138_NNC | | | | | | |
| Wed 04/21/2021 | to | Wed 04/21/2021 | <u>CANCELLED</u> | <u>by ISONE</u> | <u>04/21/2021</u> | |
| 0800 | Continuous | 1600 | | | SCH - NPX_1385 | 0 MW |
| Work scheduled by: ISONE | | | | | Impacts Total Transfer Capability | 200 MW |
| | | | | | TTC with All Lines In Service | 200 MW |
| MILLWOOD_345KV_18 | | | | | | |
| Fri 04/23/2021 | to | Sat 04/24/2021 | <u>CANCELLED</u> | <u>by ConEd</u> | <u>04/23/2021</u> | |
| 0201 | Continuous | 2200 | | | UPNY CONED | 4350 MW |
| Work scheduled by: ConEd | | | | | Impacts Total Transfer Capability | 1870 MW |
| | | | | | TTC with All Lines In Service | 6220 MW |
| N.SCTLND-ALPS____345_2 & NRTH1385-NOR HBR__138_601 | | | | | | |
| Fri 04/23/2021 | to | Fri 04/23/2021 | | | | |
| 0800 | | 1600 | | | SCH - NPX_1385 | 0 MW |
| Work scheduled by: | | | | | Impacts Total Transfer Capability | 200 MW |
| | | | | | TTC with All Lines In Service | 200 MW |
| N.SCTLND-ALPS____345_2 & NRTH1385-NOR HBR__138_602 | | | | | | |
| Fri 04/23/2021 | to | Fri 04/23/2021 | | | | |
| 0800 | | 1600 | | | SCH - NPX_1385 | 0 MW |
| Work scheduled by: | | | | | Impacts Total Transfer Capability | 200 MW |
| | | | | | TTC with All Lines In Service | 200 MW |
| N.SCTLND-ALPS____345_2 & NRTH1385-NOR HBR__138_603 | | | | | | |
| Fri 04/23/2021 | to | Fri 04/23/2021 | | | | |
| 0800 | | 1600 | | | SCH - NPX_1385 | 0 MW |
| Work scheduled by: | | | | | Impacts Total Transfer Capability | 200 MW |
| | | | | | TTC with All Lines In Service | 200 MW |

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | |
|---|------------|------|-----------------------------------|---------------|
| NRTH1385-NOR HBR__138_601 | | | FWD | REV |
| Fri 04/23/2021 to Fri 04/23/2021 | | | (Import) | (Export) |
| 0800 | Continuous | 1600 | SCH - NPX_1385 | 100 MW 100 MW |
| Work scheduled by: ISONE | | | Impacts Total Transfer Capability | 100 MW 100 MW |
| | | | TTC with All Lines In Service | 200 MW 200 MW |
| NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602 | | | FWD | REV |
| Fri 04/23/2021 to Fri 04/23/2021 | | | (Import) | (Export) |
| 0800 | | 1600 | SCH - NPX_1385 | 0 MW 0 MW |
| Work scheduled by: | | | Impacts Total Transfer Capability | 200 MW 200 MW |
| | | | TTC with All Lines In Service | 200 MW 200 MW |
| NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603 | | | FWD | REV |
| Fri 04/23/2021 to Fri 04/23/2021 | | | (Import) | (Export) |
| 0800 | | 1600 | SCH - NPX_1385 | 0 MW 0 MW |
| Work scheduled by: | | | Impacts Total Transfer Capability | 200 MW 200 MW |
| | | | TTC with All Lines In Service | 200 MW 200 MW |
| NRTH1385-NOR HBR__138_602 | | | FWD | REV |
| Fri 04/23/2021 to Fri 04/23/2021 | | | (Import) | (Export) |
| 0800 | Continuous | 1600 | SCH - NPX_1385 | 100 MW 100 MW |
| Work scheduled by: ISONE | | | Impacts Total Transfer Capability | 100 MW 100 MW |
| | | | TTC with All Lines In Service | 200 MW 200 MW |
| NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603 | | | FWD | REV |
| Fri 04/23/2021 to Fri 04/23/2021 | | | (Import) | (Export) |
| 0800 | | 1600 | SCH - NPX_1385 | 0 MW 0 MW |
| Work scheduled by: | | | Impacts Total Transfer Capability | 200 MW 200 MW |
| | | | TTC with All Lines In Service | 200 MW 200 MW |
| NRTH1385-NOR HBR__138_603 | | | FWD | REV |
| Fri 04/23/2021 to Fri 04/23/2021 | | | (Import) | (Export) |
| 0800 | Continuous | 1600 | SCH - NPX_1385 | 100 MW 100 MW |
| Work scheduled by: ISONE | | | Impacts Total Transfer Capability | 100 MW 100 MW |
| | | | TTC with All Lines In Service | 200 MW 200 MW |
| NRTH1385-NRTHPORT_138_NNC | | | FWD | REV |
| Fri 04/23/2021 to Fri 04/23/2021 | | | (Import) | (Export) |
| 0800 | Continuous | 1600 | SCH - NPX_1385 | 0 MW 0 MW |
| Work scheduled by: ISONE | | | Impacts Total Transfer Capability | 200 MW 200 MW |
| | | | TTC with All Lines In Service | 200 MW 200 MW |

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 7815MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-WOOD_ST__345_F30

FWD

Sat 04/24/2021 to Sat 04/24/2021 **CANCELLED** **by ConEd** **04/22/2021**

(Import)

0201 Continuous 0230

Work scheduled by: ConEd

UPNY CONED

4000 MW

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

PLSNTVLY_345KV_RNS5

FWD

Sat 04/24/2021 to Sat 04/24/2021 **CANCELLED** **by ConEd** **04/22/2021**

(Import)

0201 Continuous 0230

Work scheduled by: ConEd

UPNY CONED

3800 MW

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

SCH-NYISO-NE_LIMIT_900

REV

Sat 04/24/2021 to Sat 05/01/2021 **UPDATED** **by ISONE** **04/20/2021**

(Export)

0801 Continuous 0800

Work scheduled by: ISONE

SCH - NE - NY

1100 MW

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 1700 MW

CHAT_DC_GC1

FWD

Sat 04/24/2021 to Sun 04/25/2021

(Import)

2000 Continuous 0500

Work scheduled by: HQ

MOSES SOUTH

2850 MW

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

CHAT_DC_GC1

REV

Sat 04/24/2021 to Sun 04/25/2021

(Export)

2000 Continuous 0500

Work scheduled by: HQ

SCH - HQ - NY

500 MW

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

SCH-IMO-NYISO_LIMIT_1250

FWD

Mon 04/26/2021 to Mon 04/26/2021 **UPDATED** **by NYISO** **04/23/2021**

(Import)

0500 Continuous 1700

Work scheduled by: NYPA

SCH - OH - NY

1550 MW

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 2300 MW

SCH-NYISO-IMO_LIMIT_1100

REV

Mon 04/26/2021 to Mon 04/26/2021 **UPDATED** **by NYISO** **04/23/2021**

(Export)

0500 Continuous 1700

Work scheduled by: NYPA

SCH - OH - NY

1400 MW

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2000 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 7815MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

KINTIGH_-STA_255__345_SH1-39

FWD

Mon 04/26/2021 to Fri 04/30/2021

(Import)

0700 Continuous 1700

DYSINGER EAST 1700 MW

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

NIAGARA_-KINTIGH__345_NS1-38

FWD

Mon 04/26/2021 to Fri 04/30/2021

(Import)

0700 Continuous 1700

DYSINGER EAST 1700 MW

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

HOMRC_NY-MAINS_NY_345_47

Mon 04/26/2021 to Sat 05/29/2021

UPDATED by NYSEG 04/26/2021

0800 Continuous 1900

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYSEG

FRASER_-COOPERS__345_33

FWD

Mon 04/26/2021 to Fri 04/30/2021

(Import)

0830 Continuous 1500

CENTRAL EAST - VC 2395 MW

Impacts Total Transfer Capability 580 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

PLSNTVLY-WOOD_ST__345_F30

FWD

Tue 04/27/2021 to Wed 04/28/2021

CANCELLED by ConEd 04/22/2021

0001 Continuous 0200

UPNY CONED 4000 MW

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

PLSNTVLY_345KV_RNS5

FWD

Tue 04/27/2021 to Wed 04/28/2021

CANCELLED by ConEd 04/22/2021

0001 Continuous 0200

UPNY CONED 3800 MW

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

MILLWOOD_345KV_18

FWD

Tue 04/27/2021 to Wed 04/28/2021

(Import)

0200 Continuous 2200

UPNY CONED 4350 MW

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 7815MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-WOOD_ST__345_F30

FWD

Tue 04/27/2021 to Tue 04/27/2021
 0201 Continuous 0230

UPDATED**by CE****04/23/2021**

Work scheduled by: ConEd

UPNY CONED

(Import)

4000 MW

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

PLSNTVLY_345KV_RNS5

FWD

Tue 04/27/2021 to Tue 04/27/2021
 0201 Continuous 0230

UPDATED**by CE****04/23/2021**

Work scheduled by: ConEd

UPNY CONED

(Import)

3800 MW

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

SCH-IMO-NYISO_NIAG_CB_3008_W/BB

REV

Tue 04/27/2021 to Tue 04/27/2021
 0500 Continuous 1700

UPDATED**by NYISO****04/23/2021**

Work scheduled by: NYPA

SCH - OH - NY

(Export)

1750 MW

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 2000 MW

ALCOA_PA_115KV_R8105

FWD

Tue 04/27/2021 to Thu 04/29/2021
 0630 Continuous 1830

Work scheduled by: NGrid

MOSES SOUTH

(Import)

3100 MW

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 3150 MW

MOTTHAVN-RAINEY__345_Q11

FWD

Wed 04/28/2021 to Sat 05/08/2021
 0001 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

(Import)

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

PLSNTVLY-WOOD_ST__345_F30

FWD

Fri 04/30/2021 to Sat 05/01/2021
 0001 Continuous 0200

UPDATED**by CE****04/23/2021**

Work scheduled by: ConEd

UPNY CONED

(Import)

4000 MW

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

PLSNTVLY_345KV_RNS5

FWD

Fri 04/30/2021 to Sat 05/01/2021
 0001 Continuous 0200

UPDATED**by CE****04/23/2021**

Work scheduled by: ConEd

UPNY CONED

(Import)

3800 MW

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | |
|---------------------------|------------|----------------|-----------------|-----------------------------------|---|
| BUCHAN_N-EASTVIEW_345_W93 | | | | | FWD |
| Fri 04/30/2021 | to | Mon 05/10/2021 | <u>EXTENDED</u> | <u>by CONED</u> <u>04/19/2021</u> | (Import) |
| 0700 | Continuous | 0159 | | | UPNY CONED 4350 MW |
| Work scheduled by: ConEd | | | | | Impacts Total Transfer Capability 1870 MW |
| | | | | | TTC with All Lines In Service 6220 MW |
| SCH-IMO-NYISO_LIMIT_1600 | | | | | FWD |
| Sat 05/01/2021 | to | Sun 10/31/2021 | <u>UPDATED</u> | <u>by IESO</u> <u>05/03/2019</u> | (Import) |
| 0001 | Continuous | 2359 | | | SCH - OH - NY 1900 MW |
| Work scheduled by: IESO | | | | | Impacts Total Transfer Capability 50 MW |
| | | | | | TTC with All Lines In Service 1950 MW |
| W49TH_ST_345KV_5 | | | | | FWD |
| Sun 05/02/2021 | to | Sun 05/02/2021 | <u>UPDATED</u> | <u>by CONED</u> <u>04/13/2021</u> | (Import) |
| 0201 | Continuous | 0231 | | | SCH - PJM_HTP 300 MW |
| Work scheduled by: ConEd | | | | | Impacts Total Transfer Capability 360 MW |
| | | | | | TTC with All Lines In Service 660 MW |
| W49TH_ST_345KV_7 | | | | | FWD |
| Sun 05/02/2021 | to | Sun 05/02/2021 | <u>UPDATED</u> | <u>by CONED</u> <u>04/13/2021</u> | (Import) |
| 0201 | Continuous | 0231 | | | SCH - PJM_HTP 300 MW |
| Work scheduled by: ConEd | | | | | Impacts Total Transfer Capability 360 MW |
| | | | | | TTC with All Lines In Service 660 MW |
| CHAT_DC_GC2 | | | | | FWD |
| Sun 05/02/2021 | to | Fri 05/28/2021 | | | (Import) |
| 0500 | Continuous | 1700 | | | MOSES SOUTH 2850 MW |
| Work scheduled by: HQ | | | | | Impacts Total Transfer Capability 300 MW |
| | | | | | TTC with All Lines In Service 3150 MW |
| CHAT_DC_GC2 | | | | | REV |
| Sun 05/02/2021 | to | Fri 05/28/2021 | | | (Export) |
| 0500 | Continuous | 1700 | | | SCH - HQ - NY 500 MW |
| Work scheduled by: HQ | | | | | Impacts Total Transfer Capability 500 MW |
| | | | | | TTC with All Lines In Service 1000 MW |
| DUNWODIE_345KV_7 | | | | | FWD |
| Mon 05/03/2021 | to | Mon 05/03/2021 | | | (Import) |
| 0001 | Continuous | 0030 | | | SPR/DUN-SOUTH 3800 MW |
| Work scheduled by: ConEd | | | | | Impacts Total Transfer Capability 800 MW |
| | | | | | TTC with All Lines In Service 4600 MW |

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | |
|--|------------|----------------|--|-----------------------------------|----------------------|
| DUNWODIE_345KV_8 | | | | FWD | |
| Mon 05/03/2021 | to | Mon 05/03/2021 | | (Import) | |
| 0001 | Continuous | 0030 | | | |
| Work scheduled by: ConEd | | | | SPR/DUN-SOUTH | 3800 MW |
| | | | | Impacts Total Transfer Capability | 800 MW |
| | | | | TTC with All Lines In Service | 4600 MW |
| DUNWODIE-MOTTHAVN_345_72 | | | | FWD | |
| Mon 05/03/2021 | to | Mon 05/03/2021 | | (Import) | |
| 0001 | Continuous | 1800 | | | |
| Work scheduled by: ConEd | | | | SPR/DUN-SOUTH | 3800 MW |
| | | | | Impacts Total Transfer Capability | 800 MW |
| | | | | TTC with All Lines In Service | 4600 MW |
| NRTH1385-NOR HBR_138_601 | | | | FWD | REV |
| Mon 05/03/2021 | to | Mon 05/24/2021 | | (Import) | (Export) |
| 0600 | Continuous | 2359 | | | |
| Work scheduled by: LI | | | | SCH - NPX_1385 | 100 MW 100 MW |
| | | | | Impacts Total Transfer Capability | 100 MW 100 MW |
| | | | | TTC with All Lines In Service | 200 MW 200 MW |
| NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_602 | | | | FWD | REV |
| Mon 05/03/2021 | to | Mon 05/24/2021 | | (Import) | (Export) |
| 0600 | | 2359 | | | |
| Work scheduled by: | | | | SCH - NPX_1385 | 0 MW 0 MW |
| | | | | Impacts Total Transfer Capability | 200 MW 200 MW |
| | | | | TTC with All Lines In Service | 200 MW 200 MW |
| NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_603 | | | | FWD | REV |
| Mon 05/03/2021 | to | Mon 05/24/2021 | | (Import) | (Export) |
| 0600 | | 2359 | | | |
| Work scheduled by: | | | | SCH - NPX_1385 | 0 MW 0 MW |
| | | | | Impacts Total Transfer Capability | 200 MW 200 MW |
| | | | | TTC with All Lines In Service | 200 MW 200 MW |
| NRTH1385-NOR HBR_138_602 | | | | FWD | REV |
| Mon 05/03/2021 | to | Mon 05/24/2021 | | (Import) | (Export) |
| 0600 | Continuous | 2359 | | | |
| Work scheduled by: LI | | | | SCH - NPX_1385 | 100 MW 100 MW |
| | | | | Impacts Total Transfer Capability | 100 MW 100 MW |
| | | | | TTC with All Lines In Service | 200 MW 200 MW |
| NRTH1385-NOR HBR_138_602 & NRTH1385-NOR HBR_138_603 | | | | FWD | REV |
| Mon 05/03/2021 | to | Mon 05/24/2021 | | (Import) | (Export) |
| 0600 | | 2359 | | | |
| Work scheduled by: | | | | SCH - NPX_1385 | 0 MW 0 MW |
| | | | | Impacts Total Transfer Capability | 200 MW 200 MW |
| | | | | TTC with All Lines In Service | 200 MW 200 MW |

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | |
|---------------------------|------------|----------------|-----------------------------------|---------------|
| NRTH1385-NOR HBR__138_603 | | | FWD | REV |
| Mon 05/03/2021 | to | Mon 05/24/2021 | (Import) | (Export) |
| 0600 | Continuous | 2359 | SCH - NPX_1385 | 100 MW 100 MW |
| Work scheduled by: LI | | | Impacts Total Transfer Capability | 100 MW 100 MW |
| | | | TTC with All Lines In Service | 200 MW 200 MW |
| NRTH1385-NRTHPORT_138_NNC | | | FWD | REV |
| Mon 05/03/2021 | to | Mon 05/24/2021 | (Import) | (Export) |
| 0600 | Continuous | 2359 | SCH - NPX_1385 | 0 MW 0 MW |
| Work scheduled by: LI | | | Impacts Total Transfer Capability | 200 MW 200 MW |
| | | | TTC with All Lines In Service | 200 MW 200 MW |
| CLAY__-EDIC__345_2-15 | | | FWD | |
| Mon 05/03/2021 | to | Fri 05/07/2021 | (Import) | |
| 0700 | Continuous | 1530 | OSWEGO EXPORT | 4850 MW |
| Work scheduled by: NYPA | | | Impacts Total Transfer Capability | 400 MW |
| | | | TTC with All Lines In Service | 5250 MW |
| FIVEMILE-STOLLERD_345_29 | | | | |
| Mon 05/03/2021 | to | Fri 05/14/2021 | SCH - PJ - NY | |
| 0700 | Continuous | 1400 | Impacts Total Transfer Capability | |
| Work scheduled by: NYSEG | | | TTC with All Lines In Service | |
| SCH-HQ-NYISO_LIMIT_1400 | | | FWD | |
| Mon 05/03/2021 | to | Fri 05/14/2021 | (Import) | |
| 0700 | Continuous | 1530 | SCH - HQ - NY | 1400 MW |
| Work scheduled by: HQ | | | Impacts Total Transfer Capability | 100 MW |
| | | | TTC with All Lines In Service | 1500 MW |
| PANNELL_-CLAY__345_2 | | | FWD | |
| Mon 05/03/2021 | to | Sun 05/30/2021 | (Import) | |
| 0700 | Continuous | 1730 | WEST CENTRAL | 1300 MW |
| Work scheduled by: NYPA | | | Impacts Total Transfer Capability | 950 MW |
| | | | TTC with All Lines In Service | 2250 MW |
| HURLYAVE-ROSETON__345_303 | | | FWD | |
| Mon 05/03/2021 | to | Fri 05/21/2021 | (Import) | |
| 0800 | Continuous | 1600 | UPNY CONED | 4100 MW |
| Work scheduled by: CHGE | | | Impacts Total Transfer Capability | 3715 MW |
| | | | TTC with All Lines In Service | 7815 MW |

CANCELLED by CHGE 04/26/2021

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| SHOR_NPX-SHOREHAM_138_CSC | | | | FWD | REV |
|-------------------------------|--------------------|----------------|---|-----------------------------------|----------------|
| | | | | (Import) | (Export) |
| Mon 05/03/2021 | to | Sat 05/08/2021 | <u>EXTENDED</u> <u>by ISONE</u> <u>03/15/2021</u> | | |
| 0900 | Continuous | 1600 | | SCH - NPX_CSC | 0 MW |
| Work scheduled by: LI | | | | Impacts Total Transfer Capability | 330 MW |
| | | | | TTC with All Lines In Service | 330 MW |
| DUNWODIE_345KV_7 | | | | FWD | |
| | | | | (Import) | |
| Mon 05/03/2021 | to | Mon 05/03/2021 | | | |
| 1730 | Continuous | 1800 | | SPR/DUN-SOUTH | 3800 MW |
| Work scheduled by: ConEd | | | | Impacts Total Transfer Capability | 800 MW |
| | | | | TTC with All Lines In Service | 4600 MW |
| DUNWODIE_345KV_8 | | | | FWD | |
| | | | | (Import) | |
| Mon 05/03/2021 | to | Mon 05/03/2021 | | | |
| 1730 | Continuous | 1800 | | SPR/DUN-SOUTH | 3800 MW |
| Work scheduled by: ConEd | | | | Impacts Total Transfer Capability | 800 MW |
| | | | | TTC with All Lines In Service | 4600 MW |
| ROTTRDAM-EASTOVER_230_38 | | | | | REV |
| | | | | | (Export) |
| Tue 05/04/2021 | to | Tue 05/04/2021 | | | |
| 0830 | Daily(No Weekends) | 1130 | | SCH - NE - NY | 1400 MW |
| Work scheduled by: NGrid | | | | Impacts Total Transfer Capability | 200 MW |
| | | | | TTC with All Lines In Service | 1600 MW |
| SCH-NYISO-IMO_NIAGARA_CB_3102 | | | | FWD | REV |
| | | | | (Import) | (Export) |
| Thu 05/06/2021 | to | Fri 05/07/2021 | | | |
| 0500 | Continuous | 1700 | | SCH - OH - NY | 1700 MW |
| Work scheduled by: NYPA | | | | Impacts Total Transfer Capability | 250 MW |
| | | | | TTC with All Lines In Service | 1950 MW |
| RAMAPO__-BUCHAN_N_345_Y94 | | | | FWD | |
| | | | | (Import) | |
| Fri 05/07/2021 | to | Mon 05/10/2021 | <u>EXTENDED</u> <u>by CONED</u> <u>04/19/2021</u> | | |
| 0001 | Continuous | 0159 | | UPNY CONED | 7580 MW |
| Work scheduled by: ConEd | | | | Impacts Total Transfer Capability | 235 MW |
| | | | | TTC with All Lines In Service | 7815 MW |
| EASTVIEW-SPRNBK__345_W79 | | | | FWD | |
| | | | | (Import) | |
| Sat 05/08/2021 | to | Sun 05/09/2021 | <u>EXTENDED</u> <u>by CONED</u> <u>04/19/2021</u> | | |
| 0700 | Continuous | 2359 | | UPNY CONED | 4350 MW |
| Work scheduled by: ConEd | | | | Impacts Total Transfer Capability | 3465 MW |
| | | | | TTC with All Lines In Service | 7815 MW |

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | |
|-------------------------------------|------------|----------------|----------------|-----------------|-----------------------------------|------------------------|
| W49TH_ST_345KV_5 | | | | | FWD | |
| Sun 05/09/2021 | to | Sun 05/09/2021 | <u>UPDATED</u> | <u>by CONED</u> | <u>04/13/2021</u> | (Import) |
| 0130 | Continuous | 0200 | | | | |
| Work scheduled by: ConEd | | | | | SCH - PJM_HTP | 300 MW |
| | | | | | Impacts Total Transfer Capability | 360 MW |
| | | | | | TTC with All Lines In Service | 660 MW |
| W49TH_ST_345KV_7 | | | | | FWD | |
| Sun 05/09/2021 | to | Sun 05/09/2021 | <u>UPDATED</u> | <u>by CONED</u> | <u>04/13/2021</u> | (Import) |
| 0130 | Continuous | 0200 | | | | |
| Work scheduled by: ConEd | | | | | SCH - PJM_HTP | 300 MW |
| | | | | | Impacts Total Transfer Capability | 360 MW |
| | | | | | TTC with All Lines In Service | 660 MW |
| W49TH_ST_345KV_7 | | | | | FWD | |
| Mon 05/10/2021 | to | Mon 05/10/2021 | | | | (Import) |
| 0001 | Continuous | 0030 | | | | |
| Work scheduled by: ConEd | | | | | SCH - PJM_HTP | 300 MW |
| | | | | | Impacts Total Transfer Capability | 360 MW |
| | | | | | TTC with All Lines In Service | 660 MW |
| W49TH_ST_345KV_8 | | | | | FWD | |
| Mon 05/10/2021 | to | Mon 05/10/2021 | | | | (Import) |
| 0001 | Continuous | 0030 | | | | |
| Work scheduled by: ConEd | | | | | SCH - PJM_HTP | 450 MW |
| | | | | | Impacts Total Transfer Capability | 210 MW |
| | | | | | TTC with All Lines In Service | 660 MW |
| HUDSONTP-W49TH_ST_345_Y56 | | | | | FWD | |
| Mon 05/10/2021 | to | Thu 05/13/2021 | | | | (Import) |
| 0001 | Continuous | 2300 | | | | |
| Work scheduled by: ConEd | | | | | SCH - PJM_HTP | 0 MW |
| | | | | | Impacts Total Transfer Capability | 660 MW |
| | | | | | TTC with All Lines In Service | 660 MW |
| SPRNBK_-TREMONT_345_X28 | | | | | FWD | |
| Mon 05/10/2021 | to | Wed 05/26/2021 | <u>UPDATED</u> | <u>by CONED</u> | <u>03/18/2021</u> | (Import) |
| 0001 | Continuous | 0200 | | | | |
| Work scheduled by: ConEd | | | | | SPR/DUN-SOUTH | 4200 MW |
| | | | | | Impacts Total Transfer Capability | 400 MW |
| | | | | | TTC with All Lines In Service | 4600 MW |
| SCH-IMO_NY_NIAG_CB_3122_W/BB | | | | | FWD REV | |
| Mon 05/10/2021 | to | Wed 05/12/2021 | <u>UPDATED</u> | <u>by NYISO</u> | <u>04/23/2021</u> | (Import) (Export) |
| 0500 | Continuous | 1700 | | | | |
| Work scheduled by: NYPA | | | | | SCH - OH - NY | 1700 MW 1400 MW |
| | | | | | Impacts Total Transfer Capability | 250 MW 300 MW |
| | | | | | TTC with All Lines In Service | 1950 MW 1700 MW |

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY -EDIC 345_1-16

Mon 05/10/2021 to Fri 05/14/2021

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

OSWEGO EXPORT

4850 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

MOSES -ADIRNDCK 230_MA2

Mon 05/10/2021 to Tue 06/01/2021

1200 Continuous 0659

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

2100 MW

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

BUCHAN_N-EASTVIEW 345_W93

Tue 05/11/2021 to Wed 05/12/2021

0001 Continuous 0200

Work scheduled by: ConEd

UPDATEDby CONED 04/23/2021

FWD

(Import)

UPNY CONED

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

RAMAPO -BUCHAN_N 345_Y94

Tue 05/11/2021 to Wed 05/12/2021

0001 Continuous 0200

Work scheduled by: ConEd

UPDATEDby CONED 04/23/2021

FWD

(Import)

UPNY CONED

7580 MW

Impacts Total Transfer Capability 235 MW

TTC with All Lines In Service 7815 MW

ALCOA_PA_115KV_R8105

Tue 05/11/2021 to Thu 06/03/2021

0630 Continuous 1630

Work scheduled by: NGrid

FWD

(Import)

MOSES SOUTH

3100 MW

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 3150 MW

DENNISON-ROSEMNTB 115_2/22

Wed 05/12/2021 to Wed 05/12/2021

0630 Daily(No Weekends) 1830

Work scheduled by: NGrid

UPDATEDby HQ 04/16/2021

FWD

(Import) (Export)

SCH - HQ_CEDARS

95 MW 40 MW

Impacts Total Transfer Capability 95 MW 0 MW

TTC with All Lines In Service 190 MW 40 MW

SCH-HQ_CEDARS-NYISO_LIMIT_80

Wed 05/12/2021 to Wed 05/12/2021

0630 Daily(No Weekends) 1830

Work scheduled by: NGrid

UPDATEDby HQ 04/16/2021

FWD

(Import)

SCH - HQ_CEDARS

80 MW

Impacts Total Transfer Capability 110 MW

TTC with All Lines In Service 190 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-IMO_NIAGARA_CB_3108

REV

Thu 05/13/2021 to Fri 05/14/2021 **UPDATED by NYISO 04/23/2021**

(Export)

0500 Continuous 1700

Work scheduled by: NYPA

SCH - OH - NY

1500 MW

Impacts Total Transfer Capability

200 MW

TTC with All Lines In Service

1700 MW

W49TH_ST_345KV_7

FWD

Thu 05/13/2021 to Thu 05/13/2021

(Import)

2230 Continuous 2300

Work scheduled by: ConEd

SCH - PJM_HTP

300 MW

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

W49TH_ST_345KV_8

FWD

Thu 05/13/2021 to Thu 05/13/2021

(Import)

2230 Continuous 2300

Work scheduled by: ConEd

SCH - PJM_HTP

450 MW

Impacts Total Transfer Capability

210 MW

TTC with All Lines In Service

660 MW

CRICKVLY-PLSNTVLY_345_F83

FWD

Fri 05/14/2021 to Fri 05/14/2021

(Import)

0001 Continuous 2200

Work scheduled by: ConEd

SCH - NE - NY

350 MW

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

1400 MW

CRICKVLY-PLSNTVLY_345_F83

FWD

REV

Fri 05/14/2021 to Fri 05/14/2021

(Import) (Export)

0001 Continuous 2200

Work scheduled by: ConEd

SCH - NPX_1385

100 MW**100 MW**

Impacts Total Transfer Capability

100 MW

100 MW

TTC with All Lines In Service

200 MW

200 MW

NRTH1385-NOR HBR_138_601 & CRICKVLY-PLSNTVLY_345_F83

FWD

REV

Fri 05/14/2021 to Fri 05/14/2021

(Import) (Export)

0001 2200

Work scheduled by:

SCH - NPX_1385

0 MW**0 MW**

Impacts Total Transfer Capability

200 MW

200 MW

TTC with All Lines In Service

200 MW

200 MW

NRTH1385-NOR HBR_138_602 & CRICKVLY-PLSNTVLY_345_F83

FWD

REV

Fri 05/14/2021 to Fri 05/14/2021

(Import) (Export)

0001 2200

Work scheduled by:

SCH - NPX_1385

0 MW**0 MW**

Impacts Total Transfer Capability

200 MW

200 MW

TTC with All Lines In Service

200 MW

200 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_603 & CRICKVLY-PLSNTVLY_345_F83

Fri 05/14/2021 to Fri 05/14/2021
0001 2200

Work scheduled by:

| | FWD | REV |
|-----------------------------------|-------------|-------------|
| | (Import) | (Export) |
| SCH - NPX_1385 | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 200 MW | 200 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4

Sat 05/15/2021 to Sat 05/15/2021
0301 2230

Work scheduled by:

| | FWD |
|-----------------------------------|----------------|
| | (Import) |
| SPR/DUN-SOUTH | 3200 MW |
| Impacts Total Transfer Capability | 1400 MW |
| TTC with All Lines In Service | 4600 MW |

NIAGARA_-STA_255__345_NH2

Mon 05/17/2021 to Fri 05/21/2021 UPDATED by NYPA 03/23/2021
0500 Continuous 1700

Work scheduled by: NYPA

| | FWD |
|-----------------------------------|----------------|
| | (Import) |
| DYSINGER EAST | 1400 MW |
| Impacts Total Transfer Capability | 1750 MW |
| TTC with All Lines In Service | 3150 MW |

SAND_BAR-PLATSBRG_115_PV20

Mon 05/17/2021 to Fri 07/02/2021
0600 Continuous 1800

Work scheduled by: ISONE

| |
|-----------------------------------|
| SCH - NE - NY |
| Impacts Total Transfer Capability |
| TTC with All Lines In Service |

GOETHALS_345KV_5

Wed 05/19/2021 to Mon 05/24/2021 EXTENDED by CE 04/05/2021
0100 Continuous 0200

Work scheduled by: ConEd

| |
|-----------------------------------|
| STATEN ISLAND |
| Impacts Total Transfer Capability |
| TTC with All Lines In Service |

LINDEN_-GOETHALS_230_A2253

Wed 05/19/2021 to Mon 05/24/2021 EXTENDED by CE 04/05/2021
0100 Continuous 0200

Work scheduled by: ConEd

| | FWD | REV |
|-----------------------------------|----------------|----------------|
| | (Import) | (Export) |
| SCH - PJ - NY | 2050 MW | 1150 MW |
| Impacts Total Transfer Capability | 150 MW | 100 MW |
| TTC with All Lines In Service | 2200 MW | 1250 MW |

LINDEN_-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402

Wed 05/19/2021 to Mon 05/24/2021
0100 0200

Work scheduled by:

| | FWD | REV |
|-----------------------------------|----------------|----------------|
| | (Import) | (Export) |
| SCH - PJ - NY | 2000 MW | 1000 MW |
| Impacts Total Transfer Capability | 200 MW | 250 MW |
| TTC with All Lines In Service | 2200 MW | 1250 MW |

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402 & MARION__-
FARRAGUT_345_C3403

Wed 05/19/2021 to Mon 05/24/2021
0100 0200

Work scheduled by:

| | | |
|-----------------------------------|----------|----------|
| | FWD | REV |
| | (Import) | (Export) |
| SCH - PJ - NY | 2000 MW | 1000 MW |
| Impacts Total Transfer Capability | 200 MW | 250 MW |
| TTC with All Lines In Service | 2200 MW | 1250 MW |

LINDEN__-GOETHALS_230_A2253 & MARION__-FARRAGUT_345_C3403

Wed 05/19/2021 to Mon 05/24/2021
0100 0200

Work scheduled by:

| | | |
|-----------------------------------|----------|----------|
| | FWD | REV |
| | (Import) | (Export) |
| SCH - PJ - NY | 2000 MW | 1000 MW |
| Impacts Total Transfer Capability | 200 MW | 250 MW |
| TTC with All Lines In Service | 2200 MW | 1250 MW |

BUCHAN_S-MILLWOOD_345_W97

Thu 05/20/2021 to Sat 05/22/2021
0001 Continuous 0200

Work scheduled by: ConEd

| | |
|-----------------------------------|----------|
| | FWD |
| | (Import) |
| UPNY CONED | 7680 MW |
| Impacts Total Transfer Capability | 135 MW |
| TTC with All Lines In Service | 7815 MW |

W49TH_ST_345KV_6

Thu 05/20/2021 to Sat 05/22/2021 UPDATED by CONED 03/30/2021
0001 Continuous 0200

Work scheduled by: ConEd

| | |
|-----------------------------------|----------|
| | FWD |
| | (Import) |
| SCH - PJM_HTP | 300 MW |
| Impacts Total Transfer Capability | 360 MW |
| TTC with All Lines In Service | 660 MW |

W49TH_ST-E13THSTA_345_M55

Thu 05/20/2021 to Mon 05/24/2021 UPDATED by CONED 03/30/2021
0001 Continuous 0200

Work scheduled by: ConEd

| | |
|-----------------------------------|----------|
| | FWD |
| | (Import) |
| SPR/DUN-SOUTH | 3800 MW |
| Impacts Total Transfer Capability | 800 MW |
| TTC with All Lines In Service | 4600 MW |

E13THSTA-FARRAGUT_345_46

Sat 05/22/2021 to Mon 05/24/2021 UPDATED by CONED 03/30/2021
0001 Continuous 0200

Work scheduled by: ConEd

| | |
|-----------------------------------|----------|
| | FWD |
| | (Import) |
| SPR/DUN-SOUTH | 3800 MW |
| Impacts Total Transfer Capability | 800 MW |
| TTC with All Lines In Service | 4600 MW |

PLSNTVLY-WOOD_ST_345_F31

Mon 05/24/2021 to Tue 05/25/2021
0001 Continuous 0159

Work scheduled by: ConEd

| | |
|-----------------------------------|----------|
| | FWD |
| | (Import) |
| UPNY CONED | 4000 MW |
| Impacts Total Transfer Capability | 3815 MW |
| TTC with All Lines In Service | 7815 MW |

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS4

FWD

Mon 05/24/2021 to Tue 05/25/2021

(Import)

0001 Continuous 0159

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

W49TH_ST_345KV_6

FWD

Mon 05/24/2021 to Mon 05/24/2021

(Import)

0130 Continuous 0200

UPDATED by CONED 03/30/2021

SCH - PJM_HTP

300 MW

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

DENNISON-ROSEMNTB_115_2/22

FWD

REV

Mon 05/24/2021 to Wed 05/26/2021

(Import) (Export)

0630 Continuous 1900

SCH - HQ_CEDARS

95 MW 40 MW

Impacts Total Transfer Capability 95 MW 0 MW

TTC with All Lines In Service 190 MW 40 MW

Work scheduled by: NGrid

SCH-HQ_CEDARS-NYISO_LIMIT_80

FWD

Mon 05/24/2021 to Wed 05/26/2021

(Import)

0630 Continuous 1900

SCH - HQ_CEDARS

80 MW

Impacts Total Transfer Capability 110 MW

TTC with All Lines In Service 190 MW

Work scheduled by: NGrid

ROSETON_-EFISHKIL_345_RFK305

FWD

Wed 05/26/2021 to Thu 05/27/2021

(Import)

0001 Continuous 0200

UPNY CONED

6680 MW

Impacts Total Transfer Capability 1135 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

DENNISON-ROSEMNTA_115_1/11

FWD

REV

Thu 05/27/2021 to Fri 05/28/2021

(Import) (Export)

0630 Continuous 1900

SCH - HQ_CEDARS

95 MW 40 MW

Impacts Total Transfer Capability 95 MW 0 MW

TTC with All Lines In Service 190 MW 40 MW

Work scheduled by: NGrid

SCH-HQ_CEDARS-NYISO_LIMIT_80

FWD

Thu 05/27/2021 to Fri 05/28/2021

(Import)

0630 Continuous 1900

SCH - HQ_CEDARS

80 MW

Impacts Total Transfer Capability 110 MW

TTC with All Lines In Service 190 MW

Work scheduled by: NGrid

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

VOLNEY__-MARCY____345_19

Tue 06/01/2021 to Wed 06/02/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2825 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 2975 MW

VOLNEY__-MARCY____345_19

Tue 06/01/2021 to Wed 06/02/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
OSWEGO EXPORT **4900 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 5250 MW

FRASER__-GILBOA____345_GF5-35

Tue 06/01/2021 to Mon 06/07/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

MOSES__-ADIRNDCK_230_MA2

Tue 06/01/2021 to Sun 11/14/2021
0700 Continuous 1300

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

MARCY__-EDIC____345_UE1-7

Thu 06/03/2021 to Fri 06/04/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19&16

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

PORTER__-ROTTRDAM_230_30

Thu 06/03/2021 to Wed 09/15/2021
0700 Continuous 0659

Work scheduled by: NGrid

UPDATED by NGRID 01/19/2021

FWD
(Import)
CENTRAL EAST - VC **2805 MW**
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

MARCY____345KV_CSC

Sat 06/05/2021 to Sat 06/05/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS4

FWD

Tue 06/08/2021 to Tue 06/08/2021 UPDATED by CONED 04/26/2021
0600 Continuous 0630

(Import)

Work scheduled by: NGrid

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

ATHENS__-PLSNTVLY_345_91

FWD

Tue 06/08/2021 to Wed 06/16/2021 UPDATED by CONED 04/26/2021
0600 Continuous 2000

(Import)

Work scheduled by: NGrid

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

GILBOA__-N.SCTLND_345_GNS-1

FWD

Wed 06/09/2021 to Wed 06/09/2021
0800 Daily 1200

(Import)

Work scheduled by: NGrid

CENTRAL EAST - VC **2520 MW**
Impacts Total Transfer Capability 455 MW
TTC with All Lines In Service 2975 MW

BECK____-NIAGARA__345_PA301

FWD

REV

Wed 06/16/2021 to Thu 06/17/2021
0500 Continuous 2330

(Import) (Export)

Work scheduled by: NYPA

SCH - OH - NY **900 MW 800 MW**
Impacts Total Transfer Capability 1050 MW 900 MW
TTC with All Lines In Service 1950 MW 1700 MW

PLSNTVLY_345KV_RNS4

FWD

Wed 06/16/2021 to Wed 06/16/2021 UPDATED by CONED 04/26/2021
1930 Continuous 2000

(Import)

Work scheduled by: NGrid

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

PLSNTVLY_345KV_RNS5

FWD

Thu 06/17/2021 to Thu 06/17/2021 UPDATED by CONED 04/19/2021
0001 Continuous 0030

(Import)

Work scheduled by: NGrid

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

LEEDS____-PLSNTVLY_345_92

FWD

Thu 06/17/2021 to Thu 06/24/2021 UPDATED by CONED 04/19/2021
0001 Continuous 2000

(Import)

Work scheduled by: NGrid

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS5

FWD

Thu 06/24/2021 to Thu 06/24/2021 UPDATED by CONED 04/19/2021

(Import)

1930 Continuous 2000

Work scheduled by: NGrid

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

BECK____-NIAGARA__345_PA301

FWD

REV

Fri 06/25/2021 to Fri 06/25/2021

(Import) (Export)

0500 Continuous 1700

Work scheduled by: NYPA

SCH - OH - NY

900 MW 800 MW

Impacts Total Transfer Capability 1050 MW 900 MW

TTC with All Lines In Service 1950 MW 1700 MW

FRASANNX-COOPERS__345_UCC2-41

FWD

Fri 06/25/2021 to Tue 08/10/2021

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

2500 MW

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

MARCY____-FRASANNX_345_UCC2-41

FWD

Fri 06/25/2021 to Tue 08/10/2021

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

2500 MW

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

BECK____-NIAGARA__345_PA302

FWD

REV

Mon 07/12/2021 to Fri 07/16/2021

(Import) (Export)

0500 Continuous 1700

Work scheduled by: NYPA

SCH - OH - NY

900 MW 800 MW

Impacts Total Transfer Capability 1050 MW 900 MW

TTC with All Lines In Service 1950 MW 1700 MW

NIAGARA__345_230_AT4

FWD

REV

Mon 07/19/2021 to Fri 07/30/2021 UPDATED by NYPA 02/19/2021

(Import) (Export)

0500 Continuous 1700

Work scheduled by: NYPA

SCH - OH - NY

1900 MW 1400 MW

Impacts Total Transfer Capability 50 MW 300 MW

TTC with All Lines In Service 1950 MW 1700 MW

NIAGARA_-STA_255__345_NH2

FWD

Mon 07/26/2021 to Fri 07/30/2021 UPDATED by NYPA 02/19/2021

(Import)

0500 Continuous 1900

Work scheduled by: NYPA

DYSINGER EAST

1400 MW

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND_BAR-PLATSBURG_115_PV20

Tue 08/03/2021 to Tue 08/03/2021
0700 Continuous 1830

Work scheduled by: NYPA

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

KINTIGH_-STA_255__345_SH1-39

Mon 08/09/2021 to Sun 08/15/2021
0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

1400 MW

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH__345_NS1-38

Mon 08/09/2021 to Sun 08/15/2021
0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

1400 MW

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

KINTIGH_-STA_255__345_SH1-39

Mon 08/16/2021 to Sun 08/22/2021
0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

1400 MW

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH__345_NS1-38

Mon 08/16/2021 to Sun 08/22/2021
0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

1400 MW

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

NIAGARA_-STA_255__345_NH2

Wed 09/01/2021 to Tue 09/21/2021
0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

1400 MW

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

FRASANNX-COOPERS__345_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC

2500 MW

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

UPDATED

by NYISO 02/03/2021

ARR: 19

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-FRASANNX_345_UCC2-41

FWD

Tue 09/07/2021 to Wed 09/15/2021 UPDATED by NYISO 02/03/2021

(Import)

0700 Continuous 1730

CENTRAL EAST - VC **2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

ARR: 19

PORTER___-ROTTRDAM_230_30

FWD

Wed 09/15/2021 to Tue 11/30/2021

(Import)

0700 Continuous 1730

CENTRAL EAST - VC **2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

EDIC___-N.SCTLND_345_14

FWD

Thu 09/16/2021 to Sun 11/14/2021

(Import)

0700 Continuous 1730

CENTRAL EAST - VC **1670 MW**

Impacts Total Transfer Capability 1305 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

EDIC___-N.SCTLND_345_14 & PORTER___-ROTTRDAM_230_30

FWD

Thu 09/16/2021 to Sun 11/14/2021

(Import)

0700 1730

CENTRAL EAST - VC **1500 MW**

Impacts Total Transfer Capability 1475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

HURLYAVE-ROSETON___345_303

FWD

Thu 09/16/2021 to Sun 10/17/2021 UPDATED by CHGE 09/22/2020

(Import)

0800 Continuous 1600

UPNY CONED **4100 MW**

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: CHGE

HOMRC_NY-MAINS_NY_345_47

Sat 09/18/2021 to Fri 11/05/2021

0800 Continuous 1600

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: PJM

PANNELL___-CLAY___345_1

FWD

Mon 09/20/2021 to Fri 09/24/2021

(Import)

0700 Continuous 1530

WEST CENTRAL **1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY____-EDIC____345_2-15

Mon 09/20/2021 to Sat 10/16/2021

0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

OSWEGO EXPORT

4850 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

KINTIGH_-STA_255_345_SH1-39

Mon 09/27/2021 to Wed 09/29/2021

0500 Continuous 0459

Work scheduled by: NYPA

UPDATEDby NYPA03/04/2021

FWD

(Import)

DYSINGER EAST

1400 MW

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH_345_NS1-38

Mon 09/27/2021 to Wed 09/29/2021

0500 Continuous 0459

Work scheduled by: NYPA

UPDATEDby NYPA03/04/2021

FWD

(Import)

DYSINGER EAST

1400 MW

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

PANNELL_-CLAY____345_2

Mon 09/27/2021 to Fri 10/01/2021

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

WEST CENTRAL

1300 MW

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

W49TH_ST_345KV_6

Tue 09/28/2021 to Tue 09/28/2021

0100 Continuous 0130

Work scheduled by: ConEd

CANCELLEDby ConEd04/23/2021

FWD

(Import)

SCH - PJM_HTP

300 MW

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

E13THSTA-FARRAGUT_345_46

Tue 09/28/2021 to Tue 10/26/2021

0100 Continuous 0300

Work scheduled by: ConEd

CANCELLEDby ConEd04/23/2021

FWD

(Import)

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

W49TH_ST-E13THSTA_345_M55

Tue 09/28/2021 to Tue 10/26/2021

0100 Continuous 0300

Work scheduled by: ConEd

CANCELLEDby ConEd04/23/2021

FWD

(Import)

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

KINTIGH_-STA_255__345_SH1-39

Wed 09/29/2021 to Wed 12/01/2021

0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST 1400 MW

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH__345_NS1-38

Wed 09/29/2021 to Wed 12/01/2021

0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST 1400 MW

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

LEEDS_-HURLYAVE_345_301

Mon 10/18/2021 to Fri 11/19/2021

0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED 4100 MW

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

GOETHALS_345KV_5

Thu 10/21/2021 to Sat 11/20/2021

0001 Continuous 0200

Work scheduled by: ConEd

UPDATEDby CONED 03/05/2021

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

W49TH_ST_345KV_6

Tue 10/26/2021 to Tue 10/26/2021

0230 Continuous 0300

Work scheduled by: ConEd

CANCELLEDby ConEd 04/23/2021

FWD

(Import)

SCH - PJM_HTP 300 MW

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

SCH-IMO-NYISO_LIMIT_1750

Mon 11/01/2021 to Fri 12/31/2021

0001 Continuous 2359

Work scheduled by: IESO

UPDATEDby IESO 05/03/2019

FWD

(Import)

SCH - OH - NY 2050 MW

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 2300 MW

SCH-NYISO-IMO_LIMIT_1600

Mon 11/01/2021 to Fri 12/31/2021

0001 Continuous 2359

Work scheduled by: IESO

UPDATEDby IESO 05/03/2019

REV

(Export)

SCH - OH - NY 1900 MW

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 2000 MW

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDN_CG-LNDVFT___345_V-3022

Tue 11/02/2021 to Fri 11/05/2021
0800 Continuous 1500

Work scheduled by: PJM

| | FWD | REV |
|-----------------------------------|----------|----------|
| | (Import) | (Export) |
| SCH - PJM_VFT | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 315 MW | 315 MW |
| TTC with All Lines In Service | 315 MW | 315 MW |

PORTER_-ROTTDAM_230_30 & MASSENA_-MARCY___765_MSU1

Mon 11/15/2021 to Tue 11/30/2021
0100 1730

Work scheduled by:

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| CENTRAL EAST - VC | 1500 MW |
| Impacts Total Transfer Capability | 1475 MW |
| TTC with All Lines In Service | 2975 MW |

CHATGUAY-MASSENA___765_7040

Mon 11/15/2021 to Tue 11/30/2021
0100 Continuous 1859

Work scheduled by: NYPA

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| MOSES SOUTH | 1550 MW |
| Impacts Total Transfer Capability | 1600 MW |
| TTC with All Lines In Service | 3150 MW |

CHATGUAY-MASSENA___765_7040

Mon 11/15/2021 to Tue 11/30/2021
0100 Continuous 1859

Work scheduled by: NYPA

| | FWD | REV |
|-----------------------------------|----------|----------|
| | (Import) | (Export) |
| SCH - HQ - NY | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 1500 MW | 1000 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

MARCY___765_345_AT1

Mon 11/15/2021 to Tue 11/30/2021
0100 Continuous 1859

Work scheduled by: NYPA

ARR: 19

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| MOSES SOUTH | 1750 MW |
| Impacts Total Transfer Capability | 1400 MW |
| TTC with All Lines In Service | 3150 MW |

MARCY___765_345_AT2

Mon 11/15/2021 to Tue 11/30/2021
0100 Continuous 1859

Work scheduled by: NYPA

ARR: 19

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| MOSES SOUTH | 1700 MW |
| Impacts Total Transfer Capability | 1450 MW |
| TTC with All Lines In Service | 3150 MW |

MASSENA_-MARCY___765_MSU1

Mon 11/15/2021 to Tue 11/30/2021
0100 Continuous 1859

Work scheduled by: NYPA

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| CENTRAL EAST - VC | 1670 MW |
| Impacts Total Transfer Capability | 1305 MW |
| TTC with All Lines In Service | 2975 MW |

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 7815MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY_765_MSU1

Mon 11/15/2021 to Tue 11/30/2021
 0100 Continuous 1859

Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **500 MW**
 Impacts Total Transfer Capability 2650 MW
 TTC with All Lines In Service 3150 MW

MASSENA_-MARCY_765_MSU1

Mon 11/15/2021 to Tue 11/30/2021
 0100 Continuous 1859

Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - HQ - NY **475 MW 1000 MW**
 Impacts Total Transfer Capability 1025 MW 0 MW
 TTC with All Lines In Service 1500 MW 1000 MW

MASSENA_-MARCY_765_MSU1

Mon 11/15/2021 to Tue 11/30/2021
 0100 Continuous 1859

Work scheduled by: NYPA

FWD
 (Import)
 SCH - HQ_CEDARS **90 MW**
 Impacts Total Transfer Capability 109 MW
 TTC with All Lines In Service 199 MW

MASSENA_-MARCY_765_MSU1 & CHATGUAY-MASSENA_765_7040

Mon 11/15/2021 to Tue 11/30/2021
 0100 1859

Work scheduled by:

FWD
 (Import)
 MOSES SOUTH **500 MW**
 Impacts Total Transfer Capability 2650 MW
 TTC with All Lines In Service 3150 MW

MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2

Mon 11/15/2021 to Tue 11/30/2021
 0100 1859

Work scheduled by:

FWD REV
 (Import) (Export)
 SCH - HQ - NY **850 MW 0 MW**
 Impacts Total Transfer Capability 650 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2

Mon 11/15/2021 to Tue 11/30/2021
 0100 1859

Work scheduled by:

FWD
 (Import)
 SCH - HQ_CEDARS **90 MW**
 Impacts Total Transfer Capability 109 MW
 TTC with All Lines In Service 199 MW

STLAWRNC-MOSES_230_L33P & MASSENA_-MARCY_765_MSU1

Mon 11/15/2021 to Tue 11/30/2021
 0100 1859

Work scheduled by:

FWD
 (Import)
 SCH - HQ_CEDARS **90 MW**
 Impacts Total Transfer Capability 109 MW
 TTC with All Lines In Service 199 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 7815MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES___230_L33P & MOSES___-MASSENA_230_MMS1 & MOSES___-
MASSENA_230_MMS2

Mon 11/15/2021 to Tue 11/30/2021
0100 1859

Work scheduled by:

SCH - HQ_CEDARS 90 MW
Impacts Total Transfer Capability 109 MW
TTC with All Lines In Service 199 MW

FRASER___345_FRASER SVC

Wed 12/01/2021 to Mon 02/28/2022
0700 Continuous 1730

Work scheduled by: NYPA

FWD (Import)
CENTRAL EAST - VC 2935 MW
Impacts Total Transfer Capability 40 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MAI

Wed 12/01/2021 to Tue 05/31/2022
0700 Continuous 1300

Work scheduled by: NYPA

FWD (Import)
MOSES SOUTH 2300 MW
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-STA_255___345_NH2

Thu 12/02/2021 to Thu 01/13/2022
0500 Continuous 1900

Work scheduled by: NYPA

FWD (Import)
DYSINGER EAST 1700 MW
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MOTTHAVN-RAINEY___345_Q12

Sun 12/05/2021 to Sat 12/25/2021 UPDATED by CONED 03/25/2021
0001 Continuous 0159

Work scheduled by: ConEd

FWD (Import)
SPR/DUN-SOUTH 3800 MW
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

LEEDS___-PLSNTVLY_345_92

Thu 02/17/2022 to Mon 02/21/2022 UPDATED by NGRID 03/31/2021
0600 Continuous 1900

Work scheduled by: NGrid

FWD (Import)
UPNY CONED 3800 MW
Impacts Total Transfer Capability 2420 MW
TTC with All Lines In Service 6220 MW

NIAGARA_-STA_255___345_NH2

Sat 02/26/2022 to Mon 02/28/2022
0500 Continuous 1900

Work scheduled by: NYPA

FWD (Import)
DYSINGER EAST 1700 MW
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PORTER__-ROTTRDAM_230_31

Tue 03/01/2022 to Tue 12/31/2030
0600 Continuous 2359

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC **2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

GOETHALS_345KV_5

Sat 03/05/2022 to Mon 04/04/2022
0001 Continuous 0200

Work scheduled by: ConEd

UPDATEDby CONED 03/26/2021

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

LINDEN__-GOETHALS_230_A2253

Sat 03/05/2022 to Mon 04/04/2022
0001 Continuous 0200

Work scheduled by: ConEd

UPDATEDby CONED 03/26/2021

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

PORTER__-ROTTRDAM_230_30

Wed 04/13/2022 to Tue 12/31/2030
0600 Continuous 2359

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC **2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

N.SCTLND-ALPS_____345_2

Mon 05/02/2022 to Mon 05/09/2022
0600 Daily 1800

Work scheduled by: NGrid

FWD

(Import)

SCH - NE - NY

750 MW

Impacts Total Transfer Capability 650 MW

TTC with All Lines In Service 1400 MW

N.SCTLND-ALPS_____345_2

Mon 05/02/2022 to Mon 05/09/2022
0600 Daily 1800

Work scheduled by: NGrid

FWD

(Import) (Export)

SCH - NPX_1385

100 MW 100 MW

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

HOMRC_NY-MAINS_NY_345_47

Fri 05/20/2022 to Fri 05/27/2022
0800 Continuous 1600

Work scheduled by: PJM

UPDATEDby PJM 11/19/2020

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Monday ,April 26, 2021 to Wednesday,October 26, 2022

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 7815MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOMR_NYW-PIERC_NY_345_48Fri 05/20/2022 to Fri 05/27/2022 **UPDATED** **by PJM** **11/19/2020**

0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

MOSES__-ADIRNDCK_230_MA2

Wed 06/01/2022 to Mon 11/14/2022

0700 Continuous 1300

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

2100 MW

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

SPRNBRK__345KV_RNS5Mon 09/19/2022 to Mon 09/19/2022 **UPDATED** **by CONED** **09/17/2020**

0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

SPRNBRK_-W49TH_ST_345_M51Mon 09/19/2022 to Wed 09/21/2022 **UPDATED** **by CONED** **09/17/2020**

0001 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

SPRNBRK__345KV_RNS5Wed 09/21/2022 to Wed 09/21/2022 **UPDATED** **by CONED** **09/17/2020**

2130 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

SPRNBRK_-W49TH_ST_345_M51Sat 10/01/2022 to Mon 10/17/2022 **UPDATED** **by CONED** **08/01/2020**

0001 Continuous 0300

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

SPRNBRK__345KV_RNS5Sat 10/01/2022 to Mon 10/17/2022 **UPDATED** **by CONED** **08/01/2020**

0001 Continuous 0300

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW