

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**HUDSONP\_-FARRAGUT\_345\_B3402**

Mon 01/15/2018 to Wed 06/30/2021 EXT FORCE by CONED 08/28/2020  
 0001 Continuous 2359  
 Work scheduled by: ConEd

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403**

Mon 01/15/2018 to Wed 06/30/2021  
 0001 2359  
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2550 MW</b>	<b>1900 MW</b>
Impacts Total Transfer Capability	250 MW	50 MW
TTC with All Lines In Service	2800 MW	1950 MW

**MARION\_-FARRAGUT\_345\_C3403**

Mon 01/15/2018 to Wed 06/30/2021 EXT FORCE by CONED 08/28/2020  
 0001 Continuous 2359  
 Work scheduled by: ConEd

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**STLAWRNC-MOSES\_230\_L33P**

Mon 04/30/2018 to Mon 10/31/2022 EXT FORCE by IESO 10/01/2020  
 0456 Continuous 1600  
 Work scheduled by: IESO

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**NEWBRDGE\_345\_138\_BK\_1**

Wed 09/02/2020 to Tue 02/01/2022 EXT FORCE by LI 01/12/2021  
 1807 Continuous 2359  
 Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	<b>375 MW</b>
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

**SPRNBK\_-EGRDNCTR\_345\_Y49**

Thu 10/01/2020 to Mon 04/19/2021 EXT FORCE by LI 02/23/2021  
 0404 Continuous 2359  
 Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	<b>775 MW</b>
Impacts Total Transfer Capability	725 MW
TTC with All Lines In Service	1500 MW

**EGRDNCTY\_345\_138\_AT2**

Sat 10/10/2020 to Mon 04/19/2021 EXT FORCE by LI 02/23/2021  
 1815 Continuous 2359  
 Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	<b>1250 MW</b>
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	1500 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EGRDNCTY_345_138_AT1</b>						FWD
Sat 10/10/2020	to	Mon 04/19/2021	<u>EXT FORCE</u>	<u>by LI</u>	<u>02/23/2021</u>	(Import)
1856	Continuous	2359				CONED - LIPA <b>1250 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 1500 MW
<b>SCH-IMO-NYISO_LIMIT_1750</b>						FWD
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				SCH - OH - NY <b>2050 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 2300 MW
<b>SCH-NYISO-IMO_LIMIT_1600</b>						REV
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Export)
0001	Continuous	2359				SCH - OH - NY <b>1900 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability 100 MW
						TTC with All Lines In Service 2000 MW
<b>SAND_BAR-PLATSBRG_115_PV20</b>						
Tue 02/23/2021	to	Mon 05/17/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>03/16/2021</u>	
1801	Continuous	0559				SCH - NE - NY
Work scheduled by: ISONE						Impacts Total Transfer Capability
						TTC with All Lines In Service
<b>W49TH_ST_345KV_8</b>						FWD
Tue 03/02/2021	to	Sun 05/02/2021	<u>EXTENDED</u>	<u>by CONED</u>	<u>04/10/2021</u>	(Import)
0201	Continuous	0200				SCH - PJM_HTP <b>300 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 360 MW
						TTC with All Lines In Service 660 MW
<b>PORTER__-ROTTRDAM_230_31</b>						FWD
Tue 03/02/2021	to	Mon 05/31/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/10/2021</u>	(Import)
0600	Continuous	1730				CENTRAL EAST - VC <b>2805 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability 170 MW
						TTC with All Lines In Service 2975 MW
<b>MOSES__-ADIRNDCK_230_MAL</b>						FWD
Tue 03/02/2021	to	Mon 05/10/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/11/2021</u>	(Import)
0700	Continuous	1159				MOSES SOUTH <b>2300 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 850 MW
						TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_6**

Sun 03/21/2021 to Sun 05/02/2021 **EXTENDED** by **CONED** 04/10/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**EDIC -N.SCTLND\_345\_14 & PORTER -ROTRDAM\_230\_31**

Mon 03/22/2021 to Mon 05/31/2021  
 0600 1730  
 Work scheduled by:

FWD  
 (Import)  
 CENTRAL EAST - VC **1500 MW**  
 Impacts Total Transfer Capability 1475 MW  
 TTC with All Lines In Service 2975 MW

**EDIC -N.SCTLND\_345\_14**

Mon 03/22/2021 to Mon 05/31/2021 **UPDATED** by **NGRID** 03/10/2021  
 0600 Continuous 1830  
 Work scheduled by: NGrid

FWD  
 (Import)  
 CENTRAL EAST - VC **1670 MW**  
 Impacts Total Transfer Capability 1305 MW  
 TTC with All Lines In Service 2975 MW

**MOTHAVN-RAINEY\_345\_Q11**

Thu 04/08/2021 to Mon 04/12/2021 **EXT FORCE** by **CONED** 04/11/2021  
 2309 Continuous 2359  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**S.RIPLEY-DUNKIRK\_230\_68**

Mon 04/12/2021 to Fri 04/23/2021 **UPDATED** by **NGRID** 04/12/2021  
 0630 Continuous 1700  
 Work scheduled by: NGrid

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**LEEDS\_345KV\_R94301**

Mon 04/12/2021 to Mon 04/12/2021 **UPDATED** by **NGRID** 02/01/2021  
 0800 Continuous 0830  
 Work scheduled by: CHGE

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 2420 MW  
 TTC with All Lines In Service 6220 MW

**LEEDS -HURLYAVE\_345\_301**

Mon 04/12/2021 to Wed 04/14/2021 **UPDATED** by **NGRID** 02/01/2021  
 0800 Continuous 1825  
 Work scheduled by: CHGE

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 2120 MW  
 TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK_-W49TH_ST_345_M51</b>					FWD	
Wed 04/14/2021	to	Mon 04/26/2021	<b>EXTENDED</b>	<b>by CONED</b>	<b>04/16/2021</b>	(Import)
1124	Continuous	2359				SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
<b>SCH-NPX_1385-NYISO_LIMIT_150</b>					FWD	
Mon 04/19/2021	to	Thu 04/29/2021	<b>FORCED</b>	<b>by ISONE</b>	<b>04/17/2021</b>	(Import)
0001	Continuous	1600				SCH - NPX_1385 <b>150 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	200 MW
<b>DUNWODIE_345KV_6</b>					FWD	
Tue 04/20/2021	to	Tue 04/20/2021	<b>UPDATED</b>	<b>by CONED</b>	<b>02/19/2021</b>	(Import)
0201	Continuous	0230				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_8</b>					FWD	
Tue 04/20/2021	to	Tue 04/20/2021	<b>UPDATED</b>	<b>by CONED</b>	<b>02/19/2021</b>	(Import)
0201	Continuous	0230				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>WOOD_ST_-PLSNTVLE_345_Y87</b>					FWD	
Tue 04/20/2021	to	Tue 04/20/2021	<b>UPDATED</b>	<b>by CONED</b>	<b>02/19/2021</b>	(Import)
0201	Continuous	0230				UPNY CONED <b>5905 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	315 MW
					TTC with All Lines In Service	6220 MW
<b>PLSNTVLE-DUNWODIE_345_W90</b>					FWD	
Tue 04/20/2021	to	Fri 04/23/2021	<b>UPDATED</b>	<b>by CONED</b>	<b>02/19/2021</b>	(Import)
0201	Continuous	0159				UPNY CONED <b>4000 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	2220 MW
					TTC with All Lines In Service	6220 MW
<b>MAINESBG-WATRCURE_345_30</b>					FWD	
Tue 04/20/2021	to	Wed 04/21/2021				(Import)
0800	Continuous	1530				SCH - PJ - NY <b>2300 MW</b>
Work scheduled by: NYSEG					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	2800 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

			FWD	REV
			(Import)	(Export)
<b>NRTH1385-NOR HBR__138_601</b>				
Wed 04/21/2021	to	Wed 04/21/2021		
0800	Continuous	1600	SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR__138_601 &amp; NRTH1385-NOR HBR__138_602</b>				
Wed 04/21/2021	to	Wed 04/21/2021		
0800		1600	SCH - NPX_1385	<b>0 MW 0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR__138_601 &amp; NRTH1385-NOR HBR__138_603</b>				
Wed 04/21/2021	to	Wed 04/21/2021		
0800		1600	SCH - NPX_1385	<b>0 MW 0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR__138_602</b>				
Wed 04/21/2021	to	Wed 04/21/2021		
0800	Continuous	1600	SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR__138_602 &amp; NRTH1385-NOR HBR__138_603</b>				
Wed 04/21/2021	to	Wed 04/21/2021		
0800		1600	SCH - NPX_1385	<b>0 MW 0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR__138_603</b>				
Wed 04/21/2021	to	Wed 04/21/2021		
0800	Continuous	1600	SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NRTHPORT_138_NNC</b>				
Wed 04/21/2021	to	Wed 04/21/2021		
0800	Continuous	1600	SCH - NPX_1385	<b>0 MW 0 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_6**

Fri 04/23/2021 to Fri 04/23/2021 UPDATED by CONED 02/19/2021  
 0130 Continuous 0159  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_8**

Fri 04/23/2021 to Fri 04/23/2021 UPDATED by CONED 02/19/2021  
 0130 Continuous 0159  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**WOOD\_ST\_-PLSNTVLE\_345\_Y87**

Fri 04/23/2021 to Fri 04/23/2021 UPDATED by CONED 02/19/2021  
 0130 Continuous 0159  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **5905 MW**  
 Impacts Total Transfer Capability 315 MW  
 TTC with All Lines In Service 6220 MW

**PLSNTVLY-WOOD\_ST\_\_345\_F30**

Fri 04/23/2021 to Fri 04/23/2021 UPDATED by CONED 04/17/2021  
 0201 Continuous 0230  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 2220 MW  
 TTC with All Lines In Service 6220 MW

**PLSNTVLY\_345KV\_RNS5**

Fri 04/23/2021 to Fri 04/23/2021 UPDATED by CONED 04/17/2021  
 0201 Continuous 0230  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 2420 MW  
 TTC with All Lines In Service 6220 MW

**MILLWOOD-EASTVIEW\_345\_W82**

Fri 04/23/2021 to Fri 04/23/2021 UPDATED by CONED 04/02/2021  
 0201 Continuous 1800  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **5985 MW**  
 Impacts Total Transfer Capability 235 MW  
 TTC with All Lines In Service 6220 MW

**MILLWOOD\_345KV\_18**

Fri 04/23/2021 to Sat 04/24/2021 UPDATED by CONED 04/02/2021  
 0201 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1870 MW  
 TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CHAT\_DC\_GC1**

Sat 04/24/2021 to Sun 04/25/2021  
 2000 Continuous 0500  
 Work scheduled by: HQ

FWD  
 (Import)  
**MOSES SOUTH 2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC1**

Sat 04/24/2021 to Sun 04/25/2021  
 2000 Continuous 0500  
 Work scheduled by: HQ

REV  
 (Export)  
**SCH - HQ - NY 500 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 1000 MW

**PLSNTVLY-WOOD\_ST\_345\_F30**

Mon 04/26/2021 to Tue 04/27/2021 **UPDATED** **by CONED** **04/17/2021**  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
**UPNY CONED 4000 MW**  
 Impacts Total Transfer Capability 2220 MW  
 TTC with All Lines In Service 6220 MW

**PLSNTVLY\_345KV\_RNS5**

Mon 04/26/2021 to Tue 04/27/2021 **UPDATED** **by CONED** **04/17/2021**  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
**UPNY CONED 3800 MW**  
 Impacts Total Transfer Capability 2420 MW  
 TTC with All Lines In Service 6220 MW

**KINTIGH\_-STA\_255\_345\_SH1-39**

Mon 04/26/2021 to Fri 04/30/2021  
 0700 Continuous 1700  
 Work scheduled by: NYPA

FWD  
 (Import)  
**DYSINGER EAST 1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

**NIAGARA\_-KINTIGH\_345\_NS1-38**

Mon 04/26/2021 to Fri 04/30/2021  
 0700 Continuous 1700  
 Work scheduled by: NYPA

FWD  
 (Import)  
**DYSINGER EAST 1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

**HOMRC\_NY-MAINS\_NY\_345\_47**

Mon 04/26/2021 to Sat 05/29/2021 **EXTENDED** **by NYSEG** **03/10/2021**  
 0800 Continuous 1900  
 Work scheduled by: NYSEG

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**FRASER\_\_-COOPERS\_\_345\_33**

Mon 04/26/2021 to Fri 04/30/2021  
 0830 Continuous 1500  
 Work scheduled by: NYSEG

FWD  
 (Import)  
 CENTRAL EAST - VC **2395 MW**  
 Impacts Total Transfer Capability 580 MW  
 TTC with All Lines In Service 2975 MW

**ALCOA\_PA\_115KV\_R8105**

Tue 04/27/2021 to Thu 04/29/2021  
 0630 Continuous 1830  
 Work scheduled by: NGrid

FWD  
 (Import)  
 MOSES SOUTH **3100 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 3150 MW

**MOTTHAVN-RAINEY\_\_345\_Q11**

Wed 04/28/2021 to Sat 05/08/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

Fri 04/30/2021 to Sun 05/09/2021 **UPDATED by CONED 04/07/2021**  
 0700 Continuous 2359  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1870 MW  
 TTC with All Lines In Service 6220 MW

**SCH-IMO-NYISO\_LIMIT\_1600**

Sat 05/01/2021 to Sun 10/31/2021 **UPDATED by IESO 05/03/2019**  
 0001 Continuous 2359  
 Work scheduled by: IESO

FWD  
 (Import)  
 SCH - OH - NY **1900 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 1950 MW

**W49TH\_ST\_345KV\_5**

Sun 05/02/2021 to Sun 05/02/2021 **UPDATED by CONED 04/13/2021**  
 0201 Continuous 0231  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_7**

Sun 05/02/2021 to Sun 05/02/2021 **UPDATED by CONED 04/13/2021**  
 0201 Continuous 0231  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event	Start	End	Time	Zone	Direction	Value
CHAT_DC_GC2	Sun 05/02/2021	Fri 05/28/2021	0500 - 1700	MOSES SOUTH	FWD (Import)	2850 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
CHAT_DC_GC2	Sun 05/02/2021	Fri 05/28/2021	0500 - 1700	SCH - HQ - NY	REV (Export)	500 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
DUNWODIE_345KV_7	Mon 05/03/2021	Mon 05/03/2021	0001 - 0030	SPR/DUN-SOUTH	FWD (Import)	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8	Mon 05/03/2021	Mon 05/03/2021	0001 - 0030	SPR/DUN-SOUTH	FWD (Import)	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE-MOTTHAVN_345_72	Mon 05/03/2021	Mon 05/03/2021	0001 - 1800	SPR/DUN-SOUTH	FWD (Import)	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
NRTH1385-NOR HBR_138_601	Mon 05/03/2021	Mon 05/24/2021	0600 - 2359	SCH - NPX_1385	FWD (Import) / REV (Export)	100 MW / 100 MW
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW / 100 MW
					TTC with All Lines In Service	200 MW / 200 MW
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_602	Mon 05/03/2021	Mon 05/24/2021	0600 - 2359	SCH - NPX_1385	FWD (Import) / REV (Export)	0 MW / 0 MW
Work scheduled by:					Impacts Total Transfer Capability	200 MW / 200 MW
					TTC with All Lines In Service	200 MW / 200 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_603**

Mon 05/03/2021 to Mon 05/24/2021  
 0600 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NOR HBR\_\_138\_602**

Mon 05/03/2021 to Mon 05/24/2021  
 0600 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NOR HBR\_\_138\_602 & NRTH1385-NOR HBR\_\_138\_603**

Mon 05/03/2021 to Mon 05/24/2021  
 0600 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NOR HBR\_\_138\_603**

Mon 05/03/2021 to Mon 05/24/2021  
 0600 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NRTHPORT\_138\_NNC**

Mon 05/03/2021 to Mon 05/24/2021  
 0600 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**CLAY\_\_-EDIC\_\_345\_2-15**

Mon 05/03/2021 to Fri 05/07/2021  
 0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
OSWEGO EXPORT	<b>4850 MW</b>
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	5250 MW

-----  
**FIVEMILE-STOLLERD\_345\_29**

Mon 05/03/2021 to Fri 05/14/2021  
 0700 Continuous 1400

Work scheduled by: NYSEG

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-HQ-NYISO\_LIMIT\_1400**

Mon 05/03/2021 to Fri 05/14/2021  
0700 Continuous 1530

Work scheduled by: HQ

FWD  
(Import)  
SCH - HQ - NY **1400 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 1500 MW

**PANNELL -CLAY\_345\_2**

Mon 05/03/2021 to Sun 05/30/2021  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**HURLYAVE-ROSETON\_345\_303**

Mon 05/03/2021 to Fri 05/21/2021  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 3715 MW  
TTC with All Lines In Service 7815 MW

**SHOR\_NPX-SHOREHAM\_138\_CSC**

Mon 05/03/2021 to Sat 05/08/2021 **EXTENDED by ISONE 03/15/2021**  
0900 Continuous 1600

Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_CSC **0 MW 0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

**DUNWODIE\_345KV\_7**

Mon 05/03/2021 to Mon 05/03/2021  
1730 Continuous 1800

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_8**

Mon 05/03/2021 to Mon 05/03/2021  
1730 Continuous 1800

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**ROTTDAM-EASTOVER\_230\_38**

Tue 05/04/2021 to Tue 05/04/2021  
0830 Daily(No Weekends) 1130

Work scheduled by: NGrid

**ARR: 77**

REV  
(Export)  
SCH - NE - NY **1400 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1600 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>RAMAPO__-BUCHAN_N_345_Y94</b>					FWD	
Fri 05/07/2021	to	Sun 05/09/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/07/2021</u>	(Import)
0001	Continuous	2359				UPNY CONED <b>7580 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 235 MW	
					TTC with All Lines In Service 7815 MW	
<b>EASTVIEW-SPRNBK__345_W79</b>					FWD	
Sat 05/08/2021	to	Sun 05/09/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/07/2021</u>	(Import)
0700	Continuous	2359				UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW	
					TTC with All Lines In Service 7815 MW	
<b>W49TH_ST_345KV_5</b>					FWD	
Sun 05/09/2021	to	Sun 05/09/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/13/2021</u>	(Import)
0130	Continuous	0200				SCH - PJM_HTP <b>300 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW	
					TTC with All Lines In Service 660 MW	
<b>W49TH_ST_345KV_7</b>					FWD	
Sun 05/09/2021	to	Sun 05/09/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/13/2021</u>	(Import)
0130	Continuous	0200				SCH - PJM_HTP <b>300 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW	
					TTC with All Lines In Service 660 MW	
<b>W49TH_ST_345KV_7</b>					FWD	
Mon 05/10/2021	to	Mon 05/10/2021				(Import)
0001	Continuous	0030				SCH - PJM_HTP <b>300 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW	
					TTC with All Lines In Service 660 MW	
<b>W49TH_ST_345KV_8</b>					FWD	
Mon 05/10/2021	to	Mon 05/10/2021				(Import)
0001	Continuous	0030				SCH - PJM_HTP <b>450 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 210 MW	
					TTC with All Lines In Service 660 MW	
<b>HUDSONTP-W49TH_ST_345_Y56</b>					FWD	
Mon 05/10/2021	to	Thu 05/13/2021				(Import)
0001	Continuous	2300				SCH - PJM_HTP <b>0 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 660 MW	
					TTC with All Lines In Service 660 MW	

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

Seasonal Limits

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD
<b>SPRNBK_-TREMONT_345_X28</b>						(Import)
Mon 05/10/2021	to	Wed 05/26/2021	<b>UPDATED</b>	<b>by CONED</b>	<b>03/18/2021</b>	
0001	Continuous	0200				<b>4200 MW</b>
Work scheduled by: ConEd					SPR/DUN-SOUTH	<b>4200 MW</b>
					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
<b>CLAY_-EDIC_345_1-16</b>						FWD
						(Import)
Mon 05/10/2021	to	Fri 05/14/2021				
0700	Continuous	1530				<b>4850 MW</b>
Work scheduled by: NYPA					OSWEGO EXPORT	<b>4850 MW</b>
					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	5250 MW
<hr/>						
<b>MOSES_-ADIRNDCK_230_MA2</b>						FWD
						(Import)
Mon 05/10/2021	to	Tue 06/01/2021				
1200	Continuous	0659				<b>2100 MW</b>
Work scheduled by: NYPA					MOSES SOUTH	<b>2100 MW</b>
					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
<hr/>						
<b>ALCOA_PA_115KV_R8105</b>						FWD
						(Import)
Tue 05/11/2021	to	Thu 06/03/2021				
0630	Continuous	1630				<b>3100 MW</b>
Work scheduled by: NGrid					MOSES SOUTH	<b>3100 MW</b>
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	3150 MW
<hr/>						
<b>DENNISON-ROSEMNTB_115_2/22</b>						FWD
						(Import) (Export)
Wed 05/12/2021	to	Wed 05/12/2021	<b>UPDATED</b>	<b>by HQ</b>	<b>04/16/2021</b>	
0630	Daily(No Weekends)	1830				<b>95 MW</b>
Work scheduled by: NGrid					SCH - HQ_CEDARS	<b>40 MW</b>
					Impacts Total Transfer Capability	95 MW
					TTC with All Lines In Service	190 MW
						40 MW
<hr/>						
<b>SCH-HQ_CEDARS-NYISO_LIMIT_80</b>						FWD
						(Import)
Wed 05/12/2021	to	Wed 05/12/2021	<b>UPDATED</b>	<b>by HQ</b>	<b>04/16/2021</b>	
0630	Daily(No Weekends)	1830				<b>80 MW</b>
Work scheduled by: NGrid					SCH - HQ_CEDARS	<b>80 MW</b>
					Impacts Total Transfer Capability	110 MW
					TTC with All Lines In Service	190 MW
<hr/>						
<b>W49TH_ST_345KV_7</b>						FWD
						(Import)
Thu 05/13/2021	to	Thu 05/13/2021				
2230	Continuous	2300				<b>300 MW</b>
Work scheduled by: ConEd					SCH - PJM_HTP	<b>300 MW</b>
					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>W49TH_ST_345KV_8</b>			FWD	
Thu 05/13/2021	to	Thu 05/13/2021	(Import)	
2230	Continuous	2300	SCH - PJM_HTP	<b>450 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	210 MW
			TTC with All Lines In Service	660 MW
<b>CRICKVLY-PLSNTVLY_345_F83</b>			FWD	
Fri 05/14/2021	to	Fri 05/14/2021	(Import)	
0001	Continuous	2200	SCH - NE - NY	<b>350 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	1050 MW
			TTC with All Lines In Service	1400 MW
<b>CRICKVLY-PLSNTVLY_345_F83</b>			FWD	REV
Fri 05/14/2021	to	Fri 05/14/2021	(Import)	(Export)
0001	Continuous	2200	SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR_138_601 &amp; CRICKVLY-PLSNTVLY_345_F83</b>			FWD	REV
Fri 05/14/2021	to	Fri 05/14/2021	(Import)	(Export)
0001		2200	SCH - NPX_1385	<b>0 MW 0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR_138_602 &amp; CRICKVLY-PLSNTVLY_345_F83</b>			FWD	REV
Fri 05/14/2021	to	Fri 05/14/2021	(Import)	(Export)
0001		2200	SCH - NPX_1385	<b>0 MW 0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR_138_603 &amp; CRICKVLY-PLSNTVLY_345_F83</b>			FWD	REV
Fri 05/14/2021	to	Fri 05/14/2021	(Import)	(Export)
0001		2200	SCH - NPX_1385	<b>0 MW 0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>BUCHAN_N-EASTVIEW_345_W93</b>			FWD	
Fri 05/14/2021	to	Sat 05/15/2021	(Import)	
0001	Continuous	0200	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	3465 MW
			TTC with All Lines In Service	7815 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>RAMAPO__-BUCHAN_N_345_Y94</b>					FWD
Fri 05/14/2021	to	Sat 05/15/2021			(Import)
0001	Continuous	0200		UPNY CONED	<b>7580 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 235 MW
					TTC with All Lines In Service 7815 MW
<b>SPRNBRK__345KV_RS3 &amp; SPRNBRK__345KV_RS4</b>					FWD
Sat 05/15/2021	to	Sat 05/15/2021			(Import)
0301		2230		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by:					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
<b>DUNWODIE_345KV_5</b>					FWD
Mon 05/17/2021	to	Tue 05/18/2021	<b>UPDATED</b>	<b>by CE</b>	<b>03/15/2021</b>
0201	Continuous	0200			SPR/DUN-SOUTH
Work scheduled by: ConEd					<b>3800 MW</b>
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>DUNWODIE_345KV_7</b>					FWD
Mon 05/17/2021	to	Tue 05/18/2021	<b>UPDATED</b>	<b>by CE</b>	<b>03/15/2021</b>
0201	Continuous	0200			SPR/DUN-SOUTH
Work scheduled by: ConEd					<b>3800 MW</b>
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>SPRNBRK_-DUNWODIE_345_W75</b>					FWD
Mon 05/17/2021	to	Tue 05/18/2021	<b>UPDATED</b>	<b>by CE</b>	<b>03/15/2021</b>
0201	Continuous	0200			SPR/DUN-SOUTH
Work scheduled by: ConEd					<b>3800 MW</b>
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>SPRNBRK__345KV_RNS3</b>					FWD
Mon 05/17/2021	to	Tue 05/18/2021	<b>UPDATED</b>	<b>by CE</b>	<b>03/15/2021</b>
0201	Continuous	0200			SPR/DUN-SOUTH
Work scheduled by: ConEd					<b>3800 MW</b>
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>NIAGARA_-STA_255__345_NH2</b>					FWD
Mon 05/17/2021	to	Fri 05/21/2021	<b>UPDATED</b>	<b>by NYPA</b>	<b>03/23/2021</b>
0500	Continuous	1700			DYSINGER EAST
Work scheduled by: NYPA					<b>1400 MW</b>
					Impacts Total Transfer Capability 1750 MW
					TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND\_BAR-PLATSBURG\_115\_PV20

Mon 05/17/2021 to Fri 07/02/2021  
 0600 Continuous 1800  
 Work scheduled by: ISONE

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

GOETHALS\_345KV\_5

Wed 05/19/2021 to Mon 05/24/2021 **EXTENDED by CE 04/05/2021**  
 0100 Continuous 0200  
 Work scheduled by: ConEd

STATEN ISLAND  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

LINDEN\_-GOETHALS\_230\_A2253

Wed 05/19/2021 to Mon 05/24/2021 **EXTENDED by CE 04/05/2021**  
 0100 Continuous 0200  
 Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2050 MW</b>	<b>1150 MW</b>
Impacts Total Transfer Capability	150 MW	100 MW
TTC with All Lines In Service	2200 MW	1250 MW

LINDEN\_-GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402

Wed 05/19/2021 to Mon 05/24/2021  
 0100 Continuous 0200  
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2000 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

LINDEN\_-GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

Wed 05/19/2021 to Mon 05/24/2021  
 0100 Continuous 0200  
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2000 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

LINDEN\_-GOETHALS\_230\_A2253 & MARION\_-FARRAGUT\_345\_C3403

Wed 05/19/2021 to Mon 05/24/2021  
 0100 Continuous 0200  
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2000 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

BUCHAN\_S-MILLWOOD\_345\_W97

Thu 05/20/2021 to Sat 05/22/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **7680 MW**  
 Impacts Total Transfer Capability 135 MW  
 TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>W49TH_ST_345KV_6</b>					FWD	
Thu 05/20/2021	to	Sat 05/22/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>03/30/2021</u>	(Import)
0001	Continuous	0200				300 MW
Work scheduled by: ConEd					SCH - PJM_HTP	360 MW
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	
<b>W49TH_ST-E13THSTA_345_M55</b>					FWD	
Thu 05/20/2021	to	Mon 05/24/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>03/30/2021</u>	(Import)
0001	Continuous	0200				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	800 MW
					Impacts Total Transfer Capability	4600 MW
					TTC with All Lines In Service	
<b>E13THSTA-FARRAGUT_345_46</b>					FWD	
Sat 05/22/2021	to	Mon 05/24/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>03/30/2021</u>	(Import)
0001	Continuous	0200				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	800 MW
					Impacts Total Transfer Capability	4600 MW
					TTC with All Lines In Service	
<b>PLSNTVLY-WOOD_ST_345_F31</b>					FWD	
Mon 05/24/2021	to	Tue 05/25/2021				(Import)
0001	Continuous	0159				4000 MW
Work scheduled by: ConEd					UPNY CONED	3815 MW
					Impacts Total Transfer Capability	7815 MW
					TTC with All Lines In Service	
<b>PLSNTVLY_345KV_RNS4</b>					FWD	
Mon 05/24/2021	to	Tue 05/25/2021				(Import)
0001	Continuous	0159				3800 MW
Work scheduled by: ConEd					UPNY CONED	4015 MW
					Impacts Total Transfer Capability	7815 MW
					TTC with All Lines In Service	
<b>W49TH_ST_345KV_6</b>					FWD	
Mon 05/24/2021	to	Mon 05/24/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>03/30/2021</u>	(Import)
0130	Continuous	0200				300 MW
Work scheduled by: ConEd					SCH - PJM_HTP	360 MW
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	
<b>DENNISON-ROSEMNTB_115_2/22</b>					FWD	
Mon 05/24/2021	to	Wed 05/26/2021				(Import) (Export)
0630	Continuous	1900				95 MW 40 MW
Work scheduled by: NGrid					SCH - HQ_CEDARS	95 MW 0 MW
					Impacts Total Transfer Capability	190 MW 40 MW
					TTC with All Lines In Service	

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event Name	Start Date	End Date	Time	Work Scheduled by	Transfer Capability	Impacts	TTC
SCH-HQ_CEDARS-NYISO_LIMIT_80	Mon 05/24/2021	Wed 05/26/2021	0630 - 1900	NGrid	FWD (Import)	SCH - HQ_CEDARS	80 MW
						Impacts Total Transfer Capability	110 MW
						TTC with All Lines In Service	190 MW
ROSETON_EFISHKIL_345_RFK305	Wed 05/26/2021	Thu 05/27/2021	0001 - 0200	ConEd	FWD (Import)	UPNY CONED	6680 MW
						Impacts Total Transfer Capability	1135 MW
						TTC with All Lines In Service	7815 MW
DENNISON-ROSEMNTA_115_1/11	Thu 05/27/2021	Fri 05/28/2021	0630 - 1900	NGrid	FWD (Import)	SCH - HQ_CEDARS	95 MW
						Impacts Total Transfer Capability	95 MW
						TTC with All Lines In Service	190 MW
							REV (Export) 40 MW
SCH-HQ_CEDARS-NYISO_LIMIT_80	Thu 05/27/2021	Fri 05/28/2021	0630 - 1900	NGrid	FWD (Import)	SCH - HQ_CEDARS	80 MW
						Impacts Total Transfer Capability	110 MW
						TTC with All Lines In Service	190 MW
VOLNEY_MARCY_345_19	Tue 06/01/2021	Wed 06/02/2021	0700 - 1730	NYPA	FWD (Import)	CENTRAL EAST - VC	2825 MW
						Impacts Total Transfer Capability	150 MW
						TTC with All Lines In Service	2975 MW
							ARR: 19
VOLNEY_MARCY_345_19	Tue 06/01/2021	Wed 06/02/2021	0700 - 1730	NYPA	FWD (Import)	OSWEGO EXPORT	4900 MW
						Impacts Total Transfer Capability	350 MW
						TTC with All Lines In Service	5250 MW
							ARR: 19
FRASER_GILBOA_345_GF5-35	Tue 06/01/2021	Mon 06/07/2021	0700 - 1730	NYPA	FWD (Import)	CENTRAL EAST - VC	2650 MW
						Impacts Total Transfer Capability	325 MW
						TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES -ADIRNDCK\_230\_MA2**

Tue 06/01/2021 to Sun 11/14/2021  
 0700 Continuous 1300  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

**MARCY -EDIC 345 UE1-7**

Thu 06/03/2021 to Fri 06/04/2021  
 0700 Continuous 1730  
 Work scheduled by: NYPA

**ARR: 19&16**

FWD  
 (Import)  
**OSWEGO EXPORT 5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

**PORTER -ROTTRDAM\_230\_30**

Thu 06/03/2021 to Wed 09/15/2021 **UPDATED by NGRID 01/19/2021**  
 0700 Continuous 0659  
 Work scheduled by: NGrid

FWD  
 (Import)  
**CENTRAL EAST - VC 2805 MW**  
 Impacts Total Transfer Capability 170 MW  
 TTC with All Lines In Service 2975 MW

**MARCY 345KV\_CSC**

Sat 06/05/2021 to Sat 06/05/2021  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
**CENTRAL EAST - VC 2925 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 2975 MW

**ATHENS -PLSNTVLY\_345\_91**

Tue 06/08/2021 to Wed 06/16/2021  
 0600 Continuous 2000  
 Work scheduled by: NGrid

FWD  
 (Import)  
**UPNY CONED 3800 MW**  
 Impacts Total Transfer Capability 4015 MW  
 TTC with All Lines In Service 7815 MW

**GILBOA -N.SCTLND\_345\_GNS-1**

Wed 06/09/2021 to Wed 06/09/2021  
 0800 Daily 1200  
 Work scheduled by: NGrid

FWD  
 (Import)  
**CENTRAL EAST - VC 2520 MW**  
 Impacts Total Transfer Capability 455 MW  
 TTC with All Lines In Service 2975 MW

**BECK -NIAGARA\_345\_PA301**

Wed 06/16/2021 to Thu 06/17/2021  
 0500 Continuous 2330  
 Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
**SCH - OH - NY 900 MW 800 MW**  
 Impacts Total Transfer Capability 1050 MW 900 MW  
 TTC with All Lines In Service 1950 MW 1700 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>LEEDS___-PLSNTVLY_345_92</b>					FWD
Thu 06/17/2021	to	Thu 06/24/2021			(Import)
0600	Continuous	2000		UPNY CONED	<b>3800 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 4015 MW
					TTC with All Lines In Service 7815 MW
<b>BECK___-NIAGARA_345_PA301</b>					FWD REV
Fri 06/25/2021	to	Fri 06/25/2021			(Import) (Export)
0500	Continuous	1700		SCH - OH - NY	<b>900 MW 800 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1050 MW 900 MW
					TTC with All Lines In Service 1950 MW 1700 MW
<b>FRASANX-COOPERS__345_UCC2-41</b>					FWD
Fri 06/25/2021	to	Tue 08/10/2021			(Import)
0700	Continuous	1530		CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 475 MW
<b>ARR: 19</b>					TTC with All Lines In Service 2975 MW
<b>MARCY___-FRASANX_345_UCC2-41</b>					FWD
Fri 06/25/2021	to	Tue 08/10/2021			(Import)
0700	Continuous	1530		CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 475 MW
<b>ARR: 19</b>					TTC with All Lines In Service 2975 MW
<b>BECK___-NIAGARA_345_PA302</b>					FWD REV
Mon 07/12/2021	to	Fri 07/16/2021			(Import) (Export)
0500	Continuous	1700		SCH - OH - NY	<b>900 MW 800 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1050 MW 900 MW
					TTC with All Lines In Service 1950 MW 1700 MW
<b>NIAGARA_345_230_AT4</b>					FWD REV
Mon 07/19/2021	to	Fri 07/30/2021	<b>UPDATED</b>	<b>by NYPA</b>	(Import) (Export)
0500	Continuous	1700		<b>02/19/2021</b>	<b>1900 MW 1400 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 50 MW 300 MW
					TTC with All Lines In Service 1950 MW 1700 MW
<b>NIAGARA_-STA_255__345_NH2</b>					FWD
Mon 07/26/2021	to	Fri 07/30/2021	<b>UPDATED</b>	<b>by NYPA</b>	(Import)
0500	Continuous	1900		<b>02/19/2021</b>	<b>1400 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1750 MW
					TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND\_BAR-PLATSBRG\_115\_PV20

Tue 08/03/2021 to Tue 08/03/2021  
 0700 Continuous 1830  
 Work scheduled by: NYPA

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

KINTIGH\_-STA\_255\_345\_SH1-39

Mon 08/09/2021 to Sun 08/15/2021  
 0500 Continuous 1900  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1400 MW**  
 Impacts Total Transfer Capability 1750 MW  
 TTC with All Lines In Service 3150 MW

NIAGARA\_-KINTIGH\_345\_NS1-38

Mon 08/09/2021 to Sun 08/15/2021  
 0500 Continuous 1900  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1400 MW**  
 Impacts Total Transfer Capability 1750 MW  
 TTC with All Lines In Service 3150 MW

KINTIGH\_-STA\_255\_345\_SH1-39

Mon 08/16/2021 to Sun 08/22/2021  
 0500 Continuous 1900  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1400 MW**  
 Impacts Total Transfer Capability 1750 MW  
 TTC with All Lines In Service 3150 MW

NIAGARA\_-KINTIGH\_345\_NS1-38

Mon 08/16/2021 to Sun 08/22/2021  
 0500 Continuous 1900  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1400 MW**  
 Impacts Total Transfer Capability 1750 MW  
 TTC with All Lines In Service 3150 MW

NIAGARA\_-STA\_255\_345\_NH2

Wed 09/01/2021 to Tue 09/21/2021  
 0500 Continuous 1900  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1400 MW**  
 Impacts Total Transfer Capability 1750 MW  
 TTC with All Lines In Service 3150 MW

FRASANNX-COOPERS\_345\_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021 **UPDATED by NYISO 02/03/2021**  
 0700 Continuous 1730  
 Work scheduled by: NYPA **ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY\_\_\_-FRASANNX\_345\_UCC2-41

FWD

Tue 09/07/2021 to Wed 09/15/2021  
0700 Continuous 1730

UPDATED by NYISO 02/03/2021

(Import)

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

PORTER\_\_\_-ROTTRDAM\_230\_30

FWD

Wed 09/15/2021 to Tue 11/30/2021  
0700 Continuous 1730

Work scheduled by: NGrid

(Import)  
CENTRAL EAST - VC **2805 MW**  
Impacts Total Transfer Capability 170 MW  
TTC with All Lines In Service 2975 MW

EDIC\_\_\_-N.SCTLND\_345\_14

FWD

Thu 09/16/2021 to Sun 11/14/2021  
0700 Continuous 1730

Work scheduled by: NGrid

(Import)  
CENTRAL EAST - VC **1670 MW**  
Impacts Total Transfer Capability 1305 MW  
TTC with All Lines In Service 2975 MW

EDIC\_\_\_-N.SCTLND\_345\_14 & PORTER\_\_\_-ROTTRDAM\_230\_30

FWD

Thu 09/16/2021 to Sun 11/14/2021  
0700 Continuous 1730

Work scheduled by:

(Import)  
CENTRAL EAST - VC **1500 MW**  
Impacts Total Transfer Capability 1475 MW  
TTC with All Lines In Service 2975 MW

HURLYAVE-ROSETON\_\_345\_303

FWD

Thu 09/16/2021 to Sun 10/17/2021  
0800 Continuous 1600

UPDATED by CHGE 09/22/2020

Work scheduled by: CHGE

(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 3715 MW  
TTC with All Lines In Service 7815 MW

HOMRC\_NY-MAINS\_NY\_345\_47

Sat 09/18/2021 to Fri 11/05/2021  
0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

PANNELL\_\_\_-CLAY\_\_\_\_\_345\_1

FWD

Mon 09/20/2021 to Fri 09/24/2021  
0700 Continuous 1530

Work scheduled by: NYPA

(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p><b>CLAY -EDIC 345_2-15</b></p> <p>Mon 09/20/2021 to Sat 10/16/2021</p> <p style="padding-left: 40px;">0700 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>OSWEGO EXPORT <b>4850 MW</b></p> <p>Impacts Total Transfer Capability 400 MW</p> <p>TTC with All Lines In Service 5250 MW</p>
<p><b>KINTIGH -STA 255_345_SH1-39</b></p> <p>Mon 09/27/2021 to Wed 09/29/2021 <b><u>UPDATED</u> by NYPA <u>03/04/2021</u></b></p> <p style="padding-left: 40px;">0500 Continuous 0459</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>DYSINGER EAST <b>1400 MW</b></p> <p>Impacts Total Transfer Capability 1750 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p><b>NIAGARA -KINTIGH 345_NS1-38</b></p> <p>Mon 09/27/2021 to Wed 09/29/2021 <b><u>UPDATED</u> by NYPA <u>03/04/2021</u></b></p> <p style="padding-left: 40px;">0500 Continuous 0459</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>DYSINGER EAST <b>1400 MW</b></p> <p>Impacts Total Transfer Capability 1750 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p><b>PANNELL -CLAY 345_2</b></p> <p>Mon 09/27/2021 to Fri 10/01/2021</p> <p style="padding-left: 40px;">0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>WEST CENTRAL <b>1300 MW</b></p> <p>Impacts Total Transfer Capability 950 MW</p> <p>TTC with All Lines In Service 2250 MW</p>
<p><b>W49TH_ST_345KV_6</b></p> <p>Tue 09/28/2021 to Tue 09/28/2021 <b><u>UPDATED</u> by CONED <u>01/15/2021</u></b></p> <p style="padding-left: 40px;">0100 Continuous 0130</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SCH - PJM_HTP <b>300 MW</b></p> <p>Impacts Total Transfer Capability 360 MW</p> <p>TTC with All Lines In Service 660 MW</p>
<p><b>E13THSTA-FARRAGUT 345_46</b></p> <p>Tue 09/28/2021 to Tue 10/26/2021 <b><u>UPDATED</u> by CONED <u>01/15/2021</u></b></p> <p style="padding-left: 40px;">0100 Continuous 0300</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH <b>3800 MW</b></p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>
<p><b>W49TH_ST-E13THSTA 345_M55</b></p> <p>Tue 09/28/2021 to Tue 10/26/2021 <b><u>UPDATED</u> by CONED <u>01/15/2021</u></b></p> <p style="padding-left: 40px;">0100 Continuous 0300</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH <b>3800 MW</b></p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**KINTIGH\_-STA\_255\_\_345\_SH1-39**

Wed 09/29/2021 to Wed 12/01/2021  
 0500 Continuous 1900  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1400 MW**  
 Impacts Total Transfer Capability 1750 MW  
 TTC with All Lines In Service 3150 MW

**NIAGARA\_-KINTIGH\_\_345\_NS1-38**

Wed 09/29/2021 to Wed 12/01/2021  
 0500 Continuous 1900  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1400 MW**  
 Impacts Total Transfer Capability 1750 MW  
 TTC with All Lines In Service 3150 MW

**LEEDS\_-HURLYAVE\_345\_301**

Mon 10/18/2021 to Fri 11/19/2021  
 0800 Continuous 1600  
 Work scheduled by: CHGE

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 3715 MW  
 TTC with All Lines In Service 7815 MW

**GOETHALS\_345KV\_5**

Thu 10/21/2021 to Sat 11/20/2021 **UPDATED by CONED 03/05/2021**  
 0001 Continuous 0200  
 Work scheduled by: ConEd

STATEN ISLAND  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**W49TH\_ST\_345KV\_6**

Tue 10/26/2021 to Tue 10/26/2021 **UPDATED by CONED 01/15/2021**  
 0230 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**SCH-IMO-NYISO\_LIMIT\_1750**

Mon 11/01/2021 to Fri 12/31/2021 **UPDATED by IESO 05/03/2019**  
 0001 Continuous 2359  
 Work scheduled by: IESO

FWD  
 (Import)  
 SCH - OH - NY **2050 MW**  
 Impacts Total Transfer Capability 250 MW  
 TTC with All Lines In Service 2300 MW

**SCH-NYISO-IMO\_LIMIT\_1600**

Mon 11/01/2021 to Fri 12/31/2021 **UPDATED by IESO 05/03/2019**  
 0001 Continuous 2359  
 Work scheduled by: IESO

REV  
 (Export)  
 SCH - OH - NY **1900 MW**  
 Impacts Total Transfer Capability 100 MW  
 TTC with All Lines In Service 2000 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event	Start	End	Time	Day	Work by	SCH	FWD	REV	
LINDN_CG-LNDVFT___345_V-3022	Tue 11/02/2021	Fri 11/05/2021	0800	Continuous	1500	PJM	SCH - PJM_VFT 0 MW	(Import) (Export) 0 MW	
							Impacts Total Transfer Capability	315 MW	
							TTC with All Lines In Service	315 MW	
<hr/>									
PORTER_-ROTTDAM_230_30 & MASSENA_-MARCY___765_MSU1	Mon 11/15/2021	Tue 11/30/2021	0100	Continuous	1730		FWD (Import)		
							CENTRAL EAST - VC	1500 MW	
							Impacts Total Transfer Capability	1475 MW	
							TTC with All Lines In Service	2975 MW	
<hr/>									
CHATGUAY-MASSENA___765_7040	Mon 11/15/2021	Tue 11/30/2021	0100	Continuous	1859		FWD (Import)		
							MOSES SOUTH	1550 MW	
							Impacts Total Transfer Capability	1600 MW	
							TTC with All Lines In Service	3150 MW	
<hr/>									
CHATGUAY-MASSENA___765_7040	Mon 11/15/2021	Tue 11/30/2021	0100	Continuous	1859		FWD	REV	
							(Import) (Export)		
							SCH - HQ - NY	0 MW	0 MW
							Impacts Total Transfer Capability	1500 MW	1000 MW
							TTC with All Lines In Service	1500 MW	1000 MW
<hr/>									
MARCY___765_345_AT1	Mon 11/15/2021	Tue 11/30/2021	0100	Continuous	1859		FWD (Import)		
							MOSES SOUTH	1750 MW	
							Impacts Total Transfer Capability	1400 MW	
							TTC with All Lines In Service	3150 MW	
							ARR: 19		
<hr/>									
MARCY___765_345_AT2	Mon 11/15/2021	Tue 11/30/2021	0100	Continuous	1859		FWD (Import)		
							MOSES SOUTH	1700 MW	
							Impacts Total Transfer Capability	1450 MW	
							TTC with All Lines In Service	3150 MW	
							ARR: 19		
<hr/>									
MASSENA_-MARCY___765_MSU1	Mon 11/15/2021	Tue 11/30/2021	0100	Continuous	1859		FWD (Import)		
							CENTRAL EAST - VC	1670 MW	
							Impacts Total Transfer Capability	1305 MW	
							TTC with All Lines In Service	2975 MW	

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Zone	Start	End	Time	Day	Impact	TTC	FWD	REV
MASSENA -MARCY 765_MSU1	Mon 11/15/2021	Tue 11/30/2021	0100	Continuous	1859	MOSES SOUTH	500 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW	
						TTC with All Lines In Service	3150 MW	
MASSENA -MARCY 765_MSU1	Mon 11/15/2021	Tue 11/30/2021	0100	Continuous	1859	SCH - HQ - NY	475 MW	1000 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW	0 MW
						TTC with All Lines In Service	1500 MW	1000 MW
MASSENA -MARCY 765_MSU1	Mon 11/15/2021	Tue 11/30/2021	0100	Continuous	1859	SCH - HQ_CEDARS	90 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	109 MW	
						TTC with All Lines In Service	199 MW	
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040	Mon 11/15/2021	Tue 11/30/2021	0100		1859	MOSES SOUTH	500 MW	
Work scheduled by:						Impacts Total Transfer Capability	2650 MW	
						TTC with All Lines In Service	3150 MW	
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	Mon 11/15/2021	Tue 11/30/2021	0100		1859	SCH - HQ - NY	850 MW	0 MW
Work scheduled by:						Impacts Total Transfer Capability	650 MW	1000 MW
						TTC with All Lines In Service	1500 MW	1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	Mon 11/15/2021	Tue 11/30/2021	0100		1859	SCH - HQ_CEDARS	90 MW	
Work scheduled by:						Impacts Total Transfer Capability	109 MW	
						TTC with All Lines In Service	199 MW	
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1	Mon 11/15/2021	Tue 11/30/2021	0100		1859	SCH - HQ_CEDARS	90 MW	
Work scheduled by:						Impacts Total Transfer Capability	109 MW	
						TTC with All Lines In Service	199 MW	

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES\_\_\_230\_L33P & MOSES\_\_\_-MASSENA\_230\_MMS1 & MOSES\_\_\_-  
MASSENA\_230\_MMS2

FWD  
(Import)

Mon 11/15/2021 to Tue 11/30/2021  
0100 1859

SCH - HQ\_CEDARS **90 MW**  
Impacts Total Transfer Capability 109 MW  
TTC with All Lines In Service 199 MW

Work scheduled by:

FRASER\_\_\_345\_FRASER SVC

FWD  
(Import)

Wed 12/01/2021 to Mon 02/28/2022  
0700 Continuous 1730

CENTRAL EAST - VC **2935 MW**  
Impacts Total Transfer Capability 40 MW  
TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

MOSES\_\_\_-ADIRNDCK\_230\_MAI

FWD  
(Import)

Wed 12/01/2021 to Tue 05/31/2022  
0700 Continuous 1300

MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

NIAGARA\_-STA\_255\_\_345\_NH2

FWD  
(Import)

Thu 12/02/2021 to Thu 01/13/2022  
0500 Continuous 1900

DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

MOTTHAVN-RAINEY\_\_\_345\_Q12

FWD  
(Import)

Sun 12/05/2021 to Sat 12/25/2021 **UPDATED by CONED 03/25/2021**  
0001 Continuous 0159

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

LEEDS\_\_\_-PLSNTVLY\_345\_92

FWD  
(Import)

Thu 02/17/2022 to Mon 02/21/2022 **UPDATED by NGRID 03/31/2021**  
0600 Continuous 1900

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 2420 MW  
TTC with All Lines In Service 6220 MW

Work scheduled by: NGrid

GOETHALS\_345KV\_5

Sat 03/05/2022 to Mon 04/04/2022 **UPDATED by CONED 03/26/2021**  
0001 Continuous 0200

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**LINDEN\_\_-GOETHALS\_230\_A2253**

Sat 03/05/2022 to Mon 04/04/2022  
0001 Continuous 0200

**UPDATED by CONED 03/26/2021**

Work scheduled by: ConEd

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**N. SCTLND-ALPS\_\_\_\_\_345\_2**

Mon 05/02/2022 to Mon 05/09/2022  
0600 Daily 1800

Work scheduled by: NGrid

FWD  
(Import)  
SCH - NE - NY **750 MW**  
Impacts Total Transfer Capability 650 MW  
TTC with All Lines In Service 1400 MW

**N. SCTLND-ALPS\_\_\_\_\_345\_2**

Mon 05/02/2022 to Mon 05/09/2022  
0600 Daily 1800

Work scheduled by: NGrid

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **100 MW 100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

**HOMRC\_NY-MAINS\_NY\_345\_47**

Fri 05/20/2022 to Fri 05/27/2022  
0800 Continuous 1600

Work scheduled by: PJM

**UPDATED by PJM 11/19/2020**

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**HOMR\_NYW-PIERC\_NY\_345\_48**

Fri 05/20/2022 to Fri 05/27/2022  
0800 Continuous 1600

Work scheduled by: PJM

**UPDATED by PJM 11/19/2020**

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Wed 06/01/2022 to Mon 11/14/2022  
0700 Continuous 1300

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**SPRNBRK\_\_345KV\_RNS5**

Mon 09/19/2022 to Mon 09/19/2022  
0001 Continuous 0030

Work scheduled by: ConEd

**UPDATED by CONED 09/17/2020**

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 17, 2021 to Monday ,October 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**SPRNBRK\_-W49TH\_ST\_345\_M51**

Mon 09/19/2022 to Wed 09/21/2022  
 0001 Continuous 2200

**UPDATED by CONED 09/17/2020**

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

FWD  
 (Import)

-----  
**SPRNBRK\_345KV\_RNS5**

Wed 09/21/2022 to Wed 09/21/2022  
 2130 Continuous 2200

**UPDATED by CONED 09/17/2020**

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

FWD  
 (Import)

-----  
**SPRNBRK\_-W49TH\_ST\_345\_M51**

Sat 10/01/2022 to Mon 10/17/2022  
 0001 Continuous 0300

**UPDATED by CONED 08/01/2020**

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

FWD  
 (Import)

-----  
**SPRNBRK\_345KV\_RNS5**

Sat 10/01/2022 to Mon 10/17/2022  
 0001 Continuous 0300

**UPDATED by CONED 08/01/2020**

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

FWD  
 (Import)