

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>HUDSONP_-FARRAGUT_345_B3402</b>					FWD	
Mon 01/15/2018	to	Tue 11/30/2021	<u>EXT FORCE</u>	<u>by CONED</u>	<u>05/26/2021</u>	(Import)
0001	Continuous	2359				SCH - PJ - NY <b>2050 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	2250 MW
<b>HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>					FWD	REV
Mon 01/15/2018	to	Tue 11/30/2021				(Import) (Export)
0001		2359				SCH - PJ - NY <b>2000 MW 1150 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	250 MW 100 MW
					TTC with All Lines In Service	2250 MW 1250 MW
<b>MARION_-FARRAGUT_345_C3403</b>					FWD	
Mon 01/15/2018	to	Tue 11/30/2021	<u>EXT FORCE</u>	<u>by CONED</u>	<u>05/26/2021</u>	(Import)
0001	Continuous	2359				SCH - PJ - NY <b>2050 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	2250 MW
<b>STLAWRNC-MOSES_230_L33P</b>						
Mon 04/30/2018	to	Mon 10/31/2022	<u>EXT FORCE</u>	<u>by IESO</u>	<u>07/08/2021</u>	
0456	Continuous	1600				SCH - OH - NY
Work scheduled by: IESO					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<b>NEWBRDGE_345_138_BK_1</b>					FWD	
Wed 09/02/2020	to	Tue 02/01/2022	<u>EXT FORCE</u>	<u>by LI</u>	<u>01/12/2021</u>	(Import)
1807	Continuous	2359				SCH - PJM_NEPTUNE <b>375 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	660 MW
<b>SCH-IMO-NYISO_LIMIT_1600</b>					FWD	
Sat 05/01/2021	to	Sun 10/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				SCH - OH - NY <b>1900 MW</b>
Work scheduled by: IESO					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	1950 MW
<b>DUNWODIE-SHORE_RD_345_Y50</b>					FWD	
Sat 07/17/2021	to	Fri 09/17/2021	<u>EXT FORCE</u>	<u>by CE</u>	<u>08/26/2021</u>	(Import)
1053	Continuous	0200				CONED - LIPA <b>800 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	1500 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SHORE_RD_345_138_BK 1</b>					FWD
Sat 07/17/2021	to	Fri 09/17/2021	<b>EXT FORCE</b> <b>by CE</b>	<b>08/26/2021</b>	(Import)
1053	Continuous	0200			CONED - LIPA <b>1350 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service 1500 MW
<b>SHORE_RD_345_138_BK 2</b>					FWD
Sat 07/17/2021	to	Fri 09/17/2021	<b>EXT FORCE</b> <b>by CE</b>	<b>08/26/2021</b>	(Import)
1053	Continuous	0200			CONED - LIPA <b>1350 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service 1500 MW
<b>EGRDNCTY_345_138_AT1</b>					FWD
Fri 08/06/2021	to	Fri 10/15/2021	<b>EXT FORCE</b> <b>by LI</b>	<b>08/11/2021</b>	(Import)
1939	Continuous	2359			CONED - LIPA <b>1250 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability 250 MW
					TTC with All Lines In Service 1500 MW
<b>EGRDNCTY_345_138_AT2</b>					FWD
Fri 08/06/2021	to	Fri 10/15/2021	<b>EXT FORCE</b> <b>by LI</b>	<b>08/11/2021</b>	(Import)
1939	Continuous	2359			CONED - LIPA <b>1250 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability 250 MW
					TTC with All Lines In Service 1500 MW
<b>SPRNBK_-EGRDNCTR_345_Y49 &amp; DUNWODIE-SHORE_RD_345_Y50</b>					FWD
Fri 08/06/2021	to	Fri 09/17/2021			(Import)
1953		0200			CONED - LIPA <b>25 MW</b>
Work scheduled by:					Impacts Total Transfer Capability 1475 MW
					TTC with All Lines In Service 1500 MW
<b>SPRNBK_-EGRDNCTR_345_Y49</b>					FWD
Fri 08/06/2021	to	Fri 10/15/2021	<b>EXT FORCE</b> <b>by LI</b>	<b>08/11/2021</b>	(Import)
1953	Continuous	2359			CONED - LIPA <b>775 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability 725 MW
					TTC with All Lines In Service 1500 MW
<b>NIAGARA_-STA_255_345_NH2</b>					FWD
Fri 08/27/2021	to	Mon 09/06/2021	<b>EXTENDED</b> <b>by NYPA</b>	<b>09/02/2021</b>	(Import)
0500	Continuous	2300			DYSINGER EAST <b>1400 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1750 MW
					TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

Seasonal Limits

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MOSES__-ADIRNDCK_230_MA2</b>						FWD
Fri 08/27/2021	to	Thu 09/02/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/01/2021</u>	(Import)
0600	Continuous	1800				<b>2100 MW</b>
Work scheduled by: NYPA						MOSES SOUTH
						Impacts Total Transfer Capability 1050 MW
						TTC with All Lines In Service 3150 MW
<b>SCH-IMO-NYISO_LIMIT_1400</b>						FWD
Fri 08/27/2021	to	Thu 09/02/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/01/2021</u>	(Import)
0600	Continuous	1800				<b>1700 MW</b>
Work scheduled by: IESO						SCH - OH - NY
						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 1950 MW
<b>SCH-NYISO-IMO_LIMIT_1200</b>						REV
Fri 08/27/2021	to	Thu 09/02/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/01/2021</u>	(Export)
0600	Continuous	1800				<b>1500 MW</b>
Work scheduled by: IESO						SCH - OH - NY
						Impacts Total Transfer Capability 200 MW
						TTC with All Lines In Service 1700 MW
<b>LINDEN__-GOETHALS_230_A2253</b>						FWD
Fri 08/27/2021	to	Mon 08/30/2021				(Import)
1541	Continuous	2359				<b>2050 MW</b>
Work scheduled by: ConEd						SCH - PJ - NY
						Impacts Total Transfer Capability 200 MW
						TTC with All Lines In Service 2250 MW
<b>LINDEN__-GOETHALS_230_A2253 &amp; HUDSONP_-FARRAGUT_345_B3402</b>						FWD      REV
Fri 08/27/2021	to	Mon 08/30/2021				(Import) (Export)
1541		2359				<b>2000 MW    1150 MW</b>
Work scheduled by:						SCH - PJ - NY
						Impacts Total Transfer Capability 250 MW    100 MW
						TTC with All Lines In Service 2250 MW    1250 MW
<b>LINDEN__-GOETHALS_230_A2253 &amp; HUDSONP_-FARRAGUT_345_B3402 &amp; MARION__-FARRAGUT_345_C3403</b>						FWD      REV
Fri 08/27/2021	to	Mon 08/30/2021				(Import) (Export)
1541		2359				<b>2000 MW    1150 MW</b>
Work scheduled by:						SCH - PJ - NY
						Impacts Total Transfer Capability 250 MW    100 MW
						TTC with All Lines In Service 2250 MW    1250 MW
<b>LINDEN__-GOETHALS_230_A2253 &amp; MARION__-FARRAGUT_345_C3403</b>						FWD      REV
Fri 08/27/2021	to	Mon 08/30/2021				(Import) (Export)
1541		2359				<b>2000 MW    1150 MW</b>
Work scheduled by:						SCH - PJ - NY
						Impacts Total Transfer Capability 250 MW    100 MW
						TTC with All Lines In Service 2250 MW    1250 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_700	REV
Sat 08/28/2021 to Wed 09/08/2021	(Export)
0700 Daily 2259	<b>900 MW</b>
Work scheduled by: ISONE	Impacts Total Transfer Capability 700 MW
	TTC with All Lines In Service 1600 MW
SCH-NE-NYISO_LIMIT_600	FWD
Sat 08/28/2021 to Wed 09/08/2021	(Import)
2300 Daily 0659	<b>800 MW</b>
Work scheduled by: ISONE	Impacts Total Transfer Capability 600 MW
	TTC with All Lines In Service 1400 MW
SCH-HQ_CEDARS-NYISO_LIMIT_80	FWD
Mon 08/30/2021 to Sun 09/05/2021	(Import)
0700 Continuous 2300 <u>by HQ</u> <u>08/26/2021</u>	<b>80 MW</b>
Work scheduled by: HQ	Impacts Total Transfer Capability 110 MW
	TTC with All Lines In Service 190 MW
N.SCTLND-LEEDS____345_93	FWD
Mon 08/30/2021 to Mon 08/30/2021	(Import)
0800 Daily(No Weekends) 1500	<b>2650 MW</b>
Work scheduled by: NGrid	Impacts Total Transfer Capability 325 MW
	TTC with All Lines In Service 2975 MW
MARCY____345KV_CSC	FWD
Mon 08/30/2021 to Mon 08/30/2021	(Import)
0800 Continuous 1530	<b>2925 MW</b>
Work scheduled by: NYPA	Impacts Total Transfer Capability 50 MW
	TTC with All Lines In Service 2975 MW
SHOR_NPX-SHOREHAM_138_CSC	FWD REV
Wed 09/01/2021 to Wed 09/01/2021	(Import) (Export)
0600 Continuous 2300	<b>0 MW 0 MW</b>
Work scheduled by: LI	Impacts Total Transfer Capability 330 MW 330 MW
	TTC with All Lines In Service 330 MW 330 MW
LAFAYTTE-CLRKSCRN_345_4-46	FWD
Wed 09/01/2021 to Wed 09/01/2021	(Import)
0630 Daily 1400	<b>2650 MW</b>
Work scheduled by: NGrid	Impacts Total Transfer Capability 325 MW
	TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					
<b>NIAGARA_-KINTIGH_345_NS1-38</b>				FWD	
Thu 09/02/2021	to	Fri 09/03/2021	<b>CANCELLED by NYPA 08/31/2021</b>	(Import)	
0500	Continuous	2300		DYSINGER EAST	<b>1400 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1750 MW
				TTC with All Lines In Service	3150 MW
<hr/>					
<b>LEEDS_-HURLYAVE_345_301</b>				FWD	
Thu 09/02/2021	to	Thu 09/02/2021		(Import)	
0730	Daily(No Weekends)	1500		UPNY CONED	<b>4100 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	3715 MW
				TTC with All Lines In Service	7815 MW
<hr/>					
<b>LEEDS_345KV_R94301</b>				FWD	
Thu 09/02/2021	to	Thu 09/02/2021		(Import)	
0730	Daily(No Weekends)	1500		UPNY CONED	<b>3800 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	4015 MW
				TTC with All Lines In Service	7815 MW
<hr/>					
<b>SPRNBK_345KV_RS3 &amp; SPRNBK_345KV_RS4</b>				FWD	
Mon 09/06/2021	to	Mon 09/06/2021		(Import)	
0001		0030		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<hr/>					
<b>SPRNBK_345KV_RS3 &amp; SPRNBK_345KV_RS4</b>				FWD	
Mon 09/06/2021	to	Mon 09/06/2021		(Import)	
2201		2230		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<hr/>					
<b>NIAGARA_-KINTIGH_345_NS1-38</b>				FWD	
Tue 09/07/2021	to	Sun 09/12/2021	<b>UPDATED by NYPA 09/02/2021</b>	(Import)	
0500	Continuous	2300		DYSINGER EAST	<b>1400 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1750 MW
				TTC with All Lines In Service	3150 MW
<hr/>					
<b>SCH-NYISO-HQ_CEDARS_LIMIT_0</b>				REV	
Tue 09/07/2021	to	Thu 09/30/2021		(Export)	
0500	Continuous	1900		SCH - HQ_CEDARS	<b>0 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	100 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>FITZPTRK-EDIC</b> _____ <b>345_FE-1</b>					FWD	
Tue 09/07/2021	to	Sat 09/11/2021	<b>UPDATED</b>	<b>by NGRID</b>	<b>08/19/2021</b>	(Import)
0600	Continuous	1830				CENTRAL EAST - VC <b>2825 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability 150 MW
						TTC with All Lines In Service 2975 MW
<b>FITZPTRK-EDIC</b> _____ <b>345_FE-1</b>					FWD	
Tue 09/07/2021	to	Sat 09/11/2021	<b>UPDATED</b>	<b>by NGRID</b>	<b>08/19/2021</b>	(Import)
0600	Continuous	1830				OSWEGO EXPORT <b>4800 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability 450 MW
						TTC with All Lines In Service 5250 MW
<b>MOSES</b> ___- <b>ADIRNDCK_230_MA2</b>					FWD	
Tue 09/07/2021	to	Sun 11/14/2021	<b>UPDATED</b>	<b>by NYPA</b>	<b>09/01/2021</b>	(Import)
0600	Continuous	1300				MOSES SOUTH <b>2100 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 1050 MW
						TTC with All Lines In Service 3150 MW
<b>SCH-IMO-NYISO_LIMIT_1400</b>					FWD	
Tue 09/07/2021	to	Sun 11/14/2021	<b>UPDATED</b>	<b>by NYPA</b>	<b>09/01/2021</b>	(Import)
0600	Continuous	1300				SCH - OH - NY <b>1700 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 1950 MW
<b>SCH-NYISO-IMO_LIMIT_1200</b>						REV
Tue 09/07/2021	to	Sun 11/14/2021	<b>UPDATED</b>	<b>by NYPA</b>	<b>09/01/2021</b>	(Export)
0600	Continuous	1300				SCH - OH - NY <b>1500 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability 200 MW
						TTC with All Lines In Service 1700 MW
<b>ROSETON</b> ___- <b>ROCKTVRN_345_311</b>					FWD	
Tue 09/07/2021	to	Fri 09/10/2021			<b>07/15/2021</b>	(Import)
0700	Continuous	1600				UPNY CONED <b>4400 MW</b>
Work scheduled by: CHGE						Impacts Total Transfer Capability 3415 MW
						TTC with All Lines In Service 7815 MW
<b>CEDARS</b> ___- <b>ROSEMNTA_115_1/11</b>					FWD	REV
Tue 09/07/2021	to	Fri 10/08/2021				(Import) (Export)
0700	Continuous	2300				SCH - HQ_CEDARS <b>95 MW 40 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability 95 MW 60 MW
						TTC with All Lines In Service 190 MW 100 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
<b>DENNISON-ROSEMNTA_115_1/11</b>						
Tue 09/07/2021	to	Fri 10/08/2021				
0700	Continuous	2300		SCH - HQ_CEDARS	<b>95 MW</b>	<b>40 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	95 MW 60 MW
					TTC with All Lines In Service	190 MW 100 MW
<b>SCH-HQ_CEDARS-NYISO_LIMIT_80</b>						
Tue 09/07/2021	to	Fri 10/08/2021				
0700	Continuous	2300		SCH - HQ_CEDARS	<b>80 MW</b>	
Work scheduled by: HQ					Impacts Total Transfer Capability	110 MW
					TTC with All Lines In Service	190 MW
<b>DUNWODIE_345KV_6</b>						
Wed 09/08/2021	to	Wed 09/08/2021	<b>UPDATED</b>	<b>by CONED</b>	<b>06/17/2021</b>	
0001	Continuous	0030				
Work scheduled by: ConEd					SPR/DUN-SOUTH	<b>3800 MW</b>
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_8</b>						
Wed 09/08/2021	to	Wed 09/08/2021	<b>UPDATED</b>	<b>by CONED</b>	<b>06/17/2021</b>	
0001	Continuous	0030				
Work scheduled by: ConEd					SPR/DUN-SOUTH	<b>3800 MW</b>
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>WOOD_ST_-PLSNTVLE_345_Y87</b>						
Wed 09/08/2021	to	Wed 09/08/2021	<b>UPDATED</b>	<b>by CONED</b>	<b>06/17/2021</b>	
0001	Continuous	0030				
Work scheduled by: ConEd					UPNY CONED	<b>7260 MW</b>
					Impacts Total Transfer Capability	555 MW
					TTC with All Lines In Service	7815 MW
<b>PLSNTVLE-DUNWODIE_345_W90</b>						
Wed 09/08/2021	to	Wed 09/15/2021	<b>UPDATED</b>	<b>by CONED</b>	<b>08/07/2021</b>	
0001	Continuous	2200				
Work scheduled by: ConEd					UPNY CONED	<b>4000 MW</b>
					Impacts Total Transfer Capability	3815 MW
					TTC with All Lines In Service	7815 MW
<b>E13THSTA-FARRAGUT_345_45</b>						
Thu 09/09/2021	to	Thu 09/09/2021	<b>CANCELLED</b>	<b>by ConEd</b>	<b>09/01/2021</b>	
0001	Continuous	0500				
Work scheduled by: ConEd					SPR/DUN-SOUTH	<b>3800 MW</b>
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE_345KV_6</b>					FWD	
Sat 09/11/2021	to	Sat 09/11/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>08/07/2021</u>	(Import)
0001	Continuous	1800				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_8</b>					FWD	
Sat 09/11/2021	to	Sat 09/11/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>08/07/2021</u>	(Import)
0001	Continuous	1800				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>WOOD_ST_-PLSNTVLE_345_Y87</b>					FWD	
Sat 09/11/2021	to	Wed 09/15/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>08/07/2021</u>	(Import)
0001	Continuous	2200				UPNY CONED <b>7260 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	555 MW
					TTC with All Lines In Service	7815 MW
<b>W49TH_ST-E13THSTA_345_M54</b>					FWD	
Mon 09/13/2021	to	Tue 09/14/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/01/2021</u>	(Import)
0001	Continuous	0200				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>DOLSONAV-ROCKTVRN_345_DART44</b>					FWD	
Mon 09/13/2021	to	Wed 09/15/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/25/2021</u>	(Import)
0700	Continuous	1600				CENTRAL EAST - VC <b>2720 MW</b>
Work scheduled by: CHGE					Impacts Total Transfer Capability	255 MW
					TTC with All Lines In Service	2975 MW
<b>PANNELL_-CLAY_345_2</b>					FWD	
Mon 09/13/2021	to	Fri 09/17/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/12/2021</u>	(Import)
0700	Continuous	1530				WEST CENTRAL <b>1300 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	2250 MW
<b>LEEDS_345_LEEDS SVC</b>					FWD	
Mon 09/13/2021	to	Fri 09/17/2021				(Import)
0800	Continuous	1100				CENTRAL EAST - VC <b>2950 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	25 MW
					TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_6**

Wed 09/15/2021 to Wed 10/13/2021  
 0001 Continuous 0030  
 Work scheduled by: ConEd

**UPDATED by CONED 08/18/2021**

FWD  
 (Import)  
 SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**E13THSTA-FARRAGUT\_345\_46**

Wed 09/15/2021 to Wed 10/13/2021  
 0001 Continuous 2300  
 Work scheduled by: ConEd

**UPDATED by CONED 08/18/2021**

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**W49TH\_ST-E13THSTA\_345\_M55**

Wed 09/15/2021 to Wed 10/13/2021  
 0001 Continuous 2300  
 Work scheduled by: ConEd

**UPDATED by CONED 08/18/2021**

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**PORTER\_\_-ROTTRDAM\_230\_30**

Wed 09/15/2021 to Tue 11/30/2021  
 0700 Continuous 1730  
 Work scheduled by: NGrid

**UPDATED by NGRID 08/31/2021**

FWD  
 (Import)  
 CENTRAL EAST - VC **2805 MW**  
 Impacts Total Transfer Capability 170 MW  
 TTC with All Lines In Service 2975 MW

**DUNWODIE\_345KV\_6**

Wed 09/15/2021 to Wed 09/15/2021  
 2130 Continuous 2200  
 Work scheduled by: ConEd

**UPDATED by CONED 08/07/2021**

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_8**

Wed 09/15/2021 to Wed 09/15/2021  
 2130 Continuous 2200  
 Work scheduled by: ConEd

**UPDATED by CONED 08/07/2021**

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**EDIC\_\_-N.SCTLND\_345\_14**

Thu 09/16/2021 to Sun 11/14/2021  
 0600 Continuous 1830  
 Work scheduled by: NGrid

**UPDATED by NGRID 08/31/2021**

FWD  
 (Import)  
 CENTRAL EAST - VC **1670 MW**  
 Impacts Total Transfer Capability 1305 MW  
 TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EDIC\_\_\_-N.SCTLND\_345\_14 & PORTER\_\_\_-ROTTDAM\_230\_30**

Thu 09/16/2021 to Sun 11/14/2021  
0600 1830

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **1500 MW**  
Impacts Total Transfer Capability 1475 MW  
TTC with All Lines In Service 2975 MW

**HURLYAVE-ROSETON\_\_\_345\_303**

Thu 09/16/2021 to Fri 09/24/2021 **UPDATED by CHGE 08/31/2021**  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 3715 MW  
TTC with All Lines In Service 7815 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

Fri 09/17/2021 to Sat 09/18/2021  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

**RAMAPO\_\_\_-BUCHAN\_N\_345\_Y94**

Fri 09/17/2021 to Sat 09/18/2021  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7580 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 7815 MW

**DUNWODIE\_345KV\_3**

Sat 09/18/2021 to Sat 09/18/2021 **UPDATED by CONED 09/02/2021**  
0201 Continuous 0231

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**PLSNTVLE-DUNWODIE\_345\_W89**

Sat 09/18/2021 to Tue 09/28/2021 **UPDATED by CONED 09/02/2021**  
0201 Continuous 1000

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

**HOMRC\_NY-MAINS\_NY\_345\_47**

Sat 09/18/2021 to Fri 11/05/2021 **UPDATED by PJM 07/23/2021**  
0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>PANNELL_-CLAY_345_1</b>					FWD	
Mon 09/20/2021	to	Fri 09/24/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/25/2021</u>	(Import)
0700	Continuous	1530				WEST CENTRAL <b>1300 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 950 MW	
					TTC with All Lines In Service 2250 MW	
<b>EFISHKIL-WOOD_ST_345_F38</b>					FWD	
Sat 09/25/2021	to	Tue 09/28/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/02/2021</u>	(Import)
0001	Continuous	1000				UPNY CONED <b>4000 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 3815 MW	
					TTC with All Lines In Service 7815 MW	
<b>WOOD_ST_-PLSNTVLE_345_Y86</b>					FWD	
Sat 09/25/2021	to	Tue 09/28/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/02/2021</u>	(Import)
0001	Continuous	1000				UPNY CONED <b>7210 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 605 MW	
					TTC with All Lines In Service 7815 MW	
<b>SCH-NYISO-NE_LIMIT_700</b>					REV	
Sat 09/25/2021	to	Thu 09/30/2021				(Export)
0700	Continuous	1600				SCH - NE - NY <b>900 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability 700 MW	
					TTC with All Lines In Service 1600 MW	
<b>NIAGARA_-KINTIGH_345_NS1-38</b>					FWD	
Mon 09/27/2021	to	Fri 10/01/2021	<u>EXTENDED</u>	<u>by NYPA</u>	<u>08/20/2021</u>	(Import)
0500	Continuous	1700				DYSINGER EAST <b>1400 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1750 MW	
					TTC with All Lines In Service 3150 MW	
<b>FIVEMILE-STOLLERD_345_29</b>						
Mon 09/27/2021	to	Fri 10/08/2021				SCH - PJ - NY
0800	Continuous	1400				Impacts Total Transfer Capability
Work scheduled by: NYSEG					TTC with All Lines In Service	
<b>LEEDS_-HURLYAVE_345_301</b>					FWD	
Mon 09/27/2021	to	Fri 10/29/2021				(Import)
0800	Continuous	1600				UPNY CONED <b>4100 MW</b>
Work scheduled by: CHGE					Impacts Total Transfer Capability 3715 MW	
					TTC with All Lines In Service 7815 MW	

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE_345KV_3</b>					FWD	
Tue 09/28/2021	to	Tue 09/28/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/02/2021</u>	(Import)
0930	Continuous	1000				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	TTC with All Lines In Service 4600 MW
<b>DUNWODIE_345KV_4</b>					FWD	
Tue 09/28/2021	to	Tue 09/28/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/02/2021</u>	(Import)
0930	Continuous	1000				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	TTC with All Lines In Service 4600 MW
<b>EFISHKIL-WOOD_ST_345_F38</b>					FWD	
Wed 09/29/2021	to	Wed 09/29/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/02/2021</u>	(Import)
0130	Continuous	0200				UPNY CONED <b>4000 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 3815 MW	TTC with All Lines In Service 7815 MW
<b>PLSNTVLE-DUNWODIE_345_W89</b>					FWD	
Wed 09/29/2021	to	Wed 09/29/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/02/2021</u>	(Import)
0130	Continuous	0200				UPNY CONED <b>4000 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 3815 MW	TTC with All Lines In Service 7815 MW
<b>WOOD_ST_-PLSNTVLE_345_Y86</b>					FWD	
Wed 09/29/2021	to	Wed 09/29/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/02/2021</u>	(Import)
0130	Continuous	0200				UPNY CONED <b>7210 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 605 MW	TTC with All Lines In Service 7815 MW
<b>LADENTWN-BUCHAN_S_345_Y88</b>					FWD	
Thu 09/30/2021	to	Thu 09/30/2021	<u>UPDATED</u>	<u>by ORU</u>	<u>08/13/2021</u>	(Import)
0800	Continuous	1600				UPNY CONED <b>7560 MW</b>
Work scheduled by: ORU					Impacts Total Transfer Capability 255 MW	TTC with All Lines In Service 7815 MW
<b>NIAGARA_-STA_255_345_NH2</b>					FWD	
Sat 10/02/2021	to	Sun 10/17/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/20/2021</u>	(Import)
0500	Continuous	1900				DYSINGER EAST <b>1400 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1750 MW	TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CLAY -EDIC 345_2-15</b>					FWD	
Mon 10/04/2021	to	Sat 10/30/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/16/2021</u>	(Import)
0700	Continuous	1730				OSWEGO EXPORT <b>4850 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	5250 MW
<b>PLSNTVLE-DUNWODIE_345_W89</b>					FWD	
Tue 10/05/2021	to	Tue 10/05/2021				(Import)
0130	Continuous	0200				UPNY CONED <b>4000 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	3815 MW
					TTC with All Lines In Service	7815 MW
<b>W49TH_ST_345KV_6</b>					FWD	
Wed 10/13/2021	to	Wed 10/13/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>08/18/2021</u>	(Import)
2230	Continuous	2300				SCH - PJM_HTP <b>300 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
<b>MILLWOOD-EASTVIEW_345_W85</b>					FWD	
Thu 10/14/2021	to	Thu 10/14/2021				(Import)
0001	Continuous	0030				UPNY CONED <b>7550 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	265 MW
					TTC with All Lines In Service	7815 MW
<b>DUNWODIE-MOTTHAVN_345_72</b>					FWD	
Thu 10/14/2021	to	Sat 10/16/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>08/04/2021</u>	(Import)
0001	Continuous	0100				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_8</b>					FWD	
Thu 10/14/2021	to	Sat 10/16/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>08/04/2021</u>	(Import)
0001	Continuous	0100				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>EASTVIEW-SPRNBK_345_W78</b>					FWD	
Thu 10/14/2021	to	Sat 10/16/2021				(Import)
0001	Continuous	0100				UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	3465 MW
					TTC with All Lines In Service	7815 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_7**

Thu 10/14/2021 to Sat 11/20/2021  
 0001 Continuous 0030  
 Work scheduled by: ConEd

UPDATED by CONED 06/20/2021

FWD  
 (Import)  
 SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**DUNWODIE\_345KV\_5**

Thu 10/14/2021 to Sun 11/28/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_7**

Thu 10/14/2021 to Sun 11/28/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**SPRNBRK\_-DUNWODIE\_345\_W75**

Thu 10/14/2021 to Sun 11/28/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**SPRNBRK\_\_345KV\_RNS3**

Thu 10/14/2021 to Sun 11/28/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**W49TH\_ST\_345KV\_5**

Thu 10/14/2021 to Sun 12/05/2021  
 0001 Continuous 0300  
 Work scheduled by: ConEd

UPDATED by CONED 06/20/2021

FWD  
 (Import)  
 SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**SPRNBRK\_\_345KV\_RS3 & SPRNBRK\_\_345KV\_RS4**

Sat 10/16/2021 to Mon 10/18/2021  
 0001 0200  
 Work scheduled by:

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MILLWOOD-EASTVIEW\_345\_W85**

Sat 10/16/2021 to Sat 10/16/2021  
 0030 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **7550 MW**  
 Impacts Total Transfer Capability 265 MW  
 TTC with All Lines In Service 7815 MW

**DUNWODIE-MOTTHAVN\_345\_71**

Sat 10/16/2021 to Mon 10/18/2021  
 0101 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_3**

Sat 10/16/2021 to Mon 10/18/2021  
 0101 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**NIAGARA\_-KINTIGH\_345\_NS1-38**

Mon 10/18/2021 to Sat 12/04/2021 **UPDATED by NYPA 08/20/2021**  
 0500 Continuous 1900  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1400 MW**  
 Impacts Total Transfer Capability 1750 MW  
 TTC with All Lines In Service 3150 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

Wed 10/20/2021 to Thu 10/21/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

**RAMAPO\_-BUCHAN\_N\_345\_Y94**

Wed 10/20/2021 to Thu 10/21/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **7580 MW**  
 Impacts Total Transfer Capability 235 MW  
 TTC with All Lines In Service 7815 MW

**SCH-NE-NYISO\_LIMIT\_900**

Thu 10/21/2021 to Fri 10/29/2021  
 1700 Continuous 1600  
 Work scheduled by: ISONE

FWD  
 (Import)  
 SCH - NE - NY **1100 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 1400 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>SHOR_NPX-SHOREHAM_138_CSC</b>							
Tue 10/26/2021	to	Sun 11/21/2021					
0600	Continuous	1600			SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: ISONE						Impacts Total Transfer Capability	330 MW
						TTC with All Lines In Service	330 MW
<b>BUCHAN_S-MILLWOOD_345_W97</b>						FWD	
Mon 11/01/2021	to	Fri 12/10/2021	<u>UPDATED</u>	<u>by CE</u>	<u>09/02/2021</u>	(Import)	
0001	Continuous	0200			UPNY CONED	<b>7680 MW</b>	
Work scheduled by: ConEd						Impacts Total Transfer Capability	135 MW
						TTC with All Lines In Service	7815 MW
<b>SCH-IMO-NYISO_LIMIT_1750</b>						FWD	
Mon 11/01/2021	to	Fri 12/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)	
0001	Continuous	2359			SCH - OH - NY	<b>2050 MW</b>	
Work scheduled by: IESO						Impacts Total Transfer Capability	250 MW
						TTC with All Lines In Service	2300 MW
<b>SCH-NYISO-IMO_LIMIT_1600</b>							REV
Mon 11/01/2021	to	Fri 12/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>		(Export)
0001	Continuous	2359			SCH - OH - NY		<b>1900 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	2000 MW
<b>HURLYAVE-ROSETON__345_303</b>						FWD	
Mon 11/01/2021	to	Fri 11/19/2021				(Import)	
0800	Continuous	1600			UPNY CONED	<b>4100 MW</b>	
Work scheduled by: CHGE						Impacts Total Transfer Capability	3715 MW
						TTC with All Lines In Service	7815 MW
<b>LINDN_CG-LNDVFT__345_V-3022</b>						FWD	REV
Tue 11/02/2021	to	Fri 11/05/2021				(Import)	(Export)
0800	Continuous	1500			SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: PJM						Impacts Total Transfer Capability	315 MW
						TTC with All Lines In Service	315 MW
<b>MILLWOOD_345KV_18</b>						FWD	
Wed 11/03/2021	to	Fri 11/12/2021	<u>UPDATED</u>	<u>by CE</u>	<u>09/02/2021</u>	(Import)	
0001	Continuous	1800			UPNY CONED	<b>4350 MW</b>	
Work scheduled by: ConEd						Impacts Total Transfer Capability	3465 MW
						TTC with All Lines In Service	7815 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BUCHAN_S-MILLWOOD_345_W98</b>					FWD	
Wed 11/03/2021	to	Tue 11/09/2021	<u>UPDATED</u>	<u>by CE</u>	<u>09/02/2021</u>	(Import)
0201	Continuous	0200				<b>7680 MW</b>
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	135 MW
					TTC with All Lines In Service	7815 MW
<b>LADENTWN-BUCHAN_S_345_Y88</b>					FWD	
Wed 11/03/2021	to	Tue 11/09/2021	<u>UPDATED</u>	<u>by CE</u>	<u>09/02/2021</u>	(Import)
0201	Continuous	0200				<b>7560 MW</b>
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	255 MW
					TTC with All Lines In Service	7815 MW
<b>HOMRC_NY-MAINS_NY_345_47</b>						
Fri 11/05/2021	to	Mon 11/08/2021				
1601	Continuous	0800				
Work scheduled by: PJM					SCH - PJ - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<b>GOETHALS_345KV_5</b>						
Fri 11/12/2021	to	Tue 11/16/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/30/2021</u>	
0001	Continuous	0300				
Work scheduled by: ConEd					STATEN ISLAND	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<b>PORTER__-ROTTRDAM_230_30 &amp; MASSENA_-MARCY___765_MSU1</b>					FWD	
Mon 11/15/2021	to	Tue 11/30/2021				(Import)
0100		1730				<b>1500 MW</b>
Work scheduled by:					CENTRAL EAST - VC	
					Impacts Total Transfer Capability	1475 MW
					TTC with All Lines In Service	2975 MW
<b>CHATGUAY-MASSENA__765_7040</b>					FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>	(Import)
0100	Continuous	1859				<b>1550 MW</b>
Work scheduled by: NYPA					MOSES SOUTH	
					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	3150 MW
<b>CHATGUAY-MASSENA__765_7040</b>					FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>	(Import) (Export)
0100	Continuous	1859				<b>0 MW 0 MW</b>
Work scheduled by: NYPA					SCH - HQ - NY	
					Impacts Total Transfer Capability	1500 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY___765_345_AT1</b>					FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<b>UPDATED</b>	<b>by NYISO</b>	<b>06/03/2021</b>	(Import)
0100	Continuous	1859				MOSES SOUTH <b>1750 MW</b>
Work scheduled by: NYPA				<b>ARR: 19</b>		Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 3150 MW
<b>MARCY___765_345_AT2</b>					FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<b>UPDATED</b>	<b>by NYISO</b>	<b>06/03/2021</b>	(Import)
0100	Continuous	1859				MOSES SOUTH <b>1700 MW</b>
Work scheduled by: NYPA				<b>ARR: 19</b>		Impacts Total Transfer Capability 1450 MW
						TTC with All Lines In Service 3150 MW
<b>MASSENA_-MARCY___765_MSU1</b>					FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<b>UPDATED</b>	<b>by NYISO</b>	<b>06/03/2021</b>	(Import)
0100	Continuous	1859				CENTRAL EAST - VC <b>1670 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 1305 MW
						TTC with All Lines In Service 2975 MW
<b>MASSENA_-MARCY___765_MSU1</b>					FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<b>UPDATED</b>	<b>by NYISO</b>	<b>06/03/2021</b>	(Import)
0100	Continuous	1859				MOSES SOUTH <b>500 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 2650 MW
						TTC with All Lines In Service 3150 MW
<b>MASSENA_-MARCY___765_MSU1</b>					FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021	<b>UPDATED</b>	<b>by NYISO</b>	<b>06/03/2021</b>	(Import) (Export)
0100	Continuous	1859				SCH - HQ - NY <b>475 MW 1000 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 1025 MW 0 MW
						TTC with All Lines In Service 1500 MW 1000 MW
<b>MASSENA_-MARCY___765_MSU1</b>					FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<b>UPDATED</b>	<b>by NYISO</b>	<b>06/03/2021</b>	(Import)
0100	Continuous	1859				SCH - HQ_CEDARS <b>90 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 109 MW
						TTC with All Lines In Service 199 MW
<b>MASSENA_-MARCY___765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>					FWD	
Mon 11/15/2021	to	Tue 11/30/2021				(Import)
0100		1859				MOSES SOUTH <b>500 MW</b>
Work scheduled by:						Impacts Total Transfer Capability 2650 MW
						TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES ___-MASSENA___ 230_MMS1 & MOSES ___-MASSENA___ 230_MMS2	FWD	REV
Mon 11/15/2021 to Tue 11/30/2021	(Import)	(Export)
0100 1859	SCH - HQ - NY	850 MW 0 MW
Work scheduled by:	Impacts Total Transfer Capability	650 MW 1000 MW
	TTC with All Lines In Service	1500 MW 1000 MW
<hr/>		
MOSES ___-MASSENA___ 230_MMS1 & MOSES ___-MASSENA___ 230_MMS2	FWD	
Mon 11/15/2021 to Tue 11/30/2021	(Import)	
0100 1859	SCH - HQ_CEDARS	90 MW
Work scheduled by:	Impacts Total Transfer Capability	109 MW
	TTC with All Lines In Service	199 MW
<hr/>		
STLAWRNC-MOSES___ 230_L33P & MASSENA_-MARCY___ 765_MSU1	FWD	
Mon 11/15/2021 to Tue 11/30/2021	(Import)	
0100 1859	SCH - HQ_CEDARS	90 MW
Work scheduled by:	Impacts Total Transfer Capability	109 MW
	TTC with All Lines In Service	199 MW
<hr/>		
STLAWRNC-MOSES___ 230_L33P & MOSES ___-MASSENA___ 230_MMS1 & MOSES ___-MASSENA___ 230_MMS2	FWD	
Mon 11/15/2021 to Tue 11/30/2021	(Import)	
0100 1859	SCH - HQ_CEDARS	90 MW
Work scheduled by:	Impacts Total Transfer Capability	109 MW
	TTC with All Lines In Service	199 MW
<hr/>		
S.RIPLEY-DUNKIRK___ 230_68		
Tue 11/16/2021 to Sat 12/04/2021		
0700 Continuous 1730	SCH - PJ - NY	
Work scheduled by: NGrid	Impacts Total Transfer Capability	
	TTC with All Lines In Service	
<hr/>		
MILLWOOD-EASTVIEW_345_W85	FWD	
Fri 11/19/2021 to Fri 11/19/2021	(Import)	
0001 Continuous 0030	UPNY CONED	7550 MW
Work scheduled by: ConEd	Impacts Total Transfer Capability	265 MW
	TTC with All Lines In Service	7815 MW
<hr/>		
EASTVIEW-SPRNBRK___ 345_W78	FWD	
Fri 11/19/2021 to Wed 11/24/2021	(Import)	
0001 Continuous 0200	UPNY CONED	4350 MW
Work scheduled by: ConEd	Impacts Total Transfer Capability	3465 MW
	TTC with All Lines In Service	7815 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE-MOTTHAVN_345_72</b>					FWD	
Sat 11/20/2021	to	Wed 11/24/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/07/2021</u>	(Import)
0001	Continuous	0200				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
<b>DUNWODIE_345KV_8</b>					FWD	
Sat 11/20/2021	to	Wed 11/24/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/07/2021</u>	(Import)
0001	Continuous	0200				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
<b>SPRNBK__345KV_RS3 &amp; SPRNBK__345KV_RS4</b>					FWD	
Wed 11/24/2021	to	Sun 11/28/2021				(Import)
0001		0200				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by:					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
<b>MILLWOOD-EASTVIEW_345_W85</b>					FWD	
Wed 11/24/2021	to	Wed 11/24/2021	<u>UPDATED</u>	<u>by CE</u>	<u>06/28/2021</u>	(Import)
0130	Continuous	0200				UPNY CONED <b>7550 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 265 MW	
					TTC with All Lines In Service 7815 MW	
<b>DUNWODIE-MOTTHAVN_345_71</b>					FWD	
Wed 11/24/2021	to	Sun 11/28/2021				(Import)
0201	Continuous	0100				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
<b>DUNWODIE_345KV_3</b>					FWD	
Wed 11/24/2021	to	Sun 11/28/2021				(Import)
0201	Continuous	0100				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
<b>SPRNBK__345KV_RNS4</b>					FWD	
Sun 11/28/2021	to	Sun 11/28/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/20/2021</u>	(Import)
0300	Continuous	0330				SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW	
					TTC with All Lines In Service 4600 MW	

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK_-W49TH_ST_345_M52</b>				FWD	
Sun 11/28/2021	to	Wed 12/01/2021	<u>UPDATED</u> <u>by CONED</u> <u>06/20/2021</u>	(Import)	
0300	Continuous	0200		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<b>NIAGARA_-PACKARD_230_61</b>				FWD	REV
Tue 11/30/2021	to	Mon 12/06/2021		(Import)	(Export)
0615	Continuous	1900		SCH - OH - NY	<b>1200 MW 1850 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	1100 MW 150 MW
				TTC with All Lines In Service	2300 MW 2000 MW
<b>SPRNBK_345KV_RNS4</b>				FWD	
Wed 12/01/2021	to	Wed 12/01/2021	<u>UPDATED</u> <u>by CONED</u> <u>06/20/2021</u>	(Import)	
0130	Continuous	0200		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<b>MOSES_-ADIRNDCK_230_MA1</b>				FWD	
Wed 12/01/2021	to	Tue 05/31/2022		(Import)	
0700	Continuous	1300		MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
<b>MARCY_345KV_CSC</b>				FWD	
Mon 12/06/2021	to	Fri 12/17/2021		(Import)	
0700	Continuous	1730		CENTRAL EAST - VC	<b>2925 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	50 MW
				TTC with All Lines In Service	2975 MW
<b>BUCHAN_S-MILLWOOD_345_W98</b>				FWD	
Tue 12/07/2021	to	Fri 12/10/2021	<u>UPDATED</u> <u>by CE</u> <u>09/02/2021</u>	(Import)	
0201	Continuous	0200		UPNY CONED	<b>7680 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	135 MW
				TTC with All Lines In Service	7815 MW
<b>LADENTWN-BUCHAN_S_345_Y88</b>				FWD	
Tue 12/07/2021	to	Fri 12/10/2021	<u>UPDATED</u> <u>by CE</u> <u>09/02/2021</u>	(Import)	
0201	Continuous	0200		UPNY CONED	<b>7560 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	255 MW
				TTC with All Lines In Service	7815 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MILLWOOD_345KV_18</b>						FWD	
Tue 12/07/2021	to	Fri 12/10/2021	<u>UPDATED</u>	<u>by CE</u>	<u>09/02/2021</u>	(Import)	
0201	Continuous	0200				UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	3465 MW
						TTC with All Lines In Service	7815 MW
<b>EASTVIEW-SPRNBK__345_W64</b>						FWD	
Sun 12/12/2021	to	Tue 12/14/2021	<u>UPDATED</u>	<u>by CE</u>	<u>07/21/2021</u>	(Import)	
2000	Continuous	0200				UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	3465 MW
						TTC with All Lines In Service	7815 MW
<b>MILLWOOD-EASTVIEW_345_W99</b>						FWD	
Sun 12/12/2021	to	Tue 12/14/2021	<u>UPDATED</u>	<u>by CE</u>	<u>07/21/2021</u>	(Import)	
2000	Continuous	0200				UPNY CONED	<b>7550 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	265 MW
						TTC with All Lines In Service	7815 MW
<b>SPRNBK__345KV_RNS5</b>						FWD	
Sun 12/12/2021	to	Tue 12/14/2021	<u>UPDATED</u>	<u>by CE</u>	<u>07/21/2021</u>	(Import)	
2000	Continuous	0200				SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	1400 MW
						TTC with All Lines In Service	4600 MW
<b>FRASER__345_FRASER SVC</b>						FWD	
Tue 01/04/2022	to	Mon 02/28/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/25/2021</u>	(Import)	
0700	Continuous	1730				CENTRAL EAST - VC	<b>2935 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	40 MW
						TTC with All Lines In Service	2975 MW
<b>NIAGARA_-PACKARD__230_61</b>						FWD	REV
Mon 01/17/2022	to	Fri 01/21/2022				(Import)	(Export)
0615	Continuous	1900				SCH - OH - NY	<b>1200 MW 1850 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	1100 MW 150 MW
						TTC with All Lines In Service	2300 MW 2000 MW
<b>NIAGARA_-STA_255__345_NH2</b>						FWD	
Fri 01/21/2022	to	Fri 03/04/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/20/2021</u>	(Import)	
0500	Continuous	1900				DYSINGER EAST	<b>1700 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1450 MW
						TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**FRASANX-COOPERS\_\_345\_UCC2-41**

Mon 02/07/2022 to Sat 02/12/2022  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**MARCY\_\_-FRASANX\_345\_UCC2-41**

Mon 02/07/2022 to Sat 02/12/2022  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**ATHENS\_\_-PLSNTVLY\_345\_91**

Sat 02/12/2022 to Wed 02/16/2022  
0600 Continuous 1900

Work scheduled by: NGrid

**UPDATED by NGRID 05/07/2021**

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Thu 02/17/2022 to Sat 02/19/2022  
0001 2200

Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**LEEDS\_\_-PLSNTVLY\_345\_92**

Thu 02/17/2022 to Fri 03/25/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**PLSNTVLY\_345KV\_RNS5**

Thu 02/17/2022 to Fri 03/25/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**PLSNTVLY-WOOD\_ST\_\_345\_F30**

Sun 02/20/2022 to Mon 02/21/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EASTVIEW-SPRNBK\_\_345\_W64**

Tue 02/22/2022 to Tue 02/22/2022  
 0001 Continuous 0030  
 Work scheduled by: ConEd

**UPDATED by CONED 08/31/2021**

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

**SPRNBK\_\_345KV\_RNS5**

Tue 02/22/2022 to Tue 02/22/2022  
 0001 Continuous 0030  
 Work scheduled by: ConEd

**UPDATED by CONED 08/31/2021**

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**MILLWOOD-EASTVIEW\_345\_W99**

Tue 02/22/2022 to Mon 03/21/2022  
 0001 Continuous 0200  
 Work scheduled by: ConEd

**UPDATED by CONED 08/31/2021**

FWD  
 (Import)  
 UPNY CONED **7550 MW**  
 Impacts Total Transfer Capability 265 MW  
 TTC with All Lines In Service 7815 MW

**MARCY\_\_-EDIC\_\_345\_UE1-7**

Wed 02/23/2022 to Mon 02/28/2022  
 0700 Continuous 1530  
 Work scheduled by: NYPA

**ARR: 19&16**

FWD  
 (Import)  
 OSWEGO EXPORT **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

**PORTER\_\_-ROTTRDAM\_230\_31**

Tue 03/01/2022 to Tue 12/31/2030  
 0600 Continuous 2359  
 Work scheduled by: NGrid

FWD  
 (Import)  
 CENTRAL EAST - VC **2805 MW**  
 Impacts Total Transfer Capability 170 MW  
 TTC with All Lines In Service 2975 MW

**FRASANX-COOPERS\_\_345\_UCC2-41**

Tue 03/01/2022 to Wed 04/20/2022  
 0700 Continuous 1530  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

**MARCY\_\_-FRASANX\_345\_UCC2-41**

Tue 03/01/2022 to Wed 04/20/2022  
 0700 Continuous 1530  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**GOETHALS\_345KV\_5**

Sat 03/05/2022 to Mon 04/04/2022 **UPDATED** by CONED 03/26/2021  
 0001 Continuous 0200 STATEN ISLAND  
 Impacts Total Transfer Capability  
 Work scheduled by: ConEd TTC with All Lines In Service

-----  
**LINDEN\_-GOETHALS\_230\_A2253**

Sat 03/05/2022 to Mon 04/04/2022 **UPDATED** by CONED 03/26/2021  
 0001 Continuous 0200 SCH - PJ - NY  
 Impacts Total Transfer Capability  
 Work scheduled by: ConEd TTC with All Lines In Service

-----  
**INDPDNCE-SCRIBA\_\_345\_25**

Thu 03/10/2022 to Wed 03/16/2022  
 0800 Continuous 1800 FWD  
 (Import)  
 OSWEGO EXPORT **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 Work scheduled by: NGrid TTC with All Lines In Service 5250 MW

-----  
**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Thu 03/17/2022 to Sun 03/20/2022 FWD  
 (Import)  
 0100 2200 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 4015 MW  
 Work scheduled by: TTC with All Lines In Service 7815 MW

-----  
**PLSNTVLY-WOOD\_ST\_\_345\_F30**

Mon 03/21/2022 to Wed 03/23/2022 FWD  
 (Import)  
 0001 Continuous 2200 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 3815 MW  
 Work scheduled by: ConEd TTC with All Lines In Service 7815 MW

-----  
**EASTVIEW-SPRNBK\_\_345\_W64**

Mon 03/21/2022 to Mon 03/21/2022 **UPDATED** by CONED 08/31/2021 FWD  
 (Import)  
 0130 Continuous 0200 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 Work scheduled by: ConEd TTC with All Lines In Service 7815 MW

-----  
**SPRNBK\_\_345KV\_RNS5**

Mon 03/21/2022 to Mon 03/21/2022 **UPDATED** by CONED 08/31/2021 FWD  
 (Import)  
 0130 Continuous 0200 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 Work scheduled by: ConEd TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Sat 03/26/2022 to Mon 03/28/2022  
 0001 2200

Work scheduled by:

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 4015 MW  
 TTC with All Lines In Service 7815 MW

-----  
**ATHENS\_-PLSNTVLY\_345\_91**

Sat 03/26/2022 to Sun 05/01/2022  
 0001 Continuous 2200

Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 4015 MW  
 TTC with All Lines In Service 7815 MW

-----  
**PLSNTVLY\_345KV\_RNS4**

Sat 03/26/2022 to Sun 05/01/2022  
 0001 Continuous 2200

Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 4015 MW  
 TTC with All Lines In Service 7815 MW

-----  
**PLSNTVLY-WOOD\_ST\_345\_F31**

Tue 03/29/2022 to Wed 03/30/2022  
 0001 Continuous 2200

Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 3815 MW  
 TTC with All Lines In Service 7815 MW

-----  
**SPRNBK\_-TREMONT\_345\_X28**

Tue 04/05/2022 to Wed 04/06/2022  
 0201 Continuous 0300

Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **4200 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 4600 MW

-----  
**BUCHAN\_N-EASTVIEW\_345\_W93**

Wed 04/06/2022 to Wed 04/06/2022 **UPDATED by CONED 08/19/2021**  
 0301 Continuous 0330

Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

-----  
**EASTVIEW-SPRNBK\_345\_W79**

Wed 04/06/2022 to Thu 04/07/2022 **UPDATED by CONED 08/19/2021**  
 0301 Continuous 0300

Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BUCHAN_N-EASTVIEW_345_W93</b>					FWD	
Thu 04/07/2022	to	Thu 04/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/19/2021</u>	(Import)
0230	Continuous	0300				UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW	TTC with All Lines In Service 7815 MW
<b>EASTVIEW-SPRNBK__345_W64</b>					FWD	
Thu 04/07/2022	to	Thu 04/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/31/2021</u>	(Import)
0301	Continuous	0330				UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW	TTC with All Lines In Service 7815 MW
<b>SPRNBK__345KV_RNS5</b>					FWD	
Thu 04/07/2022	to	Thu 04/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/31/2021</u>	(Import)
0301	Continuous	0330				SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW	TTC with All Lines In Service 4600 MW
<b>MILLWOOD-EASTVIEW_345_W99</b>					FWD	
Thu 04/07/2022	to	Tue 04/26/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/31/2021</u>	(Import)
0301	Continuous	2200				UPNY CONED <b>7550 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 265 MW	TTC with All Lines In Service 7815 MW
<b>PANNELL_-CLAY____345_1</b>					FWD	
Mon 04/11/2022	to	Fri 04/15/2022				(Import)
0700	Continuous	1530				WEST CENTRAL <b>1300 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 950 MW	TTC with All Lines In Service 2250 MW
<b>PORTER_-ROTTRDAM_230_30</b>					FWD	
Wed 04/13/2022	to	Tue 12/31/2030				(Import)
0600	Continuous	2359				CENTRAL EAST - VC <b>2805 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 170 MW	TTC with All Lines In Service 2975 MW
<b>PANNELL_-CLAY____345_2</b>					FWD	
Mon 04/18/2022	to	Fri 04/22/2022				(Import)
0700	Continuous	1530				WEST CENTRAL <b>1300 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 950 MW	TTC with All Lines In Service 2250 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EDIC -FRASER 345_EF24-40</b>				FWD
Thu 04/21/2022	to	Tue 06/14/2022		(Import)
0700	Continuous	1530	CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 475 MW
				TTC with All Lines In Service 2975 MW
<b>PLSNTVLY_345KV_RN5 &amp; PLSNTVLY_345KV_RN4</b>				FWD
Sat 04/23/2022	to	Tue 04/26/2022		(Import)
0001		2200	UPNY CONED	<b>3800 MW</b>
Work scheduled by:				Impacts Total Transfer Capability 4015 MW
				TTC with All Lines In Service 7815 MW
<b>EASTVIEW-SPRNBK 345_W64</b>				FWD
Tue 04/26/2022	to	Tue 04/26/2022	<u>UPDATED</u> <u>by CONED</u> <u>08/31/2021</u>	(Import)
2130	Continuous	2200	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
<b>SPRNBK 345KV_RNS5</b>				FWD
Tue 04/26/2022	to	Tue 04/26/2022	<u>UPDATED</u> <u>by CONED</u> <u>08/31/2021</u>	(Import)
2130	Continuous	2200	SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
<b>PLSNTVLY-WOOD_ST 345_F31</b>				FWD
Wed 04/27/2022	to	Fri 04/29/2022		(Import)
0001	Continuous	2200	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 3815 MW
				TTC with All Lines In Service 7815 MW
<b>NIAGARA 345_230_AT4</b>				REV
Fri 04/29/2022	to	Fri 04/29/2022		(Export)
0500	Continuous	1700	SCH - OH - NY	<b>1750 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 250 MW
				TTC with All Lines In Service 2000 MW
<b>BUCHAN_N-EASTVIEW_345_W93</b>				FWD
Mon 05/02/2022	to	Mon 05/02/2022		(Import)
0001	Continuous	0030	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EASTVIEW-SPRNBK__345_W79</b>				FWD	
Mon 05/02/2022	to	Thu 05/05/2022		(Import)	
0001	Continuous	0200	UPNY CONED	<b>4350 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3465 MW	
			TTC with All Lines In Service	7815 MW	
<b>ROCHESTR-PANNELL__345_RP2</b>				FWD	
Mon 05/02/2022	to	Fri 05/06/2022		(Import)	
0500	Continuous	1700	DYSINGER EAST	<b>2300 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
<b>N. SCTLND-ALPS____345_2</b>				FWD	
Mon 05/02/2022	to	Mon 05/09/2022		(Import)	
0600	Daily	1800	SCH - NE - NY	<b>750 MW</b>	
Work scheduled by: NGrid			Impacts Total Transfer Capability	650 MW	
			TTC with All Lines In Service	1400 MW	
<b>N. SCTLND-ALPS____345_2</b>				FWD	REV
Mon 05/02/2022	to	Mon 05/09/2022		(Import)	(Export)
0600	Daily	1800	SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	100 MW	100 MW
			TTC with All Lines In Service	200 MW	200 MW
<b>BUCHAN_N-EASTVIEW_345_W93</b>				FWD	
Thu 05/05/2022	to	Thu 05/05/2022		(Import)	
0130	Continuous	0200	UPNY CONED	<b>4350 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3465 MW	
			TTC with All Lines In Service	7815 MW	
<b>SPRNBK_-TREMONT__345_X28</b>				FWD	
Fri 05/06/2022	to	Mon 05/09/2022	<b>UPDATED by CONED 08/19/2021</b>	(Import)	
0201	Continuous	1800	SPR/DUN-SOUTH	<b>4200 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	4600 MW	
<b>FRASER__345_FRASER SVC</b>				FWD	
Mon 05/09/2022	to	Fri 05/13/2022		(Import)	
0800	Continuous	1700	CENTRAL EAST - VC	<b>2935 MW</b>	
Work scheduled by: NYSEG			Impacts Total Transfer Capability	40 MW	
			TTC with All Lines In Service	2975 MW	

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**HOMRC\_NY-MAINS\_NY\_345\_47**

Fri 05/20/2022 to Fri 05/27/2022 **UPDATED** **by PJM** **11/19/2020**  
 0800 Continuous 1600  
 Work scheduled by: PJM  
 SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**HOMR\_NYW-PIERC\_NY\_345\_48**

Fri 05/20/2022 to Fri 05/27/2022 **UPDATED** **by PJM** **11/19/2020**  
 0800 Continuous 1600  
 Work scheduled by: PJM  
 SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**NIAGARA\_-PACKARD\_230\_62**

Sat 06/18/2022 to Sat 06/18/2022  
 0500 Continuous 1700  
 Work scheduled by: NYPA  
 SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>700 MW</b>	<b>1550 MW</b>
Impacts Total Transfer Capability	1250 MW	150 MW
TTC with All Lines In Service	1950 MW	1700 MW

**NIAGARA\_345\_230\_AT4**

Tue 06/28/2022 to Wed 06/29/2022  
 0500 Continuous 1700  
 Work scheduled by: NYPA  
 SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1900 MW</b>	<b>1400 MW</b>
Impacts Total Transfer Capability	50 MW	300 MW
TTC with All Lines In Service	1950 MW	1700 MW

**BECK\_-NIAGARA\_230\_PA27**

Tue 07/05/2022 to Sat 07/09/2022  
 0500 Continuous 2100  
 Work scheduled by: NYPA  
 SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**ROCHESTR-PANNELL\_345\_RP1**

Mon 07/25/2022 to Fri 07/29/2022  
 0500 Continuous 2100  
 Work scheduled by: NYPA  
 DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

	FWD
	(Import)
DYSINGER EAST	<b>2300 MW</b>
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

**PANNELL\_-CLAY\_345\_1**

Mon 09/12/2022 to Fri 09/16/2022  
 0700 Continuous 1530  
 Work scheduled by: NYPA  
 WEST CENTRAL  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

	FWD
	(Import)
WEST CENTRAL	<b>1300 MW</b>
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	2250 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September02, 2021 to Saturday ,March 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**FRASER -GILBOA 345\_GF5-35**

Mon 09/12/2022 to Sun 09/18/2022  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

**SPRNBRK 345KV\_RNS5**

Mon 09/19/2022 to Mon 09/19/2022 **UPDATED by CONED 09/17/2020**  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**SPRNBRK -W49TH\_ST\_345\_M51**

Mon 09/19/2022 to Wed 09/21/2022 **UPDATED by CONED 09/17/2020**  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**PANNELL -CLAY 345\_2**

Mon 09/19/2022 to Fri 09/23/2022  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

**SPRNBRK 345KV\_RNS5**

Wed 09/21/2022 to Wed 09/21/2022 **UPDATED by CONED 09/17/2020**  
 2130 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**SPRNBRK -W49TH\_ST\_345\_M51**

Sat 10/01/2022 to Mon 10/17/2022 **UPDATED by CONED 08/01/2020**  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**SPRNBRK 345KV\_RNS5**

Sat 10/01/2022 to Mon 10/17/2022 **UPDATED by CONED 08/01/2020**  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW