

# NYISO TRANSFER LIMITATIONS

Monday ,September06, 2021 to Wednesday, March 08, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Tue 11/30/2021 EXT FORCE by CONED 05/26/2021

0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJ - NY **2050 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 2250 MW

## HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Tue 11/30/2021

0001 2359

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2000 MW 1150 MW**  
Impacts Total Transfer Capability 250 MW 100 MW  
TTC with All Lines In Service 2250 MW 1250 MW

## MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Tue 11/30/2021 EXT FORCE by CONED 05/26/2021

0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJ - NY **2050 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 2250 MW

## STLAWRNC-MOSES\_230\_L33P

Mon 04/30/2018 to Mon 10/31/2022 EXT FORCE by IESO 07/08/2021

0456 Continuous 1600

Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## NEWBRIDGE\_345\_138\_BK\_1

Wed 09/02/2020 to Tue 02/01/2022 EXT FORCE by LI 01/12/2021

1807 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

## SCH-IMO-NYISO\_LIMIT\_1600

Sat 05/01/2021 to Sun 10/31/2021 UPDATED by IESO 05/03/2019

0001 Continuous 2359

Work scheduled by: IESO

FWD  
(Import)  
SCH - OH - NY **1900 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 1950 MW

## DUNWODIE-SHORE\_RD\_345\_Y50

Sat 07/17/2021 to Fri 09/17/2021 EXT FORCE by CE 08/26/2021

1053 Continuous 0200

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **800 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1500 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,September06, 2021 to Wednesday, March 08, 2023

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 7815MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHORE_RD_345_138_BK 1						FWD
Sat 07/17/2021	to	Fri 09/17/2021	<u>EXT FORCE</u>	<u>by CE</u>	<u>08/26/2021</u>	(Import)
1053	Continuous	0200				CONED - LIPA 1350 MW
Work scheduled by: LI						Impacts Total Transfer Capability 150 MW
						TTC with All Lines In Service 1500 MW
SHORE_RD_345_138_BK 2						FWD
Sat 07/17/2021	to	Fri 09/17/2021	<u>EXT FORCE</u>	<u>by CE</u>	<u>08/26/2021</u>	(Import)
1053	Continuous	0200				CONED - LIPA 1350 MW
Work scheduled by: LI						Impacts Total Transfer Capability 150 MW
						TTC with All Lines In Service 1500 MW
EGRDNCTY_345_138_AT1						FWD
Fri 08/06/2021	to	Fri 10/15/2021	<u>EXT FORCE</u>	<u>by LI</u>	<u>08/11/2021</u>	(Import)
1939	Continuous	2359				CONED - LIPA 1250 MW
Work scheduled by: LI						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 1500 MW
EGRDNCTY_345_138_AT2						FWD
Fri 08/06/2021	to	Fri 10/15/2021	<u>EXT FORCE</u>	<u>by LI</u>	<u>08/11/2021</u>	(Import)
1939	Continuous	2359				CONED - LIPA 1250 MW
Work scheduled by: LI						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 1500 MW
SPRNBK_-EGRDNCTR_345_Y49 & DUNWODIE-SHORE_RD_345_Y50						FWD
Fri 08/06/2021	to	Fri 09/17/2021				(Import)
1953		0200				CONED - LIPA 25 MW
Work scheduled by:						Impacts Total Transfer Capability 1475 MW
						TTC with All Lines In Service 1500 MW
SPRNBK_-EGRDNCTR_345_Y49						FWD
Fri 08/06/2021	to	Fri 10/15/2021	<u>EXT FORCE</u>	<u>by LI</u>	<u>08/11/2021</u>	(Import)
1953	Continuous	2359				CONED - LIPA 775 MW
Work scheduled by: LI						Impacts Total Transfer Capability 725 MW
						TTC with All Lines In Service 1500 MW
NIAGARA_-STA_255_345_NH2						FWD
Fri 08/27/2021	to	Mon 09/06/2021	<u>EXTENDED</u>	<u>by NYPA</u>	<u>09/02/2021</u>	(Import)
0500	Continuous	2300				DYSINGER EAST 1400 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1750 MW
						TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Monday ,September06, 2021 to Wednesday, March 08, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Fri 08/27/2021 to Thu 09/02/2021 UPDATED by NYPA 09/01/2021  
0600 Continuous 1800

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## SCH-IMO-NYISO\_LIMIT\_1400

Fri 08/27/2021 to Thu 09/02/2021 UPDATED by NYPA 09/01/2021  
0600 Continuous 1800

Work scheduled by: IESO

FWD  
(Import)  
SCH - OH - NY **1700 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1950 MW

## SCH-NYISO-IMO\_LIMIT\_1200

Fri 08/27/2021 to Thu 09/02/2021 UPDATED by NYPA 09/01/2021  
0600 Continuous 1800

Work scheduled by: IESO

REV  
(Export)  
SCH - OH - NY **1500 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1700 MW

## SCH-NYISO-NE\_LIMIT\_700

Sat 08/28/2021 to Wed 09/08/2021  
0700 Daily 2259

Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY **900 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1600 MW

## SCH-NE-NYISO\_LIMIT\_600

Sat 08/28/2021 to Wed 09/08/2021  
2300 Daily 0659

Work scheduled by: ISONE

FWD  
(Import)  
SCH - NE - NY **800 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1400 MW

## SCH-HQ\_CEDARS-NYISO\_LIMIT\_80

Mon 08/30/2021 to Sun 09/05/2021 by HQ 08/26/2021  
0700 Continuous 2300

Work scheduled by: HQ

FWD  
(Import)  
SCH - HQ\_CEDARS **80 MW**  
Impacts Total Transfer Capability 110 MW  
TTC with All Lines In Service 190 MW

## SHOR\_NPX-SHOREHAM\_138\_CSC

Wed 09/01/2021 to Wed 09/01/2021  
0600 Continuous 2300

Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_CSC **0 MW 0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>LAFAYTTE-CLRKSCRN_345_4-46</b>					FWD (Import)	
Wed 09/01/2021	to	Wed 09/01/2021			CENTRAL EAST - VC	<b>2650 MW</b>
0630	Daily	1400			Impacts Total Transfer Capability	325 MW
Work scheduled by: NGrid					TTC with All Lines In Service	2975 MW
<b>LEEDS__-HURLYAVE_345_301</b>					FWD (Import)	
Thu 09/02/2021	to	Fri 09/03/2021			UPNY CONED	<b>4100 MW</b>
0730	Daily(No Weekends)	2359			Impacts Total Transfer Capability	3715 MW
Work scheduled by: NGrid					TTC with All Lines In Service	7815 MW
<b>LEEDS__345KV_R94301</b>					FWD (Import)	
Thu 09/02/2021	to	Fri 09/03/2021			UPNY CONED	<b>3800 MW</b>
0730	Daily(No Weekends)	2359			Impacts Total Transfer Capability	4015 MW
Work scheduled by: NGrid					TTC with All Lines In Service	7815 MW
<b>SCH-NYISO-NE_LIMIT_1100</b>					REV (Export)	
Sun 09/05/2021	to	Sun 09/05/2021	<b><u>UPDATED</u></b>	<b><u>by ISONE</u></b>	<b><u>09/04/2021</u></b>	
0001	Daily	0700			SCH - NE - NY	<b>1300 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	1600 MW
<b>SCH-NYISO-NE_LIMIT_1000</b>					REV (Export)	
Mon 09/06/2021	to	Mon 09/06/2021	<b><u>UPDATED</u></b>	<b><u>by ISONE</u></b>	<b><u>09/04/2021</u></b>	
0001	Daily	0700			SCH - NE - NY	<b>1200 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	1600 MW
<b>SCH-NYISO-NE_LIMIT_1000</b>					REV (Export)	
Mon 09/06/2021	to	Tue 09/07/2021	<b><u>UPDATED</u></b>	<b><u>by ISONE</u></b>	<b><u>09/04/2021</u></b>	
2300	Daily	0700			SCH - NE - NY	<b>1200 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	1600 MW
<b>SPRNBK__345KV_RS3 &amp; SPRNBK__345KV_RS4</b>					FWD (Import)	
Tue 09/07/2021	to	Tue 09/07/2021			SPR/DUN-SOUTH	<b>3200 MW</b>
0001		0030			Impacts Total Transfer Capability	1400 MW
Work scheduled by:					TTC with All Lines In Service	4600 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,September06, 2021 to Wednesday, March 08, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_-KINTIGH\_\_345\_NS1-38**

FWD

Tue 09/07/2021 to Sun 09/12/2021

UPDATEDby NYPA09/02/2021

(Import)

0500 Continuous 2300

DYSINGER EAST

**1400 MW**

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**SCH-NYISO-HQ\_CEDARS\_LIMIT\_0**

REV

Tue 09/07/2021 to Thu 09/30/2021

(Export)

0500 Continuous 1900

SCH - HQ\_CEDARS

**0 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 100 MW

Work scheduled by: HQ

**FITZPTRK-EDIC\_\_\_\_345\_FE-1**

FWD

Tue 09/07/2021 to Sat 09/11/2021

UPDATEDby NGRID08/19/2021

(Import)

0600 Continuous 1830

CENTRAL EAST - VC

**2825 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**FITZPTRK-EDIC\_\_\_\_345\_FE-1**

FWD

Tue 09/07/2021 to Sat 09/11/2021

UPDATEDby NGRID08/19/2021

(Import)

0600 Continuous 1830

OSWEGO EXPORT

**4800 MW**

Impacts Total Transfer Capability 450 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

**MOSES\_\_-ADIRNDCK\_230\_MA2**

FWD

Tue 09/07/2021 to Sun 11/14/2021

UPDATEDby NYPA09/01/2021

(Import)

0600 Continuous 1300

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**SCH-IMO-NYISO\_LIMIT\_1400**

FWD

Tue 09/07/2021 to Sun 11/14/2021

UPDATEDby NYPA09/01/2021

(Import)

0600 Continuous 1300

SCH - OH - NY

**1700 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1950 MW

Work scheduled by: IESO

**SCH-NYISO-IMO\_LIMIT\_1200**

REV

Tue 09/07/2021 to Sun 11/14/2021

UPDATEDby NYPA09/01/2021

(Export)

0600 Continuous 1300

SCH - OH - NY

**1500 MW**

Impacts Total Transfer Capability 200 MW

TTC with All Lines In Service 1700 MW

Work scheduled by: IESO

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 7815MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**ROSETON\_-ROCKTVRN\_345\_311**

Tue 09/07/2021 to Fri 09/10/2021  
0700 Continuous 1600

**07/15/2021**

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 3415 MW  
TTC with All Lines In Service 7815 MW

**CEDARS\_-ROSEMNTA\_115\_1/11**

Tue 09/07/2021 to Fri 10/08/2021  
0700 Continuous 2300

Work scheduled by: HQ

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **95 MW 40 MW**  
Impacts Total Transfer Capability 95 MW 60 MW  
TTC with All Lines In Service 190 MW 100 MW

**DENNISON-ROSEMNTA\_115\_1/11**

Tue 09/07/2021 to Fri 10/08/2021  
0700 Continuous 2300

Work scheduled by: HQ

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **95 MW 40 MW**  
Impacts Total Transfer Capability 95 MW 60 MW  
TTC with All Lines In Service 190 MW 100 MW

**SCH-HQ\_CEDARS-NYISO\_LIMIT\_80**

Tue 09/07/2021 to Fri 10/08/2021  
0700 Continuous 2300

Work scheduled by: HQ

FWD  
(Import)  
SCH - HQ\_CEDARS **80 MW**  
Impacts Total Transfer Capability 110 MW  
TTC with All Lines In Service 190 MW

**SPRNBK\_\_345KV\_RS3 & SPRNBK\_\_345KV\_RS4**

Tue 09/07/2021 to Tue 09/07/2021  
2201 2230

Work scheduled by:

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

**SCH-NYISO-NE\_LIMIT\_1100**

Tue 09/07/2021 to Wed 09/08/2021  
2300 Daily 0700

Work scheduled by: ISONE

**UPDATED by ISONE 09/04/2021**

REV  
(Export)  
SCH - NE - NY **1300 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 1600 MW

**DUNWODIE\_345KV\_6**

Wed 09/08/2021 to Wed 09/08/2021  
0001 Continuous 0030

Work scheduled by: ConEd

**UPDATED by CONED 06/17/2021**

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Monday ,September06, 2021 to Wednesday, March 08, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## DUNWODIE\_345KV\_8

FWD

Wed 09/08/2021 to Wed 09/08/2021 UPDATED by CONED 06/17/2021

(Import)

0001 Continuous 0030

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## WOOD\_ST\_-PLSNTVLE\_345\_Y87

FWD

Wed 09/08/2021 to Wed 09/08/2021 UPDATED by CONED 06/17/2021

(Import)

0001 Continuous 0030

UPNY CONED **7260 MW**

Impacts Total Transfer Capability 555 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## PLSNTVLE-DUNWODIE\_345\_W90

FWD

Wed 09/08/2021 to Sun 09/12/2021 UPDATED by CONED 09/03/2021

(Import)

0001 Continuous 1800

UPNY CONED **4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## PIERCBRK-FIVEMILE\_345\_37

Wed 09/08/2021 to Thu 09/09/2021

0730 Continuous 1630

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NGrid

## E13THSTA-FARRAGUT\_345\_45

FWD

Thu 09/09/2021 to Thu 09/09/2021 CANCELLED by ConEd 09/01/2021

(Import)

0001 Continuous 0500

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## DUNWODIE\_345KV\_6

FWD

Sat 09/11/2021 to Sat 09/11/2021 UPDATED by CONED 09/03/2021

(Import)

0001 Continuous 1800

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## DUNWODIE\_345KV\_8

FWD

Sat 09/11/2021 to Sat 09/11/2021 UPDATED by CONED 09/03/2021

(Import)

0001 Continuous 1800

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD\_ST\_-PLSNTVLE\_345\_Y87

Sat 09/11/2021 to Sun 09/12/2021  
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 09/03/2021

UPNY CONED

Impacts Total Transfer Capability	555 MW
TTC with All Lines In Service	7815 MW

FRASER 345 FRASER SVC

Sat 09/11/2021	to	Sat 09/11/2021
0800	Continuous	1000

Work scheduled by: NYSEG

	FWD
	(Import)
CENTRAL EAST - VC	<b>2935 MW</b>
Impacts Total Transfer Capability	40 MW
TTC with All Lines In Service	2975 MW

FRASER 345 FRASER SVC

Sat 09/11/2021	to	Sat 09/11/2021
1500	Continuous	1700

Work scheduled by: NYSEG

	FWD
	(Import)
CENTRAL EAST - VC	<b>2935 MW</b>
Impacts Total Transfer Capability	40 MW
TTC with All Lines In Service	2975 MW

## FRASER 345 FRASER SVC

Sun 09/12/2021	to	Sun 09/12/2021
0800	Continuous	1000

Work scheduled by: NYSEG

	FWD
	( Import )
CENTRAL EAST - VC	<b>2935 MW</b>
Impacts Total Transfer Capability	40 MW
TTC with All Lines In Service	2975 MW

## FRASER 345 FRASER SVC

Sun 09/12/2021 to Sun 09/12/2021  
1500 Continuous 1700

Work scheduled by: NYSEG

	FWD
	(Import)
CENTRAL EAST - VC	<b>2935 MW</b>
Impacts Total Transfer Capability	40 MW
TTC with All Lines In Service	2975 MW

## DUNWODIE\_345KV\_6

```
Sun 09/12/2021      to      Sun 09/12/2021
      1730      Continuous      1800
```

Work scheduled by: ConEd

UPDATED by CONED 09/03/2021

	FWD
	( Import )
SPR/DUN-SOUTH	<b>3800 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

## DUNWODIE 345KV 8

Sun 09/12/2021 to Sun 09/12/2021  
1730 Continuous 1800

Work scheduled by: ConEd

UPDATED by CONED 09/03/2021

	FWD
	( Import )
SPR/DUN-SOUTH	<b>3800 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW



CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>W49TH_ST-E13THSTA_345_M54</b>						FWD
Mon 09/13/2021	to	Tue 09/14/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/01/2021</u>	(Import)
0001	Continuous	0200				<b>3800 MW</b>
Work scheduled by: ConEd						SPR/DUN-SOUTH Impacts Total Transfer Capability 800 MW TTC with All Lines In Service 4600 MW
<b>DOLSONAV-ROCKTVRN_345_DART44</b>						FWD
Mon 09/13/2021	to	Wed 09/15/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/25/2021</u>	(Import)
0700	Continuous	1600				<b>2720 MW</b>
Work scheduled by: CHGE						CENTRAL EAST - VC Impacts Total Transfer Capability 255 MW TTC with All Lines In Service 2975 MW
<b>PANNELL_-CLAY_____345_2</b>						FWD
Mon 09/13/2021	to	Fri 09/17/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/12/2021</u>	(Import)
0700	Continuous	1530				<b>1300 MW</b>
Work scheduled by: NYPA						WEST CENTRAL Impacts Total Transfer Capability 950 MW TTC with All Lines In Service 2250 MW
<b>LEEDS____345_LEEDS SVC</b>						FWD
Mon 09/13/2021	to	Fri 09/17/2021				(Import)
0800	Continuous	1100				<b>2950 MW</b>
Work scheduled by: NGrid						CENTRAL EAST - VC Impacts Total Transfer Capability 25 MW TTC with All Lines In Service 2975 MW
<b>W49TH_ST_345KV_6</b>						FWD
Wed 09/15/2021	to	Wed 10/13/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>08/18/2021</u>	(Import)
0001	Continuous	0030				<b>300 MW</b>
Work scheduled by: ConEd						SCH - PJM_HTP Impacts Total Transfer Capability 360 MW TTC with All Lines In Service 660 MW
<b>E13THSTA-FARRAGUT_345_46</b>						FWD
Wed 09/15/2021	to	Wed 10/13/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>08/18/2021</u>	(Import)
0001	Continuous	2300				<b>3800 MW</b>
Work scheduled by: ConEd						SPR/DUN-SOUTH Impacts Total Transfer Capability 800 MW TTC with All Lines In Service 4600 MW
<b>W49TH_ST-E13THSTA_345_M55</b>						FWD
Wed 09/15/2021	to	Wed 10/13/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>08/18/2021</u>	(Import)
0001	Continuous	2300				<b>3800 MW</b>
Work scheduled by: ConEd						SPR/DUN-SOUTH Impacts Total Transfer Capability 800 MW TTC with All Lines In Service 4600 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PORTER\_\_-ROTTRDAM\_230\_30**

FWD

Wed 09/15/2021 to Tue 11/30/2021 UPDATED by NGRID 08/31/2021

(Import)

0700 Continuous 1730

Work scheduled by: NGrid

CENTRAL EAST - VC **2805 MW**  
 Impacts Total Transfer Capability 170 MW  
 TTC with All Lines In Service 2975 MW

**EDIC\_\_\_\_-N.SCTLND\_345\_14**

FWD

Thu 09/16/2021 to Sun 11/14/2021 UPDATED by NGRID 08/31/2021

(Import)

0600 Continuous 1830

Work scheduled by: NGrid

CENTRAL EAST - VC **1670 MW**  
 Impacts Total Transfer Capability 1305 MW  
 TTC with All Lines In Service 2975 MW

**EDIC\_\_\_\_-N.SCTLND\_345\_14 & PORTER\_\_-ROTTRDAM\_230\_30**

FWD

Thu 09/16/2021 to Sun 11/14/2021

(Import)

0600 1830

Work scheduled by:

CENTRAL EAST - VC **1500 MW**  
 Impacts Total Transfer Capability 1475 MW  
 TTC with All Lines In Service 2975 MW

**HURLYAVE-ROSETON\_\_345\_303**

FWD

Thu 09/16/2021 to Fri 09/24/2021 UPDATED by CHGE 08/31/2021

(Import)

0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 3715 MW  
 TTC with All Lines In Service 7815 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

FWD

Fri 09/17/2021 to Sat 09/18/2021

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

**RAMAPO\_\_-BUCHAN\_N\_345\_Y94**

FWD

Fri 09/17/2021 to Sat 09/18/2021

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED **7580 MW**  
 Impacts Total Transfer Capability 235 MW  
 TTC with All Lines In Service 7815 MW

**DUNWODIE\_345KV\_3**

FWD

Sat 09/18/2021 to Sat 09/18/2021 UPDATED by CONED 09/02/2021

(Import)

0201 Continuous 0231

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,September06, 2021 to Wednesday, March 08, 2023

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 7815MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLE-DUNWODIE\_345\_W89**

FWD

Sat 09/18/2021 to Tue 09/28/2021 UPDATED by CONED 09/02/2021

(Import)

0201 Continuous 1000

UPNY CONED

**4000 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

**HOMRC\_NY-MAINS\_NY\_345\_47**Sat 09/18/2021 to Fri 11/05/2021 UPDATED by PJM 07/23/2021

0800 Continuous 1600

SCH - PJ - NY

Work scheduled by: PJM

Impacts Total Transfer Capability

TTC with All Lines In Service

**PANNELL\_-CLAY\_\_\_\_345\_1**

FWD

Mon 09/20/2021 to Fri 09/24/2021 UPDATED by NYPA 08/25/2021

(Import)

0700 Continuous 1530

WEST CENTRAL

**1300 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

**PIERCBRK-FIVEMILE\_345\_37**

Wed 09/22/2021 to Wed 09/22/2021

0730 Continuous 1100

SCH - PJ - NY

Work scheduled by: PJM

Impacts Total Transfer Capability

TTC with All Lines In Service

**EFISHKIL-WOOD\_ST\_\_345\_F38**

FWD

Sat 09/25/2021 to Tue 09/28/2021 UPDATED by CONED 09/02/2021

(Import)

0001 Continuous 1000

UPNY CONED

**4000 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

**WOOD\_ST\_-PLSNTVLE\_345\_Y86**

FWD

Sat 09/25/2021 to Tue 09/28/2021 UPDATED by CONED 09/02/2021

(Import)

0001 Continuous 1000

UPNY CONED

**7210 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 605 MW

TTC with All Lines In Service 7815 MW

**SCH-NYISO-NE\_LIMIT\_1000**

REV

Sat 09/25/2021 to Sun 10/24/2021

(Export)

0700 Continuous 1600

SCH - NE - NY

**1200 MW**

Work scheduled by: ISONE

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 1600 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CHAT\_DC\_GC1**

Sun 09/26/2021 to Sun 09/26/2021  
0001 Continuous 0200  
Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC1**

Sun 09/26/2021 to Sun 09/26/2021  
0001 Continuous 0200  
Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

**CHAT\_DC\_GC1 & CHAT\_DC\_GC2**

Sun 09/26/2021 to Sun 09/26/2021  
0001 0200  
Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **2550 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC1 & CHAT\_DC\_GC2**

Sun 09/26/2021 to Sun 09/26/2021  
0001 0200  
Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY **1370 MW 0 MW**  
Impacts Total Transfer Capability 130 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

**CHAT\_DC\_GC2**

Sun 09/26/2021 to Sun 09/26/2021  
0001 Continuous 0200  
Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC2**

Sun 09/26/2021 to Sun 09/26/2021  
0001 Continuous 0200  
Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

**SCH-HQ-NYISO\_LIMIT\_1150**

Sun 09/26/2021 to Sun 09/26/2021  
0001 Continuous 0200  
Work scheduled by: HQ

FWD  
(Import)  
SCH - HQ - NY **1150 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 1500 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_-KINTIGH\_\_345\_Ns1-38**

FWD

Mon 09/27/2021 to Fri 10/01/2021

EXTENDEDby NYPA08/20/2021

(Import)

0500 Continuous 1700

DYSINGER EAST

**1400 MW**

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**FIVEMILE-STOLLERD\_345\_29**

Mon 09/27/2021 to Fri 10/08/2021

0800 Continuous 1400

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYSEG

**LEEDS\_-HURLYAVE\_345\_301**

FWD

Mon 09/27/2021 to Fri 10/29/2021

0800 Continuous 1600

(Import)

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: CHGE

**DUNWODIE\_345KV\_3**

FWD

Tue 09/28/2021 to Tue 09/28/2021

UPDATEDby CONED09/02/2021

(Import)

0930 Continuous 1000

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**DUNWODIE\_345KV\_4**

FWD

Tue 09/28/2021 to Tue 09/28/2021

UPDATEDby CONED09/02/2021

(Import)

0930 Continuous 1000

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**EFISHKIL-WOOD\_ST\_\_345\_F38**

FWD

Wed 09/29/2021 to Wed 09/29/2021

UPDATEDby CONED09/02/2021

(Import)

0130 Continuous 0200

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**PLSNTVLE-DUNWODIE\_345\_W89**

FWD

Wed 09/29/2021 to Wed 09/29/2021

UPDATEDby CONED09/02/2021

(Import)

0130 Continuous 0200

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD_ST_-PLSNTVLE_345_Y86						FWD
Wed 09/29/2021	to	Wed 09/29/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/02/2021</u>	(Import)
0130	Continuous	0200				<b>7210 MW</b>
Work scheduled by: ConEd						UPNY CONED
						Impacts Total Transfer Capability 605 MW
						TTC with All Lines In Service 7815 MW
LADENTWN-BUCHAN_S_345_Y88						FWD
Thu 09/30/2021	to	Thu 09/30/2021	<u>UPDATED</u>	<u>by ORU</u>	<u>08/13/2021</u>	(Import)
0800	Continuous	1600				<b>7560 MW</b>
Work scheduled by: ORU						UPNY CONED
						Impacts Total Transfer Capability 255 MW
						TTC with All Lines In Service 7815 MW
NIAGARA_-STA_255__345_NH2						FWD
Sat 10/02/2021	to	Sun 10/17/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/20/2021</u>	(Import)
0500	Continuous	1900				<b>1400 MW</b>
Work scheduled by: NYPA						DYSINGER EAST
						Impacts Total Transfer Capability 1750 MW
						TTC with All Lines In Service 3150 MW
CLAY____-EDIC____345_2-15						FWD
Mon 10/04/2021	to	Sat 10/30/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/16/2021</u>	(Import)
0700	Continuous	1730				<b>4850 MW</b>
Work scheduled by: NYPA						OSWEGO EXPORT
						Impacts Total Transfer Capability 400 MW
						TTC with All Lines In Service 5250 MW
PLSNTVLE-DUNWODIE_345_W89						FWD
Tue 10/05/2021	to	Tue 10/05/2021				(Import)
0130	Continuous	0200				<b>4000 MW</b>
Work scheduled by: ConEd						UPNY CONED
						Impacts Total Transfer Capability 3815 MW
						TTC with All Lines In Service 7815 MW
W49TH_ST_345KV_6						FWD
Wed 10/13/2021	to	Wed 10/13/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>08/18/2021</u>	(Import)
2230	Continuous	2300				<b>300 MW</b>
Work scheduled by: ConEd						SCH - PJM_HTP
						Impacts Total Transfer Capability 360 MW
						TTC with All Lines In Service 660 MW
MILLWOOD-EASTVIEW_345_W85						FWD
Thu 10/14/2021	to	Thu 10/14/2021				(Import)
0001	Continuous	0030				<b>7550 MW</b>
Work scheduled by: ConEd						UPNY CONED
						Impacts Total Transfer Capability 265 MW
						TTC with All Lines In Service 7815 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE-MOTTHAVN_345_72						FWD
Thu 10/14/2021	to	Sat 10/16/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>08/04/2021</u>	(Import)
0001	Continuous	0100				3800 MW
Work scheduled by: ConEd						800 MW
SPR/DUN-SOUTH						4600 MW
Impacts Total Transfer Capability						
TTC with All Lines In Service						
DUNWODIE_345KV_8						FWD
Thu 10/14/2021	to	Sat 10/16/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>08/04/2021</u>	(Import)
0001	Continuous	0100				3800 MW
Work scheduled by: ConEd						800 MW
SPR/DUN-SOUTH						4600 MW
Impacts Total Transfer Capability						
TTC with All Lines In Service						
EASTVIEW-SPRNBK__345_W78						FWD
Thu 10/14/2021	to	Sat 10/16/2021				(Import)
0001	Continuous	0100				4350 MW
Work scheduled by: ConEd						3465 MW
UPNY CONED						7815 MW
Impacts Total Transfer Capability						
TTC with All Lines In Service						
W49TH_ST_345KV_7						FWD
Thu 10/14/2021	to	Sat 11/20/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/20/2021</u>	(Import)
0001	Continuous	0030				300 MW
Work scheduled by: ConEd						360 MW
SCH - PJM_HTP						660 MW
Impacts Total Transfer Capability						
TTC with All Lines In Service						
DUNWODIE_345KV_5						FWD
Thu 10/14/2021	to	Sun 11/28/2021				(Import)
0001	Continuous	0200				3800 MW
Work scheduled by: ConEd						800 MW
SPR/DUN-SOUTH						4600 MW
Impacts Total Transfer Capability						
TTC with All Lines In Service						
DUNWODIE_345KV_7						FWD
Thu 10/14/2021	to	Sun 11/28/2021				(Import)
0001	Continuous	0200				3800 MW
Work scheduled by: ConEd						800 MW
SPR/DUN-SOUTH						4600 MW
Impacts Total Transfer Capability						
TTC with All Lines In Service						
SPRNBK_-DUNWODIE_345_W75						FWD
Thu 10/14/2021	to	Sun 11/28/2021				(Import)
0001	Continuous	0200				3800 MW
Work scheduled by: ConEd						800 MW
SPR/DUN-SOUTH						4600 MW
Impacts Total Transfer Capability						
TTC with All Lines In Service						

**NYISO TRANSFER LIMITATIONS**

Monday ,September06, 2021 to Wednesday, March 08, 2023

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 7815MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SPRNBK\_\_345KV\_RNS3**

FWD

Thu 10/14/2021 to Sun 11/28/2021

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

Work scheduled by: ConEd

TTC with All Lines In Service 4600 MW

**W49TH\_ST\_345KV\_5**

FWD

Thu 10/14/2021 to Sun 12/05/2021

(Import)

0001 Continuous 0300

**UPDATED by CONED 06/20/2021**

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

Work scheduled by: ConEd

TTC with All Lines In Service 660 MW

**SPRNBK\_\_345KV\_RS3 & SPRNBK\_\_345KV\_RS4**

FWD

Sat 10/16/2021 to Mon 10/18/2021

(Import)

0001 0200

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

Work scheduled by:

TTC with All Lines In Service 4600 MW

**MILLWOOD-EASTVIEW\_345\_W85**

FWD

Sat 10/16/2021 to Sat 10/16/2021

(Import)

0030 Continuous 0100

UPNY CONED

**7550 MW**

Impacts Total Transfer Capability 265 MW

Work scheduled by: ConEd

TTC with All Lines In Service 7815 MW

**DUNWODIE-MOTTHAVN\_345\_71**

FWD

Sat 10/16/2021 to Mon 10/18/2021

(Import)

0101 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

Work scheduled by: ConEd

TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_3**

FWD

Sat 10/16/2021 to Mon 10/18/2021

(Import)

0101 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

Work scheduled by: ConEd

TTC with All Lines In Service 4600 MW

**NIAGARA\_-KINTIGH\_345\_NS1-38**

FWD

Mon 10/18/2021 to Sat 12/04/2021

(Import)

0500 Continuous 1900

**UPDATED by NYPA 08/20/2021**

DYSINGER EAST

**1400 MW**

Impacts Total Transfer Capability 1750 MW

Work scheduled by: NYPA

TTC with All Lines In Service 3150 MW



**NYISO TRANSFER LIMITATIONS**

Monday ,September06, 2021 to Wednesday, March 08, 2023

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 7815MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BUCHAN\_N-EASTVIEW\_345\_W93**

FWD

Wed 10/20/2021 to Thu 10/21/2021

(Import)

0001 Continuous 0200

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

Work scheduled by: ConEd

TTC with All Lines In Service 7815 MW

**RAMAPO\_\_-BUCHAN\_N\_345\_Y94**

FWD

Wed 10/20/2021 to Thu 10/21/2021

(Import)

0001 Continuous 0200

UPNY CONED

**7580 MW**

Impacts Total Transfer Capability 235 MW

Work scheduled by: ConEd

TTC with All Lines In Service 7815 MW

**SCH-NE-NYISO\_LIMIT\_900**

FWD

Thu 10/21/2021 to Fri 10/29/2021

(Import)

1700 Continuous 1600

SCH - NE - NY

**1100 MW**

Impacts Total Transfer Capability 300 MW

Work scheduled by: ISONE

TTC with All Lines In Service 1400 MW

**SHOR\_NPX-SHOREHAM\_138\_CSC**

FWD

REV

Tue 10/26/2021 to Sun 11/21/2021

(Import) (Export)

0600 Continuous 1600

SCH - NPX\_CSC

**0 MW****0 MW**

Impacts Total Transfer Capability 330 MW 330 MW

Work scheduled by: ISONE

TTC with All Lines In Service 330 MW 330 MW

**BUCHAN\_S-MILLWOOD\_345\_W97**

FWD

Mon 11/01/2021 to Fri 12/10/2021

(Import)

0001 Continuous 0200

**UPDATED****by CE****09/02/2021**

UPNY CONED

**7680 MW**

Impacts Total Transfer Capability 135 MW

Work scheduled by: ConEd

TTC with All Lines In Service 7815 MW

**SCH-IMO-NYISO\_LIMIT\_1750**

FWD

Mon 11/01/2021 to Fri 12/31/2021

(Import)

0001 Continuous 2359

**UPDATED****by IESO****05/03/2019**

SCH - OH - NY

**2050 MW**

Impacts Total Transfer Capability 250 MW

Work scheduled by: IESO

TTC with All Lines In Service 2300 MW

**SCH-NYISO-IMO\_LIMIT\_1600**

REV

Mon 11/01/2021 to Fri 12/31/2021

(Export)

0001 Continuous 2359

**UPDATED****by IESO****05/03/2019**

SCH - OH - NY

**1900 MW**

Impacts Total Transfer Capability 100 MW

Work scheduled by: IESO

TTC with All Lines In Service 2000 MW





CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1						FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>	(Import)	(Export)
0100	Continuous	1859			SCH - HQ - NY	475 MW	1000 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW 0 MW
						TTC with All Lines In Service	1500 MW 1000 MW
MASSENA -MARCY 765_MSU1						FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>	(Import)	
0100	Continuous	1859			SCH - HQ_CEDARS	90 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	109 MW
						TTC with All Lines In Service	199 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040						FWD	
Mon 11/15/2021	to	Tue 11/30/2021			MOSES SOUTH	(Import)	
0100		1859			Impacts Total Transfer Capability	500 MW	
Work scheduled by:						TTC with All Lines In Service	2650 MW 3150 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2						FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021			SCH - HQ - NY	(Import)	(Export)
0100		1859			Impacts Total Transfer Capability	850 MW	0 MW
Work scheduled by:						TTC with All Lines In Service	650 MW 1000 MW 1500 MW 1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2						FWD	
Mon 11/15/2021	to	Tue 11/30/2021			SCH - HQ_CEDARS	(Import)	
0100		1859			Impacts Total Transfer Capability	90 MW	
Work scheduled by:						TTC with All Lines In Service	109 MW 199 MW
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1						FWD	
Mon 11/15/2021	to	Tue 11/30/2021			SCH - HQ_CEDARS	(Import)	
0100		1859			Impacts Total Transfer Capability	90 MW	
Work scheduled by:						TTC with All Lines In Service	109 MW 199 MW
STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2						FWD	
Mon 11/15/2021	to	Tue 11/30/2021			SCH - HQ_CEDARS	(Import)	
0100		1859			Impacts Total Transfer Capability	90 MW	
Work scheduled by:						TTC with All Lines In Service	109 MW 199 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,September06, 2021 to Wednesday, March 08, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**S.RIPLEY-DUNKIRK\_\_230\_68**

Tue 11/16/2021 to Sat 12/04/2021

0700 Continuous 1730

Work scheduled by: NGrid

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**MILLWOOD-EASTVIEW\_345\_W85**

Fri 11/19/2021 to Fri 11/19/2021

0001 Continuous 0030

Work scheduled by: ConEd

UPDATEDby CE06/28/2021

UPNY CONED

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

FWD

(Import)

**7550 MW****EASTVIEW-SPRNBK\_\_345\_W78**

Fri 11/19/2021 to Wed 11/24/2021

0001 Continuous 0200

Work scheduled by: ConEd

UPDATEDby CE06/28/2021

UPNY CONED

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

FWD

(Import)

**4350 MW****DUNWODIE-MOTTHAVN\_345\_72**

Sat 11/20/2021 to Wed 11/24/2021

0001 Continuous 0200

Work scheduled by: ConEd

UPDATEDby CONED06/07/2021

SPR/DUN-SOUTH

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

FWD

(Import)

**3800 MW****DUNWODIE\_345KV\_8**

Sat 11/20/2021 to Wed 11/24/2021

0001 Continuous 0200

Work scheduled by: ConEd

UPDATEDby CONED06/07/2021

SPR/DUN-SOUTH

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

FWD

(Import)

**3800 MW****SPRNBK\_\_345KV\_RS3 & SPRNBK\_\_345KV\_RS4**

Wed 11/24/2021 to Sun 11/28/2021

0001 0200

Work scheduled by:

SPR/DUN-SOUTH

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

FWD

(Import)

**3800 MW****MILLWOOD-EASTVIEW\_345\_W85**

Wed 11/24/2021 to Wed 11/24/2021

0130 Continuous 0200

Work scheduled by: ConEd

UPDATEDby CE06/28/2021

UPNY CONED

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

FWD

(Import)

**7550 MW**

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE-MOTHAVN_345_71					FWD	
Wed 11/24/2021	to	Sun 11/28/2021			(Import)	
0201	Continuous	0100			SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_3					FWD	
Wed 11/24/2021	to	Sun 11/28/2021			(Import)	
0201	Continuous	0100			SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
SPRNBK__345KV_RNS4					FWD	
Sun 11/28/2021	to	Sun 11/28/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/20/2021</u>	(Import)
0300	Continuous	0330			SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
SPRNBK_-W49TH_ST_345_M52					FWD	
Sun 11/28/2021	to	Wed 12/01/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/20/2021</u>	(Import)
0300	Continuous	0200			SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
NIAGARA_-PACKARD__230_61					FWD	REV
Tue 11/30/2021	to	Mon 12/06/2021			(Import) (Export)	
0615	Continuous	1900			SCH - OH - NY	1200 MW 1850 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 7815MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_\_345KV\_CSC**

FWD

Mon 12/06/2021 to Fri 12/17/2021

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

**2925 MW**

Impacts Total Transfer Capability 50 MW

Work scheduled by: NYPA

TTC with All Lines In Service 2975 MW

**BUCHAN\_S-MILLWOOD\_345\_W98**

FWD

Tue 12/07/2021 to Fri 12/10/2021

(Import)

UPDATEDby CE09/02/2021

0201 Continuous 0200

UPNY CONED

**7680 MW**

Impacts Total Transfer Capability 135 MW

Work scheduled by: ConEd

TTC with All Lines In Service 7815 MW

**LADENTWN-BUCHAN\_S\_345\_Y88**

FWD

Tue 12/07/2021 to Fri 12/10/2021

(Import)

UPDATEDby CE09/02/2021

0201 Continuous 0200

UPNY CONED

**7560 MW**

Impacts Total Transfer Capability 255 MW

Work scheduled by: ConEd

TTC with All Lines In Service 7815 MW

**MILLWOOD\_345KV\_18**

FWD

Tue 12/07/2021 to Fri 12/10/2021

(Import)

UPDATEDby CE09/02/2021

0201 Continuous 0200

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

Work scheduled by: ConEd

TTC with All Lines In Service 7815 MW

**EASTVIEW-SPRNBK\_\_345\_W64**

FWD

Sun 12/12/2021 to Tue 12/14/2021

(Import)

UPDATEDby CE07/21/2021

2000 Continuous 0200

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

Work scheduled by: ConEd

TTC with All Lines In Service 7815 MW

**MILLWOOD-EASTVIEW\_345\_W99**

FWD

Sun 12/12/2021 to Tue 12/14/2021

(Import)

UPDATEDby CE07/21/2021

2000 Continuous 0200

UPNY CONED

**7550 MW**

Impacts Total Transfer Capability 265 MW

Work scheduled by: ConEd

TTC with All Lines In Service 7815 MW

**SPRNBK\_\_345KV\_RNS5**

FWD

Sun 12/12/2021 to Tue 12/14/2021

(Import)

UPDATEDby CE07/21/2021

2000 Continuous 0200

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

Work scheduled by: ConEd

TTC with All Lines In Service 4600 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,September06, 2021 to Wednesday, March 08, 2023

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 7815MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**FRASER\_\_\_345\_FRASER SVC**

FWD

Tue 01/04/2022 to Mon 02/28/2022 UPDATED by NYPA 05/25/2021

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

**2935 MW**

Impacts Total Transfer Capability 40 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**NIAGARA\_-PACKARD\_\_230\_61**

FWD

REV

Mon 01/17/2022 to Fri 01/21/2022

(Import) (Export)

0615 Continuous 1900

SCH - OH - NY

**1200 MW 1850 MW**

Impacts Total Transfer Capability 1100 MW 150 MW

TTC with All Lines In Service 2300 MW 2000 MW

Work scheduled by: NGrid

**NIAGARA\_-STA\_255\_\_345\_NH2**

FWD

Fri 01/21/2022 to Fri 03/04/2022 UPDATED by NYPA 08/20/2021

(Import)

0500 Continuous 1900

DYSINGER EAST

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**FRASANNX-COOPERS\_\_345\_UCC2-41**

FWD

Mon 02/07/2022 to Sat 02/12/2022

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 19****MARCY\_\_\_-FRASANNX\_345\_UCC2-41**

FWD

Mon 02/07/2022 to Sat 02/12/2022

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 19****ATHENS\_\_\_-PLSNTVLY\_345\_91**

FWD

Sat 02/12/2022 to Wed 02/16/2022 UPDATED by NGRID 05/07/2021

(Import)

0600 Continuous 1900

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

FWD

Thu 02/17/2022 to Sat 02/19/2022

(Import)

0001 2200

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by:





CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 7815MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PORTER\_\_-ROTTRDAM\_230\_31**

Tue 03/01/2022 to Tue 12/31/2030  
0600 Continuous 2359

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC **2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

**FRASANNX-COOPERS\_\_345\_UCC2-41**

Tue 03/01/2022 to Wed 04/20/2022  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD

(Import)

CENTRAL EAST - VC **2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

**MARCY\_\_-FRASANNX\_345\_UCC2-41**

Tue 03/01/2022 to Wed 04/20/2022  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD

(Import)

CENTRAL EAST - VC **2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

**GOETHALS\_345KV\_5**

Sat 03/05/2022 to Mon 04/04/2022  
0001 Continuous 0200

Work scheduled by: ConEd

**UPDATED****by CONED 03/26/2021**

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

**LINDEN\_\_-GOETHALS\_230\_A2253**

Sat 03/05/2022 to Mon 04/04/2022  
0001 Continuous 0200

Work scheduled by: ConEd

**UPDATED****by CONED 03/26/2021**

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**INDPDNCE-SCRIBA\_\_345\_25**

Thu 03/10/2022 to Wed 03/16/2022  
0800 Continuous 1800

Work scheduled by: NGrid

FWD

(Import)

OSWEGO EXPORT **5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Thu 03/17/2022 to Sun 03/20/2022  
0100 2200

Work scheduled by:

FWD

(Import)

UPNY CONED **3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 7815MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLY-WOOD\_ST\_\_345\_F30**

FWD

Mon 03/21/2022 to Wed 03/23/2022

(Import)

0001 Continuous 2200

Work scheduled by: ConEd

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

**EASTVIEW-SPRNBK\_\_345\_W64**

FWD

Mon 03/21/2022 to Mon 03/21/2022

(Import)

UPDATEDby CONED 08/31/2021

0130 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

**SPRNBK\_\_345KV\_RNS5**

FWD

Mon 03/21/2022 to Mon 03/21/2022

(Import)

UPDATEDby CONED 08/31/2021

0130 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

FWD

Sat 03/26/2022 to Mon 03/28/2022

(Import)

0001 2200

Work scheduled by:

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

**ATHENS\_\_-PLSNTVLY\_345\_91**

FWD

Sat 03/26/2022 to Sun 05/01/2022

(Import)

0001 Continuous 2200

Work scheduled by: ConEd

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

**PLSNTVLY\_345KV\_RNS4**

FWD

Sat 03/26/2022 to Sun 05/01/2022

(Import)

0001 Continuous 2200

Work scheduled by: ConEd

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

**PLSNTVLY-WOOD\_ST\_\_345\_F31**

FWD

Tue 03/29/2022 to Wed 03/30/2022

(Import)

0001 Continuous 2200

Work scheduled by: ConEd

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW



CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 7815MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PANNELL\_-CLAY\_\_\_\_\_345\_1**

Mon 04/11/2022 to Fri 04/15/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**PORTER\_-ROTTDAM\_230\_30**

Wed 04/13/2022 to Tue 12/31/2030  
0600 Continuous 2359

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2805 MW**  
Impacts Total Transfer Capability 170 MW  
TTC with All Lines In Service 2975 MW

**PANNELL\_-CLAY\_\_\_\_\_345\_2**

Mon 04/18/2022 to Fri 04/22/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**EDIC\_-FRASER\_\_\_\_\_345\_EF24-40**

Thu 04/21/2022 to Tue 06/14/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Sat 04/23/2022 to Tue 04/26/2022  
0001 2200

Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**EASTVIEW-SPRNBK\_\_\_\_\_345\_W64**

Tue 04/26/2022 to Tue 04/26/2022 **UPDATED by CONED 08/31/2021**  
2130 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

**SPRNBK\_\_\_\_\_345KV\_RNS5**

Tue 04/26/2022 to Tue 04/26/2022 **UPDATED by CONED 08/31/2021**  
2130 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLY-WOOD\_ST\_\_345\_F31**

FWD

Wed 04/27/2022 to Fri 04/29/2022

(Import)

0001 Continuous 2200

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**NIAGARA\_\_345\_230\_AT4**

REV

Fri 04/29/2022 to Fri 04/29/2022

(Export)

0500 Continuous 1700

SCH - OH - NY

**1750 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 2000 MW

Work scheduled by: NYPA

**BUCHAN\_N-EASTVIEW\_345\_W93**

FWD

Mon 05/02/2022 to Mon 05/02/2022

(Import)

0001 Continuous 0030

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**EASTVIEW-SPRNBK\_\_345\_W79**

FWD

Mon 05/02/2022 to Thu 05/05/2022

(Import)

0001 Continuous 0200

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**ROCHESTR-PANNELL\_\_345\_RP2**

FWD

Mon 05/02/2022 to Fri 05/06/2022

(Import)

0500 Continuous 1700

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**N.SCTLND-ALPS\_\_\_\_345\_2**

FWD

Mon 05/02/2022 to Mon 05/09/2022

(Import)

0600 Daily 1800

SCH - NE - NY

**750 MW**

Impacts Total Transfer Capability 650 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: NGrid

**N.SCTLND-ALPS\_\_\_\_345\_2**

FWD

REV

Mon 05/02/2022 to Mon 05/09/2022

(Import) (Export)

0600 Daily 1800

SCH - NPX\_1385

**100 MW****100 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 200 MW

Work scheduled by: NGrid

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BUCHAN\_N-EASTVIEW\_345\_W93**

Thu 05/05/2022 to Thu 05/05/2022  
0130 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

**SPRNBRK\_-TREMONT\_345\_X28**

Fri 05/06/2022 to Mon 05/09/2022  
0201 Continuous 1800

Work scheduled by: ConEd

UPDATED by CONED 08/19/2021

FWD  
(Import)  
SPR/DUN-SOUTH **4200 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

**FRASER\_345\_FRASER SVC**

Mon 05/09/2022 to Fri 05/13/2022  
0800 Continuous 1700

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2935 MW**  
Impacts Total Transfer Capability 40 MW  
TTC with All Lines In Service 2975 MW

**HOMRC\_NY-MAINS\_NY\_345\_47**

Fri 05/20/2022 to Fri 05/27/2022  
0800 Continuous 1600

Work scheduled by: PJM

UPDATED by PJM 11/19/2020

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**HOMR\_NYW-PIERC\_NY\_345\_48**

Fri 05/20/2022 to Fri 05/27/2022  
0800 Continuous 1600

Work scheduled by: PJM

UPDATED by PJM 11/19/2020

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**NIAGARA\_-PACKARD\_230\_62**

Sat 06/18/2022 to Sat 06/18/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **700 MW 1550 MW**  
Impacts Total Transfer Capability 1250 MW 150 MW  
TTC with All Lines In Service 1950 MW 1700 MW

**NIAGARA\_345\_230\_AT4**

Tue 06/28/2022 to Wed 06/29/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1900 MW 1400 MW**  
Impacts Total Transfer Capability 50 MW 300 MW  
TTC with All Lines In Service 1950 MW 1700 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 7815MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BECK\_\_\_\_-NIAGARA\_\_230\_PA27**

Tue 07/05/2022 to Sat 07/09/2022  
0500 Continuous 2100

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**ROCHESTR-PANNELL\_\_345\_RP1**

Mon 07/25/2022 to Fri 07/29/2022  
0500 Continuous 2100

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

**PANNELL\_-CLAY\_\_\_\_345\_1**

Mon 09/12/2022 to Fri 09/16/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

**FRASER\_-GILBOA\_\_345\_GF5-35**

Mon 09/12/2022 to Sun 09/18/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

**SPRNBK\_\_345KV\_RNS5**

Mon 09/19/2022 to Mon 09/19/2022  
0001 Continuous 0030

Work scheduled by: ConEd

**UPDATED**

**by CONED 09/17/2020**

FWD

(Import)

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

**SPRNBK\_-W49TH\_ST\_345\_M51**

Mon 09/19/2022 to Wed 09/21/2022  
0001 Continuous 2200

Work scheduled by: ConEd

**UPDATED**

**by CONED 09/17/2020**

FWD

(Import)

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

**PANNELL\_-CLAY\_\_\_\_345\_2**

Mon 09/19/2022 to Fri 09/23/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW



**NYISO TRANSFER LIMITATIONS**

Monday ,September06, 2021 to Wednesday, March 08, 2023

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 7815MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK\_\_345KV\_RNS5

FWD

Wed 09/21/2022 to Wed 09/21/2022 UPDATED by CONED 09/17/2020

(Import)

2130 Continuous 2200

SPR/DUN-SOUTH 3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

SPRNBRK\_-W49TH\_ST\_345\_M51

FWD

Sat 10/01/2022 to Mon 10/17/2022 UPDATED by CONED 08/01/2020

(Import)

0001 Continuous 0300

SPR/DUN-SOUTH 3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

SPRNBRK\_\_345KV\_RNS5

FWD

Sat 10/01/2022 to Mon 10/17/2022 UPDATED by CONED 08/01/2020

(Import)

0001 Continuous 0300

SPR/DUN-SOUTH 3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd