

# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Tue 11/30/2021 EXT FORCE by CONED 05/26/2021

0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJ - NY **2050 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 2250 MW

## HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Tue 11/30/2021

0001 2359

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2000 MW 1150 MW**  
Impacts Total Transfer Capability 250 MW 100 MW  
TTC with All Lines In Service 2250 MW 1250 MW

## MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Tue 11/30/2021 EXT FORCE by CONED 05/26/2021

0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJ - NY **2050 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 2250 MW

## STLAWRNC-MOSES\_230\_L33P

Mon 04/30/2018 to Mon 10/31/2022 EXT FORCE by IESO 07/08/2021

0456 Continuous 1600

Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## NEWBRIDGE\_345\_138\_BK\_1

Wed 09/02/2020 to Tue 02/01/2022 EXT FORCE by LI 01/12/2021

1807 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

## SCH-IMO-NYISO\_LIMIT\_1600

Sat 05/01/2021 to Sun 10/31/2021 UPDATED by IESO 05/03/2019

0001 Continuous 2359

Work scheduled by: IESO

FWD  
(Import)  
SCH - OH - NY **1900 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 1950 MW

## DUNWODIE-SHORE\_RD\_345\_Y50

Sat 07/17/2021 to Sun 09/19/2021 EXT FORCE by CE 09/12/2021

1053 Continuous 0200

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **800 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHORE_RD_345_138_BK 1						FWD
Sat 07/17/2021	to	Sun 09/19/2021	<u>EXT FORCE</u>	<u>by CE</u>	<u>09/12/2021</u>	(Import)
1053	Continuous	0200				CONED - LIPA 1350 MW
Work scheduled by: LI						Impacts Total Transfer Capability 150 MW
						TTC with All Lines In Service 1500 MW
SHORE_RD_345_138_BK 2						FWD
Sat 07/17/2021	to	Sun 09/19/2021	<u>EXT FORCE</u>	<u>by CE</u>	<u>09/12/2021</u>	(Import)
1053	Continuous	0200				CONED - LIPA 1350 MW
Work scheduled by: LI						Impacts Total Transfer Capability 150 MW
						TTC with All Lines In Service 1500 MW
EGRDNCTY_345_138_AT1						FWD
Fri 08/06/2021	to	Fri 10/15/2021	<u>EXT FORCE</u>	<u>by LI</u>	<u>08/11/2021</u>	(Import)
1939	Continuous	2359				CONED - LIPA 1250 MW
Work scheduled by: LI						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 1500 MW
EGRDNCTY_345_138_AT2						FWD
Fri 08/06/2021	to	Fri 10/15/2021	<u>EXT FORCE</u>	<u>by LI</u>	<u>08/11/2021</u>	(Import)
1939	Continuous	2359				CONED - LIPA 1250 MW
Work scheduled by: LI						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 1500 MW
SPRNBK_-EGRDNCTR_345_Y49 & DUNWODIE-SHORE_RD_345_Y50						FWD
Fri 08/06/2021	to	Sun 09/19/2021				(Import)
1953		0200				CONED - LIPA 25 MW
Work scheduled by:						Impacts Total Transfer Capability 1475 MW
						TTC with All Lines In Service 1500 MW
SPRNBK_-EGRDNCTR_345_Y49						FWD
Fri 08/06/2021	to	Fri 10/15/2021	<u>EXT FORCE</u>	<u>by LI</u>	<u>08/11/2021</u>	(Import)
1953	Continuous	2359				CONED - LIPA 775 MW
Work scheduled by: LI						Impacts Total Transfer Capability 725 MW
						TTC with All Lines In Service 1500 MW
NIAGARA_-KINTIGH__345_NS1-38						FWD
Tue 09/07/2021	to	Wed 09/15/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/02/2021</u>	(Import)
0500	Continuous	2300				DYSINGER EAST 1400 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1750 MW
						TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NYISO-HQ\_CEDARS\_LIMIT\_0

Tue 09/07/2021 to Thu 09/30/2021  
0500 Continuous 1900

Work scheduled by: HQ

REV  
(Export)  
**0 MW**  
SCH - HQ\_CEDARS  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 100 MW

## FITZPTRK-EDIC\_\_\_\_345\_FE-1

Tue 09/07/2021 to Sat 09/11/2021  
0600 Continuous 1830

Work scheduled by: NGrid

UPDATED by NGRID 08/19/2021

FWD  
(Import)  
CENTRAL EAST - VC **2825 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 2975 MW

## FITZPTRK-EDIC\_\_\_\_345\_FE-1

Tue 09/07/2021 to Sat 09/11/2021  
0600 Continuous 1830

Work scheduled by: NGrid

UPDATED by NGRID 08/19/2021

FWD  
(Import)  
OSWEGO EXPORT **4800 MW**  
Impacts Total Transfer Capability 450 MW  
TTC with All Lines In Service 5250 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Tue 09/07/2021 to Sun 11/14/2021  
0600 Continuous 1300

Work scheduled by: NYPA

UPDATED by NYPA 09/01/2021

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## SCH-IMO-NYISO\_LIMIT\_1400

Tue 09/07/2021 to Sun 11/14/2021  
0600 Continuous 1300

Work scheduled by: IESO

UPDATED by NYPA 09/01/2021

FWD  
(Import)  
SCH - OH - NY **1700 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1950 MW

## SCH-NYISO-IMO\_LIMIT\_1200

Tue 09/07/2021 to Sun 11/14/2021  
0600 Continuous 1300

Work scheduled by: IESO

UPDATED by NYPA 09/01/2021

REV  
(Export)  
SCH - OH - NY **1500 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1700 MW

## SCH-HQ\_CEDARS-NYISO\_LIMIT\_80

Tue 09/07/2021 to Fri 10/15/2021  
0700 Continuous 2300

Work scheduled by: HQ

FWD  
(Import)  
SCH - HQ\_CEDARS **80 MW**  
Impacts Total Transfer Capability 110 MW  
TTC with All Lines In Service 190 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PLSNTVLE-DUNWODIE\_345\_W90

FWD

Wed 09/08/2021 to Sun 09/12/2021 UPDATED by CONED 09/03/2021

(Import)

0001 Continuous 1800

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### HURLYAVE-ROSETON\_345\_303

FWD

Fri 09/10/2021 to Wed 09/15/2021 UPDATED by CHGE 09/15/2021

(Import)

0800 Daily 0759

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: CHGE

### DUNWODIE\_345KV\_8

FWD

Sat 09/11/2021 to Sat 09/11/2021 UPDATED by CONED 09/03/2021

(Import)

0001 Continuous 1800

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### WOOD\_ST\_-PLSNTVLE\_345\_Y87

FWD

Sat 09/11/2021 to Sun 09/12/2021 UPDATED by CONED 09/03/2021

(Import)

0001 Continuous 0200

UPNY CONED

**7260 MW**

Impacts Total Transfer Capability 555 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### DUNWODIE\_345KV\_6

FWD

Sat 09/11/2021 to Sun 09/19/2021 UPDATED by CONED 09/03/2021

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### FRASER\_345\_FRASER SVC

FWD

Sat 09/11/2021 to Sat 09/11/2021

(Import)

0800 Continuous 1000

CENTRAL EAST - VC

**2935 MW**

Impacts Total Transfer Capability 40 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

### FRASER\_345\_FRASER SVC

FWD

Sat 09/11/2021 to Sat 09/11/2021

(Import)

1500 Continuous 1700

CENTRAL EAST - VC

**2935 MW**

Impacts Total Transfer Capability 40 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## W49TH\_ST-E13THSTA\_345\_M54

FWD

Mon 09/13/2021 to Mon 09/13/2021 CANCELLED by ConEd 09/12/2021

(Import)

0001 Continuous 0500

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## VOLNEY-CLAY\_345\_6

FWD

Mon 09/13/2021 to Mon 09/13/2021

(Import)

0700 Daily(No Weekends) 1730

OSWEGO EXPORT

5250 MW

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

## DOLSONAV-ROCKTVRN\_345\_DART44

FWD

Mon 09/13/2021 to Wed 09/15/2021 UPDATED by NYPA 08/25/2021

(Import)

0700 Continuous 1600

CENTRAL EAST - VC

2720 MW

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: CHGE

## PANNELL-CLAY\_345\_2

FWD

Mon 09/13/2021 to Fri 09/17/2021 UPDATED by NYPA 05/12/2021

(Import)

0700 Continuous 1530

WEST CENTRAL

1300 MW

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

## LEEDS\_345\_LEEDS SVC

FWD

Mon 09/13/2021 to Fri 09/17/2021

(Import)

0800 Continuous 1100

CENTRAL EAST - VC

2950 MW

Impacts Total Transfer Capability 25 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

## DUNWODIE\_345KV\_4

FWD

Tue 09/14/2021 to Sun 09/19/2021 EXT FORCE by CE 09/12/2021

(Import)

0133 Continuous 0200

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: LI

## W49TH\_ST\_345KV\_6

FWD

Wed 09/15/2021 to Wed 09/15/2021 UPDATED by CONED 09/15/2021

(Import)

0001 Continuous 0030

SCH - PJM\_HTP

300 MW

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**E13THSTA-FARRAGUT\_345\_46**

FWD

Wed 09/15/2021 to Wed 10/13/2021 UPDATED by CONED 09/15/2021

(Import)

0001 Continuous 2300

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**W49TH\_ST-E13THSTA\_345\_M55**

FWD

Wed 09/15/2021 to Wed 10/13/2021 UPDATED by CONED 09/15/2021

(Import)

0001 Continuous 2300

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**PORTER\_\_-ROTTRDAM\_230\_30**

FWD

Wed 09/15/2021 to Tue 11/30/2021 UPDATED by NGRID 08/31/2021

(Import)

0700 Continuous 1730

CENTRAL EAST - VC **2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**BUCHAN\_N-EASTVIEW\_345\_W93**

FWD

Wed 09/15/2021 to Sat 09/18/2021

(Import)

2100 Continuous 0200

UPNY CONED **4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**EASTVIEW-SPRNBK\_\_345\_W79**

FWD

Wed 09/15/2021 to Sat 09/18/2021

(Import)

2100 Continuous 0200

UPNY CONED **4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**RAMAPO\_\_-BUCHAN\_N\_345\_Y94**

FWD

Wed 09/15/2021 to Sat 09/18/2021

(Import)

2100 Continuous 0200

UPNY CONED **7580 MW**

Impacts Total Transfer Capability 235 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**EDIC\_\_\_\_-N.SCTLND\_345\_14**

FWD

Thu 09/16/2021 to Sun 11/14/2021 UPDATED by NGRID 08/31/2021

(Import)

0600 Continuous 1830

CENTRAL EAST - VC **1670 MW**

Impacts Total Transfer Capability 1305 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC\_\_\_\_-N.SCTLND\_345\_14 & PORTER\_\_\_\_-ROTTDAM\_230\_30

FWD

Thu 09/16/2021 to Sun 11/14/2021  
0600 1830

(Import)

CENTRAL EAST - VC **1500 MW**  
Impacts Total Transfer Capability 1475 MW  
TTC with All Lines In Service 2975 MW

Work scheduled by:

HURLYAVE-ROSETON\_\_\_\_345\_303

FWD

Thu 09/16/2021 to Fri 09/24/2021  
0800 Continuous 1600

(Import)

CANCELLED by CHGE 09/15/2021

UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 3715 MW  
TTC with All Lines In Service 7815 MW

Work scheduled by: CHGE

DUNWODIE\_345KV\_3

FWD

Sat 09/18/2021 to Sat 09/18/2021  
0201 Continuous 0231

(Import)

UPDATED by CONED 09/02/2021

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

PLSNTVLE-DUNWODIE\_345\_W89

FWD

Sat 09/18/2021 to Tue 09/28/2021  
0201 Continuous 1000

(Import)

UPDATED by CONED 09/02/2021

UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

HOMRC\_NY-MAINS\_NY\_345\_47

Sat 09/18/2021 to Fri 11/05/2021  
0800 Continuous 1600

UPDATED by PJM 07/23/2021

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

Work scheduled by: PJM

PANNELL\_-CLAY\_\_\_\_345\_1

FWD

Mon 09/20/2021 to Fri 09/24/2021  
0700 Continuous 1530

(Import)

UPDATED by NYPA 08/25/2021

WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

PIERCBRK-FIVEMILE\_345\_37

Wed 09/22/2021 to Wed 09/22/2021  
0730 Continuous 1100

CANCELLED by PJM 09/13/2021

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

Work scheduled by: PJM

# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LEEDS\_\_\_\_345KV\_R395

FWD

Thu 09/23/2021 to Thu 10/07/2021 CANCELLED by NYISO 09/14/2021

(Import)

0830 Continuous 1530

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

## EFISHKIL-WOOD\_ST\_\_345\_F38

FWD

Sat 09/25/2021 to Tue 09/28/2021 UPDATED by CONED 09/02/2021

(Import)

0001 Continuous 1000

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## WOOD\_ST\_-PLSNTVLE\_345\_Y86

FWD

Sat 09/25/2021 to Tue 09/28/2021 UPDATED by CONED 09/02/2021

(Import)

0001 Continuous 1000

UPNY CONED

**7210 MW**

Impacts Total Transfer Capability 605 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## SCH-NYISO-NE\_LIMIT\_1000

REV

Sat 09/25/2021 to Sun 10/24/2021

(Export)

0700 Continuous 1600

SCH - NE - NY

**1200 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 1600 MW

Work scheduled by: ISONE

## CHAT\_DC\_GC1

FWD

Sun 09/26/2021 to Sun 09/26/2021

(Import)

0001 Continuous 0200

MOSES SOUTH

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

## CHAT\_DC\_GC1

REV

Sun 09/26/2021 to Sun 09/26/2021

(Export)

0001 Continuous 0200

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

Work scheduled by: HQ

## CHAT\_DC\_GC1 &amp; CHAT\_DC\_GC2

FWD

Sun 09/26/2021 to Sun 09/26/2021

(Import)

0001 0200

MOSES SOUTH

**2550 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 3150 MW

Work scheduled by:



# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Sun 09/26/2021 to Sun 09/26/2021  
0001 0200

Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ - NY	<b>1370 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	130 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

## CHAT\_DC\_GC2

Sun 09/26/2021 to Sun 09/26/2021  
0001 Continuous 0200

Work scheduled by: HQ

	FWD (Import)
MOSES SOUTH	<b>2850 MW</b>
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

## CHAT\_DC\_GC2

Sun 09/26/2021 to Sun 09/26/2021  
0001 Continuous 0200

Work scheduled by: HQ

	REV (Export)
SCH - HQ - NY	<b>500 MW</b>
Impacts Total Transfer Capability	500 MW
TTC with All Lines In Service	1000 MW

## SCH-HQ-NYISO\_LIMIT\_1150

Sun 09/26/2021 to Sun 09/26/2021  
0001 Continuous 0200

Work scheduled by: HQ

	FWD (Import)
SCH - HQ - NY	<b>1150 MW</b>
Impacts Total Transfer Capability	350 MW
TTC with All Lines In Service	1500 MW

## NIAGARA\_-KINTIGH\_345\_NS1-38

Mon 09/27/2021 to Fri 10/01/2021  
0500 Continuous 1700

Work scheduled by: NYPA

**EXTENDED by NYPA 08/20/2021**

	FWD (Import)
DYSINGER EAST	<b>1400 MW</b>
Impacts Total Transfer Capability	1750 MW
TTC with All Lines In Service	3150 MW

## LEEDS\_345KV\_R94301

Mon 09/27/2021 to Mon 09/27/2021  
0800 Continuous 0900

Work scheduled by: CHGE

	FWD (Import)
UPNY CONED	<b>3800 MW</b>
Impacts Total Transfer Capability	4015 MW
TTC with All Lines In Service	7815 MW

## FIVEMILE-STOLLERD\_345\_29

Mon 09/27/2021 to Fri 10/08/2021  
0800 Continuous 1400

Work scheduled by: NYSEG

SCH - PJ - NY	
Impacts Total Transfer Capability	
TTC with All Lines In Service	

# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LEEDS\_\_\_-HURLYAVE\_345\_301

FWD

Mon 09/27/2021 to Fri 10/29/2021

(Import)

0800 Continuous 1600

UPNY CONED

4100 MW

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: CHGE

## DUNWODIE\_345KV\_3

FWD

Tue 09/28/2021 to Tue 09/28/2021

(Import)

0930 Continuous 1000

UPDATEDby CONED 09/02/2021

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## DUNWODIE\_345KV\_4

FWD

Tue 09/28/2021 to Tue 09/28/2021

(Import)

0930 Continuous 1000

UPDATEDby CONED 09/02/2021

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## EFISHKIL-WOOD\_ST\_345\_F38

FWD

Wed 09/29/2021 to Wed 09/29/2021

(Import)

0130 Continuous 0200

UPDATEDby CONED 09/02/2021

UPNY CONED

4000 MW

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## PLSNTVLE-DUNWODIE\_345\_W89

FWD

Wed 09/29/2021 to Wed 09/29/2021

(Import)

0130 Continuous 0200

UPDATEDby CONED 09/02/2021

UPNY CONED

4000 MW

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## WOOD\_ST\_-PLSNTVLE\_345\_Y86

FWD

Wed 09/29/2021 to Wed 09/29/2021

(Import)

0130 Continuous 0200

UPDATEDby CONED 09/02/2021

UPNY CONED

7210 MW

Impacts Total Transfer Capability 605 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## LADENTWN-BUCHAN\_S\_345\_Y88

FWD

Thu 09/30/2021 to Thu 09/30/2021

(Import)

0800 Continuous 1600

UPDATEDby ORU 08/13/2021

UPNY CONED

7560 MW

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ORU

# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LEEDS\_\_\_\_345KV\_R395

Thu 09/30/2021 to Thu 10/14/2021  
0900 Continuous 1500  
Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### NIAGARA -STA\_255\_\_345\_NH2

Sat 10/02/2021 to Sun 10/17/2021  
0500 Continuous 1900  
Work scheduled by: NYPA

UPDATED by NYPA 08/20/2021

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

### CHAT\_DC\_GC1

Sun 10/03/2021 to Tue 11/23/2021  
0500 Continuous 2000  
Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

### CHAT\_DC\_GC1

Sun 10/03/2021 to Tue 11/23/2021  
0500 Continuous 2000  
Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

### SCH-NYISO-HQ\_LIMIT\_800

Mon 10/04/2021 to Tue 10/05/2021  
0400 Continuous 1900  
Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **800 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1000 MW

### CLAY\_\_\_\_-EDIC\_\_\_\_345\_2-15

Mon 10/04/2021 to Sat 10/30/2021  
0700 Continuous 1730  
Work scheduled by: NYPA

UPDATED by NYPA 08/16/2021

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

### FRASER\_\_\_\_345\_FRASER SVC

Mon 10/04/2021 to Mon 10/04/2021  
0800 Continuous 1700  
Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2935 MW**  
Impacts Total Transfer Capability 40 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PLSNTVLE-DUNWODIE\_345\_W89

FWD

Tue 10/05/2021 to Tue 10/05/2021  
0130 Continuous 0200

**CANCELLED** **by ConEd** **09/14/2021**

(Import)

Work scheduled by: ConEd

UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

### SCH-NYISO-HQ\_LIMIT\_800

REV

Wed 10/06/2021 to Thu 10/07/2021  
0400 Continuous 1900

Work scheduled by: HQ

SCH - HQ - NY **800 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1000 MW

### MILLWOOD\_345KV\_18

FWD

Thu 10/07/2021 to Thu 10/07/2021  
0001 Continuous 0030

**CANCELLED** **by ConEd** **09/11/2021**

(Import)

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

### BUCHAN\_S-MILLWOOD\_345\_W98

FWD

Thu 10/07/2021 to Fri 10/08/2021  
0001 Continuous 2200

**CANCELLED** **by ConEd** **09/11/2021**

(Import)

Work scheduled by: ConEd

UPNY CONED **7680 MW**  
Impacts Total Transfer Capability 135 MW  
TTC with All Lines In Service 7815 MW

### MILLWOOD\_345KV\_18

FWD

Fri 10/08/2021 to Fri 10/08/2021  
2130 Continuous 2200

**CANCELLED** **by ConEd** **09/11/2021**

(Import)

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

### W49TH\_ST\_345KV\_6

FWD

Wed 10/13/2021 to Wed 10/13/2021  
2230 Continuous 2300

**UPDATED** **by CONED** **09/15/2021**

(Import)

Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

### MILLWOOD-EASTVIEW\_345\_W85

FWD

Thu 10/14/2021 to Thu 10/14/2021  
0001 Continuous 0030

Work scheduled by: ConEd

UPNY CONED **7550 MW**  
Impacts Total Transfer Capability 265 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE-MOTTHAVN\_345\_72

FWD

Thu 10/14/2021 to Sat 10/16/2021 UPDATED by CONED 08/04/2021

(Import)

0001 Continuous 0100

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### DUNWODIE\_345KV\_8

FWD

Thu 10/14/2021 to Sat 10/16/2021 UPDATED by CONED 08/04/2021

(Import)

0001 Continuous 0100

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### EASTVIEW-SPRNBK\_345\_W78

FWD

Thu 10/14/2021 to Sat 10/16/2021

(Import)

0001 Continuous 0100

UPNY CONED **4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### DUNWODIE\_345KV\_5

FWD

Thu 10/14/2021 to Sun 11/28/2021

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### DUNWODIE\_345KV\_7

FWD

Thu 10/14/2021 to Sun 11/28/2021

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### SPRNBK\_-DUNWODIE\_345\_W75

FWD

Thu 10/14/2021 to Sun 11/28/2021

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### SPRNBK\_345KV\_RNS3

FWD

Thu 10/14/2021 to Sun 11/28/2021

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SPRNBK\_\_345KV\_RS3 & SPRNBK\_\_345KV\_RS4

Sat 10/16/2021 to Mon 10/18/2021  
0001 0200

Work scheduled by:

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

## MILLWOOD-EASTVIEW\_345\_W85

Sat 10/16/2021 to Sat 10/16/2021  
0030 Continuous 0100

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7550 MW**  
Impacts Total Transfer Capability 265 MW  
TTC with All Lines In Service 7815 MW

## DUNWODIE-MOTTHAVN\_345\_71

Sat 10/16/2021 to Mon 10/18/2021  
0101 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## DUNWODIE\_345KV\_3

Sat 10/16/2021 to Mon 10/18/2021  
0101 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## NIAGARA\_-KINTIGH\_345\_NS1-38

Mon 10/18/2021 to Sat 12/04/2021  
0500 Continuous 1900

Work scheduled by: NYPA

**UPDATED by NYPA 08/20/2021**

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

Wed 10/20/2021 to Thu 10/21/2021  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

## RAMAPO\_-BUCHAN\_N\_345\_Y94

Wed 10/20/2021 to Thu 10/21/2021  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7580 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 7815 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NE-NYISO\_LIMIT\_900

Thu 10/21/2021 to Fri 10/29/2021  
1700 Continuous 1600  
Work scheduled by: ISONE

FWD  
(Import)  
SCH - NE - NY **1100 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 1400 MW

## SHOR\_NPX-SHOREHAM\_138\_CSC

Tue 10/26/2021 to Sun 11/21/2021  
0600 Continuous 1600  
Work scheduled by: ISONE

FWD REV  
(Import) (Export)  
SCH - NPX\_CSC **0 MW 0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

## LEEDS\_\_\_\_345KV\_R94301

Fri 10/29/2021 to Fri 10/29/2021  
1500 Continuous 1600  
Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## W49TH\_ST\_345KV\_7

Sat 10/30/2021 to Sat 10/30/2021  
0001 Continuous 0030  
Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

## W49TH\_ST\_345KV\_5

Sat 10/30/2021 to Sun 12/05/2021 **UPDATED by CONED 06/20/2021**  
0001 Continuous 0300  
Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

## BUCHAN\_S-MILLWOOD\_345\_W97

Mon 11/01/2021 to Fri 12/10/2021 **UPDATED by CE 09/10/2021**  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7680 MW**  
Impacts Total Transfer Capability 135 MW  
TTC with All Lines In Service 7815 MW

## SCH-IMO-NYISO\_LIMIT\_1750

Mon 11/01/2021 to Fri 12/31/2021 **UPDATED by IESO 05/03/2019**  
0001 Continuous 2359  
Work scheduled by: IESO

FWD  
(Import)  
SCH - OH - NY **2050 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 2300 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NYISO-IMO\_LIMIT\_1600

REV

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019

(Export)

0001 Continuous 2359

Work scheduled by: IESO

SCH - OH - NY

**1900 MW**

Impacts Total Transfer Capability

100 MW

TTC with All Lines In Service

2000 MW

### HURLYAVE-ROSETON\_345\_303

FWD

Mon 11/01/2021 to Fri 11/19/2021

(Import)

0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability

3715 MW

TTC with All Lines In Service

7815 MW

### W49TH\_ST\_345KV\_7

FWD

Tue 11/02/2021 to Tue 11/02/2021

(Import)

0200 Continuous 0230

Work scheduled by: ConEd

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

### LINDN\_CG-LNDVFT\_345\_V-3022

FWD

REV

Tue 11/02/2021 to Fri 11/05/2021

(Import) (Export)

0800 Continuous 1500

Work scheduled by: PJM

SCH - PJM\_VFT

**0 MW**

**0 MW**

Impacts Total Transfer Capability

315 MW

315 MW

TTC with All Lines In Service

315 MW

315 MW

### MILLWOOD\_345KV\_18

FWD

Wed 11/03/2021 to Fri 11/12/2021 UPDATED by CE 09/10/2021

(Import)

0001 Continuous 1800

Work scheduled by: ConEd

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability

3465 MW

TTC with All Lines In Service

7815 MW

### BUCHAN\_S-MILLWOOD\_345\_W98

FWD

Wed 11/03/2021 to Tue 11/09/2021 UPDATED by CE 09/10/2021

(Import)

0201 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

**7680 MW**

Impacts Total Transfer Capability

135 MW

TTC with All Lines In Service

7815 MW

### LADENTWN-BUCHAN\_S\_345\_Y88

FWD

Wed 11/03/2021 to Tue 11/09/2021 UPDATED by CE 09/10/2021

(Import)

0201 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

**7560 MW**

Impacts Total Transfer Capability

255 MW

TTC with All Lines In Service

7815 MW



# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HOMRC\_NY-MAINS\_NY\_345\_47

Fri 11/05/2021 to Mon 11/08/2021

1601 Continuous 0800

Work scheduled by: PJM

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## GOETHALS\_345KV\_5

Fri 11/12/2021 to Tue 11/16/2021

0001 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 06/30/2021

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

## BERKSHIR-ALPS\_\_\_\_345\_393

Sun 11/14/2021 to Wed 11/24/2021

0700 Continuous 1600

Work scheduled by: ISONE

ARR: 78

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	1100 MW	1700 MW
Impacts Total Transfer Capability	300 MW	0 MW
TTC with All Lines In Service	1400 MW	1700 MW

## BERKSHIR-ALPS\_\_\_\_345\_393

Sun 11/14/2021 to Wed 11/24/2021

0700 Continuous 1600

Work scheduled by: ISONE

ARR: 78

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

## BERKSHIR-ALPS\_\_\_\_345\_393 & BERKSHIR-NORTHFLD\_345\_312

Sun 11/14/2021 to Wed 11/24/2021

0700 Continuous 1600

Work scheduled by:

ARR: 78

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	1100 MW	1700 MW
Impacts Total Transfer Capability	300 MW	0 MW
TTC with All Lines In Service	1400 MW	1700 MW

## BERKSHIR-NORTHFLD\_345\_312

Sun 11/14/2021 to Wed 11/24/2021

0700 Continuous 1600

Work scheduled by: ISONE

	FWD
	(Import)
SCH - NE - NY	1300 MW
Impacts Total Transfer Capability	100 MW
TTC with All Lines In Service	1400 MW

## BERKSHIR-NORTHFLD\_345\_312

Sun 11/14/2021 to Wed 11/24/2021

0700 Continuous 1600

Work scheduled by: ISONE

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, September 15, 2021 to Friday, March 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NE-NYISO_LIMIT_800</b>					FWD	
Sun 11/14/2021	to	Wed 11/24/2021			(Import)	
0700	Continuous	1600			SCH - NE - NY	<b>1000 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_700</b>					REV	
Sun 11/14/2021	to	Wed 11/24/2021			(Export)	
0700	Continuous	1600			SCH - NE - NY	<b>900 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	1700 MW
<b>PORTER__-ROTTRDAM_230_30 &amp; MASSENA_-MARCY___765_MSU1</b>					FWD	
Mon 11/15/2021	to	Tue 11/30/2021			(Import)	
0100		1730			CENTRAL EAST - VC	<b>1500 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	1475 MW
					TTC with All Lines In Service	2975 MW
<b>CHATGUAY-MASSENA___765_7040</b>					FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<b>UPDATED</b>	<b>by NYISO 06/03/2021</b>	(Import)	
0100	Continuous	1859			MOSES SOUTH	<b>1550 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	3150 MW
<b>CHATGUAY-MASSENA___765_7040</b>					FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021	<b>UPDATED</b>	<b>by NYISO 06/03/2021</b>	(Import)	(Export)
0100	Continuous	1859			SCH - HQ - NY	<b>0 MW</b> <b>0 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1500 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW
<b>MARCY___765_345_AT1</b>					FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<b>UPDATED</b>	<b>by NYISO 06/03/2021</b>	(Import)	
0100	Continuous	1859			MOSES SOUTH	<b>1750 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	3150 MW
<b>MARCY___765_345_AT2</b>					FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<b>UPDATED</b>	<b>by NYISO 06/03/2021</b>	(Import)	
0100	Continuous	1859			MOSES SOUTH	<b>1700 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY____765_MSU1						FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>	(Import)	
0100	Continuous	1859				CENTRAL EAST - VC	1670 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1305 MW
						TTC with All Lines In Service	2975 MW
<hr/>							
MASSENA_-MARCY____765_MSU1						FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>	(Import)	
0100	Continuous	1859				MOSES SOUTH	500 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
<hr/>							
MASSENA_-MARCY____765_MSU1						FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>	(Import)	(Export)
0100	Continuous	1859				SCH - HQ - NY	475 MW 1000 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW 0 MW
						TTC with All Lines In Service	1500 MW 1000 MW
<hr/>							
MASSENA_-MARCY____765_MSU1						FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>	(Import)	
0100	Continuous	1859				SCH - HQ_CEDARS	90 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	109 MW
						TTC with All Lines In Service	199 MW
<hr/>							
MASSENA_-MARCY____765_MSU1 & CHATGUAY-MASSENA_765_7040						FWD	
Mon 11/15/2021	to	Tue 11/30/2021				(Import)	
0100		1859				MOSES SOUTH	500 MW
Work scheduled by:						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
<hr/>							
MOSES____-MASSENA_230_MMS1 & MOSES____-MASSENA_230_MMS2						FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021				(Import)	(Export)
0100		1859				SCH - HQ - NY	850 MW 0 MW
Work scheduled by:						Impacts Total Transfer Capability	650 MW 1000 MW
						TTC with All Lines In Service	1500 MW 1000 MW
<hr/>							
MOSES____-MASSENA_230_MMS1 & MOSES____-MASSENA_230_MMS2						FWD	
Mon 11/15/2021	to	Tue 11/30/2021				(Import)	
0100		1859				SCH - HQ_CEDARS	90 MW
Work scheduled by:						Impacts Total Transfer Capability	109 MW
						TTC with All Lines In Service	199 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES____230_L33P & MASSENA_-MARCY____765_MSU1					FWD
Mon 11/15/2021	to	Tue 11/30/2021			(Import)
0100		1859		SCH - HQ_CEDARS	90 MW
Work scheduled by:					Impacts Total Transfer Capability 109 MW
					TTC with All Lines In Service 199 MW
STLAWRNC-MOSES____230_L33P & MOSES____-MASSENA_230_MMS1 & MOSES____-MASSENA_230_MMS2					FWD
Mon 11/15/2021	to	Tue 11/30/2021			(Import)
0100		1859		SCH - HQ_CEDARS	90 MW
Work scheduled by:					Impacts Total Transfer Capability 109 MW
					TTC with All Lines In Service 199 MW
S.RIPLEY-DUNKIRK__230_68					
Tue 11/16/2021	to	Sat 12/04/2021			SCH - PJ - NY
0700	Continuous	1730			Impacts Total Transfer Capability
Work scheduled by: NGrid					TTC with All Lines In Service
MILLWOOD-EASTVIEW_345_W85					FWD
Fri 11/19/2021	to	Fri 11/19/2021	<u>UPDATED</u>	<u>by CE</u> <u>06/28/2021</u>	(Import)
0001	Continuous	0030			UPNY CONED
Work scheduled by: ConEd					7550 MW
					Impacts Total Transfer Capability 265 MW
					TTC with All Lines In Service 7815 MW
EASTVIEW-SPRNBK__345_W78					FWD
Fri 11/19/2021	to	Wed 11/24/2021	<u>UPDATED</u>	<u>by CE</u> <u>06/28/2021</u>	(Import)
0001	Continuous	0200			UPNY CONED
Work scheduled by: ConEd					4350 MW
					Impacts Total Transfer Capability 3465 MW
					TTC with All Lines In Service 7815 MW
W49TH_ST_345KV_7					FWD
Sat 11/20/2021	to	Sat 11/20/2021	<u>UPDATED</u>	<u>by CONED</u> <u>06/20/2021</u>	(Import)
0001	Continuous	0030			SCH - PJM_HTP
Work scheduled by: ConEd					300 MW
					Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service 660 MW
DUNWODIE-MOTTHAVN_345_72					FWD
Sat 11/20/2021	to	Wed 11/24/2021	<u>UPDATED</u>	<u>by CONED</u> <u>06/07/2021</u>	(Import)
0001	Continuous	0200			SPR/DUN-SOUTH
Work scheduled by: ConEd					3800 MW
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_8**

FWD

Sat 11/20/2021 to Wed 11/24/2021 UPDATED by CONED 06/07/2021

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**SPRNBK\_345KV\_RS3 & SPRNBK\_345KV\_RS4**

FWD

Wed 11/24/2021 to Sun 11/28/2021

(Import)

0001 0200

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by:

**MILLWOOD-EASTVIEW\_345\_W85**

FWD

Wed 11/24/2021 to Wed 11/24/2021 UPDATED by CE 06/28/2021

(Import)

0130 Continuous 0200

UPNY CONED **7550 MW**

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**DUNWODIE-MOTTHAVN\_345\_71**

FWD

Wed 11/24/2021 to Sun 11/28/2021

(Import)

0201 Continuous 0100

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**DUNWODIE\_345KV\_3**

FWD

Wed 11/24/2021 to Sun 11/28/2021

(Import)

0201 Continuous 0100

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**W49TH\_ST\_345KV\_7**

FWD

Thu 11/25/2021 to Fri 12/03/2021 UPDATED by CONED 06/20/2021

(Import)

0001 Continuous 0200

SCH - PJM\_HTP **300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**SPRNBK\_345KV\_RNS4**

FWD

Sun 11/28/2021 to Sun 11/28/2021 UPDATED by CONED 06/20/2021

(Import)

0300 Continuous 0330

SPR/DUN-SOUTH **3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SPRNBK -W49TH\_ST\_345\_M52

Sun 11/28/2021 to Wed 12/01/2021 UPDATED by CONED 06/20/2021  
0300 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
**3200 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

## NEPTUNE -DUFFYAVE\_345\_NEPTUNE

Mon 11/29/2021 to Fri 12/17/2021 UPDATED by PJM 09/15/2021  
0600 Continuous 1600

Work scheduled by: PJM

FWD  
(Import)  
**0 MW**  
SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

## NEWBRDGE-DUFFYAVE\_345\_501

Mon 11/29/2021 to Fri 12/17/2021 UPDATED by PJM 09/15/2021  
0600 Continuous 1600

Work scheduled by: PJM

FWD  
(Import)  
**0 MW**  
SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

## NEWBRDGE\_345\_138\_BK\_2

Mon 11/29/2021 to Fri 12/17/2021 UPDATED by PJM 09/15/2021  
0600 Continuous 1600

Work scheduled by: PJM

FWD  
(Import)  
**375 MW**  
SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

## NIAGARA -PACKARD\_230\_61

Tue 11/30/2021 to Mon 12/06/2021  
0615 Continuous 1900

Work scheduled by: NGrid

FWD REV  
(Import) (Export)  
**1200 MW 1850 MW**  
SCH - OH - NY  
Impacts Total Transfer Capability 1100 MW 150 MW  
TTC with All Lines In Service 2300 MW 2000 MW

## SPRNBK\_345KV\_RNS4

Wed 12/01/2021 to Wed 12/01/2021 UPDATED by CONED 06/20/2021  
0130 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
**3200 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

## MOSES -ADIRNDCK\_230\_MAI

Wed 12/01/2021 to Tue 05/31/2022  
0700 Continuous 1300

Work scheduled by: NYPA

FWD  
(Import)  
**2300 MW**  
MOSES SOUTH  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MILLWOOD_345KV_18</b>					FWD		
Mon 12/06/2021	to	Fri 12/10/2021	<u>UPDATED</u>	<u>by CE</u>	<u>09/10/2021</u>	(Import)	
0001	Continuous	0200				UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW		
					TTC with All Lines In Service 7815 MW		
<b>MARCY_345KV_CSC</b>					FWD		
Mon 12/06/2021	to	Fri 12/17/2021				(Import)	
0700	Continuous	1730				CENTRAL EAST - VC	<b>2925 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 50 MW		
					TTC with All Lines In Service 2975 MW		
<b>BUCHAN_S-MILLWOOD_345_W98</b>					FWD		
Tue 12/07/2021	to	Fri 12/10/2021	<u>UPDATED</u>	<u>by CE</u>	<u>09/10/2021</u>	(Import)	
0201	Continuous	0200				UPNY CONED	<b>7680 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 135 MW		
					TTC with All Lines In Service 7815 MW		
<b>LADENTWN-BUCHAN_S_345_Y88</b>					FWD		
Tue 12/07/2021	to	Fri 12/10/2021	<u>UPDATED</u>	<u>by CE</u>	<u>09/10/2021</u>	(Import)	
0201	Continuous	0200				UPNY CONED	<b>7560 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 255 MW		
					TTC with All Lines In Service 7815 MW		
<b>FRASER_345_FRASER SVC</b>					FWD		
Tue 01/04/2022	to	Mon 02/28/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/25/2021</u>	(Import)	
0700	Continuous	1730				CENTRAL EAST - VC	<b>2935 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 40 MW		
					TTC with All Lines In Service 2975 MW		
<b>NIAGARA_-PACKARD_230_61</b>					FWD		
Mon 01/17/2022	to	Fri 01/21/2022				(Import)	REV (Export)
0615	Continuous	1900				SCH - OH - NY	<b>1200 MW 1850 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 1100 MW 150 MW		
					TTC with All Lines In Service 2300 MW 2000 MW		
<b>NIAGARA_-STA_255_345_NH2</b>					FWD		
Fri 01/21/2022	to	Fri 03/04/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/20/2021</u>	(Import)	
0500	Continuous	1900				DYSINGER EAST	<b>1700 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1450 MW		
					TTC with All Lines In Service 3150 MW		

# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### FRASANNX-COOPERS\_\_345\_UCC2-41

Mon 02/07/2022 to Sat 02/12/2022  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

### MARCY\_\_-FRASANNX\_345\_UCC2-41

Mon 02/07/2022 to Sat 02/12/2022  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

### ATHENS\_\_-PLSNTVLY\_345\_91

Sat 02/12/2022 to Wed 02/16/2022  
0600 Continuous 1900

Work scheduled by: NGrid

UPDATED by NGRID 05/07/2021

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Thu 02/17/2022 to Sat 02/19/2022  
0001 2200

Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### LEEDS\_\_-PLSNTVLY\_345\_92

Thu 02/17/2022 to Fri 03/25/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLY\_345KV\_RNS5

Thu 02/17/2022 to Fri 03/25/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLY-WOOD\_ST\_\_345\_F30

Sun 02/20/2022 to Mon 02/21/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW



# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## EASTVIEW-SPRNBK\_\_345\_W64

FWD

Tue 02/22/2022 to Tue 02/22/2022 UPDATED by CONED 08/31/2021

(Import)

0001 Continuous 0030

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

## SPRNBK\_\_345KV\_RNS5

FWD

Tue 02/22/2022 to Tue 02/22/2022 UPDATED by CONED 08/31/2021

(Import)

0001 Continuous 0030

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

## MILLWOOD-EASTVIEW\_345\_W99

FWD

Tue 02/22/2022 to Mon 03/21/2022 UPDATED by CONED 08/31/2021

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED **7550 MW**  
 Impacts Total Transfer Capability 265 MW  
 TTC with All Lines In Service 7815 MW

## MARCY\_\_-EDIC\_\_345\_UE1-7

FWD

Wed 02/23/2022 to Mon 02/28/2022

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19&16

OSWEGO EXPORT **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

## PORTER\_\_-ROTTRDAM\_230\_31

FWD

Tue 03/01/2022 to Tue 12/31/2030

(Import)

0600 Continuous 2359

Work scheduled by: NGrid

CENTRAL EAST - VC **2805 MW**  
 Impacts Total Transfer Capability 170 MW  
 TTC with All Lines In Service 2975 MW

## N.SCTLND-LEEDS\_\_345\_93

FWD

Tue 03/01/2022 to Tue 03/15/2022

(Import)

0700 Continuous 1900

Work scheduled by: NGrid

CENTRAL EAST - VC **2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

## EDIC\_\_-N.SCTLND\_345\_14

FWD

Tue 03/01/2022 to Tue 04/12/2022

(Import)

0700 Continuous 1900

Work scheduled by: NGrid

CENTRAL EAST - VC **1670 MW**  
 Impacts Total Transfer Capability 1305 MW  
 TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC\_\_\_\_-N.SCTLND\_345\_14 & PORTER\_\_\_\_-ROTTDAM\_230\_31

FWD

Tue 03/01/2022 to Tue 04/12/2022  
0700 1900

(Import)

Work scheduled by:

CENTRAL EAST - VC **1500 MW**  
Impacts Total Transfer Capability 1475 MW  
TTC with All Lines In Service 2975 MW

FRASANNX-COOPERS\_\_\_\_345\_UCC2-41

FWD

Tue 03/01/2022 to Wed 04/20/2022  
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

**ARR: 19**

CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

MARCY\_\_\_\_-FRASANNX\_345\_UCC2-41

FWD

Tue 03/01/2022 to Wed 04/20/2022  
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

**ARR: 19**

CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

N.SCTLND-ALPS\_\_\_\_345\_2

FWD

Tue 03/01/2022 to Tue 05/24/2022  
0700 Continuous 1900

(Import)

Work scheduled by: NGrid

SCH - NE - NY **900 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1400 MW

N.SCTLND-ALPS\_\_\_\_345\_2

FWD

REV

Tue 03/01/2022 to Tue 05/24/2022  
0700 Continuous 1900

(Import) (Export)

Work scheduled by: NGrid

SCH - NPX\_1385 **100 MW** **100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

GOETHALS\_345KV\_5

Sat 03/05/2022 to Mon 04/04/2022  
0001 Continuous 0200

UPDATED

by CONED 03/26/2021

Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

LINDEN\_\_\_\_-GOETHALS\_230\_A2253

Sat 03/05/2022 to Mon 04/04/2022  
0001 Continuous 0200

UPDATED

by CONED 03/26/2021

Work scheduled by: ConEd

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 7815MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## INDPDNCE-SCRIBA\_\_345\_25

Thu 03/10/2022 to Wed 03/16/2022  
0800 Continuous 1800  
Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT 5250 MW  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

## PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Thu 03/17/2022 to Sun 03/20/2022  
0100 2200  
Work scheduled by:

FWD  
(Import)  
UPNY CONED 3800 MW  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## PLSNTVLY-WOOD\_ST\_\_345\_F30

Mon 03/21/2022 to Wed 03/23/2022  
0001 Continuous 2200  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED 4000 MW  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

## EASTVIEW-SPRNBRK\_\_345\_W64

Mon 03/21/2022 to Mon 03/21/2022 UPDATED by CONED 08/31/2021  
0130 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED 4350 MW  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

## SPRNBRK\_\_345KV\_RNS5

Mon 03/21/2022 to Mon 03/21/2022 UPDATED by CONED 08/31/2021  
0130 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH 3200 MW  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

## PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Sat 03/26/2022 to Mon 03/28/2022  
0001 2200  
Work scheduled by:

FWD  
(Import)  
UPNY CONED 3800 MW  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## ATHENS\_\_-PLSNTVLY\_345\_91

Sat 03/26/2022 to Sun 05/01/2022  
0001 Continuous 2200  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED 3800 MW  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PLSNTVLY\_345KV\_RNS4

FWD

Sat 03/26/2022 to Sun 05/01/2022

(Import)

0001 Continuous 2200

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### PLSNTVLY-WOOD\_ST\_345\_F31

FWD

Tue 03/29/2022 to Wed 03/30/2022

(Import)

0001 Continuous 2200

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### LINDN\_CG-LNDVFT\_345\_V-3022

FWD

REV

Sun 04/03/2022 to Sat 04/09/2022

(Import) (Export)

1400 Continuous 1400

SCH - PJM\_VFT

**0 MW**

**0 MW**

Impacts Total Transfer Capability 315 MW 315 MW

TTC with All Lines In Service 315 MW 315 MW

Work scheduled by: PJM

### SPRNBRK\_-TREMONT\_345\_X28

FWD

Tue 04/05/2022 to Wed 04/06/2022

(Import)

0201 Continuous 0300

SPR/DUN-SOUTH

**4200 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### BUCHAN\_N-EASTVIEW\_345\_W93

FWD

Wed 04/06/2022 to Wed 04/06/2022

UPDATED

by CONED

08/19/2021

(Import)

0301 Continuous 0330

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### EASTVIEW-SPRNBRK\_345\_W79

FWD

Wed 04/06/2022 to Thu 04/07/2022

UPDATED

by CONED

08/19/2021

(Import)

0301 Continuous 0300

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### BUCHAN\_N-EASTVIEW\_345\_W93

FWD

Thu 04/07/2022 to Thu 04/07/2022

UPDATED

by CONED

08/19/2021

(Import)

0230 Continuous 0300

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### EASTVIEW-SPRNBK\_\_345\_W64

FWD

Thu 04/07/2022 to Thu 04/07/2022 UPDATED by CONED 08/31/2021

(Import)

0301 Continuous 0330

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### SPRNBK\_\_345KV\_RNS5

FWD

Thu 04/07/2022 to Thu 04/07/2022 UPDATED by CONED 08/31/2021

(Import)

0301 Continuous 0330

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### MILLWOOD-EASTVIEW\_345\_W99

FWD

Thu 04/07/2022 to Tue 04/26/2022 UPDATED by CONED 08/31/2021

(Import)

0301 Continuous 2200

UPNY CONED

**7550 MW**

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### PANNELL\_-CLAY\_\_\_\_345\_1

FWD

Mon 04/11/2022 to Fri 04/15/2022

(Import)

0700 Continuous 1530

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

### PORTER\_\_-ROTTRDAM\_230\_30

FWD

Wed 04/13/2022 to Tue 12/31/2030

(Import)

0600 Continuous 2359

CENTRAL EAST - VC

**2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

### PANNELL\_-CLAY\_\_\_\_345\_2

FWD

Mon 04/18/2022 to Fri 04/22/2022

(Import)

0700 Continuous 1530

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

### EDIC\_\_-FRASER\_\_\_\_345\_EF24-40

FWD

Thu 04/21/2022 to Tue 06/14/2022

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Sat 04/23/2022 to Tue 04/26/2022  
0001 2200

Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## EASTVIEW-SPRNBK\_\_345\_W64

Tue 04/26/2022 to Tue 04/26/2022  
2130 Continuous 2200

Work scheduled by: ConEd

UPDATED by CONED 08/31/2021

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

## SPRNBK\_\_345KV\_RNS5

Tue 04/26/2022 to Tue 04/26/2022  
2130 Continuous 2200

Work scheduled by: ConEd

UPDATED by CONED 08/31/2021

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

## PLSNTVLY-WOOD\_ST\_\_345\_F31

Wed 04/27/2022 to Fri 04/29/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

## NIAGARA\_\_345\_230\_AT4

Fri 04/29/2022 to Fri 04/29/2022  
0500 Continuous 1700

Work scheduled by: NYPA

REV  
(Export)  
SCH - OH - NY **1750 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 2000 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

Mon 05/02/2022 to Mon 05/02/2022  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

## EASTVIEW-SPRNBK\_\_345\_W79

Mon 05/02/2022 to Thu 05/05/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## ROCHESTR-PANNELL\_\_345\_RP2

Mon 05/02/2022 to Fri 05/06/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

Thu 05/05/2022 to Thu 05/05/2022  
0130 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

## SPRNBK\_-TREMONT\_\_345\_X28

Fri 05/06/2022 to Mon 05/09/2022 UPDATED by CONED 08/19/2021  
0201 Continuous 1800

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **4200 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

## FRASER\_\_345\_FRASER SVC

Mon 05/09/2022 to Fri 05/13/2022  
0800 Continuous 1700

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2935 MW**  
Impacts Total Transfer Capability 40 MW  
TTC with All Lines In Service 2975 MW

## HOMRC\_NY-MAINS\_NY\_345\_47

Fri 05/20/2022 to Fri 05/27/2022 UPDATED by PJM 11/19/2020  
0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## HOMR\_NYW-PIERC\_NY\_345\_48

Fri 05/20/2022 to Fri 05/27/2022 UPDATED by PJM 11/19/2020  
0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## NIAGARA\_-PACKARD\_\_230\_62

Sat 06/18/2022 to Sat 06/18/2022  
0500 Continuous 1700

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>700 MW</b>	<b>1550 MW</b>
Impacts Total Transfer Capability	1250 MW	150 MW
TTC with All Lines In Service	1950 MW	1700 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NIAGARA\_\_345\_230\_AT4

Tue 06/28/2022 to Wed 06/29/2022  
0500 Continuous 1700  
Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1900 MW	1400 MW
Impacts Total Transfer Capability	50 MW	300 MW
TTC with All Lines In Service	1950 MW	1700 MW

### BECK\_\_\_\_-NIAGARA\_\_230\_PA27

Tue 07/05/2022 to Sat 07/09/2022  
0500 Continuous 2100  
Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

### ROCHESTR-PANNELL\_\_345\_RP1

Mon 07/25/2022 to Fri 07/29/2022  
0500 Continuous 2100  
Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

### PANNELL\_-CLAY\_\_\_\_345\_1

Mon 09/12/2022 to Fri 09/16/2022  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD
	(Import)
WEST CENTRAL	1300 MW
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	2250 MW

### FRASER\_\_-GILBOA\_\_345\_GF5-35

Mon 09/12/2022 to Sun 09/18/2022  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	2650 MW
Impacts Total Transfer Capability	325 MW
TTC with All Lines In Service	2975 MW

### SPRNBRK\_\_345KV\_RNS5

Mon 09/19/2022 to Mon 09/19/2022 UPDATED by CONED 09/17/2020  
0001 Continuous 0030  
Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	3200 MW
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

### SPRNBRK\_-W49TH\_ST\_345\_M51

Mon 09/19/2022 to Wed 09/21/2022 UPDATED by CONED 09/17/2020  
0001 Continuous 2200  
Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	3200 MW
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW



# NYISO TRANSFER LIMITATIONS

Wednesday, September 15, 2021 to Friday, March 17, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PANNELL\_-CLAY\_\_\_\_\_345\_2

Mon 09/19/2022 to Fri 09/23/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

### SPRNBRK\_345KV\_RNS5

Wed 09/21/2022 to Wed 09/21/2022  
2130 Continuous 2200

Work scheduled by: ConEd

UPDATED by CONED 09/17/2020

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

### SPRNBRK\_-W49TH\_ST\_345\_M51

Sat 10/01/2022 to Mon 10/17/2022  
0001 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 08/01/2020

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

### SPRNBRK\_345KV\_RNS5

Sat 10/01/2022 to Mon 10/17/2022  
0001 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 08/01/2020

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

### GILBOA\_-N.SCTLND\_345\_GNS-1

Mon 10/31/2022 to Mon 11/28/2022  
0500 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2520 MW**  
Impacts Total Transfer Capability 455 MW  
TTC with All Lines In Service 2975 MW

### LEEDS\_\_\_\_\_345KV\_R94301

Mon 10/31/2022 to Mon 11/28/2022  
0500 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### MARCY\_-N.SCTLND\_345\_18

Mon 10/31/2022 to Mon 11/28/2022  
0500 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **1470 MW**  
Impacts Total Transfer Capability 1505 MW  
TTC with All Lines In Service 2975 MW

ARR: 19

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**N.SCTLND-LEEDS\_\_\_\_345\_94**

FWD

Mon 10/31/2022 to Mon 11/28/2022

(Import)

0500 Continuous 1900

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

---

**PORTER\_\_-ROTTRDAM\_230\_30 & MARCY\_\_-N.SCTLND\_345\_18**

FWD

Mon 10/31/2022 to Mon 11/28/2022

(Import)

0500 1900

CENTRAL EAST - VC

**1300 MW**

Impacts Total Transfer Capability 1675 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

---

**PORTER\_\_-ROTTRDAM\_230\_31 & MARCY\_\_-N.SCTLND\_345\_18**

FWD

Mon 10/31/2022 to Mon 11/28/2022

(Import)

0500 1900

CENTRAL EAST - VC

**1300 MW**

Impacts Total Transfer Capability 1675 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: