

# NYISO TRANSFER LIMITATIONS

Wednesday, December 22, 2021 to Friday, June 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Tue 05/31/2022 EXT FORCE by CONED 11/08/2021

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Tue 05/31/2022

0001 2359

Work scheduled by:

	FWD (Import)	REV (Export)
SCH - PJ - NY	<b>2550 MW</b>	<b>1900 MW</b>
Impacts Total Transfer Capability	300 MW	300 MW
TTC with All Lines In Service	2850 MW	2200 MW

## MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Tue 05/31/2022 EXT FORCE by CONED 11/08/2021

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## STLAWRNC-MOSES\_230\_L33P

Mon 04/30/2018 to Tue 05/31/2022 EXT FORCE by IESO 11/04/2021

0456 Continuous 1600

Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## NEWBRIDGE\_345\_138\_BK\_1

Wed 09/02/2020 to Mon 08/01/2022 EXT FORCE by LI 12/10/2021

1807 Continuous 2359

Work scheduled by: LI

	FWD (Import)
SCH - PJM_NEPTUNE	<b>375 MW</b>
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

## NIAGARA\_-KINTIGH\_345\_NS1-38

Mon 10/18/2021 to Sat 12/31/2022 UPDATED by NYPA 12/05/2021

0500 Continuous 2359

Work scheduled by: NYPA

	FWD (Import)
DYSINGER EAST	<b>1700 MW</b>
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

## BUCHAN\_S-MILLWOOD\_345\_W97

Mon 11/01/2021 to Fri 12/24/2021 EXTENDED by CE 12/21/2021

0001 Continuous 0200

Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	<b>7680 MW</b>
Impacts Total Transfer Capability	135 MW
TTC with All Lines In Service	7815 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 22, 2021 to Friday, June 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-IMO-NYISO_LIMIT_1750</b>						FWD
Mon 11/01/2021	to	Sat 04/30/2022	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				<b>2050 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 2300 MW
<b>SCH-NYISO-IMO_LIMIT_1600</b>						REV
Mon 11/01/2021	to	Sat 04/30/2022	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Export)
0001	Continuous	2359				<b>1900 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability 100 MW
						TTC with All Lines In Service 2000 MW
<b>SCH-NYISO-IMO_LIMIT_1200</b>						REV
Wed 11/03/2021	to	Fri 12/17/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>12/15/2021</u>	(Export)
0800	Continuous	0600				<b>1500 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 2000 MW
<b>SCH-IMO-NYISO_LIMIT_1550</b>						FWD
Fri 11/12/2021	to	Fri 12/17/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>12/15/2021</u>	(Import)
1201	Continuous	0600				<b>1850 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability 450 MW
						TTC with All Lines In Service 2300 MW
<b>NEPTUNE_-DUFFYAVE_345_NEPTUNE</b>						FWD
Mon 11/29/2021	to	Fri 12/17/2021	<u>UPDATED</u>	<u>by PJM</u>	<u>09/15/2021</u>	(Import)
0600	Continuous	1600				<b>0 MW</b>
Work scheduled by: PJM						Impacts Total Transfer Capability 660 MW
						TTC with All Lines In Service 660 MW
<b>NEWBRDGE-DUFFYAVE_345_501</b>						FWD
Mon 11/29/2021	to	Fri 12/17/2021	<u>UPDATED</u>	<u>by PJM</u>	<u>09/15/2021</u>	(Import)
0600	Continuous	1600				<b>0 MW</b>
Work scheduled by: PJM						Impacts Total Transfer Capability 660 MW
						TTC with All Lines In Service 660 MW
<b>NEWBRDGE_345_138_BK_2</b>						FWD
Mon 11/29/2021	to	Fri 12/17/2021	<u>UPDATED</u>	<u>by PJM</u>	<u>09/15/2021</u>	(Import)
0600	Continuous	1600				<b>375 MW</b>
Work scheduled by: PJM						Impacts Total Transfer Capability 285 MW
						TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 22, 2021 to Friday, June 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HURLYAVE-ROSETON\_\_345\_303

FWD

Mon 11/29/2021 to Fri 12/17/2021

UPDATEDby CH10/07/2021

(Import)

0800 Continuous 1600

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: CHGE

## MOSES\_\_-ADIRNDCK\_230\_MAI

FWD

Wed 12/01/2021 to Thu 12/23/2021

UPDATEDby NYPA12/13/2021

(Import)

0700 Continuous 1500

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## KINTIGH\_-STA\_255\_\_345\_SH1-39

FWD

Wed 12/08/2021 to Sat 12/31/2022

UPDATEDby NYSEG12/14/2021

(Import)

2000 Continuous 2359

DYSINGER EAST

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYSEG

## DYSINGER-KINTIGH\_\_345\_39 & DYSINGER-STA\_255\_\_345\_DH1

FWD

Tue 12/14/2021 to Sun 01/16/2022

(Import)

1129 1900

DYSINGER EAST

**2650 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 3150 MW

Work scheduled by:

## DYSINGER-STA\_255\_\_345\_DH1

FWD

Tue 12/14/2021 to Sun 01/16/2022

FORCEDby NYISO12/14/2021

(Import)

1129 Continuous 1900

DYSINGER EAST

**2550 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYISO

## BUCHAN\_S-MILLWOOD\_345\_W98

FWD

Thu 12/16/2021 to Fri 12/24/2021

EXTENDEDby CE12/21/2021

(Import)

0201 Continuous 0200

UPNY CONED

**7680 MW**

Impacts Total Transfer Capability 135 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## LADENTWN-BUCHAN\_S\_345\_Y88

FWD

Thu 12/16/2021 to Fri 12/24/2021

EXTENDEDby CE12/21/2021

(Import)

0201 Continuous 0200

UPNY CONED

**7560 MW**

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Wednesday, December 22, 2021 to Friday , June 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-TREMONT__345_X28				FWD	
Fri 12/17/2021	to	Fri 12/17/2021		(Import)	
0001	Continuous	1800		SPR/DUN-SOUTH	4200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	4600 MW
LEEDS__345_LEEDS SVC				FWD	
Fri 12/17/2021	to	Wed 12/22/2021	<u>EXT FORCE</u> <u>by NGRID</u> <u>12/20/2021</u>	(Import)	
0226	Continuous	1618		CENTRAL EAST - VC	2950 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	25 MW
				TTC with All Lines In Service	2975 MW
PIERCBRK-FIVEMILE_345_37				FWD	
Fri 12/17/2021	to	Fri 12/17/2021		(Import)	
0600	Continuous	1137		SCH - PJ - NY	2700 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	150 MW
				TTC with All Lines In Service	2850 MW
SCH-IMO-NYISO_LIMIT_1550				FWD	
Fri 12/17/2021	to	Thu 12/23/2021		(Import)	
0601	Continuous	1500		SCH - OH - NY	1850 MW
Work scheduled by: IESO				Impacts Total Transfer Capability	450 MW
				TTC with All Lines In Service	2300 MW
SCH-NYISO-IMO_LIMIT_1400				REV	
Fri 12/17/2021	to	Thu 12/23/2021		(Export)	
0601	Continuous	1500		SCH - OH - NY	1700 MW
Work scheduled by: IESO				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	2000 MW
BERKSHIR-ALPS__345_393				FWD	REV
Fri 12/17/2021	to	Fri 12/17/2021	<u>UPDATED</u> <u>by ISONE</u> <u>12/15/2021</u>	(Import)	(Export)
0800	Daily(No Weekends)	1700		SCH - NE - NY	1100 MW 1700 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	300 MW 100 MW
				TTC with All Lines In Service	1400 MW 1800 MW
BERKSHIR-ALPS__345_393				FWD	REV
Fri 12/17/2021	to	Fri 12/17/2021	<u>UPDATED</u> <u>by ISONE</u> <u>12/15/2021</u>	(Import)	(Export)
0800	Daily(No Weekends)	1700		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 22, 2021 to Friday, June 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N.SCTLND-ALPS_____345_2					FWD	
Fri 12/17/2021	to	Fri 12/17/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>12/15/2021</u>	(Import)
0800	Daily(No Weekends)	1700				900 MW
Work scheduled by: NGrid					SCH - NE - NY	Impacts Total Transfer Capability
					TTC with All Lines In Service	1400 MW
N.SCTLND-ALPS_____345_2					FWD	REV
Fri 12/17/2021	to	Fri 12/17/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>12/15/2021</u>	(Import) (Export)
0800	Daily(No Weekends)	1700				100 MW 100 MW
Work scheduled by: NGrid					SCH - NPX_1385	Impacts Total Transfer Capability
					TTC with All Lines In Service	200 MW 200 MW
SCH-NE-NYISO_LIMIT_900					FWD	
Fri 12/17/2021	to	Fri 12/17/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>12/15/2021</u>	(Import)
0800	Daily(No Weekends)	1700				1100 MW
Work scheduled by: NGrid					SCH - NE - NY	Impacts Total Transfer Capability
					TTC with All Lines In Service	300 MW 1400 MW
SCH-NYISO-NE_LIMIT_800						REV
Fri 12/17/2021	to	Fri 12/17/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>12/15/2021</u>	(Export)
0800	Daily(No Weekends)	1700				1000 MW
Work scheduled by: NGrid					SCH - NE - NY	Impacts Total Transfer Capability
					TTC with All Lines In Service	800 MW 1800 MW
DUNWODIE-MOTTHAVN_345_71					FWD	
Fri 12/17/2021	to	Fri 12/24/2021	<u>EXT FORCE</u>	<u>by CONED</u>	<u>12/20/2021</u>	(Import)
2304	Continuous	2359				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	Impacts Total Transfer Capability
					TTC with All Lines In Service	800 MW 4600 MW
SCH-NYISO-IMO_LIMIT_1200						REV
Sat 12/18/2021	to	Sat 12/18/2021				(Export)
0900	Continuous	1600				1500 MW
Work scheduled by: IESO					SCH - OH - NY	Impacts Total Transfer Capability
					TTC with All Lines In Service	500 MW 2000 MW
DUNWODIE_345KV_3					FWD	
Sat 12/18/2021	to	Fri 12/24/2021	<u>EXT FORCE</u>	<u>by CONED</u>	<u>12/20/2021</u>	(Import)
2306	Continuous	2359				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	Impacts Total Transfer Capability
					TTC with All Lines In Service	800 MW 4600 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## DUNWODIE\_345KV\_5

Sat 12/18/2021 to Fri 12/24/2021 EXT FORCE by CONED 12/20/2021

2308 Continuous 2359

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

## CHAT\_DC\_GC1

Sun 12/19/2021 to Sun 12/19/2021

0001 Continuous 0200

Work scheduled by: HQ

FWD

(Import)

MOSES SOUTH

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC1

Sun 12/19/2021 to Sun 12/19/2021

0001 Continuous 0200

Work scheduled by: HQ

REV

(Export)

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

## CHAT\_DC\_GC1 &amp; CHAT\_DC\_GC2

Sun 12/19/2021 to Sun 12/19/2021

0001 0200

Work scheduled by:

FWD

(Import)

MOSES SOUTH

**2550 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC1 &amp; CHAT\_DC\_GC2

Sun 12/19/2021 to Sun 12/19/2021

0001 0200

Work scheduled by:

FWD

(Import) (Export)

SCH - HQ - NY

**1370 MW 0 MW**

Impacts Total Transfer Capability 130 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

## CHAT\_DC\_GC2

Sun 12/19/2021 to Sun 12/19/2021

0001 Continuous 0200

Work scheduled by: HQ

FWD

(Import)

MOSES SOUTH

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC2

Sun 12/19/2021 to Sun 12/19/2021

0001 Continuous 0200

Work scheduled by: HQ

REV

(Export)

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 22, 2021 to Friday, June 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-HQ-NYISO\_LIMIT\_1150

Sun 12/19/2021 to Sun 12/19/2021  
0001 Continuous 0200  
Work scheduled by: HQ

FWD  
(Import)  
SCH - HQ - NY **1150 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 1500 MW

## SCH-NE-NYISO\_LIMIT\_700

Sun 12/19/2021 to Thu 12/23/2021  
2300 Daily 0659  
Work scheduled by: ISONE

FWD  
(Import)  
SCH - NE - NY **900 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1400 MW

## SCH-NYISO-NE\_LIMIT\_1600

Sun 12/19/2021 to Thu 12/23/2021  
2300 Daily 0659  
Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY **1800 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 1800 MW

## MILLWOOD\_345KV\_18

Mon 12/20/2021 to Mon 12/20/2021 EXTENDED by CE 12/21/2021  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

## BECK\_\_\_\_-NIAGARA\_230\_PA27

Mon 12/20/2021 to Tue 12/21/2021 UPDATED by NYPA 12/21/2021  
0430 Continuous 1700  
Work scheduled by: NYPA

FWD  
(Import)  
SCH - OH - NY **2100 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 2300 MW

## FRASER\_\_-GILBOA\_\_345\_GF5-35

Mon 12/20/2021 to Tue 12/21/2021 UPDATED by NYPA 12/17/2021  
0800 Continuous 1700  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

## LEEDS\_\_\_\_345\_LEEDS SVC &amp; MARCY\_SO\_SERIES\_COMP\_I/S

Mon 12/20/2021 to Tue 12/21/2021  
0800 1700  
Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **2715 MW**  
Impacts Total Transfer Capability 260 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 22, 2021 to Friday, June 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MARCY\_SO\_SERIES\_COMP\_I/S

FWD

Mon 12/20/2021 to Tue 12/21/2021

(Import)

0800 Continuous 1700

CENTRAL EAST - VC

**2740 MW**

Impacts Total Transfer Capability 235 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYISO

## HOMR\_NYW-PIERC\_NY\_345\_48

Tue 12/21/2021 to Tue 12/21/2021

0800 Continuous 1600

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYSEG

## FRASER\_\_\_345\_FRASER SVC

FWD

Wed 12/22/2021 to Fri 12/24/2021

**CANCELLED by NYISO 12/17/2021**

(Import)

0800 Continuous 2359

CENTRAL EAST - VC

**2935 MW**

Impacts Total Transfer Capability 40 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

## LEEDS\_\_\_-PLSNTVLY\_345\_92

FWD

Mon 12/27/2021 to Mon 12/27/2021

(Import)

0830 Daily(No Weekends) 1500

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

## LEEDS\_\_\_-ATHENS\_\_\_345\_95

FWD

Tue 12/28/2021 to Tue 12/28/2021

**UPDATED by CE 12/09/2021**

(Import)

0900 Daily(No Weekends) 1400

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

## LEEDS\_\_\_345KV\_R395

FWD

Tue 12/28/2021 to Tue 12/28/2021

**UPDATED by CE 12/09/2021**

(Import)

0900 Daily(No Weekends) 1400

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

## SHOR\_NPX-SHOREHAM\_138\_CSC

FWD

REV

Wed 12/29/2021 to Wed 12/29/2021

(Import) (Export)

0800 Continuous 1800

SCH - NPX\_CSC

**0 MW****0 MW**

Impacts Total Transfer Capability 330 MW 330 MW

TTC with All Lines In Service 330 MW 330 MW

Work scheduled by: LI



# NYISO TRANSFER LIMITATIONS

Wednesday, December 22, 2021 to Friday, June 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## EDIC - FRASER 345 EF24-40

FWD

Wed 12/29/2021 to Thu 12/30/2021 UPDATED by NYSEG 12/17/2021

(Import)

0830 Continuous 1500

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

## SCH-IMO-NYISO\_LIMIT\_1550

FWD

Mon 01/03/2022 to Sat 04/30/2022

(Import)

0700 Continuous 2359

SCH - OH - NY

**1850 MW**

Impacts Total Transfer Capability 450 MW

TTC with All Lines In Service 2300 MW

Work scheduled by: IESO

## SCH-NYISO-IMO\_LIMIT\_1400

REV

Mon 01/03/2022 to Sat 04/30/2022

(Export)

0700 Continuous 2359

SCH - OH - NY

**1700 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 2000 MW

Work scheduled by: IESO

## MOSES - ADIRNDCK 230 MA1

FWD

Mon 01/03/2022 to Tue 05/31/2022 UPDATED by NYPA 12/13/2021

(Import)

0700 Continuous 1300

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## SAND\_BAR-PLATSBURG\_115\_PV20

Tue 01/04/2022 to Thu 01/06/2022

0700 Continuous 1530

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYPA

## FRASER 345 FRASER SVC

FWD

Tue 01/04/2022 to Mon 02/28/2022 UPDATED by NYPA 05/25/2021

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

**2935 MW**

Impacts Total Transfer Capability 40 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

## SCH-HQ\_CEDARS-NYISO\_LIMIT\_80

FWD

Wed 01/05/2022 to Wed 01/05/2022

(Import)

0800 Continuous 1700

SCH - HQ\_CEDARS

**80 MW**

Impacts Total Transfer Capability 199 MW

TTC with All Lines In Service 279 MW

Work scheduled by: HQ

**NYISO TRANSFER LIMITATIONS**

Wednesday, December 22, 2021 to Friday, June 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOPATCON-RAMAPO___500_5018			FWD	REV
Thu 01/06/2022	to	Mon 01/10/2022	(Import)	(Export)
0200	Continuous	1900	SCH - PJ - NY	<b>1650 MW 1200 MW</b>
Work scheduled by: PJM			Impacts Total Transfer Capability	1200 MW 1000 MW
			TTC with All Lines In Service	2850 MW 2200 MW
HOPATCON-RAMAPO___500_5018			FWD	
Thu 01/06/2022	to	Mon 01/10/2022	(Import)	
0200	Continuous	1900	UPNY CONED	<b>7480 MW</b>
Work scheduled by: PJM			Impacts Total Transfer Capability	335 MW
			TTC with All Lines In Service	7815 MW
RAMAPO___345_345_PAR3500			FWD	REV
Thu 01/06/2022	to	Mon 01/10/2022	(Import)	(Export)
0200	Continuous	1900	SCH - PJ - NY	<b>2500 MW 1250 MW</b>
Work scheduled by: PJM			Impacts Total Transfer Capability	350 MW 950 MW
			TTC with All Lines In Service	2850 MW 2200 MW
RAMAPO___345_345_PAR4500			FWD	REV
Thu 01/06/2022	to	Mon 01/10/2022	(Import)	(Export)
0200	Continuous	1900	SCH - PJ - NY	<b>2500 MW 1250 MW</b>
Work scheduled by: PJM			Impacts Total Transfer Capability	350 MW 950 MW
			TTC with All Lines In Service	2850 MW 2200 MW
RAMAPO___500_345_BK 1500			FWD	REV
Thu 01/06/2022	to	Mon 01/10/2022	(Import)	(Export)
0200	Continuous	1900	SCH - PJ - NY	<b>1650 MW 1200 MW</b>
Work scheduled by: PJM			Impacts Total Transfer Capability	1200 MW 1000 MW
			TTC with All Lines In Service	2850 MW 2200 MW
RAMAPO___500_345_BK 1500			FWD	
Thu 01/06/2022	to	Mon 01/10/2022	(Import)	
0200	Continuous	1900	UPNY CONED	<b>7480 MW</b>
Work scheduled by: PJM			Impacts Total Transfer Capability	335 MW
			TTC with All Lines In Service	7815 MW
BEAR SWP-EASTOVER_230_E205W				
Mon 01/10/2022	to	Thu 01/13/2022	SCH - NE - NY	
0600	Continuous	1700	Impacts Total Transfer Capability	
Work scheduled by: ISONE			TTC with All Lines In Service	

# NYISO TRANSFER LIMITATIONS

Wednesday, December 22, 2021 to Friday , June 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HURLYAVE-ROSETON\_\_345\_303

FWD

Tue 01/11/2022 to Sat 01/22/2022

UPDATEDby CHGE11/30/2021

(Import)

0600 Continuous 1600

Work scheduled by: CHGE

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

## CHATGUAY-MASSENA\_\_765\_7040

FWD

Wed 01/12/2022 to Sat 01/15/2022

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH

**1550 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

## CHATGUAY-MASSENA\_\_765\_7040

FWD

REV

Wed 01/12/2022 to Sat 01/15/2022

(Import) (Export)

0700 Continuous 1530

Work scheduled by: NYPA

SCH - HQ - NY

**0 MW****0 MW**

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

## DYSINGER-KINTIGH\_\_345\_38

FWD

Mon 01/17/2022 to Thu 01/20/2022

(Import)

0500 Continuous 1900

Work scheduled by: NYSEG

DYSINGER EAST

**2500 MW**

Impacts Total Transfer Capability 650 MW

TTC with All Lines In Service 3150 MW

## NIAGARA\_-DYSINGER\_345\_ND1

FWD

Mon 01/17/2022 to Thu 01/20/2022

(Import)

0500 Continuous 1900

Work scheduled by: NYPA

DYSINGER EAST

**2650 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 3150 MW

## S.RIPLEY-DUNKIRK\_\_230\_68

Tue 01/18/2022 to Fri 02/04/2022

UPDATEDby NGRID09/24/2021

0700 Continuous 1730

Work scheduled by: NGrid

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## NIAGARA\_-STA\_255\_\_345\_NH2

FWD

Fri 01/21/2022 to Fri 03/04/2022

UPDATEDby NYPA08/20/2021

(Import)

0500 Continuous 1900

Work scheduled by: NYPA

DYSINGER EAST

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 22, 2021 to Friday, June 23, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NIAGARA\_-STA\_255\_\_345\_NH2 & KINTIGH\_-STA\_255\_\_345\_SH1-39

Fri 01/21/2022 to Fri 03/04/2022  
0500 1900

Work scheduled by:

FWD  
(Import)  
DYSINGER EAST **1250 MW**  
Impacts Total Transfer Capability 1900 MW  
TTC with All Lines In Service 3150 MW

### FIVEMILE-STOLLERD\_345\_29

Mon 01/24/2022 to Sun 01/30/2022  
0500 Continuous 1900

Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### E13THSTA-FARRAGUT\_345\_45

Thu 01/27/2022 to Fri 01/28/2022  
0001 Continuous 0100

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### PLSNTVLY-WOOD\_ST\_\_345\_F30

Sat 01/29/2022 to Sat 01/29/2022  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLY\_345KV\_RNS5

Sat 01/29/2022 to Sat 01/29/2022  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLY-WOOD\_ST\_\_345\_F30

Wed 02/02/2022 to Wed 02/02/2022  
1930 Continuous 2000

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLY\_345KV\_RNS5

Wed 02/02/2022 to Wed 02/02/2022  
1930 Continuous 2000

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 22, 2021 to Friday, June 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_\_PACKARD\_\_230\_61

Thu 02/03/2022 to Sat 02/12/2022  
0615 Continuous 1900

UPDATED by NGRID 12/03/2021

Work scheduled by: NGrid

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1400 MW</b>	<b>1850 MW</b>
Impacts Total Transfer Capability	900 MW	150 MW
TTC with All Lines In Service	2300 MW	2000 MW

## MARCY\_\_N.SCTLND\_345\_18

Tue 02/08/2022 to Wed 02/09/2022  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
CENTRAL EAST - VC	<b>1470 MW</b>
Impacts Total Transfer Capability	1505 MW
TTC with All Lines In Service	2975 MW

## PLSNTVLY\_345KV\_RNS4

Sat 02/12/2022 to Sat 02/12/2022  
0600 Continuous 0630

UPDATED by CONED 11/12/2021

Work scheduled by: NGrid

	FWD
	(Import)
UPNY CONED	<b>3800 MW</b>
Impacts Total Transfer Capability	4015 MW
TTC with All Lines In Service	7815 MW

## ATHENS\_\_PLSNTVLY\_345\_91

Sat 02/12/2022 to Wed 02/16/2022  
0600 Continuous 1900

UPDATED by CONED 11/12/2021

Work scheduled by: NGrid

	FWD
	(Import)
UPNY CONED	<b>3800 MW</b>
Impacts Total Transfer Capability	4015 MW
TTC with All Lines In Service	7815 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

Sun 02/13/2022 to Mon 02/14/2022  
0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>4350 MW</b>
Impacts Total Transfer Capability	3465 MW
TTC with All Lines In Service	7815 MW

## RAMAPO\_\_BUCHAN\_N\_345\_Y94

Sun 02/13/2022 to Mon 02/14/2022  
0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>7580 MW</b>
Impacts Total Transfer Capability	235 MW
TTC with All Lines In Service	7815 MW

## MILLWOOD\_345KV\_18

Mon 02/14/2022 to Tue 02/15/2022  
0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>4350 MW</b>
Impacts Total Transfer Capability	3465 MW
TTC with All Lines In Service	7815 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 22, 2021 to Friday, June 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## EDIC\_\_\_\_-FRASER\_\_\_\_345\_EF24-40

FWD

Mon 02/14/2022 to Tue 02/22/2022

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

## PLSNTVLY\_345KV\_RNS4

FWD

Wed 02/16/2022 to Wed 02/16/2022

(Import)

1830 Continuous 1900

UPDATEDby CONED 11/12/2021

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

## PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

FWD

Thu 02/17/2022 to Sat 02/19/2022

(Import)

0001 2200

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by:

## LEEDS\_\_\_\_-PLSNTVLY\_345\_92

FWD

Thu 02/17/2022 to Fri 03/25/2022

(Import)

0001 Continuous 2200

UPDATEDby NYISO 11/15/2021

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## PLSNTVLY\_345KV\_RNS5

FWD

Thu 02/17/2022 to Fri 03/25/2022

(Import)

0001 Continuous 2200

UPDATEDby NYISO 11/15/2021

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## PLSNTVLY-WOOD\_ST\_\_345\_F30

FWD

Sun 02/20/2022 to Mon 02/21/2022

(Import)

0001 Continuous 2200

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## EASTVIEW-SPRNBK\_\_345\_W64

FWD

Sun 02/20/2022 to Mon 02/21/2022

(Import)

2000 Continuous 2359

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Wednesday, December 22, 2021 to Friday, June 23, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MILLWOOD-EASTVIEW\_345\_W99

Sun 02/20/2022 to Mon 02/21/2022  
2000 Continuous 2359  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7550 MW**  
Impacts Total Transfer Capability 265 MW  
TTC with All Lines In Service 7815 MW

### SPRNBK\_345KV\_RNS5

Sun 02/20/2022 to Mon 02/21/2022  
2000 Continuous 2359  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

### EASTVIEW-SPRNBK\_345\_W64

Tue 02/22/2022 to Tue 02/22/2022 UPDATED by CONED 08/31/2021  
0001 Continuous 0030  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

### SPRNBK\_345KV\_RNS5

Tue 02/22/2022 to Tue 02/22/2022 UPDATED by CONED 08/31/2021  
0001 Continuous 0030  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

### MILLWOOD-EASTVIEW\_345\_W99

Tue 02/22/2022 to Mon 03/21/2022 UPDATED by CONED 08/31/2021  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7550 MW**  
Impacts Total Transfer Capability 265 MW  
TTC with All Lines In Service 7815 MW

### MARCY-EDIC\_345\_UE1-7

Wed 02/23/2022 to Mon 02/28/2022  
0700 Continuous 1530  
Work scheduled by: NYPA

ARR: 19&16

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

### W49TH\_ST-E13THSTA\_345\_M54

Sun 02/27/2022 to Wed 03/02/2022  
0201 Continuous 2230  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 22, 2021 to Friday, June 23, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### FIVEMILE-STOLLERD\_345\_29

Tue 03/01/2022 to Tue 04/12/2022  
0500 Continuous 1900

Work scheduled by: NYSEG

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### PORTER\_-ROTTDAM\_230\_31

Tue 03/01/2022 to Tue 12/31/2030  
0600 Continuous 2359

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC

**2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

### N.SCTLND-LEEDS\_345\_93

Tue 03/01/2022 to Mon 03/28/2022  
0700 Continuous 1900

Work scheduled by: NGrid

UPDATED

by NGRID 11/15/2021

FWD

(Import)

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

### EDIC\_-N.SCTLND\_345\_14

Tue 03/01/2022 to Tue 04/12/2022  
0700 Continuous 1900

Work scheduled by: NGrid

UPDATED

by NGRID 11/15/2021

FWD

(Import)

CENTRAL EAST - VC

**1670 MW**

Impacts Total Transfer Capability 1305 MW

TTC with All Lines In Service 2975 MW

### EDIC\_-N.SCTLND\_345\_14 & PORTER\_-ROTTDAM\_230\_31

Tue 03/01/2022 to Tue 04/12/2022  
0700 1900

Work scheduled by:

FWD

(Import)

CENTRAL EAST - VC

**1500 MW**

Impacts Total Transfer Capability 1475 MW

TTC with All Lines In Service 2975 MW

### FRASANX-COOPERS\_345\_UCC2-41

Tue 03/01/2022 to Wed 04/20/2022  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD

(Import)

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

### MARCY\_-FRASANX\_345\_UCC2-41

Tue 03/01/2022 to Wed 04/20/2022  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD

(Import)

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW



# NYISO TRANSFER LIMITATIONS

Wednesday, December 22, 2021 to Friday, June 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>N.SCTLND-ALPS_____345_2</b>						FWD	
Tue 03/01/2022	to	Fri 06/24/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>11/15/2021</u>	(Import)	
0700	Continuous	1900				<b>900 MW</b>	
Work scheduled by: NGrid						SCH - NE - NY	500 MW
						Impacts Total Transfer Capability	1400 MW
						TTC with All Lines In Service	
<b>N.SCTLND-ALPS_____345_2</b>						FWD	REV
Tue 03/01/2022	to	Fri 06/24/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>11/15/2021</u>	(Import) (Export)	
0700	Continuous	1900				<b>100 MW 100 MW</b>	
Work scheduled by: NGrid						SCH - NPX_1385	100 MW 100 MW
						Impacts Total Transfer Capability	200 MW 200 MW
						TTC with All Lines In Service	
<b>GOETHALS_345KV_5</b>						STATEN ISLAND	
Sat 03/05/2022	to	Mon 04/04/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>03/26/2021</u>	Impacts Total Transfer Capability	
0001	Continuous	0200				TTC with All Lines In Service	
Work scheduled by: ConEd							
<b>LINDEN__-GOETHALS_230_A2253</b>						SCH - PJ - NY	
Sat 03/05/2022	to	Mon 04/04/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>03/26/2021</u>	Impacts Total Transfer Capability	
0001	Continuous	0200				TTC with All Lines In Service	
Work scheduled by: ConEd							
<b>LINDEN__-GOETHALS_230_A2253 &amp; HUDSONP_-FARRAGUT_345_B3402</b>						FWD	REV
Sat 03/05/2022	to	Mon 04/04/2022				(Import) (Export)	
0001		0200				<b>2550 MW 1900 MW</b>	
Work scheduled by:						SCH - PJ - NY	300 MW 300 MW
						Impacts Total Transfer Capability	2850 MW 2200 MW
						TTC with All Lines In Service	
<b>LINDEN__-GOETHALS_230_A2253 &amp; HUDSONP_-FARRAGUT_345_B3402 &amp; MARION__-FARRAGUT_345_C3403</b>						FWD	REV
Sat 03/05/2022	to	Mon 04/04/2022				(Import) (Export)	
0001		0200				<b>2550 MW 1900 MW</b>	
Work scheduled by:						SCH - PJ - NY	300 MW 300 MW
						Impacts Total Transfer Capability	2850 MW 2200 MW
						TTC with All Lines In Service	
<b>LINDEN__-GOETHALS_230_A2253 &amp; MARION__-FARRAGUT_345_C3403</b>						FWD	REV
Sat 03/05/2022	to	Mon 04/04/2022				(Import) (Export)	
0001		0200				<b>2550 MW 1900 MW</b>	
Work scheduled by:						SCH - PJ - NY	300 MW 300 MW
						Impacts Total Transfer Capability	2850 MW 2200 MW
						TTC with All Lines In Service	

# NYISO TRANSFER LIMITATIONS

Wednesday, December 22, 2021 to Friday, June 23, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### INDPDNCE-SCRIBA\_\_345\_25

Thu 03/10/2022 to Wed 03/16/2022  
0800 Continuous 1800

Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

### NIAGARA\_-DYSINGER\_345\_ND1

Fri 03/11/2022 to Fri 03/11/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2650 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 3150 MW

### PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Thu 03/17/2022 to Sun 03/20/2022  
0100 2200

Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLY-WOOD\_ST\_\_345\_F30

Mon 03/21/2022 to Wed 03/23/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

### EASTVIEW-SPRNBRK\_\_345\_W64

Mon 03/21/2022 to Mon 03/21/2022 **UPDATED by CONED 08/31/2021**  
0130 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

### SPRNBRK\_\_345KV\_RNS5

Mon 03/21/2022 to Mon 03/21/2022 **UPDATED by CONED 08/31/2021**  
0130 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

### NIAGARA\_-STA\_255\_\_345\_NH2

Fri 03/25/2022 to Fri 03/25/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_-STA\_255\_\_345\_NH2 & KINTIGH\_-STA\_255\_\_345\_SH1-39

Fri 03/25/2022 to Fri 03/25/2022  
0500 1700

Work scheduled by:

FWD  
(Import)  
DYSINGER EAST **1250 MW**  
Impacts Total Transfer Capability 1900 MW  
TTC with All Lines In Service 3150 MW

## PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Sat 03/26/2022 to Mon 03/28/2022  
0001 2200

Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## ATHENS\_-PLSNTVLY\_345\_91

Sat 03/26/2022 to Sun 05/01/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## PLSNTVLY\_345KV\_RNS4

Sat 03/26/2022 to Sun 05/01/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## PLSNTVLY-WOOD\_ST\_\_345\_F31

Tue 03/29/2022 to Wed 03/30/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

## LINDN\_CG-LNDVFT\_\_345\_V-3022

Sun 04/03/2022 to Sat 04/09/2022  
1400 Continuous 1400

Work scheduled by: PJM

FWD	REV
(Import)	(Export)
SCH - PJM_VFT	<b>0 MW</b> <b>0 MW</b>
Impacts Total Transfer Capability	315 MW 315 MW
TTC with All Lines In Service	315 MW 315 MW

## SPRNBK\_-TREMONT\_\_345\_X28

Tue 04/05/2022 to Wed 04/06/2022  
0201 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **4200 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 22, 2021 to Friday , June 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## BUCHAN\_N-EASTVIEW\_345\_W93

FWD

Wed 04/06/2022 to Wed 04/06/2022 UPDATED by CONED 08/19/2021

(Import)

0301 Continuous 0330

UPNY CONED

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## EASTVIEW-SPRNBK\_\_345\_W79

FWD

Wed 04/06/2022 to Thu 04/07/2022 UPDATED by CONED 08/19/2021

(Import)

0301 Continuous 0300

UPNY CONED

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## BUCHAN\_N-EASTVIEW\_345\_W93

FWD

Thu 04/07/2022 to Thu 04/07/2022 UPDATED by CONED 08/19/2021

(Import)

0230 Continuous 0300

UPNY CONED

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## EASTVIEW-SPRNBK\_\_345\_W64

FWD

Thu 04/07/2022 to Thu 04/07/2022 UPDATED by CONED 08/31/2021

(Import)

0301 Continuous 0330

UPNY CONED

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## SPRNBK\_\_345KV\_RNS5

FWD

Thu 04/07/2022 to Thu 04/07/2022 UPDATED by CONED 08/31/2021

(Import)

0301 Continuous 0330

SPR/DUN-SOUTH

3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## MILLWOOD-EASTVIEW\_345\_W99

FWD

Thu 04/07/2022 to Tue 04/26/2022 UPDATED by CONED 08/31/2021

(Import)

0301 Continuous 2200

UPNY CONED

7550 MW

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## MOTTHAVN-RAINEY\_\_345\_Q12

FWD

Mon 04/11/2022 to Thu 04/28/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Wednesday, December 22, 2021 to Friday, June 23, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PANNELL\_-CLAY\_\_\_\_\_345\_1

Mon 04/11/2022 to Fri 04/15/2022

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

WEST CENTRAL **1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

### GOETHALS\_345KV\_5

Wed 04/13/2022 to Fri 05/13/2022

0001 Continuous 0259

Work scheduled by: ConEd

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

### PORTER\_-ROTTRDAM\_230\_30

Wed 04/13/2022 to Tue 12/31/2030

0600 Continuous 2359

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC **2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

### PANNELL\_-CLAY\_\_\_\_\_345\_2

Mon 04/18/2022 to Fri 04/22/2022

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

WEST CENTRAL **1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

### SCH-NE-NYISO\_LIMIT\_700

Tue 04/19/2022 to Fri 04/22/2022

0601 Continuous 0759

Work scheduled by: ISONE

FWD

(Import)

SCH - NE - NY **900 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1400 MW

### EDIC\_-FRASER\_\_\_\_\_345\_EF24-40

Thu 04/21/2022 to Tue 06/14/2022

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

### MARCY\_\_\_\_\_345KV\_CSC

Fri 04/22/2022 to Sat 04/23/2022

0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2925 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 22, 2021 to Friday, June 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NE-NYISO\_LIMIT\_700

Fri 04/22/2022 to Sun 04/24/2022

1601 Continuous 1800

Work scheduled by: ISONE

FWD

(Import)

SCH - NE - NY

900 MW

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1400 MW

## PLSNTVLY\_345KV\_RN5 &amp; PLSNTVLY\_345KV\_RN4

Sat 04/23/2022 to Tue 04/26/2022

0001 2200

Work scheduled by:

FWD

(Import)

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

## ROCHESTR-PANNELL\_345\_RP1

Mon 04/25/2022 to Fri 04/29/2022

0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## SAND\_BAR-PLATSBRG\_115\_PV20

Mon 04/25/2022 to Fri 04/29/2022

0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## EASTVIEW-SPRNBK\_345\_W64

Tue 04/26/2022 to Tue 04/26/2022

2130 Continuous 2200

Work scheduled by: ConEd

UPDATEDby CONED08/31/2021

FWD

(Import)

UPNY CONED

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

## SPRNBK\_345KV\_RNS5

Tue 04/26/2022 to Tue 04/26/2022

2130 Continuous 2200

Work scheduled by: ConEd

UPDATEDby CONED08/31/2021

FWD

(Import)

SPR/DUN-SOUTH

3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

## PLSNTVLY-WOOD\_ST\_345\_F31

Wed 04/27/2022 to Fri 04/29/2022

0001 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

4000 MW

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_\_345\_230\_AT4

REV

Fri 04/29/2022 to Fri 04/29/2022  
0500 Continuous 1700

Work scheduled by: NYPA

SCH - OH - NY

(Export)

Impacts Total Transfer Capability

1750 MW

TTC with All Lines In Service

250 MW

2000 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

FWD

Mon 05/02/2022 to Mon 05/02/2022  
0001 Continuous 0030

Work scheduled by: ConEd

(Import)

UPNY CONED

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

## EASTVIEW-SPRNBK\_\_345\_W79

FWD

Mon 05/02/2022 to Thu 05/05/2022  
0001 Continuous 0200

Work scheduled by: ConEd

(Import)

UPNY CONED

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

## ROCHESTR-PANNELL\_\_345\_RP2

FWD

Mon 05/02/2022 to Fri 05/06/2022  
0500 Continuous 1700

Work scheduled by: NYPA

(Import)

DYSINGER EAST

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

FWD

Thu 05/05/2022 to Thu 05/05/2022  
0130 Continuous 0200

Work scheduled by: ConEd

(Import)

UPNY CONED

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

## SPRNBK\_-TREMONT\_\_345\_X28

FWD

Fri 05/06/2022 to Mon 05/09/2022  
0201 Continuous 1800

Work scheduled by: ConEd

(Import)

SPR/DUN-SOUTH

4200 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

## FRASER\_\_345\_FRASER SVC

FWD

Mon 05/09/2022 to Fri 05/13/2022  
0800 Continuous 1700

Work scheduled by: NYSEG

(Import)

CENTRAL EAST - VC

2935 MW

Impacts Total Transfer Capability 40 MW

TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 22, 2021 to Friday, June 23, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PLSNTVLE-DUNWODIE\_345\_W89

Fri 05/13/2022 to Fri 05/13/2022  
0200 Continuous 0230  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

### EFISHKIL-WOOD\_ST\_345\_F38

Fri 05/13/2022 to Fri 05/13/2022  
0200 Continuous 0430  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

### WOOD\_ST-PLSNTVLE\_345\_Y86

Fri 05/13/2022 to Fri 05/13/2022  
0200 Continuous 0430  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7210 MW**  
Impacts Total Transfer Capability 605 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLE-DUNWODIE\_345\_W89

Fri 05/13/2022 to Fri 05/13/2022  
0400 Continuous 0430  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 05/16/2022 to Fri 05/27/2022  
0600 Continuous 1800  
Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_CSC **0 MW 0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

### DUNWODIE-MOTTHAVN\_345\_71

Thu 05/19/2022 to Fri 05/20/2022  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### DUNWODIE\_345KV\_3

Thu 05/19/2022 to Fri 05/20/2022  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW



# NYISO TRANSFER LIMITATIONS

Wednesday, December 22, 2021 to Friday, June 23, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_5

FWD

Thu 05/19/2022 to Fri 05/20/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### HOMRC\_NY-MAINS\_NY\_345\_47

Fri 05/20/2022 to Fri 05/27/2022

UPDATED

by PJM

11/19/2020

0800 Continuous 1600

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: PJM

### HOMR\_NYW-PIERC\_NY\_345\_48

Fri 05/20/2022 to Fri 05/27/2022

UPDATED

by PJM

11/19/2020

0800 Continuous 1600

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: PJM

### MARCY\_-EDIC\_345\_UE1-7

FWD

Sat 05/21/2022 to Sat 05/21/2022

(Import)

0700 Continuous 1730

OSWEGO EXPORT

5250 MW

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

ARR: 19&16

### PORTER\_-ROTTRDAM\_230\_30 & VOLNEY\_-MARCY\_345\_19

FWD

Sat 05/21/2022 to Sat 05/21/2022

(Import)

0700 1730

CENTRAL EAST - VC

2655 MW

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

### PORTER\_-ROTTRDAM\_230\_31 & VOLNEY\_-MARCY\_345\_19

FWD

Sat 05/21/2022 to Sat 05/21/2022

(Import)

0700 1730

CENTRAL EAST - VC

2655 MW

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

### VOLNEY\_-MARCY\_345\_19

FWD

Sat 05/21/2022 to Sat 05/21/2022

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

2825 MW

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

ARR: 19

# NYISO TRANSFER LIMITATIONS

Wednesday, December 22, 2021 to Friday, June 23, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

VOLNEY__-MARCY____345_19			FWD	
Sat 05/21/2022	to	Sat 05/21/2022	(Import)	
0700	Continuous	1730	OSWEGO EXPORT	4900 MW
Work scheduled by: NYPA		ARR: 19	Impacts Total Transfer Capability	350 MW
			TTC with All Lines In Service	5250 MW
MOSES__-ADIRNDCK_230_MA2			FWD	
Wed 06/01/2022	to	Tue 11/29/2022	(Import)	
0700	Continuous	1800	MOSES SOUTH	2100 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW
			TTC with All Lines In Service	3150 MW
NIAGARA_-DYSINGER_345_ND1			FWD	
Mon 06/13/2022	to	Fri 06/17/2022	(Import)	
0500	Continuous	2100	DYSINGER EAST	2650 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	3150 MW
NIAGARA_-PACKARD__230_62			FWD	REV
Sat 06/18/2022	to	Sat 06/18/2022	(Import)	(Export)
0500	Continuous	1700	SCH - OH - NY	700 MW 1550 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1250 MW 150 MW
			TTC with All Lines In Service	1950 MW 1700 MW
NIAGARA__345_230_AT4			FWD	REV
Tue 06/28/2022	to	Wed 06/29/2022	(Import)	(Export)
0500	Continuous	1700	SCH - OH - NY	1900 MW 1400 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	50 MW 300 MW
			TTC with All Lines In Service	1950 MW 1700 MW
BECK__-NIAGARA__230_PA27				
Tue 07/05/2022	to	Sat 07/09/2022		
0500	Continuous	2100	SCH - OH - NY	
Work scheduled by: NYPA			Impacts Total Transfer Capability	
			TTC with All Lines In Service	
NIAGARA_-DYSINGER_345_ND1			FWD	
Mon 07/11/2022	to	Fri 07/15/2022	(Import)	
0500	Continuous	1700	DYSINGER EAST	2650 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 22, 2021 to Friday, June 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## ROCHESTR-PANNELL\_\_345\_RP1

FWD

Mon 07/25/2022 to Fri 07/29/2022

(Import)

0500 Continuous 2100

DYSINGER EAST **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## NIAGARA\_-STA\_255\_\_345\_NH2

FWD

Mon 08/01/2022 to Fri 08/05/2022

(Import)

0500 Continuous 1700

DYSINGER EAST **1400 MW**

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## NIAGARA\_-STA\_255\_\_345\_NH2 & KINTIGH\_-STA\_255\_\_345\_SH1-39

FWD

Mon 08/01/2022 to Fri 08/05/2022

(Import)

0500 1700

DYSINGER EAST **1250 MW**

Impacts Total Transfer Capability 1900 MW

TTC with All Lines In Service 3150 MW

Work scheduled by:

## MARCY\_-EDIC\_\_345\_UE1-7

FWD

Sat 08/06/2022 to Sat 08/06/2022

(Import)

0500 Continuous 1830

OSWEGO EXPORT **5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

ARR: 19&amp;16

## PORTER\_-ROTTRDAM\_230\_30 & VOLNEY\_-MARCY\_\_345\_19

FWD

Sat 08/06/2022 to Sat 08/06/2022

(Import)

0500 1830

CENTRAL EAST - VC **2655 MW**

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

## PORTER\_-ROTTRDAM\_230\_31 & VOLNEY\_-MARCY\_\_345\_19

FWD

Sat 08/06/2022 to Sat 08/06/2022

(Import)

0500 1830

CENTRAL EAST - VC **2655 MW**

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

## VOLNEY\_-MARCY\_\_345\_19

FWD

Sat 08/06/2022 to Sat 08/06/2022

(Import)

0500 Continuous 1830

CENTRAL EAST - VC **2825 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

ARR: 19

# NYISO TRANSFER LIMITATIONS

Wednesday, December 22, 2021 to Friday, June 23, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### VOLNEY - MARCY 345\_19

Sat 08/06/2022 to Sat 08/06/2022  
0500 Continuous 1830

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
OSWEGO EXPORT **4900 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 5250 MW

### SAND BAR-PLATSBURG 115\_PV20

Mon 08/22/2022 to Fri 08/26/2022  
0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### ROSETON - ROCKTVERN 345\_311

Mon 08/29/2022 to Fri 09/09/2022  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 3415 MW  
TTC with All Lines In Service 7815 MW

### MOTTHAVN-RAINEY 345\_Q12

Thu 09/01/2022 to Mon 09/05/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### PANNELL - CLAY 345\_1

Mon 09/12/2022 to Fri 09/16/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

### FRASER - GILBOA 345\_GF5-35

Mon 09/12/2022 to Sun 09/18/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

### PANNELL - CLAY 345\_2

Mon 09/19/2022 to Fri 09/23/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 22, 2021 to Friday, June 23, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NIAGARA\_-DYSINGER\_345\_ND1

Mon 09/26/2022 to Fri 09/30/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2650 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 3150 MW

### SPRNBRK\_345KV\_RNS5

Sat 10/01/2022 to Mon 10/17/2022  
0001 Continuous 0300

Work scheduled by: ConEd

**CANCELLED by ConEd 12/18/2021**

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

### SPRNBRK\_-W49TH\_ST\_345\_M51

Sat 10/01/2022 to Tue 11/08/2022  
0001 Continuous 0300

Work scheduled by: ConEd

**CANCELLED by ConEd 12/18/2021**

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 10/03/2022 to Fri 10/21/2022  
0600 Continuous 1800

Work scheduled by: LI

FWD	REV
(Import)	(Export)
SCH - NPX_CSC	<b>0 MW</b> <b>0 MW</b>
Impacts Total Transfer Capability	330 MW 330 MW
TTC with All Lines In Service	330 MW 330 MW

### NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 10/10/2022 to Fri 10/14/2022  
0600 Continuous 1600

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 10/10/2022 to Fri 10/14/2022  
0600 Continuous 1600

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

### NEWBRDGE\_345\_138\_BK\_1

Mon 10/10/2022 to Fri 10/14/2022  
0600 Continuous 1600

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NEWBRIDGE\_345\_138\_BK\_2**

FWD

Mon 10/10/2022 to Fri 10/14/2022

(Import)

0600 Continuous 1600

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

**GILBOA -N.SCTLND\_345\_GNS-1**

FWD

Mon 10/31/2022 to Mon 11/28/2022

(Import)

0500 Continuous 1900

CENTRAL EAST - VC

**2520 MW**

Impacts Total Transfer Capability 455 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**LEEDS\_345KV\_R94301**

FWD

Mon 10/31/2022 to Mon 11/28/2022

(Import)

0500 Continuous 1900

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

**MARCY -N.SCTLND\_345\_18**

FWD

Mon 10/31/2022 to Mon 11/28/2022

(Import)

0500 Continuous 1900

CENTRAL EAST - VC

**1470 MW**

Impacts Total Transfer Capability 1505 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**ARR: 19****N.SCTLND-LEEDS\_345\_94**

FWD

Mon 10/31/2022 to Mon 11/28/2022

(Import)

0500 Continuous 1900

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**PORTER -ROTTRDAM\_230\_30 & MARCY -N.SCTLND\_345\_18**

FWD

Mon 10/31/2022 to Mon 11/28/2022

(Import)

0500 1900

CENTRAL EAST - VC

**1300 MW**

Impacts Total Transfer Capability 1675 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

**PORTER -ROTTRDAM\_230\_31 & MARCY -N.SCTLND\_345\_18**

FWD

Mon 10/31/2022 to Mon 11/28/2022

(Import)

0500 1900

CENTRAL EAST - VC

**1300 MW**

Impacts Total Transfer Capability 1675 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

# NYISO TRANSFER LIMITATIONS

Wednesday, December 22, 2021 to Friday , June 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**SPRNBRK\_\_345KV\_RNS5**

FWD

Tue 11/08/2022 to Tue 11/08/2022 CANCELLED by ConEd 12/18/2021

(Import)

0230 Continuous 0300

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

---

**MOSES\_\_-ADIRNDCK\_230\_MAI**

FWD

Wed 11/30/2022 to Wed 03/01/2023

(Import)

0700 Continuous 1100

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

---

**SHOR\_NPX-SHOREHAM\_138\_CSC**

FWD

REV

Mon 05/01/2023 to Fri 05/05/2023

(Import) (Export)

0600 Continuous 1800

SCH - NPX\_CSC

**0 MW****0 MW**

Impacts Total Transfer Capability 330 MW 330 MW

TTC with All Lines In Service 330 MW 330 MW

Work scheduled by: LI