

# NYISO TRANSFER LIMITATIONS

Wednesday, December 01, 2021 to Friday, June 02, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Tue 05/31/2022 EXT FORCE by CONED 11/08/2021

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Tue 05/31/2022

0001 2359

Work scheduled by:

	FWD (Import)	REV (Export)
SCH - PJ - NY	<b>2550 MW</b>	<b>1900 MW</b>
Impacts Total Transfer Capability	300 MW	300 MW
TTC with All Lines In Service	2850 MW	2200 MW

## MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Tue 05/31/2022 EXT FORCE by CONED 11/08/2021

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## STLAWRNC-MOSES\_230\_L33P

Mon 04/30/2018 to Tue 05/31/2022 EXT FORCE by IESO 11/04/2021

0456 Continuous 1600

Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## NEWBRIDGE\_345\_138\_BK\_1

Wed 09/02/2020 to Mon 08/01/2022 EXT FORCE by LI 11/29/2021

1807 Continuous 2359

Work scheduled by: LI

	FWD (Import)
SCH - PJM_NEPTUNE	<b>375 MW</b>
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

## PORTER\_-ROTTDAM\_230\_30

Wed 09/15/2021 to Tue 11/30/2021 UPDATED by NGRID 08/31/2021

0700 Continuous 1730

Work scheduled by: NGrid

	FWD (Import)
CENTRAL EAST - VC	<b>2805 MW</b>
Impacts Total Transfer Capability	170 MW
TTC with All Lines In Service	2975 MW

## CHAT\_DC\_GC1

Sun 10/03/2021 to Tue 11/30/2021 UPDATED by HQ 11/23/2021

0500 Continuous 1900

Work scheduled by: HQ

	FWD (Import)
MOSES SOUTH	<b>2850 MW</b>
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 01, 2021 to Friday , June 02, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHAT\_DC\_GC1

Sun 10/03/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>11/23/2021</u>	SCH - HQ - NY	REV
0500	Continuous	1900				Impacts Total Transfer Capability	(Export)
Work scheduled by: HQ						TTC with All Lines In Service	500 MW
							500 MW
							1000 MW

### SCH-HQ-NYISO\_LIMIT\_1200

Thu 10/07/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>11/23/2021</u>	SCH - HQ - NY	FWD
0001	Continuous	1900				Impacts Total Transfer Capability	(Import)
Work scheduled by: HQ						TTC with All Lines In Service	1200 MW
							300 MW
							1500 MW

### DUNWODIE\_345KV\_5

Thu 10/14/2021	to	Thu 12/02/2021	<u>EXTENDED</u>	<u>by CONED</u>	<u>11/21/2021</u>	SPR/DUN-SOUTH	FWD
0001	Continuous	2200				Impacts Total Transfer Capability	(Import)
Work scheduled by: ConEd						TTC with All Lines In Service	3800 MW
							800 MW
							4600 MW

### DUNWODIE\_345KV\_7

Thu 10/14/2021	to	Thu 12/02/2021	<u>EXTENDED</u>	<u>by CONED</u>	<u>11/21/2021</u>	SPR/DUN-SOUTH	FWD
0001	Continuous	2200				Impacts Total Transfer Capability	(Import)
Work scheduled by: ConEd						TTC with All Lines In Service	3800 MW
							800 MW
							4600 MW

### SPRNBK\_-DUNWODIE\_345\_W75

Thu 10/14/2021	to	Thu 12/02/2021	<u>EXTENDED</u>	<u>by CONED</u>	<u>11/21/2021</u>	SPR/DUN-SOUTH	FWD
0001	Continuous	2200				Impacts Total Transfer Capability	(Import)
Work scheduled by: ConEd						TTC with All Lines In Service	3800 MW
							800 MW
							4600 MW

### SPRNBK\_345KV\_RNS3

Thu 10/14/2021	to	Thu 12/02/2021	<u>EXTENDED</u>	<u>by CONED</u>	<u>11/21/2021</u>	SPR/DUN-SOUTH	FWD
0001	Continuous	2200				Impacts Total Transfer Capability	(Import)
Work scheduled by: ConEd						TTC with All Lines In Service	3800 MW
							800 MW
							4600 MW

### NIAGARA\_-KINTIGH\_345\_NS1-38

Mon 10/18/2021	to	Sat 12/31/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/18/2021</u>	DYSINGER EAST	FWD
0500	Continuous	2359				Impacts Total Transfer Capability	(Import)
Work scheduled by: NYPA						TTC with All Lines In Service	1700 MW
							1450 MW
							3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 01, 2021 to Friday , June 02, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## DYSINGER-KINTIGH\_\_345\_38

Tue 10/26/2021 to Wed 12/08/2021  
1127 Continuous 1900

Work scheduled by: NYISO

FWD

(Import)

DYSINGER EAST **2500 MW**  
Impacts Total Transfer Capability 650 MW  
TTC with All Lines In Service 3150 MW

## NIAGARA\_-DYSINGER\_345\_ND1

Tue 10/26/2021 to Wed 12/08/2021  
1127 Continuous 1900

Work scheduled by: NYISO

FWD

(Import)

DYSINGER EAST **2500 MW**  
Impacts Total Transfer Capability 650 MW  
TTC with All Lines In Service 3150 MW

## W49TH\_ST\_345KV\_5

Sat 10/30/2021 to Thu 12/09/2021 EXTENDED by CONED 11/17/2021  
0001 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

## BUCHAN\_S-MILLWOOD\_345\_W97

Mon 11/01/2021 to Thu 12/16/2021 UPDATED by CE 11/26/2021  
0001 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **7680 MW**  
Impacts Total Transfer Capability 135 MW  
TTC with All Lines In Service 7815 MW

## SCH-IMO-NYISO\_LIMIT\_1750

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019  
0001 Continuous 2359

Work scheduled by: IESO

FWD

(Import)

SCH - OH - NY **2050 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 2300 MW

## SCH-NYISO-IMO\_LIMIT\_1600

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019  
0001 Continuous 2359

Work scheduled by: IESO

REV

(Export)

SCH - OH - NY **1900 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 2000 MW

## SCH-NYISO-IMO\_LIMIT\_1200

Wed 11/03/2021 to Fri 12/17/2021 EXTENDED by IESO 11/19/2021  
0800 Continuous 1700

Work scheduled by: IESO

REV

(Export)

SCH - OH - NY **1500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 2000 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 01, 2021 to Friday , June 02, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CHATGUAY-MASSENA\_\_765\_7040

Wed 11/10/2021 to Tue 11/30/2021  
0300 Continuous 1859

EXTENDED by HQ 11/04/2021

Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

## CHATGUAY-MASSENA\_\_765\_7040

Wed 11/10/2021 to Tue 11/30/2021  
0300 Continuous 1859

EXTENDED by HQ 11/04/2021

Work scheduled by: HQ

FWD REV  
(Import) (Export)  
SCH - HQ - NY **0 MW 0 MW**  
Impacts Total Transfer Capability 1500 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

## CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Wed 11/10/2021 to Tue 11/30/2021  
0300 1859

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **2550 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Wed 11/10/2021 to Tue 11/30/2021  
0300 1859

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY **1370 MW 0 MW**  
Impacts Total Transfer Capability 130 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

## CHAT\_DC\_GC2

Wed 11/10/2021 to Tue 11/30/2021  
0300 Continuous 1859

EXTENDED by HQ 11/04/2021

Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC2

Wed 11/10/2021 to Tue 11/30/2021  
0300 Continuous 1859

EXTENDED by HQ 11/04/2021

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

## SCH-IMO-NYISO\_LIMIT\_1550

Fri 11/12/2021 to Fri 12/17/2021  
1201 Continuous 1700

EXTENDED by IESO 11/19/2021

Work scheduled by: IESO

FWD  
(Import)  
SCH - OH - NY **1850 MW**  
Impacts Total Transfer Capability 450 MW  
TTC with All Lines In Service 2300 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 01, 2021 to Friday , June 02, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PORTER\_\_-ROTTRDAM\_230\_30 &amp; MASSENA\_-MARCY\_\_\_\_765\_MSU1

FWD

Mon 11/15/2021 to Tue 11/30/2021

(Import)

0100

1730

CENTRAL EAST - VC

1500 MW

Impacts Total Transfer Capability 1475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

MARCY\_\_\_\_765\_345\_AT1

FWD

Mon 11/15/2021 to Tue 11/30/2021

(Import)

0100

Continuous

1859

UPDATEDby NYPA11/24/2021

MOSES SOUTH

1750 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

ARR: 19

MARCY\_\_\_\_765\_345\_AT2

FWD

Mon 11/15/2021 to Tue 11/30/2021

(Import)

0100

Continuous

1859

UPDATEDby NYPA11/24/2021

MOSES SOUTH

1700 MW

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

ARR: 19

MASSENA\_-MARCY\_\_\_\_765\_MSU1

FWD

Mon 11/15/2021 to Tue 11/30/2021

(Import)

0100

Continuous

1859

UPDATEDby NYPA11/24/2021

CENTRAL EAST - VC

1670 MW

Impacts Total Transfer Capability 1305 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

MASSENA\_-MARCY\_\_\_\_765\_MSU1

FWD

Mon 11/15/2021 to Tue 11/30/2021

(Import)

0100

Continuous

1859

UPDATEDby NYPA11/24/2021

MOSES SOUTH

500 MW

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

MASSENA\_-MARCY\_\_\_\_765\_MSU1

FWD

REV

Mon 11/15/2021 to Tue 11/30/2021

(Import) (Export)

0100

Continuous

1859

UPDATEDby NYPA11/24/2021

SCH - HQ - NY

475 MW

1000 MW

Impacts Total Transfer Capability 1025 MW

0 MW

TTC with All Lines In Service 1500 MW

1000 MW

Work scheduled by: NYPA

MASSENA\_-MARCY\_\_\_\_765\_MSU1

FWD

Mon 11/15/2021 to Tue 11/30/2021

(Import)

0100

Continuous

1859

UPDATEDby NYPA11/24/2021

SCH - HQ\_CEDARS

90 MW

Impacts Total Transfer Capability 189 MW

TTC with All Lines In Service 279 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Wednesday, December 01, 2021 to Friday, June 02, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA\_-MARCY\_\_\_765\_MSU1 & CHATGUAY-MASSENA\_\_\_765\_7040

Mon 11/15/2021 to Tue 11/30/2021  
0100 1859

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

STLAWRNC-MOSES\_\_\_230\_L33P & MASSENA\_-MARCY\_\_\_765\_MSU1

Mon 11/15/2021 to Tue 11/30/2021  
0100 1859

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS **90 MW**  
Impacts Total Transfer Capability 189 MW  
TTC with All Lines In Service 279 MW

SPRNBRK\_\_\_345KV\_RS3 & SPRNBRK\_\_\_345KV\_RS4

Tue 11/23/2021 to Wed 12/01/2021  
0001 0200

Work scheduled by:

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

HOMR\_NYW-PIERC\_NY\_345\_48

Tue 11/23/2021 to Tue 12/07/2021  
0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

DUNWODIE-MOTTHAVN\_345\_71

Wed 11/24/2021 to Tue 11/30/2021 UPDATED by CE 10/01/2021  
0201 Continuous 0100

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

DUNWODIE\_345KV\_3

Wed 11/24/2021 to Tue 11/30/2021 UPDATED by CE 10/01/2021  
0201 Continuous 0100

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

SCH-IMO\_NY\_NIAG\_NRTH\_BUS\_W/BB

Mon 11/29/2021 to Tue 11/30/2021 UPDATED by NYPA 08/20/2021  
0500 Continuous 1900

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1650 MW 1450 MW**  
Impacts Total Transfer Capability 650 MW 550 MW  
TTC with All Lines In Service 2300 MW 2000 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 01, 2021 to Friday , June 02, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

FWD

Mon 11/29/2021 to Fri 12/17/2021 UPDATED by PJM 09/15/2021

(Import)

0600 Continuous 1600

Work scheduled by: PJM

SCH - PJM\_NEPTUNE

0 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

## NEWBRDGE-DUFFYAVE\_345\_501

FWD

Mon 11/29/2021 to Fri 12/17/2021 UPDATED by PJM 09/15/2021

(Import)

0600 Continuous 1600

Work scheduled by: PJM

SCH - PJM\_NEPTUNE

0 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

## NEWBRDGE\_345\_138\_BK\_2

FWD

Mon 11/29/2021 to Fri 12/17/2021 UPDATED by PJM 09/15/2021

(Import)

0600 Continuous 1600

Work scheduled by: PJM

SCH - PJM\_NEPTUNE

375 MW

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

## SCH-NE-NYISO\_LIMIT\_800

FWD

Mon 11/29/2021 to Wed 12/01/2021

(Import)

0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

1000 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 1400 MW

## SCH-NE-NYISO\_LIMIT\_900

FWD

Mon 11/29/2021 to Wed 12/01/2021

(Import)

0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

1100 MW

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 1400 MW

## SCH-NYISO-NE\_LIMIT\_800

REV

Mon 11/29/2021 to Wed 12/01/2021

(Export)

0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

1000 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 1800 MW

## BERKSHIR-ALPS\_345\_393

FWD

REV

Mon 11/29/2021 to Thu 12/02/2021 UPDATED by ISONE 11/24/2021

(Import) (Export)

0700 Continuous 1200

Work scheduled by: ISONE

ARR: 78

SCH - NE - NY

1100 MW

1700 MW

Impacts Total Transfer Capability 300 MW

100 MW

TTC with All Lines In Service 1400 MW

1800 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 01, 2021 to Friday, June 02, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BERKSHIR-ALPS_____345_393</b>						FWD	REV
Mon 11/29/2021	to	Thu 12/02/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>11/24/2021</u>	(Import)	(Export)
0700	Continuous	1200				<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: ISONE					ARR: 78	Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
<b>BERKSHIR-ALPS_____345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>						FWD	REV
Mon 11/29/2021	to	Thu 12/02/2021				(Import)	(Export)
0700		1200				<b>1100 MW</b>	<b>1700 MW</b>
Work scheduled by:					ARR: 78	Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	1400 MW
<b>BERKSHIR-NORTHFLD_345_312</b>						FWD	
Mon 11/29/2021	to	Thu 12/02/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>11/24/2021</u>	(Import)	
0700	Continuous	1200				<b>1300 MW</b>	
Work scheduled by: ISONE						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	1400 MW
<b>BERKSHIR-NORTHFLD_345_312</b>						FWD	REV
Mon 11/29/2021	to	Thu 12/02/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>11/24/2021</u>	(Import)	(Export)
0700	Continuous	1200				<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: ISONE						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
<b>SCH-NPX_1385-NYISO_LIMIT_75</b>						FWD	
Mon 11/29/2021	to	Thu 12/02/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>11/24/2021</u>	(Import)	
0700	Continuous	1200				<b>75 MW</b>	
Work scheduled by: ISONE						Impacts Total Transfer Capability	125 MW
						TTC with All Lines In Service	200 MW
<b>LEEDS_____345KV_R395</b>						FWD	
Mon 11/29/2021	to	Fri 12/03/2021				(Import)	
0700	Continuous	1700				<b>3800 MW</b>	
Work scheduled by: NGrid						Impacts Total Transfer Capability	4015 MW
						TTC with All Lines In Service	7815 MW
<b>HURLYAVE-ROSETON____345_303</b>						FWD	
Mon 11/29/2021	to	Fri 12/17/2021	<u>UPDATED</u>	<u>by CH</u>	<u>10/07/2021</u>	(Import)	
0800	Continuous	1600				<b>4100 MW</b>	
Work scheduled by: CHGE						Impacts Total Transfer Capability	3715 MW
						TTC with All Lines In Service	7815 MW



# NYISO TRANSFER LIMITATIONS

Wednesday, December 01, 2021 to Friday , June 02, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NE-NYISO_LIMIT_600</b>				FWD	
Mon 11/29/2021	to	Thu 12/02/2021		(Import)	
2300	Daily	0659		SCH - NE - NY	<b>800 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability	600 MW
				TTC with All Lines In Service	1400 MW
<b>SCH-NE-NYISO_LIMIT_700</b>				FWD	
Mon 11/29/2021	to	Thu 12/02/2021		(Import)	
2300	Daily	0659		SCH - NE - NY	<b>900 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_200</b>				REV	
Mon 11/29/2021	to	Thu 12/02/2021		(Export)	
2300	Daily	0659		SCH - NE - NY	<b>400 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	1800 MW
<b>SCH-NYISO-NE_LIMIT_600</b>				REV	
Mon 11/29/2021	to	Thu 12/02/2021		(Export)	
2300	Daily	0659		SCH - NE - NY	<b>800 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	1800 MW
<b>NIAGARA_-PACKARD__230_61</b>				FWD	REV
Tue 11/30/2021	to	Fri 12/10/2021		(Import)	(Export)
0821	Continuous	1900		SCH - OH - NY	<b>1200 MW 1850 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	1100 MW 150 MW
				TTC with All Lines In Service	2300 MW 2000 MW
<b>W49TH_ST_345KV_7</b>				FWD	
Wed 12/01/2021	to	Thu 12/09/2021	<b><u>EXTENDED</u> by CONED <u>11/17/2021</u></b>	(Import)	
0001	Continuous	0200		SCH - PJM_HTP	<b>300 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	360 MW
				TTC with All Lines In Service	660 MW
<b>SCH-NYISO-NE_LIMIT_600</b>				REV	
Wed 12/01/2021	to	Wed 12/01/2021		(Export)	
0700	Daily	2259		SCH - NE - NY	<b>800 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	1800 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MAl

Wed 12/01/2021 to Tue 05/31/2022  
0700 Continuous 1300  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## SCH-NE-NYISO\_LIMIT\_800

Thu 12/02/2021 to Thu 12/02/2021  
0700 Daily 1200  
Work scheduled by: ISONE

FWD  
(Import)  
SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

## SCH-NE-NYISO\_LIMIT\_900

Thu 12/02/2021 to Thu 12/02/2021  
0700 Daily 1200  
Work scheduled by: ISONE

FWD  
(Import)  
SCH - NE - NY **1100 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 1400 MW

## SCH-NYISO-NE\_LIMIT\_600

Thu 12/02/2021 to Thu 12/02/2021  
0700 Daily 1200  
Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY **800 MW**  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 1800 MW

## SCH-NYISO-NE\_LIMIT\_800

Thu 12/02/2021 to Thu 12/02/2021  
0700 Daily 1200  
Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 1800 MW

## SPRNBRK\_\_345KV\_RNS4

Fri 12/03/2021 to Fri 12/03/2021 EXTENDED by CONED 11/17/2021  
0300 Continuous 0330  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

## SPRNBRK\_-W49TH\_ST\_345\_M52

Fri 12/03/2021 to Mon 12/06/2021 EXTENDED by CONED 11/17/2021  
0300 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 01, 2021 to Friday , June 02, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY\_\_\_-EDIC\_\_\_345\_UE1-7

Fri 12/03/2021 to Fri 12/03/2021

0700 Daily(No Weekends) 1000

Work scheduled by: NGrid

ARR: 19&16

FWD

(Import)

OSWEGO EXPORT 5250 MW

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

FRASER\_\_\_345\_FRASER SVC

Sat 12/04/2021 to Sun 12/05/2021

0800 Continuous 1600

Work scheduled by: NYSEG

FWD

(Import)

CENTRAL EAST - VC 2935 MW

Impacts Total Transfer Capability 40 MW

TTC with All Lines In Service 2975 MW

SPRNBK\_\_\_345KV\_RNS4

Mon 12/06/2021 to Mon 12/06/2021

0130 Continuous 0200

Work scheduled by: ConEd

EXTENDED by CONED 11/17/2021

FWD

(Import)

SPR/DUN-SOUTH 3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

MARCY\_\_\_345KV\_CSC

Mon 12/06/2021 to Fri 12/17/2021

0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC 2925 MW

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

MILLWOOD\_345KV\_18

Tue 12/07/2021 to Thu 12/16/2021

0201 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 11/26/2021

FWD

(Import)

UPNY CONED 4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

BECK\_\_\_-NIAGARA\_230\_PA27

Wed 12/08/2021 to Fri 12/10/2021

0530 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

SCH - OH - NY 2100 MW

Impacts Total Transfer Capability 200 MW

TTC with All Lines In Service 2300 MW

KINTIGH\_-STA\_255\_345\_SH1-39

Wed 12/08/2021 to Sun 01/16/2022

2000 Continuous 1900

Work scheduled by: NYSEG

UPDATED by NYSEG 12/01/2021

FWD

(Import)

DYSINGER EAST 1700 MW

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 01, 2021 to Friday , June 02, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CHAT\_DC\_GC1

Sun 12/12/2021 to Sun 12/12/2021  
0001 Continuous 0200

Work scheduled by: HQ

FWD

(Import)

MOSES SOUTH

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC1

Sun 12/12/2021 to Sun 12/12/2021  
0001 Continuous 0200

Work scheduled by: HQ

REV

(Export)

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

## CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Sun 12/12/2021 to Sun 12/12/2021  
0001 0200

Work scheduled by:

FWD

(Import)

MOSES SOUTH

**2550 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Sun 12/12/2021 to Sun 12/12/2021  
0001 0200

Work scheduled by:

FWD

(Import)

REV

(Export)

SCH - HQ - NY

**1370 MW 0 MW**

Impacts Total Transfer Capability 130 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

## CHAT\_DC\_GC2

Sun 12/12/2021 to Sun 12/12/2021  
0001 Continuous 0200

Work scheduled by: HQ

FWD

(Import)

MOSES SOUTH

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC2

Sun 12/12/2021 to Sun 12/12/2021  
0001 Continuous 0200

Work scheduled by: HQ

REV

(Export)

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

## SCH-HQ-NYISO\_LIMIT\_1150

Sun 12/12/2021 to Sun 12/12/2021  
0001 Continuous 0200

Work scheduled by: HQ

FWD

(Import)

SCH - HQ - NY

**1150 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 01, 2021 to Friday , June 02, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LADENTWN-BUCHAN\_S\_345\_Y88

FWD

Thu 12/16/2021 to Sun 12/19/2021  
0201 Continuous 0200

UPDATEDby CE11/26/2021

Work scheduled by: ConEd

UPNY CONED

(Import)

**7560 MW**

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 7815 MW

## FRASER\_\_GILBOA\_\_345\_GF5-35

FWD

Mon 12/20/2021 to Tue 12/21/2021  
0800 Continuous 1700

Work scheduled by: NYSEG

CENTRAL EAST - VC

(Import)

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

## EDIC\_\_FRASER\_\_345\_EF24-40

FWD

Wed 12/22/2021 to Thu 12/23/2021  
0830 Continuous 1500

UPDATEDby NYSEG11/05/2021

Work scheduled by: NYSEG

CENTRAL EAST - VC

(Import)

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

## LEEDS\_\_PLSNTVLY\_345\_92

FWD

Mon 12/27/2021 to Mon 12/27/2021  
0830 Daily(No Weekends) 1500

Work scheduled by: NGrid

UPNY CONED

(Import)

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

## FRASER\_\_345\_FRASER SVC

FWD

Tue 01/04/2022 to Mon 02/28/2022  
0700 Continuous 1730

UPDATEDby NYPA05/25/2021

Work scheduled by: NYPA

CENTRAL EAST - VC

(Import)

**2935 MW**

Impacts Total Transfer Capability 40 MW

TTC with All Lines In Service 2975 MW

## HOPATCON-RAMAPO\_\_500\_5018

FWD

REV

Thu 01/06/2022 to Mon 01/10/2022  
0200 Continuous 1900

Work scheduled by: PJM

SCH - PJ - NY

(Import) (Export)

**1450 MW 1200 MW**

Impacts Total Transfer Capability 1400 MW 1000 MW

TTC with All Lines In Service 2850 MW 2200 MW

## HOPATCON-RAMAPO\_\_500\_5018

FWD

Thu 01/06/2022 to Mon 01/10/2022  
0200 Continuous 1900

Work scheduled by: PJM

UPNY CONED

(Import)

**7480 MW**

Impacts Total Transfer Capability 335 MW

TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 01, 2021 to Friday , June 02, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO___345_345_PAR3500				FWD	REV
Thu 01/06/2022	to	Mon 01/10/2022		(Import)	(Export)
0200	Continuous	1900		SCH - PJ - NY	<b>2350 MW 1250 MW</b>
Work scheduled by: PJM				Impacts Total Transfer Capability	500 MW 950 MW
				TTC with All Lines In Service	2850 MW 2200 MW
RAMAPO___345_345_PAR4500				FWD	REV
Thu 01/06/2022	to	Mon 01/10/2022		(Import)	(Export)
0200	Continuous	1900		SCH - PJ - NY	<b>2350 MW 1250 MW</b>
Work scheduled by: PJM				Impacts Total Transfer Capability	500 MW 950 MW
				TTC with All Lines In Service	2850 MW 2200 MW
RAMAPO___500_345_BK 1500				FWD	REV
Thu 01/06/2022	to	Mon 01/10/2022		(Import)	(Export)
0200	Continuous	1900		SCH - PJ - NY	<b>1450 MW 1200 MW</b>
Work scheduled by: PJM				Impacts Total Transfer Capability	1400 MW 1000 MW
				TTC with All Lines In Service	2850 MW 2200 MW
RAMAPO___500_345_BK 1500				FWD	
Thu 01/06/2022	to	Mon 01/10/2022		(Import)	
0200	Continuous	1900		UPNY CONED	<b>7480 MW</b>
Work scheduled by: PJM				Impacts Total Transfer Capability	335 MW
				TTC with All Lines In Service	7815 MW
BEAR SWP-EASTOVER_230_E205W					
Mon 01/10/2022	to	Thu 01/13/2022		SCH - NE - NY	
0700	Continuous	1700		Impacts Total Transfer Capability	
Work scheduled by: ISONE				TTC with All Lines In Service	
HURLYAVE-ROSETON___345_303				FWD	
Tue 01/11/2022	to	Sat 01/22/2022	<u>UPDATED</u> <u>by CHGE</u> <u>11/30/2021</u>	(Import)	
0600	Continuous	1600		UPNY CONED	<b>4100 MW</b>
Work scheduled by: CHGE				Impacts Total Transfer Capability	3715 MW
				TTC with All Lines In Service	7815 MW
MOTTHAVN-RAINEY___345_Q11				FWD	
Wed 01/12/2022	to	Sat 01/15/2022		(Import)	
0001	Continuous	0200		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, December 01, 2021 to Friday , June 02, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DYSINGER-KINTIGH\_\_345\_38**

FWD

Mon 01/17/2022 to Thu 01/20/2022

(Import)

0500 Continuous 1900

DYSINGER EAST **2500 MW**

Impacts Total Transfer Capability 650 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYSEG

**NIAGARA\_-DYSINGER\_345\_ND1**

FWD

Mon 01/17/2022 to Thu 01/20/2022

(Import)

0500 Continuous 1900

DYSINGER EAST **2500 MW**

Impacts Total Transfer Capability 650 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**NIAGARA\_-PACKARD\_\_230\_61**

FWD

REV

Mon 01/17/2022 to Fri 01/21/2022

(Import) (Export)

0615 Continuous 1900

SCH - OH - NY **1200 MW 1850 MW**

Impacts Total Transfer Capability 1100 MW 150 MW

TTC with All Lines In Service 2300 MW 2000 MW

Work scheduled by: NGrid

**S.RIPLEY-DUNKIRK\_\_230\_68**

Tue 01/18/2022 to Fri 02/04/2022

**UPDATED****by NGRID 09/24/2021**

0700 Continuous 1730

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NGrid

**NIAGARA\_-STA\_255\_\_345\_NH2**

FWD

Fri 01/21/2022 to Fri 03/04/2022

(Import)

0500 Continuous 1900

**UPDATED****by NYPA 08/20/2021**DYSINGER EAST **1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**FIVEMILE-STOLLERD\_345\_29**

Mon 01/24/2022 to Sun 01/30/2022

0500 Continuous 1900

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: PJM

**PLSNTVLY-WOOD\_ST\_\_345\_F30**

FWD

Sat 01/29/2022 to Sat 01/29/2022

(Import)

0001 Continuous 0030

UPNY CONED **4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Wednesday, December 01, 2021 to Friday, June 02, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PLSNTVLY\_345KV\_RNS5

FWD

Sat 01/29/2022 to Sat 01/29/2022

(Import)

0001 Continuous 0030

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### PLSNTVLY-WOOD\_ST\_\_345\_F30

FWD

Wed 02/02/2022 to Wed 02/02/2022

(Import)

1930 Continuous 2000

UPNY CONED

4000 MW

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### PLSNTVLY\_345KV\_RNS5

FWD

Wed 02/02/2022 to Wed 02/02/2022

(Import)

1930 Continuous 2000

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### MARCY\_\_-N.SCTLND\_345\_18

FWD

Tue 02/08/2022 to Wed 02/09/2022

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

1470 MW

Impacts Total Transfer Capability 1505 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

ARR: 19

### PLSNTVLY\_345KV\_RNS4

FWD

Sat 02/12/2022 to Sat 02/12/2022

(Import)

0600 Continuous 0630

UPDATED

by CONED 11/12/2021

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

### ATHENS\_\_-PLSNTVLY\_345\_91

FWD

Sat 02/12/2022 to Wed 02/16/2022

(Import)

0600 Continuous 1900

UPDATED

by CONED 11/12/2021

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

### BUCHAN\_N-EASTVIEW\_345\_W93

FWD

Sun 02/13/2022 to Mon 02/14/2022

(Import)

0001 Continuous 0200

UPNY CONED

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd



# NYISO TRANSFER LIMITATIONS

Wednesday, December 01, 2021 to Friday, June 02, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### RAMAPO\_\_-BUCHAN\_N\_345\_Y94

FWD

Sun 02/13/2022 to Mon 02/14/2022

(Import)

0001 Continuous 0200

UPNY CONED

7580 MW

Impacts Total Transfer Capability 235 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### MILLWOOD\_345KV\_18

FWD

Mon 02/14/2022 to Tue 02/15/2022

(Import)

0001 Continuous 0200

UPNY CONED

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### PLSNTVLY\_345KV\_RNS4

FWD

Wed 02/16/2022 to Wed 02/16/2022

(Import)

1830 Continuous 1900

UPDATED by CONED 11/12/2021

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

### PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

FWD

Thu 02/17/2022 to Sat 02/19/2022

(Import)

0001 2200

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by:

### LEEDS\_\_-PLSNTVLY\_345\_92

FWD

Thu 02/17/2022 to Fri 03/25/2022

(Import)

0001 Continuous 2200

UPDATED by NYISO 11/15/2021

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### PLSNTVLY\_345KV\_RNS5

FWD

Thu 02/17/2022 to Fri 03/25/2022

(Import)

0001 Continuous 2200

UPDATED by NYISO 11/15/2021

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### PLSNTVLY-WOOD\_ST\_\_345\_F30

FWD

Sun 02/20/2022 to Mon 02/21/2022

(Import)

0001 Continuous 2200

UPNY CONED

4000 MW

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Wednesday, December 01, 2021 to Friday , June 02, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## EASTVIEW-SPRNBK\_\_345\_W64

Sun 02/20/2022 to Mon 02/21/2022

2000 Continuous 2359

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

## MILLWOOD-EASTVIEW\_345\_W99

Sun 02/20/2022 to Mon 02/21/2022

2000 Continuous 2359

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **7550 MW**

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

## SPRNBK\_\_345KV\_RNS5

Sun 02/20/2022 to Mon 02/21/2022

2000 Continuous 2359

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

## EASTVIEW-SPRNBK\_\_345\_W64

Tue 02/22/2022 to Tue 02/22/2022

0001 Continuous 0030

Work scheduled by: ConEd

UPDATEDby CONED 08/31/2021

FWD

(Import)

UPNY CONED **4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

## SPRNBK\_\_345KV\_RNS5

Tue 02/22/2022 to Tue 02/22/2022

0001 Continuous 0030

Work scheduled by: ConEd

UPDATEDby CONED 08/31/2021

FWD

(Import)

SPR/DUN-SOUTH **3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

## MILLWOOD-EASTVIEW\_345\_W99

Tue 02/22/2022 to Mon 03/21/2022

0001 Continuous 0200

Work scheduled by: ConEd

UPDATEDby CONED 08/31/2021

FWD

(Import)

UPNY CONED **7550 MW**

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

## MARCY\_\_-EDIC\_\_345\_UE1-7

Wed 02/23/2022 to Mon 02/28/2022

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

OSWEGO EXPORT **5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

ARR: 19&amp;16

# NYISO TRANSFER LIMITATIONS

Wednesday, December 01, 2021 to Friday , June 02, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### FIVEMILE-STOLLERD\_345\_29

Tue 03/01/2022 to Tue 04/12/2022  
0500 Continuous 1900

Work scheduled by: NYSEG

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### PORTER\_-ROTTRDAM\_230\_31

Tue 03/01/2022 to Tue 12/31/2030  
0600 Continuous 2359

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC

**2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

### N.SCTLND-LEEDS\_345\_93

Tue 03/01/2022 to Mon 03/28/2022  
0700 Continuous 1900

Work scheduled by: NGrid

UPDATED

by NGRID 11/15/2021

FWD

(Import)

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

### EDIC\_-N.SCTLND\_345\_14

Tue 03/01/2022 to Tue 04/12/2022  
0700 Continuous 1900

Work scheduled by: NGrid

UPDATED

by NGRID 11/15/2021

FWD

(Import)

CENTRAL EAST - VC

**1670 MW**

Impacts Total Transfer Capability 1305 MW

TTC with All Lines In Service 2975 MW

### EDIC\_-N.SCTLND\_345\_14 & PORTER\_-ROTTRDAM\_230\_31

Tue 03/01/2022 to Tue 04/12/2022  
0700 1900

Work scheduled by:

FWD

(Import)

CENTRAL EAST - VC

**1500 MW**

Impacts Total Transfer Capability 1475 MW

TTC with All Lines In Service 2975 MW

### FRASANX-COOPERS\_345\_UCC2-41

Tue 03/01/2022 to Wed 04/20/2022  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD

(Import)

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

### MARCY\_-FRASANX\_345\_UCC2-41

Tue 03/01/2022 to Wed 04/20/2022  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD

(Import)

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 01, 2021 to Friday, June 02, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>N.SCTLND-ALPS_____345_2</b>						FWD	
Tue 03/01/2022	to	Fri 06/24/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>11/15/2021</u>	(Import)	
0700	Continuous	1900				<b>900 MW</b>	
Work scheduled by: NGrid						SCH - NE - NY	
						Impacts Total Transfer Capability	500 MW
						TTC with All Lines In Service	1400 MW
<hr/>							
<b>N.SCTLND-ALPS_____345_2</b>						FWD	REV
Tue 03/01/2022	to	Fri 06/24/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>11/15/2021</u>	(Import)	(Export)
0700	Continuous	1900				<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
<hr/>							
<b>GOETHALS_345KV_5</b>							
Sat 03/05/2022	to	Mon 04/04/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>03/26/2021</u>	STATEN ISLAND	
0001	Continuous	0200				Impacts Total Transfer Capability	
Work scheduled by: ConEd						TTC with All Lines In Service	
<hr/>							
<b>LINDEN__-GOETHALS_230_A2253</b>							
Sat 03/05/2022	to	Mon 04/04/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>03/26/2021</u>	SCH - PJ - NY	
0001	Continuous	0200				Impacts Total Transfer Capability	
Work scheduled by: ConEd						TTC with All Lines In Service	
<hr/>							
<b>LINDEN__-GOETHALS_230_A2253 &amp; HUDSONP_-FARRAGUT_345_B3402</b>						FWD	REV
Sat 03/05/2022	to	Mon 04/04/2022				(Import)	(Export)
0001		0200				<b>2550 MW</b>	<b>1900 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	2850 MW
<hr/>							
<b>LINDEN__-GOETHALS_230_A2253 &amp; HUDSONP_-FARRAGUT_345_B3402 &amp; MARION__-FARRAGUT_345_C3403</b>						FWD	REV
Sat 03/05/2022	to	Mon 04/04/2022				(Import)	(Export)
0001		0200				<b>2550 MW</b>	<b>1900 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	2850 MW
<hr/>							
<b>LINDEN__-GOETHALS_230_A2253 &amp; MARION__-FARRAGUT_345_C3403</b>						FWD	REV
Sat 03/05/2022	to	Mon 04/04/2022				(Import)	(Export)
0001		0200				<b>2550 MW</b>	<b>1900 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	2850 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 01, 2021 to Friday , June 02, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### INDPDNCE-SCRIBA\_\_345\_25

Thu 03/10/2022 to Wed 03/16/2022  
0800 Continuous 1800

Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

### NIAGARA\_-DYSINGER\_345\_ND1

Fri 03/11/2022 to Fri 03/11/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2500 MW**  
Impacts Total Transfer Capability 650 MW  
TTC with All Lines In Service 3150 MW

### PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Thu 03/17/2022 to Sun 03/20/2022  
0100 2200

Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLY-WOOD\_ST\_\_345\_F30

Mon 03/21/2022 to Wed 03/23/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

### EASTVIEW-SPRNBRK\_\_345\_W64

Mon 03/21/2022 to Mon 03/21/2022 **UPDATED by CONED 08/31/2021**  
0130 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

### SPRNBRK\_\_345KV\_RNS5

Mon 03/21/2022 to Mon 03/21/2022 **UPDATED by CONED 08/31/2021**  
0130 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

### NIAGARA\_-STA\_255\_\_345\_NH2

Fri 03/25/2022 to Fri 03/25/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Sat 03/26/2022 to Mon 03/28/2022  
0001 2200

Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## ATHENS\_\_-PLSNTVLY\_345\_91

Sat 03/26/2022 to Sun 05/01/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## PLSNTVLY\_345KV\_RNS4

Sat 03/26/2022 to Sun 05/01/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## PLSNTVLY-WOOD\_ST\_\_345\_F31

Tue 03/29/2022 to Wed 03/30/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

## LINDN\_CG-LNDVFT\_\_345\_V-3022

Sun 04/03/2022 to Sat 04/09/2022  
1400 Continuous 1400

Work scheduled by: PJM

FWD	REV
(Import)	(Export)
SCH - PJM_VFT	<b>0 MW</b> <b>0 MW</b>
Impacts Total Transfer Capability	315 MW 315 MW
TTC with All Lines In Service	315 MW 315 MW

## SPRNBK\_-TREMONT\_\_345\_X28

Tue 04/05/2022 to Wed 04/06/2022  
0201 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **4200 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

Wed 04/06/2022 to Wed 04/06/2022  
0301 Continuous 0330

Work scheduled by: ConEd

UPDATED by CONED 08/19/2021

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 01, 2021 to Friday , June 02, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## EASTVIEW-SPRNBK\_\_345\_W79

FWD

Wed 04/06/2022 to Thu 04/07/2022 UPDATED by CONED 08/19/2021

(Import)

0301 Continuous 0300

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## BUCHAN\_N-EASTVIEW\_345\_W93

FWD

Thu 04/07/2022 to Thu 04/07/2022 UPDATED by CONED 08/19/2021

(Import)

0230 Continuous 0300

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## EASTVIEW-SPRNBK\_\_345\_W64

FWD

Thu 04/07/2022 to Thu 04/07/2022 UPDATED by CONED 08/31/2021

(Import)

0301 Continuous 0330

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## SPRNBK\_\_345KV\_RNS5

FWD

Thu 04/07/2022 to Thu 04/07/2022 UPDATED by CONED 08/31/2021

(Import)

0301 Continuous 0330

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## MILLWOOD-EASTVIEW\_345\_W99

FWD

Thu 04/07/2022 to Tue 04/26/2022 UPDATED by CONED 08/31/2021

(Import)

0301 Continuous 2200

UPNY CONED

**7550 MW**

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## PANNELL\_-CLAY\_\_\_\_345\_1

FWD

Mon 04/11/2022 to Fri 04/15/2022

(Import)

0700 Continuous 1530

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

## GOETHALS\_345KV\_5

Wed 04/13/2022 to Fri 05/13/2022

0001 Continuous 0259

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: ConEd

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 7815MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PORTER\_\_-ROTTRDAM\_230\_30**

FWD

Wed 04/13/2022 to Tue 12/31/2030

(Import)

0600 Continuous 2359

CENTRAL EAST - VC

**2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**PANNELL\_-CLAY\_\_\_\_345\_2**

FWD

Mon 04/18/2022 to Fri 04/22/2022

(Import)

0700 Continuous 1530

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

**EDIC\_\_\_\_-FRASER\_\_\_\_345\_EF24-40**

FWD

Thu 04/21/2022 to Tue 06/14/2022

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**MARCY\_\_\_\_345KV\_CSC**

FWD

Fri 04/22/2022 to Sat 04/23/2022

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

**2925 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

FWD

Sat 04/23/2022 to Tue 04/26/2022

(Import)

0001 2200

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by:

**ROCHESTR-PANNELL\_\_345\_RP1**

FWD

Mon 04/25/2022 to Fri 04/29/2022

(Import)

0500 Continuous 1700

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 04/25/2022 to Fri 04/29/2022

0700 Continuous 1530

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYPA



# NYISO TRANSFER LIMITATIONS

Wednesday, December 01, 2021 to Friday , June 02, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EASTVIEW-SPRNBK__345_W64</b>					FWD
Tue 04/26/2022	to	Tue 04/26/2022	<u>UPDATED</u>	<u>by CONED</u> <u>08/31/2021</u>	(Import)
2130	Continuous	2200			UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW
					TTC with All Lines In Service 7815 MW
<b>SPRNBK__345KV_RNS5</b>					FWD
Tue 04/26/2022	to	Tue 04/26/2022	<u>UPDATED</u>	<u>by CONED</u> <u>08/31/2021</u>	(Import)
2130	Continuous	2200			SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
<b>PLSNTVLY-WOOD_ST__345_F31</b>					FWD
Wed 04/27/2022	to	Fri 04/29/2022			(Import)
0001	Continuous	2200			UPNY CONED <b>4000 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 3815 MW
					TTC with All Lines In Service 7815 MW
<b>NIAGARA__345_230_AT4</b>					REV
Fri 04/29/2022	to	Fri 04/29/2022			(Export)
0500	Continuous	1700			SCH - OH - NY <b>1750 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 250 MW
					TTC with All Lines In Service 2000 MW
<b>BUCHAN_N-EASTVIEW_345_W93</b>					FWD
Mon 05/02/2022	to	Mon 05/02/2022			(Import)
0001	Continuous	0030			UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW
					TTC with All Lines In Service 7815 MW
<b>EASTVIEW-SPRNBK__345_W79</b>					FWD
Mon 05/02/2022	to	Thu 05/05/2022			(Import)
0001	Continuous	0200			UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW
					TTC with All Lines In Service 7815 MW
<b>ROCHESTR-PANNELL__345_RP2</b>					FWD
Mon 05/02/2022	to	Fri 05/06/2022			(Import)
0500	Continuous	1700			DYSINGER EAST <b>2300 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW
					TTC with All Lines In Service 3150 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## BUCHAN\_N-EASTVIEW\_345\_W93

Thu 05/05/2022 to Thu 05/05/2022  
0130 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

## SPRNBRK\_-TREMONT\_\_345\_X28

Fri 05/06/2022 to Mon 05/09/2022  
0201 Continuous 1800

Work scheduled by: ConEd

UPDATED by CONED 08/19/2021

FWD  
(Import)  
SPR/DUN-SOUTH **4200 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

## FRASER\_\_345\_FRASER SVC

Mon 05/09/2022 to Fri 05/13/2022  
0800 Continuous 1700

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2935 MW**  
Impacts Total Transfer Capability 40 MW  
TTC with All Lines In Service 2975 MW

## SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 05/16/2022 to Fri 05/27/2022  
0600 Continuous 1800

Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_CSC **0 MW 0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

## HOMRC\_NY-MAINS\_NY\_345\_47

Fri 05/20/2022 to Fri 05/27/2022  
0800 Continuous 1600

Work scheduled by: PJM

UPDATED by PJM 11/19/2020

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## HOMR\_NYW-PIERC\_NY\_345\_48

Fri 05/20/2022 to Fri 05/27/2022  
0800 Continuous 1600

Work scheduled by: PJM

UPDATED by PJM 11/19/2020

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## MARCY\_-EDIC\_\_\_\_345\_UE1-7

Sat 05/21/2022 to Sat 05/21/2022  
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19&16

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 01, 2021 to Friday , June 02, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PORTER\_\_-ROTTRDAM\_230\_30 & VOLNEY\_\_-MARCY\_\_\_\_345\_19

Sat 05/21/2022 to Sat 05/21/2022  
0700 1730

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **2655 MW**  
Impacts Total Transfer Capability 320 MW  
TTC with All Lines In Service 2975 MW

PORTER\_\_-ROTTRDAM\_230\_31 & VOLNEY\_\_-MARCY\_\_\_\_345\_19

Sat 05/21/2022 to Sat 05/21/2022  
0700 1730

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **2655 MW**  
Impacts Total Transfer Capability 320 MW  
TTC with All Lines In Service 2975 MW

VOLNEY\_\_-MARCY\_\_\_\_345\_19

Sat 05/21/2022 to Sat 05/21/2022  
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2825 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 2975 MW

VOLNEY\_\_-MARCY\_\_\_\_345\_19

Sat 05/21/2022 to Sat 05/21/2022  
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
OSWEGO EXPORT **4900 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 5250 MW

MOSES\_\_-ADIRNDCK\_230\_MA2

Wed 06/01/2022 to Tue 11/29/2022  
0700 Continuous 1800

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

NIAGARA\_-DYSINGER\_345\_ND1

Mon 06/13/2022 to Fri 06/17/2022  
0500 Continuous 2100

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2500 MW**  
Impacts Total Transfer Capability 650 MW  
TTC with All Lines In Service 3150 MW

NIAGARA\_-PACKARD\_\_230\_62

Sat 06/18/2022 to Sat 06/18/2022  
0500 Continuous 1700

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>700 MW</b>	<b>1550 MW</b>
Impacts Total Transfer Capability	1250 MW	150 MW
TTC with All Lines In Service	1950 MW	1700 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_\_345\_230\_AT4

Tue 06/28/2022 to Wed 06/29/2022  
0500 Continuous 1700

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1900 MW	1400 MW
Impacts Total Transfer Capability	50 MW	300 MW
TTC with All Lines In Service	1950 MW	1700 MW

## BECK\_\_\_\_-NIAGARA\_\_230\_PA27

Tue 07/05/2022 to Sat 07/09/2022  
0500 Continuous 2100

Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

## NIAGARA\_-DYSINGER\_345\_ND1

Mon 07/11/2022 to Fri 07/15/2022  
0500 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	2500 MW
Impacts Total Transfer Capability	650 MW
TTC with All Lines In Service	3150 MW

## ROCHESTR-PANNELL\_\_345\_RP1

Mon 07/25/2022 to Fri 07/29/2022  
0500 Continuous 2100

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## NIAGARA\_-STA\_255\_\_345\_NH2

Mon 08/01/2022 to Fri 08/05/2022  
0500 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	1400 MW
Impacts Total Transfer Capability	1750 MW
TTC with All Lines In Service	3150 MW

## MARCY\_\_\_\_-EDIC\_\_\_\_345\_UE1-7

Sat 08/06/2022 to Sat 08/06/2022  
0500 Continuous 1830

Work scheduled by: NYPA

ARR: 19&16

	FWD
	(Import)
OSWEGO EXPORT	5250 MW
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	5250 MW

## PORTER\_\_-ROTTDAM\_230\_30 & VOLNEY\_\_-MARCY\_\_\_\_345\_19

Sat 08/06/2022 to Sat 08/06/2022  
0500 1830

Work scheduled by:

	FWD
	(Import)
CENTRAL EAST - VC	2655 MW
Impacts Total Transfer Capability	320 MW
TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 01, 2021 to Friday , June 02, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PORTER\_\_-ROTTRDAM\_230\_31 & VOLNEY\_\_-MARCY\_\_\_\_345\_19

Sat 08/06/2022 to Sat 08/06/2022  
0500 1830

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **2655 MW**  
Impacts Total Transfer Capability 320 MW  
TTC with All Lines In Service 2975 MW

VOLNEY\_\_-MARCY\_\_\_\_345\_19

Sat 08/06/2022 to Sat 08/06/2022  
0500 Continuous 1830

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2825 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 2975 MW

VOLNEY\_\_-MARCY\_\_\_\_345\_19

Sat 08/06/2022 to Sat 08/06/2022  
0500 Continuous 1830

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
OSWEGO EXPORT **4900 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 5250 MW

SAND\_BAR-PLATSBRG\_115\_PV20

Mon 08/22/2022 to Fri 08/26/2022  
0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

ROSETON\_-ROCKTVRN\_345\_311

Mon 08/29/2022 to Fri 09/09/2022  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 3415 MW  
TTC with All Lines In Service 7815 MW

PANNELL\_-CLAY\_\_\_\_345\_1

Mon 09/12/2022 to Fri 09/16/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

FRASER\_\_-GILBOA\_\_\_\_345\_GF5-35

Mon 09/12/2022 to Sun 09/18/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 01, 2021 to Friday , June 02, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>PANNELL_-CLAY_____345_2</b>					FWD	
Mon 09/19/2022	to	Fri 09/23/2022			(Import)	
0700	Continuous	1530			WEST CENTRAL	<b>1300 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	2250 MW
<b>NIAGARA_-DYSINGER_345_ND1</b>					FWD	
Mon 09/26/2022	to	Fri 09/30/2022			(Import)	
0500	Continuous	1700			DYSINGER EAST	<b>2500 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	650 MW
					TTC with All Lines In Service	3150 MW
<b>SPRNBK_-W49TH_ST_345_M51</b>					FWD	
Sat 10/01/2022	to	Mon 10/17/2022	<u>UPDATED</u>	<u>by CONED 08/01/2020</u>	(Import)	
0001	Continuous	0300			SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
<b>SPRNBK_345KV_RNS5</b>					FWD	
Sat 10/01/2022	to	Mon 10/17/2022	<u>UPDATED</u>	<u>by CONED 08/01/2020</u>	(Import)	
0001	Continuous	0300			SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>					FWD	REV
Mon 10/03/2022	to	Fri 10/21/2022			(Import)	(Export)
0600	Continuous	1800			SCH - NPX_CSC	<b>0 MW 0 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	330 MW 330 MW
					TTC with All Lines In Service	330 MW 330 MW
<b>NEPTUNE_-DUFFYAVE_345_NEPTUNE</b>					FWD	
Mon 10/10/2022	to	Fri 10/14/2022			(Import)	
0600	Continuous	1600			SCH - PJM_NEPTUNE	<b>0 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
<b>NEWBRDGE-DUFFYAVE_345_501</b>					FWD	
Mon 10/10/2022	to	Fri 10/14/2022			(Import)	
0600	Continuous	1600			SCH - PJM_NEPTUNE	<b>0 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 01, 2021 to Friday, June 02, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEWBRIDGE\_345\_138\_BK\_1

Mon 10/10/2022 to Fri 10/14/2022  
0600 Continuous 1600  
Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

### NEWBRIDGE\_345\_138\_BK\_2

Mon 10/10/2022 to Fri 10/14/2022  
0600 Continuous 1600  
Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

### GILBOA\_\_-N.SCTLND\_345\_GNS-1

Mon 10/31/2022 to Mon 11/28/2022  
0500 Continuous 1900  
Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2520 MW**  
Impacts Total Transfer Capability 455 MW  
TTC with All Lines In Service 2975 MW

### LEEDS\_\_\_\_345KV\_R94301

Mon 10/31/2022 to Mon 11/28/2022  
0500 Continuous 1900  
Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### MARCY\_\_\_\_-N.SCTLND\_345\_18

Mon 10/31/2022 to Mon 11/28/2022  
0500 Continuous 1900  
Work scheduled by: NGrid

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **1470 MW**  
Impacts Total Transfer Capability 1505 MW  
TTC with All Lines In Service 2975 MW

### N.SCTLND-LEEDS\_\_\_\_345\_94

Mon 10/31/2022 to Mon 11/28/2022  
0500 Continuous 1900  
Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

### PORTER\_\_-ROTTRDAM\_230\_30 & MARCY\_\_\_\_-N.SCTLND\_345\_18

Mon 10/31/2022 to Mon 11/28/2022  
0500 Continuous 1900  
Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **1300 MW**  
Impacts Total Transfer Capability 1675 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, December 01, 2021 to Friday , June 02, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PORTER\_\_-ROTTRDAM\_230\_31 & MARCY\_\_-N.SCTLND\_345\_18

FWD

Mon 10/31/2022 to Mon 11/28/2022

(Import)

0500

1900

CENTRAL EAST - VC

**1300 MW**

Impacts Total Transfer Capability 1675 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

MOSES\_\_-ADIRNDCK\_230\_MAI

FWD

Wed 11/30/2022 to Wed 03/01/2023

(Import)

0700

Continuous

1100

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

SHOR\_NPX-SHOREHAM\_138\_CSC

FWD

REV

Mon 05/01/2023 to Fri 05/05/2023

(Import) (Export)

0600

Continuous

1800

SCH - NPX\_CSC

**0 MW****0 MW**

Impacts Total Transfer Capability 330 MW 330 MW

TTC with All Lines In Service 330 MW 330 MW

Work scheduled by: LI