

# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Tue 05/31/2022 EXT FORCE by CONED 11/08/2021

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Tue 05/31/2022

0001 2359

Work scheduled by:

FWD REV  
(Import) (Export)

SCH - PJ - NY

Impacts Total Transfer Capability 2550 MW 1900 MW

TTC with All Lines In Service 300 MW 300 MW

### MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Tue 05/31/2022 EXT FORCE by CONED 11/08/2021

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### STLAWRNC-MOSES\_230\_L33P

Mon 04/30/2018 to Tue 05/31/2022 EXT FORCE by IESO 11/04/2021

0456 Continuous 1600

Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### NEWBRDGE\_345\_138\_BK\_1

Wed 09/02/2020 to Mon 08/01/2022 EXT FORCE by LI 12/10/2021

1807 Continuous 2359

Work scheduled by: LI

FWD  
(Import)

SCH - PJM\_NEPTUNE

Impacts Total Transfer Capability 375 MW 285 MW

TTC with All Lines In Service 660 MW

### NIAGARA\_-KINTIGH\_345\_NS1-38

Mon 10/18/2021 to Sat 12/31/2022 UPDATED by NYPA 12/05/2021

0500 Continuous 2359

Work scheduled by: NYPA

FWD  
(Import)

DYSINGER EAST 1700 MW

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

### DYSINGER-KINTIGH\_345\_38

Tue 10/26/2021 to Wed 12/08/2021

1127 Continuous 1900

Work scheduled by: NYISO

FWD  
(Import)

DYSINGER EAST 2500 MW

Impacts Total Transfer Capability 650 MW

TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NIAGARA\_-DYSINGER\_345\_ND1

Tue 10/26/2021 to Wed 12/08/2021  
1127 Continuous 1900

Work scheduled by: NYISO

FWD  
(Import)  
DYSINGER EAST **2500 MW**  
Impacts Total Transfer Capability 650 MW  
TTC with All Lines In Service 3150 MW

### W49TH\_ST\_345KV\_5

Sat 10/30/2021 to Sun 12/12/2021 EXTENDED by CONED 12/02/2021  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

### BUCHAN\_S-MILLWOOD\_345\_W97

Mon 11/01/2021 to Thu 12/16/2021 UPDATED by CE 12/07/2021  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7680 MW**  
Impacts Total Transfer Capability 135 MW  
TTC with All Lines In Service 7815 MW

### SCH-IMO-NYISO\_LIMIT\_1750

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019  
0001 Continuous 2359

Work scheduled by: IESO

FWD  
(Import)  
SCH - OH - NY **2050 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 2300 MW

### SCH-NYISO-IMO\_LIMIT\_1600

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019  
0001 Continuous 2359

Work scheduled by: IESO

REV  
(Export)  
SCH - OH - NY **1900 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 2000 MW

### SCH-NYISO-IMO\_LIMIT\_1200

Wed 11/03/2021 to Fri 12/17/2021 EXTENDED by IESO 11/19/2021  
0800 Continuous 0600

Work scheduled by: IESO

REV  
(Export)  
SCH - OH - NY **1500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 2000 MW

### SCH-IMO-NYISO\_LIMIT\_1550

Fri 11/12/2021 to Fri 12/17/2021 EXTENDED by IESO 11/19/2021  
1201 Continuous 0600

Work scheduled by: IESO

FWD  
(Import)  
SCH - OH - NY **1850 MW**  
Impacts Total Transfer Capability 450 MW  
TTC with All Lines In Service 2300 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HOMR\_NYW-PIERC\_NY\_345\_48

Tue 11/23/2021 to Thu 12/09/2021 EXTENDED by PJM 12/07/2021  
0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 11/29/2021 to Fri 12/17/2021 UPDATED by PJM 09/15/2021  
0600 Continuous 1600

Work scheduled by: PJM

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 11/29/2021 to Fri 12/17/2021 UPDATED by PJM 09/15/2021  
0600 Continuous 1600

Work scheduled by: PJM

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

### NEWBRDGE\_345\_138\_BK\_2

Mon 11/29/2021 to Fri 12/17/2021 UPDATED by PJM 09/15/2021  
0600 Continuous 1600

Work scheduled by: PJM

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

### HURLYAVE-ROSETON\_\_345\_303

Mon 11/29/2021 to Fri 12/17/2021 UPDATED by CH 10/07/2021  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 3715 MW  
TTC with All Lines In Service 7815 MW

### NIAGARA\_-PACKARD\_\_230\_61

Tue 11/30/2021 to Fri 12/10/2021  
0821 Continuous 1900

Work scheduled by: NGrid

FWD REV  
(Import) (Export)  
SCH - OH - NY **1200 MW 1850 MW**  
Impacts Total Transfer Capability 1100 MW 150 MW  
TTC with All Lines In Service 2300 MW 2000 MW

### W49TH\_ST\_345KV\_7

Wed 12/01/2021 to Sun 12/12/2021 EXTENDED by CONED 12/02/2021  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOSES\_\_\_-ADIRNDCK\_230\_MA1

FWD

Wed 12/01/2021 to Tue 05/31/2022

(Import)

0700 Continuous 1300

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

### MARCY\_\_\_345KV\_CSC

FWD

Mon 12/06/2021 to Fri 12/17/2021

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

**2925 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

### SPRNBRK\_\_\_345KV\_RNS4

FWD

Tue 12/07/2021 to Tue 12/07/2021

(Import)

0300 Continuous 0330

EXTENDED by CONED 12/02/2021

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### SPRNBRK\_\_\_W49TH\_ST\_345\_M52

FWD

Tue 12/07/2021 to Fri 12/10/2021

(Import)

0300 Continuous 0200

EXTENDED by CONED 12/02/2021

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### MILLWOOD\_345KV\_18

FWD

Wed 12/08/2021 to Thu 12/16/2021

(Import)

0201 Continuous 0200

UPDATED by CE 12/07/2021

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### KINTIGH\_-STA\_255\_\_\_345\_SH1-39

FWD

Wed 12/08/2021 to Sun 01/16/2022

(Import)

2000 Continuous 1900

UPDATED by NYSEG 12/01/2021

DYSINGER EAST

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYSEG

### SPRNBRK\_\_\_345KV\_RNS4

FWD

Fri 12/10/2021 to Fri 12/10/2021

(Import)

0130 Continuous 0200

EXTENDED by CONED 12/02/2021

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### BUCHAN\_S-MILLWOOD\_345\_W98

Fri 12/10/2021 to Sat 12/11/2021 **FORCED** **by CONED** **12/10/2021**  
1252 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7680 MW**  
Impacts Total Transfer Capability 135 MW  
TTC with All Lines In Service 7815 MW

### LADENTWN-BUCHAN\_S\_345\_Y88

Fri 12/10/2021 to Sat 12/11/2021 **FORCED** **by CONED** **12/10/2021**  
1252 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7560 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 7815 MW

### CHAT\_DC\_GC1

Sun 12/12/2021 to Sun 12/12/2021  
0001 Continuous 0200

Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

### CHAT\_DC\_GC1

Sun 12/12/2021 to Sun 12/12/2021  
0001 Continuous 0200

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

### CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Sun 12/12/2021 to Sun 12/12/2021  
0001 0200

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **2550 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 3150 MW

### CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Sun 12/12/2021 to Sun 12/12/2021  
0001 0200

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY **1370 MW 0 MW**  
Impacts Total Transfer Capability 130 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

### CHAT\_DC\_GC2

Sun 12/12/2021 to Sun 12/12/2021  
0001 Continuous 0200

Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CHAT\_DC\_GC2**

Sun 12/12/2021 to Sun 12/12/2021  
0001 Continuous 0200  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

REV  
(Export)

**SCH-HQ-NYISO\_LIMIT\_1150**

Sun 12/12/2021 to Sun 12/12/2021  
0001 Continuous 0200  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 1500 MW

FWD  
(Import)

**LEEDS\_\_\_\_-HURLYAVE\_345\_301**

Mon 12/13/2021 to Fri 12/17/2021  
0630 Continuous 1600  
Work scheduled by: CHGE

UPDATED by CHGE 12/10/2021

UPNY CONED  
Impacts Total Transfer Capability 3715 MW  
TTC with All Lines In Service 7815 MW

FWD  
(Import)

**BERKSHIR-ALPS\_\_\_\_345\_393**

Tue 12/14/2021 to Tue 12/14/2021  
0800 Continuous 1700  
Work scheduled by: NGrid

SCH - NE - NY  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 1400 MW

FWD REV  
(Import) (Export)

ARR: 78

**BERKSHIR-ALPS\_\_\_\_345\_393**

Tue 12/14/2021 to Tue 12/14/2021  
0800 Continuous 1700  
Work scheduled by: NGrid

SCH - NPX\_1385  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 200 MW

FWD REV  
(Import) (Export)

ARR: 78

**N.SCTLND-ALPS\_\_\_\_345\_2**

Tue 12/14/2021 to Tue 12/14/2021  
0800 Continuous 1700  
Work scheduled by: NGrid

SCH - NE - NY  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1400 MW

FWD  
(Import)

**N.SCTLND-ALPS\_\_\_\_345\_2**

Tue 12/14/2021 to Tue 12/14/2021  
0800 Continuous 1700  
Work scheduled by: NGrid

SCH - NPX\_1385  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 200 MW

FWD REV  
(Import) (Export)

# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LADENTWN-BUCHAN\_S\_345\_Y88

FWD

Thu 12/16/2021 to Wed 12/22/2021  
0201 Continuous 0200

UPDATED

by CE

12/07/2021

Work scheduled by: ConEd

UPNY CONED **7560 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 7815 MW

### BECK\_-NIAGARA\_230\_PA27

FWD

Mon 12/20/2021 to Wed 12/22/2021  
0430 Continuous 1700

UPDATED

by NYPA

12/08/2021

Work scheduled by: NYPA

SCH - OH - NY **2100 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 2300 MW

### FRASER\_-GILBOA\_345\_GF5-35

FWD

Mon 12/20/2021 to Tue 12/21/2021  
0800 Continuous 1700

Work scheduled by: NYSEG

CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

### EDIC\_-FRASER\_345\_EF24-40

FWD

Wed 12/22/2021 to Thu 12/23/2021  
0830 Continuous 1500

UPDATED

by NYSEG

11/05/2021

Work scheduled by: NYSEG

CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

### LEEDS\_-PLSNTVLY\_345\_92

FWD

Mon 12/27/2021 to Mon 12/27/2021  
0830 Daily(No Weekends) 1500

Work scheduled by: NGrid

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### LEEDS\_-ATHENS\_345\_95

FWD

Tue 12/28/2021 to Tue 12/28/2021  
0900 Daily(No Weekends) 1400

UPDATED

by CE

12/09/2021

Work scheduled by: NGrid

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### LEEDS\_345KV\_R395

FWD

Tue 12/28/2021 to Tue 12/28/2021  
0900 Daily(No Weekends) 1400

UPDATED

by CE

12/09/2021

Work scheduled by: NGrid

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### FRASER\_\_\_345\_FRASER SVC

FWD

Tue 01/04/2022 to Mon 02/28/2022  
0700 Continuous 1730

UPDATED by NYPA 05/25/2021

Work scheduled by: NYPA

CENTRAL EAST - VC **2935 MW**  
Impacts Total Transfer Capability 40 MW  
TTC with All Lines In Service 2975 MW

### SCH-HQ\_CEDARS-NYISO LIMIT\_80

FWD

Wed 01/05/2022 to Wed 01/05/2022  
0800 Continuous 1700

Work scheduled by: HQ

(Import)  
SCH - HQ\_CEDARS **80 MW**  
Impacts Total Transfer Capability 199 MW  
TTC with All Lines In Service 279 MW

### HOPATCON-RAMAPO\_\_\_500\_5018

FWD

REV

Thu 01/06/2022 to Mon 01/10/2022  
0200 Continuous 1900

Work scheduled by: PJM

(Import) (Export)  
SCH - PJ - NY **1450 MW 1200 MW**  
Impacts Total Transfer Capability 1400 MW 1000 MW  
TTC with All Lines In Service 2850 MW 2200 MW

### HOPATCON-RAMAPO\_\_\_500\_5018

FWD

Thu 01/06/2022 to Mon 01/10/2022  
0200 Continuous 1900

Work scheduled by: PJM

(Import)  
UPNY CONED **7480 MW**  
Impacts Total Transfer Capability 335 MW  
TTC with All Lines In Service 7815 MW

### RAMAPO\_\_\_345\_345\_PAR3500

FWD

REV

Thu 01/06/2022 to Mon 01/10/2022  
0200 Continuous 1900

Work scheduled by: PJM

(Import) (Export)  
SCH - PJ - NY **2350 MW 1250 MW**  
Impacts Total Transfer Capability 500 MW 950 MW  
TTC with All Lines In Service 2850 MW 2200 MW

### RAMAPO\_\_\_345\_345\_PAR4500

FWD

REV

Thu 01/06/2022 to Mon 01/10/2022  
0200 Continuous 1900

Work scheduled by: PJM

(Import) (Export)  
SCH - PJ - NY **2350 MW 1250 MW**  
Impacts Total Transfer Capability 500 MW 950 MW  
TTC with All Lines In Service 2850 MW 2200 MW

### RAMAPO\_\_\_500\_345\_BK 1500

FWD

REV

Thu 01/06/2022 to Mon 01/10/2022  
0200 Continuous 1900

Work scheduled by: PJM

(Import) (Export)  
SCH - PJ - NY **1450 MW 1200 MW**  
Impacts Total Transfer Capability 1400 MW 1000 MW  
TTC with All Lines In Service 2850 MW 2200 MW



# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## RAMAPO\_\_\_500\_345\_BK 1500

FWD

Thu 01/06/2022 to Mon 01/10/2022

(Import)

0200 Continuous 1900

UPNY CONED

7480 MW

Impacts Total Transfer Capability 335 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: PJM

## BEAR SWP-EASTOVER\_230\_E205W

Mon 01/10/2022 to Thu 01/13/2022

UPDATEDby NGRID 12/06/2021

0600 Continuous 1700

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: ISONE

## HURLYAVE-ROSETON\_\_\_345\_303

FWD

Tue 01/11/2022 to Sat 01/22/2022

UPDATEDby CHGE 11/30/2021

0600 Continuous 1600

UPNY CONED

4100 MW

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: CHGE

## MOTTHAVN-RAINEY\_\_\_345\_Q11

FWD

Wed 01/12/2022 to Sat 01/15/2022

CANCELLEDby ConEd 12/06/2021

0001 Continuous 0200

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## DYSINGER-KINTIGH\_\_\_345\_38

FWD

Mon 01/17/2022 to Thu 01/20/2022

(Import)

0500 Continuous 1900

DYSINGER EAST

2500 MW

Impacts Total Transfer Capability 650 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYSEG

## NIAGARA\_-DYSINGER\_345\_ND1

FWD

Mon 01/17/2022 to Thu 01/20/2022

(Import)

0500 Continuous 1900

DYSINGER EAST

2500 MW

Impacts Total Transfer Capability 650 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## S.RIPLEY-DUNKIRK\_\_\_230\_68

Tue 01/18/2022 to Fri 02/04/2022

UPDATEDby NGRID 09/24/2021

0700 Continuous 1730

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NGrid

# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NIAGARA\_-STA\_255\_\_345\_NH2

FWD

Fri 01/21/2022 to Fri 03/04/2022  
0500 Continuous 1900

UPDATED

by NYPA

08/20/2021

(Import)

Work scheduled by: NYPA

DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

### FIVEMILE-STOLLERD\_345\_29

Mon 01/24/2022 to Sun 01/30/2022  
0500 Continuous 1900

Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### E13THSTA-FARRAGUT\_345\_45

FWD

Thu 01/27/2022 to Fri 01/28/2022  
0001 Continuous 0100

Work scheduled by: ConEd

(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### PLSNTVLY-WOOD\_ST\_\_345\_F30

FWD

Sat 01/29/2022 to Sat 01/29/2022  
0001 Continuous 0030

Work scheduled by: ConEd

(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLY\_345KV\_RNS5

FWD

Sat 01/29/2022 to Sat 01/29/2022  
0001 Continuous 0030

Work scheduled by: ConEd

(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLY-WOOD\_ST\_\_345\_F30

FWD

Wed 02/02/2022 to Wed 02/02/2022  
1930 Continuous 2000

Work scheduled by: ConEd

(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLY\_345KV\_RNS5

FWD

Wed 02/02/2022 to Wed 02/02/2022  
1930 Continuous 2000

Work scheduled by: ConEd

(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NIAGARA\_\_-PACKARD\_\_230\_61

Thu 02/03/2022 to Sat 02/12/2022  
0615 Continuous 1900

UPDATED by NGRID 12/03/2021

Work scheduled by: NGrid

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1200 MW</b>	<b>1850 MW</b>
Impacts Total Transfer Capability	1100 MW	150 MW
TTC with All Lines In Service	2300 MW	2000 MW

### MARCY\_\_-N.SCTLND\_345\_18

Tue 02/08/2022 to Wed 02/09/2022  
0700 Continuous 1530

ARR: 19

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>1470 MW</b>
Impacts Total Transfer Capability	1505 MW
TTC with All Lines In Service	2975 MW

### PLSNTVLY\_345KV\_RNS4

Sat 02/12/2022 to Sat 02/12/2022  
0600 Continuous 0630

UPDATED by CONED 11/12/2021

Work scheduled by: NGrid

	FWD
	(Import)
UPNY CONED	<b>3800 MW</b>
Impacts Total Transfer Capability	4015 MW
TTC with All Lines In Service	7815 MW

### ATHENS\_\_-PLSNTVLY\_345\_91

Sat 02/12/2022 to Wed 02/16/2022  
0600 Continuous 1900

UPDATED by CONED 11/12/2021

Work scheduled by: NGrid

	FWD
	(Import)
UPNY CONED	<b>3800 MW</b>
Impacts Total Transfer Capability	4015 MW
TTC with All Lines In Service	7815 MW

### BUCHAN\_N-EASTVIEW\_345\_W93

Sun 02/13/2022 to Mon 02/14/2022  
0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>4350 MW</b>
Impacts Total Transfer Capability	3465 MW
TTC with All Lines In Service	7815 MW

### RAMAPO\_\_-BUCHAN\_N\_345\_Y94

Sun 02/13/2022 to Mon 02/14/2022  
0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>7580 MW</b>
Impacts Total Transfer Capability	235 MW
TTC with All Lines In Service	7815 MW

### MILLWOOD\_345KV\_18

Mon 02/14/2022 to Tue 02/15/2022  
0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>4350 MW</b>
Impacts Total Transfer Capability	3465 MW
TTC with All Lines In Service	7815 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PLSNTVLY\_345KV\_RNS4

FWD

Wed 02/16/2022 to Wed 02/16/2022 UPDATED by CONED 11/12/2021

(Import)

1830 Continuous 1900

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

### PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

FWD

Thu 02/17/2022 to Sat 02/19/2022

(Import)

0001 2200

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by:

### LEEDS\_\_-PLSNTVLY\_345\_92

FWD

Thu 02/17/2022 to Fri 03/25/2022 UPDATED by NYISO 11/15/2021

(Import)

0001 Continuous 2200

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### PLSNTVLY\_345KV\_RNS5

FWD

Thu 02/17/2022 to Fri 03/25/2022 UPDATED by NYISO 11/15/2021

(Import)

0001 Continuous 2200

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### PLSNTVLY-WOOD\_ST\_\_345\_F30

FWD

Sun 02/20/2022 to Mon 02/21/2022

(Import)

0001 Continuous 2200

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### EASTVIEW-SPRNBRK\_\_345\_W64

FWD

Sun 02/20/2022 to Mon 02/21/2022

(Import)

2000 Continuous 2359

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### MILLWOOD-EASTVIEW\_345\_W99

FWD

Sun 02/20/2022 to Mon 02/21/2022

(Import)

2000 Continuous 2359

UPNY CONED

**7550 MW**

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_\_345KV\_RNS5

Sun 02/20/2022 to Mon 02/21/2022

2000 Continuous 2359

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

### EASTVIEW-SPRNBK\_\_345\_W64

Tue 02/22/2022 to Tue 02/22/2022

0001 Continuous 0030

Work scheduled by: ConEd

UPDATED

by CONED 08/31/2021

FWD

(Import)

UPNY CONED **4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

### SPRNBK\_\_345KV\_RNS5

Tue 02/22/2022 to Tue 02/22/2022

0001 Continuous 0030

Work scheduled by: ConEd

UPDATED

by CONED 08/31/2021

FWD

(Import)

SPR/DUN-SOUTH **3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

### MILLWOOD-EASTVIEW\_345\_W99

Tue 02/22/2022 to Mon 03/21/2022

0001 Continuous 0200

Work scheduled by: ConEd

UPDATED

by CONED 08/31/2021

FWD

(Import)

UPNY CONED **7550 MW**

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

### MARCY\_\_-EDIC\_\_345\_UE1-7

Wed 02/23/2022 to Mon 02/28/2022

0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19&16**

FWD

(Import)

OSWEGO EXPORT **5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

### FIVEMILE-STOLLERD\_345\_29

Tue 03/01/2022 to Tue 04/12/2022

0500 Continuous 1900

Work scheduled by: NYSEG

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### PORTER\_\_-ROTTRDAM\_230\_31

Tue 03/01/2022 to Tue 12/31/2030

0600 Continuous 2359

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC **2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### N.SCTLND-LEEDS\_\_\_\_345\_93

Tue 03/01/2022 to Mon 03/28/2022 UPDATED by NGRID 11/15/2021  
0700 Continuous 1900

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

### EDIC\_\_\_\_-N.SCTLND\_345\_14

Tue 03/01/2022 to Tue 04/12/2022 UPDATED by NGRID 11/15/2021  
0700 Continuous 1900

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC **1670 MW**  
Impacts Total Transfer Capability 1305 MW  
TTC with All Lines In Service 2975 MW

### EDIC\_\_\_\_-N.SCTLND\_345\_14 & PORTER\_\_\_\_-ROTTRDAM\_230\_31

Tue 03/01/2022 to Tue 04/12/2022  
0700 1900

Work scheduled by:

FWD

(Import)

CENTRAL EAST - VC **1500 MW**  
Impacts Total Transfer Capability 1475 MW  
TTC with All Lines In Service 2975 MW

### FRASANX-COOPERS\_\_345\_UCC2-41

Tue 03/01/2022 to Wed 04/20/2022  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

### MARCY\_\_\_\_-FRASANX\_345\_UCC2-41

Tue 03/01/2022 to Wed 04/20/2022  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

### N.SCTLND-ALPS\_\_\_\_345\_2

Tue 03/01/2022 to Fri 06/24/2022 UPDATED by NGRID 11/15/2021  
0700 Continuous 1900

Work scheduled by: NGrid

FWD

(Import)

SCH - NE - NY **900 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1400 MW

### N.SCTLND-ALPS\_\_\_\_345\_2

Tue 03/01/2022 to Fri 06/24/2022 UPDATED by NGRID 11/15/2021  
0700 Continuous 1900

Work scheduled by: NGrid

FWD

(Import) (Export)

SCH - NPX\_1385 **100 MW** **100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### GOETHALS\_345KV\_5

Sat 03/05/2022 to Mon 04/04/2022 UPDATED by CONED 03/26/2021

0001 Continuous 0200

Work scheduled by: ConEd

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

### LINDEN\_\_-GOETHALS\_230\_A2253

Sat 03/05/2022 to Mon 04/04/2022 UPDATED by CONED 03/26/2021

0001 Continuous 0200

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### LINDEN\_\_-GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402

Sat 03/05/2022 to Mon 04/04/2022

0001 0200

Work scheduled by:

FWD REV

(Import) (Export)

SCH - PJ - NY

**2550 MW 1900 MW**

Impacts Total Transfer Capability 300 MW 300 MW

TTC with All Lines In Service 2850 MW 2200 MW

### LINDEN\_\_-GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_\_-FARRAGUT\_345\_C3403

Sat 03/05/2022 to Mon 04/04/2022

0001 0200

Work scheduled by:

FWD REV

(Import) (Export)

SCH - PJ - NY

**2550 MW 1900 MW**

Impacts Total Transfer Capability 300 MW 300 MW

TTC with All Lines In Service 2850 MW 2200 MW

### LINDEN\_\_-GOETHALS\_230\_A2253 & MARION\_\_-FARRAGUT\_345\_C3403

Sat 03/05/2022 to Mon 04/04/2022

0001 0200

Work scheduled by:

FWD REV

(Import) (Export)

SCH - PJ - NY

**2550 MW 1900 MW**

Impacts Total Transfer Capability 300 MW 300 MW

TTC with All Lines In Service 2850 MW 2200 MW

### INDPDNCE-SCRIBA\_\_345\_25

Thu 03/10/2022 to Wed 03/16/2022

0800 Continuous 1800

Work scheduled by: NGrid

FWD

(Import)

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

### NIAGARA\_-DYSINGER\_345\_ND1

Fri 03/11/2022 to Fri 03/11/2022

0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

**2500 MW**

Impacts Total Transfer Capability 650 MW

TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

FWD

Thu 03/17/2022 to Sun 03/20/2022  
0100 2200

Work scheduled by:

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## PLSNTVLY-WOOD\_ST\_\_345\_F30

FWD

Mon 03/21/2022 to Wed 03/23/2022  
0001 Continuous 2200

Work scheduled by: ConEd

(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

## EASTVIEW-SPRNBK\_\_345\_W64

FWD

Mon 03/21/2022 to Mon 03/21/2022 UPDATED by CONED 08/31/2021  
0130 Continuous 0200

Work scheduled by: ConEd

(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

## SPRNBK\_\_345KV\_RNS5

FWD

Mon 03/21/2022 to Mon 03/21/2022 UPDATED by CONED 08/31/2021  
0130 Continuous 0200

Work scheduled by: ConEd

(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

## NIAGARA\_-STA\_255\_\_345\_NH2

FWD

Fri 03/25/2022 to Fri 03/25/2022  
0500 Continuous 1700

Work scheduled by: NYPA

(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

FWD

Sat 03/26/2022 to Mon 03/28/2022  
0001 2200

Work scheduled by:

(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## ATHENS\_-PLSNTVLY\_345\_91

FWD

Sat 03/26/2022 to Sun 05/01/2022  
0001 Continuous 2200

Work scheduled by: ConEd

(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW



# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PLSNTVLY\_345KV\_RNS4

FWD

Sat 03/26/2022 to Sun 05/01/2022

(Import)

0001 Continuous 2200

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### PLSNTVLY-WOOD\_ST\_\_345\_F31

FWD

Tue 03/29/2022 to Wed 03/30/2022

(Import)

0001 Continuous 2200

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### LINDN\_CG-LNDVFT\_\_345\_V-3022

FWD

REV

Sun 04/03/2022 to Sat 04/09/2022

(Import) (Export)

1400 Continuous 1400

SCH - PJM\_VFT

**0 MW**

**0 MW**

Impacts Total Transfer Capability 315 MW 315 MW

TTC with All Lines In Service 315 MW 315 MW

Work scheduled by: PJM

### SPRNBK\_-TREMONT\_\_345\_X28

FWD

Tue 04/05/2022 to Wed 04/06/2022

(Import)

0201 Continuous 0300

SPR/DUN-SOUTH

**4200 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### BUCHAN\_N-EASTVIEW\_345\_W93

FWD

Wed 04/06/2022 to Wed 04/06/2022

UPDATED

by CONED

08/19/2021

(Import)

0301 Continuous 0330

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### EASTVIEW-SPRNBK\_\_345\_W79

FWD

Wed 04/06/2022 to Thu 04/07/2022

UPDATED

by CONED

08/19/2021

(Import)

0301 Continuous 0300

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### BUCHAN\_N-EASTVIEW\_345\_W93

FWD

Thu 04/07/2022 to Thu 04/07/2022

UPDATED

by CONED

08/19/2021

(Import)

0230 Continuous 0300

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## EASTVIEW-SPRNBK\_\_345\_W64

FWD

Thu 04/07/2022 to Thu 04/07/2022 UPDATED by CONED 08/31/2021

(Import)

0301 Continuous 0330

Work scheduled by: ConEd

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

## SPRNBK\_\_345KV\_RNS5

FWD

Thu 04/07/2022 to Thu 04/07/2022 UPDATED by CONED 08/31/2021

(Import)

0301 Continuous 0330

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

## MILLWOOD-EASTVIEW\_345\_W99

FWD

Thu 04/07/2022 to Tue 04/26/2022 UPDATED by CONED 08/31/2021

(Import)

0301 Continuous 2200

Work scheduled by: ConEd

UPNY CONED

**7550 MW**

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

## PANNELL\_-CLAY\_\_\_\_345\_1

FWD

Mon 04/11/2022 to Fri 04/15/2022

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

## GOETHALS\_345KV\_5

Wed 04/13/2022 to Fri 05/13/2022

0001 Continuous 0259

Work scheduled by: ConEd

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

## PORTER\_-ROTTDAM\_230\_30

FWD

Wed 04/13/2022 to Tue 12/31/2030

(Import)

0600 Continuous 2359

Work scheduled by: NGrid

CENTRAL EAST - VC

**2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

## PANNELL\_-CLAY\_\_\_\_345\_2

FWD

Mon 04/18/2022 to Fri 04/22/2022

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## EDIC\_\_\_\_-FRASER\_\_\_\_345\_EF24-40

Thu 04/21/2022 to Tue 06/14/2022  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

## MARCY\_\_\_\_345KV\_CSC

Fri 04/22/2022 to Sat 04/23/2022  
0700 Continuous 1730  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

## PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Sat 04/23/2022 to Tue 04/26/2022  
0001 2200  
Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## ROCHESTR-PANNELL\_\_\_\_345\_RP1

Mon 04/25/2022 to Fri 04/29/2022  
0500 Continuous 1700  
Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## SAND\_BAR-PLATSBRG\_115\_PV20

Mon 04/25/2022 to Fri 04/29/2022  
0700 Continuous 1530  
Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## EASTVIEW-SPRNBK\_\_\_\_345\_W64

Tue 04/26/2022 to Tue 04/26/2022 UPDATED by CONED 08/31/2021  
2130 Continuous 2200  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

## SPRNBK\_\_\_\_345KV\_RNS5

Tue 04/26/2022 to Tue 04/26/2022 UPDATED by CONED 08/31/2021  
2130 Continuous 2200  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PLSNTVLY-WOOD\_ST\_\_345\_F31

FWD

Wed 04/27/2022 to Fri 04/29/2022

(Import)

0001 Continuous 2200

UPNY CONED **4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### NIAGARA\_\_345\_230\_AT4

REV

Fri 04/29/2022 to Fri 04/29/2022

(Export)

0500 Continuous 1700

SCH - OH - NY **1750 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 2000 MW

Work scheduled by: NYPA

### BUCHAN\_N-EASTVIEW\_345\_W93

FWD

Mon 05/02/2022 to Mon 05/02/2022

(Import)

0001 Continuous 0030

UPNY CONED **4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### EASTVIEW-SPRNBK\_\_345\_W79

FWD

Mon 05/02/2022 to Thu 05/05/2022

(Import)

0001 Continuous 0200

UPNY CONED **4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### ROCHESTR-PANNELL\_\_345\_RP2

FWD

Mon 05/02/2022 to Fri 05/06/2022

(Import)

0500 Continuous 1700

DYSINGER EAST **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

### BUCHAN\_N-EASTVIEW\_345\_W93

FWD

Thu 05/05/2022 to Thu 05/05/2022

(Import)

0130 Continuous 0200

UPNY CONED **4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### SPRNBK\_-TREMONT\_\_345\_X28

FWD

Fri 05/06/2022 to Mon 05/09/2022

(Import)

0201 Continuous 1800

SPR/DUN-SOUTH **4200 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

UPDATED by CONED 08/19/2021

# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### FRASER\_\_\_345\_FRASER SVC

Mon 05/09/2022 to Fri 05/13/2022  
0800 Continuous 1700

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2935 MW**  
Impacts Total Transfer Capability 40 MW  
TTC with All Lines In Service 2975 MW

### PLSNTVLE-DUNWODIE\_345\_W89

Fri 05/13/2022 to Fri 05/13/2022  
0200 Continuous 0230

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

### EFISHKIL-WOOD\_ST\_\_345\_F38

Fri 05/13/2022 to Fri 05/13/2022  
0200 Continuous 0430

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

### WOOD\_ST\_-PLSNTVLE\_345\_Y86

Fri 05/13/2022 to Fri 05/13/2022  
0200 Continuous 0430

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7210 MW**  
Impacts Total Transfer Capability 605 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLE-DUNWODIE\_345\_W89

Fri 05/13/2022 to Fri 05/13/2022  
0400 Continuous 0430

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 05/16/2022 to Fri 05/27/2022  
0600 Continuous 1800

Work scheduled by: LI

FWD	REV
(Import)	(Export)
SCH - NPX_CSC	<b>0 MW</b> <b>0 MW</b>
Impacts Total Transfer Capability	330 MW 330 MW
TTC with All Lines In Service	330 MW 330 MW

### DUNWODIE-MOTTHAVN\_345\_71

Thu 05/19/2022 to Fri 05/20/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_3

FWD

Thu 05/19/2022 to Fri 05/20/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### DUNWODIE\_345KV\_5

FWD

Thu 05/19/2022 to Fri 05/20/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### HOMRC\_NY-MAINS\_NY\_345\_47

Fri 05/20/2022 to Fri 05/27/2022

UPDATED

by PJM

11/19/2020

0800 Continuous 1600

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: PJM

### HOMR\_NYW-PIERC\_NY\_345\_48

Fri 05/20/2022 to Fri 05/27/2022

UPDATED

by PJM

11/19/2020

0800 Continuous 1600

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: PJM

### MARCY\_\_-EDIC\_\_\_\_345\_UE1-7

FWD

Sat 05/21/2022 to Sat 05/21/2022

(Import)

0700 Continuous 1730

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19&16**

### PORTER\_\_-ROTTRDAM\_230\_30 & VOLNEY\_\_-MARCY\_\_\_\_345\_19

FWD

Sat 05/21/2022 to Sat 05/21/2022

(Import)

0700 1730

CENTRAL EAST - VC

**2655 MW**

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

### PORTER\_\_-ROTTRDAM\_230\_31 & VOLNEY\_\_-MARCY\_\_\_\_345\_19

FWD

Sat 05/21/2022 to Sat 05/21/2022

(Import)

0700 1730

CENTRAL EAST - VC

**2655 MW**

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### VOLNEY\_\_-MARCY\_\_\_\_345\_19

Sat 05/21/2022 to Sat 05/21/2022  
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2825 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 2975 MW

### VOLNEY\_\_-MARCY\_\_\_\_345\_19

Sat 05/21/2022 to Sat 05/21/2022  
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
OSWEGO EXPORT **4900 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 5250 MW

### MOSES\_\_-ADIRNDCK\_230\_MA2

Wed 06/01/2022 to Tue 11/29/2022  
0700 Continuous 1800

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

### NIAGARA\_-DYSINGER\_345\_ND1

Mon 06/13/2022 to Fri 06/17/2022  
0500 Continuous 2100

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2500 MW**  
Impacts Total Transfer Capability 650 MW  
TTC with All Lines In Service 3150 MW

### NIAGARA\_-PACKARD\_\_230\_62

Sat 06/18/2022 to Sat 06/18/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD	REV
(Import)	(Export)
SCH - OH - NY	<b>700 MW 1550 MW</b>
Impacts Total Transfer Capability	1250 MW 150 MW
TTC with All Lines In Service	1950 MW 1700 MW

### NIAGARA\_\_345\_230\_AT4

Tue 06/28/2022 to Wed 06/29/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD	REV
(Import)	(Export)
SCH - OH - NY	<b>1900 MW 1400 MW</b>
Impacts Total Transfer Capability	50 MW 300 MW
TTC with All Lines In Service	1950 MW 1700 MW

### BECK\_\_\_\_-NIAGARA\_\_230\_PA27

Tue 07/05/2022 to Sat 07/09/2022  
0500 Continuous 2100

Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NIAGARA\_-DYSINGER\_345\_ND1

FWD

Mon 07/11/2022 to Fri 07/15/2022

(Import)

0500 Continuous 1700

DYSINGER EAST **2500 MW**

Impacts Total Transfer Capability 650 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

### ROCHESTR-PANNELL\_345\_RP1

FWD

Mon 07/25/2022 to Fri 07/29/2022

(Import)

0500 Continuous 2100

DYSINGER EAST **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

### NIAGARA\_-STA\_255\_345\_NH2

FWD

Mon 08/01/2022 to Fri 08/05/2022

(Import)

0500 Continuous 1700

DYSINGER EAST **1400 MW**

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

### MARCY\_-EDIC\_345\_UE1-7

FWD

Sat 08/06/2022 to Sat 08/06/2022

(Import)

0500 Continuous 1830

OSWEGO EXPORT **5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

ARR: 19&16

### PORTER\_-ROTTRDAM\_230\_30 & VOLNEY\_-MARCY\_345\_19

FWD

Sat 08/06/2022 to Sat 08/06/2022

(Import)

0500 1830

CENTRAL EAST - VC **2655 MW**

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

### PORTER\_-ROTTRDAM\_230\_31 & VOLNEY\_-MARCY\_345\_19

FWD

Sat 08/06/2022 to Sat 08/06/2022

(Import)

0500 1830

CENTRAL EAST - VC **2655 MW**

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

### VOLNEY\_-MARCY\_345\_19

FWD

Sat 08/06/2022 to Sat 08/06/2022

(Import)

0500 Continuous 1830

CENTRAL EAST - VC **2825 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

ARR: 19



# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### VOLNEY\_\_-MARCY\_\_\_\_345\_19

Sat 08/06/2022 to Sat 08/06/2022  
0500 Continuous 1830

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
OSWEGO EXPORT **4900 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 5250 MW

### SAND\_BAR-PLATSBURG\_115\_PV20

Mon 08/22/2022 to Fri 08/26/2022  
0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### ROSETON\_-ROCKTVRN\_345\_311

Mon 08/29/2022 to Fri 09/09/2022  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 3415 MW  
TTC with All Lines In Service 7815 MW

### PANNELL\_-CLAY\_\_\_\_345\_1

Mon 09/12/2022 to Fri 09/16/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

### FRASER\_\_-GILBOA\_\_\_\_345\_GF5-35

Mon 09/12/2022 to Sun 09/18/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

### PANNELL\_-CLAY\_\_\_\_345\_2

Mon 09/19/2022 to Fri 09/23/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

### NIAGARA\_-DYSINGER\_345\_ND1

Mon 09/26/2022 to Fri 09/30/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2500 MW**  
Impacts Total Transfer Capability 650 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_\_345KV\_RNS5

FWD

Sat 10/01/2022 to Mon 10/17/2022 EXTENDED by CONED 12/06/2021

(Import)

0001 Continuous 0300

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### SPRNBK\_-W49TH\_ST\_345\_M51

FWD

Sat 10/01/2022 to Tue 11/08/2022 EXTENDED by CONED 12/06/2021

(Import)

0001 Continuous 0300

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### SHOR\_NPX-SHOREHAM\_138\_CSC

FWD

REV

Mon 10/03/2022 to Fri 10/21/2022

(Import) (Export)

0600 Continuous 1800

SCH - NPX\_CSC

**0 MW**

**0 MW**

Impacts Total Transfer Capability 330 MW 330 MW

TTC with All Lines In Service 330 MW 330 MW

Work scheduled by: LI

### NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

FWD

Mon 10/10/2022 to Fri 10/14/2022

(Import)

0600 Continuous 1600

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

### NEWBRDGE-DUFFYAVE\_345\_501

FWD

Mon 10/10/2022 to Fri 10/14/2022

(Import)

0600 Continuous 1600

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

### NEWBRDGE\_345\_138\_BK\_1

FWD

Mon 10/10/2022 to Fri 10/14/2022

(Import)

0600 Continuous 1600

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

### NEWBRDGE\_345\_138\_BK\_2

FWD

Mon 10/10/2022 to Fri 10/14/2022

(Import)

0600 Continuous 1600

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

# NYISO TRANSFER LIMITATIONS

Saturday ,December 11, 2021 to Monday ,June 12, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### GILBOA\_\_-N.SCTLND\_345\_GNS-1

Mon 10/31/2022 to Mon 11/28/2022  
0500 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2520 MW**  
Impacts Total Transfer Capability 455 MW  
TTC with All Lines In Service 2975 MW

### LEEDS\_\_\_\_345KV\_R94301

Mon 10/31/2022 to Mon 11/28/2022  
0500 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### MARCY\_\_-N.SCTLND\_345\_18

Mon 10/31/2022 to Mon 11/28/2022  
0500 Continuous 1900

Work scheduled by: NGrid

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **1470 MW**  
Impacts Total Transfer Capability 1505 MW  
TTC with All Lines In Service 2975 MW

### N.SCTLND-LEEDS\_\_\_\_345\_94

Mon 10/31/2022 to Mon 11/28/2022  
0500 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

### PORTER\_\_-ROTTRDAM\_230\_30 & MARCY\_\_-N.SCTLND\_345\_18

Mon 10/31/2022 to Mon 11/28/2022  
0500 1900

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **1300 MW**  
Impacts Total Transfer Capability 1675 MW  
TTC with All Lines In Service 2975 MW

### PORTER\_\_-ROTTRDAM\_230\_31 & MARCY\_\_-N.SCTLND\_345\_18

Mon 10/31/2022 to Mon 11/28/2022  
0500 1900

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **1300 MW**  
Impacts Total Transfer Capability 1675 MW  
TTC with All Lines In Service 2975 MW

### SPRNBK\_\_345KV\_RNS5

Tue 11/08/2022 to Tue 11/08/2022  
0230 Continuous 0300

Work scheduled by: ConEd

EXTENDED by CONED 12/06/2021

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

**NYISO TRANSFER LIMITATIONS**

Saturday ,December 11, 2021 to Monday ,June 12, 2023

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 7815MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MAl

FWD

Wed 11/30/2022 to Wed 03/01/2023

(Import)

0700 Continuous 1100

MOSES SOUTH

**2300 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## SHOR\_NPX-SHOREHAM\_138\_CSC

FWD

REV

Mon 05/01/2023 to Fri 05/05/2023

(Import) (Export)

0600 Continuous 1800

SCH - NPX\_CSC

**0 MW****0 MW**

Work scheduled by: LI

Impacts Total Transfer Capability 330 MW 330 MW

TTC with All Lines In Service 330 MW 330 MW