

# NYISO TRANSFER LIMITATIONS

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Tue 05/31/2022 EXT FORCE by CONED 11/08/2021

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Tue 05/31/2022

0001 2359

Work scheduled by:

FWD REV  
(Import) (Export)

SCH - PJ - NY

Impacts Total Transfer Capability 300 MW 300 MW

TTC with All Lines In Service 2850 MW 2200 MW

## MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Tue 05/31/2022 EXT FORCE by CONED 11/08/2021

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## STLAWRNC-MOSES\_230\_L33P

Mon 04/30/2018 to Tue 05/31/2022 EXT FORCE by IESO 11/04/2021

0456 Continuous 1600

Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## NEWBRDGE\_345\_138\_BK\_1

Wed 09/02/2020 to Mon 08/01/2022 EXT FORCE by LI 11/29/2021

1807 Continuous 2359

Work scheduled by: LI

FWD  
(Import)

SCH - PJM\_NEPTUNE

Impacts Total Transfer Capability 375 MW 285 MW

TTC with All Lines In Service 660 MW

## PORTER\_-ROTTRDAM\_230\_30

Wed 09/15/2021 to Tue 11/30/2021 UPDATED by NGRID 08/31/2021

0700 Continuous 1730

Work scheduled by: NGrid

FWD  
(Import)

CENTRAL EAST - VC

Impacts Total Transfer Capability 2805 MW 170 MW

TTC with All Lines In Service 2975 MW

## CHAT\_DC\_GC1

Sun 10/03/2021 to Tue 11/30/2021 UPDATED by HQ 11/23/2021

0500 Continuous 1900

Work scheduled by: HQ

FWD  
(Import)

MOSES SOUTH

Impacts Total Transfer Capability 2850 MW 300 MW

TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CHAT\_DC\_GC1

REV

Sun 10/03/2021 to Tue 11/30/2021  
0500 Continuous 1900

UPDATEDby HQ11/23/2021

Work scheduled by: HQ

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

(Export)

**500 MW**

500 MW

1000 MW

## SCH-HQ-NYISO\_LIMIT\_1200

FWD

Thu 10/07/2021 to Tue 11/30/2021  
0001 Continuous 1900

UPDATEDby HQ11/23/2021

Work scheduled by: HQ

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

(Import)

**1200 MW**

300 MW

1500 MW

## DUNWODIE\_345KV\_5

FWD

Thu 10/14/2021 to Thu 12/02/2021  
0001 Continuous 2200

EXTENDEDby CONED11/21/2021

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

(Import)

**3800 MW**

800 MW

4600 MW

## DUNWODIE\_345KV\_7

FWD

Thu 10/14/2021 to Thu 12/02/2021  
0001 Continuous 2200

EXTENDEDby CONED11/21/2021

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

(Import)

**3800 MW**

800 MW

4600 MW

## SPRNBK\_-DUNWODIE\_345\_W75

FWD

Thu 10/14/2021 to Thu 12/02/2021  
0001 Continuous 2200

EXTENDEDby CONED11/21/2021

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

(Import)

**3800 MW**

800 MW

4600 MW

## SPRNBK\_345KV\_RNS3

FWD

Thu 10/14/2021 to Thu 12/02/2021  
0001 Continuous 2200

EXTENDEDby CONED11/21/2021

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

(Import)

**3800 MW**

800 MW

4600 MW

## NIAGARA\_-KINTIGH\_345\_NS1-38

FWD

Mon 10/18/2021 to Sat 12/31/2022  
0500 Continuous 2359

UPDATEDby NYPA11/18/2021

Work scheduled by: NYPA

DYSINGER EAST

Impacts Total Transfer Capability

TTC with All Lines In Service

(Import)

**1700 MW**

1450 MW

3150 MW

**NYISO TRANSFER LIMITATIONS**

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DYSINGER-KINTIGH__345_38</b>					FWD
Tue 10/26/2021	to	Wed 12/08/2021			(Import)
1127	Continuous	1900			
Work scheduled by: NYISO					
					DYSINGER EAST <b>2500 MW</b>
					Impacts Total Transfer Capability 650 MW
					TTC with All Lines In Service 3150 MW
<b>NIAGARA_-DYSINGER_345_ND1</b>					FWD
Tue 10/26/2021	to	Wed 12/08/2021			(Import)
1127	Continuous	1900			
Work scheduled by: NYISO					
					DYSINGER EAST <b>2500 MW</b>
					Impacts Total Transfer Capability 650 MW
					TTC with All Lines In Service 3150 MW
<b>W49TH_ST_345KV_5</b>					FWD
Sat 10/30/2021	to	Sun 12/12/2021	<u>EXTENDED</u>	<u>by CONED</u> <u>12/02/2021</u>	(Import)
0001	Continuous	0200			
Work scheduled by: ConEd					
					SCH - PJM_HTP <b>300 MW</b>
					Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service 660 MW
<b>BUCHAN_S-MILLWOOD_345_W97</b>					FWD
Mon 11/01/2021	to	Thu 12/16/2021	<u>UPDATED</u>	<u>by CE</u> <u>11/26/2021</u>	(Import)
0001	Continuous	0200			
Work scheduled by: ConEd					
					UPNY CONED <b>7680 MW</b>
					Impacts Total Transfer Capability 135 MW
					TTC with All Lines In Service 7815 MW
<b>SCH-IMO-NYISO_LIMIT_1750</b>					FWD
Mon 11/01/2021	to	Fri 12/31/2021	<u>UPDATED</u>	<u>by IESO</u> <u>05/03/2019</u>	(Import)
0001	Continuous	2359			
Work scheduled by: IESO					
					SCH - OH - NY <b>2050 MW</b>
					Impacts Total Transfer Capability 250 MW
					TTC with All Lines In Service 2300 MW
<b>SCH-NYISO-IMO_LIMIT_1600</b>					REV
Mon 11/01/2021	to	Fri 12/31/2021	<u>UPDATED</u>	<u>by IESO</u> <u>05/03/2019</u>	(Export)
0001	Continuous	2359			
Work scheduled by: IESO					
					SCH - OH - NY <b>1900 MW</b>
					Impacts Total Transfer Capability 100 MW
					TTC with All Lines In Service 2000 MW
<b>SCH-NYISO-IMO_LIMIT_1200</b>					REV
Wed 11/03/2021	to	Fri 12/17/2021	<u>EXTENDED</u>	<u>by IESO</u> <u>11/19/2021</u>	(Export)
0800	Continuous	1700			
Work scheduled by: IESO					
					SCH - OH - NY <b>1500 MW</b>
					Impacts Total Transfer Capability 500 MW
					TTC with All Lines In Service 2000 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CHATGUAY-MASSENA\_\_765\_7040

Wed 11/10/2021 to Tue 11/30/2021  
0300 Continuous 1859

EXTENDED by HQ 11/04/2021

Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

## CHATGUAY-MASSENA\_\_765\_7040

Wed 11/10/2021 to Tue 11/30/2021  
0300 Continuous 1859

EXTENDED by HQ 11/04/2021

Work scheduled by: HQ

FWD REV  
(Import) (Export)  
SCH - HQ - NY **0 MW 0 MW**  
Impacts Total Transfer Capability 1500 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

## CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Wed 11/10/2021 to Tue 11/30/2021  
0300 1859

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **2550 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Wed 11/10/2021 to Tue 11/30/2021  
0300 1859

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY **1370 MW 0 MW**  
Impacts Total Transfer Capability 130 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

## CHAT\_DC\_GC2

Wed 11/10/2021 to Tue 11/30/2021  
0300 Continuous 1859

EXTENDED by HQ 11/04/2021

Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC2

Wed 11/10/2021 to Tue 11/30/2021  
0300 Continuous 1859

EXTENDED by HQ 11/04/2021

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

## SCH-IMO-NYISO\_LIMIT\_1550

Fri 11/12/2021 to Fri 12/17/2021  
1201 Continuous 1700

EXTENDED by IESO 11/19/2021

Work scheduled by: IESO

FWD  
(Import)  
SCH - OH - NY **1850 MW**  
Impacts Total Transfer Capability 450 MW  
TTC with All Lines In Service 2300 MW

**NYISO TRANSFER LIMITATIONS**

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PORTER\_\_-ROTTRDAM\_230\_30 &amp; MASSENA\_-MARCY\_\_\_\_765\_MSU1

FWD

Mon 11/15/2021 to Tue 11/30/2021

(Import)

0100

1730

CENTRAL EAST - VC

**1500 MW**

Impacts Total Transfer Capability 1475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

MARCY\_\_\_\_765\_345\_AT1

FWD

Mon 11/15/2021 to Tue 11/30/2021

(Import)

0100

Continuous

1859

UPDATEDby NYPA11/24/2021

MOSES SOUTH

**1750 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19**

MARCY\_\_\_\_765\_345\_AT2

FWD

Mon 11/15/2021 to Tue 11/30/2021

(Import)

0100

Continuous

1859

UPDATEDby NYPA11/24/2021

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19**

MASSENA\_-MARCY\_\_\_\_765\_MSU1

FWD

Mon 11/15/2021 to Tue 11/30/2021

(Import)

0100

Continuous

1859

UPDATEDby NYPA11/24/2021

CENTRAL EAST - VC

**1670 MW**

Impacts Total Transfer Capability 1305 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

MASSENA\_-MARCY\_\_\_\_765\_MSU1

FWD

Mon 11/15/2021 to Tue 11/30/2021

(Import)

0100

Continuous

1859

UPDATEDby NYPA11/24/2021

MOSES SOUTH

**500 MW**

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

MASSENA\_-MARCY\_\_\_\_765\_MSU1

FWD

REV

Mon 11/15/2021 to Tue 11/30/2021

(Import) (Export)

0100

Continuous

1859

UPDATEDby NYPA11/24/2021

SCH - HQ - NY

**475 MW****1000 MW**

Impacts Total Transfer Capability 1025 MW

0 MW

TTC with All Lines In Service 1500 MW

1000 MW

Work scheduled by: NYPA

MASSENA\_-MARCY\_\_\_\_765\_MSU1

FWD

Mon 11/15/2021 to Tue 11/30/2021

(Import)

0100

Continuous

1859

UPDATEDby NYPA11/24/2021

SCH - HQ\_CEDARS

**90 MW**

Impacts Total Transfer Capability 189 MW

TTC with All Lines In Service 279 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA\_-MARCY\_\_\_765\_MSU1 & CHATGUAY-MASSENA\_\_\_765\_7040

Mon 11/15/2021 to Tue 11/30/2021  
0100 1859

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

STLAWRNC-MOSES\_\_\_230\_L33P & MASSENA\_-MARCY\_\_\_765\_MSU1

Mon 11/15/2021 to Tue 11/30/2021  
0100 1859

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS **90 MW**  
Impacts Total Transfer Capability 189 MW  
TTC with All Lines In Service 279 MW

SPRNBRK\_\_\_345KV\_RS3 & SPRNBRK\_\_\_345KV\_RS4

Tue 11/23/2021 to Wed 12/01/2021  
0001 0200

Work scheduled by:

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

HOMR\_NYW-PIERC\_NY\_345\_48

Tue 11/23/2021 to Tue 12/07/2021  
0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

DUNWODIE-MOTTHAVN\_345\_71

Wed 11/24/2021 to Tue 11/30/2021 **UPDATED by CE 10/01/2021**  
0201 Continuous 0100

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

DUNWODIE\_345KV\_3

Wed 11/24/2021 to Tue 11/30/2021 **UPDATED by CE 10/01/2021**  
0201 Continuous 0100

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

SCH-IMO\_NY\_NIAG\_NRTH\_BUS\_W/BB

Mon 11/29/2021 to Tue 11/30/2021 **UPDATED by NYPA 08/20/2021**  
0500 Continuous 1900

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1650 MW 1450 MW**  
Impacts Total Transfer Capability 650 MW 550 MW  
TTC with All Lines In Service 2300 MW 2000 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

FWD

Mon 11/29/2021 to Fri 12/17/2021 UPDATED by PJM 09/15/2021

(Import)

0600 Continuous 1600

Work scheduled by: PJM

SCH - PJM\_NEPTUNE

0 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

## NEWBRDGE-DUFFYAVE\_345\_501

FWD

Mon 11/29/2021 to Fri 12/17/2021 UPDATED by PJM 09/15/2021

(Import)

0600 Continuous 1600

Work scheduled by: PJM

SCH - PJM\_NEPTUNE

0 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

## NEWBRDGE\_345\_138\_BK\_2

FWD

Mon 11/29/2021 to Fri 12/17/2021 UPDATED by PJM 09/15/2021

(Import)

0600 Continuous 1600

Work scheduled by: PJM

SCH - PJM\_NEPTUNE

375 MW

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

## SCH-NE-NYISO\_LIMIT\_800

FWD

Mon 11/29/2021 to Wed 12/01/2021 UPDATED by ISONE 12/02/2021

(Import)

0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

1000 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 1400 MW

## SCH-NE-NYISO\_LIMIT\_900

FWD

Mon 11/29/2021 to Wed 12/01/2021

(Import)

0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

1100 MW

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 1400 MW

## SCH-NYISO-NE\_LIMIT\_800

REV

Mon 11/29/2021 to Wed 12/01/2021

(Export)

0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

1000 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 1800 MW

## BERKSHIR-ALPS\_\_\_\_\_345\_393

FWD

REV

Mon 11/29/2021 to Thu 12/02/2021 UPDATED by ISONE 11/24/2021

(Import) (Export)

0700 Continuous 1200

Work scheduled by: ISONE

ARR: 78

SCH - NE - NY

1100 MW

1700 MW

Impacts Total Transfer Capability 300 MW 100 MW

TTC with All Lines In Service 1400 MW 1800 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BERKSHIR-ALPS_____345_393</b>						FWD	REV
Mon 11/29/2021	to	Thu 12/02/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>11/24/2021</u>	(Import)	(Export)
0700	Continuous	1200				<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: ISONE					ARR: 78	Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
<b>BERKSHIR-ALPS_____345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>						FWD	REV
Mon 11/29/2021	to	Thu 12/02/2021				(Import)	(Export)
0700		1200				<b>1100 MW</b>	<b>1700 MW</b>
Work scheduled by:					ARR: 78	Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	1400 MW
<b>BERKSHIR-NORTHFLD_345_312</b>						FWD	
Mon 11/29/2021	to	Thu 12/02/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>11/24/2021</u>	(Import)	
0700	Continuous	1200				<b>1300 MW</b>	
Work scheduled by: ISONE						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	1400 MW
<b>BERKSHIR-NORTHFLD_345_312</b>						FWD	REV
Mon 11/29/2021	to	Thu 12/02/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>11/24/2021</u>	(Import)	(Export)
0700	Continuous	1200				<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: ISONE						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
<b>SCH-NPX_1385-NYISO_LIMIT_75</b>						FWD	
Mon 11/29/2021	to	Thu 12/02/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>11/24/2021</u>	(Import)	
0700	Continuous	1200				<b>75 MW</b>	
Work scheduled by: ISONE						Impacts Total Transfer Capability	125 MW
						TTC with All Lines In Service	200 MW
<b>LEEDS_____345KV_R395</b>						FWD	
Mon 11/29/2021	to	Fri 12/03/2021				(Import)	
0700	Continuous	1700				<b>3800 MW</b>	
Work scheduled by: NGrid						Impacts Total Transfer Capability	4015 MW
						TTC with All Lines In Service	7815 MW
<b>HURLYAVE-ROSETON____345_303</b>						FWD	
Mon 11/29/2021	to	Fri 12/17/2021	<u>UPDATED</u>	<u>by CH</u>	<u>10/07/2021</u>	(Import)	
0800	Continuous	1600				<b>4100 MW</b>	
Work scheduled by: CHGE						Impacts Total Transfer Capability	3715 MW
						TTC with All Lines In Service	7815 MW



# NYISO TRANSFER LIMITATIONS

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NE-NYISO_LIMIT_600</b>					FWD	
Mon 11/29/2021	to	Thu 12/02/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>12/02/2021</u>	(Import)
2300	Daily	0659				
Work scheduled by: ISONE					SCH - NE - NY	<b>800 MW</b>
					Impacts Total Transfer Capability	600 MW
					TTC with All Lines In Service	1400 MW
<b>SCH-NE-NYISO_LIMIT_700</b>					FWD	
Mon 11/29/2021	to	Thu 12/02/2021				(Import)
2300	Daily	0659				
Work scheduled by: ISONE					SCH - NE - NY	<b>900 MW</b>
					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_200</b>					REV	
Mon 11/29/2021	to	Thu 12/02/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>12/02/2021</u>	(Export)
2300	Daily	0659				
Work scheduled by: ISONE					SCH - NE - NY	<b>400 MW</b>
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	1800 MW
<b>SCH-NYISO-NE_LIMIT_600</b>					REV	
Mon 11/29/2021	to	Thu 12/02/2021				(Export)
2300	Daily	0659				
Work scheduled by: ISONE					SCH - NE - NY	<b>800 MW</b>
					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	1800 MW
<b>NIAGARA_-PACKARD__230_61</b>					FWD	REV
Tue 11/30/2021	to	Fri 12/10/2021				(Import) (Export)
0821	Continuous	1900				
Work scheduled by: NGrid					SCH - OH - NY	<b>1200 MW 1850 MW</b>
					Impacts Total Transfer Capability	1100 MW 150 MW
					TTC with All Lines In Service	2300 MW 2000 MW
<b>W49TH_ST_345KV_7</b>					FWD	
Wed 12/01/2021	to	Sun 12/12/2021	<u>EXTENDED</u>	<u>by CONED</u>	<u>12/02/2021</u>	(Import)
0001	Continuous	0200				
Work scheduled by: ConEd					SCH - PJM_HTP	<b>300 MW</b>
					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
<b>SCH-NYISO-NE_LIMIT_600</b>					REV	
Wed 12/01/2021	to	Wed 12/01/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>12/02/2021</u>	(Export)
0700	Daily	2259				
Work scheduled by: ISONE					SCH - NE - NY	<b>800 MW</b>
					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	1800 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MAl

Wed 12/01/2021 to Tue 05/31/2022  
0700 Continuous 1300

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## SCH-NE-NYISO\_LIMIT\_800

Thu 12/02/2021 to Thu 12/02/2021 UPDATED by ISONE 12/02/2021  
0700 Daily 1200

Work scheduled by: ISONE

FWD  
(Import)  
SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

## SCH-NE-NYISO\_LIMIT\_900

Thu 12/02/2021 to Thu 12/02/2021  
0700 Daily 1200

Work scheduled by: ISONE

FWD  
(Import)  
SCH - NE - NY **1100 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 1400 MW

## SCH-NYISO-NE\_LIMIT\_600

Thu 12/02/2021 to Thu 12/02/2021 UPDATED by ISONE 12/02/2021  
0700 Daily 1200

Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY **800 MW**  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 1800 MW

## SCH-NYISO-NE\_LIMIT\_800

Thu 12/02/2021 to Thu 12/02/2021  
0700 Daily 1200

Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 1800 MW

## LINDN\_CG-LNDVFT\_\_\_345\_V-3022

Thu 12/02/2021 to Thu 12/02/2021  
0800 Continuous 1000

Work scheduled by: PJM

FWD REV  
(Import) (Export)  
SCH - PJM\_VFT **0 MW 0 MW**  
Impacts Total Transfer Capability 315 MW 315 MW  
TTC with All Lines In Service 315 MW 315 MW

## SCH-NE-NYISO\_LIMIT\_700

Thu 12/02/2021 to Sat 12/04/2021 UPDATED by ISONE 12/02/2021  
2300 Daily 0659

Work scheduled by: ISONE

FWD  
(Import)  
SCH - NE - NY **900 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1400 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NYISO-NE\_LIMIT\_1100

Thu 12/02/2021 to Sat 12/04/2021 **UPDATED** **by ISONE** **12/02/2021**  
 2300 Daily 0659  
 Work scheduled by: ISONE

REV  
 (Export)  
**1300 MW**  
 SCH - NE - NY  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 1800 MW

### MARCY -EDIC 345 UE1-7

Fri 12/03/2021 to Fri 12/03/2021  
 0700 Daily(No Weekends) 1000  
 Work scheduled by: NGrid **ARR: 19&16**

FWD  
 (Import)  
**5250 MW**  
 OSWEGO EXPORT  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

### FRASER 345 FRASER SVC

Sat 12/04/2021 to Sun 12/05/2021  
 0800 Continuous 1600  
 Work scheduled by: NYSEG

FWD  
 (Import)  
**2935 MW**  
 CENTRAL EAST - VC  
 Impacts Total Transfer Capability 40 MW  
 TTC with All Lines In Service 2975 MW

### LINDN\_CG-LNDVFT 345 V-3022

Sun 12/05/2021 to Sun 12/05/2021  
 1300 Continuous 1500  
 Work scheduled by: PJM

FWD REV  
 (Import) (Export)  
**0 MW 0 MW**  
 SCH - PJM\_VFT  
 Impacts Total Transfer Capability 315 MW 315 MW  
 TTC with All Lines In Service 315 MW 315 MW

### MARCY 345KV\_CSC

Mon 12/06/2021 to Fri 12/17/2021  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
**2925 MW**  
 CENTRAL EAST - VC  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 2975 MW

### MILLWOOD\_345KV\_18

Tue 12/07/2021 to Thu 12/16/2021 **UPDATED** **by CE** **11/26/2021**  
 0201 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
**4350 MW**  
 UPNY CONED  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

### SPRNBK 345KV\_RNS4

Tue 12/07/2021 to Tue 12/07/2021 **EXTENDED** **by CONED** **12/02/2021**  
 0300 Continuous 0330  
 Work scheduled by: ConEd

FWD  
 (Import)  
**3200 MW**  
 SPR/DUN-SOUTH  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SPRNBRK\_-W49TH\_ST\_345\_M52

FWD

Tue 12/07/2021 to Fri 12/10/2021 EXTENDED by CONED 12/02/2021  
0300 Continuous 0200

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

## KINTIGH\_-STA\_255\_345\_SH1-39

FWD

Wed 12/08/2021 to Sun 01/16/2022 UPDATED by NYSEG 12/01/2021  
2000 Continuous 1900

(Import)

Work scheduled by: NYSEG

DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## SPRNBRK\_345KV\_RNS4

FWD

Fri 12/10/2021 to Fri 12/10/2021 EXTENDED by CONED 12/02/2021  
0130 Continuous 0200

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

## CHAT\_DC\_GC1

FWD

Sun 12/12/2021 to Sun 12/12/2021  
0001 Continuous 0200

(Import)

Work scheduled by: HQ

MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC1

REV

Sun 12/12/2021 to Sun 12/12/2021  
0001 Continuous 0200

(Export)

Work scheduled by: HQ

SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

## CHAT\_DC\_GC1 & CHAT\_DC\_GC2

FWD

Sun 12/12/2021 to Sun 12/12/2021  
0001 0200

(Import)

Work scheduled by:

MOSES SOUTH **2550 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC1 & CHAT\_DC\_GC2

FWD

REV

Sun 12/12/2021 to Sun 12/12/2021  
0001 0200

(Import) (Export)

Work scheduled by:

SCH - HQ - NY **1370 MW 0 MW**  
Impacts Total Transfer Capability 130 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CHAT\_DC\_GC2

FWD

Sun 12/12/2021 to Sun 12/12/2021

(Import)

0001 Continuous 0200

MOSES SOUTH

2850 MW

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

## CHAT\_DC\_GC2

REV

Sun 12/12/2021 to Sun 12/12/2021

(Export)

0001 Continuous 0200

SCH - HQ - NY

500 MW

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

Work scheduled by: HQ

## SCH-HQ-NYISO\_LIMIT\_1150

FWD

Sun 12/12/2021 to Sun 12/12/2021

(Import)

0001 Continuous 0200

SCH - HQ - NY

1150 MW

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: HQ

## LADENTWN-BUCHAN\_S\_345\_Y88

FWD

Thu 12/16/2021 to Sun 12/19/2021

(Import)

0201 Continuous 0200

UPDATEDby CE11/26/2021

UPNY CONED

7560 MW

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## BECK\_\_\_\_-NIAGARA\_230\_PA27

FWD

Thu 12/16/2021 to Sat 12/18/2021

(Import)

0530 Continuous 1700

UPDATEDby NYPA12/02/2021

SCH - OH - NY

2100 MW

Impacts Total Transfer Capability 200 MW

TTC with All Lines In Service 2300 MW

Work scheduled by: NYPA

## FRASER\_\_-GILBOA\_\_345\_GF5-35

FWD

Mon 12/20/2021 to Tue 12/21/2021

(Import)

0800 Continuous 1700

CENTRAL EAST - VC

2650 MW

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

## EDIC\_\_\_\_-FRASER\_\_345\_EF24-40

FWD

Wed 12/22/2021 to Thu 12/23/2021

(Import)

0830 Continuous 1500

UPDATEDby NYSEG11/05/2021

CENTRAL EAST - VC

2500 MW

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**LEEDS\_\_\_-PLSNTVLY\_345\_92**

FWD

Mon 12/27/2021 to Mon 12/27/2021

(Import)

0830 Daily(No Weekends) 1500

Work scheduled by: NGrid

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

**FRASER\_\_\_345\_FRASER SVC**

FWD

Tue 01/04/2022 to Mon 02/28/2022

(Import)

0700 Continuous 1730

Work scheduled by: NYPA

UPDATEDby NYPA05/25/2021

CENTRAL EAST - VC

**2935 MW**

Impacts Total Transfer Capability 40 MW

TTC with All Lines In Service 2975 MW

**HOPATCON-RAMAPO\_\_\_500\_5018**

FWD

REV

Thu 01/06/2022 to Mon 01/10/2022

(Import) (Export)

0200 Continuous 1900

Work scheduled by: PJM

SCH - PJ - NY

**1450 MW 1200 MW**

Impacts Total Transfer Capability 1400 MW 1000 MW

TTC with All Lines In Service 2850 MW 2200 MW

**HOPATCON-RAMAPO\_\_\_500\_5018**

FWD

Thu 01/06/2022 to Mon 01/10/2022

(Import)

0200 Continuous 1900

Work scheduled by: PJM

UPNY CONED

**7480 MW**

Impacts Total Transfer Capability 335 MW

TTC with All Lines In Service 7815 MW

**RAMAPO\_\_\_345\_345\_PAR3500**

FWD

REV

Thu 01/06/2022 to Mon 01/10/2022

(Import) (Export)

0200 Continuous 1900

Work scheduled by: PJM

SCH - PJ - NY

**2350 MW 1250 MW**

Impacts Total Transfer Capability 500 MW 950 MW

TTC with All Lines In Service 2850 MW 2200 MW

**RAMAPO\_\_\_345\_345\_PAR4500**

FWD

REV

Thu 01/06/2022 to Mon 01/10/2022

(Import) (Export)

0200 Continuous 1900

Work scheduled by: PJM

SCH - PJ - NY

**2350 MW 1250 MW**

Impacts Total Transfer Capability 500 MW 950 MW

TTC with All Lines In Service 2850 MW 2200 MW

**RAMAPO\_\_\_500\_345\_BK 1500**

FWD

REV

Thu 01/06/2022 to Mon 01/10/2022

(Import) (Export)

0200 Continuous 1900

Work scheduled by: PJM

SCH - PJ - NY

**1450 MW 1200 MW**

Impacts Total Transfer Capability 1400 MW 1000 MW

TTC with All Lines In Service 2850 MW 2200 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### RAMAPO\_\_\_500\_345\_BK 1500

Thu 01/06/2022 to Mon 01/10/2022  
0200 Continuous 1900

Work scheduled by: PJM

FWD  
(Import)  
UPNY CONED **7480 MW**  
Impacts Total Transfer Capability 335 MW  
TTC with All Lines In Service 7815 MW

### BEAR SWP-EASTOVER\_230\_E205W

Mon 01/10/2022 to Thu 01/13/2022  
0700 Continuous 1700

Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### HURLYAVE-ROSETON\_\_\_345\_303

Tue 01/11/2022 to Sat 01/22/2022  
0600 Continuous 1600

Work scheduled by: CHGE

UPDATED by CHGE 11/30/2021

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 3715 MW  
TTC with All Lines In Service 7815 MW

### MOTTHAVN-RAINEY\_\_\_345\_Q11

Wed 01/12/2022 to Sat 01/15/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### DYSINGER-KINTIGH\_\_\_345\_38

Mon 01/17/2022 to Thu 01/20/2022  
0500 Continuous 1900

Work scheduled by: NYSEG

FWD  
(Import)  
DYSINGER EAST **2500 MW**  
Impacts Total Transfer Capability 650 MW  
TTC with All Lines In Service 3150 MW

### NIAGARA\_-DYSINGER\_345\_ND1

Mon 01/17/2022 to Thu 01/20/2022  
0500 Continuous 1900

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2500 MW**  
Impacts Total Transfer Capability 650 MW  
TTC with All Lines In Service 3150 MW

### NIAGARA\_-PACKARD\_\_\_230\_61

Mon 01/17/2022 to Fri 01/21/2022  
0615 Continuous 1900

Work scheduled by: NGrid

FWD REV  
(Import) (Export)  
SCH - OH - NY **1200 MW 1850 MW**  
Impacts Total Transfer Capability 1100 MW 150 MW  
TTC with All Lines In Service 2300 MW 2000 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### S.RIPLEY-DUNKIRK\_\_230\_68

Tue 01/18/2022 to Fri 02/04/2022 UPDATED by NGRID 09/24/2021

0700 Continuous 1730

Work scheduled by: NGrid

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### NIAGARA -STA 255\_\_345\_NH2

Fri 01/21/2022 to Fri 03/04/2022 UPDATED by NYPA 08/20/2021

0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

### FIVEMILE-STOLLERD\_345\_29

Mon 01/24/2022 to Sun 01/30/2022

0500 Continuous 1900

Work scheduled by: PJM

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### PLSNTVLY-WOOD\_ST\_\_345\_F30

Sat 01/29/2022 to Sat 01/29/2022

0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

### PLSNTVLY\_345KV\_RNS5

Sat 01/29/2022 to Sat 01/29/2022

0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

### PLSNTVLY-WOOD\_ST\_\_345\_F30

Wed 02/02/2022 to Wed 02/02/2022

1930 Continuous 2000

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

### PLSNTVLY\_345KV\_RNS5

Wed 02/02/2022 to Wed 02/02/2022

1930 Continuous 2000

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW



# NYISO TRANSFER LIMITATIONS

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MARCY\_\_\_-N.SCTLND\_345\_18

Tue 02/08/2022 to Wed 02/09/2022  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **1470 MW**  
Impacts Total Transfer Capability 1505 MW  
TTC with All Lines In Service 2975 MW

## PLSNTVLY\_345KV\_RNS4

Sat 02/12/2022 to Sat 02/12/2022  
0600 Continuous 0630

Work scheduled by: NGrid

UPDATED by CONED 11/12/2021

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## ATHENS\_\_\_-PLSNTVLY\_345\_91

Sat 02/12/2022 to Wed 02/16/2022  
0600 Continuous 1900

Work scheduled by: NGrid

UPDATED by CONED 11/12/2021

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

Sun 02/13/2022 to Mon 02/14/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

## RAMAPO\_\_\_-BUCHAN\_N\_345\_Y94

Sun 02/13/2022 to Mon 02/14/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7580 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 7815 MW

## MILLWOOD\_345KV\_18

Mon 02/14/2022 to Tue 02/15/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

## PLSNTVLY\_345KV\_RNS4

Wed 02/16/2022 to Wed 02/16/2022  
1830 Continuous 1900

Work scheduled by: NGrid

UPDATED by CONED 11/12/2021

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

FWD

Thu 02/17/2022 to Sat 02/19/2022  
0001 2200

Work scheduled by:

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### LEEDS-PLSNTVLY\_345\_92

FWD

Thu 02/17/2022 to Fri 03/25/2022 UPDATED by NYISO 11/15/2021  
0001 Continuous 2200

Work scheduled by: ConEd

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLY\_345KV\_RNS5

FWD

Thu 02/17/2022 to Fri 03/25/2022 UPDATED by NYISO 11/15/2021  
0001 Continuous 2200

Work scheduled by: ConEd

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLY-WOOD\_ST\_345\_F30

FWD

Sun 02/20/2022 to Mon 02/21/2022  
0001 Continuous 2200

Work scheduled by: ConEd

UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

### EASTVIEW-SPRNBK\_345\_W64

FWD

Sun 02/20/2022 to Mon 02/21/2022  
2000 Continuous 2359

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

### MILLWOOD-EASTVIEW\_345\_W99

FWD

Sun 02/20/2022 to Mon 02/21/2022  
2000 Continuous 2359

Work scheduled by: ConEd

UPNY CONED **7550 MW**  
Impacts Total Transfer Capability 265 MW  
TTC with All Lines In Service 7815 MW

### SPRNBK\_345KV\_RNS5

FWD

Sun 02/20/2022 to Mon 02/21/2022  
2000 Continuous 2359

Work scheduled by: ConEd

(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## EASTVIEW-SPRNBK\_\_345\_W64

FWD

Tue 02/22/2022 to Tue 02/22/2022 UPDATED by CONED 08/31/2021

(Import)

0001 Continuous 0030

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

## SPRNBK\_\_345KV\_RNS5

FWD

Tue 02/22/2022 to Tue 02/22/2022 UPDATED by CONED 08/31/2021

(Import)

0001 Continuous 0030

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

## MILLWOOD-EASTVIEW\_345\_W99

FWD

Tue 02/22/2022 to Mon 03/21/2022 UPDATED by CONED 08/31/2021

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED **7550 MW**  
 Impacts Total Transfer Capability 265 MW  
 TTC with All Lines In Service 7815 MW

## MARCY\_\_-EDIC\_\_345\_UE1-7

FWD

Wed 02/23/2022 to Mon 02/28/2022

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19&amp;16

OSWEGO EXPORT **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

## FIVEMILE-STOLLERD\_345\_29

Tue 03/01/2022 to Tue 04/12/2022

0500 Continuous 1900

Work scheduled by: NYSEG

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

## PORTER\_\_-ROTTRDAM\_230\_31

FWD

Tue 03/01/2022 to Tue 12/31/2030

(Import)

0600 Continuous 2359

Work scheduled by: NGrid

CENTRAL EAST - VC **2805 MW**  
 Impacts Total Transfer Capability 170 MW  
 TTC with All Lines In Service 2975 MW

## N.SCTLND-LEEDS\_\_345\_93

FWD

Tue 03/01/2022 to Mon 03/28/2022 UPDATED by NGRID 11/15/2021

(Import)

0700 Continuous 1900

Work scheduled by: NGrid

CENTRAL EAST - VC **2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## EDIC\_\_\_\_-N.SCTLND\_345\_14

FWD

Tue 03/01/2022 to Tue 04/12/2022 UPDATED by NGRID 11/15/2021

(Import)

0700 Continuous 1900

CENTRAL EAST - VC

**1670 MW**

Impacts Total Transfer Capability 1305 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

## EDIC\_\_\_\_-N.SCTLND\_345\_14 & PORTER\_\_\_\_-ROTTRDAM\_230\_31

FWD

Tue 03/01/2022 to Tue 04/12/2022

(Import)

0700 1900

CENTRAL EAST - VC

**1500 MW**

Impacts Total Transfer Capability 1475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

## FRASANNX-COOPERS\_\_\_\_345\_UCC2-41

FWD

Tue 03/01/2022 to Wed 04/20/2022

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

ARR: 19

## MARCY\_\_\_\_-FRASANNX\_345\_UCC2-41

FWD

Tue 03/01/2022 to Wed 04/20/2022

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

ARR: 19

## N.SCTLND-ALPS\_\_\_\_345\_2

FWD

Tue 03/01/2022 to Fri 06/24/2022 UPDATED by NGRID 11/15/2021

(Import)

0700 Continuous 1900

SCH - NE - NY

**900 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: NGrid

## N.SCTLND-ALPS\_\_\_\_345\_2

FWD

REV

Tue 03/01/2022 to Fri 06/24/2022 UPDATED by NGRID 11/15/2021

(Import) (Export)

0700 Continuous 1900

SCH - NPX\_1385

**100 MW****100 MW**

Impacts Total Transfer Capability 100 MW

100 MW

100 MW

TTC with All Lines In Service 200 MW

200 MW

200 MW

Work scheduled by: NGrid

## GOETHALS\_345KV\_5

Sat 03/05/2022 to Mon 04/04/2022 UPDATED by CONED 03/26/2021

0001 Continuous 0200

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LINDEN\_\_-GOETHALS\_230\_A2253

Sat 03/05/2022 to Mon 04/04/2022 UPDATED by CONED 03/26/2021

0001 Continuous 0200

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## LINDEN\_\_-GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402

Sat 03/05/2022 to Mon 04/04/2022

0001 0200

Work scheduled by:

FWD REV  
(Import) (Export)

SCH - PJ - NY

**2550 MW 1900 MW**

Impacts Total Transfer Capability 300 MW 300 MW

TTC with All Lines In Service 2850 MW 2200 MW

## LINDEN\_\_-GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_\_-FARRAGUT\_345\_C3403

Sat 03/05/2022 to Mon 04/04/2022

0001 0200

Work scheduled by:

FWD REV  
(Import) (Export)

SCH - PJ - NY

**2550 MW 1900 MW**

Impacts Total Transfer Capability 300 MW 300 MW

TTC with All Lines In Service 2850 MW 2200 MW

## LINDEN\_\_-GOETHALS\_230\_A2253 & MARION\_\_-FARRAGUT\_345\_C3403

Sat 03/05/2022 to Mon 04/04/2022

0001 0200

Work scheduled by:

FWD REV  
(Import) (Export)

SCH - PJ - NY

**2550 MW 1900 MW**

Impacts Total Transfer Capability 300 MW 300 MW

TTC with All Lines In Service 2850 MW 2200 MW

## INDPDNCE-SCRIBA\_\_345\_25

Thu 03/10/2022 to Wed 03/16/2022

0800 Continuous 1800

Work scheduled by: NGrid

FWD  
(Import)

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

## NIAGARA\_-DYSINGER\_345\_ND1

Fri 03/11/2022 to Fri 03/11/2022

0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)

DYSINGER EAST

**2500 MW**

Impacts Total Transfer Capability 650 MW

TTC with All Lines In Service 3150 MW

## PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Thu 03/17/2022 to Sun 03/20/2022

0100 2200

Work scheduled by:

FWD  
(Import)

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PLSNTVLY-WOOD\_ST\_\_345\_F30

Mon 03/21/2022 to Wed 03/23/2022

0001 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

### EASTVIEW-SPRNBK\_\_345\_W64

Mon 03/21/2022 to Mon 03/21/2022

0130 Continuous 0200

Work scheduled by: ConEd

UPDATED

by CONED 08/31/2021

FWD

(Import)

UPNY CONED **4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

### SPRNBK\_\_345KV\_RNS5

Mon 03/21/2022 to Mon 03/21/2022

0130 Continuous 0200

Work scheduled by: ConEd

UPDATED

by CONED 08/31/2021

FWD

(Import)

SPR/DUN-SOUTH **3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

### NIAGARA\_-STA\_255\_\_345\_NH2

Fri 03/25/2022 to Fri 03/25/2022

0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

### PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Sat 03/26/2022 to Mon 03/28/2022

0001 2200

Work scheduled by:

FWD

(Import)

UPNY CONED **3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

### ATHENS\_-PLSNTVLY\_345\_91

Sat 03/26/2022 to Sun 05/01/2022

0001 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

### PLSNTVLY\_345KV\_RNS4

Sat 03/26/2022 to Sun 05/01/2022

0001 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 7815MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLY-WOOD\_ST\_\_345\_F31**

Tue 03/29/2022 to Wed 03/30/2022

0001 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

**LINDN\_CG-LNDVFT\_\_345\_V-3022**

Sun 04/03/2022 to Sat 04/09/2022

1400 Continuous 1400

Work scheduled by: PJM

FWD

(Import) (Export)

SCH - PJM\_VFT

**0 MW****0 MW**

Impacts Total Transfer Capability 315 MW 315 MW

TTC with All Lines In Service 315 MW 315 MW

**SPRNBK\_-TREMONT\_\_345\_X28**

Tue 04/05/2022 to Wed 04/06/2022

0201 Continuous 0300

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

**4200 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

Wed 04/06/2022 to Wed 04/06/2022

0301 Continuous 0330

Work scheduled by: ConEd

**UPDATED****by CONED 08/19/2021**

FWD

(Import)

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

**EASTVIEW-SPRNBK\_\_345\_W79**

Wed 04/06/2022 to Thu 04/07/2022

0301 Continuous 0300

Work scheduled by: ConEd

**UPDATED****by CONED 08/19/2021**

FWD

(Import)

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

Thu 04/07/2022 to Thu 04/07/2022

0230 Continuous 0300

Work scheduled by: ConEd

**UPDATED****by CONED 08/19/2021**

FWD

(Import)

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

**EASTVIEW-SPRNBK\_\_345\_W64**

Thu 04/07/2022 to Thu 04/07/2022

0301 Continuous 0330

Work scheduled by: ConEd

**UPDATED****by CONED 08/31/2021**

FWD

(Import)

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_\_345KV\_RNS5

FWD

Thu 04/07/2022 to Thu 04/07/2022 UPDATED by CONED 08/31/2021

(Import)

0301 Continuous 0330

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

### MILLWOOD-EASTVIEW\_345\_W99

FWD

Thu 04/07/2022 to Tue 04/26/2022 UPDATED by CONED 08/31/2021

(Import)

0301 Continuous 2200

Work scheduled by: ConEd

UPNY CONED **7550 MW**  
Impacts Total Transfer Capability 265 MW  
TTC with All Lines In Service 7815 MW

### PANNELL\_-CLAY\_\_\_\_345\_1

FWD

Mon 04/11/2022 to Fri 04/15/2022

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

### GOETHALS\_345KV\_5

Wed 04/13/2022 to Fri 05/13/2022

0001 Continuous 0259

Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### PORTER\_\_-ROTTRDAM\_230\_30

FWD

Wed 04/13/2022 to Tue 12/31/2030

(Import)

0600 Continuous 2359

Work scheduled by: NGrid

CENTRAL EAST - VC **2805 MW**  
Impacts Total Transfer Capability 170 MW  
TTC with All Lines In Service 2975 MW

### PANNELL\_-CLAY\_\_\_\_345\_2

FWD

Mon 04/18/2022 to Fri 04/22/2022

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

### EDIC\_\_\_\_-FRASER\_\_\_\_345\_EF24-40

FWD

Thu 04/21/2022 to Tue 06/14/2022

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW



**NYISO TRANSFER LIMITATIONS**

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_345KV\_CSC**

FWD

Fri 04/22/2022 to Sat 04/23/2022

(Import)

0700 Continuous 1730

Work scheduled by: NYPA

CENTRAL EAST - VC

**2925 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

FWD

Sat 04/23/2022 to Tue 04/26/2022

(Import)

0001 2200

Work scheduled by:

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

**ROCHESTR-PANNELL\_\_\_345\_RP1**

FWD

Mon 04/25/2022 to Fri 04/29/2022

(Import)

0500 Continuous 1700

Work scheduled by: NYPA

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 04/25/2022 to Fri 04/29/2022

0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**EASTVIEW-SPRNBK\_\_\_345\_W64**

FWD

Tue 04/26/2022 to Tue 04/26/2022

**UPDATED****by CONED 08/31/2021**

(Import)

2130 Continuous 2200

Work scheduled by: ConEd

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

**SPRNBK\_\_\_345KV\_RNS5**

FWD

Tue 04/26/2022 to Tue 04/26/2022

**UPDATED****by CONED 08/31/2021**

(Import)

2130 Continuous 2200

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

**PLSNTVLY-WOOD\_ST\_\_\_345\_F31**

FWD

Wed 04/27/2022 to Fri 04/29/2022

(Import)

0001 Continuous 2200

Work scheduled by: ConEd

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_\_345\_230\_AT4

REV

Fri 04/29/2022 to Fri 04/29/2022  
0500 Continuous 1700

Work scheduled by: NYPA

SCH - OH - NY

(Export)

Impacts Total Transfer Capability

1750 MW

TTC with All Lines In Service

250 MW

2000 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

FWD

Mon 05/02/2022 to Mon 05/02/2022  
0001 Continuous 0030

Work scheduled by: ConEd

(Import)

UPNY CONED

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

## EASTVIEW-SPRNBK\_\_345\_W79

FWD

Mon 05/02/2022 to Thu 05/05/2022  
0001 Continuous 0200

Work scheduled by: ConEd

(Import)

UPNY CONED

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

## ROCHESTR-PANNELL\_\_345\_RP2

FWD

Mon 05/02/2022 to Fri 05/06/2022  
0500 Continuous 1700

Work scheduled by: NYPA

(Import)

DYSINGER EAST

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

FWD

Thu 05/05/2022 to Thu 05/05/2022  
0130 Continuous 0200

Work scheduled by: ConEd

(Import)

UPNY CONED

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

## SPRNBK\_-TREMONT\_\_345\_X28

FWD

Fri 05/06/2022 to Mon 05/09/2022  
0201 Continuous 1800

Work scheduled by: ConEd

(Import)

SPR/DUN-SOUTH

4200 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

## FRASER\_\_345\_FRASER SVC

FWD

Mon 05/09/2022 to Fri 05/13/2022  
0800 Continuous 1700

Work scheduled by: NYSEG

(Import)

CENTRAL EAST - VC

2935 MW

Impacts Total Transfer Capability 40 MW

TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SHOR_NPX-SHOREHAM_138_CSC</b>					FWD	REV
Mon 05/16/2022	to	Fri 05/27/2022			(Import)	(Export)
0600	Continuous	1800			SCH - NPX_CSC	<b>0 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	330 MW
					TTC with All Lines In Service	330 MW
<b>HOMRC_NY-MAINS_NY_345_47</b>						
Fri 05/20/2022	to	Fri 05/27/2022	<u>UPDATED</u>	<u>by PJM</u>	<u>11/19/2020</u>	SCH - PJ - NY
0800	Continuous	1600				Impacts Total Transfer Capability
Work scheduled by: PJM					TTC with All Lines In Service	
<b>HOMR_NYW-PIERC_NY_345_48</b>						
Fri 05/20/2022	to	Fri 05/27/2022	<u>UPDATED</u>	<u>by PJM</u>	<u>11/19/2020</u>	SCH - PJ - NY
0800	Continuous	1600				Impacts Total Transfer Capability
Work scheduled by: PJM					TTC with All Lines In Service	
<b>MARCY_-EDIC_345_UE1-7</b>					FWD	
Sat 05/21/2022	to	Sat 05/21/2022			(Import)	
0700	Continuous	1730			OSWEGO EXPORT	<b>5250 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	5250 MW
<b>PORTER_-ROTTRDAM_230_30 &amp; VOLNEY_-MARCY_345_19</b>					FWD	
Sat 05/21/2022	to	Sat 05/21/2022			(Import)	
0700		1730			CENTRAL EAST - VC	<b>2655 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	320 MW
					TTC with All Lines In Service	2975 MW
<b>PORTER_-ROTTRDAM_230_31 &amp; VOLNEY_-MARCY_345_19</b>					FWD	
Sat 05/21/2022	to	Sat 05/21/2022			(Import)	
0700		1730			CENTRAL EAST - VC	<b>2655 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	320 MW
					TTC with All Lines In Service	2975 MW
<b>VOLNEY_-MARCY_345_19</b>					FWD	
Sat 05/21/2022	to	Sat 05/21/2022			(Import)	
0700	Continuous	1730			CENTRAL EAST - VC	<b>2825 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	2975 MW

ARR: 19&16

ARR: 19

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**VOLNEY\_\_-MARCY\_\_345\_19**

Sat 05/21/2022 to Sat 05/21/2022  
0700 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
OSWEGO EXPORT **4900 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 5250 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Wed 06/01/2022 to Tue 11/29/2022  
0700 Continuous 1800

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**NIAGARA\_-DYSINGER\_345\_ND1**

Mon 06/13/2022 to Fri 06/17/2022  
0500 Continuous 2100

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2500 MW**  
Impacts Total Transfer Capability 650 MW  
TTC with All Lines In Service 3150 MW

**NIAGARA\_-PACKARD\_\_230\_62**

Sat 06/18/2022 to Sat 06/18/2022  
0500 Continuous 1700

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>700 MW</b>	<b>1550 MW</b>
Impacts Total Transfer Capability	1250 MW	150 MW
TTC with All Lines In Service	1950 MW	1700 MW

**NIAGARA\_\_345\_230\_AT4**

Tue 06/28/2022 to Wed 06/29/2022  
0500 Continuous 1700

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1900 MW</b>	<b>1400 MW</b>
Impacts Total Transfer Capability	50 MW	300 MW
TTC with All Lines In Service	1950 MW	1700 MW

**BECK\_\_-NIAGARA\_\_230\_PA27**

Tue 07/05/2022 to Sat 07/09/2022  
0500 Continuous 2100

Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**NIAGARA\_-DYSINGER\_345\_ND1**

Mon 07/11/2022 to Fri 07/15/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2500 MW**  
Impacts Total Transfer Capability 650 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## ROCHESTR-PANNELL\_\_345\_RP1

FWD

Mon 07/25/2022 to Fri 07/29/2022

(Import)

0500 Continuous 2100

DYSINGER EAST **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## NIAGARA\_-STA\_255\_\_345\_NH2

FWD

Mon 08/01/2022 to Fri 08/05/2022

(Import)

0500 Continuous 1700

DYSINGER EAST **1400 MW**

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## MARCY\_-EDIC\_\_\_\_345\_UE1-7

FWD

Sat 08/06/2022 to Sat 08/06/2022

(Import)

0500 Continuous 1830

OSWEGO EXPORT **5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

ARR: 19&amp;16

## PORTER\_-ROTTDAM\_230\_30 & VOLNEY\_-MARCY\_\_\_\_345\_19

FWD

Sat 08/06/2022 to Sat 08/06/2022

(Import)

0500 1830

CENTRAL EAST - VC **2655 MW**

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

## PORTER\_-ROTTDAM\_230\_31 & VOLNEY\_-MARCY\_\_\_\_345\_19

FWD

Sat 08/06/2022 to Sat 08/06/2022

(Import)

0500 1830

CENTRAL EAST - VC **2655 MW**

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

## VOLNEY\_-MARCY\_\_\_\_345\_19

FWD

Sat 08/06/2022 to Sat 08/06/2022

(Import)

0500 Continuous 1830

CENTRAL EAST - VC **2825 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

ARR: 19

## VOLNEY\_-MARCY\_\_\_\_345\_19

FWD

Sat 08/06/2022 to Sat 08/06/2022

(Import)

0500 Continuous 1830

OSWEGO EXPORT **4900 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

ARR: 19

# NYISO TRANSFER LIMITATIONS

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SAND\_BAR-PLATSBURG\_115\_PV20

Mon 08/22/2022 to Fri 08/26/2022

0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### ROSETON\_-ROCKTVRN\_345\_311

Mon 08/29/2022 to Fri 09/09/2022

0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED

**4400 MW**

Impacts Total Transfer Capability 3415 MW

TTC with All Lines In Service 7815 MW

### PANNELL\_-CLAY\_\_\_\_345\_1

Mon 09/12/2022 to Fri 09/16/2022

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

### FRASER\_-GILBOA\_\_\_\_345\_GF5-35

Mon 09/12/2022 to Sun 09/18/2022

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

### PANNELL\_-CLAY\_\_\_\_345\_2

Mon 09/19/2022 to Fri 09/23/2022

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

### NIAGARA\_-DYSINGER\_345\_ND1

Mon 09/26/2022 to Fri 09/30/2022

0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

**2500 MW**

Impacts Total Transfer Capability 650 MW

TTC with All Lines In Service 3150 MW

### SPRNBK\_-W49TH\_ST\_345\_M51

Sat 10/01/2022 to Mon 10/17/2022

0001 Continuous 0300

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

UPDATED by CONED 08/01/2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SPRNBRK\_\_345KV\_RNS5

FWD

Sat 10/01/2022 to Mon 10/17/2022 UPDATED by CONED 08/01/2020

(Import)

0001 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH

3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

## SHOR\_NPX-SHOREHAM\_138\_CSC

FWD

REV

Mon 10/03/2022 to Fri 10/21/2022

(Import) (Export)

0600 Continuous 1800

Work scheduled by: LI

SCH - NPX\_CSC

0 MW

0 MW

Impacts Total Transfer Capability 330 MW 330 MW

TTC with All Lines In Service 330 MW 330 MW

## NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

FWD

Mon 10/10/2022 to Fri 10/14/2022

(Import)

0600 Continuous 1600

Work scheduled by: LI

SCH - PJM\_NEPTUNE

0 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

## NEWBRDGE-DUFFYAVE\_345\_501

FWD

Mon 10/10/2022 to Fri 10/14/2022

(Import)

0600 Continuous 1600

Work scheduled by: LI

SCH - PJM\_NEPTUNE

0 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

## NEWBRDGE\_345\_138\_BK\_1

FWD

Mon 10/10/2022 to Fri 10/14/2022

(Import)

0600 Continuous 1600

Work scheduled by: LI

SCH - PJM\_NEPTUNE

375 MW

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

## NEWBRDGE\_345\_138\_BK\_2

FWD

Mon 10/10/2022 to Fri 10/14/2022

(Import)

0600 Continuous 1600

Work scheduled by: LI

SCH - PJM\_NEPTUNE

375 MW

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

## GILBOA\_-N.SCTLND\_345\_GNS-1

FWD

Mon 10/31/2022 to Mon 11/28/2022

(Import)

0500 Continuous 1900

Work scheduled by: NGrid

CENTRAL EAST - VC

2520 MW

Impacts Total Transfer Capability 455 MW

TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,December 02, 2021 to Saturday ,June 03, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>LEEDS____345KV_R94301</b>			FWD	
Mon 10/31/2022	to	Mon 11/28/2022	(Import)	
0500	Continuous	1900	UPNY CONED	<b>3800 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	4015 MW
			TTC with All Lines In Service	7815 MW
<b>MARCY____-N.SCTLND_345_18</b>			FWD	
Mon 10/31/2022	to	Mon 11/28/2022	(Import)	
0500	Continuous	1900	CENTRAL EAST - VC	<b>1470 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	1505 MW
<b>ARR: 19</b>			TTC with All Lines In Service	2975 MW
<b>N.SCTLND-LEEDS____345_94</b>			FWD	
Mon 10/31/2022	to	Mon 11/28/2022	(Import)	
0500	Continuous	1900	CENTRAL EAST - VC	<b>2650 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	325 MW
			TTC with All Lines In Service	2975 MW
<b>PORTER____-ROTTRDAM_230_30 &amp; MARCY____-N.SCTLND_345_18</b>			FWD	
Mon 10/31/2022	to	Mon 11/28/2022	(Import)	
0500		1900	CENTRAL EAST - VC	<b>1300 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	1675 MW
			TTC with All Lines In Service	2975 MW
<b>PORTER____-ROTTRDAM_230_31 &amp; MARCY____-N.SCTLND_345_18</b>			FWD	
Mon 10/31/2022	to	Mon 11/28/2022	(Import)	
0500		1900	CENTRAL EAST - VC	<b>1300 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	1675 MW
			TTC with All Lines In Service	2975 MW
<b>MOSES____-ADIRNDCK_230_MAI</b>			FWD	
Wed 11/30/2022	to	Wed 03/01/2023	(Import)	
0700	Continuous	1100	MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>			FWD	REV
Mon 05/01/2023	to	Fri 05/05/2023	(Import)	(Export)
0600	Continuous	1800	SCH - NPX_CSC	<b>0 MW 0 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability	330 MW 330 MW
			TTC with All Lines In Service	330 MW 330 MW