

# NYISO TRANSFER LIMITATIONS

Saturday ,February 12, 2022 to Monday ,August 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Sun 07/31/2022 EXT FORCE by CONED 01/04/2022

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Sun 07/31/2022

0001 2359

Work scheduled by:

FWD REV  
(Import) (Export)

SCH - PJ - NY

Impacts Total Transfer Capability 300 MW 300 MW

TTC with All Lines In Service 2850 MW 2200 MW

## MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Sun 07/31/2022 EXT FORCE by CONED 01/04/2022

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## STLAWRNC-MOSES\_230\_L33P

Mon 04/30/2018 to Tue 05/31/2022 EXT FORCE by IESO 11/04/2021

0456 Continuous 1600

Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## NEWBRDGE\_345\_138\_BK\_1

Wed 09/02/2020 to Mon 08/01/2022 EXT FORCE by LI 12/10/2021

1807 Continuous 2359

Work scheduled by: LI

FWD  
(Import)

SCH - PJM\_NEPTUNE

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

## NIAGARA\_-KINTIGH\_345\_NS1-38

Mon 10/18/2021 to Sat 12/31/2022 UPDATED by NYPA 01/08/2022

0500 Continuous 2359

Work scheduled by: NYPA

FWD  
(Import)

DYSINGER EAST

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

## SCH-IMO-NYISO\_LIMIT\_1750

Mon 11/01/2021 to Sat 04/30/2022 UPDATED by IESO 05/03/2019

0001 Continuous 2359

Work scheduled by: IESO

FWD  
(Import)

SCH - OH - NY

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 2300 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 12, 2022 to Monday ,August 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NYISO-IMO_LIMIT_1600</b>						REV
Mon 11/01/2021	to	Sat 04/30/2022	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Export)
0001	Continuous	2359				<b>1900 MW</b>
Work scheduled by: IESO						100 MW
						2000 MW
<b>KINTIGH_STA_255_345_SH1-39</b>						FWD
Wed 12/08/2021	to	Sat 12/31/2022	<u>UPDATED</u>	<u>by RGE</u>	<u>01/08/2022</u>	(Import)
2000	Continuous	2359				<b>1700 MW</b>
Work scheduled by: NYSEG						1450 MW
						3150 MW
<b>DYSINGER-KINTIGH_345_39 &amp; DYSINGER-STA_255_345_DH1</b>						FWD
Fri 01/28/2022	to	Fri 02/11/2022				(Import)
0600		1259				<b>2650 MW</b>
Work scheduled by:						500 MW
						3150 MW
<b>DYSINGER-STA_255_345_DH1</b>						FWD
Fri 01/28/2022	to	Fri 02/11/2022	<u>UPDATED</u>	<u>by NT</u>	<u>02/09/2022</u>	(Import)
0600	Continuous	1259				<b>2550 MW</b>
Work scheduled by: NT						600 MW
						3150 MW
<b>MOSES_ADIRNDCK_230_MAI</b>						FWD
Fri 01/28/2022	to	Mon 02/28/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>01/21/2022</u>	(Import)
0700	Continuous	1600				<b>2300 MW</b>
Work scheduled by: NYPA						850 MW
						3150 MW
<b>SCH-IMO-NYISO_LIMIT_1550</b>						FWD
Fri 01/28/2022	to	Mon 02/28/2022	<u>UPDATED</u>	<u>by IESO</u>	<u>01/19/2022</u>	(Import)
0700	Continuous	1600				<b>1850 MW</b>
Work scheduled by: IESO						450 MW
						2300 MW
<b>SCH-NYISO-IMO_LIMIT_1400</b>						REV
Fri 01/28/2022	to	Mon 02/28/2022	<u>UPDATED</u>	<u>by IESO</u>	<u>01/19/2022</u>	(Export)
0700	Continuous	1600				<b>1700 MW</b>
Work scheduled by: IESO						300 MW
						2000 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 12, 2022 to Monday ,August 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## FIVEMILE-STOLLERD\_345\_29

Mon 01/31/2022 to Sun 02/13/2022 UPDATED by NYSEG 01/20/2022

0500 Continuous 1900

Work scheduled by: NYSEG

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## SCH-IMO-NYISO\_LIMIT\_500

Fri 02/04/2022 to Thu 02/10/2022

0600 Continuous 2000

Work scheduled by: NGrid

FWD

(Import)

SCH - OH - NY

**800 MW**

Impacts Total Transfer Capability 1500 MW

TTC with All Lines In Service 2300 MW

## NIAGARA\_-PACKARD\_230\_61

Fri 02/04/2022 to Tue 02/08/2022 UPDATED by NGRID 02/09/2022

0615 Continuous 2000

Work scheduled by: NGrid

FWD REV

(Import) (Export)

SCH - OH - NY

**1400 MW 1850 MW**

Impacts Total Transfer Capability 900 MW 150 MW

TTC with All Lines In Service 2300 MW 2000 MW

## HOPATCON-RAMAPO\_\_\_500\_5018

Mon 02/07/2022 to Mon 02/07/2022

0301 Continuous 1800

Work scheduled by: ConEd

FWD REV

(Import) (Export)

SCH - PJ - NY

**1650 MW 1200 MW**

Impacts Total Transfer Capability 1200 MW 1000 MW

TTC with All Lines In Service 2850 MW 2200 MW

## HOPATCON-RAMAPO\_\_\_500\_5018

Mon 02/07/2022 to Mon 02/07/2022

0301 Continuous 1800

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

**7480 MW**

Impacts Total Transfer Capability 335 MW

TTC with All Lines In Service 7815 MW

## RAMAPO\_\_\_345\_345\_PAR3500

Mon 02/07/2022 to Mon 02/07/2022

0301 Continuous 1800

Work scheduled by: ConEd

FWD REV

(Import) (Export)

SCH - PJ - NY

**2500 MW 1250 MW**

Impacts Total Transfer Capability 350 MW 950 MW

TTC with All Lines In Service 2850 MW 2200 MW

## RAMAPO\_\_\_345\_345\_PAR4500

Mon 02/07/2022 to Mon 02/07/2022

0301 Continuous 1800

Work scheduled by: ConEd

FWD REV

(Import) (Export)

SCH - PJ - NY

**2500 MW 1250 MW**

Impacts Total Transfer Capability 350 MW 950 MW

TTC with All Lines In Service 2850 MW 2200 MW

**NYISO TRANSFER LIMITATIONS**

Saturday ,February 12, 2022 to Monday ,August 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>RAMAPO___500_345_BK 1500</b>				FWD	REV
Mon 02/07/2022 to Mon 02/07/2022				(Import)	(Export)
0301	Continuous	1800		SCH - PJ - NY	<b>1650 MW 1200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1200 MW 1000 MW
				TTC with All Lines In Service	2850 MW 2200 MW
<b>RAMAPO___500_345_BK 1500</b>				FWD	
Mon 02/07/2022 to Mon 02/07/2022				(Import)	
0301	Continuous	1800		UPNY CONED	<b>7480 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	335 MW
				TTC with All Lines In Service	7815 MW
<b>SCH-HQ_CEDARS-NYISO_LIMIT_20</b>				FWD	
Mon 02/07/2022 to Mon 02/07/2022				(Import)	
0700	Daily(No Weekends)	1700	<b>UPDATED by NYISO 02/04/2022</b>	SCH - HQ_CEDARS	<b>20 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	259 MW
				TTC with All Lines In Service	279 MW
<b>MOSES___-ADIRNDCK_230_MAl &amp; MOSES___-MASSENA_230_MMS1 &amp; MOSES___-MASSENA_230_MMS2</b>				FWD	
Tue 02/08/2022 to Tue 02/08/2022				(Import)	
0700		1200		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	189 MW
				TTC with All Lines In Service	279 MW
<b>MOSES___-MASSENA_230_MMS1 &amp; MOSES___-MASSENA_230_MMS2</b>				FWD	REV
Tue 02/08/2022 to Tue 02/08/2022				(Import)	(Export)
0700		1200		SCH - HQ - NY	<b>850 MW 0 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	650 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
<b>MOSES___-MASSENA_230_MMS1 &amp; MOSES___-MASSENA_230_MMS2</b>				FWD	
Tue 02/08/2022 to Tue 02/08/2022				(Import)	
0700		1200		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	189 MW
				TTC with All Lines In Service	279 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 12, 2022 to Monday ,August 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES___230_L33P & MOSES___-ADIRNDCK_230_MA1 & MOSES___-					FWD	
MASSENA___230_MMS1 & MOSES___-MASSENA___230_MMS2					(Import)	
Tue 02/08/2022	to	Tue 02/08/2022			SCH - HQ_CEDARS	90 MW
0700		1200			Impacts Total Transfer Capability	189 MW
Work scheduled by:					TTC with All Lines In Service	279 MW
STLAWRNC-MOSES___230_L33P & MOSES___-MASSENA___230_MMS1 & MOSES___-					FWD	
MASSENA___230_MMS2					(Import)	
Tue 02/08/2022	to	Tue 02/08/2022			SCH - HQ_CEDARS	90 MW
0700		1200			Impacts Total Transfer Capability	189 MW
Work scheduled by:					TTC with All Lines In Service	279 MW
CHATGUAY-MASSENA___765_7040					FWD	
Wed 02/09/2022	to	Fri 02/11/2022	<u>EXTENDED</u>	<u>by NYPA</u> <u>02/10/2022</u>	(Import)	
0700	Continuous	1530			MOSES SOUTH	1550 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA___765_7040					FWD	REV
Wed 02/09/2022	to	Fri 02/11/2022	<u>EXTENDED</u>	<u>by NYPA</u> <u>02/10/2022</u>	(Import)	(Export)
0700	Continuous	1530			SCH - HQ - NY	0 MW 0 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1500 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW
BECK___-NIAGARA___345_PA301					FWD	REV
Wed 02/09/2022	to	Fri 06/17/2022	<u>UPDATED</u>	<u>by IESO</u> <u>02/07/2022</u>	(Import)	(Export)
0700	Continuous	1700			SCH - OH - NY	1100 MW 950 MW
Work scheduled by: IESO					Impacts Total Transfer Capability	1200 MW 1050 MW
					TTC with All Lines In Service	2300 MW 2000 MW
MARCY___-N.SCTLND_345_18					FWD	
Wed 02/09/2022	to	Thu 02/10/2022	<u>UPDATED</u>	<u>by NYPA</u> <u>02/09/2022</u>	(Import)	
0730	Continuous	1730			CENTRAL EAST - VC	1470 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1505 MW
					TTC with All Lines In Service	2975 MW

ARR: 19

**NYISO TRANSFER LIMITATIONS**

Saturday ,February 12, 2022 to Monday ,August 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CHAT\_DC\_GC1**

FWD

Wed 02/09/2022 to Fri 02/11/2022 UPDATED by HQ 02/11/2022

(Import)

0741 Continuous 1530

MOSES SOUTH

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

**CHAT\_DC\_GC1**

REV

Wed 02/09/2022 to Fri 02/11/2022 UPDATED by HQ 02/11/2022

(Export)

0741 Continuous 1530

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

Work scheduled by: HQ

**CHAT\_DC\_GC1 & CHAT\_DC\_GC2**

FWD

Wed 02/09/2022 to Fri 02/11/2022

(Import)

0743 1530

MOSES SOUTH

**2550 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 3150 MW

Work scheduled by:

**CHAT\_DC\_GC1 & CHAT\_DC\_GC2**

FWD

REV

Wed 02/09/2022 to Fri 02/11/2022

(Import) (Export)

0743 1530

SCH - HQ - NY

**1370 MW 0 MW**

Impacts Total Transfer Capability 130 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by:

**CHAT\_DC\_GC2**

FWD

Wed 02/09/2022 to Fri 02/11/2022 UPDATED by HQ 02/11/2022

(Import)

0743 Continuous 1530

MOSES SOUTH

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

**CHAT\_DC\_GC2**

REV

Wed 02/09/2022 to Fri 02/11/2022 UPDATED by HQ 02/11/2022

(Export)

0743 Continuous 1530

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

Work scheduled by: HQ

**SCH-IMO-NYISO\_LIMIT\_200**

FWD

Wed 02/09/2022 to Tue 03/01/2022 UPDATED by NYISO 02/07/2022

(Import)

2300 Daily 0500

SCH - OH - NY

**500 MW**

Impacts Total Transfer Capability 1800 MW

TTC with All Lines In Service 2300 MW

Work scheduled by: NYISO

# NYISO TRANSFER LIMITATIONS

Saturday ,February 12, 2022 to Monday ,August 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-IMO-NYISO\_LIMIT\_500

Thu 02/10/2022 to Tue 03/01/2022 UPDATED by IESO 02/07/2022  
 2001 Continuous 2359  
 Work scheduled by: IESO

FWD  
 (Import)  
 SCH - OH - NY **800 MW**  
 Impacts Total Transfer Capability 1500 MW  
 TTC with All Lines In Service 2300 MW

## CHAT\_DC\_GC1

Fri 02/11/2022 to Fri 02/11/2022 CANCELLED by HQ 02/09/2022  
 0500 Continuous 2000  
 Work scheduled by: HQ

FWD  
 (Import)  
 MOSES SOUTH **2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC1

Fri 02/11/2022 to Fri 02/11/2022 CANCELLED by HQ 02/09/2022  
 0500 Continuous 2000  
 Work scheduled by: HQ

REV  
 (Export)  
 SCH - HQ - NY **500 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 1000 MW

## NIAGARA\_-DYSINGER\_345\_ND1

Fri 02/11/2022 to Sat 02/19/2022 UPDATED by NT 02/09/2022  
 1300 Continuous 1700  
 Work scheduled by: NT

FWD  
 (Import)  
 DYSINGER EAST **2650 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 3150 MW

## PLSNTVLY\_345KV\_RNS4

Sat 02/12/2022 to Sat 02/12/2022 UPDATED by CONED 11/12/2021  
 0600 Continuous 0630  
 Work scheduled by: NGrid

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 4015 MW  
 TTC with All Lines In Service 7815 MW

## ATHENS\_-PLSNTVLY\_345\_91

Sat 02/12/2022 to Sat 02/12/2022 UPDATED by CONED 11/12/2021  
 0600 Continuous 1630  
 Work scheduled by: NGrid

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 4015 MW  
 TTC with All Lines In Service 7815 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

Sun 02/13/2022 to Mon 02/14/2022 UPDATED by CONED 02/12/2022  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 12, 2022 to Monday ,August 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## RAMAPO\_\_-BUCHAN\_N\_345\_Y94

FWD

Sun 02/13/2022 to Mon 02/14/2022

UPDATEDby CONED 02/12/2022

(Import)

0001 Continuous 0200

UPNY CONED

**7580 MW**

Impacts Total Transfer Capability 235 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## MILLWOOD\_345KV\_18

FWD

Mon 02/14/2022 to Tue 02/15/2022

(Import)

0001 Continuous 0200

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## EASTVIEW-SPRNBK\_\_345\_W78

FWD

Tue 02/15/2022 to Wed 02/16/2022

CANCELLEDby ConEd 02/08/2022

(Import)

0201 Continuous 0200

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## MILLWOOD-EASTVIEW\_345\_W85

FWD

Tue 02/15/2022 to Wed 02/16/2022

CANCELLEDby ConEd 02/08/2022

(Import)

0201 Continuous 0200

UPNY CONED

**7550 MW**

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## SPRNBK\_\_345KV\_RNS3

FWD

Tue 02/15/2022 to Wed 02/16/2022

CANCELLEDby ConEd 02/08/2022

(Import)

0201 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## W49TH\_ST\_345KV\_5

FWD

Wed 02/16/2022 to Wed 02/16/2022

UPDATEDby CONED 02/07/2022

(Import)

0201 Continuous 0230

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

## W49TH\_ST\_345KV\_7

FWD

Wed 02/16/2022 to Wed 02/16/2022

UPDATEDby CONED 02/07/2022

(Import)

0201 Continuous 0230

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd



**NYISO TRANSFER LIMITATIONS**

Saturday ,February 12, 2022 to Monday ,August 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

FWD

Thu 02/17/2022 to Sat 02/19/2022  
0001 2200

(Import)

Work scheduled by:

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**LEEDS - PLSNTVLY\_345\_92**

FWD

Thu 02/17/2022 to Fri 03/25/2022  
0001 Continuous 2200

(Import)

Work scheduled by: ConEd

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**PLSNTVLY\_345KV\_RNS5**

FWD

Thu 02/17/2022 to Fri 03/25/2022  
0001 Continuous 2200

(Import)

Work scheduled by: ConEd

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**SCH-NYISO-IMO\_NIAGARA\_CB\_3108**

REV

Thu 02/17/2022 to Thu 02/17/2022  
0500 Continuous 1600

(Export)

Work scheduled by: NYPA

SCH - OH - NY **1900 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 2000 MW

**PLSNTVLY-WOOD\_ST\_345\_F30**

FWD

Sun 02/20/2022 to Mon 02/21/2022  
0001 Continuous 2200

(Import)

Work scheduled by: ConEd

UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

**EASTVIEW-SPRNBK\_345\_W64**

FWD

Sun 02/20/2022 to Mon 02/21/2022  
2000 Continuous 2359

(Import)

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

**MILLWOOD-EASTVIEW\_345\_W99**

FWD

Sun 02/20/2022 to Mon 02/21/2022  
2000 Continuous 2359

(Import)

Work scheduled by: ConEd

UPNY CONED **7550 MW**  
Impacts Total Transfer Capability 265 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 12, 2022 to Monday ,August 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SPRNBRK\_\_345KV\_RNS5

FWD

Sun 02/20/2022 to Mon 02/21/2022

(Import)

2000 Continuous 2359

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## NIAGARA\_-STA\_255\_\_345\_NH2

FWD

Mon 02/21/2022 to Sat 04/02/2022

(Import)

0500 Continuous 1900

UPDATEDby NYPA02/04/2022

DYSINGER EAST

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## NIAGARA\_-STA\_255\_\_345\_NH2 &amp; KINTIGH\_-STA\_255\_\_345\_SH1-39

FWD

Mon 02/21/2022 to Sat 04/02/2022

(Import)

0500 1900

DYSINGER EAST

**1250 MW**

Impacts Total Transfer Capability 1900 MW

TTC with All Lines In Service 3150 MW

Work scheduled by:

## W49TH\_ST\_345KV\_5

FWD

Mon 02/21/2022 to Mon 02/21/2022

(Import)

2130 Continuous 2200

UPDATEDby CONED02/07/2022

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

## W49TH\_ST\_345KV\_7

FWD

Mon 02/21/2022 to Mon 02/21/2022

(Import)

2130 Continuous 2200

UPDATEDby CONED02/07/2022

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

## HOPATCON-RAMAPO\_\_500\_5018

FWD

REV

Tue 02/22/2022 to Tue 02/22/2022

(Import) (Export)

0001 Continuous 1800

SCH - PJ - NY

**1650 MW 1200 MW**

Impacts Total Transfer Capability 1200 MW 1000 MW

TTC with All Lines In Service 2850 MW 2200 MW

Work scheduled by: ConEd

## HOPATCON-RAMAPO\_\_500\_5018

FWD

Tue 02/22/2022 to Tue 02/22/2022

(Import)

0001 Continuous 1800

UPNY CONED

**7480 MW**

Impacts Total Transfer Capability 335 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Saturday ,February 12, 2022 to Monday ,August 14, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO___345_345_PAR3500					FWD	REV
Tue 02/22/2022 to Tue 02/22/2022					(Import)	(Export)
0001	Continuous	1800			SCH - PJ - NY	<b>2500 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	350 MW
					TTC with All Lines In Service	2850 MW
RAMAPO___345_345_PAR4500					FWD	REV
Tue 02/22/2022 to Tue 02/22/2022					(Import)	(Export)
0001	Continuous	1800			SCH - PJ - NY	<b>2500 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	350 MW
					TTC with All Lines In Service	2850 MW
RAMAPO___500_345_BK 1500					FWD	REV
Tue 02/22/2022 to Tue 02/22/2022					(Import)	(Export)
0001	Continuous	1800			SCH - PJ - NY	<b>1650 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1200 MW
					TTC with All Lines In Service	2850 MW
RAMAPO___500_345_BK 1500					FWD	
Tue 02/22/2022 to Tue 02/22/2022					(Import)	
0001	Continuous	1800			UPNY CONED	<b>7480 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	335 MW
					TTC with All Lines In Service	7815 MW
EASTVIEW-SPRNBK___345_W64					FWD	
Tue 02/22/2022 to Wed 02/23/2022					(Import)	
0001	Continuous	0030	<u>UPDATED</u>	<u>by CONED 02/11/2022</u>	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	3465 MW
					TTC with All Lines In Service	7815 MW
SPRNBK___345KV_RNS5					FWD	
Tue 02/22/2022 to Wed 02/23/2022					(Import)	
0001	Continuous	0030	<u>UPDATED</u>	<u>by CONED 02/11/2022</u>	SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
MILLWOOD-EASTVIEW_345_W99					FWD	
Tue 02/22/2022 to Mon 03/21/2022					(Import)	
0001	Continuous	0200	<u>UPDATED</u>	<u>by CONED 02/11/2022</u>	UPNY CONED	<b>7550 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	265 MW
					TTC with All Lines In Service	7815 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 12, 2022 to Monday ,August 14, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_-EDIC\_\_\_\_345\_UE1-7

Wed 02/23/2022 to Mon 02/28/2022  
0600 Continuous 1730

UPDATED by NYPA 01/17/2022

Work scheduled by: NYPA

ARR: 19&16

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

### W49TH\_ST-E13THSTA\_345\_M54

Sun 02/27/2022 to Wed 03/02/2022  
0201 Continuous 2230

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### MOSES\_\_-ADIRNDCK\_230\_MAL

Mon 02/28/2022 to Tue 05/31/2022  
1601 Continuous 1300

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### FIVEMILE-STOLLERD\_345\_29

Tue 03/01/2022 to Tue 04/12/2022  
0500 Continuous 1900

Work scheduled by: NYSEG

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### PORTER\_\_-ROTTRDAM\_230\_31

Tue 03/01/2022 to Tue 12/31/2030  
0600 Continuous 2359

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2805 MW**  
Impacts Total Transfer Capability 170 MW  
TTC with All Lines In Service 2975 MW

### SCH-NYISO-NE\_LIMIT\_800

Tue 03/01/2022 to Sat 03/26/2022  
0700 Continuous 2259

Work scheduled by: NGrid

UPDATED by ISONE 02/03/2022

REV  
(Export)  
SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 1800 MW

### BERKSHIR-ALPS\_\_\_\_345\_393

Tue 03/01/2022 to Sun 03/27/2022  
0700 Continuous 1800

Work scheduled by: NGrid

UPDATED by ISONE 02/03/2022

ARR: 78

FWD REV  
(Import) (Export)  
SCH - NE - NY **1100 MW 1700 MW**  
Impacts Total Transfer Capability 300 MW 100 MW  
TTC with All Lines In Service 1400 MW 1800 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 12, 2022 to Monday ,August 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BERKSHIR-ALPS_____345_393</b>						FWD	REV
Tue 03/01/2022	to	Sun 03/27/2022	<u>UPDATED</u>	<u>by ISONE</u>	<u>02/03/2022</u>	(Import)	(Export)
0700	Continuous	1800				<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: NGrid					ARR: 78		
					SCH - NPX_1385	100 MW	100 MW
					Impacts Total Transfer Capability	100 MW	100 MW
					TTC with All Lines In Service	200 MW	200 MW
<b>BERKSHIR-ALPS_____345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>						FWD	REV
Tue 03/01/2022	to	Sun 03/27/2022				(Import)	(Export)
0700		1800				<b>1100 MW</b>	<b>1700 MW</b>
Work scheduled by:					ARR: 78		
					SCH - NE - NY	300 MW	100 MW
					Impacts Total Transfer Capability	1400 MW	1800 MW
					TTC with All Lines In Service		
<b>BERKSHIR-NORTHFLD_345_312</b>						FWD	
Tue 03/01/2022	to	Sun 03/27/2022	<u>UPDATED</u>	<u>by ISONE</u>	<u>02/03/2022</u>	(Import)	
0700	Continuous	1800				<b>1300 MW</b>	
Work scheduled by: NGrid							
					SCH - NE - NY	100 MW	
					Impacts Total Transfer Capability	1400 MW	
					TTC with All Lines In Service		
<b>BERKSHIR-NORTHFLD_345_312</b>						FWD	REV
Tue 03/01/2022	to	Sun 03/27/2022	<u>UPDATED</u>	<u>by ISONE</u>	<u>02/03/2022</u>	(Import)	(Export)
0700	Continuous	1800				<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: NGrid							
					SCH - NPX_1385	100 MW	100 MW
					Impacts Total Transfer Capability	200 MW	200 MW
					TTC with All Lines In Service		
<b>N.SCTLND-LEEDS_____345_93</b>						FWD	
Tue 03/01/2022	to	Mon 03/28/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>11/15/2021</u>	(Import)	
0700	Continuous	1900				<b>2650 MW</b>	
Work scheduled by: NGrid							
					CENTRAL EAST - VC	325 MW	
					Impacts Total Transfer Capability	2975 MW	
					TTC with All Lines In Service		
<b>EDIC_____ -N.SCTLND_345_14</b>						FWD	
Tue 03/01/2022	to	Tue 04/12/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>11/15/2021</u>	(Import)	
0700	Continuous	1900				<b>1670 MW</b>	
Work scheduled by: NGrid							
					CENTRAL EAST - VC	1305 MW	
					Impacts Total Transfer Capability	2975 MW	
					TTC with All Lines In Service		
<b>EDIC_____ -N.SCTLND_345_14 &amp; PORTER____-ROTTRDAM_230_31</b>						FWD	
Tue 03/01/2022	to	Tue 04/12/2022				(Import)	
0700		1900				<b>1500 MW</b>	
Work scheduled by:							
					CENTRAL EAST - VC	1475 MW	
					Impacts Total Transfer Capability	2975 MW	
					TTC with All Lines In Service		

# NYISO TRANSFER LIMITATIONS

Saturday ,February 12, 2022 to Monday ,August 14, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### FRASANNX-COOPERS\_\_345\_UCC2-41

Tue 03/01/2022 to Wed 04/20/2022  
0700 Continuous 1530

UPDATED

by NYPA

02/02/2022

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

### MARCY\_\_-FRASANNX\_345\_UCC2-41

Tue 03/01/2022 to Wed 04/20/2022  
0700 Continuous 1530

UPDATED

by NYPA

02/02/2022

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

### N.SCTLND-ALPS\_\_\_\_345\_2

Tue 03/01/2022 to Fri 06/24/2022  
0700 Continuous 1900

UPDATED

by NGRID

11/15/2021

Work scheduled by: NGrid

FWD  
(Import)  
SCH - NE - NY **900 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1400 MW

### N.SCTLND-ALPS\_\_\_\_345\_2

Tue 03/01/2022 to Fri 06/24/2022  
0700 Continuous 1900

UPDATED

by NGRID

11/15/2021

Work scheduled by: NGrid

FWD	REV
(Import)	(Export)
SCH - NPX_1385 <b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability 100 MW	100 MW
TTC with All Lines In Service 200 MW	200 MW

### SCH-NYISO-NE\_LIMIT\_600

Tue 03/01/2022 to Sun 03/27/2022  
2300 Continuous 0659

UPDATED

by ISONE

02/03/2022

Work scheduled by: NGrid

	REV
	(Export)
SCH - NE - NY <b>800 MW</b>	
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	1800 MW

### W49TH\_ST\_345KV\_5

Fri 03/04/2022 to Fri 03/04/2022  
0001 Continuous 0031

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

### SPRNBK\_\_345KV\_RNS4

Fri 03/04/2022 to Sat 03/05/2022  
0001 Continuous 1800

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**SPRNBRK\_-W49TH\_ST\_345\_M52**

Fri 03/04/2022 to Sat 03/19/2022  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

---

**W49TH\_ST\_345KV\_5**

Mon 03/07/2022 to Sat 03/19/2022  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

---

**SPRNBRK\_\_345KV\_RNS4**

Thu 03/10/2022 to Tue 03/15/2022  
0001 Continuous 1800  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

---

**INDPDNCE-SCRIBA\_\_345\_25**

Thu 03/10/2022 to Wed 03/16/2022  
0800 Continuous 1800  
Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

---

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Thu 03/17/2022 to Sun 03/20/2022  
0100 2200  
Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

---

**GOETHALS\_345KV\_5**

Sat 03/19/2022 to Wed 04/20/2022  
0001 Continuous 0300  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

---

**PLSNTVLY-WOOD\_ST\_\_345\_F30**

Mon 03/21/2022 to Wed 03/23/2022  
0001 Continuous 2200  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

**NYISO TRANSFER LIMITATIONS**

Saturday ,February 12, 2022 to Monday ,August 14, 2023

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 7815MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EGRDNCTY\_345\_138\_AT1**

FWD

Mon 03/21/2022 to Sat 03/26/2022

(Import)

0001 Continuous 0300

CONED - LIPA

**1250 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: ConEd

**EGRDNCTY\_345\_138\_AT2**

FWD

Mon 03/21/2022 to Sat 03/26/2022

(Import)

0001 Continuous 0300

CONED - LIPA

**1250 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: ConEd

**SPRNBK -EGRDNCTR\_345\_Y49**

FWD

Mon 03/21/2022 to Sat 03/26/2022

(Import)

0001 Continuous 0300

CONED - LIPA

**775 MW**

Impacts Total Transfer Capability 725 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: ConEd

**EASTVIEW-SPRNBK\_345\_W64**

FWD

Mon 03/21/2022 to Mon 03/21/2022

**UPDATED****by CONED 02/11/2022**

(Import)

0130 Continuous 0200

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**SPRNBK\_345KV\_RNS5**

FWD

Mon 03/21/2022 to Mon 03/21/2022

**UPDATED****by CONED 02/11/2022**

(Import)

0130 Continuous 0200

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

FWD

Sat 03/26/2022 to Mon 03/28/2022

(Import)

0001 2200

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by:

**ATHENS -PLSNTVLY\_345\_91**

FWD

Sat 03/26/2022 to Sun 05/01/2022

**UPDATED****by CE 01/03/2022**

(Import)

0001 Continuous 2200

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd



# NYISO TRANSFER LIMITATIONS

Saturday ,February 12, 2022 to Monday ,August 14, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PLSNTVLY\_345KV\_RNS4

FWD

Sat 03/26/2022 to Sun 05/01/2022  
0001 Continuous 2200

UPDATED

by CE

01/03/2022

Work scheduled by: ConEd

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

(Import)

### SCH-NYISO-NE\_LIMIT\_800

REV

Sun 03/27/2022 to Sun 03/27/2022  
0700 Continuous 1800

UPDATED

by ISONE

02/03/2022

Work scheduled by: NGrid

SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 1800 MW

(Export)

### PLSNTVLY-WOOD\_ST\_345\_F31

FWD

Tue 03/29/2022 to Wed 03/30/2022  
0001 Continuous 2200

Work scheduled by: ConEd

UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

(Import)

### DUNWODIE\_345KV\_6

FWD

Fri 04/01/2022 to Sat 04/02/2022  
0001 Continuous 0300

UPDATED

by CE

01/25/2022

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

(Import)

### DUNWODIE\_345KV\_8

FWD

Fri 04/01/2022 to Sat 04/02/2022  
0001 Continuous 0300

UPDATED

by CE

01/25/2022

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

(Import)

### PLSNTVLE-DUNWODIE\_345\_W90

FWD

Fri 04/01/2022 to Tue 04/05/2022  
0001 Continuous 2200

UPDATED

by CE

01/25/2022

Work scheduled by: ConEd

UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

(Import)

### WOOD\_ST\_-PLSNTVLE\_345\_Y87

FWD

Fri 04/01/2022 to Tue 04/05/2022  
0001 Continuous 2200

UPDATED

by CE

01/25/2022

Work scheduled by: ConEd

UPNY CONED **7260 MW**  
Impacts Total Transfer Capability 555 MW  
TTC with All Lines In Service 7815 MW

(Import)

# NYISO TRANSFER LIMITATIONS

Saturday ,February 12, 2022 to Monday ,August 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDN_CG-LNDVFT___345_V-3022			FWD	REV
Sun 04/03/2022	to	Sat 04/09/2022	(Import)	(Export)
1400	Continuous	1400	SCH - PJM_VFT	0 MW 0 MW
Work scheduled by: PJM			Impacts Total Transfer Capability	315 MW 315 MW
			TTC with All Lines In Service	315 MW 315 MW
N.SCTLND-ALPS___345_2 & NRTH1385-NOR HBR___138_601			FWD	REV
Mon 04/04/2022	to	Mon 04/18/2022	(Import)	(Export)
0001		2359	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
N.SCTLND-ALPS___345_2 & NRTH1385-NOR HBR___138_602			FWD	REV
Mon 04/04/2022	to	Mon 04/18/2022	(Import)	(Export)
0001		2359	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
N.SCTLND-ALPS___345_2 & NRTH1385-NOR HBR___138_603			FWD	REV
Mon 04/04/2022	to	Mon 04/18/2022	(Import)	(Export)
0001		2359	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR___138_601			FWD	REV
Mon 04/04/2022	to	Mon 04/18/2022	(Import)	(Export)
0001	Continuous	2359	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR___138_601 & NRTH1385-NOR HBR___138_602			FWD	REV
Mon 04/04/2022	to	Mon 04/18/2022	(Import)	(Export)
0001		2359	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR___138_601 & NRTH1385-NOR HBR___138_603			FWD	REV
Mon 04/04/2022	to	Mon 04/18/2022	(Import)	(Export)
0001		2359	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 12, 2022 to Monday ,August 14, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_602					FWD	REV
Mon 04/04/2022	to	Mon 04/18/2022			(Import)	(Export)
0001	Continuous	2359			SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603					FWD	REV
Mon 04/04/2022	to	Mon 04/18/2022			(Import)	(Export)
0001		2359			SCH - NPX_1385	0 MW 0 MW
Work scheduled by:					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_603					FWD	REV
Mon 04/04/2022	to	Mon 04/18/2022			(Import)	(Export)
0001	Continuous	2359			SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NRTHPORT_138_NNC					FWD	REV
Mon 04/04/2022	to	Mon 04/18/2022			(Import)	(Export)
0001	Continuous	2359			SCH - NPX_1385	0 MW 0 MW
Work scheduled by: LI					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW
SPRNBK_-TREMONT__345_X28					FWD	
Tue 04/05/2022	to	Wed 04/06/2022	<u>UPDATED</u>	<u>by CE</u> <u>01/12/2022</u>	(Import)	
0201	Continuous	0300			SPR/DUN-SOUTH	4200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_6					FWD	
Tue 04/05/2022	to	Tue 04/05/2022	<u>UPDATED</u>	<u>by CE</u> <u>01/25/2022</u>	(Import)	
2130	Continuous	2200			SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8					FWD	
Tue 04/05/2022	to	Tue 04/05/2022	<u>UPDATED</u>	<u>by CE</u> <u>01/25/2022</u>	(Import)	
2130	Continuous	2200			SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW

**NYISO TRANSFER LIMITATIONS**

Saturday ,February 12, 2022 to Monday ,August 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BUCHAN\_N-EASTVIEW\_345\_W93**

FWD

Wed 04/06/2022 to Wed 04/06/2022 UPDATED by CONED 08/19/2021

(Import)

0301 Continuous 0330

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**EASTVIEW-SPRNBK\_\_345\_W79**

FWD

Wed 04/06/2022 to Thu 04/07/2022 UPDATED by CONED 08/19/2021

(Import)

0301 Continuous 0300

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**BUCHAN\_N-EASTVIEW\_345\_W93**

FWD

Thu 04/07/2022 to Thu 04/07/2022 UPDATED by CONED 08/19/2021

(Import)

0230 Continuous 0300

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**EASTVIEW-SPRNBK\_\_345\_W64**

FWD

Thu 04/07/2022 to Thu 04/07/2022 UPDATED by CONED 02/11/2022

(Import)

0301 Continuous 0330

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**SPRNBK\_\_345KV\_RNS5**

FWD

Thu 04/07/2022 to Thu 04/07/2022 UPDATED by CONED 02/11/2022

(Import)

0301 Continuous 0330

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**MILLWOOD-EASTVIEW\_345\_W99**

FWD

Thu 04/07/2022 to Tue 04/26/2022 UPDATED by CONED 02/11/2022

(Import)

0301 Continuous 2200

UPNY CONED

**7550 MW**

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**MOTTHAVN-RAINEY\_\_345\_Q12**

FWD

Mon 04/11/2022 to Thu 04/28/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Saturday ,February 12, 2022 to Monday ,August 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## FROST\_BR-SOUTHNGT\_345\_329 & NRTH1385-NOR HBR\_\_138\_601

Mon 04/11/2022 to Tue 04/12/2022  
0600 1800

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

## FROST\_BR-SOUTHNGT\_345\_329 & NRTH1385-NOR HBR\_\_138\_602

Mon 04/11/2022 to Tue 04/12/2022  
0600 1800

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

## FROST\_BR-SOUTHNGT\_345\_329 & NRTH1385-NOR HBR\_\_138\_603

Mon 04/11/2022 to Tue 04/12/2022  
0600 1800

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

## SCH-NYISO-NE\_LIMIT\_1100

Mon 04/11/2022 to Tue 04/12/2022  
0600 Continuous 1800

Work scheduled by: ISONE

		REV
		(Export)
SCH - NE - NY		1300 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1800 MW

## PANNELL\_-CLAY\_\_\_\_345\_1

Mon 04/11/2022 to Fri 04/15/2022  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
WEST CENTRAL	1300 MW
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	2250 MW

## PORTER\_-ROTTRDAM\_230\_30

Wed 04/13/2022 to Tue 12/31/2030  
0600 Continuous 2359

Work scheduled by: NGrid

	FWD
	(Import)
CENTRAL EAST - VC	2805 MW
Impacts Total Transfer Capability	170 MW
TTC with All Lines In Service	2975 MW

## PORTER\_-ROTTRDAM\_230\_30 & PORTER\_-ROTTRDAM\_230\_31

Wed 04/13/2022 to Tue 12/31/2030  
0600 2359

Work scheduled by:

	FWD
	(Import)
CENTRAL EAST - VC	2635 MW
Impacts Total Transfer Capability	340 MW
TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 12, 2022 to Monday ,August 14, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PANNELL\_-CLAY\_\_\_\_\_345\_2

Mon 04/18/2022 to Fri 04/22/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

### SCH-NE-NYISO\_LIMIT\_700

Tue 04/19/2022 to Fri 04/22/2022  
0601 Continuous 0759

Work scheduled by: ISONE

FWD  
(Import)  
SCH - NE - NY **900 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1400 MW

### EDIC\_\_\_\_\_FRASER\_\_\_\_\_345\_EF24-40

Thu 04/21/2022 to Tue 06/14/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

### DUNWODIE\_345KV\_4

Fri 04/22/2022 to Fri 04/22/2022  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### DUNWODIE\_345KV\_6

Fri 04/22/2022 to Fri 04/22/2022  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### DUNWODIE-SHORE\_RD\_345\_Y50

Fri 04/22/2022 to Sun 04/24/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
CONED - LIPA **800 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1500 MW

### SHORE\_RD\_345\_138\_BK\_1

Fri 04/22/2022 to Sun 04/24/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
CONED - LIPA **1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 12, 2022 to Monday ,August 14, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SHORE\_RD\_345\_138\_BK 2

Fri 04/22/2022 to Sun 04/24/2022

0001 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

CONED - LIPA

**1350 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1500 MW

### MARCY\_345KV\_CSC

Fri 04/22/2022 to Sat 04/23/2022

0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC

**2925 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

### SCH-NE-NYISO\_LIMIT\_700

Fri 04/22/2022 to Sun 04/24/2022

1601 Continuous 1800

Work scheduled by: ISONE

FWD

(Import)

SCH - NE - NY

**900 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1400 MW

### PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Sat 04/23/2022 to Tue 04/26/2022

0001 2200

Work scheduled by:

FWD

(Import)

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

### DUNWODIE\_345KV\_4

Sun 04/24/2022 to Sun 04/24/2022

2130 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

### DUNWODIE\_345KV\_6

Sun 04/24/2022 to Sun 04/24/2022

2130 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

### ROCHESTR-PANNELL\_345\_RP1

Mon 04/25/2022 to Fri 04/29/2022

0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 12, 2022 to Monday ,August 14, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SAND\_BAR-PLATSBURG\_115\_PV20

Mon 04/25/2022 to Fri 04/29/2022 UPDATED by ISONE 01/28/2022  
0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### SCH-NYISO-NE\_LIMIT\_1500

Mon 04/25/2022 to Fri 04/29/2022 UPDATED by ISONE 01/28/2022  
0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
REV  
(Export)  
**1700 MW**  
100 MW  
1800 MW

### EASTVIEW-SPRNBK\_345\_W64

Tue 04/26/2022 to Tue 04/26/2022 UPDATED by CONED 02/11/2022  
2130 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
**4350 MW**  
3465 MW  
7815 MW

### SPRNBK\_345KV\_RNS5

Tue 04/26/2022 to Tue 04/26/2022 UPDATED by CONED 02/11/2022  
2130 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
**3200 MW**  
1400 MW  
4600 MW

### PLSNTVLY-WOOD\_ST\_345\_F31

Wed 04/27/2022 to Fri 04/29/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
**4000 MW**  
3815 MW  
7815 MW

### NIAGARA\_345\_230\_AT4

Fri 04/29/2022 to Fri 04/29/2022  
0500 Continuous 1700

Work scheduled by: NYPA

REV  
(Export)  
SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
**1750 MW**  
250 MW  
2000 MW

### BUCHAN\_N-EASTVIEW\_345\_W93

Mon 05/02/2022 to Mon 05/02/2022  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
**4350 MW**  
3465 MW  
7815 MW



**NYISO TRANSFER LIMITATIONS**

Saturday ,February 12, 2022 to Monday ,August 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EASTVIEW-SPRNBK\_\_345\_W79**

FWD

Mon 05/02/2022 to Thu 05/05/2022

(Import)

0001 Continuous 0200

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**ROCHESTR-PANNELL\_\_345\_RP2**

FWD

Mon 05/02/2022 to Fri 05/06/2022

(Import)

0500 Continuous 1700

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**BUCHAN\_N-EASTVIEW\_345\_W93**

FWD

Thu 05/05/2022 to Thu 05/05/2022

(Import)

0130 Continuous 0200

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**SPRNBK\_-TREMONT\_\_345\_X28**

FWD

Fri 05/06/2022 to Mon 05/09/2022

(Import)

0201 Continuous 1800

**UPDATED by CONED 08/19/2021**

SPR/DUN-SOUTH

**4200 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**FRASER\_\_345\_FRASER SVC**

FWD

Mon 05/09/2022 to Fri 05/13/2022

(Import)

0800 Continuous 1700

CENTRAL EAST - VC

**2935 MW**

Impacts Total Transfer Capability 40 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

**PLSNTVLE-DUNWODIE\_345\_W89**

FWD

Fri 05/13/2022 to Fri 05/13/2022

(Import)

0200 Continuous 0230

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**EFISHKIL-WOOD\_ST\_\_345\_F38**

FWD

Fri 05/13/2022 to Fri 05/13/2022

(Import)

0200 Continuous 0430

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Saturday ,February 12, 2022 to Monday ,August 14, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### WOOD\_ST\_-PLSNTVLE\_345\_Y86

FWD

Fri 05/13/2022 to Fri 05/13/2022  
0200 Continuous 0430

(Import)

Work scheduled by: ConEd

UPNY CONED **7210 MW**  
Impacts Total Transfer Capability 605 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLE-DUNWODIE\_345\_W89

FWD

Fri 05/13/2022 to Fri 05/13/2022  
0400 Continuous 0430

(Import)

Work scheduled by: ConEd

UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

### EFISHKIL-WOOD\_ST\_345\_F38

FWD

Sun 05/15/2022 to Tue 05/17/2022  
2100 Continuous 0300

(Import)

Work scheduled by: ConEd

UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLE-DUNWODIE\_345\_W89

FWD

Sun 05/15/2022 to Tue 05/17/2022  
2100 Continuous 0300

(Import)

Work scheduled by: ConEd

UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

### WOOD\_ST\_-PLSNTVLE\_345\_Y86

FWD

Sun 05/15/2022 to Tue 05/17/2022  
2100 Continuous 0300

(Import)

Work scheduled by: ConEd

UPNY CONED **7210 MW**  
Impacts Total Transfer Capability 605 MW  
TTC with All Lines In Service 7815 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

FWD

REV

Mon 05/16/2022 to Sat 05/21/2022 UPDATED by LI 02/10/2022  
0600 Continuous 2000

(Import) (Export)

Work scheduled by: LI

SCH - NPX\_CSC **0 MW** **0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

### DUNWODIE-MOTTHAVN\_345\_71

FWD

Thu 05/19/2022 to Fri 05/20/2022  
0001 Continuous 0200

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,February 12, 2022 to Monday ,August 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_3**

FWD

Thu 05/19/2022 to Fri 05/20/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**DUNWODIE\_345KV\_5**

FWD

Thu 05/19/2022 to Fri 05/20/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**MARCY\_-EDIC\_345\_UE1-7**

FWD

Sat 05/21/2022 to Sat 05/21/2022

(Import)

0700 Continuous 1730

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19&16****PORTER\_-ROTTRDAM\_230\_30 & VOLNEY\_-MARCY\_345\_19**

FWD

Sat 05/21/2022 to Sat 05/21/2022

(Import)

0700 1730

CENTRAL EAST - VC

**2655 MW**

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

**PORTER\_-ROTTRDAM\_230\_31 & VOLNEY\_-MARCY\_345\_19**

FWD

Sat 05/21/2022 to Sat 05/21/2022

(Import)

0700 1730

CENTRAL EAST - VC

**2655 MW**

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

**VOLNEY\_-MARCY\_345\_19**

FWD

Sat 05/21/2022 to Sat 05/21/2022

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

**2825 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 19****VOLNEY\_-MARCY\_345\_19**

FWD

Sat 05/21/2022 to Sat 05/21/2022

(Import)

0700 Continuous 1730

OSWEGO EXPORT

**4900 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19**

**NYISO TRANSFER LIMITATIONS**

Saturday ,February 12, 2022 to Monday ,August 14, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Wed 06/01/2022 to Tue 11/29/2022

(Import)

0700 Continuous 1800

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**NIAGARA\_-DYSINGER\_345\_ND1**

FWD

Mon 06/13/2022 to Fri 06/17/2022

(Import)

0500 Continuous 2100

DYSINGER EAST

**2650 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**NIAGARA\_-PACKARD\_230\_62**

FWD

REV

Sat 06/18/2022 to Sat 06/18/2022

(Import) (Export)

0500 Continuous 1700

SCH - OH - NY

**700 MW****1550 MW**

Impacts Total Transfer Capability 1250 MW 150 MW

TTC with All Lines In Service 1950 MW 1700 MW

Work scheduled by: NYPA

**BEAR SWP-EASTOVER\_230\_E205W**

Mon 06/27/2022 to Tue 06/28/2022

0700 Continuous 0759

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: ISONE

**NIAGARA\_345\_230\_AT4**

FWD

REV

Tue 06/28/2022 to Wed 06/29/2022

(Import) (Export)

0500 Continuous 1700

SCH - OH - NY

**1900 MW****1400 MW**

Impacts Total Transfer Capability 50 MW 300 MW

TTC with All Lines In Service 1950 MW 1700 MW

Work scheduled by: NYPA

**BEAR SWP-EASTOVER\_230\_E205W**

Tue 06/28/2022 to Tue 06/28/2022

0800 Daily(No Weekends) 1500

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NGrid

**BEAR SWP-EASTOVER\_230\_E205W**

Tue 06/28/2022 to Thu 06/30/2022

1501 Continuous 1700

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: ISONE

**NYISO TRANSFER LIMITATIONS**

Saturday ,February 12, 2022 to Monday ,August 14, 2023

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 7815MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BECK\_\_\_\_-NIAGARA\_\_230\_PA27**

Tue 07/05/2022 to Sat 07/09/2022

0500 Continuous 2100

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**NIAGARA\_-DYSINGER\_345\_ND1**

Mon 07/11/2022 to Fri 07/15/2022

0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

**2650 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 3150 MW

**ROCHESTR-PANNELL\_\_345\_RP1**

Mon 07/25/2022 to Fri 07/29/2022

0500 Continuous 2100

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

**MARCY\_\_\_\_-EDIC\_\_\_\_345\_UE1-7**

Sat 08/06/2022 to Sat 08/06/2022

0500 Continuous 1830

Work scheduled by: NYPA

**ARR: 19&16**

FWD

(Import)

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

**PORTER\_\_-ROTTRDAM\_230\_30 & VOLNEY\_\_-MARCY\_\_\_\_345\_19**

Sat 08/06/2022 to Sat 08/06/2022

0500 1830

Work scheduled by:

FWD

(Import)

CENTRAL EAST - VC

**2655 MW**

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 2975 MW

**PORTER\_\_-ROTTRDAM\_230\_31 & VOLNEY\_\_-MARCY\_\_\_\_345\_19**

Sat 08/06/2022 to Sat 08/06/2022

0500 1830

Work scheduled by:

FWD

(Import)

CENTRAL EAST - VC

**2655 MW**

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 2975 MW

**VOLNEY\_\_-MARCY\_\_\_\_345\_19**

Sat 08/06/2022 to Sat 08/06/2022

0500 Continuous 1830

Work scheduled by: NYPA

**ARR: 19**

FWD

(Import)

CENTRAL EAST - VC

**2825 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 2975 MW

**NYISO TRANSFER LIMITATIONS**

Saturday ,February 12, 2022 to Monday ,August 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**VOLNEY\_\_-MARCY\_\_\_\_345\_19**

Sat 08/06/2022 to Sat 08/06/2022  
0500 Continuous 1830

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
OSWEGO EXPORT **4900 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 5250 MW

**SAND\_BAR-PLATSBURG\_115\_PV20**

Mon 08/22/2022 to Fri 08/26/2022  
0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**ROSETON\_-ROCKTVRN\_345\_311**

Mon 08/29/2022 to Fri 09/09/2022  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 3415 MW  
TTC with All Lines In Service 7815 MW

**MOTTHAVN-RAINEY\_\_\_\_345\_Q12**

Thu 09/01/2022 to Mon 09/05/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**PANNELL\_-CLAY\_\_\_\_345\_1**

Mon 09/12/2022 to Fri 09/16/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**FRASER\_-GILBOA\_\_\_\_345\_GF5-35**

Mon 09/12/2022 to Sun 09/18/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

**PANNELL\_-CLAY\_\_\_\_345\_2**

Mon 09/19/2022 to Fri 09/23/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**NYISO TRANSFER LIMITATIONS**

Saturday ,February 12, 2022 to Monday ,August 14, 2023

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 7815MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY -EDIC 345 UE1-7

Mon 09/19/2022 to Sat 10/08/2022

0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19&amp;16

FWD  
(Import)  
OSWEGO EXPORT 5250 MW  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

LEEDS -HURLYAVE 345 301

Mon 09/19/2022 to Fri 10/21/2022

0800 Continuous 1600

Work scheduled by: CHGE

10/04/2021

FWD  
(Import)  
UPNY CONED 4100 MW  
Impacts Total Transfer Capability 3715 MW  
TTC with All Lines In Service 7815 MW

EGRDNCTY 345 138 AT1

Sat 10/01/2022 to Wed 05/31/2023

0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA 1250 MW  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

EGRDNCTY 345 138 AT2

Sat 10/01/2022 to Wed 05/31/2023

0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA 1250 MW  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

SPRNBK -EGRDNCTR 345 Y49

Sat 10/01/2022 to Wed 05/31/2023

0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA 775 MW  
Impacts Total Transfer Capability 725 MW  
TTC with All Lines In Service 1500 MW

SHOR\_NPX-SHOREHAM 138 CSC

Mon 10/03/2022 to Fri 10/21/2022

1000 Continuous 1500

Work scheduled by: LI

UPDATEDby LI01/07/2022

FWD REV  
(Import) (Export)  
SCH - NPX\_CSC 0 MW 0 MW  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

EDIC -N.SCTLND 345 14

Mon 10/10/2022 to Mon 10/31/2022

0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC 1670 MW  
Impacts Total Transfer Capability 1305 MW  
TTC with All Lines In Service 2975 MW

**NYISO TRANSFER LIMITATIONS**

Saturday ,February 12, 2022 to Monday ,August 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC\_\_\_\_-N.SCTLND\_345\_14 &amp; PORTER\_\_\_\_-ROTTRDAM\_230\_30

FWD

Mon 10/10/2022 to Mon 10/31/2022

(Import)

0700

1530

CENTRAL EAST - VC

**1500 MW**

Impacts Total Transfer Capability 1475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

EDIC\_\_\_\_-N.SCTLND\_345\_14 &amp; PORTER\_\_\_\_-ROTTRDAM\_230\_31

FWD

Mon 10/10/2022 to Mon 10/31/2022

(Import)

0700

1530

CENTRAL EAST - VC

**1500 MW**

Impacts Total Transfer Capability 1475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

NIAGARA\_-DYSINGER\_345\_ND1

FWD

Mon 10/17/2022 to Fri 10/21/2022

(Import)

0500

Continuous

1700

UPDATEDby NYPA02/10/2022

DYSINGER EAST

**2650 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

HURLYAVE-ROSETON\_\_\_\_345\_303

FWD

Mon 10/24/2022 to Fri 11/04/2022

(Import)

0800

Continuous

1600

10/04/2021

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: CHGE

GILBOA\_\_\_\_-N.SCTLND\_345\_GNS-1

FWD

Tue 11/01/2022 to Tue 12/06/2022

(Import)

0500

Continuous

1900

UPDATEDby NGRID12/29/2021

CENTRAL EAST - VC

**2520 MW**

Impacts Total Transfer Capability 455 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

LEEDS\_\_\_\_345KV\_R94301

FWD

Tue 11/01/2022 to Tue 12/06/2022

(Import)

0500

Continuous

1900

UPDATEDby NGRID12/29/2021

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

MARCY\_\_\_\_-N.SCTLND\_345\_18

FWD

Tue 11/01/2022 to Tue 12/06/2022

(Import)

0500

Continuous

1900

UPDATEDby NGRID12/29/2021

CENTRAL EAST - VC

**1470 MW**

Impacts Total Transfer Capability 1505 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**ARR: 19**



# NYISO TRANSFER LIMITATIONS

Saturday ,February 12, 2022 to Monday ,August 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## N.SCTLND-LEEDS\_\_\_\_345\_94

FWD

Tue 11/01/2022 to Tue 12/06/2022 UPDATED by NGRID 12/29/2021

(Import)

0500 Continuous 1900

CENTRAL EAST - VC **2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

## PORTER\_\_-ROTTRDAM\_230\_30 & MARCY\_\_\_\_-N.SCTLND\_345\_18

FWD

Tue 11/01/2022 to Tue 12/06/2022

(Import)

0500 1900

CENTRAL EAST - VC **1300 MW**

Impacts Total Transfer Capability 1675 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

## PORTER\_\_-ROTTRDAM\_230\_31 & MARCY\_\_\_\_-N.SCTLND\_345\_18

FWD

Tue 11/01/2022 to Tue 12/06/2022

(Import)

0500 1900

CENTRAL EAST - VC **1300 MW**

Impacts Total Transfer Capability 1675 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

## LEEDS\_\_\_\_-HURLYAVE\_345\_301

FWD

Mon 11/07/2022 to Fri 12/09/2022

(Import)

0800 Continuous 1600

UPNY CONED **4100 MW**

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: CHGE

## MOSES\_\_\_\_-ADIRNDCK\_230\_MAI

FWD

Wed 11/30/2022 to Wed 03/01/2023

(Import)

0700 Continuous 1100

MOSES SOUTH **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## FRASER\_\_\_\_345\_FRASER SVC

FWD

Tue 01/03/2023 to Tue 02/28/2023 UPDATED by NYPA 12/30/2021

(Import)

0700 Continuous 1730

CENTRAL EAST - VC **2935 MW**

Impacts Total Transfer Capability 40 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

## PLSNTVLY\_345KV\_RNS4

FWD

Sat 04/01/2023 to Sat 04/01/2023

(Import)

0700 Continuous 0730

UPNY CONED **3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

**NYISO TRANSFER LIMITATIONS**

Saturday ,February 12, 2022 to Monday ,August 14, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**ATHENS\_\_-PLSNTVLY\_345\_91**

Sat 04/01/2023 to Sat 04/15/2023  
0700 Continuous 1900  
Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**PLSNTVLY\_345KV\_RNS4**

Sat 04/15/2023 to Sat 04/15/2023  
1830 Continuous 1900  
Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**PLSNTVLY\_345KV\_RNS5**

Sun 04/16/2023 to Sun 04/16/2023  
0700 Continuous 0730  
Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**LEEDS\_\_-PLSNTVLY\_345\_92**

Sun 04/16/2023 to Sun 04/30/2023  
0700 Continuous 1900  
Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**PLSNTVLY\_345KV\_RNS5**

Sun 04/30/2023 to Sun 04/30/2023  
1830 Continuous 1900  
Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**SHOR\_NPX-SHOREHAM\_138\_CSC**

Mon 05/01/2023 to Fri 05/05/2023  
0600 Continuous 1800  
Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW