

# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Sun 07/31/2022 EXT FORCE by CONED 01/04/2022

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Sun 07/31/2022

0001 2359

Work scheduled by:

FWD REV  
(Import) (Export)

SCH - PJ - NY

**2550 MW 1900 MW**

Impacts Total Transfer Capability 300 MW 300 MW

TTC with All Lines In Service 2850 MW 2200 MW

### MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Sun 07/31/2022 EXT FORCE by CONED 01/04/2022

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### STLAWRNC-MOSES\_230\_L33P

Mon 04/30/2018 to Tue 05/31/2022 EXT FORCE by IESO 11/04/2021

0456 Continuous 1600

Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### NEWBRDGE\_345\_138\_BK\_1

Wed 09/02/2020 to Mon 08/01/2022 EXT FORCE by LI 12/10/2021

1807 Continuous 2359

Work scheduled by: LI

FWD  
(Import)

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

### NIAGARA\_-KINTIGH\_345\_NS1-38

Mon 10/18/2021 to Sat 12/31/2022 UPDATED by NYPA 01/08/2022

0500 Continuous 2359

Work scheduled by: NYPA

FWD  
(Import)

DYSINGER EAST

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

### SCH-IMO-NYISO\_LIMIT\_1750

Mon 11/01/2021 to Sat 04/30/2022 UPDATED by IESO 05/03/2019

0001 Continuous 2359

Work scheduled by: IESO

FWD  
(Import)

SCH - OH - NY

**2050 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 2300 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NYISO-IMO\_LIMIT\_1600

Mon 11/01/2021 to Sat 04/30/2022  
0001 Continuous 2359

UPDATED by IESO 05/03/2019

Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 2000 MW

REV

(Export)

1900 MW

## KINTIGH\_STA\_255\_345\_SH1-39

Wed 12/08/2021 to Sat 12/31/2022  
2000 Continuous 2359

UPDATED by RGE 01/08/2022

Work scheduled by: NYSEG

FWD  
(Import)  
DYSINGER EAST 1700 MW  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## BECK\_NIAGARA\_345\_PA301

Thu 01/20/2022 to Fri 06/17/2022  
0700 Continuous 1700

UPDATED by IESO 01/18/2022

Work scheduled by: IESO

FWD REV  
(Import) (Export)  
SCH - OH - NY 1100 MW 950 MW  
Impacts Total Transfer Capability 1200 MW 1050 MW  
TTC with All Lines In Service 2300 MW 2000 MW

## SCH-IMO-NYISO\_LIMIT\_500

Wed 01/26/2022 to Tue 03/01/2022  
0001 Continuous 2359

UPDATED by IESO 01/18/2022

Work scheduled by: IESO

FWD  
(Import)  
SCH - OH - NY 800 MW  
Impacts Total Transfer Capability 1500 MW  
TTC with All Lines In Service 2300 MW

## NIAGARA\_ROBNSNRD\_230\_64

Fri 01/28/2022 to Fri 01/28/2022  
0600 Continuous 0700

UPDATED by IESO 01/18/2022

Work scheduled by: NT

REV  
(Export)  
SCH - OH - NY 1900 MW  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 2000 MW

## DYSINGER-KINTIGH\_345\_39 &amp; DYSINGER-STA\_255\_345\_DH1

Fri 01/28/2022 to Sat 02/05/2022  
0600 2300

UPDATED by IESO 01/18/2022

Work scheduled by:

FWD  
(Import)  
DYSINGER EAST 2650 MW  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 3150 MW

## DYSINGER-STA\_255\_345\_DH1

Fri 01/28/2022 to Sat 02/05/2022  
0600 Continuous 2300

UPDATED by IESO 01/18/2022

Work scheduled by: NT

FWD  
(Import)  
DYSINGER EAST 2550 MW  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MAl

FWD

Fri 01/28/2022 to Mon 02/28/2022 UPDATED by NYPA 01/21/2022  
0700 Continuous 1600

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## SCH-IMO-NYISO\_LIMIT\_1550

FWD

Fri 01/28/2022 to Mon 02/28/2022 UPDATED by IESO 01/19/2022  
0700 Continuous 1600

(Import)

Work scheduled by: IESO

SCH - OH - NY **1850 MW**  
Impacts Total Transfer Capability 450 MW  
TTC with All Lines In Service 2300 MW

## SCH-NYISO-IMO\_LIMIT\_1400

REV

Fri 01/28/2022 to Mon 02/28/2022 UPDATED by IESO 01/19/2022  
0700 Continuous 1600

(Export)

Work scheduled by: IESO

SCH - OH - NY **1700 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 2000 MW

## LINDN\_CG-LNDVFT\_\_\_345\_V-3022

FWD

REV

Fri 01/28/2022 to Fri 01/28/2022 UPDATED by PJM 01/25/2022  
1300 Continuous 1500

(Import) (Export)

Work scheduled by: PJM

SCH - PJM\_VFT **0 MW** **0 MW**  
Impacts Total Transfer Capability 315 MW 315 MW  
TTC with All Lines In Service 315 MW 315 MW

## NIAGARA\_-DYSINGER\_345\_ND1

FWD

Sat 01/29/2022 to Tue 02/01/2022 CANCELLED by NT 01/29/2022  
0500 Continuous 1900

(Import)

Work scheduled by: NYPA

DYSINGER EAST **2650 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 3150 MW

## FIVEMILE-STOLLERD\_345\_29

Mon 01/31/2022 to Sun 02/13/2022 UPDATED by NYSEG 01/20/2022  
0500 Continuous 1900

Work scheduled by: NYSEG

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## SCH-IMO-NYISO\_LIMIT\_200

FWD

Wed 02/02/2022 to Wed 02/02/2022  
0001 Daily 0500

(Import)

Work scheduled by: NYISO

SCH - OH - NY **500 MW**  
Impacts Total Transfer Capability 1800 MW  
TTC with All Lines In Service 2300 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## S.RIPLEY-DUNKIRK\_\_230\_68

Wed 02/02/2022 to Wed 02/02/2022

0630 Daily(No Weekends) 1730

Work scheduled by: NGrid

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## CHATGUAY-MASSENA\_\_765\_7040

Wed 02/02/2022 to Sat 02/05/2022

0700 Continuous 1530

Work scheduled by: NYPA

**CANCELLED by NYISO 01/31/2022**

FWD  
(Import)

MOSES SOUTH **1550 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

## CHATGUAY-MASSENA\_\_765\_7040

Wed 02/02/2022 to Sat 02/05/2022

0700 Continuous 1530

Work scheduled by: NYPA

**CANCELLED by NYISO 01/31/2022**

FWD REV  
(Import) (Export)

SCH - HQ - NY **0 MW 0 MW**

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

## SCRIBA\_\_-VOLNEY\_\_345\_20

Wed 02/02/2022 to Wed 02/02/2022

0730 Daily(No Weekends) 1630

Work scheduled by: NGrid

FWD  
(Import)

OSWEGO EXPORT **5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

## MOTTHAVN-RAINEY\_\_345\_Q11

Wed 02/02/2022 to Fri 02/04/2022

1416 Continuous 2300

Work scheduled by: ConEd

FWD  
(Import)

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

## NIAGARA\_\_-ROBNSNRD\_\_230\_64

Wed 02/02/2022 to Wed 02/02/2022

2259 Continuous 2359

Work scheduled by: NT

REV  
(Export)

SCH - OH - NY **1900 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 2000 MW

## SCH-IMO-NYISO\_LIMIT\_200

Wed 02/02/2022 to Tue 03/01/2022

2300 Daily 0500

Work scheduled by: NYISO

FWD  
(Import)

SCH - OH - NY **500 MW**

Impacts Total Transfer Capability 1800 MW

TTC with All Lines In Service 2300 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
<b>NIAGARA__PACKARD__230_61</b>						
Fri 02/04/2022	to	Thu 02/10/2022	<u>UPDATED</u>	<u>by NGRID</u> <u>12/03/2021</u>	SCH - OH - NY	<b>1400 MW</b>
0615	Continuous	1900			Impacts Total Transfer Capability	150 MW
Work scheduled by: NGrid					TTC with All Lines In Service	2300 MW
<b>NIAGARA__DYSINGER_345_ND1</b>						
Sun 02/06/2022	to	Wed 02/09/2022			DYSINGER EAST	<b>2650 MW</b>
0500	Continuous	1700			Impacts Total Transfer Capability	500 MW
Work scheduled by: NT					TTC with All Lines In Service	3150 MW
<b>W49TH_ST_345KV_5</b>						
Mon 02/07/2022	to	Mon 02/07/2022	<u>CANCELLED</u>	<u>by ConEd</u> <u>01/28/2022</u>	SCH - PJM_HTP	<b>300 MW</b>
0001	Continuous	0030			Impacts Total Transfer Capability	360 MW
Work scheduled by: ConEd					TTC with All Lines In Service	660 MW
<b>W49TH_ST_345KV_7</b>						
Mon 02/07/2022	to	Mon 02/07/2022	<u>CANCELLED</u>	<u>by ConEd</u> <u>01/28/2022</u>	SCH - PJM_HTP	<b>300 MW</b>
0001	Continuous	0030			Impacts Total Transfer Capability	360 MW
Work scheduled by: ConEd					TTC with All Lines In Service	660 MW
<b>HOPATCON-RAMAPO__500_5018</b>						
Mon 02/07/2022	to	Mon 02/07/2022			SCH - PJ - NY	<b>1650 MW</b>
0301	Continuous	1800			Impacts Total Transfer Capability	1000 MW
Work scheduled by: ConEd					TTC with All Lines In Service	2850 MW
<b>HOPATCON-RAMAPO__500_5018</b>						
Mon 02/07/2022	to	Mon 02/07/2022			UPNY CONED	<b>7480 MW</b>
0301	Continuous	1800			Impacts Total Transfer Capability	335 MW
Work scheduled by: ConEd					TTC with All Lines In Service	7815 MW
<b>RAMAPO__345_345_PAR3500</b>						
Mon 02/07/2022	to	Mon 02/07/2022			SCH - PJ - NY	<b>2500 MW</b>
0301	Continuous	1800			Impacts Total Transfer Capability	950 MW
Work scheduled by: ConEd					TTC with All Lines In Service	2850 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>RAMAPO___345_345_PAR4500</b>				FWD	REV
Mon 02/07/2022	to	Mon 02/07/2022		(Import)	(Export)
0301	Continuous	1800		SCH - PJ - NY	<b>2500 MW</b> <b>1250 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	350 MW 950 MW
				TTC with All Lines In Service	2850 MW 2200 MW
<b>RAMAPO___500_345_BK 1500</b>				FWD	REV
Mon 02/07/2022	to	Mon 02/07/2022		(Import)	(Export)
0301	Continuous	1800		SCH - PJ - NY	<b>1650 MW</b> <b>1200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1200 MW 1000 MW
				TTC with All Lines In Service	2850 MW 2200 MW
<b>RAMAPO___500_345_BK 1500</b>				FWD	
Mon 02/07/2022	to	Mon 02/07/2022		(Import)	
0301	Continuous	1800		UPNY CONED	<b>7480 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	335 MW
				TTC with All Lines In Service	7815 MW
<b>SCH-IMO-NYISO_LIMIT_700</b>				FWD	
Mon 02/07/2022	to	Fri 02/18/2022	<b><u>CANCELLED</u> by NYPA <u>01/31/2022</u></b>	(Import)	
0500	Continuous	2100		SCH - OH - NY	<b>1000 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1300 MW
				TTC with All Lines In Service	2300 MW
<b>MOSES___-ADIRNDCK_230_MAL &amp; MOSES___-MASSENA_230_MMS1 &amp; MOSES___-MASSENA_230_MMS2</b>				FWD	
Tue 02/08/2022	to	Tue 02/08/2022		(Import)	
0700		1200		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	189 MW
				TTC with All Lines In Service	279 MW
<b>MOSES___-MASSENA_230_MMS1 &amp; MOSES___-MASSENA_230_MMS2</b>				FWD	REV
Tue 02/08/2022	to	Tue 02/08/2022		(Import)	(Export)
0700		1200		SCH - HQ - NY	<b>850 MW</b> <b>0 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	650 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
<b>MOSES___-MASSENA_230_MMS1 &amp; MOSES___-MASSENA_230_MMS2</b>				FWD	
Tue 02/08/2022	to	Tue 02/08/2022		(Import)	
0700		1200		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	189 MW
				TTC with All Lines In Service	279 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES___230_L33P & MOSES___-ADIRNDCK_230_MA1 & MOSES___-					FWD	
MASSENA___230_MMS1 & MOSES___-MASSENA___230_MMS2					(Import)	
Tue 02/08/2022	to	Tue 02/08/2022			SCH - HQ_CEDARS	90 MW
0700		1200			Impacts Total Transfer Capability	189 MW
Work scheduled by:					TTC with All Lines In Service	279 MW
STLAWRNC-MOSES___230_L33P & MOSES___-MASSENA___230_MMS1 & MOSES___-					FWD	
MASSENA___230_MMS2					(Import)	
Tue 02/08/2022	to	Tue 02/08/2022			SCH - HQ_CEDARS	90 MW
0700		1200			Impacts Total Transfer Capability	189 MW
Work scheduled by:					TTC with All Lines In Service	279 MW
MARCY___-N.SCTLND_345_18					FWD	
Tue 02/08/2022	to	Wed 02/09/2022	<u>UPDATED</u>	<u>by NYPA</u> <u>01/18/2022</u>	(Import)	
0730	Continuous	1730			CENTRAL EAST - VC	1470 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1505 MW
					TTC with All Lines In Service	2975 MW
CHATGUAY-MASSENA___765_7040					FWD	
Wed 02/09/2022	to	Sat 02/12/2022			(Import)	
0700	Continuous	1530			MOSES SOUTH	1550 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA___765_7040					FWD	REV
Wed 02/09/2022	to	Sat 02/12/2022			(Import)	(Export)
0700	Continuous	1530			SCH - HQ - NY	0 MW 0 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1500 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW
NIAGARA___-STA_255___345_NH2					FWD	
Thu 02/10/2022	to	Tue 03/22/2022	<u>UPDATED</u>	<u>by NYPA</u> <u>01/25/2022</u>	(Import)	
0500	Continuous	1900			DYSINGER EAST	1700 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_-STA\_255\_\_345\_NH2 & KINTIGH\_-STA\_255\_\_345\_SH1-39

Thu 02/10/2022 to Tue 03/22/2022  
0500 1900

Work scheduled by:

FWD  
(Import)  
DYSINGER EAST **1250 MW**  
Impacts Total Transfer Capability 1900 MW  
TTC with All Lines In Service 3150 MW

## W49TH\_ST\_345KV\_5

Thu 02/10/2022 to Thu 02/10/2022  
2130 Continuous 2200

Work scheduled by: ConEd

**CANCELLED** **by ConEd** **01/28/2022**

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

## W49TH\_ST\_345KV\_7

Thu 02/10/2022 to Thu 02/10/2022  
2130 Continuous 2200

Work scheduled by: ConEd

**CANCELLED** **by ConEd** **01/28/2022**

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

## PLSNTVLY\_345KV\_RNS4

Sat 02/12/2022 to Sat 02/12/2022  
0600 Continuous 0630

Work scheduled by: NGrid

**UPDATED** **by CONED** **11/12/2021**

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## ATHENS\_-PLSNTVLY\_345\_91

Sat 02/12/2022 to Wed 02/16/2022  
0600 Continuous 1900

Work scheduled by: NGrid

**UPDATED** **by CONED** **11/12/2021**

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

Sun 02/13/2022 to Mon 02/14/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

## RAMAPO\_-BUCHAN\_N\_345\_Y94

Sun 02/13/2022 to Mon 02/14/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7580 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 7815 MW



**NYISO TRANSFER LIMITATIONS**

Wednesday, February 02, 2022 to Friday , August 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MILLWOOD\_345KV\_18**

FWD

Mon 02/14/2022 to Tue 02/15/2022

(Import)

0001 Continuous 0200

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**EASTVIEW-SPRNBK\_\_345\_W78**

FWD

Tue 02/15/2022 to Wed 02/16/2022

(Import)

0201 Continuous 0200

UPDATEDby CE01/07/2022

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**MILLWOOD-EASTVIEW\_345\_W85**

FWD

Tue 02/15/2022 to Wed 02/16/2022

(Import)

0201 Continuous 0200

UPDATEDby CE01/07/2022

UPNY CONED

**7550 MW**

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**SPRNBK\_\_345KV\_RNS3**

FWD

Tue 02/15/2022 to Wed 02/16/2022

(Import)

0201 Continuous 0200

UPDATEDby CE01/07/2022

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**W49TH\_ST\_345KV\_5**

FWD

Wed 02/16/2022 to Wed 02/16/2022

(Import)

0201 Continuous 0230

UPDATEDby CONED02/01/2022

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**W49TH\_ST\_345KV\_7**

FWD

Wed 02/16/2022 to Wed 02/16/2022

(Import)

0201 Continuous 0230

UPDATEDby CONED02/01/2022

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**PLSNTVLY\_345KV\_RNS4**

FWD

Wed 02/16/2022 to Wed 02/16/2022

(Import)

1830 Continuous 1900

UPDATEDby CONED11/12/2021

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

FWD

Thu 02/17/2022 to Sat 02/19/2022  
0001 2200

Work scheduled by:

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## LEEDS - PLSNTVLY\_345\_92

FWD

Thu 02/17/2022 to Fri 03/25/2022 UPDATED by NYISO 11/15/2021  
0001 Continuous 2200

Work scheduled by: ConEd

(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## PLSNTVLY\_345KV\_RNS5

FWD

Thu 02/17/2022 to Fri 03/25/2022 UPDATED by NYISO 11/15/2021  
0001 Continuous 2200

Work scheduled by: ConEd

(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## W49TH\_ST\_345KV\_5

FWD

Fri 02/18/2022 to Fri 02/18/2022 UPDATED by CONED 02/01/2022  
2130 Continuous 2200

Work scheduled by: ConEd

(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

## W49TH\_ST\_345KV\_7

FWD

Fri 02/18/2022 to Fri 02/18/2022 UPDATED by CONED 02/01/2022  
2130 Continuous 2200

Work scheduled by: ConEd

(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

## PLSNTVLY-WOOD\_ST\_345\_F30

FWD

Sun 02/20/2022 to Mon 02/21/2022  
0001 Continuous 2200

Work scheduled by: ConEd

(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

## EASTVIEW-SPRNBK\_345\_W64

FWD

Sun 02/20/2022 to Mon 02/21/2022  
2000 Continuous 2359

Work scheduled by: ConEd

(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MILLWOOD-EASTVIEW\_345\_W99

Sun 02/20/2022 to Mon 02/21/2022  
2000 Continuous 2359  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7550 MW**  
Impacts Total Transfer Capability 265 MW  
TTC with All Lines In Service 7815 MW

### SPRNBK\_345KV\_RNS5

Sun 02/20/2022 to Mon 02/21/2022  
2000 Continuous 2359  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

### EASTVIEW-SPRNBK\_345\_W64

Tue 02/22/2022 to Wed 02/23/2022 UPDATED by CONED 01/13/2022  
0001 Continuous 0030  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

### SPRNBK\_345KV\_RNS5

Tue 02/22/2022 to Wed 02/23/2022 UPDATED by CONED 01/13/2022  
0001 Continuous 0030  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

### MILLWOOD-EASTVIEW\_345\_W99

Tue 02/22/2022 to Mon 03/21/2022 UPDATED by CONED 01/13/2022  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7550 MW**  
Impacts Total Transfer Capability 265 MW  
TTC with All Lines In Service 7815 MW

### MARCY\_-EDIC\_345\_UE1-7

Wed 02/23/2022 to Mon 02/28/2022 UPDATED by NYPA 01/17/2022  
0600 Continuous 1730  
Work scheduled by: NYPA **ARR: 19&16**

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

### W49TH\_ST-E13THSTA\_345\_M54

Sun 02/27/2022 to Wed 03/02/2022  
0201 Continuous 2230  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, February 02, 2022 to Friday , August 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Mon 02/28/2022 to Tue 05/31/2022

(Import)

1601 Continuous 1300

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**FIVEMILE-STOLLERD\_345\_29**

Tue 03/01/2022 to Tue 04/12/2022

0500 Continuous 1900

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYSEG

**PORTER\_\_\_-ROTTRDAM\_230\_31**

FWD

Tue 03/01/2022 to Tue 12/31/2030

(Import)

0600 Continuous 2359

CENTRAL EAST - VC

**2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**N.SCTLND-LEEDS\_\_\_345\_93**

FWD

Tue 03/01/2022 to Mon 03/28/2022

(Import)

0700 Continuous 1900

**UPDATED****by NGRID 11/15/2021**

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**EDIC\_\_\_-N.SCTLND\_345\_14**

FWD

Tue 03/01/2022 to Tue 04/12/2022

(Import)

0700 Continuous 1900

**UPDATED****by NGRID 11/15/2021**

CENTRAL EAST - VC

**1670 MW**

Impacts Total Transfer Capability 1305 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**EDIC\_\_\_-N.SCTLND\_345\_14 & PORTER\_\_\_-ROTTRDAM\_230\_31**

FWD

Tue 03/01/2022 to Tue 04/12/2022

(Import)

0700 1900

CENTRAL EAST - VC

**1500 MW**

Impacts Total Transfer Capability 1475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

**FRASANNX-COOPERS\_\_\_345\_UCC2-41**

FWD

Tue 03/01/2022 to Wed 04/20/2022

(Import)

0700 Continuous 1530

**UPDATED****by NYPA 02/02/2022**

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 19**

# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MARCY\_\_\_-FRASANNX\_345\_UCC2-41

FWD

Tue 03/01/2022 to Wed 04/20/2022  
0700 Continuous 1530

UPDATEDby NYPA02/02/2022

(Import)

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

## N.SCTLND-ALPS\_\_\_345\_2

FWD

Tue 03/01/2022 to Fri 06/24/2022  
0700 Continuous 1900

UPDATEDby NGRID11/15/2021

(Import)

Work scheduled by: NGrid

SCH - NE - NY

**900 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1400 MW

## N.SCTLND-ALPS\_\_\_345\_2

FWD

REV

Tue 03/01/2022 to Fri 06/24/2022  
0700 Continuous 1900

UPDATEDby NGRID11/15/2021

(Import) (Export)

Work scheduled by: NGrid

SCH - NPX\_1385

**100 MW****100 MW**

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

## SCH-IMO-NYISO\_LIMIT\_200

FWD

Tue 03/01/2022 to Tue 03/01/2022  
2300 Daily 2359

(Import)

Work scheduled by: NYISO

SCH - OH - NY

**500 MW**

Impacts Total Transfer Capability 1800 MW

TTC with All Lines In Service 2300 MW

## W49TH\_ST\_345KV\_5

FWD

Fri 03/04/2022 to Fri 03/04/2022  
0001 Continuous 0031

(Import)

Work scheduled by: ConEd

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

## SPRNBRK\_\_\_345KV\_RNS4

FWD

Fri 03/04/2022 to Sat 03/05/2022  
0001 Continuous 1800

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

## SPRNBRK\_-W49TH\_ST\_345\_M52

FWD

Fri 03/04/2022 to Sat 03/19/2022  
0001 Continuous 0200

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_5

FWD

Mon 03/07/2022 to Sat 03/19/2022

(Import)

0001 Continuous 0200

SCH - PJM\_HTP

300 MW

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

### SPRNBRK\_345KV\_RNS4

FWD

Thu 03/10/2022 to Tue 03/15/2022

(Import)

0001 Continuous 1800

SPR/DUN-SOUTH

3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### INDPDNCE-SCRIBA\_345\_25

FWD

Thu 03/10/2022 to Wed 03/16/2022

(Import)

0800 Continuous 1800

OSWEGO EXPORT

5250 MW

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

### PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

FWD

Thu 03/17/2022 to Sun 03/20/2022

(Import)

0100 2200

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by:

### PLSNTVLY-WOOD\_ST\_345\_F30

FWD

Mon 03/21/2022 to Wed 03/23/2022

(Import)

0001 Continuous 2200

UPNY CONED

4000 MW

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### EGRDNCTY\_345\_138\_AT1

FWD

Mon 03/21/2022 to Sat 03/26/2022

(Import)

0001 Continuous 0300

CONED - LIPA

1250 MW

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: ConEd

### EGRDNCTY\_345\_138\_AT2

FWD

Mon 03/21/2022 to Sat 03/26/2022

(Import)

0001 Continuous 0300

CONED - LIPA

1250 MW

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SPRNBK\_-EGRDNCTR\_345\_Y49**

FWD

Mon 03/21/2022 to Sat 03/26/2022

(Import)

0001 Continuous 0300

CONED - LIPA

**775 MW**

Impacts Total Transfer Capability 725 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: ConEd

**EASTVIEW-SPRNBK\_345\_W64**

FWD

Mon 03/21/2022 to Mon 03/21/2022

(Import)

UPDATEDby CONED 01/13/2022

0130 Continuous 0200

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**SPRNBK\_345KV\_RNS5**

FWD

Mon 03/21/2022 to Mon 03/21/2022

(Import)

UPDATEDby CONED 01/13/2022

0130 Continuous 0200

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

FWD

Sat 03/26/2022 to Mon 03/28/2022

(Import)

0001 2200

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by:

**ATHENS\_-PLSNTVLY\_345\_91**

FWD

Sat 03/26/2022 to Sun 05/01/2022

(Import)

UPDATEDby CE01/03/2022

0001 Continuous 2200

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**PLSNTVLY\_345KV\_RNS4**

FWD

Sat 03/26/2022 to Sun 05/01/2022

(Import)

UPDATEDby CE01/03/2022

0001 Continuous 2200

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**PLSNTVLY-WOOD\_ST\_345\_F31**

FWD

Tue 03/29/2022 to Wed 03/30/2022

(Import)

0001 Continuous 2200

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE_345KV_6</b>						FWD	
Fri 04/01/2022	to	Sat 04/02/2022	<u>UPDATED</u>	<u>by CE</u>	<u>01/25/2022</u>	(Import)	
0001	Continuous	0300				SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_8</b>						FWD	
Fri 04/01/2022	to	Sat 04/02/2022	<u>UPDATED</u>	<u>by CE</u>	<u>01/25/2022</u>	(Import)	
0001	Continuous	0300				SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
<b>PLSNTVLE-DUNWODIE_345_W90</b>						FWD	
Fri 04/01/2022	to	Tue 04/05/2022	<u>UPDATED</u>	<u>by CE</u>	<u>01/25/2022</u>	(Import)	
0001	Continuous	2200				UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	3815 MW
						TTC with All Lines In Service	7815 MW
<b>WOOD_ST_-PLSNTVLE_345_Y87</b>						FWD	
Fri 04/01/2022	to	Tue 04/05/2022	<u>UPDATED</u>	<u>by CE</u>	<u>01/25/2022</u>	(Import)	
0001	Continuous	2200				UPNY CONED	<b>7260 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	555 MW
						TTC with All Lines In Service	7815 MW
<b>LINDN_CG-LNDVFT__345_V-3022</b>						FWD	REV
Sun 04/03/2022	to	Sat 04/09/2022				(Import)	(Export)
1400	Continuous	1400				SCH - PJM_VFT	<b>0 MW</b> <b>0 MW</b>
Work scheduled by: PJM						Impacts Total Transfer Capability	315 MW 315 MW
						TTC with All Lines In Service	315 MW 315 MW
<b>N.SCTLND-ALPS____345_2 &amp; NRTH1385-NOR HBR__138_601</b>						FWD	REV
Mon 04/04/2022	to	Mon 04/18/2022				(Import)	(Export)
0001		2359				SCH - NPX_1385	<b>0 MW</b> <b>0 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	200 MW 200 MW
						TTC with All Lines In Service	200 MW 200 MW
<b>N.SCTLND-ALPS____345_2 &amp; NRTH1385-NOR HBR__138_602</b>						FWD	REV
Mon 04/04/2022	to	Mon 04/18/2022				(Import)	(Export)
0001		2359				SCH - NPX_1385	<b>0 MW</b> <b>0 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	200 MW 200 MW
						TTC with All Lines In Service	200 MW 200 MW



# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N.SCTLND-ALPS_____345_2 & NRTH1385-NOR HBR__138_603				FWD	REV
Mon 04/04/2022	to	Mon 04/18/2022		(Import)	(Export)
0001		2359	SCH - NPX_1385	0 MW	0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_601				FWD	REV
Mon 04/04/2022	to	Mon 04/18/2022		(Import)	(Export)
0001	Continuous	2359	SCH - NPX_1385	100 MW	100 MW
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602				FWD	REV
Mon 04/04/2022	to	Mon 04/18/2022		(Import)	(Export)
0001		2359	SCH - NPX_1385	0 MW	0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603				FWD	REV
Mon 04/04/2022	to	Mon 04/18/2022		(Import)	(Export)
0001		2359	SCH - NPX_1385	0 MW	0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_602				FWD	REV
Mon 04/04/2022	to	Mon 04/18/2022		(Import)	(Export)
0001	Continuous	2359	SCH - NPX_1385	100 MW	100 MW
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603				FWD	REV
Mon 04/04/2022	to	Mon 04/18/2022		(Import)	(Export)
0001		2359	SCH - NPX_1385	0 MW	0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_603				FWD	REV
Mon 04/04/2022	to	Mon 04/18/2022		(Import)	(Export)
0001	Continuous	2359	SCH - NPX_1385	100 MW	100 MW
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NRTH1385-NRTHPORT_138_NNC</b>						FWD	REV
Mon 04/04/2022	to	Mon 04/18/2022				(Import)	(Export)
0001	Continuous	2359			SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	200 MW
						TTC with All Lines In Service	200 MW
<b>SPRNBRK_-TREMONT__345_X28</b>						FWD	
Tue 04/05/2022	to	Wed 04/06/2022	<u>UPDATED</u>	<u>by CE</u>	<u>01/12/2022</u>	(Import)	
0201	Continuous	0300			SPR/DUN-SOUTH	<b>4200 MW</b>	
Work scheduled by: ConEd						Impacts Total Transfer Capability	400 MW
						TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_6</b>						FWD	
Tue 04/05/2022	to	Tue 04/05/2022	<u>UPDATED</u>	<u>by CE</u>	<u>01/25/2022</u>	(Import)	
2130	Continuous	2200			SPR/DUN-SOUTH	<b>3800 MW</b>	
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_8</b>						FWD	
Tue 04/05/2022	to	Tue 04/05/2022	<u>UPDATED</u>	<u>by CE</u>	<u>01/25/2022</u>	(Import)	
2130	Continuous	2200			SPR/DUN-SOUTH	<b>3800 MW</b>	
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
<b>BUCHAN_N-EASTVIEW_345_W93</b>						FWD	
Wed 04/06/2022	to	Wed 04/06/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/19/2021</u>	(Import)	
0301	Continuous	0330			UPNY CONED	<b>4350 MW</b>	
Work scheduled by: ConEd						Impacts Total Transfer Capability	3465 MW
						TTC with All Lines In Service	7815 MW
<b>EASTVIEW-SPRNBRK__345_W79</b>						FWD	
Wed 04/06/2022	to	Thu 04/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/19/2021</u>	(Import)	
0301	Continuous	0300			UPNY CONED	<b>4350 MW</b>	
Work scheduled by: ConEd						Impacts Total Transfer Capability	3465 MW
						TTC with All Lines In Service	7815 MW
<b>BUCHAN_N-EASTVIEW_345_W93</b>						FWD	
Thu 04/07/2022	to	Thu 04/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/19/2021</u>	(Import)	
0230	Continuous	0300			UPNY CONED	<b>4350 MW</b>	
Work scheduled by: ConEd						Impacts Total Transfer Capability	3465 MW
						TTC with All Lines In Service	7815 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EASTVIEW-SPRNBK\_\_345\_W64**

FWD

 Thu 04/07/2022 to Thu 04/07/2022 UPDATED by CONED 01/13/2022

(Import)

0301 Continuous 0330

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**SPRNBK\_\_345KV\_RNS5**

FWD

 Thu 04/07/2022 to Thu 04/07/2022 UPDATED by CONED 01/13/2022

(Import)

0301 Continuous 0330

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**MILLWOOD-EASTVIEW\_345\_W99**

FWD

 Thu 04/07/2022 to Tue 04/26/2022 UPDATED by CONED 01/13/2022

(Import)

0301 Continuous 2200

UPNY CONED

**7550 MW**

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**MOTTHAVN-RAINEY\_\_345\_Q12**

FWD

Mon 04/11/2022 to Thu 04/28/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**PANNELL\_-CLAY\_\_\_\_345\_1**

FWD

Mon 04/11/2022 to Fri 04/15/2022

(Import)

0700 Continuous 1530

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

**PORTER\_-ROTTRDAM\_230\_30**

FWD

Wed 04/13/2022 to Tue 12/31/2030

(Import)

0600 Continuous 2359

CENTRAL EAST - VC

**2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**PORTER\_-ROTTRDAM\_230\_30 & PORTER\_-ROTTRDAM\_230\_31**

FWD

Wed 04/13/2022 to Tue 12/31/2030

(Import)

0600 2359

CENTRAL EAST - VC

**2635 MW**

Impacts Total Transfer Capability 340 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PANNELL\_-CLAY\_\_\_\_\_345\_2

Mon 04/18/2022 to Fri 04/22/2022

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

WEST CENTRAL **1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

## SCH-NE-NYISO\_LIMIT\_700

Tue 04/19/2022 to Fri 04/22/2022

0601 Continuous 0759

Work scheduled by: ISONE

FWD

(Import)

SCH - NE - NY **900 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1400 MW

## EDIC\_\_\_\_\_-FRASER\_\_\_\_345\_EF24-40

Thu 04/21/2022 to Tue 06/14/2022

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

## MARCY\_\_\_\_\_345KV\_CSC

Fri 04/22/2022 to Sat 04/23/2022

0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2925 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

## SCH-NE-NYISO\_LIMIT\_700

Fri 04/22/2022 to Sun 04/24/2022

1601 Continuous 1800

Work scheduled by: ISONE

FWD

(Import)

SCH - NE - NY **900 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1400 MW

## PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Sat 04/23/2022 to Tue 04/26/2022

0001 2200

Work scheduled by:

FWD

(Import)

UPNY CONED **3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

## ROCHESTR-PANNELL\_\_\_\_345\_RP1

Mon 04/25/2022 to Fri 04/29/2022

0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, February 02, 2022 to Friday , August 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SAND\_BAR-PLATSBURG\_115\_PV20**

Mon 04/25/2022 to Fri 04/29/2022 **UPDATED** **by ISONE** **01/28/2022**  
0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**SCH-NYISO-NE\_LIMIT\_1500**

Mon 04/25/2022 to Fri 04/29/2022 **UPDATED** **by ISONE** **01/28/2022**  
0700 Continuous 1530

Work scheduled by: NYPA

REV  
(Export)  
**1700 MW**  
SCH - NE - NY  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 1800 MW

**EASTVIEW-SPRNBK\_345\_W64**

Tue 04/26/2022 to Tue 04/26/2022 **UPDATED** **by CONED** **01/13/2022**  
2130 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

**SPRNBK\_345KV\_RNS5**

Tue 04/26/2022 to Tue 04/26/2022 **UPDATED** **by CONED** **01/13/2022**  
2130 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

**PLSNTVLY-WOOD\_ST\_345\_F31**

Wed 04/27/2022 to Fri 04/29/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

**NIAGARA\_345\_230\_AT4**

Fri 04/29/2022 to Fri 04/29/2022  
0500 Continuous 1700

Work scheduled by: NYPA

REV  
(Export)  
**1750 MW**  
SCH - OH - NY  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 2000 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

Mon 05/02/2022 to Mon 05/02/2022  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EASTVIEW-SPRNBK\_\_345\_W79**

FWD

Mon 05/02/2022 to Thu 05/05/2022

(Import)

0001 Continuous 0200

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**ROCHESTR-PANNELL\_\_345\_RP2**

FWD

Mon 05/02/2022 to Fri 05/06/2022

(Import)

0500 Continuous 1700

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**BUCHAN\_N-EASTVIEW\_345\_W93**

FWD

Thu 05/05/2022 to Thu 05/05/2022

(Import)

0130 Continuous 0200

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**SPRNBK\_-TREMONT\_\_345\_X28**

FWD

Fri 05/06/2022 to Mon 05/09/2022

(Import)

0201 Continuous 1800

**UPDATED by CONED 08/19/2021**

SPR/DUN-SOUTH

**4200 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**FRASER\_\_345\_FRASER SVC**

FWD

Mon 05/09/2022 to Fri 05/13/2022

(Import)

0800 Continuous 1700

CENTRAL EAST - VC

**2935 MW**

Impacts Total Transfer Capability 40 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

**PLSNTVLE-DUNWODIE\_345\_W89**

FWD

Fri 05/13/2022 to Fri 05/13/2022

(Import)

0200 Continuous 0230

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**EFISHKIL-WOOD\_ST\_\_345\_F38**

FWD

Fri 05/13/2022 to Fri 05/13/2022

(Import)

0200 Continuous 0430

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### WOOD\_ST\_-PLSNTVLE\_345\_Y86

FWD

Fri 05/13/2022 to Fri 05/13/2022

(Import)

0200 Continuous 0430

UPNY CONED

7210 MW

Impacts Total Transfer Capability 605 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### PLSNTVLE-DUNWODIE\_345\_W89

FWD

Fri 05/13/2022 to Fri 05/13/2022

(Import)

0400 Continuous 0430

UPNY CONED

4000 MW

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### EFISHKIL-WOOD\_ST\_345\_F38

FWD

Sun 05/15/2022 to Tue 05/17/2022

(Import)

2100 Continuous 0300

UPNY CONED

4000 MW

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### PLSNTVLE-DUNWODIE\_345\_W89

FWD

Sun 05/15/2022 to Tue 05/17/2022

(Import)

2100 Continuous 0300

UPNY CONED

4000 MW

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### WOOD\_ST\_-PLSNTVLE\_345\_Y86

FWD

Sun 05/15/2022 to Tue 05/17/2022

(Import)

2100 Continuous 0300

UPNY CONED

7210 MW

Impacts Total Transfer Capability 605 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### SHOR\_NPX-SHOREHAM\_138\_CSC

FWD

REV

Mon 05/16/2022 to Fri 05/27/2022

(Import) (Export)

0600 Continuous 1800

SCH - NPX\_CSC

0 MW

0 MW

Impacts Total Transfer Capability 330 MW 330 MW

TTC with All Lines In Service 330 MW 330 MW

Work scheduled by: LI

### DUNWODIE-MOTTHAVN\_345\_71

FWD

Thu 05/19/2022 to Fri 05/20/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**NYISO TRANSFER LIMITATIONS**

Wednesday, February 02, 2022 to Friday , August 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_3**

FWD

Thu 05/19/2022 to Fri 05/20/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**DUNWODIE\_345KV\_5**

FWD

Thu 05/19/2022 to Fri 05/20/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**MARCY\_-EDIC\_345\_UE1-7**

FWD

Sat 05/21/2022 to Sat 05/21/2022

(Import)

0700 Continuous 1730

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19&16****PORTER\_-ROTTRDAM\_230\_30 & VOLNEY\_-MARCY\_345\_19**

FWD

Sat 05/21/2022 to Sat 05/21/2022

(Import)

0700 1730

CENTRAL EAST - VC

**2655 MW**

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

**PORTER\_-ROTTRDAM\_230\_31 & VOLNEY\_-MARCY\_345\_19**

FWD

Sat 05/21/2022 to Sat 05/21/2022

(Import)

0700 1730

CENTRAL EAST - VC

**2655 MW**

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

**VOLNEY\_-MARCY\_345\_19**

FWD

Sat 05/21/2022 to Sat 05/21/2022

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

**2825 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 19****VOLNEY\_-MARCY\_345\_19**

FWD

Sat 05/21/2022 to Sat 05/21/2022

(Import)

0700 Continuous 1730

OSWEGO EXPORT

**4900 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19**



# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Wed 06/01/2022 to Tue 11/29/2022  
0700 Continuous 1800

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## NIAGARA\_-DYSINGER\_345\_ND1

Mon 06/13/2022 to Fri 06/17/2022  
0500 Continuous 2100

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2650 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 3150 MW

## NIAGARA\_-PACKARD\_230\_62

Sat 06/18/2022 to Sat 06/18/2022  
0500 Continuous 1700

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>700 MW</b>	<b>1550 MW</b>
Impacts Total Transfer Capability	1250 MW	150 MW
TTC with All Lines In Service	1950 MW	1700 MW

## NIAGARA\_345\_230\_AT4

Tue 06/28/2022 to Wed 06/29/2022  
0500 Continuous 1700

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1900 MW</b>	<b>1400 MW</b>
Impacts Total Transfer Capability	50 MW	300 MW
TTC with All Lines In Service	1950 MW	1700 MW

## BEAR SWP-EASTOVER\_230\_E205W

Tue 06/28/2022 to Tue 06/28/2022  
0800 Daily(No Weekends) 1500

Work scheduled by: NGrid

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## BECK\_\_\_-NIAGARA\_230\_PA27

Tue 07/05/2022 to Sat 07/09/2022  
0500 Continuous 2100

Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## NIAGARA\_-DYSINGER\_345\_ND1

Mon 07/11/2022 to Fri 07/15/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2650 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**ROCHESTR-PANNELL\_\_345\_RP1**

FWD

Mon 07/25/2022 to Fri 07/29/2022

(Import)

0500 Continuous 2100

DYSINGER EAST **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

---

**MARCY\_\_-EDIC\_\_345\_UE1-7**

FWD

Sat 08/06/2022 to Sat 08/06/2022

(Import)

0500 Continuous 1830

OSWEGO EXPORT **5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19&16**


---

**PORTER\_\_-ROTTRDAM\_230\_30 & VOLNEY\_\_-MARCY\_\_345\_19**

FWD

Sat 08/06/2022 to Sat 08/06/2022

(Import)

0500 1830

CENTRAL EAST - VC **2655 MW**

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

---

**PORTER\_\_-ROTTRDAM\_230\_31 & VOLNEY\_\_-MARCY\_\_345\_19**

FWD

Sat 08/06/2022 to Sat 08/06/2022

(Import)

0500 1830

CENTRAL EAST - VC **2655 MW**

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

---

**VOLNEY\_\_-MARCY\_\_345\_19**

FWD

Sat 08/06/2022 to Sat 08/06/2022

(Import)

0500 Continuous 1830

CENTRAL EAST - VC **2825 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 19**


---

**VOLNEY\_\_-MARCY\_\_345\_19**

FWD

Sat 08/06/2022 to Sat 08/06/2022

(Import)

0500 Continuous 1830

OSWEGO EXPORT **4900 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19**


---

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 08/22/2022 to Fri 08/26/2022

0700 Continuous 1530

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## ROSETON\_-ROCKTVRN\_345\_311

FWD

Mon 08/29/2022 to Fri 09/09/2022

(Import)

0800 Continuous 1600

UPNY CONED

**4400 MW**

Impacts Total Transfer Capability 3415 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: CHGE

## MOTTHAVN-RAINEY\_345\_Q12

FWD

Thu 09/01/2022 to Mon 09/05/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## PANNELL\_-CLAY\_345\_1

FWD

Mon 09/12/2022 to Fri 09/16/2022

(Import)

0700 Continuous 1530

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

## FRASER\_-GILBOA\_345\_GF5-35

FWD

Mon 09/12/2022 to Sun 09/18/2022

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

## PANNELL\_-CLAY\_345\_2

FWD

Mon 09/19/2022 to Fri 09/23/2022

(Import)

0700 Continuous 1530

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

## MARCY\_-EDIC\_345\_UE1-7

FWD

Mon 09/19/2022 to Sat 10/08/2022

(Import)

0700 Continuous 1530

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19&16**

## LEEDS\_-HURLYAVE\_345\_301

FWD

Mon 09/19/2022 to Fri 10/21/2022

(Import)

0800 Continuous 1600

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: CHGE

**10/04/2021**

# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_-DYSINGER\_345\_ND1

Mon 09/26/2022 to Fri 09/30/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2650 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 3150 MW

## EGRDNCTY\_345\_138\_AT1

Sat 10/01/2022 to Wed 05/31/2023  
0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

## EGRDNCTY\_345\_138\_AT2

Sat 10/01/2022 to Wed 05/31/2023  
0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

## SPRNBRK\_-EGRDNCTR\_345\_Y49

Sat 10/01/2022 to Wed 05/31/2023  
0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **775 MW**  
Impacts Total Transfer Capability 725 MW  
TTC with All Lines In Service 1500 MW

## SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 10/03/2022 to Fri 10/21/2022 **UPDATED by LI 01/07/2022**  
1000 Continuous 1500

Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_CSC **0 MW 0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

## EDIC\_-N.SCTLND\_345\_14

Mon 10/10/2022 to Mon 10/31/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **1670 MW**  
Impacts Total Transfer Capability 1305 MW  
TTC with All Lines In Service 2975 MW

## EDIC\_-N.SCTLND\_345\_14 & PORTER\_-ROTTRDAM\_230\_30

Mon 10/10/2022 to Mon 10/31/2022  
0700 1530

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **1500 MW**  
Impacts Total Transfer Capability 1475 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC\_\_\_\_-N.SCTLND\_345\_14 & PORTER\_\_\_\_-ROTTDAM\_230\_31

FWD

Mon 10/10/2022 to Mon 10/31/2022  
0700 1530

(Import)

CENTRAL EAST - VC **1500 MW**  
Impacts Total Transfer Capability 1475 MW  
TTC with All Lines In Service 2975 MW

Work scheduled by:

HURLYAVE-ROSETON\_\_\_\_345\_303

FWD

Mon 10/24/2022 to Fri 11/04/2022  
0800 Continuous 1600

(Import)

10/04/2021

UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 3715 MW  
TTC with All Lines In Service 7815 MW

Work scheduled by: CHGE

GILBOA\_\_\_\_-N.SCTLND\_345\_GNS-1

FWD

Tue 11/01/2022 to Tue 12/06/2022  
0500 Continuous 1900

(Import)

UPDATED by NGRID 12/29/2021

CENTRAL EAST - VC **2520 MW**  
Impacts Total Transfer Capability 455 MW  
TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

LEEDS\_\_\_\_345KV\_R94301

FWD

Tue 11/01/2022 to Tue 12/06/2022  
0500 Continuous 1900

(Import)

UPDATED by NGRID 12/29/2021

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

MARCY\_\_\_\_-N.SCTLND\_345\_18

FWD

Tue 11/01/2022 to Tue 12/06/2022  
0500 Continuous 1900

(Import)

UPDATED by NGRID 12/29/2021

CENTRAL EAST - VC **1470 MW**  
Impacts Total Transfer Capability 1505 MW  
TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

ARR: 19

N.SCTLND-LEEDS\_\_\_\_345\_94

FWD

Tue 11/01/2022 to Tue 12/06/2022  
0500 Continuous 1900

(Import)

UPDATED by NGRID 12/29/2021

CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

PORTER\_\_\_\_-ROTTDAM\_230\_30 & MARCY\_\_\_\_-N.SCTLND\_345\_18

FWD

Tue 11/01/2022 to Tue 12/06/2022  
0500 1900

(Import)

CENTRAL EAST - VC **1300 MW**  
Impacts Total Transfer Capability 1675 MW  
TTC with All Lines In Service 2975 MW

Work scheduled by:

# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PORTER\_\_-ROTTRDAM\_230\_31 & MARCY\_\_-N.SCTLND\_345\_18

Tue 11/01/2022 to Tue 12/06/2022  
0500 1900

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **1300 MW**  
Impacts Total Transfer Capability 1675 MW  
TTC with All Lines In Service 2975 MW

## LEEDS\_\_-HURLYAVE\_345\_301

Mon 11/07/2022 to Fri 12/09/2022  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 3715 MW  
TTC with All Lines In Service 7815 MW

## MOSES\_\_-ADIRNDCK\_230\_MAl

Wed 11/30/2022 to Wed 03/01/2023  
0700 Continuous 1100

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## FRASER\_\_345\_FRASER SVC

Tue 01/03/2023 to Tue 02/28/2023 **UPDATED by NYPA 12/30/2021**  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2935 MW**  
Impacts Total Transfer Capability 40 MW  
TTC with All Lines In Service 2975 MW

## PLSNTVLY\_345KV\_RNS4

Sat 04/01/2023 to Sat 04/01/2023  
0700 Continuous 0730

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## ATHENS\_\_-PLSNTVLY\_345\_91

Sat 04/01/2023 to Sat 04/15/2023  
0700 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## PLSNTVLY\_345KV\_RNS4

Sat 04/15/2023 to Sat 04/15/2023  
1830 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 02, 2022 to Friday , August 04, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PLSNTVLY\_345KV\_RNS5

Sun 04/16/2023 to Sun 04/16/2023  
0700 Continuous 0730

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### LEEDS - PLSNTVLY\_345\_92

Sun 04/16/2023 to Sun 04/30/2023  
0700 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLY\_345KV\_RNS5

Sun 04/30/2023 to Sun 04/30/2023  
1830 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 05/01/2023 to Fri 05/05/2023  
0600 Continuous 1800

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW