

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Sun 07/31/2022 EXT FORCE by CONED 01/04/2022

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Sun 07/31/2022

0001 2359

Work scheduled by:

FWD REV  
(Import) (Export)

SCH - PJ - NY

2550 MW 1900 MW

Impacts Total Transfer Capability 300 MW 300 MW

TTC with All Lines In Service 2850 MW 2200 MW

## MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Sun 07/31/2022 EXT FORCE by CONED 01/04/2022

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## STLAWRNC-MOSES\_230\_L33P

Mon 04/30/2018 to Mon 07/25/2022 EXT FORCE by IESO 11/04/2021

0456 Continuous 0800

Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## NEWBRDGE\_345\_138\_BK\_1

Wed 09/02/2020 to Mon 08/01/2022 EXT FORCE by LI 12/10/2021

1807 Continuous 2359

Work scheduled by: LI

FWD  
(Import)

SCH - PJM\_NEPTUNE

375 MW

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

## SCH-IMO-NYISO\_LIMIT\_1750

Mon 11/01/2021 to Sat 04/30/2022 UPDATED by IESO 05/03/2019

0001 Continuous 2359

Work scheduled by: IESO

FWD  
(Import)

SCH - OH - NY

2050 MW

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 2300 MW

## SCH-NYISO-IMO\_LIMIT\_1600

Mon 11/01/2021 to Sat 04/30/2022 UPDATED by IESO 05/03/2019

0001 Continuous 2359

Work scheduled by: IESO

REV  
(Export)

SCH - OH - NY

1900 MW

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 2000 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>BECK___-NIAGARA__345_PA301</b>							
Wed 02/09/2022	to	Fri 06/17/2022	<u>UPDATED</u>	<u>by NYISO</u>	<u>03/22/2022</u>		
0700	Continuous	1700				SCH - OH - NY	<b>1100 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability	1050 MW
						TTC with All Lines In Service	2000 MW
<b>NIAGARA_-STA_255__345_NH2</b>						FWD	
Mon 02/21/2022	to	Tue 12/31/2030	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/04/2022</u>	(Import)	
0500	Continuous	1900				DYSINGER EAST	<b>1700 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1450 MW
						TTC with All Lines In Service	3150 MW
<b>MOSES___-ADIRNDCK_230_MA1</b>						FWD	
Mon 02/28/2022	to	Tue 05/31/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/16/2022</u>	(Import)	
0700	Continuous	1300				MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
<b>PORTER___-ROTTDAM_230_31</b>						FWD	
Tue 03/01/2022	to	Tue 12/31/2030				(Import)	
0600	Continuous	2359				CENTRAL EAST - VC	<b>2805 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	170 MW
						TTC with All Lines In Service	2975 MW
<b>FRASANNX-COOPERS__345_UCC2-41</b>						FWD	
Tue 03/01/2022	to	Thu 04/21/2022	<u>EXTENDED</u>	<u>by NYPA</u>	<u>04/13/2022</u>	(Import)	
0700	Continuous	1530				CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYPA				<b>ARR: 19</b>		Impacts Total Transfer Capability	475 MW
						TTC with All Lines In Service	2975 MW
<b>MARCY___-FRASANNX_345_UCC2-41</b>						FWD	
Tue 03/01/2022	to	Thu 04/21/2022	<u>EXTENDED</u>	<u>by NYPA</u>	<u>04/13/2022</u>	(Import)	
0700	Continuous	1530				CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYPA				<b>ARR: 19</b>		Impacts Total Transfer Capability	475 MW
						TTC with All Lines In Service	2975 MW
<b>N.SCTLND-LEEDS___345_93</b>						FWD	
Tue 03/08/2022	to	Tue 04/12/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/09/2022</u>	(Import)	
0700	Continuous	1900				CENTRAL EAST - VC	<b>2650 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	325 MW
						TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC____-N.SCTLND_345_14					FWD		
Tue 03/08/2022	to	Tue 05/10/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/09/2022</u>	(Import)	
0700	Continuous	1530					CENTRAL EAST - VC <b>1670 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 1305 MW		
					TTC with All Lines In Service 2975 MW		
EDIC____-N.SCTLND_345_14 & PORTER____-ROTTRDAM_230_31					FWD		
Tue 03/08/2022	to	Tue 05/10/2022					(Import)
0700		1530					CENTRAL EAST - VC <b>1500 MW</b>
Work scheduled by:					Impacts Total Transfer Capability 1475 MW		
					TTC with All Lines In Service 2975 MW		
N.SCTLND-ALPS____345_2					FWD		
Tue 03/08/2022	to	Fri 06/24/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/09/2022</u>	(Import)	
0700	Continuous	1900					SCH - NE - NY <b>900 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 500 MW		
					TTC with All Lines In Service 1400 MW		
N.SCTLND-ALPS____345_2					FWD		
Tue 03/08/2022	to	Fri 06/24/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/09/2022</u>	(Import)	REV (Export)
0700	Continuous	1900					SCH - NPX_1385 <b>100 MW 100 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 100 MW 100 MW		
					TTC with All Lines In Service 200 MW 200 MW		
EGRDNCTY_345_138_AT1					FWD		
Sat 03/12/2022	to	Sun 05/15/2022	<u>FORCED</u>	<u>by CE</u>	<u>03/13/2022</u>	(Import)	
2148	Continuous	2359					CONED - LIPA <b>1250 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 250 MW		
					TTC with All Lines In Service 1500 MW		
EGRDNCTY_345_138_AT2					FWD		
Sat 03/12/2022	to	Sun 05/15/2022	<u>FORCED</u>	<u>by CE</u>	<u>03/13/2022</u>	(Import)	
2148	Continuous	2359					CONED - LIPA <b>1250 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 250 MW		
					TTC with All Lines In Service 1500 MW		
SPRNBK_-EGRDNCTR_345_Y49					FWD		
Sat 03/12/2022	to	Sun 05/15/2022	<u>FORCED</u>	<u>by CE</u>	<u>03/13/2022</u>	(Import)	
2148	Continuous	2359					CONED - LIPA <b>775 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 725 MW		
					TTC with All Lines In Service 1500 MW		

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-HQ\_CEDARS-NYISO\_LIMIT\_240

FWD

Mon 03/14/2022 to Tue 04/12/2022

EXTENDEDby HQ04/07/2022

(Import)

0500 Continuous 1700

Work scheduled by: HQ

SCH - HQ\_CEDARS

240 MW

Impacts Total Transfer Capability 39 MW

TTC with All Lines In Service 279 MW

## SCH-NYISO-HQ\_CEDARS\_LIMIT\_0

REV

Mon 03/14/2022 to Tue 04/12/2022

EXTENDEDby HQ04/07/2022

(Export)

0500 Continuous 1700

Work scheduled by: HQ

SCH - HQ\_CEDARS

0 MW

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 100 MW

## GOETHALS\_345KV\_5

Sat 03/19/2022 to Wed 04/20/2022

UPDATEDby CE04/01/2022

0001 Continuous 0300

Work scheduled by: ConEd

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

## W49TH\_ST\_345KV\_6

FWD

Mon 03/21/2022 to Sat 04/30/2022

EXT FORCEby CE04/04/2022

(Import)

0809 Continuous 2359

Work scheduled by: ConEd

SCH - PJM\_HTP

310 MW

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 660 MW

## W49TH\_ST\_345KV\_8

FWD

Mon 03/21/2022 to Sat 04/30/2022

EXT FORCEby CE04/04/2022

(Import)

0811 Continuous 2359

Work scheduled by: ConEd

SCH - PJM\_HTP

310 MW

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 660 MW

## SCH-IMO-NYISO\_LIMIT\_700

FWD

Fri 03/25/2022 to Sat 04/30/2022

UPDATEDby NYISO03/22/2022

(Import)

0001 Continuous 2359

Work scheduled by: IESO

SCH - OH - NY

1000 MW

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 2300 MW

## SCH-IMO-NYISO\_LIMIT\_400

FWD

Fri 03/25/2022 to Sat 04/30/2022

UPDATEDby NYISO03/22/2022

(Import)

2300 Daily 0500

Work scheduled by: NYISO

SCH - OH - NY

700 MW

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 2300 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## FIVEMILE-STOLLERD\_345\_29

Fri 04/01/2022 to Tue 12/31/2030 EXTENDED by NYSEG 04/06/2022

0500 Continuous 2359

Work scheduled by: NYSEG

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## N.SCTLND-ALPS\_345\_2 & NRTH1385-NOR HBR\_138\_601

Mon 04/04/2022 to Thu 04/14/2022

0001 1919

Work scheduled by:

FWD REV

(Import) (Export)

SCH - NPX\_1385

0 MW 0 MW

Impacts Total Transfer Capability 200 MW 200 MW

TTC with All Lines In Service 200 MW 200 MW

## NRTH1385-NOR HBR\_138\_601

Mon 04/04/2022 to Thu 04/14/2022

0001 Continuous 1919

Work scheduled by: LI

FWD REV

(Import) (Export)

SCH - NPX\_1385

100 MW 100 MW

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

## NRTH1385-NOR HBR\_138\_601 & NRTH1385-NOR HBR\_138\_602

Mon 04/04/2022 to Thu 04/14/2022

0001 1919

Work scheduled by:

FWD REV

(Import) (Export)

SCH - NPX\_1385

0 MW 0 MW

Impacts Total Transfer Capability 200 MW 200 MW

TTC with All Lines In Service 200 MW 200 MW

## NRTH1385-NOR HBR\_138\_601 & NRTH1385-NOR HBR\_138\_603

Mon 04/04/2022 to Thu 04/14/2022

0001 1919

Work scheduled by:

FWD REV

(Import) (Export)

SCH - NPX\_1385

0 MW 0 MW

Impacts Total Transfer Capability 200 MW 200 MW

TTC with All Lines In Service 200 MW 200 MW

## NRTH1385-NRTHPORT\_138\_NNC

Mon 04/04/2022 to Thu 04/14/2022

0001 Continuous 1919

Work scheduled by: LI

FWD REV

(Import) (Export)

SCH - NPX\_1385

0 MW 0 MW

Impacts Total Transfer Capability 200 MW 200 MW

TTC with All Lines In Service 200 MW 200 MW

## N.SCTLND-ALPS\_345\_2 & NRTH1385-NOR HBR\_138\_602

Mon 04/04/2022 to Thu 04/14/2022

0001 1923

Work scheduled by:

FWD REV

(Import) (Export)

SCH - NPX\_1385

0 MW 0 MW

Impacts Total Transfer Capability 200 MW 200 MW

TTC with All Lines In Service 200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_602					FWD	REV
Mon 04/04/2022	to	Thu 04/14/2022	<u>UPDATED</u>	<u>by ISONE</u> <u>04/02/2022</u>	(Import)	(Export)
0001	Continuous	1923			SCH - NPX_1385	100 MW
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603					FWD	REV
Mon 04/04/2022	to	Thu 04/14/2022			(Import)	(Export)
0001		1923			SCH - NPX_1385	0 MW
Work scheduled by:					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	200 MW
N.SCTLND-ALPS____345_2 & NRTH1385-NOR HBR__138_603					FWD	REV
Mon 04/04/2022	to	Thu 04/14/2022			(Import)	(Export)
0001		1926			SCH - NPX_1385	0 MW
Work scheduled by:					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_603					FWD	REV
Mon 04/04/2022	to	Thu 04/14/2022	<u>UPDATED</u>	<u>by ISONE</u> <u>04/02/2022</u>	(Import)	(Export)
0001	Continuous	1926			SCH - NPX_1385	100 MW
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
SCH-NYISO-NE_LIMIT_1300						REV
Mon 04/04/2022	to	Fri 04/15/2022	<u>UPDATED</u>	<u>by ISONE</u> <u>04/02/2022</u>		(Export)
0001	Continuous	1600			SCH - NE - NY	1500 MW
Work scheduled by: LI					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	1800 MW
MILLWOOD-EASTVIEW_345_W99					FWD	
Mon 04/11/2022	to	Fri 04/15/2022	<u>UPDATED</u>	<u>by CONED</u> <u>04/07/2022</u>	(Import)	
0301	Continuous	1716			UPNY CONED	7550 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	265 MW
					TTC with All Lines In Service	7815 MW
FROST_BR-SOUTHNGT_345_329 & NRTH1385-NOR HBR__138_601					FWD	REV
Mon 04/11/2022	to	Thu 04/14/2022			(Import)	(Export)
0600		1919			SCH - NPX_1385	0 MW
Work scheduled by:					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	200 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## FROST\_BR-SOUTHNGT\_345\_329 & NRTH1385-NOR HBR\_138\_602

Mon 04/11/2022 to Thu 04/14/2022  
0600 1923

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

## FROST\_BR-SOUTHNGT\_345\_329 & NRTH1385-NOR HBR\_138\_603

Mon 04/11/2022 to Thu 04/14/2022  
0600 1926

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

## PANNELL\_-CLAY\_345\_1

Mon 04/11/2022 to Fri 04/15/2022  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
WEST CENTRAL	1300 MW
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	2250 MW

## SCH-NE-NYISO\_LIMIT\_300

Tue 04/12/2022 to Fri 04/15/2022  
1800 Continuous 1559

Work scheduled by: ISONE

**UPDATED by ISONE 04/08/2022**

	FWD
	(Import)
SCH - NE - NY	500 MW
Impacts Total Transfer Capability	900 MW
TTC with All Lines In Service	1400 MW

## WATRCURE-OAKDALE\_345\_31

Wed 04/13/2022 to Wed 04/13/2022  
0800 Continuous 1500

Work scheduled by: NYSEG

SCH - PJ - NY	
Impacts Total Transfer Capability	
TTC with All Lines In Service	

## EASTVIEW-SPRNBK\_345\_W64

Thu 04/14/2022 to Thu 04/14/2022  
0300 Continuous 0600

Work scheduled by: ConEd

**CANCELLED by ConEd 04/14/2022**

	FWD
	(Import)
UPNY CONED	4350 MW
Impacts Total Transfer Capability	3465 MW
TTC with All Lines In Service	7815 MW

## OSWEGO\_-VOLNEY\_345\_11

Sat 04/16/2022 to Sat 04/16/2022  
0630 Daily 1700

Work scheduled by: NGrid

	FWD
	(Import)
OSWEGO EXPORT	5250 MW
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	5250 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PLSNTVLY-WOOD\_ST\_\_345\_F31

FWD

Mon 04/18/2022 to Tue 04/19/2022 UPDATED by CONED 04/07/2022

(Import)

0001 Continuous 2200

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### ATHENS\_\_-PLSNTVLY\_345\_91

FWD

Mon 04/18/2022 to Sun 05/15/2022 UPDATED by CE 04/07/2022

(Import)

0001 Continuous 2200

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### PLSNTVLY\_345KV\_RNS4

FWD

Mon 04/18/2022 to Sun 05/15/2022 UPDATED by CE 04/07/2022

(Import)

0001 Continuous 2200

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### W49TH\_ST\_345KV\_7

FWD

Mon 04/18/2022 to Mon 04/18/2022

(Import)

0600 Continuous 0630

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

### SCH-NE-NYISO\_LIMIT\_800

FWD

Mon 04/18/2022 to Mon 04/18/2022

(Import)

0600 Continuous 0659

SCH - NE - NY

**1000 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

### HUDSONTP-W49TH\_ST\_345\_Y56

FWD

Mon 04/18/2022 to Fri 04/22/2022

(Import)

0600 Continuous 1900

SCH - PJM\_HTP

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

### SCH-NE-NYISO\_LIMIT\_900

FWD

Mon 04/18/2022 to Thu 04/21/2022

(Import)

0700 Continuous 2259

SCH - NE - NY

**1100 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE



# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>PANNELL_-CLAY_____345_2</b>				FWD	
Mon 04/18/2022	to	Fri 04/22/2022		(Import)	
0700	Continuous	1530		WEST CENTRAL	<b>1300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	950 MW
				TTC with All Lines In Service	2250 MW
<b>SCH-NE-NYISO_LIMIT_800</b>				FWD	
Mon 04/18/2022	to	Fri 04/22/2022		(Import)	
2300	Continuous	0659		SCH - NE - NY	<b>1000 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	1400 MW
<b>SCH-NE-NYISO_LIMIT_300</b>				FWD	
Tue 04/19/2022	to	Fri 04/22/2022		(Import)	
0601	Continuous	0759		SCH - NE - NY	<b>500 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability	900 MW
				TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_1300</b>				REV	
Tue 04/19/2022	to	Fri 04/22/2022		(Export)	
0601	Continuous	0759		SCH - NE - NY	<b>1500 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	1800 MW
<b>SAND_BAR-PLATSBURG_115_PV20</b>					
Tue 04/19/2022	to	Tue 04/26/2022	<b>UPDATED by NYPA 04/13/2022</b>	SCH - NE - NY	
0700	Continuous	1730		Impacts Total Transfer Capability	
Work scheduled by: NYPA				TTC with All Lines In Service	
<b>CHAT_DC_GC1</b>				FWD	
Tue 04/19/2022	to	Wed 04/20/2022		(Import)	
2200	Continuous	0300		MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC1</b>				REV	
Tue 04/19/2022	to	Wed 04/20/2022		(Export)	
2200	Continuous	0300		SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	1000 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 7815MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Tue 04/19/2022 to Wed 04/20/2022  
2200 0300

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **2550 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Tue 04/19/2022 to Wed 04/20/2022  
2200 0300

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY **1370 MW 0 MW**  
Impacts Total Transfer Capability 130 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

## CHAT\_DC\_GC2

Tue 04/19/2022 to Wed 04/20/2022  
2200 Continuous 0300

Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC2

Tue 04/19/2022 to Wed 04/20/2022  
2200 Continuous 0300

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

## SCH-HQ-NYISO\_LIMIT\_1150

Tue 04/19/2022 to Wed 04/20/2022  
2200 Continuous 0300

Work scheduled by: HQ

FWD  
(Import)  
SCH - HQ - NY **1150 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 1500 MW

## PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Wed 04/20/2022 to Fri 04/22/2022  
0001 2200

Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## SCH-NE-NYISO\_LIMIT\_200

Wed 04/20/2022 to Fri 04/22/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
SCH - NE - NY **400 MW**  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 1400 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## GOETHALS\_345KV\_5

Wed 04/20/2022 to Fri 05/20/2022

0301 Continuous 0300

Work scheduled by: ConEd

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

## LINDEN\_\_GOETHALS\_230\_A2253

Wed 04/20/2022 to Fri 05/20/2022

0301 Continuous 0300

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## LINDEN\_\_GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402

Wed 04/20/2022 to Fri 05/20/2022

0301 0300

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2550 MW</b>	<b>1900 MW</b>
Impacts Total Transfer Capability	300 MW	300 MW
TTC with All Lines In Service	2850 MW	2200 MW

## LINDEN\_\_GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_\_-FARRAGUT\_345\_C3403

Wed 04/20/2022 to Fri 05/20/2022

0301 0300

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2550 MW</b>	<b>1900 MW</b>
Impacts Total Transfer Capability	300 MW	300 MW
TTC with All Lines In Service	2850 MW	2200 MW

## LINDEN\_\_GOETHALS\_230\_A2253 & MARION\_\_-FARRAGUT\_345\_C3403

Wed 04/20/2022 to Fri 05/20/2022

0301 0300

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2550 MW</b>	<b>1900 MW</b>
Impacts Total Transfer Capability	300 MW	300 MW
TTC with All Lines In Service	2850 MW	2200 MW

## SCH-NE-NYISO\_LIMIT\_900

Fri 04/22/2022 to Fri 04/22/2022

0700 Continuous 1800

Work scheduled by: ISONE

	FWD
	(Import)
SCH - NE - NY	<b>1100 MW</b>
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	1400 MW

## MARCY\_\_\_\_345KV\_CSC

Fri 04/22/2022 to Sat 04/23/2022

0700 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2925 MW</b>
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## EDIC\_\_\_\_-FRASER\_\_\_\_345\_EF24-40

Fri 04/22/2022 to Tue 06/14/2022  
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NJYPA 04/13/2022

CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

FWD  
(Import)

## SCH-NE-NYISO\_LIMIT\_300

Fri 04/22/2022 to Sun 04/24/2022  
1601 Continuous 1800

Work scheduled by: ISONE

SCH - NE - NY **500 MW**  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 1400 MW

FWD  
(Import)

## SCH-NYISO-NE\_LIMIT\_1300

Fri 04/22/2022 to Sun 04/24/2022  
1601 Continuous 1800

Work scheduled by: ISONE

SCH - NE - NY **1500 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 1800 MW

REV  
(Export)

## W49TH\_ST\_345KV\_7

Fri 04/22/2022 to Fri 04/22/2022  
1830 Continuous 1900

Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

FWD  
(Import)

## BUCHAN\_N-EASTVIEW\_345\_W93

Mon 04/25/2022 to Mon 04/25/2022  
0001 Continuous 0030

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

FWD  
(Import)

## RAMAPO\_\_-BUCHAN\_N\_345\_Y94

Mon 04/25/2022 to Mon 04/25/2022  
0001 Continuous 0030

Work scheduled by: ConEd

UPNY CONED **7580 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 7815 MW

FWD  
(Import)

## ROCHESTR-PANNELL\_\_345\_RP1

Mon 04/25/2022 to Fri 04/29/2022  
0500 Continuous 1700

Work scheduled by: NYPA

DYSINGER EAST **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

FWD  
(Import)

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DYSINGER-STA\_255\_\_345\_DH1**

FWD

Mon 04/25/2022 to Sat 04/30/2022

(Import)

0600 Continuous 1800

DYSINGER EAST

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NT

**NIAGARA\_-STA\_255\_\_345\_NH2 & DYSINGER-STA\_255\_\_345\_DH1**

FWD

Mon 04/25/2022 to Sat 04/30/2022

(Import)

0600 1800

DYSINGER EAST

**1250 MW**

Impacts Total Transfer Capability 1900 MW

TTC with All Lines In Service 3150 MW

Work scheduled by:

**SAND\_BAR-PLATSBURG\_115\_PV20**

Mon 04/25/2022 to Fri 04/29/2022

**CANCELLED by NYPA 04/12/2022**

0700 Continuous 1530

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYPA

**SCH-NYISO-NE\_LIMIT\_1500**

REV

Mon 04/25/2022 to Fri 04/29/2022

**CANCELLED by NYPA 04/12/2022**

(Export)

0700 Continuous 1530

SCH - NE - NY

**1700 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 1800 MW

Work scheduled by: NYPA

**SCH-NE-NYISO\_LIMIT\_700**

FWD

Tue 04/26/2022 to Sat 04/30/2022

(Import)

0801 Continuous 0800

SCH - NE - NY

**900 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

**SCH-NYISO-HQ\_LIMIT\_800**

REV

Wed 04/27/2022 to Thu 04/28/2022

(Export)

0500 Continuous 1900

SCH - HQ - NY

**800 MW**

Impacts Total Transfer Capability 200 MW

TTC with All Lines In Service 1000 MW

Work scheduled by: HQ

**NIAGARA\_\_345\_230\_AT4**

REV

Fri 04/29/2022 to Fri 04/29/2022

(Export)

0500 Continuous 1700

SCH - OH - NY

**1750 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 2000 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-IMO-NYISO\_LIMIT\_400

FWD

Sat 04/30/2022 to Sat 04/30/2022  
2300 Daily 2359

UPDATED

by NYISO 03/22/2022

(Import)

Work scheduled by: NYISO

SCH - OH - NY **700 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 2300 MW

### BUCHAN\_N-EASTVIEW\_345\_W93

FWD

Mon 05/02/2022 to Mon 05/02/2022  
0130 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

### RAMAPO\_\_-BUCHAN\_N\_345\_Y94

FWD

Mon 05/02/2022 to Mon 05/02/2022  
0130 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **7580 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 7815 MW

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_220

FWD

Mon 05/02/2022 to Fri 05/20/2022  
0200 Continuous 0200

(Import)

Work scheduled by: HQ

SCH - HQ\_CEDARS **220 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 270 MW

### ROCHESTR-PANNELL\_\_345\_RP2

FWD

Mon 05/02/2022 to Fri 05/06/2022  
0500 Continuous 1700

(Import)

Work scheduled by: NYPA

DYSINGER EAST **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### BUCHAN\_N-EASTVIEW\_345\_W93

FWD

Tue 05/03/2022 to Tue 05/03/2022  
0001 Continuous 0030

(Import)

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

### EASTVIEW-SPRNBK\_\_345\_W79

FWD

Tue 05/03/2022 to Fri 05/06/2022  
0001 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHATGUAY-MASSENA\_\_765\_7040

Tue 05/03/2022 to Fri 05/06/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

### CHATGUAY-MASSENA\_\_765\_7040

Tue 05/03/2022 to Fri 05/06/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - HQ - NY **0 MW 0 MW**  
Impacts Total Transfer Capability 1500 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

### LEEDS\_\_\_\_345KV\_R395

Tue 05/03/2022 to Tue 05/03/2022  
0830 Daily(No Weekends) 1100

Work scheduled by: NGrid

UPDATED by NGRID 04/14/2022

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### BUCHAN\_N-EASTVIEW\_345\_W93

Fri 05/06/2022 to Fri 05/06/2022  
0130 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Sat 05/07/2022 to Tue 05/10/2022  
0001 2200

Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### SPRNBK\_-TREMONT\_\_345\_X28

Sun 05/08/2022 to Wed 05/11/2022  
0201 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 04/13/2022

FWD  
(Import)  
SPR/DUN-SOUTH **4200 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

### E13THSTA-FARRAGUT\_345\_46

Mon 05/09/2022 to Tue 05/24/2022  
0301 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 03/29/2022

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

S.PERRY\_-MEYER\_\_\_230\_87 & NIAGARA\_-STA\_255\_\_\_345\_NH2

FWD

Mon 05/09/2022 to Mon 05/09/2022  
0700 1400

DYSINGER EAST **1200 MW**  
Impacts Total Transfer Capability 1950 MW  
TTC with All Lines In Service 3150 MW

Work scheduled by:

WETHSRFD-S.PERRY\_\_\_230\_85 & NIAGARA\_-STA\_255\_\_\_345\_NH2

FWD

Mon 05/09/2022 to Mon 05/09/2022  
0700 1400

DYSINGER EAST **1200 MW**  
Impacts Total Transfer Capability 1950 MW  
TTC with All Lines In Service 3150 MW

Work scheduled by:

FRASER\_\_\_345\_FRASER SVC

FWD

Mon 05/09/2022 to Fri 05/13/2022  
0800 Continuous 1700

CENTRAL EAST - VC **2935 MW**  
Impacts Total Transfer Capability 40 MW  
TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

RAMAPO\_-LADENTWN\_345\_W72

FWD

Tue 05/10/2022 to Wed 05/11/2022  
0700 Continuous 1900

**UPDATED by CE 02/23/2022**

UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 3415 MW  
TTC with All Lines In Service 7815 MW

Work scheduled by: ORU

PLSNTVLY-WOOD\_ST\_\_\_345\_F31

FWD

Wed 05/11/2022 to Fri 05/13/2022  
0001 Continuous 2200

**UPDATED by CONED 04/07/2022**

UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

PORTER\_-ROTTRDAM\_230\_30

FWD

Wed 05/11/2022 to Tue 12/31/2030  
0600 Continuous 2359

**UPDATED by NGRID 03/09/2022**

CENTRAL EAST - VC **2805 MW**  
Impacts Total Transfer Capability 170 MW  
TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

PORTER\_-ROTTRDAM\_230\_30 & PORTER\_-ROTTRDAM\_230\_31

FWD

Wed 05/11/2022 to Tue 12/31/2030  
0600 2359

CENTRAL EAST - VC **2635 MW**  
Impacts Total Transfer Capability 340 MW  
TTC with All Lines In Service 2975 MW

Work scheduled by:



# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PLSNTVLE-DUNWODIE\_345\_W89

Fri 05/13/2022 to Fri 05/13/2022  
0200 Continuous 0230  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

### EFISHKIL-WOOD\_ST\_\_345\_F38

Fri 05/13/2022 to Fri 05/13/2022  
0200 Continuous 0430  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

### WOOD\_ST\_-PLSNTVLE\_345\_Y86

Fri 05/13/2022 to Fri 05/13/2022  
0200 Continuous 0430  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7210 MW**  
Impacts Total Transfer Capability 605 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLE-DUNWODIE\_345\_W89

Fri 05/13/2022 to Fri 05/13/2022  
0400 Continuous 0430  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 05/16/2022 to Sat 05/21/2022 **UPDATED by LI 02/10/2022**  
0600 Continuous 2000  
Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_CSC **0 MW 0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

### HOMR\_NYW-PIERC\_NY\_345\_48

Mon 05/16/2022 to Fri 05/20/2022  
0800 Continuous 1500  
Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### HOPATCON-RAMAPO\_\_500\_5018

Wed 05/18/2022 to Sun 05/22/2022  
0200 Continuous 2300  
Work scheduled by: PJM

FWD REV  
(Import) (Export)  
SCH - PJ - NY **1100 MW 1000 MW**  
Impacts Total Transfer Capability 1150 MW 250 MW  
TTC with All Lines In Service 2250 MW 1250 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HOPATCON-RAMAPO\_\_\_500\_5018

Wed 05/18/2022 to Sun 05/22/2022  
0200 Continuous 2300

Work scheduled by: PJM

FWD

(Import)

UPNY CONED **7480 MW**

Impacts Total Transfer Capability 335 MW

TTC with All Lines In Service 7815 MW

## RAMAPO\_\_\_345\_345\_PAR3500

Wed 05/18/2022 to Sun 05/22/2022  
0200 Continuous 2300

Work scheduled by: PJM

FWD

(Import)

SCH - PJ - NY **1750 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 2250 MW

## RAMAPO\_\_\_345\_345\_PAR4500

Wed 05/18/2022 to Sun 05/22/2022  
0200 Continuous 2300

Work scheduled by: PJM

FWD

(Import)

SCH - PJ - NY **1750 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 2250 MW

## RAMAPO\_\_\_500\_345\_BK 1500

Wed 05/18/2022 to Sun 05/22/2022  
0200 Continuous 2300

Work scheduled by: PJM

FWD

REV

(Import) (Export)

SCH - PJ - NY **1100 MW 1000 MW**

Impacts Total Transfer Capability 1150 MW 250 MW

TTC with All Lines In Service 2250 MW 1250 MW

## RAMAPO\_\_\_500\_345\_BK 1500

Wed 05/18/2022 to Sun 05/22/2022  
0200 Continuous 2300

Work scheduled by: PJM

FWD

(Import)

UPNY CONED **7480 MW**

Impacts Total Transfer Capability 335 MW

TTC with All Lines In Service 7815 MW

## DUNWODIE-MOTTHAVN\_345\_71

Thu 05/19/2022 to Fri 05/20/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

## DUNWODIE\_345KV\_3

Thu 05/19/2022 to Fri 05/20/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_5

FWD

Thu 05/19/2022 to Fri 05/20/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### MOTTHAVN-RAINEY\_345\_Q11

FWD

Sat 05/21/2022 to Tue 05/24/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### MARCY\_-EDIC\_345\_UE1-7

FWD

Sat 05/21/2022 to Sun 05/22/2022

(Import)

0500 Continuous 1730

UPDATED

by NYPA 04/07/2022

OSWEGO EXPORT

5250 MW

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

ARR: 19&16

### PORTER\_-ROTTRDAM\_230\_30 & VOLNEY\_-MARCY\_345\_19

FWD

Sat 05/21/2022 to Sun 05/22/2022

(Import)

0500 1730

CENTRAL EAST - VC

2655 MW

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

### PORTER\_-ROTTRDAM\_230\_31 & VOLNEY\_-MARCY\_345\_19

FWD

Sat 05/21/2022 to Sun 05/22/2022

(Import)

0500 1730

CENTRAL EAST - VC

2655 MW

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

### VOLNEY\_-MARCY\_345\_19

FWD

Sat 05/21/2022 to Sun 05/22/2022

(Import)

0500 Continuous 1730

UPDATED

by NYPA 04/07/2022

CENTRAL EAST - VC

2825 MW

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

ARR: 19

### VOLNEY\_-MARCY\_345\_19

FWD

Sat 05/21/2022 to Sun 05/22/2022

(Import)

0500 Continuous 1730

UPDATED

by NYPA 04/07/2022

OSWEGO EXPORT

4900 MW

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

ARR: 19

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CRICKVLY-PLSNTVLY\_345\_F84**

Mon 05/23/2022 to Fri 05/27/2022  
0001 Continuous 2200

UPDATEDby CE04/06/2022

Work scheduled by: ConEd

FWD  
(Import)  
**350 MW**  
SCH - NE - NY  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 1400 MW

**CRICKVLY-PLSNTVLY\_345\_F84**

Mon 05/23/2022 to Fri 05/27/2022  
0001 Continuous 2200

UPDATEDby CE04/06/2022

Work scheduled by: ConEd

FWD REV  
(Import) (Export)  
**100 MW 100 MW**  
SCH - NPX\_1385  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

**DUNWODIE-SHORE\_RD\_345\_Y50**

Mon 05/23/2022 to Sun 05/29/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
**800 MW**  
CONED - LIPA  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1500 MW

**DUNWODIE\_345KV\_4**

Mon 05/23/2022 to Sun 05/29/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
**3800 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_6**

Mon 05/23/2022 to Sun 05/29/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
**3800 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**SHORE\_RD\_345\_138\_BK 1**

Mon 05/23/2022 to Sun 05/29/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
**1350 MW**  
CONED - LIPA  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

**SHORE\_RD\_345\_138\_BK 2**

Mon 05/23/2022 to Sun 05/29/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
**1350 MW**  
CONED - LIPA  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOTTHAVN-RAINEY\_\_\_345\_Q12

Tue 05/24/2022 to Sat 05/28/2022  
0201 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## BUCHAN\_S-MILLWOOD\_345\_W97

Fri 05/27/2022 to Sat 05/28/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7680 MW**  
Impacts Total Transfer Capability 135 MW  
TTC with All Lines In Service 7815 MW

## MARCY\_\_\_-EDIC\_\_\_345\_UE1-7

Sat 05/28/2022 to Sun 05/29/2022  
0600 Continuous 1830

Work scheduled by: NYPA

ARR: 19&amp;16

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

## DUNWODIE\_345KV\_3

Sun 05/29/2022 to Sun 05/29/2022 UPDATED by CE 04/12/2022  
0201 Continuous 1800

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## DUNWODIE\_345KV\_4

Sun 05/29/2022 to Sun 05/29/2022 UPDATED by CE 04/12/2022  
0201 Continuous 1800

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## PLSNTVLE-DUNWODIE\_345\_W89

Sun 05/29/2022 to Sun 05/29/2022 UPDATED by CE 04/12/2022  
0201 Continuous 1800

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

## PIERCBRK-FIVEMILE\_345\_37

Tue 05/31/2022 to Wed 06/01/2022  
0730 Continuous 1600

Work scheduled by: NGrid

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NE-NYISO\_LIMIT\_300

FWD

Wed 06/01/2022 to Wed 06/08/2022 UPDATED by ISONE 03/04/2022

(Import)

0700 Continuous 1600

Work scheduled by: ISONE

SCH - NE - NY

500 MW

Impacts Total Transfer Capability 900 MW

TTC with All Lines In Service 1400 MW

## SCH-NYISO-NE\_LIMIT\_900

REV

Wed 06/01/2022 to Wed 06/08/2022 UPDATED by ISONE 03/04/2022

(Export)

0700 Continuous 1600

Work scheduled by: ISONE

SCH - NE - NY

1100 MW

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1600 MW

## MOSES\_\_-ADIRNDCK\_230\_MA2

FWD

Wed 06/01/2022 to Tue 11/29/2022

(Import)

0700 Continuous 1800

Work scheduled by: NYPA

MOSES SOUTH

2100 MW

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

## FROST\_BR-LONG\_MTN\_345\_352

FWD

Thu 06/09/2022 to Sat 06/18/2022 UPDATED by ISONE 03/04/2022

(Import)

0700 Continuous 1600

Work scheduled by: ISONE

SCH - NE - NY

1150 MW

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1400 MW

## SCH-NE-NYISO\_LIMIT\_200

FWD

Thu 06/09/2022 to Sat 06/18/2022 UPDATED by ISONE 03/04/2022

(Import)

0700 Continuous 1600

Work scheduled by: ISONE

SCH - NE - NY

400 MW

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 1400 MW

## NIAGARA\_-DYSINGER\_345\_ND1

FWD

Mon 06/13/2022 to Fri 06/17/2022

(Import)

0500 Continuous 2100

Work scheduled by: NYPA

DYSINGER EAST

2700 MW

Impacts Total Transfer Capability 450 MW

TTC with All Lines In Service 3150 MW

## OAKDALE\_-FRASER\_\_345\_32

FWD

Wed 06/15/2022 to Fri 06/17/2022

(Import)

0800 Continuous 1600

Work scheduled by: NYSEG

CENTRAL EAST - VC

2650 MW

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NIAGARA\_\_PACKARD\_\_230\_62

Sat 06/18/2022 to Fri 06/24/2022  
0500 Continuous 1700

UPDATED by NYPA 03/02/2022

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>700 MW</b>	<b>1550 MW</b>
Impacts Total Transfer Capability	1250 MW	150 MW
TTC with All Lines In Service	1950 MW	1700 MW

### MARCY\_\_EDIC\_\_345\_UE1-7

Sat 06/18/2022 to Sun 06/19/2022  
0600 Continuous 1830

Work scheduled by: NYPA

**ARR: 19&16**

	FWD
	(Import)
OSWEGO EXPORT	<b>5250 MW</b>
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	5250 MW

### FRASER\_\_GILBOA\_\_345\_GF5-35

Tue 06/21/2022 to Sun 06/26/2022  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2650 MW</b>
Impacts Total Transfer Capability	325 MW
TTC with All Lines In Service	2975 MW

### BEAR SWP-EASTOVER\_230\_E205W

Mon 06/27/2022 to Tue 06/28/2022  
0700 Continuous 0759

Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

### CLRKSCRN-OAKDALE\_\_345\_36

Mon 06/27/2022 to Fri 07/01/2022  
0830 Continuous 1530

Work scheduled by: NYSEG

	FWD
	(Import)
CENTRAL EAST - VC	<b>2650 MW</b>
Impacts Total Transfer Capability	325 MW
TTC with All Lines In Service	2975 MW

### NIAGARA\_\_345\_230\_AT4

Tue 06/28/2022 to Wed 06/29/2022  
0500 Continuous 1700

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1900 MW</b>	<b>1400 MW</b>
Impacts Total Transfer Capability	50 MW	300 MW
TTC with All Lines In Service	1950 MW	1700 MW

### BEAR SWP-EASTOVER\_230\_E205W

Tue 06/28/2022 to Tue 06/28/2022  
0800 Daily(No Weekends) 1500

Work scheduled by: NGrid

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## BEAR SWP-EASTOVER\_230\_E205W

Tue 06/28/2022 to Thu 06/30/2022

1501 Continuous 1700

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## BECK -NIAGARA\_230\_PA27

Tue 07/05/2022 to Sat 07/09/2022

0500 Continuous 2100

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## NIAGARA -DYSINGER\_345\_ND1

Mon 07/11/2022 to Fri 07/15/2022

0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

**2700 MW**

Impacts Total Transfer Capability 450 MW

TTC with All Lines In Service 3150 MW

## HURLYAVE-ROSETON\_345\_303

Mon 07/11/2022 to Fri 07/22/2022

0800 Continuous 1600

Work scheduled by: CHGE

02/14/2022

FWD

(Import)

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

## ROCHESTR-PANNELL\_345\_RP1

Mon 07/25/2022 to Fri 07/29/2022

0500 Continuous 2100

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## FRASANX-COOPERS\_345\_UCC2-41

Mon 07/25/2022 to Fri 08/05/2022

0700 Continuous 1700

Work scheduled by: NYPA

**ARR: 19**

FWD

(Import)

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

## MARCY -FRASANX\_345\_UCC2-41

Mon 07/25/2022 to Fri 08/05/2022

0700 Continuous 1700

Work scheduled by: NYPA

**ARR: 19**

FWD

(Import)

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW



# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_-DYSINGER\_345\_ND2

FWD

Mon 08/01/2022 to Fri 08/05/2022  
0500 Continuous 1700

Work scheduled by: NYPA

DYSINGER EAST **2700 MW**  
Impacts Total Transfer Capability 450 MW  
TTC with All Lines In Service 3150 MW

## MARCY\_-EDIC\_345\_UE1-7

FWD

Sat 08/06/2022 to Sun 08/07/2022 UPDATED by NYPA 04/07/2022  
0500 Continuous 1830

Work scheduled by: NYPA

ARR: 19&amp;16

OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

## PORTER\_-ROTTRDAM\_230\_30 & VOLNEY\_-MARCY\_345\_19

FWD

Sat 08/06/2022 to Sun 08/07/2022  
0500 1830

Work scheduled by:

CENTRAL EAST - VC **2655 MW**  
Impacts Total Transfer Capability 320 MW  
TTC with All Lines In Service 2975 MW

## PORTER\_-ROTTRDAM\_230\_31 & VOLNEY\_-MARCY\_345\_19

FWD

Sat 08/06/2022 to Sun 08/07/2022  
0500 1830

Work scheduled by:

CENTRAL EAST - VC **2655 MW**  
Impacts Total Transfer Capability 320 MW  
TTC with All Lines In Service 2975 MW

## VOLNEY\_-MARCY\_345\_19

FWD

Sat 08/06/2022 to Sun 08/07/2022 UPDATED by NYPA 04/07/2022  
0500 Continuous 1830

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC **2825 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 2975 MW

## VOLNEY\_-MARCY\_345\_19

FWD

Sat 08/06/2022 to Sun 08/07/2022 UPDATED by NYPA 04/07/2022  
0500 Continuous 1830

Work scheduled by: NYPA

ARR: 19

OSWEGO EXPORT **4900 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 5250 MW

## FRASANNX-COOPERS\_345\_UCC2-41

FWD

Mon 08/08/2022 to Fri 09/09/2022  
0700 Continuous 1700

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MARCY\_\_\_-FRASANNX\_345\_UCC2-41

FWD

Mon 08/08/2022 to Fri 09/09/2022

(Import)

0700 Continuous 1700

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 19**

## SAND\_BAR-PLATSBRG\_115\_PV20

Mon 08/22/2022 to Fri 08/26/2022

0700 Continuous 1530

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYPA

## ROSETON\_-ROCKTVRN\_345\_311

FWD

Mon 08/29/2022 to Fri 09/09/2022

(Import)

0800 Continuous 1600

UPNY CONED

**4400 MW**

Impacts Total Transfer Capability 3415 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: CHGE

## MOTTHAVN-RAINEY\_\_\_345\_Q12

FWD

Thu 09/01/2022 to Mon 09/05/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## FRASER\_\_\_-GILBOA\_\_\_345\_GF5-35

FWD

Mon 09/12/2022 to Sun 09/18/2022

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

## MARCY\_\_\_-EDIC\_\_\_345\_UE1-7

FWD

Mon 09/19/2022 to Sat 10/08/2022

(Import)

0700 Continuous 1530

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19&16**

## LEEDS\_\_\_-HURLYAVE\_345\_301

FWD

Mon 09/19/2022 to Fri 10/21/2022

(Import)

0800 Continuous 1600

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: CHGE

**10/04/2021**

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EGRDNCTY_345_138_AT1</b>						FWD	
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED</u>	<u>by CONED</u>	<u>03/10/2022</u>	(Import)	
0001	Continuous	2359				CONED - LIPA	<b>1250 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	250 MW
						TTC with All Lines In Service	1500 MW
<b>EGRDNCTY_345_138_AT2</b>						FWD	
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED</u>	<u>by CONED</u>	<u>03/10/2022</u>	(Import)	
0001	Continuous	2359				CONED - LIPA	<b>1250 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	250 MW
						TTC with All Lines In Service	1500 MW
<b>SPRNBK_-EGRDNCTR_345_Y49</b>						FWD	
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED</u>	<u>by CONED</u>	<u>03/10/2022</u>	(Import)	
0001	Continuous	2359				CONED - LIPA	<b>775 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	725 MW
						TTC with All Lines In Service	1500 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>						FWD	REV
Mon 10/03/2022	to	Fri 10/21/2022	<u>UPDATED</u>	<u>by LI</u>	<u>01/07/2022</u>	(Import)	(Export)
1000	Continuous	1500				SCH - NPX_CSC	<b>0 MW</b> <b>0 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	330 MW 330 MW
						TTC with All Lines In Service	330 MW 330 MW
<b>EDIC____-N.SCTLND_345_14</b>						FWD	
Mon 10/10/2022	to	Mon 10/31/2022				(Import)	
0700	Continuous	1530				CENTRAL EAST - VC	<b>1670 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1305 MW
						TTC with All Lines In Service	2975 MW
<b>EDIC____-N.SCTLND_345_14 &amp; PORTER_-ROTTRDAM_230_30</b>						FWD	
Mon 10/10/2022	to	Mon 10/31/2022				(Import)	
0700		1530				CENTRAL EAST - VC	<b>1500 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	1475 MW
						TTC with All Lines In Service	2975 MW
<b>EDIC____-N.SCTLND_345_14 &amp; PORTER_-ROTTRDAM_230_31</b>						FWD	
Mon 10/10/2022	to	Mon 10/31/2022				(Import)	
0700		1530				CENTRAL EAST - VC	<b>1500 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	1475 MW
						TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_-DYSINGER\_345\_ND1

FWD

Mon 10/17/2022 to Fri 10/21/2022 UPDATED by NYPA 02/10/2022

(Import)

0500 Continuous 1700

DYSINGER EAST **2700 MW**

Impacts Total Transfer Capability 450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## PANNELL\_-CLAY\_345\_1

FWD

Mon 10/24/2022 to Fri 10/28/2022

(Import)

0700 Continuous 1530

WEST CENTRAL **1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

## HURLYAVE-ROSETON\_345\_303

FWD

Mon 10/24/2022 to Fri 11/04/2022 UPDATED by CH 04/13/2022

(Import)

0800 Continuous 1600

UPNY CONED **4100 MW**

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: CHGE

## MAINESBG-WATRCURE\_345\_30

FWD

Tue 10/25/2022 to Tue 10/25/2022

(Import)

0800 Daily 1500

SCH - PJ - NY **2200 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYSEG

## WATRCURE-OAKDALE\_345\_31

Thu 10/27/2022 to Thu 10/27/2022

0800 Daily 1500

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYSEG

## PANNELL\_-CLAY\_345\_2

FWD

Mon 10/31/2022 to Fri 11/04/2022

(Import)

0700 Continuous 1530

WEST CENTRAL **1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

## CLAY\_-EDIC\_345\_1-16

FWD

Tue 11/01/2022 to Thu 11/03/2022

(Import)

0600 Continuous 1900

OSWEGO EXPORT **4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## GILBOA\_\_-N.SCTLND\_345\_GNS-1

FWD

Tue 11/01/2022 to Tue 12/06/2022 UPDATED by NGRID 12/29/2021

(Import)

0700 Continuous 1900

CENTRAL EAST - VC **2520 MW**

Impacts Total Transfer Capability 455 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

## LEEDS\_\_\_\_345KV\_R94301

FWD

Tue 11/01/2022 to Tue 12/06/2022 UPDATED by NGRID 12/29/2021

(Import)

0700 Continuous 1900

UPNY CONED **3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

## MARCY\_\_-N.SCTLND\_345\_18

FWD

Tue 11/01/2022 to Tue 12/06/2022 UPDATED by NGRID 12/29/2021

(Import)

0700 Continuous 1900

CENTRAL EAST - VC **1470 MW**

Impacts Total Transfer Capability 1505 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

ARR: 19

## N.SCTLND-LEEDS\_\_\_\_345\_94

FWD

Tue 11/01/2022 to Tue 12/06/2022 UPDATED by NGRID 12/29/2021

(Import)

0700 Continuous 1900

CENTRAL EAST - VC **2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

## PORTER\_\_-ROTTRDAM\_230\_30 &amp; MARCY\_\_-N.SCTLND\_345\_18

FWD

Tue 11/01/2022 to Tue 12/06/2022

(Import)

0700 1900

CENTRAL EAST - VC **1300 MW**

Impacts Total Transfer Capability 1675 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

## PORTER\_\_-ROTTRDAM\_230\_31 &amp; MARCY\_\_-N.SCTLND\_345\_18

FWD

Tue 11/01/2022 to Tue 12/06/2022

(Import)

0700 1900

CENTRAL EAST - VC **1300 MW**

Impacts Total Transfer Capability 1675 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

## LINDN\_CG-LNDVFT\_\_\_\_345\_V-3022

FWD

REV

Tue 11/01/2022 to Fri 11/04/2022

(Import) (Export)

0800 Continuous 1500

SCH - PJM\_VFT **0 MW** **0 MW**

Impacts Total Transfer Capability 315 MW 315 MW

TTC with All Lines In Service 315 MW 315 MW

Work scheduled by: PJM

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**LEEDS\_\_\_-HURLYAVE\_345\_301**

FWD

Mon 11/07/2022 to Fri 12/09/2022

(Import)

0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MAI**

FWD

Wed 11/30/2022 to Wed 03/01/2023

(Import)

0700 Continuous 1100

Work scheduled by: NYPA

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

**CLAY\_\_\_-EDIC\_\_\_345\_1-16**

FWD

Fri 12/30/2022 to Sat 12/31/2022

(Import)

0600 Continuous 1900

Work scheduled by: NGrid

OSWEGO EXPORT

**4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

**FRASER\_\_\_345\_FRASER SVC**

FWD

Tue 01/03/2023 to Tue 02/28/2023

(Import)

0700 Continuous 1730

Work scheduled by: NYPA

UPDATEDby NYPA12/30/2021

CENTRAL EAST - VC

**2935 MW**

Impacts Total Transfer Capability 40 MW

TTC with All Lines In Service 2975 MW

**PLSNTVLY\_345KV\_RNS4**

FWD

Sat 04/01/2023 to Sat 04/01/2023

(Import)

0700 Continuous 0730

Work scheduled by: NGrid

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

**ATHENS\_\_\_-PLSNTVLY\_345\_91**

FWD

Sat 04/01/2023 to Sat 04/15/2023

(Import)

0700 Continuous 1900

Work scheduled by: NGrid

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

**PLSNTVLY\_345KV\_RNS4**

FWD

Sat 04/15/2023 to Sat 04/15/2023

(Import)

1830 Continuous 1900

Work scheduled by: NGrid

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PLSNTVLY\_345KV\_RNS5

FWD

Sun 04/16/2023 to Sun 04/16/2023

(Import)

0700 Continuous 0730

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

### LEEDS\_-PLSNTVLY\_345\_92

FWD

Sun 04/16/2023 to Sun 04/30/2023

(Import)

0700 Continuous 1900

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

### PLSNTVLY\_345KV\_RNS5

FWD

Sun 04/30/2023 to Sun 04/30/2023

(Import)

1830 Continuous 1900

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

### SHOR\_NPX-SHOREHAM\_138\_CSC

FWD

REV

Mon 05/01/2023 to Fri 05/05/2023

(Import) (Export)

0600 Continuous 1800

SCH - NPX\_CSC

0 MW

0 MW

Impacts Total Transfer Capability 330 MW 330 MW

TTC with All Lines In Service 330 MW 330 MW

Work scheduled by: LI

### SHOR\_NPX-SHOREHAM\_138\_CSC

FWD

REV

Mon 10/02/2023 to Fri 10/06/2023

(Import) (Export)

0600 Continuous 1800

SCH - NPX\_CSC

0 MW

0 MW

Impacts Total Transfer Capability 330 MW 330 MW

TTC with All Lines In Service 330 MW 330 MW

Work scheduled by: LI

### NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

FWD

Mon 10/09/2023 to Fri 10/13/2023

(Import)

0600 Continuous 1600

SCH - PJM\_NEPTUNE

0 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

### NEWBRDGE-DUFFYAVE\_345\_501

FWD

Mon 10/09/2023 to Fri 10/13/2023

(Import)

0600 Continuous 1600

SCH - PJM\_NEPTUNE

0 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

**NYISO TRANSFER LIMITATIONS**

Sunday ,April 17, 2022 to Tuesday ,October 17, 2023

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 7815MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NEWBRDGE\_345\_138\_BK\_1

FWD

Mon 10/09/2023 to Fri 10/13/2023

(Import)

0600 Continuous 1600

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

## NEWBRDGE\_345\_138\_BK\_2

FWD

Mon 10/09/2023 to Fri 10/13/2023

(Import)

0600 Continuous 1600

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI